


NASA/TM-2014-218314



# **Exploratory Study for Continuous-Time Parameter Estimation of Ankle Dynamics**

*Sunil L. Kukreja*  
*NASA Armstrong Flight Research Center*

*Richard D. Boyle*  
*NASA Ames Research Center*

---

May 2014

## NASA STI Program . . . in Profile

Since its founding, NASA has been dedicated to the advancement of aeronautics and space science. The NASA scientific and technical information (STI) program plays a key part in helping NASA maintain this important role.

The NASA STI Program operates under the auspices of the Agency Chief Information Officer. It collects, organizes, provides for archiving, and disseminates NASA's STI. The NASA STI Program provides access to the NASA Aeronautics and Space Database and its public interface, the NASA Technical Report Server, thus providing one of the largest collection of aeronautical and space science STI in the world. Results are published in both non-NASA channels and by NASA in the NASA STI Report Series, which includes the following report types:

- **TECHNICAL PUBLICATION.** Reports of completed research or a major significant phase of research that present the results of NASA programs and include extensive data or theoretical analysis. Includes compilations of significant scientific and technical data and information deemed to be of continuing reference value. NASA counterpart of peer-reviewed formal professional papers, but having less stringent limitations on manuscript length and extent of graphic presentations.
- **TECHNICAL MEMORANDUM.** Scientific and technical findings that are preliminary or of specialized interest, e.g., quick release reports, working papers, and bibliographies that contain minimal annotation. Does not contain extensive analysis.
- **CONTRACTOR REPORT.** Scientific and technical findings by NASA-sponsored contractors and grantees.


- **CONFERENCE PUBLICATION.** Collected papers from scientific and technical conferences, symposia, seminars, or other meetings sponsored or co-sponsored by NASA.
- **SPECIAL PUBLICATION.** Scientific, technical, or historical information from NASA programs, projects, and missions, often concerned with subjects having substantial public interest.
- **TECHNICAL TRANSLATION.** English- language translations of foreign scientific and technical material pertinent to NASA's mission.

Specialized services also include creating custom thesauri, building customized databases, and organizing and publishing research results.

For more information about the NASA STI Program, see the following:

- Access the NASA STI program home page at <http://www.sti.nasa.gov>
- E-mail your question via the Internet to [help@sti.nasa.gov](mailto:help@sti.nasa.gov)
- Fax your question to the NASA STI Help Desk at 443-757-5803
- Phone the NASA STI Help Desk at 443-757-5802
- Write to:  
NASA STI Help Desk  
NASA Center for AeroSpace Information  
7115 Standard Drive  
Hanover, MD 21076-1320

NASA/TM-2014-218314



# Exploratory Study for Continuous-Time Parameter Estimation of Ankle Dynamics

*Sunil L. Kukreja*  
*NASA Armstrong Flight Research Center*

*Richard D. Boyle*  
*NASA Ames Research Center*

National Aeronautics and  
Space Administration

NASA Armstrong Flight Research Center, Edwards, California 93524-0001

---

May 2014

The use of trademarks or names of manufacturers in this report is for accurate reporting and does not constitute an official endorsement, either expressed or implied, of such products or manufacturers by the National Aeronautics and Space Administration.

Available from:

NASA Center for AeroSpace Information  
7115 Standard Drive  
Hanover, MD 21076-1320  
443-757-5802

## **Abstract**

Recently, a parallel pathway model to describe ankle dynamics was proposed. This model provides a relationship between ankle angle and net ankle torque as the sum of a linear and nonlinear contribution. A technique to identify parameters of this model in discrete-time has been developed. However, these parameters are a nonlinear combination of the continuous-time physiology, making insight into the underlying physiology impossible. The stable and accurate estimation of continuous-time parameters is critical for accurate disease modeling, clinical diagnosis, robotic control strategies, development of optimal exercise protocols for longterm space exploration, sports medicine, etc.

This paper explores the development of a system identification technique to estimate the continuous-time parameters of ankle dynamics. The effectiveness of this approach is assessed via simulation of a continuous-time model of ankle dynamics with typical parameters found in clinical studies. The results show that although this technique improves estimates, it does not provide robust estimates of continuous-time parameters of ankle dynamics. Due to this we conclude that alternative modeling strategies and more advanced estimation techniques be considered for future work.

# Nomenclature

## Acronyms

IRF- Impulse Response Function  
NARMAX- Nonlinear AutoRegressive, Moving Average eXogenous  
ELS - Extended Least-Squares  
PEI - Prediction Error Identification  
SLS - Standardized Least-Squares  
PRBS - Pseudo-Random Binary Sequence  
SNR - Signal-to-Noise Ratio  
NF - Noise-Free  
CT - Continuous-Time  
FIR - Finite Impulse Response  
IIR - Infinite Impulse Response  
LTI - Linear Time Invariant

## Symbols

$\mathcal{F}^l$  - nonlinear mapping  
 $u$  - exogenous input  
 $z$  - output  
 $e$  - innovation, or uncontrolled input  
 $n$  - sample index point  
 $l$  - maximum polynomial order  
 $n_z$  - maximum output lag  
 $n_u$  - maximum input lag  
 $n_e$  - maximum error (innovation) lag  
 $I$  - inertia  
 $B$  - viscosity  
 $K$  - elasticity  
 $\Delta$  - reflex time delay  
 $\zeta$  - damping parameter  
 $\omega$  - natural frequency  
 $g$  - gain  
 $c_0$  - zeroth-order coefficient of polynomial nonlinearity  
 $c_1$  - first-order term coefficient of polynomial nonlinearity  
 $c_2$  - second-order term coefficient of polynomial nonlinearity  
 $s$  - Laplace variable  
 $U(s)$  - ankle angle  
 $V(s)$  - ankle velocity  
 $V(s)e^{-\Delta s}$  - delayed ankle velocity  
 $X(s)$  - output of half-wave rectifier  
 $Y_L(s)$  - noise-free linear path output  
 $Y_{NL}(s)$  - noise-free nonlinear path output  
 $Y(s)$  - noise-free net torque

$E(s)$  - measurement noise  
 $\theta_0 - \theta_{11}$  - discrete-time coefficients of ankle dynamics model  
 $\tau$  - discrete-time delay  
 $v(n)$  - terms of discrete-time ankle model associated with nonlinear polynomial coefficient  $c_1$   
 $\chi(n)$  - terms of discrete-time ankle model associated with nonlinear polynomial coefficient  $c_2$   
 $T$  - sampling rate  
 $\hat{\epsilon}$  - prediction errors  
 $\mathbb{R}$  - set of real numbers  
 $N$  - data length  
 $\mathbf{Z}$  - vector of measured outputs  
 $\hat{\mathbf{Z}}$  - vector of predicted outputs  
 $\hat{\theta}$  - extended least-squares estimate of the system parameters  
 $p$  - number of system parameters  
 $\Psi$  - partitioned regressor matrix  
 $\Psi_{zu}$  - regressor matrix that is a function of  $z$  and  $u$  only  
 $\Psi_{zu\hat{\epsilon}}$  - regressor matrix that represents all the cross products involving  $\hat{\epsilon}$   
 $\Psi_{\hat{\epsilon}}$  - regressor matrix that is a polynomial function of the prediction errors  
 $\tilde{\Psi}$  - centered and standardized variate of  $\Psi$   
 $\tilde{\mathbf{Z}}$  - centered and standardized variate of  $\mathbf{Z}$   
 $\Sigma_{\Psi}$  - diagonal matrix of standard deviations  
 $\Sigma_{\Psi_k}$  - standard deviation of the  $k$ th column of  $\Psi$   
 $\mu_{\Psi}$  - matrix who's  $k$ th column has all entries equal to the mean of column  $k$  of  $\Psi$   
 $\tilde{\theta}$  - centered and standardized system parameters  
 $\min_{\tilde{\theta}} \frac{1}{2} \left\| \left( \tilde{\mathbf{Z}} - \tilde{\Psi} \tilde{\theta} \right) \right\|_2^2$  - standardized least-squares objective function  
 Hz - Hertz  
 ms - millisecond  
 dB - decibel

# 1 Introduction

In a zero or low-g environment it is critical to keep astronauts healthy and functional. To maintain bone and muscle mass, astronauts need to exercise everyday [1]. Under terrestrial 1-g conditions gravity works against muscles and bones, which requires the neuromuscular system to maintain enough muscle and bone mass to support body weight. In an altered gravity-inertial environment the forces of gravity are significantly reduced. As a result, astronauts lose muscle mass and bone density since it is not required to support body weight [2].

Under current technological limitations (e.g. lack of artificial gravity through inertial forces), rigorous physical activity is the only successful way to compensate for the lack of gravity [2]. Nevertheless, even with rigorous exercise, astronauts have typically lost 0.4-1% of their bone density per month in space [3]. Upon return to Earth, with a thorough physical therapy regime astronauts progressively recover muscle tissue and much of the bone mass lost during a semi-long duration (i.e. 4-6 months) in low Earth orbit. However, throughout the mission span it is important that astronauts are strong enough to perform strenuous activities in space, such as spacewalks and emergency procedures during landing. Due to these possible vital mission activities, a regular exercise routine in orbit prepares astronaut for such situations and accelerates a reconditioning period to recover muscle and bone loss.

A parallel pathway model of ankle dynamics has been proposed that measures changes to intrinsic, reflex and muscle properties [4]. These characteristics change, for example, due to a lack of effective exercise. Therefore, astronaut health and exercise effectiveness can be monitored in orbit by evaluating deviations of these parameters from optimal pre-orbit measures. In this work, we propose to use this parallel pathway model as a foundation to assess lower limb health during orbit to maintain an optimal exercise program.

Traditional approaches to nonlinear system identification of human ankle dynamics have relied on quasi-linear methods, e.g. impulse response function (IRF) method [5]. These methods provide convenient, robust means of characterizing the dynamics of nonlinear systems without requiring a priori assumptions regarding the system structure. However, nonparametric techniques may require many parameters to describe even simple systems and can be difficult to relate to the parameters of the underlying physiological system.

The NARMAX (Nonlinear AutoRegressive, Moving Average eXogenous) model structure has been shown to be well suited to modeling the input-output behavior of ankle dynamics [6]. The unknown model parameters can be estimated in discrete-time using the extended least-squares (ELS) algorithm [7–9]. However, discrete-time parameters are a nonlinear combination of the continuous-time physiology, making insight into the underlying mechanisms difficult. The primary objective of biological system identification is to provide parameters that give insight and relevance to the underlying biology, which are represented in continuous-time.

The problem of continuous-time system identification from sampled input-



output data can be divided into two broad approaches: (i) indirect methods, where a discrete-time model is estimated from sampled data; then an equivalent continuous-time model is calculated and (ii) direct methods, where a continuous-time model is obtained directly without going through the intermediate step of first determining a discrete-time model; based on concepts of approximate numerical integration to recreate time-derivatives needed in continuous-time formulations [10].

The central problem for indirect methods is that of estimating stable and robust continuous-time parameters from discrete-time estimates. For both linear and nonlinear systems, the inverse mapping problem often results in large bias or sign flips. To address these issues several indirect techniques have been developed to modify the estimators, keeping the computational complexity low [11–13]. In addition, a method for estimating the natural logarithm of a square matrix to map discrete-time parameters to continuous-time has been proposed [14]. Most other procedures are variants of these two approaches.

Direct methods avoid the inverse mapping problem by identifying a continuous-time model directly from sampled data. This raises several technical issues. Unlike a difference equation model, a differential equation model contains time-derivative terms that may be required but not available from measurements. Many techniques have been devised to deal with the need to reconstruct these time-derivatives (see e.g. [10, 15–17]). However, these approaches are challenged by a lack of robust implementation for numerical computation of derivatives, selection of filter cutoffs to suppress high frequency noise, filter order, etc. These problems are more complex when the system under study is nonlinear, which is inherently the case for biological systems.

We propose to investigate the problem of continuous-time system identification by developing methodology using an indirect approach. One such approach relies on matrix preconditioning techniques, such as standardized least-squares, to improve the spectral properties of the regressor matrix [18, 19]. The transformed matrix will have a smaller spectral condition number, and eigenvalues clustered around one. Often when the clustered spectrum is away from zero it results in rapid and robust convergence, especially when the preconditioned matrix is close to normal. We deem this will provide more robust solutions and greater consistency for nonlinear biological systems by circumventing issues of implementing numerical derivatives and filter selection required by direct techniques, which are more challenging in a nonlinear framework. Here, we focus on one critical issue, namely, that of mapping the underlying continuous-time system to discrete-time for estimation, then inverse mapping back to continuous-time to provide physiological relevance and insight.

The organization of this paper is as follows. The NARMAX model structure is described in section 2. Section 3 discusses a continuous-time representation of a parallel pathway model describing ankle dynamics and its NARMAX representation. In Section 4 we summarize the parameter estimation method implemented in this study, namely, extended least-squares. Section 5 shows how to standardized the identification data to formulate a standardized least-squares approach, which we investigate for its utility as an indirect technique

to estimate continuous-time parameters of ankle dynamics. Section 6 illustrates the results of our proposed approach on a simulated ankle model. Section 7 provides a discussion of our findings and suggestions for future direction. Section 8 summarizes the conclusions of our study.

## 2 NARMAX Model Description

The input-output relationship of many nonlinear dynamic systems can be written as the nonlinear difference equation

$$z(n) = \mathcal{F}^l[z(n-1), \dots, z(n-n_z), u(n), \dots, u(n-n_u), e(n-1), \dots, e(n-n_e)] + e(n) \quad (1)$$

where  $\mathcal{F}^l$  is a nonlinear mapping,  $u$  is the exogenous input,  $z$  is the output, and  $e$  is the innovation, or uncontrolled input. This structure describes both the stochastic and deterministic components of a system. This nonlinear mapping may include a variety of nonlinear terms, such as terms raised to an integer power (e.g.  $u^2(n-3)$ ), products of present and past inputs (e.g.  $u(n)u(n-1)$ ), past outputs (e.g.  $z(n-1)z(n-2)$ ), or cross-terms (e.g.  $u^2(n-1)z(n-2)$ ). This system description encompasses most forms of nonlinear difference equations that are linear-in-the-parameters.

## 3 Parallel Pathway Model of Ankle Dynamics

The Neuromuscular Control Laboratory (Department of Biomedical Engineering, McGill University, Montréal Canada), has developed a parallel pathway model (Fig. 1) to describe ankle dynamics [4]. This model provides a relationship between ankle angle (rad) and net ankle torque (Nm) as the sum of a linear and nonlinear contribution. The upper, linear pathway models intrinsic stiffness as a second-order system with parameters corresponding to inertia ( $I$ ), viscosity ( $B$ ) and elasticity ( $K$ ). The lower, nonlinear pathway models reflex stiffness as a cascade of a derivative, a reflex time delay, a static nonlinearity (i.e. half-wave rectifier) and a low-pass system representing muscle activation. The parameters associated with the low-pass system are damping parameter ( $\zeta$ ), natural frequency ( $\omega$ ) and gain ( $g$ ). This model is ideally suited to study the effects of exercise (in space) because it quantifies both the intrinsic and reflex stiffness components. The parameters of these two paths will deviate from normal a priori terrestrial measurements due to a suboptimal exercise regime. A method to monitor changes of these parameters could be used to develop individualized exercise protocols for astronauts.

Kukreja *et al.* [6] showed that a second-order static polynomial ( $c_0 + c_1x(n) + c_2x^2(n)$ ) provided a good approximation to the half-wave rectifier which gave




Figure 1. Continuous-time morphological model describing ankle dynamics. Upper (linear) path: intrinsic stiffness. Lower (nonlinear) path: reflex stiffness.

a NARMAX representation for this model of ankle dynamics as

$$\begin{aligned}
z(n) &= \theta_0 + \theta_1 z(n-1) + \theta_2 z(n-2) + \theta_3 u(n) + \theta_4 u(n-1) + \theta_5 u(n-2) + \theta_6 u(n-3) \\
&+ \theta_7 u(n-4) + \theta_8 [u(n-\tau) + u(n-\tau-1) - u(n-\tau-2) - u(n-\tau-3)] \\
&+ \theta_9 [u^2(n-\tau) + 3u^2(n-\tau-1) + 3u^2(n-\tau-2) + u^2(n-\tau-3)] \\
&- 2u(n-\tau)u(n-\tau-1) - 4u(n-\tau-1)u(n-\tau-2) - 2u(n-\tau-2)u(n-\tau-3)] \\
&+ \theta_{10} e(n-1) + \theta_{11} e(n-2) + e(n) \\
&= \theta_0 + \theta_1 y(n-1) + \theta_2 y(n-2) + \theta_3 u(n) + \theta_4 u(n-1) + \theta_5 u(n-2) + \theta_6 u(n-3) \\
&+ \theta_7 u(n-4) + \theta_8 v(n) + \theta_9 \chi(n) + \theta_{10} e(n-1) + \theta_{11} e(n-2) + e(n)
\end{aligned}$$

where  $\tau$  is the discrete-time delay,

$$v(n) = u(n-\tau) + u(n-\tau-1) - u(n-\tau-2) - u(n-\tau-3) \quad (3)$$

and

$$\begin{aligned}
\chi(n) &= u^2(n-\tau) + 3u^2(n-\tau-1) + 3u^2(n-\tau-2) + u^2(n-\tau-3) \\
&- 2u(n-\tau)u(n-\tau-1) - 4u(n-\tau-1)u(n-\tau-2) \\
&- 2u(n-\tau-2)u(n-\tau-3).
\end{aligned} \quad (4)$$

Table 1 gives the relationships of these discrete-time NARMAX parameters (Eqn. 2) to the underlying continuous-time coefficients (the “extra” coefficient  $T$  denotes the sampling rate). An estimate of unknown system parameters can be obtained using standard prediction error identification (PEI) techniques, such as extended least-squares.

NARMAX Coefficient	Relationship to Continuous-time Coefficient
$\theta_0$	$\frac{4c_0g\omega^2T^2}{4+\omega^2T^2+4\zeta\omega T}$
$\theta_1$	$-\frac{-8+2\omega^2T^2}{4+\omega^2T^2+4\zeta\omega T}$
$\theta_2$	$-\frac{-4\zeta\omega T+4+\omega^2T^2}{4+\omega^2T^2+4\zeta\omega T}$
$\theta_3$	$\frac{I}{T^2} + \frac{B}{T} + K$
$\theta_4$	$(\frac{-2I}{T^2} - \frac{B}{T}) - ((-\frac{-8+2\omega^2T^2}{4+\omega^2T^2+4\zeta\omega T})(\frac{I}{T^2} + \frac{B}{T} + K))$
$\theta_5$	$(\frac{I}{T^2}) - ((-\frac{-8+2\omega^2T^2}{4+\omega^2T^2+4\zeta\omega T})(\frac{-2I}{T^2} - \frac{B}{T})) - ((-\frac{-4\zeta\omega T+4+\omega^2T^2}{4+\omega^2T^2+4\zeta\omega T})(\frac{I}{T^2} + \frac{B}{T} + K))$
$\theta_6$	$-((-\frac{-8+2\omega^2T^2}{4+\omega^2T^2+4\zeta\omega T})(\frac{I}{T^2}) - ((-\frac{-4\zeta\omega T+4+\omega^2T^2}{4+\omega^2T^2+4\zeta\omega T})(\frac{-2I}{T^2} - \frac{B}{T})))$
$\theta_7$	$-((-\frac{-4\zeta\omega T+4+\omega^2T^2}{4+\omega^2T^2+4\zeta\omega T})(\frac{I}{T^2}))$
$\theta_8$	$\frac{g\omega^2T^2c_1}{(4+\omega^2T^2+4\zeta\omega T)T}$
$\theta_9$	$\frac{g\omega^2T^2c_2}{(4+\omega^2T^2+4\zeta\omega T)T^2}$

Table 1. Theoretical relationship of NARMAX model parameters to continuous-time system coefficients.

## 4 Parameter Estimation

Many parameter estimation techniques are based on least-squares theory. However, ordinary least-squares algorithms for linear systems cannot be applied here because they assume that the noise terms in the model are independent and the regressor matrix is deterministic [20]. Both of these conditions are violated in Eqn. 2, when one considers that only a noisy measure of the output is available.

Clearly, the regressors in Eqn. 2 contain correlated error terms and noisy data. To obtain unbiased parameters other estimation techniques based on least-squares must be used. One such method that is applicable to NARMAX model estimation is extended least-squares. This technique provides unbiased parameter estimates and is iterative [19, 21, 22].

### 4.1 Extended Least-Squares

Extended least-squares is one method, appropriate for NARMAX models that easily enables unbiased estimates to be computed. ELS addresses the bias problem by modeling the lagged errors to obtain unbiased parameter estimates. ELS for linear systems has been widely studied and is also referred to as Panuska's method, the extended matrix method, or approximate maximum likelihood [7–9].

In general, since the noise sequence is a realization of a stochastic process, it is not possible to solve for the noise source  $e$ , and it will not be equal to the

prediction errors [23]. The prediction errors,  $\hat{\varepsilon} \in \mathbb{R}^{N \times 1}$ , are defined as

$$\hat{\varepsilon} = \mathbf{Z} - \hat{\mathbf{Z}} \quad (5)$$

where  $\mathbf{Z} \in \mathbb{R}^{N \times 1}$  is the measured output and  $\hat{\mathbf{Z}} = \Psi \hat{\theta} \in \mathbb{R}^{N \times 1}$  is the predicted output. In ELS, the NARMAX formulation of Eqn. 1 is redefined into a prediction error model by replacing  $e$  with  $\hat{\varepsilon}$ ; making it a deterministic least-squares problem.

The ELS formulation is defined as

$$\hat{\theta} = (\Psi^T \Psi)^{-1} \Psi^T \mathbf{Z}; \quad \text{where } \Psi = [\Psi_{zu} \Psi_{zu\hat{\varepsilon}} \Psi_{\hat{\varepsilon}}]. \quad (6)$$

$\hat{\theta} \in \mathbb{R}^{p \times 1}$  is an ELS estimate of the system parameters,  $\Psi \in \mathbb{R}^{N \times p}$  is a partitioned regressor matrix where  $\Psi_{zu}$  is a function of  $z$  and  $u$  only,  $\Psi_{zu\hat{\varepsilon}}$  represents all the cross products involving  $\hat{\varepsilon}$ , and  $\Psi_{\hat{\varepsilon}}$  is a polynomial function of the prediction errors only [23].

Often, ELS is considered a pseudolinear approach to parameter estimation [7,9,24]. Strictly speaking, the introduction of prediction errors into the model formulation no longer makes the model linear-in-the-parameters because the prediction errors depend on the model output, which is a function of all model parameters. The ELS technique solves a nonlinear optimization problem by ignoring the nonlinear character of the model and employing a least-squares approach. Essentially, ELS uses an approximate gradient of the model output with respect to the model parameters as a regression vector.

## 5 Standardized Least-Squares

In many nonlinear systems there are large numerical differences of the regressors due to the basis function(s) used to estimate the static map. The large differences lead to the regressor matrix being ill-conditioned and results in unstable matrix inversion and poor parameter estimates [25]. To alleviate ill-conditioning we propose using standardized least-squares (SLS). The SLS technique is summarized as follows.

Given a matrix of independent variables  $\Psi$  and of dependent variables  $\mathbf{Z}$  compute the mean and standard deviation of each variable and replace  $\Psi$  and  $\mathbf{Z}$  with the centered and standardized variate as

$$\tilde{\Psi} = (\Psi - \mu_{\Psi}) \Sigma_{\Psi}^{-1} \quad \text{and} \quad \tilde{\mathbf{Z}} = (\mathbf{Z} - \mu_{\mathbf{Z}}) \Sigma_{\mathbf{Z}}^{-1} \quad (7)$$

where  $\Sigma_{\Psi}$  is a diagonal matrix of standard deviations with  $\Sigma_{\Psi_k}$  denoting the standard deviation of the  $k$ th column of  $\Psi$  and  $\mu_{\Psi}$  is a matrix whose  $k$ th column has all entries equal to the mean of column  $k$  of  $\Psi$ . Substituting Eqn. 7 into 6 yields a SLS formulation. The SLS objective function is compactly expressed as

$$\min_{\hat{\theta}} \frac{1}{2} \left\| \left( \tilde{\mathbf{Z}} - \tilde{\Psi} \hat{\theta} \right) \right\|_2^2. \quad (8)$$

This is an unbiased estimator and converges asymptotically to the true system parameters.

## 6 Simulations

The efficacy of the SLS ELS technique was assessed to provide stable estimates of continuous-time parameters describing ankle dynamics by simulating the parallel pathway model in continuous-time using Simulink (Fig. 1). The inputs were bandlimited 30 Hz pseudo-random binary sequences (PRBS) which were 0.02 rad (peak-to-peak) and had a 35 ms switching rate. A PRBS input was used to excite the system dynamics since it is standard practice in experimental settings. The continuous-time coefficients used in this study correspond to values found in experiments and are shown in Table 2. One thousand Monte-

CT Coefficient	Value
$I$	0.015 Nm/rad/s <sup>2</sup>
$B$	0.8 Nm/rad/s
$K$	150 Nm/rad
$\omega$	40.0
$\zeta$	1.00
$g$	10.00 Nm/rad/s
$\Delta$	0.045 s
$T$	0.005 s

Table 2. Continuous-time coefficient values.  $I$ : inertia,  $B$ : viscosity,  $K$ : elasticity,  $\omega$ : natural frequency,  $\zeta$ : damping parameter,  $g$ : reflex stiffness gain,  $\Delta$ : reflex delay and  $T$ : sampling interval.

Carlo simulations were generated in which each input-output realization was unique, and had a unique Gaussian, white, zero-mean, noise sequence added to the output. Excluding the noise-free (NF) case the signal-to-noise ratio (SNR) of the noise sequence was decreased from 20 to 0 dB in increments of 5 dB. For identification, the data length was  $N = 4,000$  points.

### 6.1 Continuous-Time Parameter Estimation

The system parameters were estimated as outlined in Eqns. 6 – 8. Specifically, for each input-output realization, we analyzed the ankle dynamics model as follows:

1. *Non-Standardized Extended Least-Squares*: Ankle dynamics were analyzed using the ELS estimator.
2. *Standardized Extended Least-Squares*: Ankle dynamics were analyzed using the ELS estimator and standardized data.

Fig. 2 shows a typical input-output realization used for this analysis. Employing our approach, continuous-time parameters were computed from discrete-time NARMAX estimates using the theoretical relationships given in Table 3.




Figure 2. Typical PRBS ankle position input and torque output with 20 dB SNR used for Monte-Carlo analysis.

CT Coefficient	DT Relationship
$I =$	$\theta_7 \times \frac{T^2}{-\theta_2}$
$B =$	$\frac{\theta_6 + \theta_1 \frac{I}{T^2}}{-\theta_2} = -\left(\frac{2I}{T^2} + \frac{B}{T}\right) + \frac{2I}{T^2} = -\frac{B}{T} \times -T$
$K =$	$\theta_3 - \left(\frac{I}{T^2} + \frac{B}{T}\right)$
$\omega =$	$\frac{-4 + 4\theta_2 + 4\theta_1}{-1 + \theta_2 - \theta_1} = \sqrt{(\omega^2 T^2)} \times \frac{1}{T^2}$
$\zeta =$	$\frac{-2 - 2\theta_2}{-1 + \theta_2 - \theta_1} = \frac{\zeta \omega T}{\omega T}$
$g =$	$\theta_8 \times (4 + \omega^2 T^2 + 4\zeta \omega T) \times T = \frac{g c_1 \omega^2 T^2}{c_1 \omega^2 T^2}$

Table 3. Discrete to continuous-time relationships for parameters I, B, K,  $\omega$ ,  $\zeta$  and g of the parallel pathway ankle model.

The results of this study are presented in Fig. 3. The panels show plots of standard deviation about the mean for estimated continuous-time parameters of the linear and nonlinear paths ( $I$ ,  $B$ ,  $K$ ,  $g$ ,  $\omega$  and  $\zeta$ ) using the non-standardized and standardized ELS identification techniques. Column one shows the linear path parameters. The continuous-time estimates using non-standardized ELS and relationships given in Table 3 provided a mean value that was close to the true parameter and had monotonically increasing variance from 20-10 dB SNR. However, with decreasing SNR (5-0 dB) the parameter mean was biased away from the true with non-monotonically increasing variance that included estimates with incorrect sign. Using standardized data with the ELS algorithm, mean and variance estimates for the linear path parameters improved for all SNR levels but experienced a similar non-monotonically increasing variance for 5-0 dB SNR and encompassed values with opposite sign. Column two represents the nonlinear path estimates. Applying non-standardized and standardized ELS to the nonlinear path illustrates that both approaches gave similar results. For the damping ( $\zeta$ ) and gain ( $g$ ) parameters standardized data provided estimate that were worse than non-standardized data. The natural frequency ( $\omega$ ) estimates were moderately improved using standardized data. Results show that, for the linear path, the parameters were close to the true mean but variance estimate was non-monotonic and included estimates with incorrect sign for low SNR levels. However, for the nonlinear path, continuous-time parameters computed using both approaches were significantly biased from the true mean for all SNR levels but did not include parameter estimates with incorrect sign.

## 7 Discussion

In this section, we summarize the findings of this study and discuss possible future approaches. The discussion highlights major features of our approach and offers possible explanations for the unexpected errors. The suggestion for future direction provided two broad alternatives to our solution, namely, an alternative identification strategy and discretization approach.

### 7.1 Continuous-Time Parameter Estimation

Estimation of continuous-time parameters of ankle dynamics demonstrates that, with noise-free input and output the both the ELS and SLS ELS approaches provided estimates that agree with the true known values. However, with output additive noise the linear path parameter estimates had non-monotonically increasing variance and encompassed values with opposite sign (see column 1, Fig. 3). For the nonlinear path, the parameters were biased and the standard deviation did not encompass the true value (see column 2, Fig. 3). Although the nonlinear path parameters were biased, they did not experience sign flips as the linear path parameters did.

The reason for the parameter bias may be due to the opposing nature of






Figure 3. Non-standardized and standardized ELS approaches to continuous-time parameter estimation of ankle dynamics. Column 1: Linear path parameters,  $I, B, K$ . Column 2: Nonlinear path parameters,  $\zeta, \omega, g$ . Ordinate: STD about mean. Abscissa: Output SNR = NF, 20, 15, 10, 5, 0 dB, where NF denotes noise-free case. (Note that the abscissa is shown in decreasing SNR which corresponds to increasing noise amplitude.)

the two paths. The linear path is described by a finite impulse response (FIR) system, which has theoretical poles close to the Nyquist frequency; requiring a high frequency signal to excite the dynamics sufficiently. The nonlinear path is described by a combination of a nonlinear static function and linear dynamics. The nonlinear function is described as a half-wave rectifier. This is considered a hard nonlinearity because it generates multiple harmonics and its output cannot be written analytically. To limit the effect of higher order harmonics and avoid internal aliasing at the nonlinearity output the input signal was bandlimited to be of low frequency. The opposing requirements of the two paths are central to this estimation problem and difficult to satisfy simultaneously. It is not possible to make more definitive comments about this approach without further detailed investigation and analysis. Below we outline a few alternative approaches to solve this identification problem.

## **7.2 Closed-Loop Simulation**

A possible solution to continuous-time parameter estimation for ankle dynamics is to identify the model in closed-loop, removing the effects of derivatives (FIR realization of the linear path). In feedback, intrinsic stiffness is represented as a compliance model (pure infinite impulse response (IIR) realization). Although it may be possible to pose the identification problem as a feedback model, the true system is represented from position input to torque output. The recorded output torque has observation noise associated with it. When identifying the model in feedback the noisy output is considered the input. Noise on the input violates assumptions and conditions for least-squares to yield unbiased parameter estimates. Implementing a feedback identification approach may require advanced methods such as total-least squares [26, 27].

## **7.3 Discrete to Continuous-Time Parameter Mapping**

Another possibility for the source of error for continuous-time parameters computed using our NARMAX approach may be related to the nonlinear relationships between discrete-time NARMAX parameters and continuous-time parameters of the physical system (see Table 3). A small deviation from the true parameter value in discrete-time, due to noise or numerical error, may appear as a significant error in the estimated continuous-time coefficients. As a result it may be advantageous to study these model parameters only in discrete-time as a combination of physiological effects.

## **7.4 Continuous to Discrete-Time Transformations**

To derive a NARMAX model formulation the bilinear transform and Newton's backwards formula were used to convert the continuous-time linear dynamics to discrete-time. These transforms were implemented since both require only a simple substitution to convert a continuous-time system to discrete-time. Two other techniques that give better approximation for linear time invariant

(LTI) systems are linear extrapolation and linear interpolation methods [28,29]. However, these techniques are seldom used due to added complexity for little gain.

Linear extrapolation gives an improper transfer function (i.e. more zeros than poles) and linear interpolation gives a transfer function that is strictly proper (i.e. equal zeros and poles) [28,29]. These methods produce a discrete-time transfer function that gives a better output response than the bilinear transform or Newton's backwards formula. However, the pitfall of these methods is that it is difficult to derive the coefficients of the discrete-time linear system. This is the main reason that almost all engineering text books and literature only discussed the bilinear transform and Newton's backwards formula.

Using linear interpolation or linear extrapolation to derive a NARMAX representation of ankle dynamics it may be possible to derive a better approximation to the derivative than the one used i.e. Newton's backwards formula. This may give a better approximation to the derivative and provide simulation data that matches the continuous-time process better. However, one drawback is that it may give a discrete-time approximation to the derivative that is higher than first order thereby increasing the complexity of the NARMAX representation [28,29]. Another limitation is that the continuous to discrete mapping of the continuous-time parameters will be more complicated since it involves exponential functions. This may result in more sensitivity for continuous-time parameter estimation since small deviations from the true value in discrete-time will result in large errors in continuous-time.

## 8 Conclusions

Clearly, much work remains to be done to resolve the possible source(s) of error for continuous-time parameter estimation for the model of ankle dynamics. Our results show that the proposed standardized extended least-squares method provided some improvement for estimating the continuous-time parameters of the linear path. However, the parameter variance was too high because it included parameters with incorrect sign. For the nonlinear path, this technique did not offer any improvement over the non-standardized extended least-squares approach. A possible explanation for these results is due to opposing constraints needed to properly excite the dynamics of both paths simultaneously. The linear path requires a high frequency signal while the nonlinear path needs low frequency. It is unclear how to satisfy both concurrently. It is not possible to make more definitive remarks about the root of this error and remains an open research question. We have offered several suggestions for alternative ways forward to estimate the continuous-time parameters of the parallel pathway model of ankle dynamics. Of these, we deem that identifying this model in closed loop and implementing more advanced estimation techniques such as total least-squares is likely the best way forward.

## References

1. V. Convertino, "Exercise as a countermeasure for physiological adaptation to prolonged spaceflight," *Medicine & Science in Sports & Exercise*, vol. 28, no. 8, pp. 999–1014., 1972.
2. K. Baldwin, T. White, S. Arnaud, V. Edgerton, W. Kraemer, R. Kram, D. Raab-Cullen, and C. Snow, "Musculoskeletal adaptations to weightlessness and development of effective countermeasures," *Medicine & Science in Sports & Exercise*, vol. 28, no. 10, pp. 1247–1253, 1996.
3. J. Iwamoto, T. Takeda, and Y. Sato, "Interventions to prevent bone loss in astronauts during space flight," *Keio Journal of Medicine*, vol. 54, no. 2, pp. 55–59, 2005.
4. R. Kearney, R. Stein, and L. Parameswaran, "Identification of intrinsic and reflex contributions to human ankle stiffness dynamics," *IEEE Trans. Biomed. Eng.*, vol. 44, no. 6, pp. 493–504, 1997.
5. R. Kearney and I. Hunter, "System identification of human joint dynamics," *Critical Reviews in Biomedical Engineering*, vol. 18, no. 1, pp. 55–87, 1990.
6. S. Kukreja, H. Galiana, and R. Kearney, "NARMAX representation and identification of ankle dynamics," *IEEE-TBME*, vol. 50, no. 1, pp. 70–81, 2003.
7. V. Panuska, "A stochastic approximation method for identification of linear systems using adaptive filtering," in *Proceedings 9th Joint Automatic Control Conference*. Ann Arbor, MI, USA: IEEE, June 1968, pp. 1014–1021.
8. ———, "An adaptive recursive least squares identification algorithm," in *Proceedings 8th IEEE Symp. on Adaptive Processes*, University Park, PA, USA, Nov. 1969, p. paper 6e.
9. P. Young, "The use of linear regression and relaxed procedures for the identification of dynamic processes," in *Proceedings 7th IEEE Symp. on Adaptive Processes*, Los Angeles, CA, USA, Dec. 1968, pp. 501–505.
10. E. D. Sontag, in *Identification of continuous-time systems. Methodology and computer implementation*, N. Sinha and G. Rao, Eds. Kluwer Academic Publishers, 1991.
11. E. K. Larsson and T. Söderström, "Continuous-time ar parameter estimation by using properties of sampled systems," in *Proceedings 15th IFAC World Congress*, vol. 15, Barcelona, Spain, July 2002.
12. H. Fan, T. Söderström, M. Mossberg, B. Carlsson, and Y.Zou, "Estimation of continuous-time ar process parameters from discrete-time data," *IEEE Transactions on Signal Processing*, vol. 47, no. 5, pp. 1232–1244, 1999.

13. T. Söderström, H. Fan, B. Carlsson, and S. Bigi, "Least squares parameter estimation of continuous-time arx models from discrete-time data," *IEEE Transactions on Automatic Control*, vol. 42, no. 5, pp. 659–673, 1997.
14. G.J.Lastman and N. Sinha, "Continuous-time model identification from sampled data. implementation issues and performance evaluation," *Electronics Letters*, vol. 27, no. 16, pp. 1468–1469, 1991.
15. H. Garnier, M. Mensler, and A. Richard, "Infinite series for logarithm of a matrix, applied to identification of continuous-time multivariable systems from discrete-time models," *International Journal of Control*, vol. 76, no. 13, pp. 1337–1357, 2003.
16. P. Young, H. Garnier, and A. Jarvis, "The identification of continuous-time linear and nonlinear models: a tutorial with environmental applications," in *13th IFAC Symposium on System Identification (SYSID2003)s*, vol. 13, Rotterdam, The Netherlands, August 2003, pp. 618–628.
17. Unbehauen and G. Rao, "A review of identification in continuous-time systems," *Annual reviews in Control*, vol. 22, pp. 145–171, 1998.
18. L. N. Trefethen and D. Bau, *Numerical Linear Algebra*. Philadelphia, PA: SIAM, 1997.
19. L. Ljung, *System Identification: Theory for the User*, 2nd ed. Upper Saddle River, New Jersey: Prentice Hall, Inc., 1999.
20. T. C. Hsia, *System Identification: Least-Squares Methods*. Lexington, Massachusetts: Lexington Books, D.C. Heath and Company, 1977.
21. S. Chen and S. Billings, "Representations of non-linear systems: the NAR-MAX model," *Int. J. Control*, vol. 49, no. 3, pp. 1013–1032, 1989.
22. T. Söderström and P. Stoica, *System Identification*. Prentice-Hall International, 1989.
23. S. Billings and W. Voon, "Least squares parameter estimation algorithms for non-linear systems," *Int.J. System Sci.*, vol. 15, no. 6, pp. 601–615, 1984.
24. G. Goodwin and R. Payne, *Dynamic System Identification: Experiment Design and Data Analysis*, ser. Mathematics in Science and Engineering. New York: Academic Press, 1977, vol. 136.
25. P. Hansen, V. Pereyra, and G. Scherer, *Least Squares Data Fitting with Applications*, 1st ed. Baltimore, MD: John Hopkins University Press, 2012.
26. Å. Björck, *Numerical Methods for Least Squares Problems*, 1st ed. Philadelphia: Siam, 1996.

27. S. V. Huffel and J. Vandewalle, *The Total Least Squares Problem: Computational Aspects and Analysis*, 1st ed. Philadelphia: Siam, 1991.
28. S. Haykin, "A unified treatment of recursive digital filtering," *IEEE Trans. Auto. Control*, vol. 17, pp. 113–116, 1972.
29. N. K. Sinha, "Estimation of transfer function of continuous system from sampled data," *Proceeding of the IEE*, vol. 119, no. 5, pp. 612–614, 1972.



REPORT DOCUMENTATION PAGE				Form Approved OMB No. 0704-0188	
The public reporting burden for this collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden, to Department of Defense, Washington Headquarters Services, Directorate for Information Operations and Reports (0704-0188), 1215 Jefferson Davis Highway, Suite 1204, Arlington, VA 22202-4302. Respondents should be aware that notwithstanding any other provision of law, no person shall be subject to any penalty for failing to comply with a collection of information if it does not display a currently valid OMB control number. <b>PLEASE DO NOT RETURN YOUR FORM TO THE ABOVE ADDRESS.</b>					
1. REPORT DATE (DD-MM-YYYY) 01-05-2014		2. REPORT TYPE Technical Memorandum		3. DATES COVERED (From - To)	
4. TITLE AND SUBTITLE Exploratory Study for Continuous-Time Parameter Estimation of Ankle Dynamics				5a. CONTRACT NUMBER	
				5b. GRANT NUMBER	
				5c. PROGRAM ELEMENT NUMBER	
6. AUTHOR(S) Sunil L. Kukreja and Richard D. Boyle				5d. PROJECT NUMBER	
				5e. TASK NUMBER	
				5f. WORK UNIT NUMBER	
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) NASA NASA Armstrong Flight Research Center, Edwards, California 93524-0001				8. PERFORMING ORGANIZATION REPORT NUMBER L-	
9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES) National Aeronautics and Space Administration Washington, DC 20546-0001				10. SPONSOR/MONITOR'S ACRONYM(S) NASA	
				11. SPONSOR/MONITOR'S REPORT NUMBER(S) NASA/TM-2014-218314	
12. DISTRIBUTION/AVAILABILITY STATEMENT Unclassified-Unlimited Subject Category Availability: NASA CASI (443) 757-5802					
13. SUPPLEMENTARY NOTES An electronic version can be found at <a href="http://ntrs.nasa.gov">http://ntrs.nasa.gov</a> .					
14. ABSTRACT Recently, a parallel pathway model to describe ankle dynamics was proposed. This model provides a relationship between ankle angle and net ankle torque as the sum of a linear and nonlinear contribution. A technique to identify parameters of this model in discrete-time has been developed. However, these parameters are a nonlinear combination of the continuous-time physiology, making insight into the underlying physiology impossible. The stable and accurate estimation of continuous-time parameters is critical for accurate disease modeling, clinical diagnosis, robotic control strategies, development of optimal exercise protocols for longterm space exploration, sports medicine, etc. This paper explores the development of a system identification technique to estimate the continuous-time parameters of ankle dynamics. The effectiveness of this approach is assessed via simulation of a continuous-time model of ankle dynamics with typical parameters found in clinical studies. The results show that although this technique improves estimates, it does not provide robust estimates of continuous-time parameters of ankle dynamics. Due to this we conclude that alternative modeling strategies and more advanced estimation techniques be considered for future work.					
15. SUBJECT TERMS System Identification, Indirect System, Least-Squares, Standardized Least-Squares, Switched Systems, Parametric Models, NARMAX, Exercise Protocols					
16. SECURITY CLASSIFICATION OF:			17. LIMITATION OF ABSTRACT	18. NUMBER OF PAGES	19a. NAME OF RESPONSIBLE PERSON
a. REPORT	b. ABSTRACT	c. THIS PAGE			STI Help Desk (email: <a href="mailto:help@sti.nasa.gov">help@sti.nasa.gov</a> )
U	U	U	UU	16	19b. TELEPHONE NUMBER (Include area code) (443) 757-5802





---