

CR-72918



DIVISION TM 7978:70-643 DATE 22 October 1970 W.O. 1475-80-0101

TECHNICAL MEMORANDUM

AUTHOR(S): E. S. Chalpin

TITLE

Design of the Bare Refractory Double-Containment (BRDC) Boiler Number 5 for PCS, SNAP-8

ABSTRACT

The design of the BRDC Boiler No. 5 is presented. The boiler meets all defined interfaces and requirements of the Power Conversion Jystem (PCS). Tantalum is used as the mercury containment material and type 300 stainless steels are used as the NaK containment material. Zirconium is employed at the mercury inlet and outlet sections as a "gettering" material for the dissolved gases in the static NaK and to minimize carbon transport from the Type 300 stainless steel to the tantalum by "gettering" carbon. Coextruded tantalum-to-stainless steel transition joints (bimetal tubes) are used at the mercury inlet and outlet.

This design, P/N 1268600, contains the salient features of the BRDC Boiler P/N CF 751840 and BRDC Boiler P/N 1266911.

APPROVED: DEPARTMENT HEAD	Reproduced by NATIONAL TECHNICAL INFORMATION SERVICE US Department of Commerce Springfield VA 22151 A NATIONAL TECHNICAL INFORMATION SERVICE
	2.21-38247
	(ACCESSION NUMBER)
	$\begin{array}{c} \overbrace{\begin{tabular}{c} \hline \hline \\ \hline \hline \\ \hline $



AEROJET-GENERAL CORPORATION

CONTENTS

Page

I.	INTRODUCTION			
II.	BAR	E REFRACTORY DOUBLE-CONTAINMENT (BRDC) #5 DESIGN	4	
	Α.	Comparison of Design to PCS-Requirements.	4	
	B.	Overall Boiler Design	5	
	C۰	Mercury Inlet Section	6	
	D.	NaK Inlet and Outlet Manifolds	7	
	E.	Tantalum Tube Bundle and Static NaK Tubes	8	
	F.	Evacuated Center Tube	9	
	G۰	Mercury Outlet Section	9	
III.	BOI	LER PERFORMANCE EVALUATION	9	
IV.	BOI	LER THERMAL ANALYSIS	10	
v.	HYD	RAULIC ANALYSES	11	
	Α.	Mercury Inlet Orifice Pressure Drop	11	
	в.	Tantalum Flug Section Pressure Drop	12	
	C.	NaK Side Overall Pressure Drop	13	
VI.	WEI	GHT ANALYSIS OF THE BOILER	13	
VII.	MAT	ERIALS ANALYSES	13	
	A.	Results of Tantalum-to-Stainless Steel Bimetal Tube Transition Joint Test and Inspection Program.	13	
	В٠	Results of Tantalum Properties Test Program	14	
	c.	Materials Analyses Results of Previous Boilers	14	
VIII.	OVE	RALL BOILER STRESS ANALYSES	15	
	A.	Boiler Operating Criteria for Stress Analyses	15	
	в.	E-11401 Computer Stress Analysis Inputs	15	
	C.	Boiler Stress Analysis Results	15	
IX.	FAI	LURE MODES AND EFFECTS ANALYSIS	16	
х.	DES	IGN REVIEW CHECK LIST	16	
XI.	CLC	SING REMARKS	17	
	A.	Thermal Stratification of the Intermediate Loop NaK Flow .	17	
	B.	Tantalum-to-Stainless Steel Joint Reliability	17	
	C.	Mercury-to-Intermediate NaK Loop Leakage Causing Major Contamination of the NaK Loop	17	
	D.	Differential Expansion Between the Tantalum and Stainless Steel	17	
	E.	Negative Slope Mercury Pressure Drop Versus Flow	17	

			CONTENTS	<u>-</u> -	continu	led		Pag	e
	F.	Natural	Convection	of	Static	NaK at	Mercury Inlet	18	b
	G.	High Axi	al Thermal	Gre	dients	in the	Shell at the	18	3
XII.	refi	ERENCES	111160					27 <u>APF</u>	7 ÆNDIX
Ground	Rule	es, Desig	n Approach	and	l Criter	ria for	BRDC Boiler #5		A
Boiler	The:	rmal Anal	yses						В
Mercury	y Sid	le Boiler	Pressure I	roj	o Analys	ses			С
BRDC Bo	oile:	r No. 5,	Pressure Di	rop	Through	n NaK Si	ide of the Boile:	r	D
Boiler	Wei	ght Analy	sis						Е
Tantalı and I	um-t Enspe	o-Stainle ection Pr	ss Steel Bi ogram	met	al Tube	e Trans	ition Joint		F
Overal]	L Bo	iler Stre	ss Analyses	3					G
Failure	e Mo	les and E	ffects Anal	lysi	is				H
Design	Rev:	iew Check	: List						I

FIGURES

 BRDC Bóiler No. 5
BRDC Mercury Inlet Design Evaluations
Effluent Water Flow Pattern Observed During Flow Tests of BRDC Boiler No. 4 Swaged Plug Insert/Tube Assemblies P/N 1266931
Reservoir - Volume Compensator for BRDC Boiler
Boiler Support Configuration

Page.

I. INTRODUCTION

Historically, the first boiler fabricated for SNAP-8 was a single pass Tube-in-Shell design. Four 0.902 in. inside diameter, Haynes 25 material, 60-foot long mercury tubes were coiled in a toroidal NaK shell. Two of the four Hg tubes were coiled on a smaller helix than the other two, resulting in a significant difference in the lengths of each pair. The NaK flow was a combination cross-flow and counter-flow pattern relative to the Hg flow. Each Hg tube contained an inlet plug insert and swirl wire.

The design was inadequate from the diagnostic viewpoint. The heat transfer characteristics in terms of tube length could not be determined adequately because of the unavailability of accurate NaK temperature profile measurements. Poor heat transfer and relatively high liquid carry-over were attributed to the Haynes 25 flow passage contamination.

The second boiler fabricated for SNAP-8 was a single-pass, Tube-in-Tube design. Seven 0.652 in. inside diameter, 9M steel, 30-foot long Hg containment tubes were twisted and then coiled in a 4.25 in. 0.D. helically coiled tube. Twisting the tube bundle prior to coiling resulted in equal length Hg tubes. Each Hg tube contained an inlet plug insert and swirl wire. The "dry-wall" concept of Hg heat transfer was used in designing the boiler and was based on SNAP-1 and SNAP-2 experience using Haynes 25 and 316 stainless steel material. Since 9M material was considered to be nonwettable, the "dry-wall" concept was applied.

The main problem with this design was metallurgical (NaK-side embrittlement, and Hg-side corrosion of the 9M material). The thermal performance was adequate with clean 9M flow passage surface conditions. The preservation of boiler Hg passage cleanliness in the integrated system's loop was not adequate however, and the boiler operated in a deconditioned state and relatively high liquid carry-over resulted.

-1-

The SB-1 test assembly was an experimental Ta-SS, double-containment, single-tube 1/7th scale boiler. Further investigations carried on with the SB-1 test assembly at AGN indicated that the two most important requirements for proper conditioning of the boiler were cleanliness of the mercury side of the boiler tubes and the assurance of a vacuum tight mercury system to preclude tantalum surface oxidation. Out of 2,558 hours of testing the SB-1, the last 165 hours were run with a conditioned boiler. The changes instituted prior to the last 165 hours were the thorough cleaning and the high vacuum integrity of the facility.

A bimetal boiler was designed at AGC using a stainless steel tube coextruded with a tantalum inner liner for the mercury containment tubes. The purposes of the tantalum was to improve mercury corrosion resistance and to enhance wetting by the mercury (which improves "conditioning" of the boiler). The boiler design was completed, and one was fabricated. However, this boiler has not been used to date.

During the design period of the bimetallic boilers, LeRC went ahead with the design and fabrication of an all-tantalum tube and header configuration for the Hg with a double-containment feature utilizing static NaK as the barrier fluid between the flowing NaK in the primary loop and the Hg. The AGC bimetal tube boiler was designed as a 30-foot long assembly while the LeRC bare refractory, double-containment (BRDC) Boiler was designed as a 37-foot long assembly.

The experimental 1/7th scale, single tube bimetal boiler (SF-1A) was designed and tested to investigate the bimetal tube and bimetal tube joint structural reliability and the single-fluted helix configuration for heat and momentum transfer performance characteristics. A 1200 hour test showed that the design had excellent and immediate performance throughout its operation. Obviously, clean Hg flow passage surfaces were provided and maintained in the leak tight Hg loop.

The SB-2 test assembly, simulating the design of the BRDC #4 boiler was tested at the Aerojet-General Corp., San Ramon facility.

-2-

The LeRC BRDC Boiler #1 has been tested at the W-1 facility at LeRC and at the General Electric Company while Boiler #2 has been tested at AGC. Problems associated with thermal differential bellows failures at the Hg inlet and outlet, shell failures at the NaK outlet, the incipient failure of the tantalum-to-stainless transition joint and the sagging of the tube bundle in the stainless shell prompted the redesign of the boiler which became BRDC #4, P/N 1266911.

The criteria used in designing the #4 boiler were:

1. It shall meet the requirements of the PCS-G prototype system using specifications AGC-10621 - "Boiler, NaK/Mercury, Prototype, SNAP-8" and AGC-10512 - "Power Conversion System, Model G, SNAP-8." The boiler envelope and interfaces shall be as described by the PCS-G.

2. The mercury lines at the injet and outlet shall incorporate a coextruded tantalum-to-stainless steel transition joint in the form of a bimetal tube.

3. The boiler shall have double containment utilizing static NaK as the barrier fluid.

4. Collector rings at the flowing NaK inlet and outlet shall be used to more efficiently mix the fluid and to reduce thermal stresses....

This boiler was fabricated at the NASA-LERC facility and tested at the Aerojet-General PCS-1 facility for 1620 hours and 28 cycles from March through June, 1970. Some deconditioning was noted during the initial runs due to system contaminants. However, as testing progressed the boiler became conditioned and performance was excellent. There was no instability over the extreme range of off-design testing and no failures or incipient failures were experienced. One area of concern was the high (~ 500°F) circumferential gradient in the shell between the mercury inlet and the NaK outlet collector ring. The thermal map was similar to that experienced with BRDC #2. It was deduced at the time of BRDC #4 design that the thermal gradient in BRDC #2 was due to forced convection of the flowing NaK past the loosely fitting baffles. BRDC #4 employed a very low leakage baffle as well as annular evacuated tubes surrounding the mercury containment tantalum tubes in this area to reduce heat transfer from the NaK to the colder mercury. Further analysis indicated that natural convection was the basic mechanism for non-symetrical circumferential thermal gradients, resulting in stratification of the NaK (The colder, more dense fluid settling to the bottom due to gravity).

-3-

The current coiled boiler, BRDC #4, became obsolete when the PCS system configuration changed from a conical shape to a paralielepiped and the performance criteria were changed. The design of the new bare refractory double-contained (BRDC) Boiler #5 is the subject of this report.

The criteria used in designing the Boiler were:

 It shall meet the requirements of DE-0018, dated 13 July 1970
"Ground Rules, Design Approach and Program Plan for BRDC Boiler #5" which includes reference to Memo No. 7978:70:0002, dated 1 July 1970 "SNAP-8
Tube Boiler (BRDC #5) Design for Revised System State Point Conditions" by E.S.Chalpin/A.J.Sellers.

2. The criteria for stress shall be as noted in Memo No. 7978:70:0003 dated 6 July 1970 "BRDC Boiler #5 Operating Criteria for Stress Analyses" by E.S.Chalpin and Memo No. 7974:70:0047 (File SS 1020) dated 10 July 1970, "Boiler #5 Critical Areas" by W. Weleff.

3. It shall be an "S" shape with a horizontal mercury inlet and outlet, coextruded tantalum-to-stainless steel bimetal tube transition joints, doublecontainment, of a co-axial 12 tube array and have collector rings at the NaK inlet and outlet.

4. The "S" shape radii and straight sections shall meet the envelope requirements of the PCS and the length of the boiler from the NaK inlet to the NaK outlet shall be 21 feet. This is 6 inches shorter than that noted in Memo No. 7978:70:0002 above due to space limitations in the PCS. However, thermal performance analysis shows that the slight change will be acceptable.

II. BARE REFRACTORY DOUBLE-CONTAINMENT (BRDC #5) DESIGN

A. COMPARISON OF DESIGN TO PCS REQUIREMENTS

Assembly Drawing No. 1268600, Figure 1, shows the new boiler design that meets all the requirements of PCS as itemized in Specification AGC 10680 (Reference a) and the interface control drawing (Reference b).

-4-

The performance requirements were based on the "PCS-G State Point Conditions - Revision Date 4/21/70," Memo EDF Serial N-SA-OOl4. These requirements were analyzed and Memo No. 7978:70:0002, dated 1 July 1970, "SNAP-8 12 Tube Boiler (BRDC #5) Design for Revised System State Point Conditions" by E.S.Chalpin/A.J.Sellers was published which identified the performance map for high and low NaK schedule as well as the basic configuration (see Appendix A). The design was approved by Systems Management in Memo No. 7992:70:0071, dated 6 July 1970 "Compatibility of Boiler Design Configurations for PCS-G" by R.G.Geimer.

The "S" configuration, double-containment, bare refractory (tantalum) mercury containment tubes with swirl wire inserts was approved by NASA in their letter No. 5211, dated 12 June 1970, "SNAP-8 PCS-G Boiler Design Contract NAS 3-13458" by M.J.Saari, Chief, SNAP-8 Project Office. In this letter he approved the 13-tube configuration. However, further analyses subsequent to the date of his letter indicated that the 12-tube concept resulted in a more compact co-axial design with acceptable performance.

· B. OVERALL BOILER DESIGN

The boiler was designed for an effective boiler length of 21 feet from the flowing NaK inlet to the flowing NaK outlet, as shown in Drawing No. 1268600 (Figure 1). The two radii of the "S" shape boiler are identical at 25 inches. The NaK shell is 7.625 inches outside diameter with a 0.120 inch wall, made of 316SS. The shell will be made in two halves and welded along the centerline perpendicular to the plane of the "S". The flowing NaK manifolds (tees) will also be made in two halves, welded along their centerlines parallel to the plane of the 3 inch port.

The tube bundle will be spaced in an annular array, co-axial with a 3.5 inch central tube which will be evacuated and sealed.

Spacers for holding the 12 tubes and the central tube concentric with the outside shell will be placed throughout the boiler.

Turbulator wires around the central tube and along the inside diameter of the shell will be installed for 10 feet in the boiler, ending at the NaK outlet tee.

-5-

The boiler support configuration for PCS can be seen in Figure 5.

The overall design described above and the detail descriptions to follow have incorporated the best design features of previous boilers plus design considerations to minimize circumferential and axial thermal gradients at the mercury inlet end.

C. MERCURY INLET SECTION

The inlet header is shown in Figure 1 as a centrally located axial entry configuration. A coextruded, tantalum-to-type 316SS bimetal tube transition joint identical in size and length to that successfully used in . BRDC Boiler #4 for 1600 hours and 28 starts is shown. The bimetal tube is 1.25 inches 0.D. by .750 inches I.D. which includes a .150 inch wall of Type 316SS metallurgically bonded to a .100 inch wall of tantalum. The tube is Electron Beam (EB) welded to the stainless steel end cap. The total effective length of the transition joint bond is 8 inches.

The evacuated annular insulator between the tantalum dome and the shell reducer is designed for thermal management. The phenomenon of induced convective patterns, wherein the colder NaK surrounding the tantalum tubes sinks due to gravity effects, has been a persistent problem in all boilers tested to date. The design minimizes this effect by the use of the "honeycomb" structure in the area between the stainless steel header and the tantalum header.

The 12 tantalum tubes are spaced on a 5.625 inch bolt circle such that the oval static NaK tubes surrounding them downstream have a more distributed NaK flow around them. The tantalum tubes are welded into the tantalum header in the same manner as BRDC Boilers #1, 2, 3 and 4. The orifices shown at the entrance of the tantalum tubes are bored to .050 inches diameter and were calculated to produce a pressure drop of 128 psid at full flow conditions. The pressure drop versus flow for the orifice, added to the pressure drop versus flow for the startup and steady-state operation of the boiler. This was a requirement of the SNAP-8 system to preclude problems in control and reactor operation.

-6-

The tantalum plugs placed in the tantalum tubes downstream of the orifices are 2.7 feet long. Sixteen equally spaced helical grooves are cut along the length of the plugs at a 6 inch pitch. Circumferential annuli are cut at ten inch intervals along their lengths to ensure a redistribution of mercury flow, should a helical groove become blocked or not perform properly.

The tantalum tube is swaged onto the tantalum plug. Seventeen plugs made as spares for BRDC #4 are to be cut from four feet to the required 2.7 feet for this boiler. The swaged plug assemblies and the orifices will be flowed with water to determine the actual pressure drop through each, as was done for BRDC #4.

Zinconium.foil.is shown in the tantalum demessres. Zinconium was found to be an excellent "hot getter" for dissolved gases and carbon in the static NaK as evidenced by the analysis of BRDC Boiler #1 and 2 following test.

The boiler shell is shown expanded radially in the area between the stainless steel header and the tantalum header. This is to allow for the vacuum chamber within the shell. The purpose and value of the vacuum insulator is discussed later in this report. Another vacuum chamber shown abutted to the stainless steel header is also discussed.

. The joint between the tantalum dome and the bi-metal tube will be EB welded in the same manner as BRDC $\#_4$.

D. NAK INLET AND OUTLET MANIFOLDS

The NaK inlet and outlet manifolds or tees are designed as collector rings which surround twelve (12) 1.25 inch diameter holes spaced between mercury tubes and drilled into the 7.625 inch O.D. flowing NaK shell. The tees are forged in two parts and welded in the plane of the 3 inch port.

The two predominant reasons for the manifold design are the better distribution of heat in the critical zones where previous shell failures have occurred and the better mixing of the NaK entering and leaving the boiler. The acceptability of the design was borne out by plastic model tests with water as well as the results of Boiler #4 tests.

-7-

Mixing of the NaK leaving the boiler will also result in a better measurement of the NaK mixed-mean temperature which is essential to obtain good thermal performance data.

E. TANTALUM TUBE BUNDLE AND STATIC Nak TUBES

The twelve (12) tantalum tubes are of equal 21 foot lengths. They are not coiled along their lengths as in earlier boilers which were coiled to obtain equal length tubes. BRDC Boiler #4 was not coiled either and its performance was excellent. The tantalum tubes are .75 inch 0.D. by .049 inch wall (the same as Boiler #4).

The tantalum tubes are placed in their respective Type 321SS oval static NaK tubes. The tantalum tube must then be held against the side of the oval tube such that it is at the greatest radius in both halves of the "S" shape. This means that the tantalum tube must cross over : in the straight midsection of the "S" (See Figure 1). Since the coefficient of thermal expansion for the stainless steel oval tube is more than twice that of the tantalum tube, the oval tube will grow outward or to a larger diameter relative to the tantalum tube. Consequently, no loading will be experienced between the two metals as the boiler heats up and cools down.

Seven (7) lattice-type spacer assemblies hold the tubes in their proper positions relative to the evacuated center tube and the NaK shell.

A .125 inch diameter wire with a pitch of 6 inches is wound on the center tube for 10 feet, starting at the mercury inlet, prior to installation of the 12 tantalum tubes and stainless steel static NaK tubes. Another wire of the same diameter, pitch and length is wound on the outside of the 12 tubes counter-rotational to the wire on the center tube. The purpose of these wires is to promote mixing of the flowing NaK in the area of the boiler where the greatest amount of heat transfer occurs. The adequacy of this configuration was vividly demonstrated by using a full scale plastic model of the boiler through which dye was injected in flowing water. The test also confirmed the calculations of the flowing NaK side pressure drop.

A coiled 90% tantalum-10% tungsten (90Ta-10W) .062 diameter wire with a 2 inch pitch was placed downstream of the plug for the remaining length of the tantalum tubes. The purpose of the wire is to maintain a centrifugal field for mercury droplets in the vapor such that the droplets would contact the hot tantalum tube walls, vaporize and thus "dry out" the mercury vapor before it leaves the boiler.

-8-

F. EVACUATED CENTER TUBE

The 3.5 inch 0.D. by .120 inch wall center tube runs the full length of the boiler. It is bent into shape, evacuated to 10^{-4} Torr and sealed. This tube was placed in the center of the annular array of mercury tubes to decrease the free flow area of the flowing NaK which in turn increased the NaK velocity to 3.4 feet per second, thus assuring turbulent flow (Reynolds number of 110,000) and subsequent good heat transfer.

G. MERCURY OUTLET SECTION

The mercury outlet, like the inlet, is a centrally located axial discharge configuration. A coextruded tantalum-to-type 31655 bimetal tube transition joint, identical in size and length to that successfully used in BRDC Boiler #4 for 1600 hours and 28 starts is shown in Figure 1. The tube is 2.26 inches 0.D. by 1.76 inches I.D. which includes a .150 inch wall of Type 31655 metallurgically bonded to a .100 inch wall of tantalum. The tube is Electron Beam (EB) welded to the stainless steel end cap. The total effective length of the transition joint bond is 8 inches, the same as the mercury inlet joint. Zirconium foil is located in the static NaK area surrounding the bimetal joint for "hot gettering" dissolved gases and carbon.

III. BOILER PERFORMANCE EVALUATION

Technical Memorandum 4921:68:550, "SNAP-8 Boiler Development Evaluation of SB-1 Boiler Test Results and Proposed Design Modifications" (Reference c), by A.J.Sellers, is an analysis of the 1/7th scale boiler and was applicable to the BRDC #4 boiler design. This technical memorandum was the basis used for determining many of the design aspects, especially as related to performance. The soundness of the analysis was borne out by the excellent performance of BRDC #4 during its tests in PCS-1 over a wide range of operating conditions (see Reference d).

As a matter of fact, BRDC ## was the most stable boiler designed, fabricated and tested in the SNAP-8 program to date.

BRDC #5 boiler was designed using the same criteria as BRDC #4 except that the excess superheat length normally added to the boiler on previous designs was not added to BRDC #5. This was not done for two reasons - one being that its addition did not improve the performance of BRDC #4 appreciably and secondly, the envelope restrictions of the PCS precluded the addition of the extra length.

-9-

Appendix A shows the performance map and criteria computed for the high and low NaK schedule as well as the basic configuration of the BRDC #5 boiler.

IV. BOILER THERMAL ANALYSIS

Appendix B shows the results of the various design approaches to the mercury inlet section for the startup transient and steady-state conditions. The analyses were concerned with the following criteria:

. The inlet dome mercury volume should be as small as possible to minimize the time to fill during startup, yet not be so small that mercury boiling and flashing in the dome causes such a high back pressure on the mercury pump that startup becomes impossible. This can occur since the boiler is preheated to the NaK inlet temperature prior to mercury injection.

. No thermal gradients in any of the materials should be so high as to cause thermal stresses which exceed the allowable strength of the materials during the transient and steady-state operating conditions.

. Natural convection currents in the static NaK should be suppressed or destroyed such that circumferential thermal gradients are minimized. The analysis of the BRDC #4 design assumed the thermal gradients were caused by forced convection. As a result, a close fitting baffle, was placed in the flowing NaK area. However, the circumferential gradient remained essentially the same as BRDC #2. Figure 2 compares the various designs of boilers and lists the changes made to each in an effort to solve the problem.

However, it became evident as the design evolved, that the thermal gradients in the dome were too severe for a thick, flat dome which held the mercury volume to a minimum. A thinner, fairly flat dome was unacceptable from a pressure stress standpoint. It was determined that a hemispherical head was the least stressed but it also resulted in an unacceptably large mercury volume. An ellipsoidal dome proved to be the most acceptable as to stress, size and mercury volume. This configuration was analyzed for the transient and steady-state conditions. At the same time, the mercury inlet steady-state temperature was decreased from 420° F to 350° F, in keeping with the latest change dictated by the change from the 4-stage turbine to the dual multi-stage reaction turbine concept.

-10-

The vacuum chamber between the stainless steel header and the tantalum header was found to be a requirement to reduce the thermal gradient across the stainless steel header.

The vacuum chamber between the tantalum dome and the NaK shell was required to reduce the thermal gradient in the shell and in the area adjacent to the end of the NaK outlet manifold. The static NaK volume in this area was reduced to a minimum to decrease the available heat to the cold mercury during startup, thus reducing the thermal shock of the materials.

The compartmentalization ("honey-combing") of the area around each tantalum tube between the stainless steel header and the tantalum header is an approach designed to minimize the natural convection of the static NaK as the colder mercury flows through the tantalum tubes. The NaK outlet manifold was placed around this area to further reduce the natural convection by supplying heat over the whole circumference. These approaches were not employed in the BRDC #2 and #4 boilers.

An analysis of the natural convection phenomenon in liquid metals can be seen in Appendix B. It should be pointed out that there is very little information available on natural convection of liquid metals with the tubes-in-shell configuration described herein.

The thermal maps shown in Appendix B were then submitted to the Stress Group so that the maximum stresses could be computed throughout the startup and steady-state operation.

V. HYDRAULIC ANALYSES

A. MERCURY INLET ORIFICE PRESSURE DROP

The available boiler inlet pressure from the mercury pump must not be exceeded and the minimum pressure to the turbine must be met. With these defined, the total pressure drop allowable across the boiler can be determined. The pressure drop across the boiler (without inlet orifices) is positive with flows up to approximately 5,000 lbs. per hour and then goes negative from there to full flow. This can cause system perturbations that are undesirable, especially for the reactor.

-11-

The pressure drop through the short tube orifices upstream of the plugs rises as a **square**: function as flow increases to normal operating conditions. Therefore, by choosing an orifice of the proper size (the sum of its pressure drop and the pressure drop of the remainder of the boiler) a positive slope of pressure drop versus flow can be attained throughout the boiler transient and at steady-state operation. The orifice size was calculated to be .050 inches diameter. The exact pressure drop versus flow curve desired was planned to be obtained by chamfering the orifice inlet, testing in water and then slightly rounding the inlet to achieve the proper curve.

Appendix C shows the calculations made by G.L.Lombard to determine the proper orifice shape and pressure drop. It is worthy to note that the determination of boiler pressure drop for past boiler designs was computed and then checked by building and testing single tube models in facilities such as the 1/7th scale loop. The correlation of design and test data for those earlier programs, plus testing of the BRDC #4 at very low flows (2500 lbs. per hr.) were used in designing BRDC #5 without the expensive and time-consuming methods employed previously. The new analytical method can be used on all future boiler designs as well.

B. TANTALUM PLUG SECTION PRESSURE DROP

The calculations to determine the tantalum plug pressure drop and its design length can be seen in Appendix A. Its relationship to the orifice pressure drop and the boiler overall pressure drop can be seen in Appendix C. The design length was calculated to be 2.7 feet. There are currently 17 plugs in stores that were made originally for two: more boilers to the BRDC #4 design (4 feet long). However, a design change in the PCS from a conical shape to a parallelepiped shape and the changes in liquid metals temperatures, pressures and flows dictated that the coiled, 7 tube boiler design would have to be changed to the "S" shape 12 tube boiler design. Therefore, a minimum of 12 of the 17 machined plugs will be remachined to the 2.7 foot length. They will then be swaged into their respective tantalum tubes and tested with water to determine the pressure drop of each. The swaged plug assemblies of BRDC #4 were tested in this manner and found to vary from 49 to 63 psid. Knowing each swaged plug assembly and each orifice pressure drop, they can be matched for the best combination for a more balanced overall boiler assembly.

-12-

Figure 3 is a sketch of the typical water flow pattern leaving the plug section. It shows the helical, cone shaped swirl produced by the plug.

C. NaK SIDE OVERALL PRESSURE DROP.

An intermediate NaK loop side pressure drop analysis was performed for the boiler in the manner shown in Appendix D. The PCSsystem requirement called for a maximum allowable pressure drop of 3:0 psid. The calculations showed that the total pressure drop would be 1.50 psid at the steady-state operating conditions.

Water testing of the boiler plastic model corroborated the calculations as a similar test did for BRDC #4. The testing of BRDC #4 in PCS-1 with NaK also agreed with the calculations and water test. It is concluded that BRDC #5 testing in PCS-1 will be in agreement also.

VI. WEIGHT ANALYSIS OF THE BOILER

The wet and dry boiler weight analysis can be seen in Appendix E. To summarize, the dry weight was calculated to be 833 pounds and the wet weight was calculated to be 1030 pounds.

The weight of static NaK was determined to be 39.3 pounds at ambient temperature. A typical design of a volume compensator reservoir to compensate for the expansion of the NaK through the thermal excursions of the boiler can be seen in Figure 4.

The conceptual design of the method of mounting the boiler based on the weights above as well as the thermal growth of the boiler can be seen in Figure 5.

VII. MATERIALS ANALYSES

A. RESULTS OF TANTALUM-TO-STAINLESS STEEL BIMETAL TUBE TRANSITION JOINT TEST AND INSPECTION PROGRAM

Typical bimetal tube transition joints used on BRDC #4 and planned for BRDC #5 were ultragonically inspected at ANSC and at Westinghouse. Agreement was reached as to the best method of inspection. Some disagreement was found in the inspection results of one of the samples. Indications of debonding was noted at ANSC but no indications were noted at Westinghouse. This sample was sectioned at Westinghouse and no debonding was found. The reason for the evident discrepancy in the ANSC results is being investigated.

-13-

It was reported by the ANSC Materials Group that the thermal cycling tests of representative bimetal tubes indicated that debonding is not a problem. However, it was reported that a 7% decrease in inside diameter of these bimetal tubes occurred during test. It is assumed that the wide difference in expansion coefficients of the tantalum $(4.1 \times 10^{-6} \text{ in./in.})$ and the Type 316 stainless steel $(10.7 \times 10^{-6} \text{ in./in.})$, the difference in their yield strengths and relaxation of the residual fabrication stresses caused the change in diameter. The amount of change in diameter does not appear to be of a significance to affect boiler performance.

Appendix F describes the above test and inspection programs.

B. RESULTS OF TANTALUM PROPERTIES TEST PROGRAM

The tantalum properties test program was directed by the NASA-LeRC Materials Lab. Extensive work was done in connection with the design of BRDC #4. Welded and non-welded tantalum was investigated. Phase I tests for low cycle fatigue at 600° F and 1100° F, were completed, followed by Phase II testing at 1350° F. (not completed to date). Results indicated that tantalum is an excellent material for mercury containment in boilers.

C. MATERIALS ANALYSES RESULTS OF PREVIOUS BOILERS

Boilers #1, 2, 3, 4 and 5 all contain the same materials, namely:

1. Type 316SS for the NaK shell, headers, turbulator wire, spacers and center tube.

2. Type 321SS for the static NaK tubes

3. Zirconium for the "hot getter."

4. Tantalum for the mercury containment parts.

5. Tantalum - 10% tungsten (Ta-10W) swirl wire in the tantalum tubes.

Reference (e) is a report on the materials analyses of BRDC #1 performed by the General Electric Co. No materials problems were noted in this boiler after 15,250 : hours of steady-state operation.

Reference (f) is a report on the materials analyses of BRDC #2 performed by ANSC. Other than cracking and failure of the Ta-LOW wire (due to hydrogen embrittlement(); some erosion of a tantalum tube caused by "talk" the flow of primary Wak through a crack in the static Nak tube

-14-

(due to excessive thermal stress), and cracking of the shell at the NaK outlet port (again due to excessive thermal stress), the boiler materials were found to be acceptable for future boiler designs.

An excellent analysis of mass transfer deposition throughout the boiler trantalum tubing can also be seen in Reference (f). It was concluded that mass transfer deposition would not be a problem in the PCS. VIII. OVERALL BOILER STRESS ANALYSES

A. BOILER OPERATING CRITERIA FOR STRESS ANALYSES

Appendix G itemizes the operating criteria of the boiler for stress analyses. The criteria define the transient, steady-state and maximum conditions for the flowing NaK side, the mercury side and the static NaK side. The expected interface loads were also defined.

B. E-11401 COMPUTER STRESS ANALYSIS INPUTS

Also included in Appendix G is a table of the inputs used in the E-11401 Computer Code for calculating the stresses in the boiler. Particular emphasis was placed on the mercury inlet configuration where the most severe pressure and thermal transients occur.

C. BOILER STRESS ANALYSIS RESULTS

The following areas were stress analyzed in detail using the criteria for pressure and temperature noted above:

- 1. NaK shell
- 2. Static NaK tubes
- 3. Center vacuum tube
- 4. Stainless steel inlet header
- 5. Stainless steel tees
- 6. Stainless steel vacuum insulators
- 7. Mercury inlet section
- 8. Overall boiler stresses with mountings recommended by PCS.
- 9. Mercury outlet section

Appendix G contains the work done in the above areas. All boiler stresses for the most severe conditions were calculated using the structural design criteria recommended in Reference (g). The approach and methods of analyses included the use of the finite element computer program E-11401 for the mercury inlet and outlet. These areas have axisymmetrical geometry and loading directly suited for application of this program.

The shell, tubes, stainless steel header tees and the vacuum insulators were hand calculated.

Thermal fatigue analyses employed the Manson equation and the computer output, where applicable. Thermal ratcheting was also considered.

The bimetal coextruded mercury inlet and outlet tubes were analyzed and compared to the values obtained when BRDC #4 was designed since the same size and length of tubes were used in BRDC #5.

The results of the boiler mounting analyses are shown in Appendix G. The piping flexibility analysis computer code MEC-21 was used. Figure 5 shows the recommended boiler mounting for PCS." It will be noted that the boiler is shown "cold sprung" such that the boiler stresses will be a minimum when steady state operation is reached.

IX. FAILURE MODES AND EFFECTS ANALYSIS

Appendix H itemizes the failure modes experienced on previous boilers or expected failure modes, the probable causes, effects on the boiler and the system, the probability of each occurrence and the criticality of each failure.

All of the failure modes occurred on all boilers to date with the exception of the BRDC #4 boiler which experienced only one. This boiler became deconditioned during the start of testing due to oil contamination from the mercury loop. However, the boiler conditioned fully after continued operation.

X. DESIGN REVIEW CHECK LIST

The Design Review Check List, Appendix I, is an integral part of the design review documentation package as required by Power Systems Division Procedure I-A6C. All items pertinent to the boiler were considered during the design phase.

-16-

XI. CLOSING REMARKS

Many problems have been in evidence with past boiler designs. Particular emphasis was placed on the resolutions of these problems during the design of BRDC Boiler No. 5 as noted below:

A. THERMAL STRATIFICATION OF THE INTERMEDIATE LOOP Nak FLOW

Manifolds or tees were incorporated with radial holes in the shell to provide more complete mixing of the NaK when entering and leaving the boiler. A turbulator wire was coiled around the center tube counter-rotational to the wire around the tube bundle for the 10 feet preceding the NaK exit. Water and dye tests on a plastic model of the boiler confirmed the efficacy of the design.

B. TANTALUM-to-STAINLESS STEEL JOINT RELIABILITY

Coextruded tubing of tantalum and stainless steel with an effective length of 8 inches for the mercury inlet and outlet was proven to be a reliable transition joint in BRDC #4. The same sizes and length of tubing were used on BRDC #5.

C. MERCURY-to-INTERMEDIATE NaK LOOP LEAKAGE CAUSING MAJOR CONTAMINATION OF THE Nak LOOP

Static NaK tubing surrounding the mercury tubes as a double containment feature was employed in the same manner as BRDC #1, 2, 3 and 4 boilers.

D. DIFFERENTIAL EXPANSION BETWEEN THE TANTALUM AND STAINLESS STEEL

The same concept of oval static NaK tubes surrounding the tantalum tubes for thermal growth allowances was used on BRDC #5 as was used on BRDC #1, 2, 3 and 4.

E. NEGATIVE SLOPE MERCURY PRESSURE DROP VERSUS FLOW

Design of the mercury inlet orifices to result in a positive slope of the mercury pressure drop versus flow was incorporated in this design. All previous boilers had a negative slope.

-17-

F. NATURAL CONVECTION OF STATIC Nak AT MERCURY INLET

Compartmentalization of areas around the tantalum tubes at the mercury inlet and the surrounding of this area with the NaK outlet tee will effectively diminish or destroy the natural convection currents which caused circumferential thermal gradients on all previous boilers.

G. HIGH AXIAL THERMAL GRADIENTS IN THE SHELL AT THE MERCURY INLET

Vacuum insulators were placed between the stainless steel header and the tantalum header as well as the area surrounding the tantalum dome. The static NaK volume around the tantalum header was also reduced for the same reason. FOLDOUT FRAME

EOLDOUT FRAME 2

ESC 6/29/70

BRDC MERCURY INLET DESIGN EVALUATIONS

FIGURE Z

1074



BRDC MERCURY INLET DESIGN EVALUATIONS

.č ö₽ 4

BRDC BOILER NO. 2 By CF 751840		BRDC BOIL	ER NO.4	BROC BOILER NO. 5	······
POSTULATIONS FOR THERMAL GRADIENTS	SOLUTIONS	POSTULATIONS FOR THERMAL GRADIENTS	SOLUTIONS		
I. STRATIFICATION (FLOW TEMP) OF PNL NAK (ROSS- FLOW NEXT TO BAFFLE DUE TO SINGLE RADIAL EXIT. 2. TOP NG TUBES DE- CONDITIONED DUE TO CONTAMINATION (OIL). 3. GRAVITY DIFFERENTIAL BETWEEN TOP & BOTTOM HG TUBES. 4. CONVECTION IN SEMI- BAFFLED NAK AREAS INDUCED BY FLOWING NAK THRU ANNULUS BETWEEN BAFFLE PLATE & STATIC NAK TUBE,	I. ADD COLLECTOR RING WITH RADIAL HALES IN SHELL. ADD TURBULATOR WIRE UPSTREAM OF NAK EXIT. 2. ADD VAC UUM TUBES TO REDUCE HEAT TRANSFER. MODIFY RS TO DECREASE INFLUX OF CONTAMINANTS, 3. VERTICAL HS INLET 4. DELETE ONE BAFFLE, INCREASE BAFFLING WITH TIGHTER FIT, ADD VACUUM TUBES, OVERLAP BAFFLE WITH TEE.	I. TIGHT BAFFLE IS TOO EFFECTIVE TO ALLOW FOR THERMAL MIXING, 2. TOP Hy TURES DE- CONDITIONED DUE TO CONTAMINATION (OLL) FLOTATION, 3. GRAVITY DIFFERENTIAL BETWEEN TOP & BOTTOM Hy TUBES. 4. CONVECTION IN TIGHT- BAFFLED NAK AREAS CAUSED BY INEFFECTIVE VACUUM TUBES \$/OR HOT WALL TO COLD WALL HEAT TRANSFER.	1. REMOVE BAFFLE. 2. FURTHER REDUCE INFLUX OF CONTAMIN- ANTS, VERTICAL HS- INLET. 3. VERTICAL HS INLET. 4. REMOVE YACUUM TUBES, DECREASE HS, VOLUME IN TUBES & INLET DOME, REMOVE BAFFLE, ENVELOP. SS HEADER & TA HEADER WITH THE, DECREASE STATIC NAK VOLUME, ADD TURBULATOR FOR FULL BOILER LENGTH ALONG INNER TUBE OD & SHELL ID FOR MORE. COMPLETE PNL MIKING, INCREASE NO. OF RADIAL SHELL HOLES FROM 6 TO 12.	-21-	

BRDC MERCURY INLET DESIGN EVALUATIONS

ESC. 6/30/70. 50F.4

BRDC BOILE	R NO. 2 340	BRDC BOILER NO.4 % 1266911		·	BRDC BOILER NO. 5	1
POSTULATIONS FOR THERMAL GRADIENTS	SOLUTIONS	POSTULATIONS FOR THERMAL GRADIENTS	SOLUTIONS	· .		
THERMAL GRADIENTS	SULUTIONS	THERMAL GRADIENTS 5. FREE CONVECTION EFFECT BETWEEN BAFFLE PLATE, SS HEADER & TANTALUM HEADER WHEN HG. VOLUME IN TA DOME IS CONSIDERED AS AN EFFECTIVE HEAT SINK.	5. ADD EIRCONIUM FOIL IN AREA BETWEEN SS HEADER & TA HEADER TO MINIMIZE CONVECTIVE CURRENTS & APPROACH PURE CONDUCTIVE HEAT TRANSFER THRU N&K.			
					-22-	





FIGURE 3



-25-



BOILER SUPPORT CONFIGURATION

REFERENCES:

- a. Specification AGC-10680 Power Conversion System, Model G, SNAP-8.
- b. Drawing No. 1268489 Interface Control Drawing, Boiler for PCS-G:
- č. Technical Memorandum 4921:68:550, SNAP-8 Boiler Development Evaluation of SB-1 Boiler Test Results and Proposed Design Modifications, by A.J.Sellers.
- d. Technical Memorandum 7992:70:633, PCS-1 Testing of March May 1970, by J.N.Hodgson.
- e. Memorandum 7978:70:000h, Post-test Materials Analyses of BRDC Boilers Numbers 1 and 2, by E.S Chalpin.
- f. Technical Memorandum 7972:70:640, Evaluation of SNAP-8 Bare Réfractory Double Contain ent Boiler No. 2 After 8700 Hours of Operation, by H.E.Bleil.
- g. Specification AGC-10650 Structural Design Criteria, SNAP-8.

APPENDIX A

GROUND RULES, DESIGN APPROACH AND CRITERIA

·

FOR BRDC BOILER #5

•

AEROJET AEROJET	NUCLEAR SYSTEMS COMPANY	ENGINEERING FILE NO.	
POWER SYS	STEMS OPERATIONS	EDF SERIAL NO	DE 0018
ENGINEE	RING DESIGN FILE	DATE	July 13, 1970
PROJECT SNA	<u>P-8 · · · · · · · · · · · · · · · · · · ·</u>	W. O. NO	<u>1475-44-0114</u> , 0117
SUBJECT GROUND	RULES, DESIGN APPROACH AND	PROGRAM PLAN FOR	BRDC BOILER #5.
ABSTRACT			
The subject is	set forth in the following	manner:	
1. S	cope		
2. B	oiler Design Approach		
A	. Thermal		
В	. Mechanical		
C	. Stress		
D). Materials		
3. F	Program Plan		
	-		
		·····	
DISTRIBUTION H.BLe	il, B. Breindel, H. Derow, D	R.G.Geimer, C.Hawk	, J.Hodgson,
	Freeger, G.L.Lombard, L.Lopes	z, R.W.Marshall, J	r., U.A.Pineda,
COVER SHEET ONLY	warden in the meaning		
			•
KEY WORDS BRD	C Boiler #5, Ground Rules, 1	Design Approach, P	rog r am Plan
AUTHOR E.S.Chalpin	SChripm DEPT REVIEW	ED DATE	REVIEWED BISTE

GROUND RULES, DESIGN APPROACH AND PROGRAM PLAN FOR BRDC BOILER #5

1. <u>SCOPE</u>.- The design of the BRDC Boiler #5 shall be based on the salient features of BRDC Boilers #2 and #4, and the analytical results of stress, thermodynamics and materials. It shall incorporate double-containment, tantalum as the mercury containment materials, swirl wire downstream of the tantalum plug, tantalum/stainless steel bimetal transition joints, twelve (12) mercury tubes and of an "S" configuration. This design scope is based on the recommendations of M. J. Saari, Chief, NASA SNAP-8 Project Office in his letter to Dr. W. F. Banks, subject "SNAP-8 PCS-G Boiler Design Contract NAS 3-13458," dated 12 June 1970.

2. BOILER DESIGN APPROACH .-

A. Thermal - As itemized in Memo 7978:70:0002, E.S.Chalpin/A.J.Sellers, Subject "SNAP-8 12 Tube Boiler (BRDC #5) Design for Revised System State Point Conditions," dated 1 July 1970. This was corroborated by R.G.Geimer, Systems Management, in Memo 7992:70:0071, subject "Compatibility of Boiler Design Configurations for PCS-G," dated 6 July 1970.

B. Mechanical - See Memo 7978:70:0002 above.

C. Stress - As itemized in Memo 7978:70:0003, E.S.Chalpin to Dr. W.Weleff/H.Derow, Subject "BRDC Boiler #5 Operating Criteria for Stress Analyses," dated 6 July 1970. The method of approach will be as itemized in Memo 7974:70:0047 (File: SS1020), W.Weleff to H.Derow, subject "Boiler #5 Critical Areas," dated 10 July 1970.

D. Materials - This shall include a review of the post-test inspection of BRDC #1 and #2 noted in Memo 7978:70:0001, E.S.Chalpin to U.A.Pineda, Subject "Post-Test Materials Analyses of BRDC Boilers Numbers 1 and 2," dated 22 June 1970, dimensional inspection and metallurgical evaluation of the low cycle fatigue exposure tests of bimetal sleeves and Memo 7972:70:0075 (File: 2104), H.Bleil to H.Derow, subject "Metallographic Examination of E.B.Welded Tantalum," dated 2 July 1970.

3. PROGRAM PLAN .-

As itemized in PMR book, Ident. Code: 6-1.1.4 Detail (July 1970). A plastic model of the boiler design will be fabricated and tested as noted in Memo 7990-70-0049, from A.H.Kreeger to M.J.Saari, subject "Additional Authorized Work," dated 6 July 1970.

A final design review is planned for 23 October 1970 and will include all of the foregoing analyses as well as a complete set of reproducible drawings to be delivered to NASA-LeRC for fabrication of the boiler.

MEMORANDUM

TO: Distribution

FROM: E. S. Chalpin/A.J.Sellers

SUBJECT: SNAP-8 12 Tube Boiler (BRDC #5) Design for Revised System State Point Conditions

- COPIES TO: W.F.Banks, R.Chesworth, H.Derow, C.Hawk, J.Hodgson, A.Kreeger, G.Lombard, L.Lopez, U.A.Pineda, R.W.Marshall, Jr., L.Breindel
- REFERENCES: (1) "BODEPE IBM 360 Computer Code for SNAP-8 Boiler Heat and Momentum Transfer Analysis," TM 4921:68-551, Oct. 1968. (2) "PCS-G State Point Conditions - Revision Date 4/21/70,"

EDF Serial N.SAO014

ENCLOSURES: Table I - SNAP-8 PCS-G BRDC #5, Boiler Design Specifications and Operating Parameters Fig. 1 - SNAP-8 PCS-G BRDC #5, BODEPE Temperature and

Pressure Profiles

This memo presents the summary of the bare refractory double contained 12 tube boiler design analysis. Per NASA-LeRC direction (5-19-70), the mercury flow containment in the oval/round SS-Ta tube assembly with a multipassage plug insert (MPP) and swirl wire (SW) internal geometry was assumed to be identical to that of BRDC #4. To meet the revised PCS-G state point conditions (Reference 2) the tube count was increased 'from 7 to 12. Lower boiler operating pressure level and pressure drop, and increased mercury flow rate were reasons for the increase in the tube count.

Relatively good agreement between the BODEPE code design predictions and the test results of the SB-2, SF-1A and BRDC #4 boilers is the basis for the new boiler design approach. The heat and momentum transfer correlations used in this analysis are those established from the wetting and non-wetting two-phase flow models in a helical flow passage (Reference 1).

The summary of the thermal design analysis is presented in Table I. It specifies the assumed boiler cross section geometry and the calculated boiler MPP and total length requirements for low NaK inlet temperature schedule as well as the boiler operating thermal and dynamic parameters for the prescribed PCS-G systems state point conditions. Figure 1, shows the graphical interpretation of the predicted boiler performance characteristics at low and high NaK inlet temperatures.

ES Chalpus

E. S. Chalpin, Supervisor Mechanical Design Group Design Engineering Section Engineering Department

gs. Sellers

A. J. Sellers Analytical Design Group Design Engineering Section Engineering Department

TABLE I

SKAP-8 FCS-G BRDC No. 5

EOULER DESIGN SPECIFICATIONS AND OPERATING PARAMETERS

MECHANICAL

Design Concept:

Boiler Type:

Design Configuration: Number of HG Tubes Hg Containment:

TA Tube

Oval 321SS Tube: Effective MPP Length: Number of Helical MPP Flow Fassages: MPP Flow Fassages:

MPP Flow Passage Crossection

"Once Phrough" mercury prehast, boiling and superheat

Ferallel counterflow Mak-Te-Nik neat exchanger

Parallel tute Fundle-Ja-Tube

12

6"

In round 12 tube contained in oval 32188 tube with stagnant NaK in annular space.

•750" OD x .049 wall .836" x 1.45" x .549 wall 2.7 Ft., Tentalum ... 16

.062" Dia. x 2" Pitch. 90% Ta-10% 7.625" OD x .120" Wall, 31688

21,5 Ft.

Swirl Wire:

NaK Shell Tube:

Length-Centerline to Centerline of Wall-Inlet and Outlet

7978:70:0002:mrs

Boiler Crossection:

Effective Boiler Length:

Sec jable I 21.5 Ft.

		THERMAL			
Etem	Parameter	Sim bol	Dimen sion	.NaK Inlet Ter Low	np. Schedule High
L.	NaK Flow Rate	W _N	LB/TR	57148	57148
2.	NaK Inlet Temp.	T. No ‡	, Ö y	1185	1911
3.	NaK Temp. Drop	∧ T _N	Ó.F	170	167
+.	NaK Pressure Drop	P _N	PSI	~ 3	~ 3
5.	HG Flow Rate	. W _{HG}	LB/HR	13775	13600 :
5.	HG Exit Pressure	P Hbo	PSIA	148	147
7•	HG Exit Temp.	^Т нье	° F	1165	1190
3.	HG Inlet Temp.	THDI	्रम	420	420
} •	HG Vapor Region Pres. Drop	▲ P _{HG}	. PS I	je j	.46
0.	HG Flow Restr.Pres. Drop	▲P _R	PSI	143	140
L.	HG Inlet Pressure	P_Hoi	PSÍA	. 32 3 ,	-333
5.	Pinch Point Temp. Diff.	▲ ^Т рр	° _F	38	玛
3.	Terminal NaK-To-HG T	▲ ^T t	°F	20	-22
4.	Vapor Superheat	▲ ^T SH	°F	197	- 224
5.	Mean Preheat Flux	e." PH	b/hr-ft ²	- 188465 -	215553
5.	Me an MPP Boiling Flux	MPF	р н	- 49237	71292
7•	Mean SW Boiling Flux	q." _{SW}	tt	57921	63338
3.	Mean Superheat Flux	. q "	, 11	· 5176·	57.07
9• ·	Boiling Termination Point	^I 100	FT	15-4	13.4
0.	MPP Vapor Exit Quality	X _{PL}	.÷ %	12	18
L.	Thermal Power Reg'd.	· ĝ	KW	600,	598
5.	External Power Loss (Assumed)	'≉ _{HL}	μ.	5	. 5

٠

A-7

PRINTED IN C. 3-Y. ON PLEA IPPIN - "ECHNICAL PAPERING, 1015

CLEARPHINT CHARTS



FIGURE 1


26

- (b) Memo 7973:70:0007 from ES Chalpin/AJ Sellers to Distribution, dtd 27 May 1970, Subj: SNAP-8 13 Tube Boiler (BRDC No. 5) Designs for Revised State-Point Conditions
- (c) Memo 7961:70:0567 from CE Hawk to Distribution, dtd 22 June 1970, Subj: 18 June 1970 Preliminary Conceptual Design Review BRDC No. 5 Boiler

The PCS-G state-point conditions presented in Reference (a) are based on the boiler design calculations for the 13 tube configuration, as contained in Table I of Reference (b). The results of the boiler design review, per Reference (c), indicated that a 12 tube configuration should also be evaluated before a final configuration is selected for PCS-G. An action item from Reference (c) requested that the Systems Group evaluate the acceptability of the 12 tube configuration. A performance evaluation of the 12 tube configuration was conducted, based on the following preliminary design point information from Mr. A. J. Sellers:

$$T_{NaK in} = 1185^{\circ}F$$

 $\Delta P_{vapor} = 32 psi$
 $\Delta T_{pinch point} = 38^{\circ}F$
 $\Delta T_{terminal temp.} = 20^{\circ}F$

The results of the evaluation by the Systems Group are presented below, along with the design conditions for the 13 tube configuration.

.

		12 tube config.	13 tube config.
W _{NaK}	(1b/hr)	57050	57050
^İ NaK in	(⁰ F)	1185	1185
△ P _{vapor}	(psi)	32	26
$\Delta_{\text{pinch point}}^{\mathtt{T}}$	(⁰ F)	- 38	44
$\Delta T_{terminal tem}$	p. (^o F)	20	20
W _{Hg} vapor	(1b/hr) .	13775	13775
P. boiler out	(psia)	- 146	145

A comparison of the above results shows that, although some variations exist in the boiler operating characteristics, the interface conditions remain essentially unchanged. Therefore, if the 12 tube configuration is adopted in the future, there will be no significant changes in system state-point conditions, but boiler operating characteristics would be reflected in a state-point revision.

R. S. Seiner

R. G. Geimer Systems Management SNAP-8 Systems and Test SNAP-8 Program

APPENDIX B

BOILER THERMAL ANALYSES

AEROJET	AEROJET NUCLEAR SYSTEMS COMPANY	ENGINEERING FILE NO	DE-0048
GENERAL	FNGINFERING DESIGN FILE	DATE .	10 September 1970
PROJECT	SNAP-8	W. O. NO.	
SUBJECT	SNAP-8 12 TUBE BOILER (BRDC #5) M	ERCURY INLET END T	HERMAL MAPPING
ABSTRACT	hermal analysis was made on the BRDC	#5 boiler mercury	inlet desígn
eor	ifiguration under PCS-G start-up tran	sient and steady-s	tate operating
eor	ditions using TAP computer code. In	e results of the a	there have a second
pro	ovided for several design configurati	ons in the form of	thermal maps
ແດະ	design I and the accessized thermal	manning is recomm	ural elements.
211C	rose of checking the boiler mercury	inlet end structum	al relighility
pur	om the combined thermal and pressure	stress viewpoint.	21 ICLIMPETION
•			
DISTRIBUT	FION C. Hawk, U.A.Pineda, R.W.Marshal A. Kreeger, H. Derow, W.M.Waters	l, Jr., G. Lombard . File	, L. Lopez,
COVER SH			
KEY WORD)S Thermal analysis structure] .]	ents temperature	gradients
	vacuum insulation	chio, competadate	
AUTHOR	A.J. Sellear DEPT REVIEW	ED DATE DATE	REVEWED and ALL DATE
			· · · · · · · · · · · · · · · · · · ·

INTRODUCTION

The purpose of this memorandum is to present the boiler mercury inlet end thermal design analysis. Because of relatively very high temperature difference between the primary NaK flow exit temperature ($T_{\rm Nb0}$ = 1210 to 1045°F and the mercury inlet temperature ($T_{\rm Hbi}$ = 80 to 420°F) during the startup, the boiler mercury inlet end structural elements are exposed to severe thermal transient gradients. One can also visualize that under the steady-state operating conditions there is a significant temperature difference ($T_{\rm Nb0} - T_{\rm Hbi}$ = 1045 - 420 = 625°F) between the NaK exit and mercury inlet ports. To assure the boiler mercury inlet end structural reliability, the above temperature conditions have been investigated in a series of different inlet end design configurations. The readily available TAP-IBM 360 computer program was utilized to determine the thermal gradients in the various structural elements of the boiler during start-up transient and for the steady-state operating conditions of the boiler. The following sections describe the analytical approach, the results of the analysis and the selection of the optimum mercury inlet end design configuration.

I. THERMAL TRANSIENT AND STEADY-STATE CONDITIONS IN THE BOILER MERCURY INLET SECTION

The basic mercury inlet end design configuration is shown in Figure 1. Prior to mercury injection the boiler is exposed to Nak flow at T=1210 F. The forced convection NaK flow region extends up to the stainless steel header where it exits from the NaK shell tube by means of 12 radial ports and an annular manifold around the NaK shell. Under these conditions the structural elements as well as the stagnant NaK contained between these structural elements assumes the flowing NaK temperature when there is no heat loss from the outer surface of stagnant NaK containment shell. During mercury injection, the mercury flow and inlet temperature as well as the NaK temperature are acting as forcing. functions in accordance to Reference (b) conditions until the steady-state boiler. operating conditions are established. The early part of the mercury injection is visualized as immediate mercury vaporization (flashing) on the hot tantalum surfaces until the buildup of the pressure in the boiler surpresses the mercury vaporization. Thereafter, the relatively high available capacitance around the tantalum bell can be the reason for transitional subcooled mercury boiling until the thermal capacitance is consumed and the Ta wall-to-bulk Hg temperature difference is reduced to a level compatible with the forced convection liquid mercury preheating flow regime. Following the capacitance consumption and the final Hg flow establishment, the boiler assumes the performance characteristics as provided in Reference (a). The determination of the temperature distribution in the boiler Hg inlet end is provided by the following analytical approach.

-3-

II. ANALYTICAL APPROACH

The basic inputs for the boiler Hg inlet end thermal mapping are the structural geometry and the time functions of T_{Nbo} , w_{Hg} and T_{Hbi} respectively. In view of the radial symmetry of the boiler cross-section only 1/24 or a 15° sector was selected to generate the three dimensional R-C network for the thermal analysis. Readily available TAP-7 IBM 360 computer code was útilized for the analysis. Typical radial and axial R-C network arrangements are shown in Figure 2 and 3 respectively. Strictly conductive heat transfer passages were assumed through the stagnant NaK volume and structural elements of the geometry. The heat source $T_{Nb0} = f_1 (\Theta)$ in the forced convection region next to the SS header was coupled axially to R-C'network by $h_N = 3000 \text{ Btu/hr} + \text{ft}^2 - F$, which is the calculated NaK side film coefficient in the boiler proper. Similarly, $\mathbf{T}_{Nbo} = \mathbf{f}_1 (\mathbf{\Theta})$ was coupled radially to R-C network axial layers surrounded by the annular NaK exit manifold using a conservative $h_{N} = 1000 \text{ Bfu/fir-ft}^{2}\text{ }^{\circ}\text{F}$. The the annular Nak exit manifold using a construction N heat sink represented by Hg flow passage volume capacitances was coupled to the -5000 1000 and 500 Btu/hr-ft² F Ta wall by mercury side film coefficients of $h_{Hg} = 5000$, 1000 and 500 Btu/hr-ft² in the plug insert region, open tube region and the Hg inlet region up to the Ta header respectively. In view of possible flashing and subcooled film boiling of mercury, as will be shown in the following section, these film coefficients may not be realistic during the early part of the mercury injection period $(\theta = 0 \text{ to } 30 \text{ sec.})$. Based on Reference (c) Figure VII-2 plot, the mercury vaporization at elevated surface-to-saturation temperature differences $(\Delta T = (T \text{ surface } - T_{net}) \gg 20^{\circ} \text{F})$ takes place in the transition and film boiling regime. This boiling regime is characterized by relatively low film heat transfer coefficients (h 🔨 500 Btu/hr-ft²-^oF) and high temperature gradients across the vapor film. The latter condition implies that relatively uniform Ta chilling will take place in the Ta bell area during the early part of the mercury injection period. The employment of relatively high mercury side film coefficients as indicated earlier during the transition period will, therefore, résult in conservative (high) thermal gradients in the structural elements containing the stagnant NaK. The assumption of strictly conductive heat transfer passages through the stagnant NaK volume is based on the condition that this volume will be subdivided in relatively small cells in the actual design thus approaching a solid configuration. The purpose of these cells is to prevent the natural convection effects in the stagnant NaK volume. In view of the relatively high thermal diffusivity (1.47 ft⁻/hr) of the NaK the compartmentized NaK volume can be treated as a solid conductor. Under these conditions a uniform and symmetric R-C network can be visualized around the individual Hg tubes between the SS and Ta headers and the Hg inlet passage up to the Ta header. The physical properties of the structural materials and working fluids were taken from the SNAP-8 H-100 Manual.

Several mercury inlet end design configurations were investigated to determine the most plausible thermal map for the boiler startup transient and steady-state operating conditions. The purpose of this mapping is to identify the locations of the maximum temperatures gradients in the structural materials and to evaluate the most prospective design configuration in the light of allowable stresses and overall structural reliability. To minimize the thermal gradients in critical areas, the application of vacuum insulation was considered in the form of annular and/or radial stainless steel vacuum cans. Radiant heat transfer across the vacuum space was specified assuming the emmissivity of the shell SS surface (g = .55) for the temperature range 0 to 1210[°]F.

III. DISCUSSION OF THE RESULTS

The initial results of the analysis are provided in Figure 4. It represents the basic boiler mercury inlet end design configuration with different annular NaK exit manifold locations denoted by DES A, B, C, D, E and F respectively. The comparison of the corresponding NaK shell-tube temperature profiles (0-----0) under steady-state operating conditions $(\Theta_{11} = 1200 \text{ sec.})$ reveals that relatively severe NaK shell-tube axial temperature gradient occurs at the termination point of the annular NaK exit manifold. The plot (x----x) referring to DES E and F represents the SS header radial temperature profiles for KND-1 and 2 respectively. Both (x - - - x)profiles also indicate severe radial thermal gradients between points 1, 2, 3 and 4 and 9, 10, 11 and 12 in the radial plane of KND=1 and 2 respectively. To minimize the NaK shell-tube axial thermal gradient at the NaK exit manifold termination point, the vacuum insulation can was placed inside the NaK shelltube, and the NaK exit manifold termination point was located between the KND = 4 and 5 as shown by the DES. G in Figure 5. The NaK exit manifold] termination point location as provided in the DES G is a compromise consideration. Firstly, it ensures a symmetric primary NaK temperature environment around the stagnant NaK volume between the SS and Ta headers, thus preventing the stagnant NaK temperature stratification under adverse heat input conditions into the mercury. Secondly, in conjunction with the vacuum insulation, it reduces the heat input from the primary NaK into Ta bell mercury volume thus minimizing the mercury vapor generation during the early part of the mercury injection period. A complete thermal map of DES G is depicted in Figures 5 and 6 for the SS and Ta structural elements of the boiler. As denoted by $(x - - - \dot{x})$ plot in Figure 5, the maximum axial temperature gradient occurs in the stagnant NaK containment tube (SS) during the transient state ($\theta_8 = 300 \text{ sec.}, \Delta T = 1031^\circ \text{F/in}$). A relatively large temperature gradient also results in the same tube ($\Delta T = 708^\circ \text{F/in}$) and the SS header (308°F/in) at the steady-state operating point ($\Theta_{1,1}$ = 1200 sec.): To minimize the thermal gradients in the stagnant NaK containment tube and the SS header as well, the DES G was modified by placing the vacuum can insulation around the Ta tubes in the SS header area as shown in Figure 7 for the DES H. The resulting temperature profiles of this design are depicted in Figures 7 and 8 for the SS and Ta structural elements of the boiler mercury inlet end. The examination of these profiles shows them to be the most plausible thermal gradients in all the structural elements of this design configuration. When considered in the light of the mercury tube circumferential pitch spacing as specified in the boiler layout $(D_{\text{pitch}} = 5.65 \text{ in})$ the vacuum can placement around the tantalum tubes is not possible because of spacing limitations unless the Ta tube pitch diameter in the SS and Ta header area is increased. An alternate modification of DES G and the associated temperature profiles are shown in Figures 9 and 10 which becomes DES J. This design incorporates the radial vacuum insulation can placed on the SS header face on the stagnant Nak volume side. The purpose of this vacuum can is to minimize the axial and the radial temperature gradients in the stagnant NaK containment SS tube and the SS header. As compared to DES G the temperature gradient reduction in DES (J) at Θ_0 and Θ_{11} are from 1034 to 1028 F/in. and from 757 to 748 F/in. respectively. The comparative axial \blacktriangle T reduction across the SS header is from 492 to 412 F/in and from 406 to 154 F/in respectively. The latter is a significant improvement over DES G. The combined effect of vacuum can placement on the Ta tubes in the SS header area and next to the SS header on the stagnant NaK side is shown in Figure 11 and 12 for the DES K. As compared to DES G, the effect of the DES K vacuum can placement is the SS header axial temperature gradient reduction from 492 to 55°F/in. and from 406 to 34°F/in. at transient and steady-state operating conditions respectively.

The stress analyses of the mercury inlet dome indicated that the initially proposed configuration would not meet the stress requirements. During the same period, a decision was, made to replace the 4 stage turbine with a multi-stage reaction turbine. This change resulted in a decrease of the steady-state mercury inlet temperature from 420°F to 350°F. These two inputs prompted a redesign of the mercury inlet configuration. This design change is shown in Figures 13 and 14 as DES L:

The use of the vacuum cans, the location of the flowing NaK manifold (tee), etc. remained the same as that noted in DES K. However, the distance between the tantalum header and the mercury inlet bimetal tube was increased to accommodate the larger tantalum dome. The volume of the mercury in the dome was increased over DES.K which in turn increased the time to fill.

Table I shows a tabulation of the maximum axial temperature gradients or various mercury inlet and design configurations considered herein.

· CONCLUSIONS AND RECOMMENDATIONS

The results of the boiler mercury inlet end thermal analysis under the prescribed start-up transient and steady-state operating conditions lead to the following conclusions and recommendations:

1. Because of relatively high temperature differences between the NaK heat source and the mercury heat sink the SS NaK shell tube, the SS header and the SS stagnant NaK containment tube are exposed to relatively high thermal gradients in the basic inlet end design configuration.

2. Under steady-state operating conditions the maximum thermal gradients are located in the structural elements next to the convective heat source,

3. Under start-up transient conditions the maximum thermal gradients are located in the structural elements next to the capacitative heat source,

4. Plausible thermal gradient reduction in the critical structural elements can be secured by selective utilization of vacuum can insulation,

5. To minimize the axial thermal gradient in the NaK shell the placement of vacuum can insulation on the ID of the NaK shell is recommended between the annular NaK exit manifold termination point and the mercury inlet SS plate,

6. The annular NaK exit manifold termination point is to be located in the radial plane next to the tantalum header in the downstream mercury flow direction. This annular manifold location will secure a symmetric thermal environment around the stagnant NaK volume between the two headers, and substantially reduce the temperature st ratifications in it,

7. To prevent possible free convection effects in the stagnant NaK volume the compartmentization of this volume is to be provided,

8. To secure the minimum axial and radial thermal gradients in the SS stagnant NaK containment tube and the SS header, the vacuum can placement on the Ta tubes in the SS header area is visualized as a most desirable design feature. Unless the Ta tube pitch diameter is modified to a larger value in the SS and Ta header area the vacuum can utilization on the Ta tubes can't be realized.

9. Because of relatively high thermal conductivity, the thermal gradients in the tantalum structural elements are expected to be within acceptable limits,

10. The recommended mercury inlet end design configuration and the associated thermal transient and steady-state conditions of the structural elements are depicted in Figures 1, 13 and 14 respectively.

11. The thermal mapping shown in Figures 13 and 14 is provided for the purpose of checking the boiler mercury inlet end structural reliability from the combined thermal and pressure stress viewpoint.

ς.

. '

REFERENCES:	(a)	"SNAP-8 12 Tube Boiler (BRDC #5) Design for Revised
	('n)	System State Point Conditions,"7978:70:0002, July 1, 1970. "PCS Startup Transients Affecting Boiler Inlet Section,"
	(c)	HDS Serial No. SA-0051, June 2, 1970. H.F.Poppendiek, J.F.Brown, et al., "Investigation of SNAP-8 Boiler Conditioning and Heat Transfer Character- istics in a Mercury-Tantalum System,""NASA-LeRC Contract NAS3-11836, Geoscience Final Report GLR-78
ENCLOSURES:	(1)	Figure 1, Mercury Inlet End, Design Configuration,
	(2)	" 2, Typical Radial R-C Network, DES.L, KND =
	(3)	" 3, Typical Axial R-C Network, DES.L, KND= -3
	(4)	" 4, BRDC #5 DES A, B, C, D, E, and F
	(5) (6)	Thermal Map "5, BRDC #5 DES G, SS Thermal Map "6 BRDC #5 DES C. The ""
	(7)	"7 BRDC #5 DES H SS "
	(8)	
	(9)	" 9, " " DES J. SS " . "
	(10)	" 10, " " " " Ta. " "
	(11)	" 11, " " DES K, SS " "
	(12)	" 12, " " " "Ta " "
	(13)	" 13, " ' DES L. SS " "
	(14)	"14, """""Ta, """
	(15),	Table I, BRDC #5 - Temperature Gradients of Various
		Hg Inlet End Design Configurations

TABLE 1

T	REF.	MAX	· AXIA	L TEMPE	RATURE	GRADI	ENT.	OF/IN				TIME REP.	ERENCE	
LIED .	FIGURE	Nak	SHELL	STAG -N	ak tube	TA T	UBE	88 H	EADER	TA H	EADER	TRANSIENT	STEADY	FEMARKS
		T	8	T	S	T	8	T	8	T	<u>8</u> .	T	3	
A	4		587						363	:	· ·		X	
·в	4		649		ι.				372				X	· ·
С	4		416	· ,		[ľ	354	· ·	[·		x ,	
D	4		364						348				' X	
Е	4	}	418					{	409		ł		x	
F	4		508				 		455				х.	
G	5,6	539	217	1034	757	502	317	588	409	* 188	130	х	х	*Ta Bell
н	7,8	539	217	194	129	855	489	440	301	*18 8	. 133	х	х	*Ta Bell
J	9,10	539	217	1028	748	569	314	480	335	*188	125	х	х	*Ta Bell
ĸ	11,12	539	.217	394	308	917.	498	55	34	*188	122 .	X	x	*Ta Bell
L.	- 13,14 .	342	186	. 717	509	- <u>5</u> 09-	- ":320		-410 -	· 334	137		,	

BRDC #5 - TEMPERATURE GRADIENTS OF VARIOUS HG INLET END DESIGN CONFIGURATIONS













KND= -3 -2 -1 1 G



1212	細胞	1.1世		2 10		H. L			24	嘲	12	- 19	63		¢a(≕	ि से स	LT:		121		1		F		-21 1	- Lu	1		F	171
							44	212.20	ΠP,					1 至	評		VRCE	16.14 1	相如	ATHU	¥ -				SNAI	2 8 B	RDC #	1 前	SIGN	R.
	1.15		常虎	6		2. II.			r_{11}	15	1		155		1 L		122				1	Ľ.		S E	HER	MĂĻ	MAP		. = /	ŝ j
5	¢.∔.		l in Li						1	X			日子	¶i]	1 13	k.			· 254											
	124 - 124					2 P 7 F	h.t.		V				A.							1		75-14			۰ <u>۴</u> ۰۰		<u>.</u>	Ĩ		
	- 48	44 /	7 /22					• . •	/#/			16	15 '	<u>1</u> .		N.								-		· · · · ·				÷.
E	- 1		13	- L		3 - 1			17			-14			1	143	+								÷		+			20
111	n yr			133					40	2	-		λ_{i}	,	1		€ 5-		fii	翼三	- Ei		+ +	···	°1, :::	: ;	+		fer fr	20
1				Hist		7	Ú de A		17	đ ,		¥	\mathbf{X}					ي الم	Ť	* -			1							f i
111-1	1777	фosh							AP.	1			K:/	اَبْ 🕹		175			H t				1		<u> </u>			*	in the	1-1
	- II:	11.	E E	(Th						"¥1		11	λ	\mathcal{F}	1.1				H f			 ''			· .;	┥╌┼╴	+.†-			
		十十言	三幕	L IX	[]+; ::	स मार			11/2		╞╴╪╴	· 4 - #	-i>	\sim	X	100	Gr .	1 4			- 27	<u>+ - -</u> -		10			- -			1
	· [1 4			-	- <u></u>			A :	7					44	₽‡2	¢.	ð z li) z		ः र	ΞŻ	12	Q.Z.	2	<u>.</u>	·		<u> - 2</u>	10
												-4	GR C	1/*	1	<u>₩</u> -	+-					<u> </u>		107		<u>.</u>	· · · -	6	₩=44	<u>qu v</u>
KHO -	<u>וּ י</u> וּ	9	42.42		1	- 23										172		- 22-		- 11		15	li il	-	24	<u> </u>	<u> </u>		- <u> </u>	+
	P			-17	K-+-			4	- 12	G			P. -	1		HI -	<u>н</u> г.	-15	14-			ю	+-+	-17						- <u> </u> - <u> </u>
1		1.107	12:00										·		+				+		·	<u></u>	1.			80/	LER	HG	INL	<u> </u>
				ŀ-ŀ-ŀ	╟╦	-,							. .	<u></u>	++	╢╌┾╶	·	┥┨╤╌┦╤	+		-	+-+-		<u>-</u>	<u> </u>	THE	RM	86.7	<u>n r a</u>	NS
1121 12 - 12	l .i		1400-	1	<u> </u>		<u>+-</u> }	<u> </u>	-		<u> </u>				<u></u>	╢┼	- -		H			<u> </u>	· .::- -						1	
	<u> </u> <u> </u> :		<u></u>	- di-			<u></u>	-+;			·					╠╌┼╶			<u> </u>			₩+-				4.4.				
		+	1000-			<u>0</u>								+	-	<u> </u> ;		<u> </u>		<u>.</u>		╎╌╌┥╌╌				·	++++		╇┷	
	<u> -</u> -			1-N	1	-14		-2				= 7 -	in the second	\$ −		╠			┢┟╍╼┤╴			<u>∔</u>		-			! .			
			-000-		4			L AN		5	×₽	\rightarrow	5 -∔-	1÷		∦ -∔-	┢╌┾		<u> </u> -			····		1		<u>-</u>		<u> </u>		<u> </u>
- ! -		1		111	<u>∦</u> ≞	\	6 – J	[]		N -	4 ∯	(-[]	<u>\</u>	<u> </u> -\	Q.L.				-		44		<u></u>	1.	· ·					
- 1-1-1 -	·[<u>ц.</u> 	-500-	17-	<u>4</u> –		¥-1	4	EN	34			_\¢		¥	╟┈┼╴	<u> </u>	_#!	4-1.			┝╍╍┝╌╴	1		<u> </u>				1	
					. .¥€ -	1	Λ_{\perp}	$\mathbb{P}^{\mathbb{N}}$	L	XI	γĽ	λa	L.K	1 -	<u> </u>	# !-		4.					.:	4i - i					1	<u> </u>
·: ·	ļ	<u> </u>	700-		1.	, l∛	4. 1 ;		XI.		Ĵ.	-44	i(¢.	+	<u> </u>		_#	+		-14			4	<u> </u>	-ŀ	<u> </u>			م
	ļ	- • -			- · · ·	<u>\$</u>	k	k	\square		-\([- \		4.1.	q.	RI	i.		ll	4.			i l	_				. i	100	bbo,
		<u>щ</u>	-600-		- 	<u> </u>		$ \lambda $		¥4	<u> </u>	-1-9	la i	44	42	ih 🔨						<u> </u>	<u> </u>	<u></u>			L	N N	01 "	- <u></u>
		Ę.						∮ -]	М.,			<u> </u>	L_[1	<u>ф. </u>	<u></u>		¥					<u></u>	<u>i </u>	4. –		!	i	\square	1	
	<u></u>	E C	560-	22	∯_£				1			<u> </u>	<u>h</u>				<u> </u>	*=	h				!	<u> </u>		, '		<u> </u>		
11.	ļ	<u><u> </u></u>			<u></u> ¶_€_	4				-41	-4		فانحوا	Į: :	J	₽ <u>-</u> +-	<u>4</u>	å⊟⊰		潮口.		<u> </u>	11	<u> </u>				1		
Ë	L i	<u> </u>	400-				4.7								¥	(a.	Q			3 ~//				1			<u> </u>		<u> </u>	
					<u></u>				تد أنها			. []		1		ļ	!		¦				ľ.				.i	<u> </u>		
i i	<u> - </u> _		-006				· ·					_ <u> </u> .			<u>.</u>	ļ :	i				:				<u>.</u>	·				1
<u> -</u>	Ŀ.											_	-			l. L.	. i.		1			-			. L.		1			
: :-'		·:	200				1.1		1		<u> </u>		- + -	4-1-			1	ļ : ;	·		·					<u> </u>				Ti
	- t	···		<u>F. ·</u>		<u>i li l</u> i							· ·	F • •					· · :	· II· II ·					. [1		TT		· [:]
	<u> -</u>	· · · · ·			1 .		1	<u> </u>			- 1-		·	· -).		•			:_].		T		[].	F	·	T - -	1	1-1.		FIG
·	- ' -	17						f -]		T	1			1	-	<u> </u> _j.							1 ::						1.1	1.1
	1	1	-11	1117	1	- 18 i i i i i i i i i i i i i i i i i i	- F	1 1 1	11 H F	41 F T	: T	1	1.1	11.11	· []	H.177	1	B	1	-II	⊐r-t		T. Tr	11			T -1'	F - +	1	· +

FOLDOUT FRAME		1 A			EQLDOUT FRAME 2
φ φ φ	$\frac{21}{29}$ $\frac{35}{29}$ $\frac{47}{29}$	2 33		`	
			7 7 6 30 4.6 7 30 6	SNAP-8 BRDC #5, DE	SIGN G
					30 ··· · · · · · ·
AB 140 127 102 104 104					
1 11 12 19 19	TA				
	STASNANT MEROMA				= 180 +
TREATURE	MART B	XX STAGN WE			, ≠ 240 , P
		× 10 10 0			- 900 -
		MERCHARL		6	=1200 +
135 132 129 134 17 13	23 31 7 -	51 54 6 27 72 78 8	2 22 - 11 - 135 - 1	- 1 <u>1</u> 1	
$k^{mp} = -3$ -2 -1 0 1 2	3 4 5 6	TB91011121	3. 4. 5. 16.		
				THERMOL	TRANSIENTS
			9 93		
O B B B B					
7579					
			╲┝╫╧╧╢╧╧╌╠╬╌┿╶╖╶	┽ _{╋┙╋╧} ┝╧┿╍╋╺╬╌┥╌╴	
			15	9 F/m	
500					
			N 0.01		
+					
			0 03		j,
			· · · · · · · · · · · · · · · · · · ·	╡╴╫╬╴ ┽╴╫┿╴╷╶╦┉╎╺╦╬╦┨╒┱╬╼┊╺╷┥╸	
200					
		····↓··↓···↓↓↓··↓			FIGURES
	v	LENGTH, INCHES	B-13		197 y-31-70

.



B-14

FOLDOUT ERAME

FOL	DOUT	FRAME C
		The turner of

FOI	'noi	TT.	E Nowar
100	-00		FRANCE.

FOL	DOUT F.F	AME		5	13	21	. 24	عالة	<u>5 4</u>	2 4	7	i i	39	;	• •																
	Letat		ر طرطون			19	C IN	s , B	₩ ₩ ₩	5.99		好 年		65 81:1	41		<u></u>	3141		- 1:-		<u>f</u> re:	-1-54	<u></u>	E.T.ª	Hera	- <u>† (}-</u> 11	iin le	1751 -	रस्रितः	्रतसंग
									₽́	F	Ϋ́́			ŇŤ	-	VR ALR	17. 1	n set	A7 -	7				NAP	8 B	a c i		SION	H		
							11 11 11 11 11 11 11 11 11		17			175		1		1.11					国.;		55	HERA	IAL I	4).P (. 9	-	5 <i>.se</i>	C .	HH.
		-5							1- 1	[]_		1	1	,	<u>, 7/</u>								- <u></u>	- <u></u>	[; ·		ė	. = 3	0.		
			X10						Kit	1		(51	<u> </u>		N		[<u></u>		<u>.</u>	<u> </u>		<u>'<u> </u></u>			e	<u> </u> ≔ 4	<u> - 1</u> 1		
р 								ľ	Ł	4	+ E		4 :	·· · 	NI L	1	li ili	-					1171				1. 6			1	17. (2.
	, di se di s	÷.	t V	=		· #		Ξľ	HEAD.		, i	1	:		- 12	×.,		<u> </u>	31						<u> </u>		E		201		
		÷.		Hê	ACCER		NGA		行者		+	\mathbb{N}	بنید. د. ارم				<u>.</u>				ŀ						6		1		
		REUDI	y	- [b [á¶		(\cdot)	Kind	NA	(1 (fi	1	忙杖	i N			1			<u> </u>	1			00		
								· · · ·	Ľ			. K			1.				1.			i			1.1.		G	= 6	00 +		
			··. :		4	-		· · · [K.				$\underline{\mathbf{X}}$	<u>}</u>	16	50 8	∮ · [†]		4	197					<u> </u>		6		00	·: ·: ·: <u>·</u>	: i i i i
				 [i					14		M	ENE	1] "	<u>i f</u>	┟╌┊╌┤	# <u> </u>	* *				+	15-		1 - +		L. f	= [2	00 +		
2		5 132	129 14	24 7	14	- 23!		31 [.	1 -		51	57	W .	6 7	72	71	92		<u> </u>		1 7	LĻ	10			101	1				
		3 <u>-</u> Z	11	244	- 12-			41	5	Ģ	7	B	9	₽0		12	3	 4	_ 15_		6	++	17				ł÷		_		<u> </u>
-				~ \$										<u></u> ∱≝=4		}_≪{	} ∢	\$	비행		<u> </u>		<u> .</u>		BoyL	ER A	(<u>c //</u>	1607	ENG		-
÷		V-TV		7 F	S\$⊂		\leq	شب ا			w	1 - 1	<u> </u>								+			<u> </u>		–		an.	5/6/1		
-	Of Car	2-12		計書	च् <u>व</u> े							h	÷	†÷				11/2	1	·						· ` ¦		<u> .</u>],			. .
,	050	S T S		218	<u>_</u>	-					*7		4- 1- + 1	Ī			1/15	۲T)	79		1.			-				+			
	$e_{\eta} \epsilon$	9-0	-0-5	¥Γ.	Y.			<u>∖</u> y–;	Ser al		<u>م</u> لام	<u> </u>			1.1	<u>R i</u>				. []		1	1				·				
				⊶₩	¥ :		X	\sim				<u> </u>	1		<u> </u>			¥			<u> </u>	l l	ļ!	<u> </u>	 	· · · ·		·			· ·
	- 		•		N		1 *	A		<u> </u>			╠╌┼	¢.,.,	[<u>ا</u> ر ک		. <u>.</u>			t	1. 44	i -		<u> </u>	ļ	-	-	·		
-				ᆑᆛ	i-#-i	i-			41			7	-	↓	<u> </u>	\mathbb{A}^{-}	<u> </u>				+		<u> </u>			11	<u> </u>			<u> </u>	· .
	· · · ·				;	; - ² 5			1 -1				·		₽ -)	$\mathbf{k} $	1 <u>\</u>				·	<u>.</u>	<u>_</u>			·				·	-
1		9	70	╺┥┤╴		··			+	+ +							<u> </u> `i,—			-++	•• •=+ •- ·	<u></u>	1		⊢ i -	+	•	+-:-:-	17		+
		ki			1							1			;	\mathbb{N}	1	1.	1	-	··· ··	Ì−- ·	[j	· ··					· -i ··	· []	
	1	1	60	°1- -				1								[]	(1)	0	Fla	- † †			Ti T		<u> </u>			· ī	1-1-		
Ļ		ER A	i i i i-50			t				ļ.		l.i					3/2	1.30-							- : 			<u>.</u>		<u> </u>	
-		- 4			- -		·	;	li						.	$ \rangle$	14		$\Phi \Theta_i$		Ļ.	·	<u> </u>				Ļ.≟		+		
Ļ			<mark>i-40</mark>		' ∦						┨ - ┥	⊧	<u> </u> _	┥┄┈┥			\overline{VH}	¥+	4	"∔		<u></u>	<u>+</u> -	¦		ļ., !	<u> </u>	<u></u>	·	-	· · · ·
	· ·· .			· -	. ·	┈╌╠╌┝				·		· ·		. ·	.:	· ; ·						;;	;	·····		₩ .	<u>∔</u> - ⊹ .		1 12		
-				0 + 1		·			$\parallel \cdot \cdot \cdot +$		f		╞┼╌┥	┉	┝╍┼╍╶	+;	, 	╂══	- 1 ST		;		╬╍┨	 :		┝╌└╴		1	+	<u> - </u>	•
.	· [!	•	···				···+·	· • • • • • • •		 	<u>+-</u>	⊢ <u>†</u> ~	. * • - ·	·:				1	ti i	:			<u> </u>		- 12	1		i i i i	+	: <u> </u> -	-
Ī	,	· j						-													7		t I		i	<u> </u>	<u>†</u> -,†			÷	l'
							: ·																			<u> -;-</u>]		FIGU	RE7	ा स्ट्रो इ
				14		, <u> </u> , .].	. .		1		· .				! .	ļ. ļ	;	<u> </u> .:!:			 	i.	1			1.	Ŀ				2
L		i	i.le	غل ألك	<u> </u>	<u>i li</u>	<u> i i</u>	LJ.		ن إِنَّا	17	Ľļ.	<u>[</u> - ·	<u> </u>			ļ	ll.	<u>li i</u>		L <u>Į</u> ∶)	<u>II. j</u>		. [.]	<u> </u>	<u> </u> ,	Π.	<u>.</u> [.].	•	
						1	•	<u> </u>		3		4		- b			۰		1		8		9			0				~ /	

OUT FRAME /	5-13			29	- <u>5</u> -4	2 47	<u> </u>	1 - 59 - 11												rul.	มงกวั	i era	ME <				
		12 1	TAC. IN								TR COL													7			
				0 - 1			6												IRA		AP ,		41+	Ś	ec.		
	72 11 22						Ø	, 11. 11.										11 J 11 J 11 J				6		<u>30 -</u> 13	*		
		<u> </u>						; † ⊤ · ¦; ; ·			R.		5 - 9				· · ·		Ļ.			G		120 120			
	44.85	R	37 <u>75</u> 1				Ŷ	\int_{-3}^{7}	TREN															240	*	-	
			····	╢┼╴┟	44			¢\$								++-						6	2 1	100 100	•		<u>.</u>
							Istr			10	90. × 				- 201- - 201-	k k	Å	<u>,</u>	Ŧ	··· ! ·			5) e 5 5) - 1	200	•	:	
ND = -3 -2 -	09 Z	2	13	31	- - - - - - - - - - - - - - - - - - -	F C 7	1 : 5 <u>*</u>			72	זאר 12	22	и.	5				7			- 12			1 			
		۵						·/···/┙╺				2-i						±		Boik	¢R.	HG 11	V6 (- 81	v D		
	•• ••	1						₩- + : 								· · · · · · ·				THE	RMA		S O M	5/ <i>6</i> /	~ 7.5	_	
	DO-	··· <u> </u>				.	<u>}</u>		- - - -	. l : ·	·				- 11.		+ +	· . · · · ·				<u></u>					<u></u>
× 0				<u> </u>									<u> </u>			· 			1				_	- <u>-</u>			····¦
		2					$(\uparrow \)$	<u>.</u>								<u> </u> . <u>+</u>	$\downarrow \diamond$	θ,	1					-: <u> </u> -		+ :	-
011 52										-		1			;	i	┼╫	-		·· + ·	· · · ·		<u> </u>		<u></u>		<u>.</u>
		/			fre.								;; ,					:0e			_` -					++	
	X										/												-		· .		
		/	7.46		5 8.		$\frac{1}{100}$		- KQL							1		e,									<u>-</u>
────┴──┴──╎ <mark>╶╢╡</mark> ── ┼┩ € _{╲╵╵} ╴┥╍┙┆╶╎╶╸┝╼ _╈ ┑╍╸	┝╋┥┽╵┿ ┆╴┥┼┵╵	` !		┿╼┨╍╼╬ ┿╴╎┄╺╢╸		<u> </u>	<u></u>		X		<u> </u>				X			9						···		<u></u>	<u>` </u>
	0-		· · · · · · · · · · · ·		· 				· <u> </u>			1/			: 	K		·			·			- <u>i</u>			<u>. 19</u> 1111
2	∳o _ ↓												0					\leq							۱ ۱		
**************************************								· · ·											\square			9			SURE	8	
			i							<u>[[]]</u>	i .		[]	<u> [.</u>		1.1			<u> </u> .		ه ۲			111-1:	:		

.



FOLDOUT FRAME /

EOLDOUT ERAME <

.

LOUT FRAME /	5 13 21 29	35 42 47 99			FOLDOUT FRAME Z
			AT THE PACENCES	MSULA TOPA	SNAP & BRDC # DESIGN T
					A THERMAL MAP & 9, = 15 sec.
					G₁ = 30 +
	5 83 S				
		HEADER XA			
	MAR ALAN		STRGN AT		
- PREQUM			OB MONTH		G = 300 +
	┙╡ ┷┯╪╍╫╵┺╴╧╲╴╴╴╴╶╷╍╍╴╺┱		Xu05		703
					6 - 900 -
·					$-\frac{1907}{100} + \frac{1}{100} + $
KM2 - 3 2 -	ρ_{1}		· · · · · · · · · · · · · · · · · · ·		
					BOILER HE INCET EN2
					THERMOL TEANSIENTS
				╪ <mark>╎╍╍┍╺┟</mark> ╎╍┎╧╧╎╴┧╒╍╹┼╍╍┽┅╺╎	
	XN			<u> </u>	
	Cod &				
314-7/17					
			<u>+ - -</u> - - - - - - - - - - -		╌╂╍╍┠╍╌╌╴┟╌┈╸┥╺┅╸┽╾┅╍┼╍┅┯┼╴┼╴┲╺┥┥╌╴╴
	- Alling				
			"Ma Q-Q-1		
	400-				€ @ K @
	┢╧╡╴┥┟┥┅╟╼┝┥╟╌┝╶┽			╫┈╫┊╴╶╲╇┯╼╍╍╸	
	┝╧╪╸┠╬╃╾┫╧╺┊╍┫╺╵╍╴╸╺┾		The later	K-19-19-19-1	·♥≠↓ · │··│··│·┤··│ ÷··↑ · ·+··/··│ │·
	200		74-5		
	Koo-				6 FIGURE 1
		╷┼╴┽╍╎╫╴┊╢┇╴╷			
					li jul I - Contra li I - I -
	'		I ENGTU INCHES		AS AS

FOLDOUT FRAME #			FOLDOUT FRAME Z	۰ ⁻ .
		55	THERMAL MAP @ 9.	- /S sec.
				30
			······································	= 120 *
	Statutute i			= /\$0 = 240 P
	106 100			= 300 +
				= 600 *
			2 - Z	=/200 +
KNP = -3 -2 -1 0 + 2 -3 -3 -4 -7 -8 -3 -3 -3 -3 -3 -3 -3 -3 -3 -3 -3 -3 -3	4 4 72 78 192 9 30 11 12 13	2 1 15 16 I	7	
			BOILER HE I	NLET ENO
		0 00	THERMRE TRA	M514N75
900				
	111119JV	· · · · · · · · · · · · · · · · · · ·		
			en THE	
		8 0.91		
		$\mathbf{\Theta}_{\mathbf{e}}$		
	╋┿╌╬╉╷┈┥╋╍╦╺╉╺╍╸┥╸╸ ┟╷┈┊╻┫╼╴╷┟╷╗╌┨╶┨╼╢╴╵			
			9 <u>10</u>	<u>الا باد ار ارواز ار ا</u> محر الا <i>م</i>
	LENGTH, INCHES	,		F" 9434755

.

NOUDOUT EBANG	no 11 35 42 17 12 59		FULDOUL FRAME
	Pingen gen gen gen gen gen gen gen gen gen		<u>М</u>
		SNAP	8 BRDC #9. DESIGN K
12 12 12 12			
			8 = 30 -
			9, = 60 + 1 + 1 + 1 + 1 + 1 + 1 + 1 + 1 + 1 +
			@ = 120
SC III	A AND AND AND AND AND AND AND AND AND AN		······································
	ALEAT TIZZEL VALLAS		6,=240
	TTATI NAME		6 = 300
			G = 600 +
			6 = 900
			⊖ <i>;=</i> /202 +
		713 . 74 92 92 31 91 92	
135 132 122 1324 14	a 4 5 0 T B 9 10		┥╧╍┥╸┟╸┊╾┥╾╤╧╶┥╍┥╧┥╼┦╺┦╺┦╸┥╝┼╧┥╌┤
			BOLLER HGINLET END
Pi Stor Press			THERMOL TROWSLENTS
		┈╢┊┈┈┨┶╎┷╢┈┟╼╢╴╎╖┽┼╴┼╸┼╧┟┙╸┼╸╎╾┥╺╂╴╩┿╸┥╍	┥╍╢╍╢╍╠╍╢╍┝╦╇╌╵╵╍┽╴╠╧╫╍╬╌┨╕╶╬╍╢
and the second			
		╶╪╬╼╞╍╊╦╌╬┉╢╼╴┊╼╫╴╤┼┅┡╬╍╌┦╼╌╬╌╢┾╍┾╧╌╢╼╊╌╶┥╾┈┼╍	
- 070X0 4800			
		╶║┈╻┠╌└╴╢╶┊╬╋╼┾╋╋┯┧╴┿╼┼╶╫╌┼╴┼	
	TT 1 1 1 1 4 4 8 V-18-		╷┝┷╺╍╧╸╴┨╺╸┠╍┊║╺╴┠╍╴╏╼╸╵╸╴┟╌┉┥┍╸┠┯╴┶┯╍┿╸┍┥╺╸╵
		┈╠╧╾╋╤╪╢╶╍╎╢╍┥╢╴┈╎┼┽╎┝╌┾╧┝┼┉┽╶╼╸	
Start Start			
E1+++\$+#N1	en la		
		╺╢╾┋╼┨╾╷╴╟╺╌╪╼╢╴╺╍┋╬╧╎╧┼┋┝╩╞╍┥╍┤╺╢╾╆╶┼┷	┥┈╬╍╢╸╫╸┧╸┼┉┾╍╬╶┅┝╦╣╧┽╬╤┽╧╬╤┥
		╤╫┈┝╾┠╌┊╾╢╌┥╴╢╧╺╎┲┥╢	
300 10 10			
200-1		┊╢╴┊╍╉╶┙╼╢╼┶╺╢╌┙╋╅╼┊╼╤╴╽╸╤╬╍╬╌┾╦╫╌╢╶╌╴╸	
			FIGURE 2
		그는 말했다. 그는 말했는 것 같아요. 그는 것 같아요. 이 가지 않는 것 같아요. 이 가지 않는 것이 가지 않는 것이 같아요. 이 가지 않는 것이 않는 것이 같아요. 이 가지 않는 것이 같아요. 이 가지 않는 것이 않는 것이 같아요. 이 가지 않는 것이 같아요. 이 가지 않는 것이 않는 않 않는 것이 않는 않는 것이 않는 않는 것이 않는 않 않는 것이 않는 것이 않는 것이 않는 않는 것이 않는 않는 것이 않는 않는 않는 것이 않는 것이 않는 것이 않는 것이 않는 것이 않는 않는 것이 않는 않는 않	

> +-+ ----: - 1 AS 7-31770 4 5 (ENGTH, INCHES 9 10 Ġ 8 7 2 ÷ B-20 . .

FOI DOUT EDAME Z

DUT FRAME/	EOLDOUT FRAME Z
21 2,2 3,5 42 0, 57 61 66 10 10 10 10 10 10 10 10 10 10 10 10	
	SS THERMAL MAP
MARTIN STAGNANT ZHEADER X	
	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
The factor of th	

1

H.,

÷.,

۰.

1.

18

11::-11

١Ö

•

1.

i - -

.1 ::

lia.

1.1.1.1

:11. : I.-. I.

Ì

: 1

.

FIGURE 13

- · · ·

11

-1-

1

 \cdot

.:|:

ĺ,

. 1

--

1

1

.....

÷.,

, i i i i

-11

ŀ

1

- <u>- -</u>

:1:

12

-

......

::

.....

1.::

F

٦÷.

1

. . .

1

.....

Ś

112

8

.

II :

. i -

FOLDOUT FRAME/

VACUUM INSULATION

ł. PRIMARY

çi î î, +

KND=

.

· • ...

--j--

.....

.....

: I.

- -

. i.

1. 1

,

.

- 1

1.1

-

· ;

÷

. .

500

300-

200

1

ıda.

EMPERA

E. . . .

1

RATURE

0,01

 $e_{\mu} \bigtriangledown$

0,0 -33

1

•

.....

.

...

· , · ·

11

. :

1

509

717 %N-

VACUUNI

-17

17,

!

- lit :

Ì

RADINE, 95 45 ADER

कुल्त Y · 1 · - ----**X** ঁট -7 ÷ 1 1 E F t:<u>∏</u>}∕ φ ÷Ð ÷. 11 . . ::ţ:

:1

φ

- 1

-: F

6 _{B-21}

-11-1

-

÷.

1

Ŧ

1 :

7

Ф

Н,

· |

:64 -11

11

11

LENGTH . INCHES

5

<u>.</u>

1

....

. T

]]

1 4 -(†) Ø7

.11

0.94 1...1

11 11

~ N1 41 · II . 5. 1 11 11

凶

8

800 H 29

°/1# ~ 700 4

T 1 15000

Ť

팝

4

÷:

111

. . . .

6

-

. 6

1

z

-f

卌

H

11

-

3

21 22 315 42 de NON NO

	d V		o 🔉 🐨	TO TO	-1618	1															
VACUUM INSULATION	241					S. 10				·····	·	11,1,1			3.		1 1				
	874711		1/0/0									· · ·		SNA	P-8	BAD	C#	X DE	SIGN	1 1	
	-174 - 7488												TA	THE	BMA	MA	•		· .		
	na de nie	NA XIN				N.87 C		- 1	-VACU	UM IN	SUL AT	ioni.					PIQ	= IC	SEC	·	1.
							100			<u> </u> : •								9 3		: 	
1 13 1 14 148 23	*	19 13 A					8.3.6					<u> </u>					`ě	ŁG	SEC		<u> </u>
					- 4	⊨ ‼N⊋			86	<u> </u>							Ð	= 12	<u>o 500</u>		. `
PRIMARY WAR			8.9			रके	$\phi \in \mathbb{R}$	$\mathbb{C}\mathbb{R}$									9	, F 18			
							X X I			a n				· · · ·				-+ 30	5-550		É
				grift				<u>† 5</u>	01.11.10		•	1		<u>: :: :</u>			. 0	ri 60	O SEC	••••	····
	<u>X:X</u>			F A B				NAK -			:18 5: .			· · · · · ·		<u>.</u>	1.9	o <u>*</u> 190	io sec		
		<u>, h</u>				4	$ \langle V_{1} \rangle$					112						1 <u>7</u> 121	0.250		
	TADAR	STACHING		a 197						<u> </u>		1	144		- 29						
		NAK .			Milt	US91		ŀ÷		i ika	S 🛃 🛛	鄉	5 9	b ii:-	= 101						
									-	- 915	1	10	/-		192	-7					
KNDd		4.4						Ŧ.ţ				20	30				115	<u> 17. </u>			
					NE								·					<u> </u>			
6. 2 Q 100			10			X												HG	NLG T	END	
		it i te	$\varphi \rightarrow \varphi$		++++-		****	1	· · ·	•·						- 44	A ATR	T-174	HNS/	<u> </u>	
							N.	1													<u> </u>
							X	ij-ij										<u></u>			
5 x x 300					N H						-									<u>.</u>	
			+ 1 + 1			. : : : X		•					16	<u>.</u>				1		÷ ;	- • •
					ΗK									× • .							
A VOL	· · · · · ·		234" FIN	No V		X-111-11	Pi	T :													··
						N.	1 L					Q			S. H			<u> </u>			
	509 .	F## \\\\	ĭ.			1.4	The second se					FΝ			. 8	e, 1					- j- :
HX X	<u>, i i i i</u>				NU		£			$\int d$		Φ	N. I.					9 . I			
						·	*	1-1	1.1		Y	\mathcal{X}		:		• : •					
520 / 1			1 K P	KEEL.		N/	1 16					ŇΝ		<u> </u>							. : :
			\diamond / $>$				<u>s ì</u>					LX.	$\sum 1$	\cdot		· i					
				$\lambda = 1$			$\phi \rightarrow \phi$					ФЩ	Smile		<u>. 4</u>	2//	<u> </u>				
300	• • • • • • • • •		4						XI				<u>`\.</u> \$		\mathbb{N}				6 F		
			¥		NI			$ \ge 1 $	· · · 1				X X		· · · · ·	21					
(),; (; ; ; ; ; ; ; ; ; ; ; ; ; ; ; ; ; ;							¥5ľ			<u> </u>			Δ		S II	_		ġ.			
							<u>4 - 1</u>	F				1	<u>-</u> :\$		<u> </u>	9		0+ - 0-	92 Ø.		
1 da -									1 5 4			<u></u>	-		<u> </u>	<u>-</u>	1	<u> </u>			
	RADIA				14			Ŀil				- F i			*	·	₽ ŗs (Ų	₽Ę.	. 4		
		* * *		에에게		<u> ser</u> ci		<u>t: it</u>	-Lit	1.411	<u>: : †</u>	11:1	<u>- 19 - 19</u>		<u> </u>	<u> </u>	<u> </u>			: ji.	- T. <u>-</u>
•	1	1 2	•	5	LENGT	H, INC	HES	θI	-22	7	8			5	10	•	Ч				

Subject: Interpretation of BRDC #4 Mercury Inlet End NaK Shell-Tube Surface Temperature Measurements

Analysis of boiler BRDC #4 mercury inlet end NaK shell-tube temperature measurement leads to the conclusion that the relatively large solutions stagnant NaK volume contained between the vertical baffle plate and header in the horizontally located NaK shell-tube mercury inlet end is condusive to free convection and body force effects of the NaK. Free convection is induced by a relatively, high baffle plate wall temperature ($1140^{\circ}F$). The body force (buoyancy) and resulting NaK temperature stratification is caused by the heat sink (Hg tube bundle) placed in the NaK volume. To eliminate non-symmetric NaK shell-tube temperature distribution, the honeycombing of the stagnant NaK volume is recommended for the purpose of providing a conductive heat transfer pass. Typical BRDC #4 temperature distribution is shown in enclosure (1). Utilizing the liquid metal free convection heat transfer correlations, the possible film inductances (h) and heat flow rates (q) are shown in Enclosure (2) for a range of wall-to-bulk temperature differences derived from Enclosure (1).

Based on the above analysis, it is concluded that BRDC boiler #5with its honeycomb structure in this are and the envelopment of the area with the flowing NaK in the tee and the incorporation of evacuated baffles, that the problem of natural or free convection of the static NaK will be eliminated.



SCHEMATIC VIEW OF BRDC BOILER #5 SKIN TEMPERATURE MEASUREMENTS AT MERCURY INLET END DURING

CLEARPRINT PAPER CO NO CJAX MILLIMETERS 200 BY 250 DIVISIONS

.

.

 																	:: :,	• • •								:::	1 1 1			7	(· .		
-				1.F.,		-Hi 1 († 1			0						†+ -		; r) -: 11	1 • 11		1 	•	ri. Irt			;;;;; ;;;;			4	1		:: 					; -:-:	: ::==	•:	-	
													11-1- 14 -				ų. T			1		H H	1 -1 - -				1111 1111	1		+			1							
		. 1	ļ.	:		1			前																	1+j	1	H	12.1	ЦЩ.		5.	11							
				-	۱ ۱		••	4	5	1 14																Z			1							17.				<u>.</u>
4.4						ļ,		11.1	ціі П		17	ii		114									FI I		X	[]			;;;;									<u>.</u>		
-			<u></u>			ļ	 · ·						11												Hi. Thi) 			T T		<u>.</u>				•					
				: :					ð								H					X				1111,									•			•		
	i		÷.,	: 		À.							11								本	li i	i.	51			;;;		÷:-1		14							. :		
•	<u>.</u>	•		1		¥	[:-]	F.		::1			11						Ľ	伯		j)		Ē	Ħ.	:.! :!!;	13:1 .1,1	1-21 224	11	i <u>t</u>		11								
	ľ :	' <u>.</u> .	;	<u> </u>			[\boldsymbol{k}								-1.: +.::					i::::	лі. - [:-	- 17.		175 175 1	1.::		•		
-		•	!	ļ					5				. ! 											1								121						•		
		· · · ·		;;;··																											1- I				1	<u></u>				
1.				;;; ; ; ;			1							l i			H			-T		E	47	<u>-</u>		17,	:+		1.4	<u> </u>				:	: ::			:		
				••••	['] .				bil										i i			ΪĪ.			Ц.			臣		ц.						: -	:::			
	<u> </u>	. · 		- - 	<u>.</u>	1.1	'ij		1	Ēij	扣					<u>III</u>	i T						Ш		H :		<u>[]</u>			畕		13	111	l: :-				:		
			1•. 12.1	: :			;;}	20	0														1::						:		Į			- (;	1 1 1 1			·	•••	
				<u>.,</u>		111											17					11														1	ц.: П. <u>н</u>			
		;	11 -			ΨK	L						TT.						- 11				-11-1								11 11	4	-111- -			1				····
	-i -			1			i,	10	0		ГШ	, T					11										rl it				;. ,							-		
	••••					Ľ	-11										T.	ΙĦ								1	,1'I		нŋ	Ш			<u>111</u>		111	171 1				
	<u></u>	<u>.</u> :	.:1:	÷1			1.i r										Ē								ii.	1.11	ITTI 			Ш.	1		1	15					ا اِ	
-			· · ·				È-i																		<u>.</u>		, 14 4			÷F.		H						-		
		·		:. : : ;				H.																		1 <u>14.</u> 114					1									
••						13.4 1777	6 ∷				加						1												1		• • • •		1		!!::		- 11		<u>.</u>	
				:		11	Ĉ.	ļ ',				Ħ	Γ		HI.		11.		Щ		Ţ				: :,;;			11	14		:: ::::	;; ~,		.,			: :			
			ii.	·:••		hi	ÏF	3	0					h													hii				1,4		i.,i				: !:	:		
		Ŀì.	<u>111;</u>	<u>,</u>																i li											14 1								:	
						Щ							H												1						1: i i i					<u>, 1</u>	···· ·	÷		
		• • •											i.														,	1.1					<u>, 1</u>			<u></u>		<u>;</u> ;		
							-ii	1.		5			ΠZ.				E	Ġ.				4	Ö,			4	20	ЦĮ.		.5	53							 i		
	;	,11		1: .' -1	111			li li			1					i li													11		Ţ	iF.	i.i			Ľ,	;	1	1	,
	<u> . :</u>						<u>E ji</u>					L L									I	4		4			4	ve	r	X.	î/i					•,*		•		,. ,. ,
	1	·	,,, ,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,														14																			÷	:			
		<u>`</u> _		1		<u> </u>				₽₿			8		ſĤ	f		11	ſ(詽	Lé la		ie c	i K	ZK T			Ņ		í	1				•• 1 1-1-5	: 		• •	
		-1		[;1	Ŧ						US I		Į,	Ш,			莭	50	Ì															Sa /			- <u>69</u> 7.	, ;	<u> 765</u>	
•••		+++++				Шï								Ĭ	Ĭ			11				iff		T		ШË		Ľ.Ţ	<u>i</u> t			LT.	li ji		III		• •			<u>,</u> ,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,
		:					-;;! ;+																														1.1.	•		:. ,
			ЩЩ									ŧ€			*	ł		#/	e.	Y	l k	14	8	14	7	64	1	S if		S I	<u> / / </u>	<u>r</u> ix	24					;;		
:"				\mathbb{H}		開		\mathbb{H}		₩		ġ.ķ		28						- 2			2	Ĥ	97		8	A						Ë,		4.1			•	
1																						₩					liii,	H		開						11. 11.				<u> . </u> .
		1				İT II	++++ +			ΓT					UII		ļ.									ĪT	titi i					Ϊli						 1		

ENCLOSURE (2)

B-25

AFROJET AE	ROJET NUCLEAR SYSTEMS COMPANY	ENGINEERING FILE NO	
BENERAL POV	WER SYSTEMS OPERATIONS	EDF SERIAL NO.	<u>DE 0026</u> 7-30-70
EN EN	GINEERING DESIGN FILE	DATE	1/75-1/1-0117
RUJECI		W. O. NO,	
SUBJECT BRD STA	C BOILER NO. 5, DIFFERENTIAL THERMA TIC Nak TUBE AND Ta TUBE	L EXPANSION BETWE	EN
ARSTRACT			
ADOT NACT			
Analy	ytical calculations to determine th	ne subject differe	ntial
ther	mal expansion are presented. The m	aximum differentia	со ^р
ther	mal expansion at the steady state t	emperature of 121	0 F
is O	.207 in. per 100 turn or 0.574 in.	, total across the	poller.
The	oval static NaK tube is designed for	or a 0.602 in. mov	ement of
the ·	tantalum tube within it. This resu	lts in a 0.314 in	. margin
over	that required. The extra clearance	e provides for ea	se of
fabr	ication and the possibility of over	r-temperature excu	rsions.
-			
DISTRIBUTION	N R. Alena, B. Breindel, E.S.Chalpi U.A.Pineda, R. W.Marshall, Jr.	in, C.Hawk, G.L.Lo	mbard,
UVER SHEE	I. Hodgson A. H ⁱ kreegen T. Long		
	s mougeon, A m Areeger, h mopes		
KEY WORDS	BRDC Boiler No. 5, Differential ' Static NaK Tube Ta Tube	Thermal Expansion	
AUTHOR		DATE	DEVENIED / an DASE
R.Alena	R. Men 7978	Malpin Autor	KUMALAD BIHI

.



73-25" DIDENSION IS THE DAX. LINRAR DIDRESION STK. NO. D.1.103

QUADRILLE WORK SHEET



AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA

PAGE Z OF Z PAGES

WORK ORDER

1475-47-01

SUBJECT BROC BOILERN. S. BY R.ALENA DIFFERENTIAL GROWITH FOR THE DAY, LINEAR С, DIDENSION OF THE BOILER (73.25") $\Delta_{LTa} = (3.89 \times 10^{-6}) (73.25) (1135) = 0.323'' HAX$ ALSS (10.80×10-6) (73.25) (1135) = 0.898 MIN

$$\frac{AL}{AL} = 0.575 \text{ in}$$

$$ALTA (3.8 \times 15^6) (73.25) (1135) = 0.316 "MAX$$

$$ALSS (10.25 \times 15^6) (73.25) (1135) = 0.852 "MIN$$

$$ALSS (10.536 \text{ in})$$

ALLOWANCE PROVIDED IN THE OVAL TUGES FOR D. DIFFERENTIAL THERMAL EXPANSION



ACTVAL ADONN' ALLOCATED DI DI FERRATIAL EXPANSION IS 0. GOV IN PER ONE TVEN OF THE OVAL TUDE MAX. DIFF. EXPANSION TO ALLOW FOR IS 0.575 in For 2-180' TVENS EXTRA CIRDENNER = 602 - 575 = 0.314 IN. IN OVAL TUGE USE 176 "0.D. X 0.049 WALL 32155 TUBE TO FORM OVAL TUBE AS SHOWN ABOVE. ١. в-28

STK. NO. D-1-103

APPENDIX C

MERCURY SIDE BOILER PRESSURE DROP ANALYSES

AEROJET NUCLEAR SYSTEMS COMPANY

7996:70:0856:GLLFplb

Date: 1 September 1970

TO: E. S. Chalpin

FROM: G. L. Lombard

SUBJECT: Predicted Boiler Pressure Drop with a Multipassage Plug Insert Length of 2.7 ft and 12 Tubes.

DISTRIBUTION: A. H. Kreeger, A. J. Sellers, File . NASA/LeRC - E. R.|Furman

A. INTRODUCTION

The following analysis was made in order to establish the effects of varying multipassage plug insert length, NaK inlet temperature and NaK flow on the boiler Hg-side pressure drop. From the test data on boilers with 4.0 ft, 3.5 ft and 3.0 ft multipassage plug inserts, it was noted that the boiler pressure drop versus mercury flow increases with flow to a maximum value then decreases as the flow is increased further. It has been concluded that this pressure drop versus flow behavior is characteristic of this mercury side geometry, namely, a multipassage plug insert and a bare tube with a swirl wire. From the test operations it was also gleaned that system control, i.e. NaK heater response, was difficult to maintain when the system was operated in the range where the boiler pressure drop decreased with increased mercury flow. Whether this is a detrimental effect when the system is tested with a reactor is not known at this time. However, it is felt that it would be desirable to have a boiler that would have, at all conditions, an increasing pressure drop with increasing mercury flow.

In order to accomplish this it is necessary to place a flow restrictor at the inlet of each boiler tube. The size of the restrictor flow path would be such that when its pressure drop is added to the boiler pressure drop, the total \triangle P would increase as the flow was increased. Stated mathematically:

$$\frac{\partial(\Delta^{P_{A}})}{\partial\dot{w}_{H}} \ge 0;$$
 FOR $0 < \dot{w}_{H} < \dot{w}_{H(MAX)}.$

However, before an inlet flow restrictor can be designed for a particular boiler design, the boiler pressure drop versus Hg flow function must be known. The remainder of this report describes the method used to extrapolate data on plug lengths that have been tested to determine performance of shorter plug inserts considered for use in future boilers. Ultimately, the information will allow an optimum choice of restrictor size to be made for a given boiler design.

B. DATA

Plotted in Figure 1 is BRDC Boiler #2 pressure drop (less restrictor ΔP) versus liquid mercury flow at NaK side flow and inlet temperature

7996:70:0856:GLL:plb

of 48500. lb/hr and 1310°F, respectively. Figure 2 shows the data taken on the SB-2 Boiler, tested at AGN, San Ramon, at the same NaK conditions. BRDC Boiler #4 data at NaK flows and inlet temperatures from 48000 to 27000 lb/hr and 1300°F to 1150°F, respectively, are presented in Figures 3,4 & 5. Each boiler tested had plug inserts of different length per the following:

Boiler #2	-4.0 ft
Boiler #4	-3.5 ft
SB-2	-3.0 ft

Figure 6 compares the pressure drop versus liquid mercury flow for the three boilers at the same NaK conditions of flow & temperature. It should be noted that the NaK flow and mercury flow are stated in terms of 1b/hr/tube so that the pressure drop can be compared on an equal basis regardless of the number of tubes. Also shown in Figure 6 is a dashed line drawn through the peaks or inflection points of each curve. A review of figures 3 to 5 shows that the liquid Hg flow at which these peaks occur is a function of the NaK flow and NaK inlet temperature and from Figure 6 is also a function of plug insert length. It is important in the choice of a flow restrictor to know this peak Δ P and the liquid mercury flow at which it occurs for a given plug insert and different NaK flows and inlet temperatures. The curves shown in Figures 1 & 2 for the #2 and SB-2 boilers, respectively, represents all of the felevant data available for these two boilers.

- C. METHOD
 - 1. Neglect the difference in boiler lengths between #2, SB-2 & #4 boilers since the largest percentage of boiler \triangle P occurs in the plug insert.
 - 2. Plotted in Figure 7 are curves of peak pressure drop versus plug insert length. The curve for TNBI = 1300 F was established from Figure 6 using the peak pressure drop established by the dashed straight line intersecting the pressure drop versus flow rate curves. The curves for 1250, 1200, and 1150 F were drawn parallel to the 1309 F curve and used Boiler #4 data only, since that was the only date: available. (NaK flow is constant at 6860. lb/hr/tube).
 - 3. Figure 8 was generated using the data from Figure 6 for 1300°F and Figure 7. The lines of constant TNBI are drawn parallel to one another. The curve of peak pressure drop vs. peak flow for Boiler #4 was first plotted (from Figure 3). Then Boiler #2 & SB-2 values at 1300°F & ---. 6860 lb/hr/tube were plotted (from Figure 6). Next the constant temperature lines were drawn. Then the peak pressure drop values (from Figure 7) were laid in on the constant temperature lines and connected with the curved lines.
 - 4. Figure 9 was generated in a similar manner to Figure 7. First, the curve for 1300°F and 6860. 1b/hr/tube was plotted using Figure 6 points at the intersection of the dashed line and the pressure drop vs. liq. flow curves.

7996:70-0856;GLL:plb

Then the curves for 1250, 1200, 1150°F and 6860. lb/hr/tube were plotted and are the same lines as given in Figure 7. The curves for 5360. & 3930. lb/hr/tube & 1300, 1250, 1200 & 1150°F were drawn parallel to their corresponding curve at 6860. lb/hr/tube using Boiler #4 data points.

- 5. Figure 10 through 13 show variations of peak pressure drop versus peak liquid mercury flow for TNBI = 1300, 1250, 1200 and 1150 F with variation of NaK flow from 3930 to 6860 lb/hr/tube and plug insert lengths of 2.2 ft to 4.0. As an example, let us look at Figure 10 for 1300 F. First plot the peak pressure drop versus peak liquid flow for the 3.5 ft plug insert (Boiler #4) from Figures 3,4 and 5 for 1300 F and NaK flows of 6860, 5360 & 3930 lb/hr/tube. Next plot from Figure 8 the points for the 4.0 ft, 3.0 ft and 2.2 ft at 1300 F and 6860 lb/hr/tube and connect them with a line (which is straight). Then draw lines for 5360 & 3930 lb/hr/tube parallel to the 6860 lb/hr/tube line through the 3.5 ft plug data. Finally, using Figure 9, pick off the necessary points to complete the plot. A similar procedure is used in generating the remaining plots for 1250, 1200 & 1150 F.
- 6. Plotted in Figure 14 is the pressure drop versus liquid Hg flow for the new PCS-G statepoint and new boiler with 12 tubes. The blackedin triangles were interpolated from the plots in Figures 10 through 13 for the 2.7 ft plug. The open triangles are from the BODEPE computer program.
- 7. Table 1, 2 & 3 are the data listings for Boiler SB-2, #2 & #4 respectively. Also included are the PHBO versus liquid Hg flow curves used (as a guide in making corrections to flow rates which seemed to be in error.

ORIFICE SIZE

Plotted in Figure 15 is the pressure drop versus liquid mercury flow (%) for the 2.7 ft plug insert, orifice pressure drop and total boiler pressure drop.

It is recommended, if the system can tolerate the total pressure drop at design flow, that the new PCS-G botler have an orifice with a .050 inch diameter, with a square edge. At100% design flow for liquid mercury the total pressure drop across the boiler would then be 174. PSID.

H. L. Sombard

G. L. Lombard Static Components Power Systems Operations

12110-16 SROC 6 500 50102 P 75 以外出 NOTES 11:2 Ήŧ ÷ ::.:|: PLUS LENS į CT11/2 10 14, 18500 8,4 1761- 1310 7 N=7 1655 08:11:05 AP B Įτ, 7 11 180 6 7. H 99 <u>i li</u>ti :] Q. 040 1. 120 : 5504 -÷ 100 Der - ; 生物出现 - 1 Mg 2011 512 80 + 劃 Ì 1.11 Ε, ----į. 60 調算 ΞĒ 1 1 ţ ្រា ľ: 1.1 1. 12 6 14 2 0

C-5

CLEARI RINT FAFEH CO NO CREX, MILLIMETERS 200 BY 250 DIVISIONS

CLARTANT CHATT

_

3



CLLARPRINT PAPER CO z C39X MILLIMETERS 200 BY 250 DIVISIONS

PRINTED IN U.S. A. ON CLEARPRINT TECHNICAL PAPER NO. 1015


PRINTED IN US.A. ON CLEARPRINT TECHNICAL PAPER NO 1015



CLEANPHINT PAPER CO. NO. C39X. MILLIMETERS 200 BY 250 DIVISIONS

CLEARPRINT PAPER CO. NO C39X MILLIMETERS 200 BY 250 DIVISIONS

PRINTED IN U S A, ON CLEARPRINT TECHNICAL PAPER NO 1015



			1		1.	1	1 t.	1		1.1		Ť		I			T	1-		- <u></u>		11.	<u></u>	•	1.	. <u>I</u> .		1 1
		i ir	<u>الماري</u> ا		·									. <u>Z</u>		• • • • • • • • • • • • • • • • • • •		-	┼╌┼╴			- '	÷			-+	··	; <u> </u> ,
			1 .				·i	+++								_	+		+	1			-+					+ - + - +
	<u> </u>	.		<u> </u>		с 1 г	·;	+-+	- 15			$\frac{1}{2}$			· ',-		+					++++						+
180	<u> </u>		 '- '' -				 											<u>-</u>		÷		<u>;</u> [:		┝╌┼╋				
	<u> </u>		<u> · · · · · · · · · · · · · · · · · · ·</u>		4.	-	<u> </u>	++	;				<u>-</u>	1	· !- -			<u>.</u>		<u>, 1 ; 2 ;</u>								
						+-+	. -		. .	·		n -					┼┯┼╌	<u>-</u>									- <u>-</u>	
						4	<u> </u> -						····				╶┟╌╤╾┽╴						_					
160	<u>.</u>						<u> </u>									- <u> </u>		<u>-</u>	:: -			NO	(6 5)				3	
•					<u></u>		[- <u></u>		· · · · · · · · · · · · · · · · · · ·			<u> </u>								<u>''''</u>					erd			
				<u> </u>		<u>. </u>	<u> - -</u>	1					- <u> </u> -	· · · ·	· [* 	<u> [</u> :		$- \varepsilon$	/	e De	- 4		
					<u> </u>	<u></u>	<u> </u>	1.1									<u>h i</u>			1.5			- 2		s e			
140								1 1			=====		1-		· · - · [*		<u>- X :</u>		r	<u> </u>	[¥					
• / -	1							-=									14.					1.4) W	N			中的	
						<u>_ = -</u>			ii E T			$\equiv l$						<u> </u>		1	1.11	重要			DIA			
						· <u></u>		<u>.</u>		<u> </u>			r				9- <u>-</u>	- 1		4.4	<u></u>)_7/	9		041	-to-,	1314 F
120						· . 						許		Kal-	1.1						デゴ閉			<u>in</u> ; T				時世
120																			R.		: <u>च</u> =:		計道	Ē				日本日本
																					<u></u>			E				開出
				E, P															N		·							
	<u> </u>					4= 4=	1	7-4-1	<i>d</i>		4 + +						::			HI354			1		7. 217			
100		<u>.</u>								<u>Á</u> len																		
	.																			: 57.5				訪托				
َ لَمْ																		T.	Ξ.									
o ·		-==																		, , , , , , ,	1 HI			.211	1.1.1			
80	S.														ŧΞĔ													
				自己												╡┶┨┶╼┑┠╢┯╍┥ ┰╾┨╧╾╷╍┨═╸╛					1			÷:;}	++++i			
				<u> </u>																								
													n 1	1517 1						·							<u> </u>	
60																												
	N -	<u> </u>									<u>11 175</u> 1				Ë F		172 171 2019 : 1											
		1	<u> </u>																									
	<u> </u>	<u></u>	<u> </u>	<u> .:' .:</u>		2		1											<u> </u>		HE					2 F	- : 	115. 1111
40	<u>iš</u>		<u></u>																				453					
							5:45	<u> 1</u>		21224		<u>Hi</u> H		234	H H				12:10			1-12			- i ri	<u> </u>		
			ļ				<u> </u>						<u>1177</u>		ξΞ													
	<u> </u>	<u> </u>		<u> </u>	<u>0</u>)			<u>. []</u>		-14-54				調話								#H7						
10								-						L I	<u> </u>	田田市				<u>i</u> tir			П.	÷	i i i	山田		
~ -							<u> </u>							1551-15	li - Li	r 1 2:11	1				用目	₿₽Ę	비브	,11	r :: î		出日:	
	<u>-</u>	<u></u>					li i		下開			i i i		Шţ	E					1.17					: 1 - 7	· ; ;	洲田	口中国
	571		1	1	1	+ +														· ·						1	4 F :	
-				[ŀ	A1	*		4	人人	13/1	817	1000			_ : .					-			† : : :	
0					2	200				//	200	<u>, 51, 10, 10, 10, 10, 10, 10, 10, 10, 10, 1</u>	ليفيقينيني			14	00					21	200	 				
					<i>ر</i> د	~~				\$ 	and the second	DOFT Y S	2			/~												

NO C 134 MILLINGLERP TOO BY 280 DIVISIONS CLEARPRINT PAPER CO

٠

]	••••		<u> </u>	.! .!		<u> '.</u>								iii:					ŀ		11 1-		1	<u>,</u>	: 1		••••	H-11					1 1	: :			1.
 	- .	:		: 	1: 2 1 73				· · · 			1:11								1				1 <u>.</u>		. •1						 31 	· ·				÷	·
				1- 111									<u> </u>	4	6	S	2	-	E		Z		226	55	2	20		D,	0	1 7	- - -	: .	 '''	· · ·				
	+						. . .	1								-111 -541 -1111	2	Ú		74	ls.			24	-7					<u> </u>		[.::: 		:	<u>ا.</u> 	
	╀	<u></u>	· · ·												1						鼦					1:51 1 ^{:2}	1111											
	-		<u> </u>	<u>':</u>					1				1			11																		<u>.</u>	i :		i	-
¦ •-			۰. 			<u> :</u>	!' 1 ;; ;	<u>.</u>		 	· · ·	ļ,	<u></u>			1.						1		·		 	111 			···· ····	· · · ·	<u></u>	<u>.</u>	<u>.</u>		/: 	 	
	-				<u> </u>	<u> .</u> .			-				 			i.	1	1+1				ri i	<u> </u>	: I	14			:1		1	1 •	 -						
	-	:	[<u>;</u> 	<u> </u>					ļ.,					E.					1. 1	11			68	śc	- 43 - 14 - 14	1.	hi		B	æ	•				; ;	·	; **	
	:: , -		- - -	. ·												11				<u>i</u> :						 		117. 1	μ. 	· 1·	++++++++++++++++++++++++++++++++++++++	<u>.</u>	:::	- T		· . : . =	: 	
	Ť			1	0		. i .	<u> </u>	 		;- ;-		- 								炭	1.	0,0			: : !:1i				,		-						
	-						<u> </u>							1				L, I		i II	II.			-1		i .:				••••				1 <u>.</u>	:: .		1	
. .	- ,	i	, , , , , , , , , , , , , , , , , , ,	.		.						; ' <u> </u>						11					25	0					Щ					r. ;:	:	· ·		
		•	-f'	-#	0		<u>-</u>					 ;:	<u></u>			 ::::		11:1		1484 14	誦		<u></u>	1.12		•••••							•		 -		 .	
	•			ļ.,		<u> </u>	<u> </u>		1											Ë.	围	ţ				([†] i I	, ; ; ; ; ; ;	1					, 1					
					;		<u>.</u>		··· 1				1								臣							i	<u>1</u>		1 1 1	1.1	; 		;			
				14	2											111				17	1			1		, <u>1</u> 1 1 1		Ë	:	11:- 11:-					1			.l
	÷		1: 		, "I		ļį.					11								Ł								1111	<u>1</u>						1			
. .:					-1-	17																		15	D e							11.1 1 11			145 1		-	
		•	, 1					- ;;				- - - -				Ŧ			Á	1		1			1									講	т:н Г:Н		<u>1</u> .1	
. ··	4	.,	<u> </u>		詽	H	1,											逆		2	1		Z													11		
		·:				- P													Z			臣					- Th	- 4								Ξ		
		···		1								i i i		i.	Ē		伯	Ź		2		Ź	Li I		•••			ii,			 							
			<u>ui</u>		[`';' ;				<u></u> ,	<u> </u>	÷+:				井 5 开		Z				Ź					13							1	邒			<u></u>	
. ⁻			÷+					1440 1440 1440								H		X		Ż																		
				• 6		1.7						71. 17					2									·										: :		
	-				 			 	<u></u>																			1) (1 1) (1	끮								:: ::	
1	•••	-,±	1		÷ -		÷																															
			·		0	1::	1: - 1														Ī										11 - 1 - 1 - 1	1111				: <u> </u> :.		
	-	,			1	i' ,						ſĹ																	F.							. [¹]	<u>.</u>	
	-	: -	Ŀ.,																																1			
		· . : 	; .'-		1	.ji	1:															ļ				111									•••			
		; .' ; ;,	:	Ľ,																		ff T									Æ	K		Z		• •		
		İ						Ī	T				İ																	1							iri;	
		, i: , , ,		Ţ																																	11. 11.	
	-	- <mark>}}</mark>				l ii																																
																	1:11 P43		L.F	i.		Ľ										ľ.					iii	
					0	0				1				2				3-				4			!	5												
																			C-	۰TT																		

.





2544 :::// 2427008 D 1404 NAK INIT S 10 A7 A 甘甘 aly = 4860 16/47 1 400 116 10/ 2/1 1, -新用 02.0 1. 쪢 1:-30 6 ••• ESSUR · · · 1 (1 e/ca <u>Ao</u> \mathbb{P}_{ij} 1220 ;1] ŧ ţ ; 1 0 500 1000 1500

CLEARPHINT PAPER CO ö C39X MILLIMETERS 200 BY 250 DIVISIONS

UARTHINI CHARTS

PRINTED IN U S ON CLEARPRINT TECHNICAL PAPER NO 1015

C-14



CLEARPHINI PAPER CO NO C39X MILLIMETERS 200 BY 250 DIVISIONS





PRINTED IN U.S.A. ON LLEARPRINT TECHNICAL PAGES NO. SOM

	1				1- 1	T IT	1:	1.11	1.4	1.7	<u>liu</u>	1: :1	1	1	· ·	1.1.	1	<u></u>	1	<u> </u>		<u></u>	1	· ·			
	-	·	••••		<u>↓</u> ' ''		造井	. <u>; .</u>	1.11				ļ:'	<u>.</u>	+	<u> . </u>		ļ <u>.</u>	<u> </u>			: 	<u> </u>	-	•	: 	
			t,-				╞┯╾		 		; 		F	G.	12	<u>[· _ </u>	<u> </u>	 	•••	ļ	. :		,			1	
		· [-					. 				ť	<u> </u> .	 `.	<u> </u>		ļ.,	 	:	,	:: :	. ,	-	1	:	•		;
				ŀ.''				• •	<u>.</u>	H.	11				<u>.</u>	11				: :-						†	
	1	-70	O-		1	ļ.,	hir:	·	<u> </u>		1.1		È i			14	±0/	DE:	-177	67	256	Ke		PO	<u> </u>	<u> </u>	;
	Ť			• •	<u>.</u>	╡┵╸╘╧ ╎╶╹╷╷	-\	ļ	•••		1			1.5			= 2-	4.	HG	·/·	10	V.	70	<u>K.</u>	; 	ļ	'· .
		!-	·····		┢╵╨	ļ			1.	· ·	· · ·	6						<u> </u>	~~~	7.11		-	Call	11	• 		, }
		;			, '					÷: :				;-1;	1.	· · ·				• • •	 -:,	-		•			
	!	14		.	l' -			• : •		; i	NI	ني. مراجع		: :	: [•	i						;;	· ·	i 1 1	İ	
	:		יי						Ī		:4	111	1.1	1. :	خدا			T	مىت - ئەر مە		<u>نن</u> ا						, <u>, , , , , , , , , , , , , , , , , , </u>
	- 1		÷.			~ '						4	-/-	4	NO.	.0	E_7	UB	£5.	Ξ.	1.2	• .		•			! .
-	;												2	Ľ,	2 <i>611</i>	FIC	£	∆ł	24	107	-17	NC	42	$\mathcal{D}\mathcal{E}$	D	· 	
	1.	. 19	!	. !	· · ·	, ,	<u>.</u>	; 			<u>.</u>		3.	í _	AL		-20	Ŵ	Ш.	غي ا	300	bo		16		.	
	-		0	· '		<u>'</u>	<u>;</u> ; ;	• • •			 		4	1		يرسر :	201	1	4	1		11			:,.`		
· · ·				: , I		• •	1:11	•		1 11		11	11		して	ipi	70	e.	م مرجح	10	1	4		10	1		
· 1		. 11		P	1,,,	۱. <u>۱</u>	:-				1	1.17	F.	ΞŲ		l lat	PINA						2.1				
		·		Š.			1.	÷.	<u></u>		$\frac{111}{11^{2}}$		1244 111			N	573	23-1	切			<u>.</u>			ЦQ		
-1	·	ایا <u>ان</u> در ان	井	\geq					리비]-[].			即	ζŝ	Ëε		$\pm i$	22	42	$\left \right\rangle$	12	15			
		-12	0			1		<u>: []</u>	1	11,1	III	114	6	16	55	-	Ë,	0	2			64 I	彭	32	2.5	- 16	h.
	· <u> .</u>		Ľ	N :	: 1	<u>i</u> .':	ŀ.	·		詽				A	π_{0}	Ne	清	112	5	法		13	60	\mathcal{O}_{i}	10	hr	LIALET
		: [.'		إنا			14	rH	HH		HI	Ini	挝	K	臣	WB	7+	121	0	F.		/3]	77	5 1		1	
		- 1	Li j	$\mathbf{S}_{\mathbf{i}}$:					11.1			i f	拍	11	÷ſ	AR	Rγ	ÖV	E K	. = = = = = = = = = = = = = = = = = = =	2	Ö	10	- <u>;-</u> ,	-
· '		1	1. 11	<u>, 1, 1</u>	••••• •••1								ЦЦ			H			,			<u> </u>		!	·		.
h		10	0	r.	<u>.::</u>	1						IrĘ.	<u></u>	:' '		1	7.5		·	1			-	- 1			1
: !				<u>x</u> ·	<u> </u>								H			<u>11.</u>	: 4	•	1	1	• . :.]					<u>1</u>	
			ų,	ĥ		·		•••		ΞŢŢ	ŀ ŀ	HT	;;	<u>† 1</u>	17				-	.]	-=-		- 	 ,			1
	1	1.		<u><u></u><u></u></u>		. : : -				-				1		<u></u>		£4_`					<u> </u>			<u>.</u>	
	•	4-	44	₹.		쁥	÷	.1.	<u></u>	1440 	4 11 14 1-1		<u>,,</u>		<u>, 11</u>	<u>i i</u>	· ·				-	_]		ا 1
		-le	Ð	*	<u>i</u> , .		, <u>, ,</u> ,				4.7		1	<u>; </u>		<u>; ; </u>		, . 	<u>r </u>	· · ·	<u>. 1².</u>	·· ;	<u> </u>	; f	<u> </u>		. 1
·	· · · ·	-		<u>2</u> :									μŢ	<u>.</u>			•		~			· · ·	•			. !	
	· .,			1	11.1				LIT I	11					Ei					;;:	•••				크	L.	
	•		1		· · ·	11		14	H	15	25	Ŧi									-						÷
	TT.				i			H				 		- 		<u>t</u>				<u>;,,</u>	-+						
		60		0†							++++					<u>.</u>		X		<u>i'</u>	<u>, 11 1</u>	::.1.	-	<u> Fi </u>		· · · ·	11
· · · · · · · · · · · · · · · · · · ·																											
111												Ŧ			1	111	Τİ	H			Π	ŇŔ	ΰĦ	111		: 1	\parallel
			İ,			前甘						tti i	ΤH	iiii		+		i li		Ś			74				
		17	۲ł†		1			\mathbf{H}	┝╍┿╢┾							╫╟					5			ЦĿ	<u>li</u>		
		. [[]]				144			┝╅┥┥			μ.		<u> </u>								N	ľ	· .]+			
					<u>i lli</u>	ШЦ											ГЦ		4-			. : ? .	X	1.1			
·			•		;	;ii							111						111				ㅠ	.	<u> </u>	; if	7
[•] [†] †		<u>Jil</u>									r itt	T! †			╪╬╞╬		`" I	τŀ					; : -	1.	. : :	<u></u>	ĺ
	1.17	29										╎╎╎		╫╫	┤┤┑┠╻											·- •	
		` <u> </u> L	ΗĻ	 	╡		╏╫┥		i i i i i i i i i i i i i i i i i i i		++++	╢╢	n li	₿. [‡]	¦ ↓	Ш.,	11	<u></u>	ļ' [<u>_</u>		•		1
1	- <u> :</u> -:-	<u>' '</u> :	; <u> :</u> :	!·		Щ	<u>' </u>	4							11 11		. <u> </u> '	•••	·		<u></u>			8-	7-1	70	
			:		<u>] </u>							1.1.		·		;			-1-	I			 	¢,	41	,	7
			ŀ	·							26	24	2¢	5/5	N.	LIQ	. 4	Ig A	40	W	·	• •	·			1	•
		<u> </u>	0				20		<u> </u>		<u>an</u>	تناحت			<u></u>	<u></u>				<u> </u>					<u>م لک م</u>	<u></u>	
			-				~U				70		C-1	8	60			4	ာပ			/	00	,			

•





PRINTED IN U.S. A ON CLEARPRINT TECHNICAL PAPEN NO IDIS

8-7-70 G.L.L.

- 44
ö
ъ
- T
•
0
- 0

AEROJET BENERAL QUADRILLE WORK SHEET

Θ

AEROJET-GENERAL CORPORATION A Z U S A . C A LIFORNIA

5 -PAGE,

PAGES

~

BY 6. LOMBARD AV -Siee 49 BOLLER subject____

WORK ORDER

DATE

	BRDC	BOILER	e NO.2	(PINCET.	51840)
		PCS-1 7	EST DA	14	
. WN	TNBI	WH(L)	DProt	DPORIF.	APBOIL.
48500.	1310°F	7500.	200.	32.	168.
•		8500	211.	41.	170.
		9500	216.	51.	165.
		10100	214.	59.	155.
		11000	205.	69.	136.
		11500	196.	75.	. 121.
t	Ŷ	12000	186	82-	104.

٠

TABLE

•	PAGE / OF	DATE
AEROJET-GENERAL CORPORATION Azusa. California		

PAGES

ONBARD 7 A 7 SIDE 1 49 e le Bon sublect_

WORK ORDER

D. P.	ŴN	TNBI	Wa(L)	APROL	Pibo
AB-12	6780.	1306.	553. ^v	25.	80/80
#B-9	6873.	1310.	706.	67.	103.
48-5	6717.	1309.	867.(900)	105	16011075
4 - 34	6756.	1314.	1014.(1060).	101.	162166
44-28	6806.	1304.	1042.(1120)	105.	188/00
4 4-25	6696.	1306.	1204. (1210/1330)	97.0	180 /180
41-29	6760.	1302.	1192.(240)	96.0	199/201.
DR-17	6661	1307-	1377.	93,0	222. 1220.
AA-77.	6725.	1305.	139 8.(1500)	74,0	248/202
4-2	6620.	1309.	1671.(1700)	62.0	236/2066
44-1	6860.	1308.	1712. (1740)	53.0	
A0-11	6757.	1308.	1791.	55.0	262,1266
7/1-17 11-12	7014	1310,	1838. V	56.0	260/266
7A-10 A A _ 17	6544.	1308.	1753. (1860)	51.0	271./271.
4 B-14	6612.	1308.	1720, (1740)	62.0	255/255,

58-2 BOILER TEST DATA TESTED AT V7 SCALE LOOP- AGN

NOTES:

1. NO ORIFICE 2. ONE TUBE BOILER

STK. NO. D.1-103

N

TABLE

QUADRILLE WORK SHEET



BOILER NO.4 - P/N 1266911 PERFORMANCE DATA PCS-1 TEST

DATA PT.	ŴN	TNB	TNBO	ΔPN		Тнві	Тиво	P _{HB1}	PHBO	DPH(T)	ΔP. ()	$\Delta P_{H(H)}$
1	48500	1304.8	///7.7	2.38	13000.	380.	1250.8	391,4	261.6	128.9	61.5	67.4
2	48500.	1305.1	1134.1	2.40	11800.	379.5	1248.1	372.9	239.	133.8	51.0	82.8
3	48300.	1305.0	1162.1	2.35	9700.	377.0	1243.0	345.6	201.2	145.6	. 36.0	109.6 .
4	48000.	1303.4	1189.1	2.33	7600.	374.D	1235.2	309.5	161.1	149.4 -	22.4	127,0
5	48 00.	/303.4	1219.9	2.14	5600	370.0	1229.7	233.4	119.7	113.8	12.2	101.6
6	47600.	1300.0	1256.7	2.20	3070.	324.1	1191.2	100,6	65.9	34.7	3.4	31,3
7	47600.	/307.3	1267.5	2.20	2880.	296.8	1173.2	91.7	61.3	28.7	3.1	25.6
8	37300.	1301.0	1072.4	1.39	11800	392.0	1249.9	338.7	238.9	100.5	46.0	54 5
9	37600.	1303.4	1116.1	1.42	9600-	389.9	1251.8	316.6	200.0	//9.3	34,4	84.9
10	37100.	1303.5	1151.8	1,44	. 7600.	385.4	1243.7	294.2	160.3	134.8	22.4	112.4
11	38000.	1298.5	. 1189.B	1.36	5500.	370.0	1227,2	237.5	118.1	119.9	12.0	107.9
12	37600.	1297,2	1232.6	1.33	3330.	338.9	1200.01	. 108 1	72.5	35.0	4.0	31.0
13									•			
14	26500,	1294.8	1003.6	0.74	10050.	390.2	1227-1	267.5	, 206.4	62.4	37.6	24.8
15	26500.	1295.3	1066.5	0.76	7700.	385.6	1236.8	251.9	161.3	91.B	23.0	68.8
16.	26500.	1297.3	1127.1	0.66	5600.	370.0	1223.5	231.6.	120.3	112.1	12.2	99.9
17 1	27400,	1296.8	1194.1	0.69	3450.	309.3	1196.3	//0.7	75.6	34.3	4,2	30.1
18							/	•				
19	48400.	1251.1	1081.8	2.45	11250.	378.8	1200.0	336.9	235.B	101.6	46:5	551
20	48200	1252.3	1111.9	2.34	9600.	376,4	1197,3	306.8	196.8	113.1		
21	48/00.	1250.5	1139.2	2.37	7600,	372.0	1185.0	278.0	155.6	123.4	22.4	101.0
22	48000.	1259.8	/174.ľ	2.17	5590 (⁵⁸⁰⁰)	361.1	1190.3	241.4	120.2	122.1	12.1(13.0)	110,0(109)
23	47100.	1261.0	1205,3	2.16	3450.	278,2	1168.0	120.4	80.3	42.5	4.2	38.3 ·
24	47600	1251.6	1211.1	2.14	2330.	235.8	1134,3	85,5	57,2	29.0		
25	37300.	1247.2	1038.8	1,39	10800.	377,5	1193,0	292.0	217.5	77,3	43.0	34.3
26	37000.	1245.8	1057.8	1,45	9600.	376.0	1195.9	277.3	197.2	<i>83.</i> 0	34.4	48.6
27	37 <i>00</i> 0.	1245,5.	1093.7	1.35	7700.	385.7	· 1189.4	257.9	156.6	102.1	23.0 .	79.1
28	37000.	1261.9	1150,9	1.32	5610.	363.1	1191.4	232.7	119.7	115,9	.12.3	103.6
29	36800.	/2 4 9.8	1172.7	1.30	3380.(35***)	279.3	1158.6	124.7	80.2	45.5	4,0(5:0)	41.5 ^(40.5)
30 .	37000.	1251.6	1198.7	1.34	2380. 12100)	234.0	1133.9	84.6	57.4	28,4	2.5(7.)	25.9 (15.4)
31	27/00.	1253.0	999.7	0.67	8700.	378,6	1195.8	233.8	178.8	56.8	28,5	28.3 .
32	27000.	/253.3	1027 8	0.69	7600.	376.4	1193.3	226.6	157.0	69.4	22.4	47.0
33	26400.	1253.4	1085,0	0.65	5600.	368.5	1185.4	215.4	119.2	95,6	12.2	83.4
34	26000.	12.46.1	1130.4	0.65	3460.(9900)	277.7	1155.0	140.0	80.7	61.6	4.2 is 7	57.4 (55-1)
35	26000-	1248.6	1168.0	0.66	2430.	234.0	1131.1	82.3	57.5	26.0	2.6	23.4

.

TABLE 3

TA PT.	WN	TNBI	TNBO	ΔP _N	WH(L)	тнві	THBO	РНВІ	PHBO	$\Delta P_{H(\tau)}$	$\Delta P_{\mu(o)}$	$\Delta P_{H(M)}$
			-					,				
36	48400.	/199.9	1040.8	2.42	112.50. (*	377.8	/130.6	296.4	22.0.4	76.9	46.5 10 - 2,	30.4 (^{25 h})
37	48200.	1198.4	1053,6	2.42	9700.	376.1	1150.0	273.7	195.7	80.2	36,0	44.2
38 -	48200.	1197.2	.1085.0	2.45	7850.	372.0	1144.2	249.4	157.B	93.3	23.6	69.7
39	48100.	1201.1	1118.8	2.17	5550.	368.2	. 1136.0	221.8	117.5	105.4	12.0	93.4 ·
10 .	48 00.	1199.2	1146.6	2.14	3520.	318,0	///1.8	//2.8	75.7	37.3	4.5	32.8
41	48000.	1202.7	1165.6	2.14	2560.	269.0	1088-1	7 <i>8</i> .9	54.5	24.2	2.6	21.6
12	37800.	11 98.7	1015.8	1.51	9700.	378.1	1/38.0	253.2	194,8	60,8	36.0	24.8
43	37700.	1195.1	1050.5	1.51	7600.	374.9	1138.4	235.B	153.Õ	76.8	22.4	544
44	37000.	1197.9	1083.6	1.21	5700.	368.9	1133.2	212.1	119.2	1 91.8	13.0	78.8
15	37000.	1194.0	1123.6	1.21	3450. ^{(g}	321.7	1107.5	129.0	75.5	52.9	4.5 ^(4)	48.4 ^(6).3)
16	36900.	1198.4	1147.9	1.19.	2650.	271.2	1085.0	77.3	54.2	22.8	3.0	19.8
17	26600.	1199.8	981.3	0.63.	7600-	376.0	/142.3	201.6	154.0	45.5	22.4	23.1
18	26300,	1199.6	1031.3	0.56	5620.	366.2	/127.8	190.0	117.4	70.8 .	12.1	58.7
19	26000.	1197.9	1086.9	0.57	3370.	277.8 .	1102.5	148.1	76.3	. 72. 5	4.0	68.5
50 _	26500.	1197.5	1102.7	0.61	2550,	2.39.4	1072.9	76.2	56.6	21.0	2.6	18.4
51	48500.	1145.1	1015.B	2.45	9300.	375.5	1092.2	239.1	183.1	57.9	32.0	25,9
52	48200.	/5 .	1049.6	2.44	7850.	372.0	1100.6	224.0	153.4	68.5	23,6	94.9
53	48400.	1154.4	1071.9	2.14	5660.	368.0	1092.0	201.9	116,3	83.5	12.5	71.0
54	48500.	/153.0	1097.9	2.12	3420. ^{(doc}	⁽²⁾ 277.4	1067.7	154.4	80.7	76.9	4.2 ^(6^)	7 2. 7 ^{(70.9})
5	48100.	1148.2	1110.4	2.11	2550.	232.0	1041.1	<i>75</i> ,7	55.7	20.9	2.6	18.3
56	37800.	1148.1	994.2	1.48	8100.	374.0	1095.2	2.17.8	161.7	47.7	25,0	22.7
57	37300.	//53.0	1040.1	1.20	5700.	<i>368.0</i> '	1093.0	190.2.	117,4	70.6	13.0	57.4
58	37200.	1151.5	1077.2	` 1.25	3420.	278.2	1065.5	152.1	80.7	74.0	4.2	69.8 (68.0)
59	37200.	1145.2	1094.8	1.26	2575.	234.0	1043.5	75.6	56.2	19.9	2, 8	17.1.
60		•	,		······································	· .						
61		-										
62	26300.	1143.1	1033.3	0.58	3450.	282.4	1061.4	142.D	77,8	66.1	4.5	61.6
63	26300.	1152.0	1073.8	0.60	2600,	234.0	1043.5	75,6	56.4	<i> 8</i> .7	2.7	16,0

TABLE 3 (CONTD)

DATA PT.	ŴN	TNBI	TNBO	ΔPN	Ŵ _{Ħ(L)}	THBI	ТНВО	<i>PHB</i> I	PHBD	APR(T)	4860	APuus
64	33400.	1221.8	1074.4	1.02	6500	370.0	11634	271 3	1251			
65	<i>3350</i> 0	1220.5	1052.8	1.04	7610	377.0	1165.7	226.2	133,6	90.7		
66	.33600.	/221.1	1030.3	1.06	8700.	379.0	1167.7	20414	136-1	14.0		
67 '	33300.	1194.9.	1048.8	1.02	6600,	370,7	1138.0	212 4	125 2	5/,6		
68	33700.	1201.4	1035.6	1.03	7600.	375.7	1148.0	772.5	152,5	16.6		
69	34200.	1203,8	1018.0	1.09	8700.	379.3	1151.4	22513	171.0	6713		
70	33700.	//74.3	1030.4	1.00	6600.	370,B	1120.7	2029	170.0	11.7		
71	33800.	1177.9	1011.9	1.07	7600.	377.4	1123.0	212.4	154.5	60.J		
72	34000.	1176.9	991.2	1.07	8610.	379.4	////;8	220.7	172.2	48.4		

TABLE 3 (CONT'D)



CLLARPHIN' PAPER CO. NO. C39X, MILLIMETERS 200 BY 250 DIVISIONS

FRINTED IN U.S. V. ON CLEARPRINT TECHNICAL PAPER NO 1015



8-7-70 5.6.6.

FIG. 1



K 10 X 10 TO 1/2 INCH 46 1323 X 10 INCHES A 400E IN U 5 A. • *A0E IN U 5 A. • KEUFPEL & ESSER CO.



Kot 10 TO 10 10 INCH 46 1323
 T X 10 INCHES MARTIN U.5 A. .
 KEUFFEL A ESSER CO.



QUADRILLE WORK SHEET

PAGE_____OF_____B___PAGES DATE SEPT. 3, 1970

SUBJECT BRDC BOILER NO. 5 BY G. LOMBARD WORK ORDER 1475-44-014

PREDICTED WATER FLOW PRESSURE DROP OF SWAGED PLUG INSERT AND TUBE ASSY'S

THE METHOD OF ANALYSIS UTILIZES THE REYNOLDS NUMBER ANALOGY.

 $RE_{H_2O} = RE_{H_3}(LIQ) \tag{1}$

$$\left(\frac{V D_{e} S}{\mu}\right)_{H_{2}O} = \left(\frac{V D_{e} S}{\mu}\right)_{H_{3}(LQ)}$$
(2)

$$V = \dot{W} / A \leq$$
 (3)

SUBSTITUTING (3) INTO (2) GIVES :

$$\left(\frac{\dot{W} De}{A\mu}\right)_{H_2O} = \left(\frac{\dot{W} De}{A\mu}\right)_{H_3(LIQ)}$$
(4)

SINCE De/A IS CONSTANT:

$$\left(\frac{\dot{w}}{\mu}\right)_{H_{2}0} = \left(\frac{\dot{w}}{\mu}\right)_{H_{2}(L)Q}$$
(5)

THE TOTAL PRESSURE DROP ACROSS THE PLUG INSERT CAN BE EXPRESSED AS THE SUM OF THE FRICTION LOSS, AND ENTRANCE/EXIT EFFECTS LOSSES. SUCH THAT:

$$\Delta P = \Delta P_{\text{FRICT.}} + \Delta P_{\text{ENT.}/\text{EX.}} \quad \text{psid} \quad (6)$$

LEROJET GERURAL TIR BENERAL

AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA

PAGE Z OF B PAGES DATE SFRT. 3. 1970 WORK ORDER

SUBJECT BRDC BOILER NO. 5 BY G. LOMBARD

QUADRILLE WORK SHEET

 $\Delta P_{FRICT.} = f_{ex} (L_e/D_e) [42/(2)(g_c)(g)(144)], psi (7)$ fex = FRICTION FACTOR DETERMINED EX-WHERE PERIMENTALLY, FROM REFERENCE 1. Le = EQUIVALENT FLOW PATH LENGTH, IN. De = EQUIVALENT DIAMETER, IN. G. = MASS VELOCITY = W/A, LB/SEC-FT2 S = FLUID DENSITY, LB/FT3 9c = GRAVITY CONSTANT, FT/SEC2

$$\Delta P_{ent/ex} = K_{ex} \left(L_e / D_e \right) \left[G^2 / (2) (g_c) ($$

WHERE Kex = ENTRANCE & EXIT LOSS COEFFICIENT EXPERIMENTALLY DETERMINED IN REFERENCE I FOR A 5-GROOVE MULTIPASSAGE PLUG INSERT AND EXTRAPOLATED FOR 16 PASSAGES. SEE FIGURE 1.

THE FLOW PATH GEOMETRY IS AS FOLLOWS:



CROSS-SECTION OF A SINGLE GROOVE.



MINIMUM AREA, PERIMETER & EQUIVALENT DIA. $a_1 = .00464 \text{ sq.in.}$ $p_1 = .2586 \text{ in.}$ $De_1 = .0716 \text{ in.} = 4a_1/p_1$

MAXIMUM AREA, PERIMETER & EQUIVALENT DIA. $a_2 = .00534$ SQ.IN. $P_2 = .2768$ IN $De_2 = .0770$ IN

THE EQUIVALENT FLOW PATH LENGTH IS: 1 Le= 35.6 IN.

FLUID PROPERTIES :

$$T_{H_{20}} = 70^{\circ}F$$

$$S_{H_{20}} = 62.3 \ LB/FT^{3}$$

$$\mu_{H_{20}} = 2.37 \ LB/HR-FT$$



CALCULATION OF WATER
$$\Delta P$$
 Based ON
MINIMUM FLOW PASSAGE DIMENSIONS
 $RE_{H20} = 1.76 \times 10^{4} (\dot{W}_{H20}) , DIM.$
 $G_{H20} = 1.94 \times 10^{3} (\dot{W}_{H20}) , LB/SEC-FT^{2}$
 $\left[G_{H10}^{2} / (2)(g_{c})(S)(144)\right] = 6.51 (\dot{W}_{H20})^{2} , P51$
 $\frac{Le}{De_{1}} = 497.$

$$W_{H_2O} = 0.912 (W_{H_2O}) , LB/SEC$$

WHG (TOTAL) LB/HR	ŴĦĢ LB/SEC-TUBE	W/H20 LB/SEC-TUBE
6000.	.139	. 127
10000.	.232	.212
14000.	.325	,296



QUADRILLE WORK SHEET

SUBJECT.

BRDC

BOILER

NIP.S

MG. LOMBARD

WORK ONDER.

AERO)ET-GENERAL CORPORATION

PAGE_ DATE SEPT 3, 1970 Կ q $\boldsymbol{\omega}$ PAGES

WATER FLOW AP BASED ON MINIMUM DIMENSIONS

WHL0	6.51 (WHO)	fex Le De	Kex	APFRICT,	DRan/Ex	ΔP
- 127	. 105	22.4	12.0	2.35	1.26	3.61
-212	, 293	18.4	12.0	5.39	3.52	8.91
.296	.570	15.9	12.0	9,07	6.84	15.91

WHEO	REHZO	fex	
. 127	2240.	.045	
.212	3730.	.037	
.296	5210.	.032	

C-34

.

QUADRILLE WORK SHEET



AZUSA. CALIFORNIA

PAGE_	OF	8PAGES
DATE_	SEPT. 3.	1970

SUBJECT BRDC BOILER NO. 5 BY G. LOMBARD WORK ORDER

CALCULATION OF WATER DP BASED ON MAXIMUM FLOW PASSAGE DIMENSIONS

WATER FLOW RATES ARE THE SAME AS GIVEN ON PAGE 4.

01-071-002

QUADRILLE WORK SHEET

SUBJECT_

BRDC

BOILER

NO.S

G.LOMBARD

WORK ORDER.



AEROJET-GENERAL CORPORATION

PAGE_ DATE. SEPT. q ω D 1970 PAGES

FLOW AP BASED ON MAXIMUM WATER DIMENSIONS

.

٠

WH20	$4.93 \dot{w}_{\mu_2 0}^2$	fex Le Dez	Kex	APFRICT	DBen/ex	ΔP
.127	.080	209	12.0	1,67	0.96	2.63
.212	. 222	17.6	12.0	3.91	2.66	6.57
.296	.432	15.25	12.0	6.60	5.20	11.80

..

WHLO	REHLO	fex
.127	2050.	.0452
.212	3420.	,0380
,296	4780.	.0330

C-36

01-071-002



QUADRILLE WORK SHEET

page_8_ of_8_pages date_<u>SEPT: 3, 1970</u>

WORK ORDER___

SUBJECT BRDC BOILER NO.5 BY G. LOMBARD

THE MAXIMUM & MINIMUM PREDICTED WATER FLOW, PRESSURE DROP VALUES ARE PLOTTED IN FIGURE 2.

REFERENCES:

1. SELLERS, A.J., <u>FORCED CONVECTION</u> <u>MERCURY BOILING - EXPERIMENTAL INVESTI-</u> <u>GATION USING A HELICAL MULTIPASSAGE</u> <u>PLUG INSECT IN A ONCE THROUGH BOILER</u> AGC TECHNICAL MEMORANDUM 4934:67:459 DATED 31 MARCH 1967.

FIGURE 1.

LOSS COEFFICIENT, KER, VERSUS THE NUMBER

OF PASSAGES FOR A MULTI-PASSAGE PLUG



1206

ę

. M 2 | - - -

со<u>1</u> Ф

> 3 SEPT. 1970 G. LOHBARD

FIGURE 2.

PREDI	CTED	WATER	FLOW	ΔP	VS	WATER
FLOW	FOR	BRDC	BOILER	NO.	5	SWAGED
PLUG	INSER	T TUBE	ASSEM	BLY	-	P/N 1268



46 7206

のたちという

35EPT. 1970 G.LOHBARD

APPENDIX D

BRDC BOILER NO. 5, PRESSURE DROP THROUGH NAK SIDE OF THE BOILER Nak - SIDE HYDRAULIC TEST RESULTS ON A PLASTIC MODEL OF

BRDC BOILER NO. 5

G. L. Lombard, Static Components

INTRODUCTION

The purpose of hydraulically testing a shell-side model of the SNAP-8 NaK-to-Hg boiler is to confirm the NaK flow mixing characteristics and pressure drop requirements are met by the current design. Tests similar to those discussed herein were conducted on BRDC Boiler No. 4 which was a 7-tube design. The results of these tests accurately predicted NaK-side pressure drop. It was demonstrated that a helical wire turbulator, wound about the tube bundle was definitely advantageous in promoting turbulent mixing of the NaK fluid and subsequent uniform circumferential temperature distribution.

Pressure drop tests were performed at water flow rates based on the Reynolds number analogy with the loss coefficient expressed in terms of the shell-side velocity head. Dye injection tests to demonstrate shell-side mixing capabilities were performed with water velocities equivalent to NaK velocities.

The remainder of this report presents the tests performed, results and methods of analyzing the data.

SUMMARY

Results of the dye injection tests run at water velocities of 5.0, 4.0, and 3.0 feet per showed that the fluid is mixed and that the wire coil pitch and wire diameter of 6.0 inches and .125 inch, respectively, are satisfactory.

The loss coefficients for the tube bundle supports, wire coils and inlet & exit manifolds are summarized below (values are based on shell-side velocity head) :

- 2 -

The total boiler NaK-side pressure drop at 58,000. lb/hr and temperature equal to 1135 F is 1.69 psid. This value is well within the system requirement of 3.0 psid.

In conclusion, the NaK-side fluid dynamics of the proposed design are satisfactory.

PRESSURE DROP TESTS

A full scale cross-sectional model boiler containing three (3) tube bundle supports, twelve (12) flattened oval tubes, two (2) helical wire coils (one righthand, one left-hand and both with a 6.0 inch pitch) wound around the 3.5 inch O.D center tube and the tube bundle and the inlet/exit manifolds is shown in Figure 1. The pressure drop readings were measured across three sections of the test piece as shown in Figure 1.

The water flow rates were determined on a equal Reynolds number as given by the following:

and

$$W = W (\mu/\mu)$$

$$H_2O NeK H_2O NeK$$

ግ
The physical properties of NaK and water are as follows:

- 3 -

Water temperature	75 ^o f
Density	62.26 lb/cu. ft.
Viscosity	2.20 lb/hr-ft.
Nak temperature	1135 ^o F (Average)
Density	45.3 lb/cu. ft.
Viscosity	0.38 lb/hrft.

therefore:

Data of pressure drop across sections (1-2)(2-5) and (3-4) are listed in Table 1 over a range of flows from 32.0 lb/sec to 91.0 lb/sec. Listed in Table 2 are the calculated loss coefficients (based on the shell-side velocity head) and Reynolds numbers for the different water flows. It should be noted that the coil loss coefficient excludes friction. The coil pressure losses were obtained by subtracting the pressure loss (3-4) multiplied by 3.0 (the total number of spacers between 2-5) and **extini** (2-5) as follows:

$$\Delta P = \Delta P - 3 \left(\Delta P - 3 \right) - \Delta P_{ax}, \text{ psi}$$

Plotted in Figures 3 and 4 are manifold pressure drop, wire coil and spacer pressure drops, respectively, versus water flow in lb/sec. In Figure 5, the shell-side velocity head, H_g , is plotted versus water flow for convenience when calculating the head loss coefficients. Figures 6,7 and 8 give manifold spacer and wire turbulator coil loss coefficients versus Reynolds manifold.

To generalize the wire turbulator coil loss calculations for NaK flow the coefficient is expressed on a per foot of axial coil length basis. Table 3 gives the equations for Reynolds number and H_a used in the analysis.

In the following calculations the NaK-side pressure loss for a full-scale BRDC Boiler No. 5 is made for W_n =58000.lb/hr and an average temperature of 1135°F

NaK	density	45.3	lb/cu.ft.

NaK viscosity 0.38 lb/hr.-ft.

Velocity: $V_n = (58000/3600) (144.0/14.25) (1/45.3) = 3.60 \text{ ft/sec.}$ Reynolds No. : $RE_n = (3.60) (.915) (45.3/0.38) (300.) = 117700$ Shell-side velocity head: $H = (3.60)^2 (45.3) / (2g_c 144.) = .0633 \text{ psi}$ Spacer pressure loss:

 $\Delta P_{sp} = nK_{sp} H_{s}, psi \qquad \text{where } n=7 \text{ spacers}$ $\Delta P_{sp} = (7.0)(0.50)(.0633) = 0.222 \text{ psid}$

Inlet & Outlet manifold loss:

$$\Delta P_{man_{\bullet}} = nK_{man}(H_s)$$
, psi where n= 2 manifolds
 $\Delta P_{man_{\bullet}} = (2)(5.65)(.0633) = 0.715$ psi

NaK turbulator coils loss:

$$\Delta P = (L)(F_c)(H_s)$$
, psi where $L = 10.0$ feet
 $\Delta P_c = (10.)(0.5) (.0633) = 0.317$ psi

Frictional pressure loss:

$$\Delta P_{f} = (f_{ex}) (\underline{L}) H_{s}, \text{ psi} \quad \text{where } f_{ex} = .0171 \\ L = 21. \text{ ft} \\ D = 0.915 \text{ in} \\ \Delta P_{f} = (.0171) (12.)(21.)(.0633)/(0.915) = 0.298 \text{ psi}$$

Pressure loss due to "S" bends:

$$\Delta P_b = (nK_b) (H_s), \text{ psi}$$
Where $K_b = \text{function of } R/d$; $R = 25 \text{ in; } d = 1.88 \text{ in}$
 $R/d = 13.3 \text{ and from ref. l page 318, Fig 137}$
 $K_b = 1.68 \text{ ; and n = the number of } 180^\circ \text{ bends = } 2.0$
 $\Delta P_b = (2)(.0633)(1.08) = 0.137 \text{ psid}$
The predicted total NaK-side pressure loss across the boiler is: $\Delta P_t = 0.222 \pm 0.715 \pm 0.317 \pm 0.298 \pm 0.137 \text{ psid}$

 $\Delta P_t = 1.69 \text{ psid}$

Shown in Figure 9 is predicted NaK-side pressure drop versus NaK flow. NaK - Side Mixing Tests

Fluid mixing was observed by injecting dye (food coloring) into the fluid stream as shown in Figure 2. These tests were performed at water velocities and Reynolds numbers tabulated below & a water temperature of 76°F.

H ₂ 0 Velocity, ft/sec	RE _{H2} 0
5.0	39100.
4.0	31200.
3.0	23400.

Visual observation of the fluid stream after injection revealed that complete mixing occurred within 1.5 feet downstream of the injection point at 5.0 ft/sec within 2.5 feet at 3.0 ft/sec. Mixing characteristics of the inlet and outlet manifolds were also observed at the same velocities as listed above. Complete mixing in the manifolds was evident. Photographs were taken during the dye injection tests as a means of recording these tests.

D-6

In comparing the Reynolds number at which the dye injection tests were performed they are substantially lower than the design value of 117700 (\dot{W} = 58000. 1b/hr) This was done for two reasons. One, at low Reynolds numbers, i.e. at water velocities equal to NaK velocities, observation of mixing is facilitated. Second, if adequate mixing was observed at these lowReynolds numbers then, at design conditions, good mixing would be assured in the boiler.

CONCLUSIONS

- 1. The expected NaK-side pressure drop for this design (1.69 psid) is well within the system requirement of 3.00 psid.
- 2. The design of the NaK turbulator coils is satisfactory for the purpose of promoting fluid mixing during boiler operation over a range of NaK flows from 30000 to 58000 lb/hr.

REFERENCES

1. Vennard, John K., Elementary Fluid Mechanics

-7-



٠

AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA

PAGE	of	PAGES
DATE		

BUBJECT BRDC BOILER NO.5 PLASTIC FLOW MODEL

_____BY_G, LOMBARD WORK ORDER_

DATA TABULATION :

TABLE 1

WH20	△P00	∆P©@	AP06	*APax	APcoil
(LB/SEC)	(P51)	(PSI)	(PSI)	(PSI)	(PSI)
32.0 35.8 41.0 48.0 53.0 60.0 68.0 75.0 81.0 90.5	1.05 1.30 1.70 2.25 2.90 3.55 4.65 5.60 6.60 8.20	0.101 0.126 0.160 0.215 0.255 0.326 0.326 0.326 0.326 0.326 0.326 0.326 0.326 0.326	1.51 1.87 2.40 3.22 3.85 4.90 5.31 7.41 8.64 10.67	0.426 0.519 0.660 0.871 1.038 1.288 1.610 1.913 2.19 2.67	0.78 0.98 1.26 1.70 2.05 2.63 3.31 4.00 4.71 5.85

$$\Delta P_{00} = \Delta P_{MAN}.$$

$$\Delta P_{00} = \Delta P_{SP}$$
*
$$\Delta P_{Ax} = f_{Ax} \frac{L}{D} H_{S} \quad ; f_{Ax} = \cdot 316 / Re^{\cdot 2S} \quad FOR \quad B.1 FT = L$$

$$\Delta P_{COIL} = \Delta P_{00} = -\Delta P_{Ax} - B.0 (\Delta P_{00})$$

FCOL	³ K _{sp.}	®KMAN.	°f _{ax.}	(PSI)	$\Delta P_{sp.}$ (PS1)	APMAN. (PSI)	Re _{H20}	WH20 LB/SEC)
.535	.561	5.83	.0223	0.78	0.101	1.05	40350.	32.0
.538	.560	5.78	.0217	0.98	0.126	1.30	45080.	35.8
.525	.540	5.74	.0210	1.26	0.160	1.70	51600.	41.0
.516	,529	5.54	,0202	1.70	0.215	2.25	60500.	48.0
.510	.513	`5,85	.0197	2.05	0.255	2.90	66800.	53.0
.Stil	.513	5.60	.0191	2.63	0.326	3.55	75600.	60.0 -
.500.	.49.7	5,68	.0185	3.31	0.408	4.65	85600.	68.0
. 494	.300	5.60	.0180	4.00	0,50	5.60	94500.	75.0
.500	.498	5.66	.0177	4.74	0.58	6.60	102000.	81.0
.495	.491	5.62	.0172	5.85	0.716	8.20	114.000.	90.5

KMAN. = DPMAN. / HSHELL & REPRESENTS LOSS COEFFICIENT FOR ONE MANIFOLD. 0 KSP. = APSP. / HSHELL & REPRESENTS THE LOSS COEFFICIENT FOR ONE SPACER.

Ð FEOR = DPCOIL (18.1) (HSHELL) WHERE B.IFT WAS THE LENGTH OF WIRE COIL BETWEEN PRESSURE TAPS @ & @

HSHELL = SHELL -SIDE VELOCITY HEAD (PSI), UPON WHICH ALL EXPERIMENTAL LOSS COEFFICIENTS ARE BASED.

D-10

 \oslash

6)

STK. NO. D.1-103

01-071-00

QUADRILLE WORK SHEET

AZUS

CALIFORNIA

AEROJET-GENERAL CORPORATION

PLASTIC

FLOW

MODE

1BARD

VORK ORD

PAGES

QUADRILLE WORK SHEET



AEROJET-GENERAL CORPORATION

PAGE_____ OF____PAGES
DATE_____
WORK ORDER_____

SUBJECT BRDC BOILER NO. 5 BY G. LOMBARD PLASTIC FLOW MODEL

TABLE 3 - EQUATIONS

REYNOLDS NUMBER $\mathbf{RE} = \left(\mathbf{V}, \frac{ft}{sec}\right) \left(\mathbf{D}_{\mathbf{E}}, \operatorname{in}\right) \left(\mathbf{S}, \frac{1b}{ft^{3}}\right) \left(\frac{1}{\mu_{2} \frac{1b}{ht^{3}}}\right) \left(\frac{3600 \operatorname{sec}}{ht^{3}}\right)$ $\left(\frac{1}{12.0\text{ m}}\right)$ $\mathsf{R} = (\mathsf{B} \mathcal{O} \mathbf{O})(\mathsf{V})(\mathsf{D}_{\mathsf{E}})(\mathsf{S})/\mu$

<u>VELOCITY HEAD:</u> $H = \left(V_{3} \frac{f+}{f+2}\right)^{2} \left(S_{3} \frac{16}{f+3}\right) \left[\left(29_{c}, \frac{f+}{5\epsilon c^{2}}\right) \left(144 \frac{10^{2}}{f+2}\right)\right], psi$ $H = \left(V\right)^{2} \left(S\right) (9270. , psi)$

DARCY-WEISBACH EQUATION:

$$\Delta P = f \perp H , PSI$$

D-11

FOLDOUT FRAME!

EOLDOUT FRAME 2







Aarojet-General CORPORATION

ً⊗

Kor Logarithmic 46 7083 ≥ x1 cycles mare in u.s.n. i keuffel a esser co.



Acrojet-General CORPORATION

ً

K4E LOGARITHMIC 46 7083 2 X 1 CYCLES NAPEIN, U.S.A. KEUFFEL & ESSER CO.



Acrost - General CORPORTION

ً⊗

K¢E LOGARITHMIC. 46 7083 2 × 1 cycles wherh u s A. Keuffel & esser co.

• •		; ;	E :				1. ::	1	1111	.				·	= F]		Fin		:==;;	· : : : : : : : : : : : : : : : : : : :								FH 1	7771	1:::		1:	<u></u>	1
<u> </u>			 		<u></u>	·	1:::.		==			<u></u> ;					T											<u></u>				- F		
							<u>.</u>	<u> </u> .			<u></u>	=			- 4	1 +-	tr:		<u>.</u>			<u> </u>	r i ,				<u></u>	HT.	+ +	1			<u> </u>	
117	4		F .: !:				15.	5								-[111	ti s F			<u>i Ei</u>	문민	<u>.</u>	÷									<u>_</u>	
· · · · · · ·					- [:			1	1-1-		Ξ					 				15		<u></u>	11-1				4		핏h	15			- 1-	
																													E					
	-			···· -					<u> </u>	F		111 1-1-1-1	41111	+						;				· • • • • • •					<u> </u>					, <u>, , , , , , , , , , , , , , , , , , </u>
			+				<u>[</u>]	〒				IN	6	1	8	C(л г	EE		MA	<u>}, </u>	ŧ0	1.5	Y -#										
:::[_:									<u> </u>				LΦ	55	讍	0	EF	HK	E	t (I		K,						詽	井					印印
								hre	177	ΞĒ	詽		V.	kΨ	Re	Ŷ	0	ED:		NUA	18					Шţ			詽	詽				
		9.6									- +++						<u>.</u>						<u>.</u>											
												+									╡╅┉╆┺╺ ┇╢╴┛┙┙ ┇╻╎╴┙╸					<u>-+++</u> 1 	┿┝┯┼┤ ┲╈┑╤┨			+++++++++++++++++++++++++++++++++++++++	┥╷╬┷┦┍┍╄ ┷┅╠┟┨┯┯╽	┿╎╬╖╍╌╍┥┽ ┿╎╠╞┝╤╕╈┥		
							+																				ÉЩ			赳		Į		
	=															Ē											曲		詌					
																		甘井																
													244	<u>tij</u>					曰日											44				
																			1 - <u>1</u> - 1 1 - 1 - 7 - 1 - 1															╺ <u>┥</u> ┍╼┝┍┥┍ ┝┑┝ <u>┤</u> ╿┽┾┯
K	A 11										44									┹┠┢╢┠┽╏ ┚╸┝┨╈╋											┙┺┍┥┠┼┤ ╽╋┍┽┠┊┼╷			
· · · · · · · · · · · · · · · · · · ·	11 (NO	<u> </u>									<u> </u>		i <u>r</u> ri		<u>#</u>																			
		ā					日三				詌			ΞĒ									邗							111				
							田田	田		24	淵	0															詽日		詌					
																			訓								詽							
																												HH						
		<u>,</u>															<u>+</u> ++	11+++				ЦЩ	단관	T.T.T.	ЦЦ		ш					┇┇╤╡╡╏┇ ╸┨┯╴╘╹╶╴┨		
		10													-1-+-	44	##	<u>Hir</u> l.					- T					ЩI	刵					
÷=				<u>.</u>		=				邗			, in i												山山			詽					[
				<u>s</u> t											拼																		ЦШ	
				17		++++		FΠ					H												田	t II	詽							
					- 1 -					1								1																
		20			ΞĒ									<u>+ </u>		┿┥┥┼ ┥╷╷┥																		
											<u>+-</u> j+		<u>F</u>									Шİ						뱀	井井				5144	
1.01	<u> </u>		1											Eit	日日	40	旧						詽	邗	眲	F	瞱			雦	비비비			
	- ·				= [=		<u>F</u>			111.	ΞĒ	<u></u>		::::	Εt		Ħ	H						<u></u>		E					FHH			
- m							1				1157		ς Ε	YA	34	D-	5	YCH	176	法保								目		<u>iiii</u>				1441
:6			5 +			7											H.	t fi	曲	THE		世日				囤				f III.				
			[-												hil	<u>H</u> TH								14	ti t			÷++				┝┥┽┥┊┽╃		1.4.1.1
	4 - '	1	1 1				1	44			7.77	- · · ·	11.17		17 M E	три	ΠH.	11 11 11		111111	rit"	12:11		-1114	1.1.1.	11.1	1111	11111	11111	a li tt	1111111	111111	11111	

нн. Hri

	, 	<u>.</u>	1					-	:::	1.			•••		:		[:-:.	• • • •	:::	·				11-7	<u>, , , , , , , , , , , , , , , , , , , </u>	,								
	;_ _ ;			•		<u>.</u>		1.1	ند. 4 الأم و						:			;	1:.:		<u>.</u>			H-				<u> -</u>		<u> </u>			<u> </u>	<u></u>
											;;;		;;;				****		· · · ·	L :						· · · · · · · ·			+ 					
	· · · -						: ÷.			_::		11.		::::				 					†	.				T .						
				1		··· 1:.·	1::::			1.1		1.1						, , , , , , , , , , , , , , , , , , ,				71								i:n				
		10								::	111	1:	押	UB	E	-B	DN	Đ	E.	#S	ÞA	a									- 11 -			
	1								••••••				<u>F</u> F	0s	5	C	0e	E A	70	lE	MT.	, X	SP				┶┶╪┙╤┾╤ ╧┸╪╵╤╛╤							
	111	9					Ē	÷				ΗĽ	Ň	S	R	Ŷ	N¢	ž	3	- N	ÛN	18	1.	2					PR	En	sici	бÞ		
									1		1				<u>111</u>	<u>titi</u>					<u>1</u>													
							,		i				<u></u> 7-71																					
							-1		1-4- 																									
																			+++															
	5	5																						Ē										
									\$.4	<u>s</u>																								
		4									- 141			*****																				
						====																								L i r				
····		- 3												+																				
<u>.</u>										Ξ.Ξ								HH.																
		- 2											<u> </u>		÷																			
<u>;;;[</u>														111																				
											::::: ::::::				г ^{1.} .							1 1 1												
E															+		Ħ		444															
<u>D</u>									I	· · · · · · · · · · · · · · · · · · ·		Re	Ĥ	YO				Y ⁽²⁾		203.1														
	 				4		1		1								8		11]]		D					X	101							
						<u></u>						1		24				;;] _																
	<u> </u>		· · ·	<u></u>	<u> </u>	<u></u>		· · · ·				<u>;</u>						:::: -:	<u>;;;;</u>	<u> ;:::</u>				++++ +									E F	
	i `	·		<u>[` :.</u>	<u></u>					.,	::;;		1.			, ,		: !			67	171		17-11	iiiii F		<u></u>	<u> </u>				<u> </u>		

D-18



٠

• • • • • • • • • • • • • • • • • • •	. 1			 5.			17. _``T	[];;;	:: ·						: =	= 1				- ! : :			;;:1 ;,:1			· · ·			: : :			1.1	曰		
								::: ::::					1	; ::	.i†	: : : : :					 ;;;;;				:1: '				1		T				
										·						÷.				1121 1121		<u>- 11 :</u>									-1 FC				
· · · · · · · · · · · · · · · · · · ·		, <u>, , , , , , , , , , , , , , , , , , </u>		 	1: F.				,																										
					-1 <u>_11</u> ;1																											 			
		2				<u> </u>	li ir																												
							1.1-					1																							
		7		 1- <u>-</u>											(5)	R	EY	N.	<u>o</u> u	5	201		N.												
		a				1.1.1. 1.1.1. 1.1.1.																				#		백태							
				 										<u>E</u>									+												
		Ż																																	
						<u> </u>					<u>+1</u>		ЦЩ ЦЦ	HT TT													Re	A		E D					
Keg	Z	G											++++ +++++ +++++								- - - -														
				 ==,	-					Ň		0	TTTTT	K I																					
																					M		¥												
		4					,																												
								4			11-1 1, 1																								
		3		 		· · · · ·	+1					-144 75.r																							
			2																																
::::::::::::::::::::::::::::::::::::::					 																														
		7																																	
								+																											
0																			44.44 14																
ð.																								127 1		-45									
- N					-			1-1				1-1 <u>1</u> 17:1-			+ 11 -[]					ħ															
		-	. j-	 	-																							44	<u>r</u> i _r ,					. T : []]	



Acrojet-Ceneral corporation

€

K4E LOGARITHMIC 46 7083 2 × 1 cycles MAR IN U.S.A. KEUFFEL & ESSER CO.

AFROJET	AEROJET NUCLEAR SYSTEMS COMPAN	NY ENGINEERING FILE NO	
GENEGAL A	POWER SYSTEMS OPERATIONS	EDF SERIAL NO.	DE 0025
CONTRACT OF	ENGINEERING DESIGN FILE	DATE	7-30-70
PROJECT_	SNAP-8		1475-44-0117
SUBJECT	BRDC BOILER NO. 5, PRESSURE DROP 1	HROUGH NaK-SIDE OF TH	Æ BOILER
ABSTRAC	T	. <u>,</u>	
	Analytical calculations to determ are presented.	nine the subject press	sure drop
	The overall pressure drop through	the NaK side of the	Boiler was
	calculated to be 1.50 PSID. The 3.0 PSID.	allowable PCS-G requ	irement is
1			
DISTRIBU	JTION R. Alena, B. Breindel, E.S.Ch R.W.Marshall, Jr., U.A.Pineda	alpin, C. Hawk, G.L.I	ombard,
COVER S	HEET ONLY		
	J.Hodgson, A.H.Kreeger, L. Lo	ppez	
KEY WOF	BRDC Boiler No. 5, NaK-Side	Pressure Drop	
AUTHOR R.A	lena N. allena DEPT REV	ENED DATE	REVIEWED Lall BATE
•		· · · · · · · · · · · · · · · · · · ·	· · · · · · · · · · · · · · · · · · ·



AEROJET-GENERAL CORPORATION AZUSA. CALIFORNIA

QUADRILLE WORK SHEET 7412 30, 1970 SUBJECT BROC BOILER NO 5 BY RALENA WORK ORDER_1415-44-0117 T INTERMEDIATE LOOP PRESSURE DROP THRU Nak-SIDE DETHE BOILER A. GIVEN DATA Nak FLOW RATE: 57.020 161HR ; WN = 15.82 16 | Sec TNak IN = 1210°F TNak OUT = 1041°F > TNAK AU = 1,1250F Nak PHYSICAL PROPERTIES AT 1,1250F - (REF. HANDBE H-100, N-2, REVC) DENSITY SNak - 45,315/FT3 ABS. VISCOSITY MINNE 0.38 15/HR-FT BOILER NO-5 GEOMETRIC DATA - (REV. ENCLOSURE 1) FREE FLOW ARRA AF= 15:01 in 2 FREE FLOW ARRA ATSPACERS AFS = 11.11 in~ WETTED AREA Aw= 18048 in2 WETTED PERIMETER PW- 80.6 in HYDRAULIC DIADETER DH = 0.915 in BOILER LENGTH . 39.50 + 2 TTx 25 + 23.25 + 32.25 = 252 in or ZIFT No of TOBRES IN BUNDLR = 12 No of TUBRE BINDLE SUPPORTS = 7 B. SHELL SIDE VELOCITY HEAD 1) Nak VELOCITY (VN) VN= <u>wsec + <u>F75</u> <u>IS.82×144</u> = <u>3.4</u> FT/Sec S(En) × AF (IN3) <u>45.3×15,01</u> = <u>3.4</u> FT/Sec</u>

#1-9**91-co**z

QUADRILLE WORK SHEET



AEROJET-GENERAL CORPORATION

PAGE 2 OF 7 PAGES

BUBJECT BRDC BOILFER NO S 2.) VELOCITY HEAD (HN) HN = $\frac{S_N V_N^2}{2g}$ $\frac{\frac{15}{FT^3} \times \frac{FT^2}{Sec^2}}{\frac{FT}{Sec^2}} = \frac{5}{ET^2} \times \frac{FT^2}{1441n^2}$ = $\frac{45\cdot3\times(34)^2}{2\times32\cdot2\times144} = \frac{0.0568 PSI}{0.0568 PSI}$

G.
$$\frac{RETNOLOS NURBER}{Re} = \frac{SN DH VN}{MN} = \frac{3600}{12} \left[\frac{45.3 \times 0.905 \times 3.4}{0.38} \right]$$

= 300 [367] = 110,000 (TURBULENT FLOW)

D. PRESSURE DROP THRU Nale-SIDE OF BOILER

11 INLET AND OUTLIEF PRESSURE LOSSES.

THE NER INLET AND OUTLET GEOMETRY IS IDENTICAL,



. 61-071-002 **AEROJET-GENERAL CORPORATION** GENERAL **AZUSA. CALIFORNIA** QUADRILLE WORK SHEET PAGE SUBJECT BROC BOILFER No. 5 BY R.AUENA THE SIZE OF THE 12 HOLES THOU THE T.S DIA SHELL BE BASED ON THE SAME RATIO OF FREE ADEATO HOLRS ARE AS FOR BOILFER # 4 BOILFER # 4 (REF. AP ANALYSIS FOR BOILFER No. 4 BT. G. LONBARD) A FREM (NO SUPPORTS) = 10.78 In" A FRAME (AT SUPPORTS) = 6.65 In~ OR AFATSIOD = 61.8% OF AFNO SUPP. RADIAL HOLRS = G - 11/2 in DIA. AH= 6x 1.767 = 10.6 m2 02 AH = 10.6 = 0.985 of A FRAME (NO SUPPORTS) BOILER # 5 (REF. ENCLOSURE 1) A FRER (NO SUPPORTS) = 15.01 in -A FRER (AT SUPPORTS) = 11.11 in AFATSHP = 73.8% OF AFERE (No SUPP.) OR USE 12 HOLES OF 1/4 DIA AH = 12 x 1.227 = 14.7 104 OR AH - 147 " 0.98 OF A FRER (NO SUPPORTS) THIS IS SAAR AS FOR BOILER # 4

D-24

AEROJET AEROJET-GENERAL CORPORATION
QUADRILLE WORK SHEET DATE AND 20 1920
SUBJECT BROC BOILFER NO. 5 BY R. ALFENA WORK ORDER 1475-44-0117
AP OUT = KOUT × HN
SINCE Nele INLET & OUTLET ARE SIMILAR KIN= KOUT AND APIN= APOUT
DETERNINATION OF KIN OR KOUT
NOTE: KIN-OUT FUL BOILER 44 KS SEO (BASED ON TEST DATA)
KIN-OUT = KENTRANCE ON FEXIT + K SUDDANCHANCE IN CRUSS SPECTED
+ K FLOW THOU 12 DEIFICES + K 90. BRIND
FRON REF. 1. pases 83 THOU 90
KENTROMER OF PEXIT = 0.5
KSVDDAN CHANCE IN CRUSS SACTON SINCE ANAL = 0.5 KENIMGENENT = KCONTRACTON = 0.28
KELOW THRU 12 DEIFICRS
ASSUME THAT THE DAAL Nok FLOW IS EVENLY DIVIDED APANG THE 12: HOLES.
CONSIDER THE HOLES AS THIN-PLATE, SOURE-EDGE ORIFICES
FOR RE=110,000 AND AHURS = 0.98
DRIFICE FLOW COEFFICIENT C = 0.78

•

QUADRILLE WORK SHEET



AEROJET-GENERAL CORPORATION

PAGE_5_OF_7_PAGES SUBJECT BROCBOILER NO.5 BY RALENA WORK ORDER CONVERSION OF C TO K' FACTOR Q= AcVZgHL $H_{L} = \frac{Q^2}{A^2 c^2 2 q} \quad but \quad Q = AV$ on $H_{L} = \frac{1}{c^2} \cdot \frac{g}{2q} \quad v^2 \quad or \quad \frac{1}{c^2} \cdot H_N$ THEREFORE $K_0 = \frac{1}{c^2} = \frac{1}{(0.78)^2} = \frac{1.64}{1.64}$ K 90° BEND = 1.1 K IN-OUT = 0.5+ 0.28 + 1.64 + 1.1 = 3.52 THEREFORE APIN= 3.52 × 0.0568 = 0.20 PSI APOUT - 3.52 × 0.0538 = 0.20 PSI 2. PRESSURE LOSS THRU & -1.80° BENOS R= 25.0 in d = 2(Do: - Dijo) = (7.26-3.5)/2= 1.88 in R/d = 25/1.28 = 13.3 N= 2 (2B=205) FRON REF. 2 Page 218, F16. 97 For RId = 13.3 Kb = 2x 0-38 = 0.76

J. PRESSURE DROP DUE TO NEL TURBULATORS

THEER ARR TWO (2) TURBULANDAS IN THE BOILRAHS. THE INNER TURBULAND IS 0.125 DIA WIRE, HR UNTED NEBULATOR IS 0.125 DIA WIRE, HR THE PITCH AND LENGTH FOR BOTH TURBULA MALS D-27 01-071-002

QUADRILLE WORK SHEET



AEROJET-GENERAL CORPORATION

BUBJECT BRDC BOILER No. 5 BY RALENA WORK ORDER 1475-44-0117
15 - G " AND 10 FT RESPECTIVELY
BOILRA # 4 HAD ONLY UNR TURBULATOR, OF 0.125 DIA WIRR, "G" PITCH AND 9 FT LONG.
THR K'FACING FOR BOILER # 4 FOR THR TURBULATOR
Kcy = 2.8 (BASED ON BOILER #4 MEST DATA)
THEERBOR
$K_{CS} = K_{CY} \times \left(\frac{L_S}{L_4}\right) / 2 = 2.8 \times \frac{10}{9} \times 2 = 6.4$
$\Delta P_{c} = K_{cs} H_{N} = 6.4 \times 0.0568 = 0.364 PSI$
6. TOTAL PRESSURE DROP THRU NEK-SIDE OF-BOILER # 5
$\Delta P_{TOTAL} = INLRT & OUTLRT 2 \times 0.20 = 0.40.0 2 - 180^{\circ} BRNOS 0.086 0.364 0.364 0.269 0.364 0.364 1.483 PSI 1.483 PSI 1.483 PSI $
APTOTAL = 1.50 PSID (CALCULATED)
REFERENCE: "HYDRANIC & PNEUDATIC POWER & GUTROL,

2. J.K. VENNARD: "ELEPRENTARY FLUID DECHAMICS" 2ª ED., 1954, JOHN WILFY & Sons NEW YORK.

7

7

AEROJET AEROJET-GENERAL CORPORATION GENERALTIRE AZUSA, CALIFORNIA GENERA QUADRILLE WORK SHEET PAGE DATE July 29 1970 BRDC BOILER No. 5 BY RALENA WORK ORDER 1475-44-017 SUBJECT DETERMINATION OF FLOW GEONETRY OF Not-SIDE DE BOILFER NS T. FREE FLOW AREA AT TUBE - BUNDLE SUPPORTS REF. FIG. 1 QUADRANT OF Nek! SIDE FLOW PATH OF BOILAR NO. 5 1. AREA OF ADDULUS QUADRANT = = (ro+ri)(ro-ri) Where $\Theta = 90^{\circ}$ or $\frac{11}{2}$ RADIANS = 1.5708 RADIANS AAN - 1.5708 (3.54+1.875) (3.54-1 875). AAN = 0.785 (5.415)(1.665) = 7.08 in2 2. ONSIDE AREA OF OVAL TUBES THERE ARE 3 CONPLETE OVAL TUBRES IN A QUADRANT

61-071-002



$$Ace = 4 \left\{ \sum \left[\frac{1}{2} (.50+.44) (.50-.44) \right] - (0.20 Ac) \right\}$$

$$A \left[1.5708 (.94) (.06) - (0.20 Ac] = 4(0.0485 - 0.00177)$$

$$Ace = 4 \times 0.0868 = 0.347 in^{2}$$

01-071-002

.

D-30

AEROJET **AEROJET-GENERAL CORPORATION** GENERALITIRE AZUSA, CALIFORNIA GENERA QUADRILLE WORK SHEET PAGE_3 HYDRANLIC DIADETER V BY DEFINITION HYDEAULIC RADIUS (RH) = AW or $R_{H} = \frac{TTD^{2}}{4TD}$ or $D_{H} = 4R_{H}$ or $D_{H} = \frac{4A_{W}}{P_{W}} = \frac{4 \times 18.48}{80.6} = 0.915$ in.



FIGI. QUADRANT OF Nak-SIDE FLOW PATH OF BOILER No. 5 - TUBE-BUNDLE SUPPORT SECTION

* WITH TURBULATOR COILS .

APPENDIX E

BOILER WEIGHT ANALYSIS



AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA

PAGE 6/ OF PAGES Aus. 12, 1970 DATE

BUBJECT BRDC BOILER NO. 5 BY G. LOMBARD WORK ORDER_

DRY BOILER WEIGHT - SUMMARY

Plitet ...

TANTALUM VOLUP	16 \$	WEIGHT	
TRANS'N JOINTS	:	v= 7.3 cu. M.	$\omega = 4.4 \ lb$
PLUG INSERTS	:	2"= 96. O II.	= 57,6 /1
TUBING	:	` <i>=3</i> 42.0	= 205.2
SWIRL WIRE	4 3	= 10.7	= 6.4
HEADERS	:	= 53.3	= 32.0
ORIFICES	•	= 4.4	= 2.7
INLET REDUCER	:	= 12.0	= 7.2
OUTLET REDUCER	•	= 11.9	= 7.1
TOTAL		537.6 cu.IA	322.6 16

TRANS'N JOINTS State	1.15 =1 16.6 CU.IN.	w = 4.8 16
NAK TURB. COIL :	2 = 18.9 Jun	= 5.4
7.5 " O.D. SHELL :	- 726.0 A. J. H.	= 209.0
3.5" O.D. SHELL "	= 251.0	= 72.4
HEADERS	= 41.6	= 12.0
TUBE SUPPORTS	= 31.8	= 9.2
Tees :	= 79.4	= 22.9
RINGS - TEE	= 5.6	= 1.6
ADAPTERS - SHELL	= 12.5	= 3.6
REDUCER - OUTLET	= 9.8	= 2.8
REDUCER - INLET	2. 29.6	= 8.5
TUBE-ENDS	= 35.3	= 10.2) 22155
STATIC - NAK TUBES :	= 511.0	- 147.05
DRAIN LINES	= 3.5	= 1.0
TOTAL	1772.6 cuin.	545.4 16

DRY BOILER WEIGHT = B33. 16 WET BOILER WEIGHT = 1030. 16



01-071-002

$$\mathcal{V} = \pi/4 \left[7.062^{2} - (12)(.755^{2}) \right] (2)(.75) + \pi/4 \left[7.062^{2} - 6.765^{2} \right] (2)(.25) + \pi/4 \left[.840^{2} - .780^{2} \right] (2)(12)(.25) \right]$$

$$\mathcal{V} = 50.8 + 2.05 + .46 = 53.3 \text{ cu. m.}$$

$$\mathcal{W} = (53.3)(0.6) = 32.0 \text{ lb}$$

E-3 |



SUBJECT BRDC BOILER NO	. <u>5</u> BY_
------------------------	----------------

PAGE.	<u></u>	OF	PAGES
			7
DATE	1		
	·		
WORK	CORDER		

PART A. - BOILER DRY WEIGHT (CONT'D)

- e. TA Hy INLET ORIFICES . . (.25) v = 4.21 + .23 = 4.44 (1).1N. W = (4.44)(0.6) = 2.66 16. f. TA HA INLET REDUCER $\mathcal{V} = \left(\frac{77}{360^{\circ}}\right) (\pi) (.64^{2} - .40^{2}) (2\pi) (3.260) + \dots + \frac{17}{27} (3.05^{2} - 1.1^{2}) (.24) + \frac{17}{4} (1.0^{2} - .75^{2}) (.4) + \dots + (.505) (2\pi) (.75)$ v = 3.40 + 6.1 + .140 + 2.38 = 12.02 cv. m. $W = (12.02)(0.6) = 7.21 \ 1b$
- Q. TA HA OUTLET REDUCER $\mathcal{V} = \left(\frac{78^{\circ}}{360^{\circ}}\right)\left(\pi\left(2.10^{2} - 1.95^{2}\right)\left(2\pi\left(2.855\right) + \frac{7}{4}\left(7.06^{2} - 6.76^{2}\right)\left(.5\right)\right)$ $\cdot + \left(\frac{68}{360^{\circ}}\right)\left(\pi\right)\left(1.89^{2} - 1.74^{2}\right)\left(2\pi\right)\left(1.5\right) + \frac{7}{4}\left(1.0^{2} - .88^{3}\right)\left(.3\right)$ v= 7.3 + 1.61 + 2.96 + .05 = 11.92 cuin W = (11.92)(0,6) = 7.15 16
- h. TA IN TRANSITION JOINTS 0= T/4(.952- 752)(8.5) + T/4(1.952- 1.752)(8.5)= 7.27 cv. 11. $\omega = (7.27)(0.6) = 4.4 \ 16$ STK. NO. D.1-103

QUADRILLE WORK SHEET		
SUBJECT BRDC BOILER NO.5 BY WORK ORDER		
2. WEIGHT OF STEEL PARTS (355 = 0.288 16/cu.in.)		
a. 7.50" O.D. SHELL (BETWEEN HEADERS)		
$v = \frac{\pi}{4} (7.5^2 - 7.26^2) (256.) = 726. cu.m.$		
w = (726.)(0.288) = 209. 16		
b. 3.5" O.D. INNER SHELL		
$v = \frac{\pi}{4}(350^2 - 3.31^2)(256.) = 251.$ cu. 11.		

$$W = (251.)(0.288) = 72.4 16$$

C. 316 SS HEADERS

$$v = \frac{1}{4} \left[7.5^{2} - 12.(1.2)^{2} \right] (.625) + \frac{1}{4} \left[1.20^{2} - 1.075^{2} \right] (12) (.093)$$

$$\dots \frac{1}{4} \left(7.50^{2} - 7.25^{2} \right) (.5)$$

$$v = 19.15 + .24 + 1.43 = 20.82 \times 2 = 41.64 cu.m$$

$$w = (41.64) (0.288) = 12.0 \ 16$$

•

v = 13.44 + 9.5 + 8.86 = 31.8 cu. 11.

W= (31.8) (0.288) = 9.15 16

-

SUBJECT_

QUADRILLE WORK SHEET



BRDC BOILER NO.5

PAGE	<u>4</u> of	9	PAGES
DATE	<u> </u>		<u></u> _
WORK	ORDER		•

BY_

QUADRILLE WORK SHEET

SUBJECT BRDL BOILER NO. 5 BY



page OF_	9 PAGES
DATE	
WORK ORDER	

6. BOILER-END REDUCER - Hg OUTLET $\mathcal{V} = \frac{\pi}{4} \left(7.95^2 - 7.70^2 \right) \left(2.4 \right) + \frac{\pi}{4} \left(4.25^2 - 4.00^2 \right) \left(1.75 \right) + \dots \\ \dots + \frac{\pi}{2.5^2 - 2.25^2} \left(\frac{55}{360} \right) \left(\frac{\pi}{4.95} \right) + \dots \\ \dots + \frac{\pi}{4.95^2 - 1.70^2} \left(\frac{55}{360} \right) \left(\frac{\pi}{4.95} \right)$ U = 7.54 + 2.75 + 12.55 + 6.71 = 29.55 cu.m. W=(29.55)(0,288) = 8.5 16 J. 321 55 STATIC Nak TUBE ENDS $W = \left[\frac{1}{4} (1.075^{2} - .875^{2}) (4.35) + \frac{1}{4} (1.187^{2} - 1.089^{2}) (.75) \right] (24.)$ V = 35.3 cu.11. W= (35,3)(0.288) = 10.17 16. K. 321 SS STATIC Nak TUBES $v = \frac{\pi}{4} (1.187^2 - 1.089^2) (12) (246.4) = 5/1. co. m.$ W = (511.) (0.288) = 147.16 l. Nak DRAIN & FILL LINES v= 1/4(.752-.5602)(18)0) = 1/3,53 cu. 10. W= (3.53)(0.288) = 1.02 16 N/ V m

n. Nak TURBULATOR COIL

$$v = \frac{\pi}{4}(.125)^{2}(256.)(\sqrt{1+(\frac{\pi}{12}\frac{\pi}{6})^{2}} + \sqrt{1+(\frac{3.62\pi}{6})^{2}}) = 18.9cu.10$$

 $w = (18.9)(0.288) = 5.4 16$
E-7 STK. NO. D.1.103


PAGE	6	_ OF	9	PAGES
DATE				
WORK C	RDER_			

SUBJECT BRDC BOILER NO.5

A. 316 SS IN THE TRANSITION JOINTS

AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA

 $v = \frac{\pi}{4} \left(2.25^{2} - 1.400^{2} \right) (.5) - \frac{\pi}{4} \left(2.25^{2} - 1.75^{2} \right) (.3) + \frac{\pi}{4} \left(1.250^{2} - 0.95^{2} \right) (9.41) + \frac{\pi}{4} \left(4.0^{2} - 2.40^{2} \right) (.50) = 1 \\ \dots - \frac{\pi}{4} \left(4.0^{2} - 3.25^{2} \right) (.30) + \frac{\pi}{4} \left(2.254^{2} - 1.96^{2} \right) (9.41)$

v = 1.21 - 0.47 + 4.88 + 3.22 - 1.27 + 9.02v = 16.6 cu.m.

W= (16.6 X 0.288) = 4.78 16



1. PRIMARY NAK:

$$v_{PN} = \left[\frac{1}{4}\left(\frac{7.2\xi^2 - 3.50^2}{5.0}\right) - 12(1.11)\right](257.) - 31.8 - 18.9$$

 $v_{PN} = 4649.$ cu.in.
 $w_{PN} = \left[\frac{4649}{1728}\right](45.0) = 121.16$

.

.

$$w_{\rm SN} = \left[1.93 - \frac{174(75)^2}{257.} \right] (257.) (12) = 1510. \text{ cu. 1A.}$$
$$w_{\rm SN} = \left[(1.510.) / (1728) \right] (45.0) = 39.3 \text{ /6}$$

QUADRILLE WORK SHEET



AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA

PAGE 8 OF 9 PAGES

WORK ORDER

SUBJECT BRDC BOILER NO. 5 BY G. LOMBARD

LIQUID MERCURY. INVENTORY

- MERCURY TEMP. (LIQ.) = 353°F MERCURY DENSITY (LIQ.) = 822.16/cu.ft.
 - A. INLET TRANSITION . TUBE :

 $v = \frac{\pi}{4}(.755)^2(8.5) + \frac{\pi}{4}(.955)^2(1.5) = 3.8 + 1.08$ v = 4.88 cv. 10.

w=(4.88)(822.)/(1728.) = 2.32 16

- B. INLET: CONCENTRIC REDUCER-DOME: $v = (174)(.10) \sum_{i=1}^{2} d_i^2 + (174)(.755^2)(1.05)$ = (174)(.10)(714.3) + .51 = 56.5 cu.10.w = (56.5)(822.)/(1728.) = 26.9 lb
- C. ORLEICES :
 - $v = \frac{1}{4}(.050)^{2}(1.06)(12.0) + \frac{1}{4}(.572)^{2}(.25)(12.0)$ = .0025 + .7725 = .775 cu.in. $\omega = (.775)(822.)/(.1728.) = .37.16$
- d. OPEN TUBE BETWEEN ORIFICES & PLUG INSTRTS = \$4(.652,2)(12.)(1.3) = 5.21 cu. 11. W= (5.21)(822.)/(1128.) = 2.5 16



QUADRILLE WORK SHEET



AEROJET-GENERAL CORPORATION

AZUSA. CALIFORNIA

PAGE_	9	OF	9	_PAGES
DATE_	Aug	28,	19	70

SUBJECT BRDC BOILER NO. 5 BY G. LOHBARD WORK ORDER

LIQUID MERCURY INVENTORY (CONT'D)

e. PLUG INSERTS:

1. LOW NAK TEMP. = 1185°F

PRE-HEAT LENGTH = 0.7 H

WH9 + 13555. 16/6+

- $w = (12.0)(0.7)(12.0)(85.4 \times 10^{-3}) = 8.61 \text{ cu.m.}$ w = (8.61)(822.)((1728.)) = 4.1 lb
- 2. HIGH Nak TEMP. = 1210°F PRE-HEAT LENGTH = 0.6 ft WHg = 13555. 16/hr

 $v = (12,)(0,6)(12,0)(85,4\times10^3) = 7.37 \text{ cu.in.}$ w = (7,37)(822,)/(1728,) = 3.51/6

TOTAL LIQUID HG INVENTORY IN THE BOILER IS!

> 36.2 16 @HTNBI = 1185°F 35.6 16 @ TNBI = 1210°F

APPENDIX F

TANTALUM-to-STAINLESS STEEL TRANSITION JOINT TEST AND INSPECTION PROGRAM

MEMORANDUM

FILE: ME 11:110

DATE: 2 September 1970 7972:70:0097:CGN:eh Bldg. 160, X6730

TO: Distribution

FROM: C. G. Neitsch

SUBJECT: Low Cycle Fatigue Evaluation of Coextruded 316SS/Ta Tubing

DISTRIBUTION: B.L. Amstadter, H.E. Bleil, E.S. Chalpin, H. Derow, A.H. Kreeger, G.L. Lombard, L.P. Lopez, R.W. Marshall, U.A. Pineda, file Cleveland: W.L. Snapp

NASA LERC: E.R. Furman, P.L. Stone

REFERENCE: (a) J.N. Kass and D.R. Stoner, "Evaluation of Ta/316SS Bimetallic Tubing," WANL-PR-PPP-001, 1968 (b) U.A. Pineda, "Stress Relaxation of Coextruded Bimetallic

Tubes", Stress Analysis 4927:SA-B-105, August 1967

- ENCLOSURE: Figure 1 316SS/Ta Coextruded Tube Thermal Exposure Specimen Figure 2 - Ultrasonic Inspection of 316SS/Ta Coextruded Tubing Figure 3 - Std. for Ultrasonic Bond Inspection of 316SS Ta Coextruded Tubing Figure 4 - Std. for Ultrasonic Inspection of Ta Liner in
 - 316SS/Ta Coextruded Tubing Figure 5 - Dimensional Changes in 316SS/Ta Coextruded Tubing Resulting from Thermal Exposure at 1350°F
 - Figure 6 Appearance of Coextruded 316SSTa Tube Specimens After Approximately 4800 hrs. at 1350°F
 - Figure 7 Coextruded 316SS/Ta Ring Specimens After Flattening Test
 - Figure 8 Hardnesses of Coextruded 31688/Ta Tubing After 1350°F Exposure
 - Figure 9 Bond Interface of 316SS/Ta Coextruded Tube Specimens After 1350°F Thermal Exposure
 - Figure 10- Microstructure of 31688 in Coextruded 31688/Ta Tubing After 4,364 hrs. at 1350°F
 - Table 1 Summary of Thermal Exposure and Evaluation of Coextruded 31655/Ta Tubing

SUMMARY, CONCLUSIONS AND RECOMMENDATIONS

Evaluation of 316SS/Ta coextruded tube specimens was conducted after a maximum of 5,353 hours exposure at 1350°F including 275 thermal cycles between 250 and 1350°F. It is concluded that:

1. Coextruded 316SS/Ta tubing of 100% initial bond exhibits no tendency of debonding under simulated SNAP-8 boiler low thermal fatigue cycling.

2. The sleeve bushing design is adequate to prevent 31655/Ta debonding at the tube ends during thermal exposure.

3. Changes in Ta hardness resulting from thermal exposure were attributed . to interstitial element diffusion from the 316SS into the Ta.

4. Additional data is required to predict the effect of sigma phase on 316SS ductility reduction resulting from 40,000 hour SNAP-8 boiler exposure.

5. It is unknown whether the dimensional changes of the bimetal tube specimens which occurred after approximately 3,000 hr. thermal exposure are representative of dimensional changes expected during boiler operation due to a 65° F axial gradient along the specimens' lengths.

6. The evaluation indicated that 316SS/Ta tubing manufactured by the coextrusion process is capable of maintaining adequate bonding during 40,000 hr. BRDC boiler exposure.

The following recommendations result from this study:

1. Continue thermal exposure of the two remaining coextruded tube specimens to accumulate additional data on the effect of sigma phase formation.

2. Review the 316SS/Ta coextruded fabrication procedure for possible modifications to reduce sigma phasecformation potential.

3. Perform a stress analysis to determine the effect of a 65°F axial temperature gradient upon the 1350°F dimensional stability of 316SS/Ta coextruded tubing.

4. Perform a stress analysis to determine the effect of BRDC boiler operation upon the dimensional stability of 316SS/Ta coextruded sleeving.

INTRODUCTION

One conceptual design of a SNAP-8 boiler uses a bonded 316SS/Ta bimetal tube as the Hg containment material. The tantalum (Ta) serves as the Hg exposed liner. Bare refractory-double containment boilers No. 4 and 5 employ coextruded Ta/316SS sleeves at the Hg inlet and outlet to provide the transition from the 316SS Hg liquid and vapor lines to the Ta boiler material. Evaluation of the metallurgical stability and debonding potential of the bimetal tubing during boiler operation is necessary to establish reliability for forty thousand hour (service. This investigation evaluated the metallurgical stability and debonding tendency of 316SS/Ta coextruded tube specimens under a simulated boiler operating environment of thermal exposure at $1350^{\circ}F$ in combination with both low thermal fatigue cycling and fast thermal cycling between 250 and $1350^{\circ}F$.

TEST PROCEDURE

Four 15 inch long 316SS/Ta coextruded specimens were prepared. The specimens were cut from 17 foot long tubes fabricated by Nuclear Metals, Concord, Mass. The tube specimens contained 316SS I.D. support bushings at the tube ends, Figure 1.

Bushings are an integral part of the bimetal boiler design to support the Ta thus minimizing potential tube end debonding stresses due to differential thermal expansion between the Ta liner and the 316SS clad during thermal cycling . One bushing in each test specimen was solid, forming an end cap. The other tube end was sealed by electron-beam welding a flat 316SS disc to the bimetal tube 316SS clad. Electron beam closure welding results in a vacuum of approximately 10⁻⁴ Torr inside the tube serving two purposes. First, the Ta liner was protected against oxidation during elevated temperature exposure. Second, a simulation is produced of the vacuum conditions imposed on the Hg containment tube during boiler hot outgassing in preparation for system start-up.

The four sealed specimens were thermally exposed in a stainless steel susceptor in a vacuum induction furname at 10^{-5} Torr for redundant protection of the tantalum liner against oxidation. The furnace controls provided automatic shutdown in case of loss of vacuum and/or excessive temperature ($1375^{\circ}F$ along centerline of susceptor). Both fast and slow cycling rates were used during thermal exposure. The thermal cycle was defined as fast if the exposure temperature was increased and/or decreased at a rate greater than $250^{\circ}F/hr$. A slow cycle was defined as the cycle resulting when both the heating and cooling rates were less than $250^{\circ}F/hr$., and is equivalent to the presumed severest SNAP-8 boiler thermal operating conditions. The slow thermal cycle is considered to be a low fatigue cycle because differential thermal expansion stresses plastically strain the tantalum during each heating phase and cooling phase of the cycle.

EVALUATION PROCEDURE

The thermal exposure was interrupted occasionally for ultrasonic bond inspection, ultrasonic Ta liner evaluation, metallography, and dimensional inspection, Table 1.

1. Ultrasonic Bond Inspection

Ultrasonic bond inspection employed the pulse-echo, immersion, C-scan, longitudinal wave technique, Figure 2. The test standard had simulated unbond for ultrasonic equipment calibration, Figure 3. Unbond was simulated by four eloxed, 1/8 inch diameter holes on the Ta I.D. with depths of .010, .020, .030, and .040 inch respectively. Ultrasonic equipment was calibrated to show all defects parallel to the 316SS/Ta interface between .010 and .040 inch from the Ta surface as unbond. The 316SS/Ta interface is a nominal .025 inch distance from the Ta I.D. surface.

2. Ultrasonic Ta Liner Inspection

Ultrasonic inspection for Ta liner integrity employed the pulse-echo, C-scan, immersion, shear wave technique, Figure 2. For ultrasonic equipment calibration, the test standard, Figure 4, had two 1/4 inch long .005 inch deep notches eloxed on the Ta I.D. surface. One notch was parallel and the other notch

⁽¹⁾ Thermal expansion coefficients, 75 to 1350°F are 4.1 x 10⁻⁶ and 10.7 x 10⁻⁶ in./in.-°F for Ta and 316SS, respectively.

was transverse to the bimetal tube axis. Ultrasonic equipment was calibrated to show all Ta I.D. defects with depths equal to or greater than .005 inches. Axial and radial shear scans were used to inspect for both longitudinal and transverse type defects.

3. Dimensional Inspection

During the periodic interruptions of the thermal exposure, the bimetal tube specimens were measured for possible changes in diameters resulting from the thermal exposure.

4. Flattening Test

Flattening tests were performed on a pre-exposure specimen and on thermally exposed specimens to determine whether the ductility of 316SS was affected by thermal exposure. Ring specimens were flattened between parallel plates until either cracking occurred or opposite I.D. surfaces came into contact.

5. Metallography

One end was removed from specimens after exposure at 1350°F for times of 1,000 hr., 4,095 hr., and 4,864 hr. Two longitudinal cross-sections at 180. and one full transverse section were examined microscopically to determine the effect of thermal exposure upon 316SS/Ta bond integrity and microstructure. Microhardnesses were measured across the Ta and 316SS to compare with before exposure hardnesses.

EVALUATION RESULTS

1. Ultrasonic Bond Inspection

No debonding was revealed by ultrasonic inspection. The last bond inspection was performed after a maximum of 3,043 hours at 1350°F.

2. Ultrasonic Ta Liner Inspection

No Ta liner defects were detected by ultrasonic inspection. The last inspection was performed after a maximum of 3,043 hours at 1350°F.

3. Dimensional Inspection

No changes in the tube specimens' outside diameters were apparent after approximately 3000 hours at 1350°F, but all four specimens showed significant changes in diameters resulting from 1350°F exposure to times greater than 3,043 hours, Figures 5 and 6. After exposure period No. 8 was complete, Table 1, it appeared that the dimensional changes were a function of axial position, and that non-uniform specimen temperature may have contributed to the unequal dimensional changes along the specimens' lengths. Therefore, specimens AA and PP were repositioned in the furnace susceptor to ensure a 1350°F $^+20°F$ along the specimens' lengths. During the ensuing exposure of 489 hr. at 1350°F, both specimens AA and PP showed additional changes in dimensions, Figure 5.

4. Flattening Test

No cracking occured in either the 316SS or Ta in the pre-exposure specimen which was flattened until opposite I.D. surfaces came into contact. Specimens which had been exposed to 4,095 and 4,864 hours at 1350°F cracked in the 316SS when flattened to 0.10 inch separation distance between I.D. surfaces, Figure 7.

5. Hardness Measurements

The hardness of the Ta increased adjacent to the 316SS/Ta interface, Figure 8. The hardness of the 316SS was unchanged.

6. Microscopic Examination

At magnifications up to 1000X, no debonding was observed either at the end of the tapered Ta liner, or along the 316SS/Ta bond length. At 2000X magnification, very localized areas of microcracking were observed in approximately 0.2% of the bond length examined, Figure 9.

No apparent change in the width of the diffusion zone between the 316SS and the Ta resulted from 1350°F exposure, Figure 9.

Thermal exposure caused sigma phase precipitation across the 316SS crosssection, Figure 10. After 4,864 hrs. thermal exposure, specimen LL had 5.1% sigma at one end (end location corresponding to tube end of greatest dimensional change, Figure 5) and 3.8% sigma at the opposite end. Carbide precipitation in the 316SS microstructure occurred prior to thermal exposure during coextruded bimetal tube fabrication.

DISCUSSION

The intact bond line at the tube end indicates that the support bushing design is adequate to prevent end debonding. It is unknown whether the microcracks in the 316SS/Ta bond in specimen LL away from the support bushing area after 4,864 hr. thermal exposure are fabrication defects or a result of thermal exposure. The extremely short crack lengths, approximately 2×10^{-4} in., are not detectable by ultrasonic inspection. Also, the linear distribution of the microcracks, along approximately 0.2% of the bond line, makes metallographic determination of the presence or absence of microcracks in pre-exposure specimens difficult.

The unchanged Ta liner I.D. hardnesses indicate that the vacuum protection of the Ta liner during thermal exposure was adequate to prevent air contamination. The increased Ta hardness adjacent to the 316SS/Ta interface indicates that diffusion, probably of interstitial elements, from the 316SS into the Ta occurred as a result of thermal exposure. An earlier investigation by Westinghouse, Reference (a), reported similar results in that quantitatively determined interstitial changes were attributed to diffusion across the bimetal interface.

The length of time required for dimensional changes to begin occurring may be related to the relaxation of residual fabrication stresses. A stress analysis, Reference (b), indicated that approximately 3000 hrs. continuous soak at 1300°F is

required for complete relaxation of the pre-stress induced in the coextrusion of the 31655/Ta tubing. The coextrusion process imposes a tensile stress in the 3165S and a compressive stress in the Ta. With relaxation of pre-stress, the stress pattern in the bimetal tubing is reversed due to differential thermal expansion stresses. The stress pattern reversal apparently results in significant reductions in bimetal tube diameter with low thermal fatigue cycling.

It appears that the greater dimensional changes that occurred at one end of each tube specimen is related to a 65°F maximum axial temperature gradient. The temperature of one end of each specimen may have approached 1400°F, the temperature of the stainless steel susceptor I.D. The temperature of the other end of each specimen may have been as low as 1335°F, the temperature along the susceptor centerline. Cross-sections through the tube revealed that although the wall thickness remained constant, a marked variation in the Ta: 316 thickness ratio occurred around the circumference of the tube at the end which exhibited the maximum dimensional change. This condition did not exist at the other end of the tube. Therefore, a stress analysis is required to determine if the dimensional changes which resulted are comparable to or greater than the effects expected as a result of boiler operation. The existence of an axial temperature gradient is also indicated by the greater amount of sigma precipitation at one tube end (5.1%) than at the other tube end (3.8%), as the amount of sigma formation is temperature independent. The unchanged width of the diffusion zone between the 316SS and the Ta after 4,864 hrs. of test indicates qualitatively that the 1350°F exposure was not greatly exceeded, as it is reported that 1600 hours exposure at 1500° F caused 2.5 x 10^{-4} inch growth in diffusion zone width of Ta/stainless steel composites, Reference (c).

Sigma phase, FeCr, is a hard, brittle constituent that forms on heating stainless steel alloys between 1000 and 1700° F. The amount of sigma formation depends upon the specific composition and structure of the stainless steel, the length of thermal exposure, and as mentioned previously, the temperature of exposure. Sigma formation is important because of the effect on the ductility of 316SS. The flattening test results indicated qualitatively reduced 316SS ductility with sigma formation. Tensile tests are required to quantitatively determine the change in ductility, but the remaining ductility appears to be acceptable as the flattening characteristics of the bimetal tubing after 4,864 hrs. at 1350°F meet the requirements of both the ASTM and ASME specifications for high quality, seamless 316SS tubing (ASTM A213 and ASME SA 213).

The current boiler design (BRDC) utilizes 10-inch long coextruded bimetal sleeves (of which 8 inches is effective) for transition sections between the Ta boiler tubing and the 3165S loop piping at the boiler inlet and outlet. 316SS to Ta bonding in the bimetal sleeving is required to maintain separation of the static NaK from the Hg loop. Test data indicates that 316SS/Ta tubing manufactured by the coextrusion process is capable of maintaining adequate bonding during the required 40,000 hr. BRDC boiler exposure. The significant effects of diameter reductions in the bimetal sleeves are changes to the Hg pressure drop across the boiler. However, if the sleeve diameter were to decrease in the same . ratio as the bimetal tubing maximum diameter reduction (7%), no noticeable effect on boiler performance would occur. The effect of thermal exposure upon bimetal tube specimens diameters of this investigation cannot be extrapolated to the bimetal sleeve design because of differences in wall thickness relationships. The ratio of 316SS thickness to Ta thickness is 2.4:1 for the thermal exposure specimens and 1.5:1 for the bimetal sleeves. A stress analysis is required to predict potential changes to bimetal sleeve diameters resulting from boiler operation.

Information on sigma effects due to long time elevated temperature exposure is insufficient to make a quantitative prediction on either the total amount of precipitate formed or the extent of ductility reduction which would occur in 40,000 hr., 1350°F exposure. Cyclic thermal exposure of the two remaining coextruded tube specimens should be continued to accumulate additional data on sigma effects. The 316SS/Ta coextruded fabrication procedure should be reviewed and modified if possible to reduce sigma phase formation potential.

Veitsch

Materials Engineering Group

APPROVED:

HE Bleil

H. E. Bleil, Supervisor Materials Engineering Group Technical Resources Section Engineering Department Power Systems Operations

EOLDOUT FRAME 2



316 SS/TA COEXTRUDED TUBE THERMAL EXPOSURE SPECIMEN

FIGURE 1

4

LEGEND

- A. ULTRASONIC SEARCH UNIT (MOVEMENT FARALLEL TO TUBE ANS) SENDS AND RECEIVES SOUND ENERGY.
- B PULSE-ECHO SOUND ENERGY IN WATER MEDIUM
- C. PATH OF REFLECTED SOUND BEAM WHEN ZIGSS TO UNBOND EXISTS , INDICATED AS UNBOND ON C. SCAN RECORDING.
- D PATH OF REFLECTED SOUND BERM WHEN 31655/TO BONDING EWSTS .
- E. 3KSS/TO TUBE ROTATED & DEGREES AFTER EACH SCAN OF THE SEARCH UNIT
- F PATH OF REFLECTED SOUND BEAM IF CRACK DEFECT EVISTS, INDICATED AS DEFECT AREA ON C-SCAN RECORDING.
- G PATH OF REFLECTED SOUND BEAM IF I D. IS DEFECT FREE , SOUND CONTINUES IN SHEAR. THROUGH TUBE WALL.



a. Ultrasonic Technique Used for Bond Inspection

b. Ultrasonic Technique Used for Ta Liner Inspection

Fig. 2. ULTRASONIC INSPECTION OF 31655/Ta Coextruded Tubing



AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA

STD FOR ULTRASONIC BOND INSPECTION SUBJECT OF 3/6SS/TA COEXTRUDED TUBING

QUADRILLE WORK SHEET

e c sectuh

PAGE			PAGES
DATE	0,7/70		<u> </u>
WORK /	RDER	• •	



FIGURE 3



AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA

QUADRILLE WORK SHEET

STO FOR ULTRASONIC INSPECTION OF TA SUBJECT LINER IN 3/655/TA COEXTRUDED TUBING

BY_C. Seitch

PAGE		or		PAGES
DATE	7/7	7 / 70	<u>.</u>	

WORK ORDER







DIMENSIONAL CHANGES IN SIGSS/TA COEXTRUDED TURING RESULTING FROM THERMAL EXPOSURE AT 1350%

FIGURE 5





Specimen KK after 4,095 hrs. at 1350°F

As coextruded specimen

4x

0149

Fig.7. Coextruded Ta/316ss tube specimens after flattening test, showing end cracking in thermally exposed specimen and absence of cracking in as coextruded specimen.



O PRE - TEST

- D POST-TEST AFTER 1,008 HRS. AT 1350°F
- POST TEST AFTER 4,095 HRS. AT 1350°F
- X POST-TEST AFTER 4,864 HRS. AT 1350 %



HARDNESSES OF CCEXTRUDED 31655/TA TUBING AFTER 1350 F EXPOSURE

FIGURE 8



Figure 9. Ta-316SS interface of coextruded tubing, 2000X All interfacial diffusion zones are 10⁻⁵ inches thick.

> (a) As coextruded specimen, (b) specimen KK after 4,095 hours at 1350°F, (c) specimen LL after 4,864 hours at 1350°F), (d) specimen LL after 4,864 hours at 1350°F showing microcracking which was present in approximately 0.2% of the interface.



2000X, 10% (NH,)2 S,08 etch. 0525

Fig. 10. Microstructure of 31655 in coextruded Ta/31655 tubing after 4,864 hours at 1350°F

		NO. OF CYC	CLES		CYCLE DI	SCRIPTION	(HRS.)				SPECIMEN E	LUATION(b)	· · · · · · · · · · · · · · · · · · ·
SPECIMEN, (a) 15" LENGIH (a)	EXPOSURE PERIOD	PER EXPOSURE · PIKIOD	ACCUMU- LATET	HEATING TIME 250 TO 1350°F.	PER CYCLE	O ^O F <u>DWFILL</u> PER EXPOSURE PERIOD	UTHE ACCUMU LAJED	COOLING 1IME 1350 TO 250°F	· CYCLE TYPE	31655/1a BOND ULTRASONIC INSPECTION	18 LL.JER ULTRASONIC INSPECTION	MELALLOCE-PHY	Dimensional Inspect 1917
KK (N24) PP (N26) PP (N26) PP (N26)	1 2 3 4 5 a b c d e f a b 7 8 9	1 25 1 51 1 1 1 1 1 1 78 52 35	1 26 27 78 79 80 81 82 83 84 85 85 86 164 216 251	1/2 1/2 4-1/2 7 1-1/2 7 3-1/2 4 7 7 8-1/4 8-1/4 8-1/4	$\begin{array}{c} 95\\ 5\\ 100\\ 13\\ 53-1/2\\ 8\\ 164\\ 58-1/2\\ 314\\ 436\\ 380-1/2\\ 645-1/2\\ 14-1/4\\ 14-1/4\\ 14-1/4\\ 14-1/4\\ 14-1/4\end{array}$	95 125 100 663 1,034 1,026 1,052 744 489	95 220 320 983 2,017 3,043 4,095 4,839 5,328	2-1/2 2-1/2 6-1/2 13 1 12 12 9-1/2 9-1/2 9-1/2	Fast Fast Slow Slow Fast Slow Fast Fast Slow Slow Slow Slow Slow	KK, PP KK, PP KK, PP KK, PP KK, FF KK, FP	KH. PF KK PP	, ₂₂₂ (e) - - - - - - - - - - - - - - - - - - -	KK PF KK PP KK PP KK PP KK PP FP
AA (H2h)) LL (N26) .	1 2 3 4 5 a 0 c d e f 6 a b 7 8 9	25 1 25 51 1 1 1 1 1 1 2 78 52 35	25 26 51 102 103 104 105 106 107 108 109 110 188 240 275	1/2 1/2 1/2 1/2 4-1/2 7 1-1/2 7 3-3/2 4 7 7 7 8-1/4 8-1/4 8-1/4	5 95 5 13 $53-1/2$ 8 164 $58-1/2$ 314 436 $380-1/2$ $645-1/2$ $645-1/2$ $14-1/4$ $14-1/4$ $14-1/4$	125 95 125 . 663 (1,034) 1,026 1,052 744 489	125 220 345 1.008 2,042 3,068 4,120 4,864 5,353	2-1/2 2-1/2 2-1/2 6-1/2 13 13 13 13 13 13 13 13 13 12 12 9-1/2 9-1/2 9-1/2	Fast Fast Slow Slow Slow Slow Slow Slow Slow Slow	AA, LL AA, LL AA, LL AA, LL AA, LL AA, LL	- - - - - - - - - - - - - - - - - - -	<u>L</u> (e)	AA LL AA LL AA LL AA LL

TABLE I - SUMMARY OF THERMAL EXPOSURE AND EVALUATION OF COLATRODED STONGUE TUBLING

(a) Specimens were cut from either N24 or N26. N24 and N26 were 2 tubes of a 10-tube order (17 ft. lengths) received from Nuclear Metals

(b) Evaluation fillowed exposure period indicated.

(c) One-inch length cut from tube end for hardness and interface examination. Specimen was then resealed and thermal exposure continued

(a) Thermal exposure discontinued

MEMORANDUM

FILE: ME 11:110

DATE: 8 October 1970 7972:70:0111:CGN:eh Bldg. 160, X6730

TO: E. S. Chelpin

FROM: C. G. Neitsch

SUBJECT: Re-evaluation of Ultrasonic Bond Inspection of Ta/316SS Bimetal Sleeve No. 7

COPIES TC: H. Derow, A. H. Kreeger, G. L. Lombard, J. R. Pope, U. A. Pineda Cleveland: W. L. Snapp NASA, LeRC: E. R. Furman, P. L. Stone NAVPLANTREP/NASA-COR: D. E. Blasco

- REFERENCE: (a
- (a) J. R. Pope to P. L. Stone, Letter 7972:70:0077, "Ultresonic Bond Inspection of Sleeve Joints No. 6 and No. 7", 15 July 1970
 - (b) D. R. Stoner to H.E. Bleil, Westinghouse Letter 70:132:DRS, 26 August 1970
 - (c) C. G. Neitsch to E. S. Chalpin, Memo 7972:70:0067, "Ultrasonic Bond Inspection of Boiler No. 4 Hg. Inlet and Outlet Bimetal Sleeves", 17 June 1970

SUMMARY & CONCLUSIONS

A re-evaluation of the ANSC/CONAM bond inspection of Ta/316SS Bimetal Sleeve No. 7 was made after Westinghouse proved the original inspection results unreliable. It was concluded that:

- 1.. The original ultrasonic inspection of Sleeve No. 7 was interpreted incorrectly as indicating unbond due to failure to follow the previously developed inspection procedure. The present inspection revealed no debonding of Sleeve No. 7.
- 2. The reported results of the ultrasonic inspection of BRDC Boiler No. 4 Hg Inlet and Outlet Bimetal Sleeves are reliable.
- 3. The ultrasonic procedure developed by ANSC to inspect the bond of bimetal sleeves is adequate.

INTRODUCTION

In July 1970 Ultrasonic Inspection of Ta/316SS bimetal sleeves No. 6 and No. 7 was performed at Conan for ANSC. This inspection resulted in reporting that sleeve No. 7 exhibited debonding at the Ta/316 interface and that sleeve No. 6 was bonded, Reference (a). Subsequent ultrasonic and metallographic examination of the sleeve by Westinghouse indicated that joint No. 7 was not debonded, Reference (b). Reinspection of the remnant section of sleeve No. 7 was conducted by Conen under ANSC surveillance on 5 October 1970 to determine the cause of the original erroteous report of the presence of debond.

ULTRASONIC RECHECK OF JOINT NC. 7 REMNANT

The remnant of joint No. 7 remaining after Westinghouse metallography was ultrasonically inspected using the C-scan technique reported previously in Reference (a). A variable reflection was received from the 316SS/Ta bond interfaces of both the inspection standard, T1286791, and joint No. 7 without a corresponding loss of reflection from the I.D. surfaces, but the amplitude of the bond interface reflection was greater from joint No. 7 than from the inspection standard. During the original inspection of joint No. 7, the greater amplitude of the interface reflection was interpreted incorrectly as indicating unboad. The greater amplitude results from a combination of two effects: (1) The 31655 thickness in joint No. 7 (.16 in.) is greater than the inspection standard thickness (.12 inch) which results in the bond interface distance from the joint O.D. being greater in joint No. 7 than in the inspection standard, and (2) The emplitude of the signal reflection is greater at .15 in. than at .12 in, distance from the O.D. due to variation in signal strength with specimen position. The originally developed inspection procedure determined that unbond is indicated by a loss of reflection from the I.D. surface, Reference (c). Therefore, no unbond of joint No. 7 is indicated as no loss of I.D. surface reflection occurred during inspection. The originally reported results of unbond in joint No. 7 resulted from the unacceptable deviation in the developed ultrasonic inspection procedure of not monitoring the I.D. surface reflection when reflections from the 316SS/Ta interface were received.

The previously reported results of ultrasonic bond inspection of Boiler No. 4 bimetal sleeves are reliable as unbonding was reported only at locations where loss of I.D. reflection accompanied bond line reflections, Reference (c).

Heleil for

C. G. Neitsch Materials Engineering Group

APPROVED:

H. E. Bleil, Supervisor Materials Engineering Group Technical Resources Section Engineering Department Power Systems Operations

APPENDIX G

OVERALL BOILER STRESS ANALYSES

AFROJET P GENERAL P PROJECT_S	EROJET NUCLEAR SYSTEMS COMPANY OWER SYSTEMS OPERATIONS INGINEERING DESIGN FILE	ENGNEERING FILE NO EDF SERIAL NO DATE W. O. NO. 1	DE 0016 6 July 1970 475-44-0114
SUBJECT	BRDC BOILER #5 OPERATING CRITERIA	FOR STRESS ANALYSES	3
ABSTRACT	MEMO 7978:70:0003, same subject, da the operating criteria to consider for the BRDC #5 boiler.	ated 6 July 1970 ite when performing str	emizes ress analyses
	With this memo and the work done p Group for BRDC #4, the parameters stress levels for BRDC #5 are well	reviously by the Str to work to in evalue defined.	ress Analysis ating the
DISTRIBUT	ON Distribution made under Memo No	. 7978:70:0003	
COVER SHE	EET ONLY E.S. Chalpin, U.A. Pineda, R. A.J. Sellers	W. Marshall, H. Der	row, Dr. W. Weleff,
KEY WORDS	S BRDC #5 Boiler, Operating Crite	eria, Stress Analyse	28
AUTHOR E.	S. Chalpin S.C. DEPT REVIEW	ED DATE R	EVIEWHL 8/5/7

DATE: 6 July 1970 7978:70:0003:mrs Bldg. 160/X5522

MEMORANDUM

TO: Dr. W. Weleff/H.Derow

FROM: E. S. Chalpin

SUDUBUT: BRDC Boiler #5 Operating Criteria for Stress Analyses

COPIES TO: B. Breindel, R. G. Geimer, C. Hawk, J. Hodgson, S. Krikopulo, G. L. Lombard, L. Lopez, R. W. Marshall, U. A. Pineda, File

ENCLOSURE: (1), Table I - "BRDC Boiler #5 Operating Criteria"

When analyzing the stresses for the BRDC Boiler #5, please use the values tabulated in Enclosure (1) and the materials properties used when you analyzed the BRDC Boiler #4 design in April through June 1969.

The following operational modes must also be considered in your analyses:

<u>Heatup</u> - Boiler heats up from ambient to 1211°F. Mercury pressure is at zero psia during this time. Static NaK pressure rises from ambient to 30 psia at 1211°F.

Flowing primary NaK inlet and outlet temperature rises from ambient to 1211°F and the pressure rises from ambient to 60 psia.

<u>Startup</u> - See A. J. Sellers' thermal map for the maximum temperature gradients during the transient state. Mercury inlet pressure rises from zero psia to 333 psia during this time. Static NaK pressure remains at 30 psia. Flowing primary NaK are at 60 psia and 57 psia respectively. NaK outlet temperature drops to 1044°F. This can occur 100 times during the 5 year life of the boiler.

<u>Steady-state</u> - Mercury inlet temperature will remain $420^{\circ}F$ and the pressure will remain at 333 psia. The mercury outlet temperature will remain at 1190°F and the pressure will be 148 psia.

The static NaK pressure will be at 30 psia and a temperature of 1190°F. The flowing primary NaK inlet will be at 60 psia and 1211°F while the outlet will be at 57 psia and 1044°F.

Emergency Conditions - Consider that for 20 cycles of 40 seconds duration each, the following conditions will exist:

Mercury inlet - 500 psia and 600°F Mercury outlet - 222 psia and 1375°F Flowing primary NaK inlet and outlet - 90 psia and 1485°F Static NaK - 90 psia and 1485°F Calculate the low cycle fatigue life of the tantalum for the 5 years of operation.

There are two (2) boilers in series for PCS-G as far as the flowing primary NaK is concerned and the mercury loops are in parallel along with the static NaK loops. Therefore, consider that one boiler will be at the "heat up" state (zero mercury pressure, static KNaK at 30 psia and 1211°F with the flowing primary NaK at 60 psia and 1211°F). This results in having one boiler at this condition while the other is at the "steady-state" condition for the 5 years of operational life.

Please see Barry Breindel for the piping and bracketry loads imposed on the boiler.

ES Chalpins.

E. S. Chalpin, Supervisor Mechanical Design Group Design Engineering Section Engineering Department

Hg Inlet	Hg Outlet	NaK Inlet	. Nak Outlet	Static NaK
Low Schedule Inlet Press.=Zero to 323 PSIA Inlet Temp.=70°F. to 420°F Flow = 7,740 #/hr. in 75 sec. =13,775 #/hr. (a) steady state.	Outlet Press. = Zero to 148 PSIA. Outlet Temp.=70 to 1185 to 1165°F.	Inlet Press.=Zero to 60 PSIA. Inlet Temp.=70°F to 1185°F Flow=57,148 #/hr.	Outlet Press.=Zero to 57 PSIA. Outlet Temp.=70°F to 1015°F.	Fress.=30 PSIA Temp: =70°F to 1185°F
High Schedule Inlet Press.= Zero to 333 PSIA. Inlet Temp. = 70°F. to 420°F. Flow = 7,740 #/hr in 75 sec. = 13,600 #/hr (@ steady state	Outlet Press. = Zero to 147 PSIA. Outlet Temp. =70 to 1211 to 1190 F.	Inlet Press.=Zero to 60 PSIA Inlet Temp. = 70 to 1211°F. Flow =57,148 #/hr.	Outlet Press.=Zero to 57 PSIA Outlet Temp.=70°F. to 1044°F.	Press. = 30 PSIA Temp. = 70°F to $1211^{\circ}F$.
<u>Max. Conditions</u> Press. = 500 PSIA Temp. = 600°F.	Press.= 222 PSIA Temp. = 1375°F.	Press. = 90 PSIA Temp. ≈ 1485°F	Press. = 90 PSIA Temp. = 1485°F.	Press. = 90 PSIA Temp. = 1485°F

MEMORANDUM

FILE: SS 1020

DATE: 10 July 1970 7974:70:0047:gk Bldg 160/X6255

TO: H. Derow

FROM: W. Weleff

- SUBJECT: Boiler #5 Critical Areas
- COPIES TO: E.S.Chalpin, A.H.Kreeger, L.P.Lopez, R.W.Marshall, U.A.Pineda, Dept 7974 File
- ENCLOSURE: (1) BRDC Boiler #5 Operating Criteria Table I (2) Boiler #5 NaK and Hg Inlet and Outlet Interface Loads -Table II

This memo contains a brief description of the critical areas in the #5 boiler which require stress analyses, the input data needed for performing this analysis, and the approach to be undertaken.

A. CRITICAL AREAS

The Boiler #5 design requires evaluation of the stresses due to the transient and steady-state operational condition. The following areas will require analyses and evaluation.

- 1. Hg Inlet End
 - c Bi-metallic tube
 - . Tantalum Dome
 - SS Headers
 - SS Dome
 - Static Nak Tube-to-Header
 - Boiler Shell-to-Header
 - . . Nak Outlet Tee-Section

2. <u>Hg Outlet</u>

- Bi-metallic Tube
- Tantalum Dome
- Tantalum Header
- SS Headers
- 。 SS Dome
- Static Nak Tube-to-Header
- NaK Inlet Tee-Section
- Boiler Shell

H. Derow

3. Overall Boiler

- Spacers
- Shell Deformation
- . Ta-Tube vs SS Housing Relative Movement

4. Boiler Mounting

- . Design Details
- Integration

B. DATA REQUIRED FOR PERFORMING THE STRUCTURAL ANALYSIS

There are three types of information needed to conduct this analysis:

1. Operational Data

Proper consideration must be given to the pressure, gravity loads and temperature. Axial and radial temperature distribution of all critical locations, particularly where sharpgradients are expected is required to properly evaluate the thermal stresses. This is of considerable importance at the Hg inlet end. This information needs to be very specific for actual values (see Enclosure (1)).

2. Interface Loads

The interface requirements at the NaK and Hg inlet and outlet junctions are specified in Enclosure (2).

3. Material Properties

Mechanical and physical properties data at various temperature levels are required. This includes tensile yield and ultimate strength, elongation, area reduction modulus of elasticity, thermal expansion, creep and stress-rupture data.

C. APPROACH AND METHOD OF ANALYSIS

1. Finite elements Computer Program E-11401 will be used for the Hg inlet and outlet ends. These components have axisymmetrical geometry and loading directly suited for application of the finite elements computer program.

2. Hand calculation will be used for evaluation of the boiler body, based on the thermal expansion characteristics of the two structural materials (Ta and SS).

3. The analyses of the interface loads and supporting structure will be performed by hand.

4. Thermal fatigue analyses will be made, using the Manson's method and the computer output, where applicable.

D. STRESS CRITERIA

Minimum design safety factors for Boiler $\frac{1}{5}$ for the most critical loading condition shall be 1.25 against allowable creep load or yield strength, 1.50 against ultimate strength and 1.50 against endurance (fatigue strength).

Analysis of the boiler evaluation of the most critical loading conditions, primary and secondary stress safety margin, etc., should be in accordance with AGC-10650

The primary stresses for all components should be kept below the yield strength of the material whenever possible. The thermal stresses should be maintained at a minimum level by providing free expansion of the various components and by reducing the axial and radial thermal gradients. Materials with compatible coefficients of thermal expansion are desired. Supporting the boiler in the frame structure should be in such a way to permit free expansion or contraction of the overall boiler, thus, reducing the effects of thermal stresses on the structure which in turn will result in longer service life.

W. Weleff, Supervisor Structural Analysis Group Technical Resources Section Engineering Department

Enclosure (1)

.

•

TABLE I - BRDC BOILER #5 OFERATING CRITERIA

Hg Inlet	Hg Outlet	Nak Inlet	Na. Outlet	Static NaK
Low Schedule Inlet Press.=Zero to 323 PSIA Inlet Temp.=70°F. to 420°F F'cw = 7,740 #/hr. in 75 sec. =13,775 #/hr. (a) steady state.	Outlet Press. = Zero to 148 PSIA. Outlet Temp.=70 to 1185 to 1165°F.	Inlet Press.=Zero to 60 PSIA. Inlet Temp.=?0°F to 1185°F Flow=57,148 #/hr.	Outlet Press.=Zero to 57 PSIA. Outlet Temp.=70°F to 1015°F.	Press.=30 PSIA Temp. =70°F to 1185°F
High Schedule Inlet Press.= Zero to 333 PSIA. Inlet Temp. = 70°F. to 420°F. Flow = 7,740 #/hr in 75 sec. = 13,600 #/hr @ steady state	Outlet Press. = Zero to 147 PSIA. Outlet Temp. =70 to 1211 to 1190 F.	Inlet Press.=Zero to 60 PSIA Inlet Temp. = 70 to 1211°F. Flow =57,148 #/hr.	Outlet Press.=Zero to 57 PSIA Outlet Temp.=70°F. to 1044°F.	Press. = 30 PSIA Temp. = 70°F to 1211°F.
Max. Conditions Press. = 500 PSIA Temp. = 600 F.	Press.= 222 PSIA Temp. = 1375°F.	Press. = 90 PSIA Temp. = 1485°F	Press. = 90 PSIA Temp. = 1485°F.	Press. = 90 PSIA Temp. = 1485 ⁰ F

Encoure (2)

TABLE II - BOILER #5 NAK AND HG INLET AND OUTLET INTERFACE LOADS

		FORCE (J	b)	MOMENT (in1b)			
INTERFACE DESCRIPTION	Fx	Fy	Fz	Mx	My	Mz	
Eoiler Hg Ou tlet	-15.1 -12 -27	10.1 9 - 19.1	39.4 285 67.9	433 333 766	414 267 681	-283 235.5 518	Thermal, T = 1190°F Weight Combined
Boiler Hg Inlet	-2.1 2 1	0 -8 -8	o ò o	0 -49 -49	19.1 ~20 0.9	-4.25 -250 -254.5	Thermal, T = 417°F Weight Combined
Boiler #1 NaK Inlet 3 in. OD x .085 in. Wall, 316 SS	+17.7 -1.4 3.7	-67 +85 18	+26.6 +4 30.6	-434 -659 -1093	276 259 535	-504 +347 -157	Thermal, 1185°F, ∆T = 1110°F Weight Total
Boiler #1 NaK Outlet 3 in. OD x .083 in. Wall, 316 SS	-1 -95 -96	2 29 27	11 -10 1	388 494 · 882	-234 -2010 -2244	1.02 1545 1647	Thermal, 1185°F, ∆T = 1110°F Weight Total
Boiler #2 Inlet 3 in. OD x .083 in. Wall, 316 88	1 95 96	2 -123 -121	11 -10 1	-513 402 -111	440 90 530	-183 -1024 -1207	Thermal, 1185°F, ∆T = 1110°F Weight Total
Boiler #2 Outlet 3 ia. QD x .083 in. Wall, 316 SS	49 39 88	11 2 . .13	3 [°] •31 -28	331 . 132 463	-830 -248 -1078	-94 -134 -228	Thermal, 1015°F, ∆T = 940°F Weight Total

•

01-071-003



AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA

E-11401 COMPUTER STRESS ANALYSIS INPUTS SUBJECT

QUADRILLE WORK SHEET

OF PAGES PAGE DATE 1 SEPT. 1970 WORK ORDER 1475-44-0114

6

II, NODAL POINTS DETERMINE LOCATION OF NODAL POINTS IN RZ PLANES

IT. MANSON EQUATION FOR DETERMINATION OF CYCLE LIFE -

$$\Delta \mathcal{E}_{\text{aff}} = \left[\frac{2(1+V)}{3}\right] \left[\frac{3.5 F_{TU}}{E}\right] \left(\mathcal{N}_{\text{f}}\right)^{0.12} + \left(\mathcal{D}\right)^{0.6} \left(\mathcal{N}_{\text{f}}\right)^{-0.12}$$

WHERE :

A E . = EFFECTIVE STRAIN

V = POISSON'S RATIO

- FTU = ULTIMATE STRENGTH AT TEMPERATURE
 - E = MODULUS OF ELASTICITY AT TEMPERATURE
 - My = CYCLES OF LIFE

RA = REDUCTION OF ARMA (%)

DETERMINE My, THEN TAKE 10% OF My FOR PREDICTED LIFE CYCLES.
LOW CYCLE FATIGUE - ELEVATED TEMPERATURE, LOW FREQUENCY, LONG TIME EXPOSURE

by: U. A. Pineda

In low cycle fatigue investigations, strain rather than stress levels and ranges become the guiding factors. Plastic strain is the dominant element and an extremely important variable in predicting low cycle fatigue behavior.

The total strain range experienced during cycling consists of plastic and elastic strain components, thus

 $\Delta \epsilon_{\tau} = \Delta \epsilon_{p} + \Delta \epsilon_{e} \qquad -----(1)$ where $\Delta \epsilon_{r}$ = Total strain range, in/in $\Delta \epsilon_{p}$ = Total plastic strain range, in/in $\Delta \epsilon_{e}$ = Total elastic strain range, in/in.

A relationship exists between the plastic strain, the number of cycles to failure and the ductility of the material. Experimental investigations have shown that the relationship can be mathematically expressed by a linearization of the log-log plot of data as follows:

$$\Delta \varepsilon_{p} = \frac{c_{p} D^{n}}{N^{k}} \qquad (2)$$
where C_{D} = coefficient to linearize the log-log plot
 D = Ductility = $\ln \left[\frac{100}{100 - RA} \right]$
RA = Reduction of Area
 N = Cycles to failure
 n = Slope of the linearized log-log plot of
cyclic life vs. ductility
 k = Slope of the linearized log-log plot of
plastic strain range vs. cyclic life.

The elastic strain range is a direct proportional relationship with the stress range in the Hooke's Law regime:

$$\Delta \epsilon_e = \frac{\Delta \sigma}{E} \qquad ---- \qquad (3)$$

 $\Delta \mathbf{C} =$ Stress range, psi

E = Young's Elastic Modulus, psi

Cyclic patterns in the elastic range are normally referred to and the endurance strength of the material,

However, in view of elevated temperature, long time exposures, creep/rupture behavior of the material predominates; therefore,

$$F_{R}$$
 = Rupture strength at exposure temperature and time, psi

The creep-rupture stress-time curve is linearized in the log-log plot to an extrapolated rupture stress level equivalent to x times the ultimate strength:

$$F_{R} = X F_{U} \left(\frac{t_{R}}{A} \right)^{-m}$$
where: A = time intercept on the linearized log-log plot
at an extrapolated rupture level equivalent
to X^{*}F_U, hours
 t_{R} = time to rupture at F_{R} level, hours
X = arbitrary multiple of the ultimate tensile strength
for linearizing the curve

G-13

using X = 1.75, adequate multiple for linearization

$$F_{R} = 1.75 F_{u} \left(\frac{t_{R}}{A}\right)^{-m}$$
(6A)

However,
$$t_{\rm H} = \frac{N}{\omega}$$
 (7)

where ω = strain cycling frequency, cycles per hour

Hence,
$$F_{R} = 1.75 F_{u} \left[\frac{N}{A\omega} \right]^{-m}$$
 (8)

Using equations (8) and (5) in equation (3) results in:

$$\Delta \epsilon = \frac{3.5 F_{\rm u}}{E} \left[\frac{N}{A\omega} \right]^{-m}$$
(9)

Equation (1) becomes:

$$\Delta \epsilon_{\rm T} = \frac{C_{\rm D} D^{\rm n}}{N^{\rm K}} + \frac{3.5 \ F_{\rm u}}{E} \left[\frac{N}{A \ \omega} \right]^{-m} \qquad (10)$$

which is the low cycle fatigue equation. Coefficients and exponents are to be formulated from test data and material property curves.

ANALYSIS NO. SA-245

DATE 3 September 1970

ProjectSNAP-8ComponentBRDC #5	Distribution:
Part NaK & Hg Inlet/Outlet Drawing No. 1268605	E. S. Chalpin
SubjectInterface_Loads	H. Derow
Reference(s) Memo E. Chalpin to W. Weleff, 6 July 1970.	U. A. Pineda
Subject: Operating Criteria for Stress Analysis	G.L. Lombard
Engineer J. C. Shen Approved W. Welff	File: SS <u>1020-03</u>

<u>OBJECTIVE</u>: To evaluate the structural integrity of NaK and Hg inlet/outlet for the piping interface loads.

ASSUMPTIONS:

Critical loading condition assumed when axial and radial forces are combined with axial and radial moments torque and internal pressure.

REFERENCES (Analysis Methods):

- 1. AGC-10650 Structural Design Criteria, SNAP-8.
- 2. Materials Manual H-100,

RESULTS AND CONCLUSIONS:

- 1. The stress levels due to each individual loading condition are below the corresponding allowables.
- 2. The results of the interaction equation indicate sufficient margins of safety for each component.
- 3. The stresses in the welds at the proposed location are acceptable.

RECOMMENDATIONS AND COMMENTS:

All parts are considered structurally safe for the given interface loads.





70

	DESIGN	I COND	INTERACTION	EQU.		
COM PONENY	P T psi of	P T psi oc	Allow Forces CRITERIA (196 40,000 HPS)	FRUKTURE * (EMERGENCY)	Notes	
NoK /WLET: @ /WTERFACE @ CURVATURE @ WELD	} p= 60 Psi ∫ T=1211 °F	}	ΣR 0, 202 ΣR	· Low 0:058 Low	STRESSES ARE LOW STRESSES LOW	RESULTS OF
Nsk Outley: @WT@Face @Curvature @WELD	(p= 57 751- (T= 1044 9-) p= 90 751 S T= 1485 97	0.a4:2 .121 .271	0;165 ,076 .726		: Awalysis
HG INLET " @ 1.5" @ 8.4") p: 333 PSI (T = 420 0F) p = 500 PSI 5 T = 600 PF	S.R. S.R	- Low	STREESES LOW	
HG Curler: @ 1.5" @ 8.4"	} p=147 PS1 { T = 1190 ℃) p= 228 PSI 5 T= 1375 °F	0.417 Low	Low Low		
* 15	r EmerGenc OF 40	y <i>co</i> ndition Seconds dui	 - REF. / S RATION EACH	i PECIFIES Fr FRØM D	de 20 cycles EF. 5 Taque III	

IS USED.

FOR PRIMARY & SECONDERY STRESSES COMBINED, THE ALLOWARLE IS 2x: Fry = 2x 14,800 = 29,600 PSI. HERE Fru = 29,000 PSI

QUADRILLE WORK SHEET

01-071-002

SUBJECT

ЯΒ

WORK ORDER

DATE PAGE

ŝ

ę

N

PAGES



AZUSA. CALIFORNIA **AEROJET-GENERAL GORPORATION**

STK. NO. D-1-103

G-18

ANALYSIS NO. SA- B-246

DATE 3 September 1970

SUMMARY	OF	ANALYSIS
---------	----	----------

ProjectSNAP-8	Component Boiler #5	Distribution:
Part 316SS Header	Drawing No	E.S. Chalpin
Subject Structural Analysis	- Interim Report	G.L. Lombard
Reference(s) Memo E. Chalpin to	W. Weleff, 6 July 1970,	U.À.Pineda/H. Derov
Subject: Operating Cr	iteria for Stress Analysis	
Engineer S. Krikopulo	Approved_ Cl. alelity	File: SS <u>1020-03</u>

<u>OBJECTIVE</u>: To evaluate the integrity of the 316SS header for the transient and steady state operational condition.

ASSUMPTIONS:

Most critical loading condition is assumed due to internal pressure differential (max.) and maximum thermal gradient -- high schedule.

REFERENCES (Analysis Methods):

AGC-10650 - Structural Design Criteria for SNAP-8 Materials Manual H-100.

RESULTS AND CONCLUSIONS:

- 1. The stresses in the stainless steel header (flat plate section) are found below the corresponding allowables.
- 2. At the juncture of the header to the exterior shell toward the inlet end a small yielding will take place.
- 3. The stress level at the juncture of the header toward the interior portion of the boiler unacceptable stress levels were obtained.

RECOMMENDATIONS AND COMMENTS:

Investigate a change in transition juncture of the header to the exterior NaK shell toward the inside section of boiler.

Finite' element computer program analysis is recommended.

NOTE: The loading condition was found unrealistic. This analysis is cancelled.

Lezhend, Corpozation

CALIFORNIA

OF 2 PAGES PAGE DATE 9-3-70

SUBJECT BRDC BOILER # 5

SK

WORK ORDER

Mercury meet End 316 SS Headow.

AI 57 PSI 1044013 Contraction of the second second 57 PSI 1044.0 F BO PSI 1211°F VAC. ¢.

F/G. 1

Material: 316 55 For temperature distrubution in FIG. 1 assumed cutical case ; high schedule For pressures Rec F16. 1.

Hender is assumed

to be a wolid caution, plate.

stranger were checked at crowspectrou A and B - see FIG. 1 Method of analysis! Conventionel calculations by hand.



AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA

PAGE_	2	OF	PAGES
DATE_		<u> </u>	

SUBJECT_

QUADRILLE WORK SHEET

BY ____

WORK ORDER_

Summary of strusses

GROSS - SECT.	MERID. OR HOOP	G PSI STRESS	TYPE OF STRASS	TOF
Δ	··M	18000	TBNS.	1000
A	H	5650	GOMP,	1200
R	M	14400	TENS.	1100
	H	75800	COMP.	1100

Material allowables

7-0 5	Fry	Fru.
1200	16000	53000
1100	16700	62000

ANALYSIS NO. SA-247

DATE 3 September 1970

SUMMARY OF ANALYSIS

ProjectSNAP-8	Component_Boiler #5	Distribution:
Part Mercury Outlet	Drawing No.	W.S. Chalpin
Subject Structural Analysi	s	G.L. Lombard
Reference(s) <u>Memo E.S. Chalpi</u>	n to W.Weleff/H. Derow, dated	U.A. Pineda
6 July 1970, Subject: Op	erating Criteria for Stress Analysis	H. Derow
Engineer S. Krikopulo	Approved U. alely	File: SS 1020-03

OBJECTIVE: Evaluate the structural integrity of the mercury outlet end for Boiler #5.

ASSUMPTIONS:

The most critical loading condition is assumed to be the maximum operational pressure and uniform steady state temperature at the emergency case: p = 222 psi $T = 1375^{\circ}F$

REFERENCES (Analysis Methods):

AGC-10650 - Structural Design Criteria for SNAP-8. Materials Manual H-100. AGC Finite Element Computer Program E-11401

RESULTS AND CONCLUSIONS:

- 1. The stress levels obtained in most areas of the outlet are close to the stress levels obtained for Boiler #4
- 2. Comparison tables of the stresses for the bimetallic section and tantalum dome for Boilers No. 4 and No 5 are included.
- 3. Fatigue life is estimated to be close to the fatigue life of Boiler #4.

RECOMMENDATIONS AND COMMENTS:

The design for the mercury outlet end is acceptable.



AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA

PAGE OF 17 PAGES DATE 10-7-70

SUBJECT BRDC BOILER # 5

BY SAT

WORK ORDER

MERCURY OUTLET

Giometry Merenny outlet causists of three parts; 1 Header - crecular plate - tautelum 2 Reducer - bell shell - tautalum 3 Bimetallic tube - imper tube tautaling outer take 316 Stainless stell See the snatch # 1 ou pg. 2 Condition: Steady State Temperature: uniform 1375°F. PRINKE NAK BOPSI Mercury 222PSI Dimensions of the bimetallie tube: see p. 3



AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA





AEROJET-GENERAL CORPORATION

AZUSA. CALIFORNIA

PAGE_	3	OF	····	PAGES
DATE_	<u>. </u>			
WORK	ORDER			

SUBJECT

ST TA .975 .880 F16,2 Dall thickness: tor=.150" tra=.095"

Material properties at 1375°F

	TA	316 SS
Ē	25.8×10°	20.4×106
¢.	4,04 × 106	10.9 × 10-6
FPHO	13500	35000
Fitz	5000	15200

Method of attack

Finite element computer program for celculating stresses and strains.



SUBJECT

PAGE 4 OF_____ PAGES

WORK ORDER.

Computer solution yields stresses and strains using six approximations. Streets is and strains are tobulated on the following poges. The abole crosspection is divided into four parts: 1 Header Tautelum 2 Bell shell 3 Meck 4 Dimetallic tube Tautalum & 31655 - & fective stress is the total combined stress a-gter SIX Iterations: Effective strain is the total combined strain corresponding to calculated effective stress. "In the "Rauge" column E stands for elastic and P for plastic struss.

AEROJET-GENERAL CORPORATION



SUBJECT

page_5	OF	PAGES
DATE		
WORK ORDER_		

Pages 16 and 17 show the crossection with the numbered elements as it was act up for the computer program: The numbers of the tabulated elements correlpoind to those on the crossoection. In the unumbered elements struses are identical or close to the adjacent and therefore ouristed. Max stressed elements wie those of Tautalismi and are located in the Simetallie tabe.

BY

AEROJET-GENERAL CORPORATION



AEROJET-GENERAL CORPORATION

BY_

AZUSA, CALIFORNIA

PAGE OF	PAGES
DATE	

SUBJECT

.

WORK ORDER

•

MATE	R: TANT	ALUM	Fity = 1	5000 F	751
EL, #	EFF, STRASS PSI	EFF. STRAIN	RANGE	T.ºF	40CATION
2,	1098	4.2.×10.5	E.	1375	
3	1206 .	4.7×10-5			
4	1434.	5.6 x 10-5			
5	1751.	6.8×10-5			
6	2086	.8.1×10-5	,		
7	2389	9.3×10-5	t ^k		
8	2,664	\$1.0 x 10-4]
2	3081	1.2×10-4	•	•	
19	754	2.9×10-5		:	0-
20	1338	· 5.2×10-5			
21	1795	7,0x1075		,	U.
22	1087 .	4.2×10-5			
23	1343	57.2x1075			
25	1267	4.9×10-5	: '		1 U
26	1570	"6.1x10""	` -	•	Ľ
27	1863	7. 2x10"	,		
28	2134	8. 3×10-5			
29 .	2,464	9.6×10-5			
30	1622	6.3×10-5			
31	2005	. 7.8×10-5	·		
32	2229	8.6x1075			
33	3201	1.2×10-4	·E	1375	



AERDIET-GENERAL CORPORATION

BY.

QUADRILLE WORK SHEET

PAGE OF	PAGES
---------	-------

•

SUBJECT.__

WORK	ORDER

DATE

.

MAPE	R.: TANTA	LUM I	- 5, = 5°	000 PS/	, ,
EL, #	EFF, STRESS PSI	EFF. STRAIN	RANGE	T° F	40CATION
34	1666	6.5×10-5	Ē	1375	
35	2037	7.9×10-5	E		
36 .	5027.	2.3×10-4	P	•	
37	5032	3.5×10-4	P	-	
38	· 1613	6,3×10-5	E		
40	4293	1.7×10-4	. <u>·</u>		
41	2274	8.8×10-5	•	-	
42	2649	1,0,10-4	ī - ·	۰	
45	2302	8.9×105			
46	1886	7.3 × 10 -5			
49	1963	7.6×10-5.	•		EN .
50	22,09	8.6×10-5		-	NN NH
53	1695	6, 6x 10-5		,	
54	2649	1.0×10-4			アイ
57	17.39	6. 7x 10 -5		•	Ψ W
58	2856	1.1×10-4		- `	1 VI
61	3318	1.3×10-4			
.62	2949	1.1.10-4			
63	4164	1.6x10-4			
64	3165	1. 2×10-4		 	
65	4716	1.8×10-4			
66	3871	1.5.10-4	E	1375	



AEROJET-GENERAL CORPORATION

AZUSA. CALIFORNIA

QUADRILLE V	VORK	SHEET
-------------	------	-------

PAGE	OFPAGES
DATE	

```
SUBJECT___
```

		- -	<u></u>		
MAT	ER .: TAN	TALUM	Fify =	5000	P5/
EL:#	EFF, STRESS PSI	EFF, STRAIN	RANGE	7.05	40CA713N
67	. 4919	1.9×10-4	Ĩ.	1375	
68.	4640	1.8×10-4	Ē		
69	: 4820	1.9×10-4	E	·	
- 70	5000	2.0×10-4	P.	·	
71	4428	1.7×10+4	E		
72	4948	1.9×10-4			
73	3804	1.5×10-4		•	7
74	4394	1.7 × 10 +4			, A A
75	3040	1.2×10^{-4}			ડ્ડ
76	3595	1.4×10-4			
79	1600	6.2 × 10 + 5		••••••	7
80	2014	7.8×10-5			N N
83	603	2.3×10-5)
84	1,012	3.9×10-5	E	۰ 	
89	5872	3.7×10-4	<i>.P</i>		
90	60301	4.9×10-4			
91	5778.	1.1x10-3		1 1 1	
92	5872	1.5×10-3			7
93	5802	2.6×10-3			Ŭ
94	5804	3.6×10+3		, 	マン
25	6/04 1	5.4×10-3			
96	6216	7.6x10+3	P	1375	

SUBJECT_____



AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA

	PAGEOFPAGES
	DATE
8Y	WORK ORDER

MATE	R.: TANTA	LUM	Fry = 5	7000 P	51
EL. #	EFF, STRASS PSI	EPF, STRAIN	RANGE	7° #	40 CA7101
98.	6973	1. 3× 10-2	P	1375]
99	6603 .	1.1×10-2:			
102	7163	1.6×10^{-2}		<u> </u>	
103	7056	1.5x10-2	· .		
106	7.1.67	1.7×1072			
107	7359	1.8×10-2.			
112 .	.7248	1.8×10-2	·	,	1
113	7415	1.9×10-2		,]
121	7255.	1.8×10-2	· · · · · · · · · · · · · · · · · · ·]
122	7445	1.9×10-2			- IN
128	7270	1.8×10-2	· ·	-	Q
129	7454	2.0×10+2			2
· 134	7272	1.8x10-2	·	•	
135	7462	2.0x10-2			V
138	7275	1.8×10-2			L
139	7467	2.0×10-2			マイ
142	7279	1,8×10-2			K
143	7472	2. 0x 10-2			NZ N
146	7279	1.8×10-2			a D
147	7474	2.0×10-2]
150	7278	1.8×10-2			
151	7474	2.0.10-2	P	1375	1.



AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA

PAGE OF	PAGES
DATE	

QUADRILLE WORK SHEET

BY_____ WORK ORDER___

_

MATE	R.: TANTA	LUM	Fry = 5	0.00 PS.	/
E4, #	ZFF, STRASS PSI	EFF. STRAIN	RANGE	705	40CATION
154	7276	1.8×10-2	P	1375	
155	. 7472	2.0×10+2		-	
158	7274	1.8×10-2			
159	7470	2.0x10-2			
162	7276	1.8×10+2			
163	7468 .	2.0x10-2			
166	7266	1.8×10-2.			lt.
167	7472	2.0×10-2			B
170	7279	1.8×10-2			2
171	7435	1.9×10=2			7
174	7204	1.8×10-2			Ų
175	7312	1.8×10-2			N N
178	7113	1.7×10-2	•		N V N
179	7336	1.9×10-2	P	1375	K
					ME
		-		[] 	D
				; ,	
				; ;	4
	• · · · · · · · · · · · · · · · · · · ·	·	+	1	-
		<u> </u>			1
<u> </u>		-			
1)	<u>l</u>	1]	1



₩Y_

AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA

.

PAGE	07	
------	----	--

SUBJECT

.

DATE_	
WORK	ORDER

MAT	ER. : 3/6	US Fry=	= 152	00 PSI	
EL, #	EFF, STRESS PSI	EFF, STRAIN	RANGE	7°,=	40CATION
9.7	13366	1.8×10=3	Ē	1375	
100	12996	8.1 x 10-4			
101	12113	9.5×10-4			
104	6069	3.0×10-4			
105	10907	5.3×10-4			
108	3103	1.5×10^{-4}			
109	3394	1.7×10-4		•	
110	4323	2.1×10^{-4}			1.1
111	9276	4.5×10-4			
114	665	3.3×10-5		=	10
115	745	3.7×10-5			
116	906	4.4×10-5			\cap
117	1177	5.8×10-5			2
118	1192	5.8×10-5			17
119	2792	1.4×10^{-4}			1 XX
120	5646	2.8×10^{-4}			U U
123	327	1.6×10-5			m
124	692	3.4×10-5			
125	710	3.5×10-5			
126	2313	1.1 x 10-4			
127	4430	2.2×10-4	Τ		
130	1596	·7.8x 10-57	E	1375	



.

BY,

QUADRILLE WORK SHEET

PAGE_//	٥F	<u> </u>	PAGES
---------	----	----------	-------

SUBJECT_

-

DATE	
WORK ORDER	

MA	TER. ; 316	SS Fity	. = 15.	200 PS	1
EL, #	EFF, STRESS PSI	EPF, STRAIN	RANGE	7.0 =	40CATION
131	1706	3.4×10-5	Ē	1375	
132	2841	1.4×10^{-4}			
133	4583	2.2×10-4		· .	-
136	. 3261	1.6×10-4	1 1		
137	4437	2.2×10-4			
140	3339	1.6×10-4			
141:	37.61	1.8×10-4			
148	3861	1.9×10-4			W
149	3759	1.8×10-4			a)
152	3914	1.9×10^{-4}		-	2
153	3925	1.9×10-4			
156	3892	. 1.9×10-4			U V
157	4050	2.0×10-4			ズイ
160	3824	1.9×10-4			I
161	4149	2.0x10-4			W
168	3674	1.8×10-4			A I
169	4293	2.1×10-4			Ø
172	3528	1.7×10-+			
173	4242	2.1×10-4			
176	4339	2.1x10-4			
177	4207	2.1×10-4	E	1375	



AEROJET-GENERAL CORPORATION

AZUSA. CALIFORNIA

PAGE_	12	OF	_pages
DATE			

SUBJECT_

......

QUADRILLE WORK SHEET

BY

WORK ORDER____

Fatigue life

Max londed elements will be chieved for fatient life. Method of attace: s.s. Mauson's unversal slope equation for multiaxial strain.

Max loaded elements are located in the Simetallic tube.

Tautalum element # 151

in the plastic range

316 SS element # 97

in the elastic range



PAGE_13	ofPages
---------	---------

SUBJECT

WORK ORDER

DATE

Fatigue life of the element # 151

ATUSA. CALIFORN

Material: Tantalum Temperature: 1375° F Material properties at 1375°F E = 25,8 × 106 F. = 13500 PSI RA=.77 reduction in area effective straim: E == = . 01977 "/" Ductility: $D = ln \frac{100}{100 - RA} = 1.47$

D.6 = 1.26 V = FA = 13500 PSI Nr - number of cycles 4 Er = EEFE =. 0198 Modified universal slope equation: ΔE, = 3.03 VII N, -.12 + D. N, -

QUADRILLE WORK SHEET	ALRONAT	AEROJET-GENERAL CORPORATION Azusa. California	PAGEOFPAGES
SUBJECT		BY	DATE

 $\Delta \mathcal{E}_{T} = 3.03 \frac{13500}{25.8} 10^{-6} N_{F}^{-.12} + 1.26 N_{F}^{-.6}$ 0Z

.0198 = .001585 N, -.12 + 1.26 N, -.6

Solution of the above equation is shown ou pg. 15 $N_{F} = 1050$

monder to account for creep using "10% rule" de réduce the number of cycles to 105

Max loaded tantalum element: 105

The inclume lage of 316 ss in mithe rauge



AERDIET-GENERAL CORPORATION

AZUSA. CALIFORNIA

ADRILLE WORK SHEET				PAGE 15	_ OF	PAGES
				DATE	<u>_</u>	
ar -		BY		WORK ORDER.		
·				•		
ar andress and market and and	umulanda an articles - rate and the		and the second second second second second second second second second second second second second second second	······································	. معرفت د	
···						
						•
			· · · · ·	······································		
					,	_ _
. ma ci	an on t 797h	kriko.	DULO			
ACKNOW	LEDGED AT 14:	42 10	-06-70			
1 a=1	585e-3*x**(-	.12)+	1.26*x**(6)			
2 x = x	<u>.+50,</u>					
	950. 500000E±02		_			
<u> </u>	2.1.4)*12				, 	_
<u>4</u> pri	nt x,a					
p:3	· · · · · · · · · · · · · · · · · · ·					
ACKHOL	ILEDGED					
$\chi = 1$	000000E+03	A =	2.066153E-02			
$\frac{\lambda = 1}{Y = 1}$	100000E+03	$\frac{\Lambda}{\Lambda} =$	<u>2.008157E-02</u> <u>1.056371E-02</u>			
X = 1	.149999E+03	A =	1.904371E-02			•
X = 1	.1999999E+03	A =	1.857726E-02			
<u> </u>		<u>A =</u>	1.814084E-02			
X = 1	300000E+03	A =	1.773143E-02			
$\frac{\chi = 1}{V - 1}$	<u>.350000E+03</u>	<u>A =</u>	$\frac{1.7346411-02}{1.6097505-02}$			
X = 1		A =	1.664071E-02			
$\frac{1}{2}$. $\frac{1}{X} = 1$.500000E+03	$\frac{n}{A} =$	1.631628E-92			
<u> </u>	.550000E+03	A =	1.600866E-02			
EXECUT	TON COMPLETED)			-	
dron	v=050					<u></u>
× arop X≈950	NOT FOUND					
sign_c	off:					
SIGNED	OFF AT 14:47	10-0	6-70			
~~		····				
·						
· · · · · · · · · · · · · · · · · · ·				-		
						-
~ <u></u>						
•			<u> </u>			
· · · · · · · · · · · · · · · · · · ·	······································					
		I				

·

,



EOLDOUT FRAME 2.



BRDC BOILER # 5



OF 4 PAGES DATE 7-28-70

SUBJECT BRDC BOILER # 5

BY_UK

AFRAIFT-GFRENAL CORPORATION

WORK ORDER

Mercury outlet

Comparison of strusses and straims in boilde # 5 to those in bailer # 4 Part: bimetallie tube immer part material Tautalum

Condition: Steady State Temperature: Boiler #5 Boiler #4 1875° F Uni-form -1300° F Ppressure NAK: 30 PSI 30 PSI Mereury: 222 PSI 259 PS/ Geometry:

Boiler # 5 ST THINK Tor = . 150" TTA = . 095" ---- ¢ Boiles # 4 ST THINK Tsr = . 120" TTA = . 100 " ¢,

01-071-008



8Y_

AEROJET-GENERAL CORPORATION

AZUSA. CALIFORNIA

PAGE_2_OFPAGES
DATE
WORK ORDER

•

SUBJECT MERC. JUTLET

BINETAL, TUBE

TANTALUM

	r~ -	۰			
三公三河	BOILER	مسلح كمختبر	30/12R	أكبسها شيتد	
<i>4</i>	010230	5. 9.414	1 C C C S E	,	
	5712	.2011	3242	· · · · · · · ·	
\$2	531	.0015			;
: 93	5802	.0025	5935	. 9917	1
94	5804	.0036	5942	· 923-	····
95	6104	.0055	3184	. 2055	
95	6216	.0076	5219	:0000 :	
. 98	6973	. 0130	6875	. 0126	
99	6603	.0110	6670	.011E	
102	7163	. 0161	710%	. 6131	
. 103	.7056	.0152	7103	.0160	
106	7167	.0168	7/35	. 0175	
107	7359	. 0/80	.7.341	.0184	
112	7248 .	.0178	7158	. 0172	
113	7415 .	.0189	7343	.0185	
. 121	7255	.0180	- 7157	.0172	
122	. 7445	. 0194	7344	.0187	
128	7,270	.0181.	7156	.0172	
129	. 7454 .	.0196	7346	.0187	•
134	7.272	.0182	7154	.0172.	
135	7462	.0197	7347	:0187	



91-071-005



QUADRILLE WORK SHEET

AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA

PAGE_2_	07 <u></u>	_Pages
DATE		

WORK ORDER

SUBJECT MERC. OUTLET BY

BIMET, TUBE

TANTALUM

CEM,	301LER # 5		BOILER # 4	
.r.:	078555	SIRAIN	578355	STR.41,1
138	-275	.0182	7155	.0172
157	7457	.0197	7349	.0187 /
122	7279	.0182	7155	.0172.
:43	7472	.0197	7350	.0187
143	7279	.0182	7153	.0172
147	7474	.0198	7349	.0187
150	7278	. 6182	7150	.0172
151	7474	.0198	7346	.0187
154	7276	.0182	7149	.0172
155	7472	.0198	7339	. 0187
	· · · · · · · · · · ·	4		•
		<u> </u>	· · · · · · · · · · · · · · · · · · ·	· · ·
····		· · · · · · · · · · · · · · · · · · ·	· · · · · · · · · · · · · · · · · · ·	
- <u></u> .	· ····································	, ,		4 +
		, ,,,,,_,_,, , ,	· · · · · · · · · · · · · · · · · · ·	
		: 		1 1
		;. 		ב - איז איז איז איז איז איז איז איז איז איז
		· · · · · · · · · · · · · · · · · · ·		· · · · · · · · · · · · ·
· · · · · ·			· · · · · · · · · · · · · · · · · · ·	
			· · · ·	· · · · · · · · · · · · · · · · · · ·
•	. A	G-43		· · · ·



Pć

G-44

ANALYSIS NÓ. SA-248

DATE 4 September 1970

SUMMARY OF ANALYSIS

Project SNAP-8	Component Boiler No. 5	Distribution:
Part Oval Tube	Drawing No	E. S. Chalpin
Subject Structural Analysis		G. L. Lombard
Reference(s) Memo E. Chalpin to W.	Weleff/H. Derow.	U.A.Pineda/H. Derow
dated 6 July 1970, Subject: Stress Analysis	Operating Criteria for	
Engineer S. Krikopulo	Approved al. aleliff	File: SS 1020-03

OBJECTIVE: Determine the stress levels and safety margin due to the given loading.

ASSUMPTIONS:

Maximum internal pressure of 30 PSI at 1211°F is the only load.

REFERENCES (Analysis Methods):

- (1) AGC-10650 Structural Design Criteria, SNAP-8
- (2) Materials Manual H-100
- (3) Hand calculations

RESULTS AND CONCLUSIONS:

Maximum calculated stress 6600 PSI (compression) MS is large (>1.5)

RECOMMENDATIONS AND COMMENTS:

Oval tubes are structurally sound for this application under the above stated load:



AEROJET-GENERAL CORPORATION AZUSA. CALIFORNIA

SK

SUBJECT BRDC BOILER # 5

WORK ORDER

OVAL TUBE

Geometry as shown OU F19. 1. C .890 L= .280" R= .420" # =. 040 "

#16. 1

Material: 316 S.S

Based on the operating criteria chart critical condition is high schedule NAK Intet: 60 PSI at 12110 5 Static NAK: 30 PSI at 1211° F morde premare 30 PSI outside " 60 " Loading: external prusture of 30 PSI Temperature: 1211° F



AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA

SUBJECT '

QUADRILLE WORK SHEET

WORK ORDER_____

DATE

Material properties at 1211°F; E=21.8x10° Fy=16000 PSI Fy=53000 PSI

Bending moment at. Pr. A $M_{A,\overline{a}} W R L \left| \frac{L}{2R} + \frac{1-\frac{1}{3}}{\frac{R}{2}} \right| =$

 $= 3.53 \left(.334 + \frac{1 - .148.}{1.57 + .667} \right) = 2.52 \frac{16m}{10}$

Vi = 6M/7 = 6300 PSI beud.



Total stress on the outer side;

V = 6600 PSI Compt.

Total stress on the inner side: V = 6000 PS/ Teus,




AEROJET-GEKERAL CORPORATION

AZUSA, CALIFORNIA

PAGE_ <u>3</u>	PAGES
DATE	<u></u>
WORK ORDER	•

SUBJECT

Bending moment at pr. c









Total stress ou the inner side:

V = 5040 PSI Tens,

MS= 16-1= Laye



DATE

SUBJECT

AEROJET-GENERAL CORPORATION

WORK ORDER_____

Deflection at PT. A

From the chart of "The analysis of a thin Obsecuted Ring "by J.C. Heap

 $\frac{4_{A}EA}{1/p^{2}} = 1.5$



 $R^2 = .176$ A = . 049 m2

Deflection on:

 $\Delta_{A} = \frac{1.5 \times 30 \times .176}{21.8 \times .049} 10^{-6} = 7.5 \times 10^{-6} "$

ANALYSIS NO. SA- 249

DATE

4 September 1970

SUMMARY OF ANALYSIS

ProjectSNAP-8	Component_Boiler #5	Distribution:
Part Center Vacuum Tube	Drawing No. 1268605	E. S. Chalpin
Subject_Structural Analysis		G. L. Lombard
Memo, E.S.Chalpin to W.W Reference(s) <u>Subj: Operating Criteri</u>	eleff/H.Derow, dtd 6 July 197 a for Stress Analysis	U. A. Pineda/H. Derow
Engineer_S. Krikopulo Ap	proved W. Well	File: SS 1020-03

OBJECTIVE:

'Evaluate the structural integrity of the inner vacuum tube - Boiler #5

ASSUMPTIONS:

Critical loading conditions external pressure of 90 psi at 1485°F

REFERENCES (Analysis Methods):

AGC-10650 Structural Design Criteria SNAP-8 Materials Manual H-100

RESULTS AND CONCLUSIONS:

Critical buckling pressure 1980 psi > 90 psi-

RECOMMENDATIONS AND COMMENTS:

The inner vacuum tube is capable of resisting the external pressure Safety margin against buckling is high (> 2.0)



AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA

I OF 2 PAGES PAGE 9-3-70

SUBJECT BRDC BOILER #5

BY_ ISK

WORK ORDER

Summary of results of strend calculations.

Central vacuum tube

wax external press, under which the take Dou't collapsel: p=1980 PSI atT=14850 F

Outer shell

Mox stress under internal pressure V2 = 2650 PSI hoop tension at T=1485°F Fty = 15000 PS1



AERCIET-GENERAL CORPORATION

AZUSA, CALIFORNIA

PAGE_	2 OF PAGE	5
DATE		_

SUBJECT

WORK ORDER

Vacuum insulators

Shell

QUADRILLE WORK SHEET

min pressure under phich the shell will collepses; p=1060 psi at T= 1485-0/F

Plate Orde collapsi under premure of 24 PSI at T= 1485°F



AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA

PAGE	4	_ OF	PACES
DATE.			

SUBJECT___

BY_____

WORK ORDER

Vacuum Tube

Max coud. $T = 1485^\circ F$ p = 90PSIwill be chroned for stability L = 25.0" & = 1.72" T = .125"Material: 31655 E= 20,0 x 10° ZL= 1= (1-122)1/2 = 2780 Ky=60 NACA TN 3783 $\nabla_{e_{n}} = \frac{K_{T}T^{n}E}{10,12} \left(\frac{T}{4}\right)^{2} = 27200 PSI$ certical pressure: p = 27200x.125 = 1980 PSI MS = Large



AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA

PAGE_	2	_ OF	 _PAGES
DATE			

SUBJECT

WORK ORDER_

Outer shell

coud. : Max 14DITATIONS $T = 1485^{\circ}F$ = 3.687 b = 90PSI4-







MS = Large

-B-ANALYSIS NO. SA- 250

DATE <u>4</u> September 1970

SUMMARY OF ANALYSIS

Project_SNAP-8	_ Component Boiler #5	Distribution:
Part_Vacuum Insulator	Drawing No	E. S. Chalpin
Subject_Structural Analysis	······	G. L. Lombard
Memo, E. S. Chalpin to Reference(s) <u>1970</u> , <u>Subj:</u> <u>Operating</u>	W. Weleff/H. Derow, dtd 6 July Criteria for Stress Analysis	U. A. Pineda/H. Derow
Engineer S. Krikopulo A	pproved U. Weleff	File: SS 1020-03

OBJECTIVE:

Evaluate the structural integrity of the vacuum insulators

ASSUMPTIONS:

Wall thickness for the toroidal and flat plate insulator 0.050 in. A support ring at 2 in. diameter is provided at center of the flat plate insulator.

REFERENCES (Analysis Methods):

AGC-10650 - Structural Design Criteria SNAP-8 Materials Manual H-100 RESULTS AND CONCLUSIONS:

> Critical pressure was found as follows: for the toroidal insulator 1060 psi for the flat plate insulator 220 psi

RECOMMENDATIONS AND COMMENTS:

The toroidal and flat plate insulators are capable of resisting the operational external pressure of 90 psi at 1485°F



AEROJET-GENERAL CORPORATION

AZUSA. CALIFORNIA

PAGE / OF 5 PAGES DATE 10-19-70

SUBJECT BROC BOILER # 5

BY SA

WORK ORDER

Vacuum meulator

Temperature: 1485°F Prusuke: 90 PS/ Material: 31655 Material properties: E= 20.0×10° 1.02 R=4.0" t=,05" Cecitical presente for cylimder: 4,0 $V_{ck} = \frac{K_{\gamma} \pi^2 E}{12(1-\mu^2)} \left(\frac{1}{L}\right)^2 =$ = 7,5° P,87x 20x 625 = 85000 PS/ MINI critical prass, 0= 8.5x10*.05 = 1060 PS/



AEROJET-GENERAL CORPORATION

PAGE Z OF PAGES DATE 10-19-70

SUBJECT BROC BOILER # 5

QUADRILLE WORK SHEET

BY____SA

WORK ORDER

Plate - Vacium moulator 1.05 .10 2.37 Outside pressure: 90 PS1 F16.1 Temperature: 1485°F Material 1 31655 E=20.0x106 D= Et= = .00023x106 assuring clamped edges, deflection at renter: $W = \frac{q^{a^{\prime}}}{64D}; \quad q = 24 \text{ PSI}$ assummy \$ = . 0,5"



ANALYSIS NO. SA-B-251

DATE 10-15-70

SUMMARY OF ANALYSIS

ProjectSNAP-8	Component_BRDC_Boiler #5	Distribution:
Part Mercury Inlet	Drawing No	E. S. Chalpin
Subject_Stress Analysis	· ·	G. L. Lombard
Reference(s)	· · · · · · · · · · · · · · · · · · ·	H. Derow/L.P. Lopez
Engineer S. Krikopulo	Approved W. Welt	U. A. Pineda

<u>OBJECTIVE</u>: Calculate the stresses as well as fatigue life due to internal pressure and thermal load.

ASSUMPTIONS:

Calculations were performed for two different loading conditions: I. (a) Uniform Temperature $T = 600^{\circ}F.$, (b) Internal Pressure = 470 psi; II. (a) Variable Temperature Distribution, (b) Internal Pressure - 470 psi.

REFERENCES (Analysis Methods):

Finite element computer program and S.S. Manson's universal slope equation.

RESULTS AND CONCLUSIONS:

Maximum stresses were found in the bimetallic tube in both conditions. These stresses are above the yield strength of the material for the corresponding temperatures. Plastic deformations are taking place. Calculated slow cycle fatigue life: 920 cycles.

RECOMMENDATIONS AND COMMENTS:



page____ of___42_pages date_____

SUBJECT_BRDC_BOILER #5

Str

ERDJET-GENERAL CORPORATION

CALIFORNIA

ZUSA.

WORK ORDER

MERCURY INLET

Geometry

Mercury met consists of three parts; 1 Header - circular plate - tautalim 2 Reducer - ellipsoidal shell - tautalum 3 Bimetallic tube - inner tube tautaling outer tube 316 stainless steel

see sketch #1 ou pg. 2

condition;

mercury meet will be checked in two different conditions: 1. Cand. I Mus form temperature T=600°F p=470 PSI 2. Courd, I Variable Temperature 10 = 470 PS/

STK. NO. D-1-103



AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA









AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA

PAGE_	4	OFPAGES
DATE		

BY

Material properties Tautalum

ToF	£106	x 10 = 6	Fry
250	27.1	3,56	13500
600	26.73	3,70	6800
900	26.35	3.84	6200
1200	25.95	3.98	5400

316 stainless Steel

TOF	E * 10 ⁶	× 10-6	F _{ty}
250	27.4	9.35	26500
400	2,6.7	9.65	24400
600	26.1	9.90	21800
1100	22.5	10.65	16700



AEROJET-GENERAL CORPORATION

AZUSA. CALIFORNIA

PAGE_	5	OF	PAGES
DATE_			·

WORK ORDER

SUBJECT

Collipsoidal shell

Equation used to calculate the shape of ellipsoidal shell: $\frac{1}{A^2} + \frac{1}{b^2} = 1$ apera

A = 3.575" 6 = 1.702"

 $4atio \frac{a}{b} = 2.1$

The above ratio Das selected on the basis of min membrane stress due to interuel prusure.

Coordinates and basic dimensions of the ellipsoidal shell are shown an FIG. 2 and 3 1995. 6 and 7

· · ·	00 00 00	
	1.4	
0 0 0	3.684 3.715	53 42 31 21 11 3.710 - 3.705
	3, 63, 574	3 5440 43 34 32 10 10
3,564	8 400 100 166	4 5541435 00 22 12 3.823
3.475 - 8	50 50 61 47 58 1	3.525
3,395- 3,3	7 5 5 67.51 62 59	110 45 21 21 -3.425:
53 42 31 -21 3 705 3,289	3.377 3.	413 1 134 23 13 3 2308
1 34 - A	50 68 3.3/6	1
54 43 32 19 1 58	3,229	Table 1 22 12 3 1 1 20 4
- 8.623 0 40 59 70/	3.114	
41 200 10 10 10 10 10 10 10 10 10 10 10 10 1	2.966	33 24 14 4 - 3,000
3.505	-2.900	
10 10 m	2.800	
56 26.37 32 37 30 3 425	0 70A	13 4 A L 23 113 14 A L 20 1 A L
45 16 58 101 -3.419 0 89 67/ 68 10		
-3.382 - 3.382	2.600	AND THE REAL PROPERTY AND
3,325 134 23		36-25-15-5-0 500
/	400	
71/72/11/5		
/95 / 97/ - N		·罗·尔·尔·24 - 14 1.5 1. 鸿语子 (5-1)
	V V. A start for the start of the start o	· · · · · · · · · · · · · · · · · · ·
	مان کے اس میں اور اور این اور این کا این کا این کا ایک میں اور ایک میں ایک میں میں میں میں میں میں ایک ایک میں ماہ کی ایک میں ایک میں ایک میں ایک میں میں میں میں میں میں میں میں میں میں	1/29 /29 /2 /2 /2 /2 /2 /2 /2 /2 /2 /2 /2 /2 /2
2.00		16 2.000
		2 /48 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 -
102 00 10 PAAA		
1 101 103/ 000	N	1 20 25 15 15 6
105		
109 106 2	and the second second second second second second second second second second second second second second secon	
197 880	الموجع المراجع المراجع المراجع المراجع المراجع المراجع المراجع المراجع المراجع المراجع المراجع المراجع المراجع والمراجع المراجع	49:
2 107 m - 1 400		
818 00 181		
	and the state of the state of the	312 + 26 16 16 V Tal 14 1 1 1
S (0) 15 15 10 1000	100	39 28 18 8 1.000
800 Mile 186		
STORE STORE	the second second second second second second second second second second second second second second second s	
	and the second se	32 27 17 -8
24 120 m 700		
100 Land		
180 18 15 100 Vol 97/ 94 93 1 7 515 500 1 militar	- 107 Jon	
928 - 107 105 1302 100 28 95 125 MOO 0 0 0 0	والترجيه بيني المتعريب المستجر والمتحرف والمتحاف والمتعادي والمتعاد والمتحاد والمتحاد والمتحاد والمتحاد والمتح	APP 建设
210 -142 199 136 132 130 128 127 120 2 2 6 6 6 9 2 6		
a wow or the second sec	the first for the start of the start of the start of the start of the start of the start of the start of the st	33 28 18 9
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1		
<u> </u>	·····	191 120 120 110 0 0
	·. FIG.2	· · · · · · · · · · · · · · · · · · ·





streld,

OF PAGE PAGES DATE

SUBJECT

ER_____

Temperature distribution in courd. I

Figures 4 and 5 show temperature dutribution - cu pp. 9 and 10.

Computer solution yields strenges and strains after six approximations. struses and strains are talulated on the following pages. The whole crassection is durided into -pour parts: 1 Headler Tautalum 2 Blans, shell 3 Meck 11 4 Bimetallic tube. Tautalum and 316 55 Enderetive stress is the total couloimed



0 F



- - -----

,

P.G. 10.





FIG. 6

G-71

16,12

É



FIG. 7

G-72

.....



AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA

page_ <u> 4</u> _	OFPAGES
-------------------	---------

SUBJECT

WORK ORDER_____

DATE_

Cond. I

QUADRILLE WORK SHEET

stresses and strains are talulated

BY

au pgs. 15-22

Fatigue life calculated au pgs. 23-26



AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA

PAGE______CF____PAGE DATE

WORK ORDER

SUBJECT.

MATER: TANTALUM Fry = 6800 PSI EFF. STRESS EFF. STRAIN RANGE TO F LOCATION EL, # 7.60× 10-5 2043 .2 600 - 3 : 9: 00x-10.75 2399 . 1.1×10-4 2994. 1.3×10-4 ·3570. 5. . 1.5x10-4 . 3892 ... 6 :1.5x10-4 3941 . 7. 1.5×10-4 3940 - 8 -1:5×10-4 · 9· 40.31 20/x10-5 566 1.0 K 8.4x10-5 ••• 2253 12: M A D M 8.3×10-5 13 22/8 3.8x10-5 - 1004. . ۰. 1.9 . 1715 6.4×10-5 ~ ZØ 3/63 1:2:70-4 21. 8.2 x 10 -5 2205 22 1 24 7.9x10-5 2:115 28 733 * • • . 2:7×10-5 1.7×10-4 .29 4455 1.4×10-4 30. 37:62 •• 1.3 x 10-4 . 3497 31 ž .3400 . 1.3×10-4 32. £ 3320 1.2×10-4 33. 600 E.

G-74

SUBJECT_____



AEROJET-GENERAL CORPORATION.

AZUSA, CALIFORNIA

#Y_

. .

_

·. PAGE__ OF _____PAGES DATE

WORK ORDER

MATE	R.: TANT	ALUM: +		800.P	5/
EL. #	EFF, STRESS PSI	EFF. STRAIN	RANGE	7.º F	40CATION
34	2159	8.1×10-5	··E,	600	
-35	2938	10/x10=4	E		• .
36	7075	5.0×10-4	P		
.37	4725	1.8×10-4	E	· · ·	
38	7028	4.8×10-4	<i>p.</i> .		
39	6880	3.3 + 10 -4	P		
40	2290	8.6x10-5	Ē.	· · · ·	-
41	3481	1.3x10-4	E		
42	6864	- 3.0×10-4	P	•.	
43	2146	8.0x10-5	·Ε		
44	4205	1.6x10-4	·E		I I
45	57.88	2.2x1074	E.		S
46.	2382	8.9×10-5	ł		
47	. 4840	1.8×10-4			D C
50	24.55	9.2×10-5			A
;51	3735	1.4×10-4			0
54	2503	9.4×10-5			R
55	. 3024.	1.1 x 104		. 4	7/
58.	2540	9.5x.10-5		-	
59	2698	: 1:0×10=4		÷	
62,	2792	1.0x10-4			· ·
63.	2,846	1.1×10-4	E	600	



AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA

PAGE__ Z OF PAGES DATE.

SUBJECT

WORK ORDER____

			/ / <u>y</u>	00007	
EL,#	EFF, STRASS PSI	EFF, STRAIN	RANGE	.7" 15	40CATION
66	2859	1.1×10-4	Ê	. 600-	
67	3021	1.01x10-4			
70	29.14	1.1. 10-4			
71	. 3363	1.3×10-4	· · ·	•••	
74 .	3114	1.2×10-4	•	·····	
75.	3745	1.4x10-4			
78.	3292	1.2×10-4			1.
				▶ 	1 1

$7/$ 3363 1.3×10^{-4} $7/$ $7/$ $31/4$ 1.2×10^{-4} $7/$ 75 3745 1.4×10^{-4} $7/$ 78 3292 1.2×10^{-4} $7/$ 79 4086 1.5×10^{-4} $7/$ 80 3346 1.3×10^{-4} $7/$ 80 3346 1.3×10^{-4} $7/$ 83 3934 1.5×10^{-4} $7/$ 80 3346 1.3×10^{-4} $7/$ 80 3652 1.4×10^{-4} $7/$ 86 3652 1.4×10^{-4} $7/$ 87 2893 1.5×10^{-4} $7/$ 88 3978 1.5×10^{-4} $7/$ 89 1.796 6.7×10^{-5} $7/$ 91 4166 1.6×10^{-4} $7/$ 91 4965 1.9×10^{-4} $7/$ 93 4965 1.9×10^{-4} $7/$ 94 $381/$ 1.4×10^{-4} $7/$ <	70	: 29.14	1.1x10-4	· , .		
74 $31/4$ $1 \cdot 2 \times 10^{-4}$ 1 75 3745 $1 \cdot 4 \times 10^{-4}$ 1 78 3292 $1 \cdot 2 \times 10^{-4}$ 1 79 4086 $1 \cdot 5 \times 10^{-4}$ 1 80 3346 $1 \cdot 5 \times 10^{-4}$ 1 80 3346 $1 \cdot 5 \times 10^{-4}$ 1 83 3934 $1 \cdot 5 \times 10^{-4}$ 1 84 3437 $1 \cdot 5 \times 10^{-4}$ 1 85 3248 $1 \cdot 2 \times 10^{-4}$ 1 85 3248 $1 \cdot 2 \times 10^{-4}$ 1 86 3652 $1 \cdot 4 \times 10^{-4}$ 10 87 2.893 $1 \cdot 1 \times 10^{-4}$ 10 88 3.978 $1 \cdot 5 \times 10^{-4}$ 10 90^{-1} 2.916 $1 \cdot 1 \times 10^{-4}$ 11 91 4166 $1 \cdot 6 \times 10^{-4}$ 11 92 4929 $1 \cdot 8 \times 10^{-4}$ 11 93 4965 $1 \cdot 9 \times 10^{-4}$ 11 94 38111 $1 \cdot 4 \times 10^{-4}$ 1	71	. 3363	. 1. 3×10-4		•••	
75 3745 1.4×10^{-4} 1.2×10^{-4} <th>74</th> <td>3114</td> <td>1.2×10-4</td> <td></td> <td></td> <td></td>	74	3114	1.2×10-4			
78 3292 1.2×10^{-4} 1.1 79 4086 1.5×10^{-4} 1.1 80 3346 1.3×10^{-4} 1.1 83 3934 1.5×10^{-4} 1.1 83 3934 1.5×10^{-4} 1.1 83 3934 1.5×10^{-4} 1.1 84 3437 1.3×10^{-4} 1.5 84 3437 1.5×10^{-4} 1.5 85 3248 1.2×10^{-4} 1.0 86 3652 1.4×10^{-4} 1.5 87 2.893 1.1×10^{-4} 1.5×10^{-5} 88 3.978 1.5×10^{-4} 1.1×10^{-4} 1.1×10^{-4} 90^{-1} 2.916 1.1×10^{-4} 1.1×10^{-4} 1.1×10^{-4} 1.1×10^{-4} 1.1×10^{-4} 1.1×10^{-4} 1.1×10^{-4} 1.1×10^{-4} 1.1×10^{-4} 1.1×10^{-4} 1.1×10^{-4} 1.1×10^{-4} 1.1×10^{-4} 1.1×10^{-4} 1.1×10^{-4} 1.1×10^{-4} 1.1×10^{-4} 1.1×10^{-4} <th< td=""><th>75.</th><td>3745</td><td>1.4×10-4</td><td></td><td></td><td></td></th<>	75.	3745	1.4×10-4			
79 4086 1.5×10^{-4} 11 80 3346 1.3×10^{-4} 11 83 3934 1.5×10^{-4} 11 83 3934 1.5×10^{-4} 11 84 3437 1.3×10^{-4} 11 85 3248 1.2×10^{-4} 11 86 3652 1.4×10^{-4} $1000000000000000000000000000000000000$	78.		1.2×10-4			
80 3346 1.3×10^{-4} 1.3×10^{-4} 83 3934 1.5×10^{-4} <	:79	4086	1.5x10-4			1
83 3934 1.5×10^{-4} HS 84 3437 1.3×10^{-4} TWO 1005 85 3248 1.2×10^{-4} TWO 1005 86 3652 1.4×10^{-4} TWO 1005 87 2.893 1.1×10^{-4} TWO 1005 88 3.978 1.5×10^{-4} TWO 1005 89 1.796 6.7×10^{-4} TWO 1005 90 2.916 1.1×10^{-4} TWO 1005 91 4166 1.6×10^{-4} TWO 1005 92 4929 1.8×10^{-4} TWO 1005 93 4965 1.9×10^{-4} TWO 1005 94 3811 1.4×10^{-4} TWO 1005 95 2985 1.1×10^{-4} TWO 1005	80	3346	- 1.3×10-4			W
84 3437 1.3×10^{-4} 7 85 3248 1.2×10^{-4} 7 86 3652 1.4×10^{-4} 7 86 3652 1.4×10^{-4} 7 87 2893 1.1×10^{-4} 7 87 2893 1.1×10^{-4} 7 88 3.978 1.5×10^{-4} 7 89 17.96 6.7×10^{-5} 7 90^{-1} 2.916 1.1×10^{-4} 7 91 4166 1.0×10^{-4} 7 92 4929 1.8×10^{-4} 7 93 4965 1.9×10^{-4} 7 94 3811 1.4×10^{-4} 7 95 2985 1.1×10^{-4} 5 600	83 -	3934.	1.5x10-4			2H
85 3248 1.2×10^{-4} 7 86 3652 1.4×10^{-4} 7 87 2.893 1.1×10^{-4} 7 87 2.893 1.1×10^{-4} 7 88 3.978 1.5×10^{-4} 7 89 1.796 6.7×10^{-5} 7 90 2.916 1.1×10^{-4} 7 91 4166 1.6×10^{-4} 7 92 4929 1.8×10^{-4} 7 93 4965 1.9×10^{-4} 7 94 3811 1.4×10^{-4} 7 95 2985 1.1×10^{-4} 7	84	3437	1.3x10-4		• F	
86 3652 1.4×10^{-4} SQ103 87 2.893 1.1×10^{-4} SQ178 88 3.978 1.57×10^{-4} SQ177 89 1796 6.7×10^{-4} SQ177 90 2.916 1.1×10^{-4} SQ177 91 4166 1.6×10^{-4} SQ177 92 4929 1.8×10^{-4} SQ177 93 4965 1.9×10^{-4} SQ177 94 3811 1.4×10^{-4} SQ177 95 2985 1.1×10^{-4} SQ177	85.	324.8	1.2×10-4			
87 2.893 1.1×10^{-4} 1050 88 3.978 1.5×10^{-4} 1050 89 17.96 6.7×10^{-5} 1170^{-4} 1770^{-5} 90^{-1} 2.916 1.1×10^{-4} 1770^{-4} 1770^{-4} 1170^{-4} 91 4166 1.6×10^{-4} 1170^{-4} 1170^{-4} 1170^{-4} 1170^{-4} 92 4929 1.8×10^{-4} 1000^{-4} 1000^{-4} 1100^{-4} 93 4965^{-5} 1.9×10^{-4} 1000^{-4} 1000^{-4} 1000^{-4} 94 3811 1.4×10^{-4} 1000^{-4} 1000^{-4} 1000^{-4} 1000^{-4} 1000^{-4} 95 2985^{-5} 1.1×10^{-4} 1000^{-	86	: 3652	1.4×10-4	· .		5.
88 3.978 $1.5x10^{-4}$ 90 89 17.96 $6.7x10^{-5}$ 0177 90 2.916 $1.1x10^{-4}$ 177 91 4166 $1.6x10^{-4}$ 1177 92 4929 $1.8x10^{-4}$ 1177 93 4965 $1.9x10^{-4}$ 1177 94 3811 $1.4x10^{-4}$ 1177 95 2985 $1.1x10^{-4}$ 1177	.87	2.893.	· . / x 10-4.	-		1/2
$\begin{array}{c ccccccccccccccccccccccccccccccccccc$	88.	3.978	"1. 5x 10-4			25
90 2916 1.1×10^{-4} 1 91 4166 1.6×10^{-4} 1 92 4929 1.8×10^{-4} 1 93 4965 1.9×10^{-4} 1 94 3811 1.4×10^{-4} E 600 95 2985 1.1×10^{-4} E 600	.89	. 17.96	6.7×10-5			Q
91 4166 1.6×10^{-4} 92 4929 1.8×10^{-4} 93 4965 1.9×10^{-4} 94 3811 1.4×10^{-4} 95 2985 1.1×10^{-4} E	.90 ·	- 2,916	1.1×104		-	
92 4929 1.8×10^{-4} 93 4965 1.9×10^{-4} 94 3811 1.4×10^{-4} 95 2985 1.1×10^{-4}	91	4166	1.6×10-4			U U
93 4965 1.9×10^{-4} 94 3811 1.4×10^{-4} 95 2985 1.1×10^{-4} E 600	92	4929	1.8×10-4].
94 3811 1.4×10 ⁻⁴ 95 2985 1.1×10 ⁻⁴ E 600	93	4965	1.9×10-4		· ·	
95 2985 1.1×10-4 E 600	94	3811	1.4×10-4			
	95	2985	1.1×10-4	E	600	



AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA

OF_____PAGES PAGE, . DATE. .

SUBJECT_

87.

.

.

- • •

WORK ORDER_

MAT	ER.: TANT	ALUM P	$\overline{F_{Y}} = 6$	800 Pi	51.
EL. #	EFF, STRESS PSI	EFF, STRAIN	RANGE	7.º F	40 CA 710 M
96.	15.95	6.0 x 10-5	E	600	
97	1897	· 7.1x10-5			
98	1616	6.0x10-5		•••	
99	13.00	4.9×10-50		· · · · · · · · · · · · · · · · · · ·	
1.00	1316	4.9×10-5		· · · · · · · · · · · · · · · · · · ·	H
101	1206	4.5x10+5		•	5
102	1360.	5.1 x 10-5			5,0
103	889	3.3×10,75			11-
104	.952	· 3. 6x10-5	•	•	775
105	1.180	4.4x10-5		· · · ·	4
106	899	3.4×10-5			
107	1005	3.8x.10-5			
108	1001	3.7x10-5		•	
109	1987	7.4x107.5			L
110.	2848	1.1×10-4			
114	38.57	1.4×10-4	E		
112	7504	3.5x10-4	P	•	V.
113	.7692	6. 3×10-4			>
114	82.72	1.4x.103		•••	
115	9219	2,3×10-3	P :	. 600	
]

_____G-77_`



AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA

BY.

Ø. OF____PAGES PAGE DATE

WORK ORDER .__

SUBJECT_

MATE	R.: TANT.	ALUM F	$\pi_{\gamma} = 6$	800 P	5/
EL, #	EFF, STRESS PSI	EFF, STRAIN	RANGE	705	40CATION
117	11020	4:2×10-3	P	600	
118	11286	- 4.5×10-3			
121	12429	5.7×10-3		· · · · · · · · · · · · · · · · · · ·	
122	13199	6.5.10-3		· .	
1.29	12756	6.1×10-3.		·	
130	14118	7.4×10-3			
134	12991.	6.3×10^{-3}			
135	14395	7.7×10+3			N N
141	13026	· 6.4x103		• • •	11
142	14479.	7.8×10-3		· · · .	L L
148	12998	6.4×10-3			
14.9.	14463 .	7.8x.10-3		- 1	Ú
152	12954	6.3×10-3	•		1.7
153	14414	7.7×10-3	· .	· · · · · · · · · · · · · · · · · · ·	76
156	12902	6.3x10"3	-		K
157	14356	7.7×10=3			N.
160	12861	6.2×10-3			2
161.	. 14306.	7.6×10=3	; 		n l
1.64	12853	6.2×10=3			
165	14289	7.6×10-3	· · ·		
168	12867	6.2 + 10-3	.		
169.	14:300	7.6×10-3	P	600	

AEROJET ENDEDAN DE GENERAL

AEROJET-GENERAL CORPORATION. AZUSA, CALIFORNIA

-

8Y_____

QUADRILLE WORK SHEET

PAGE 20 OF PAGES

SUBJECT___

.

DATE_ , WORK ORDER

MATE	R.: TANT	ALUM	Fy = 6	800 P	5/
EL; #	EFF, STRESS PSI	EPF. STRAIN	RANGE	.T:0 F	LOCATION
172	1.2880	6.2 × 10-3	P	600	
173:	14.299	-7.6x.10-3	· . ·		- 1. 1
176	12843	6,2×10-3		· .:-	BA
1.77	- 14199.	7.5x10-3			101
1.80	12645	6.0x10-3.			
181	13827	7.1×10-3			-0
. 184.	12:306	5.6×10-3			776
185	: 12763	6.0×10-3			к Х
188	12586	. 5.7×10-3	· · · ·	· · ·	ME
189	11.337	4.5 10-3	P.	600	A A
	•				
	······································		· · · · · · · · · · · · · · · · · · ·	· · ·	
		· · ·	···		- ·
r	•		······		
	· · · · ·	· · · · · · · · · · · · · · · · · · ·	-	· · ·	-
	, ,		··		· ·
in the state				· ·	
	······································				
	· · ·			· · · · · · · · · · · · · · · · · · ·	
	n				
				· · · · · · · · · · · · · · · · · · ·	-
وندارا المتحد المتحديثة كيزيدي	والمرابية الأشارك مباغات المبطل معراف الشياط فشياط فاليعد معافي ويوجونها	~ ~ ~			• • • • • • • • • •

G-79

STK. NO. D-1-103



AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA

PAGE_____PAGES DATE

SUBJECT_____

۰.

BY _____

WORK ORDER_____

MATE	R.: 31655	Fity =	2180	10 DS1	÷
EL. #	EFF, STRESS PSI	EFF. STRAIN	RANGE	TOF	LOCATION
116	20883	9.6x.10-4	E	-6.0"0 -	
119	6215	2.4×10-4			
120	13644	5.2×10-4	,	*•	
124	5079	1.9×10-4			
1:25	3314	1.3x107.4			
126	2786	1.1x10-4	•		
127	6567	2.5x10.4			
- 128	11872	4.5x10-4	-		M.
131	: 4205	1.6×1074			5
132	. 6172 '	2.4×10-4	· ·		
. 133	95.46	3.7×10-4			/ •
13.6	991	· 3.8x.10-5			$\frac{1}{2}$
13.7.	- 1.261.	4.8×10-5	·		
1.38	3.372	1.3×10.74		, * :	D 1
139	6009	2.3×10+4			K
140.	8624	3.3×10-4	-		N
143	1262	4.8x10-5	· · ·		¥/
:144	1713	6.6×10-5		<i>.</i>	P
145	4100	1.6×10-4.	, ,		
146	7199	2.8,10-4		, , , , , , , , , , , , , , , , , , ,	
147	9318	3.6×10-4			
150	9516	3.6×10-4	E	600	

STK. NO. D-1-103



AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNÍÅ

BY_

PAGE 22 OF PAGES ۰. . DATE

SUBJECT____

.

WORK ORDER___

MATE	R.: 3/655	$F_{fy} = 2.18$	200 PS	/	-
EL. #	EFF, STRESS PSI	EPF, STRAIN	RANGE	705	40CATION
151	10536	4.0×10+4	E	600	
154	10099	3.9×10-4			
155	- 11696	4.5x10-4			· ·
162	.9899	3.8×10.74		• • •	
1.63	12081:	4. 6x10.4		· · · ·	· .
170	9054	3.5×10-4			
171.	11123	4.3×10-4	·		-
174	. 8037	3.1×1074	· ·		. M
175.	10911	4.2×10-4		•	
182.	6705	2.6×10-4		-	
183	13272	5.1×10-4	ŀ		
186.	13666	5.2×10-4		-	
187	18514	7.1x10-4	.E,	600] · Ų
		· · · · · ·	-	} 	
					AL
· · · · ·	•		· ·	· .	
					I U L
· · ·	· · · · · · · · · · · · · · · · · · ·				
	· · ·	······		· · · · · · · · · · · · · · · · · · ·	D D
				· .	-
				-	1
	•		<u> </u>		

-G**-**81



AEROJET-GENERAL CORPORAT

AZUSA, CALIFORNIA

SUBJECT

PAGE	23_	OF
DATE	-	

WORK ORDER

Fatigue life Max loaded elements will be checked for fatgue life. Methed of attack : S.S. Mausey's universal slope equation for unetraxial steam

Max loaded elements are located in the -bimetallic tube.

Tautalum in the plastic large

element # 142

316 SS In the ellastic ruge



AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA

PAGE_	24	OF.	PAGES
DATE			

SUBJECT

WORK ORDER

Fatique life of the element # 142

Material: Tautalum Temperature: 600° F Material properties at 600° F E = 26.73×10° Fty = 24000 PSI Fty = 24000 PSI RA = . 985 reduction in area effective straim: E = . 00781 "/" Ductility: $D = lm \frac{100}{100 - DA} = 4.2$ D"= 2.366 Vy = Fty = 24000 PS/ N = - mumber of cyclus 48, = E EFF = . 00781 Modified unversal slope equation: AET= 3.03 UH NE -12+ D. NE -. 6


ΔE= 3.03 24000 10-6 N= 12 + 2.366 N= 02

 $00781 = .00272 N_{\mu}^{-.12} + 2.366 N_{\mu}^{-.6}$

solution of the above equation is shown oll pg. 26 $N_{F} = 16500$

"In order to account for one using "10% rule" are reduce the number of cycles to 1650

Contracted number of cycles for nox loaded Tautalum element: 1650

The cycling life of 316 ss is in the range above 100000 cyclig.

SUBJECT_

QUADRILLE WORK SHEET



AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA

•		PAGE 20 OF	PA
		DATE	
		WARK OPDER	
	BY	WORK ORDER	
	ور در در در در باین استان میاند با باین بین بین بین سی سی میشون میداند این این میدون استان در استان می موان و م	u arthuantist australia	
	· ·	•	
	, , , , , , , , , , , , , , , , , , , ,		
7 7			
eu 			
~ ~	ma, sign_on: 7974, krikopulo		
	ACKNOWLEDGED AT 11:01 10-14-70		
-	$\frac{1}{1} = 2 \cdot 72 - 3 \star \star \star \star (-, 12) + 2 \cdot 366 \star \star \star \star (-, 6)$		
	12 x = x + 500.		
	x=14000.		
	X = 1.399999E + 04	·	
	$\frac{3}{2}$ e:(2,1,4)*15		
-	$\underline{4} \text{ print } \mathbf{x}, \mathbf{a}$		
~	ACKNOW EDGED		
•	$X = 1.449999E+04$ $\Lambda = 8.398320E-03$	-	
	X = -1.500000E + 04 $A = -8.243062E - 03$		
,	X = 1.550000E+0h A = 8.095815E-03		
	$X = 1.60000F + 04 \qquad A = 7.955938E - 03$		
٣	$\frac{X - y}{X} = \frac{3.64999992 + 04}{6.099992 + 04} A = \frac{7.622828282 - 05}{6.09976 - 03}$		
	X = 1.750000E+04 A = 7.574919E-03		
~ -	$X = 1.300000E \pm 04$ $A = 7.459230E - 03$	· · · · · · · · · · · · · · · · · · ·	
	X = 1.350000E + 04 A = 7.348541E - 03		
-	$X = 1.399999E + 04 \qquad A = 7.242497E - 03$		
و.	X = 1.94999922404 $A = 7.14030924095Y = 2.0000002404$ $A = 7.0031502405$		
-	X = 2.050000E+04 A = 6.949316E-03		
_ م	X = 2.100000E + 04 A = 6.859034E-03		
	$X = 2.149999E+04$ $\Lambda = 6.772104E-03$		
-	EXECUTION COMPLETED		1
۰ ^و ر	- sign off.		
-	SIGNED OFF AT 11:05 10-14-70		
-			
·** .			
-		<u></u>	
.	······································		
	•		



AEROJET-GENERAL CORPORATION

AZUSA. CALIFORNIA

page <u>27</u>	of	PAGES
DATE		

SUBJECT

BY_____

WORK ORDER.

Condition II,

QUADRILLE WORK SHEET

stresses and strains are takenlated an

per. 28-35

Fatigue life is calculated an 1995, 36-42

SUBJECT____

QUADRILLE WORK SHEET

2



AEROJET-GENERAL CORPORATION

AZUSA. CALIFORNIA

PAGE 28 OF PAGES DATE

EL: #	EFF. STRASS PSI	EFF, STRAIN	RANGE	T. F.	40CA
2	.5.533	. 2. 6. 10 -4	P.	1167	
3***	-54.51	2.1.x.10-4	»:р:-	1183	•
4.	:5.08.9	2,0*10-4	Ē	1.1.95	
5	5371	2:01x10-4	Ē		
:6	5458	-2.2×10-4	P	1196	
7	5166	2.0x10-4	.E	1197.	
8	4796	1.8x10-4	E.	1197.	
2 -	4827	1.9×10-4	E	1197	
- 1.0 -	5559	· 2.3×10-4	. p .	1141	
12	3412	1.3×10-4	E	.11:6:8	j.
13	2205	8.5.1075	E	11.86	· .
.19	5738	3.0x10-4	-P	1109	
20	5803.	3.6×10-4	: p :	1:1.0.8] : (] :
21	3945	1.5×10-4	E	1118] : [
	3202	1.2.10-4	Ë.	1150	
24	5531	2.5×10-4	·:P	1.174.] · 、
28	3247	1.3×10-4	E.	1186	
:29.	5910	6.2×10-4	P.	1172	
30 :	5825	4.9×10-4		11:78.	
31	. 5.7.9.9	4.1×10-4		1180	
32	5.757.	3.6×10-4		11.82	
33	5732 :	3.3×10-4	P	1184	



_____ BY___

AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA

PAGE 27 OF	PAGES
DATE	
WORK ORDER	<u> </u>

SUBJECT___

MATE	R.: TANT	ALUM			Se
EL. #.	EFF, STRESS PSI	EFF, STRAIN	RANGE	7:05	LOCATION
34	5951	4.5 , 10 - 4	· .P :	1.081	
35	5403	2.1×10-4		10.75	
36.	5700	3.4×104		1071	:
37	5602	2.1×10-4		1076	•
.38	660.6	101×10-3		1090	
39 -	6350	8.6×10-4		1105	
- 40	5909	:4:1x10=#	P:	1055	12
41 1	5159	2.0×10-4	E.	1051	
42	5702	2.4×10+4	P.	:104.7	. 7
43.	: 5663	2:2×10-4	P:	1024	· 11.
44	4995	1.9×10-4	E.	1028	C /
.45 .	3.292	1.3×10-4		10.14	
46	4039	10:5×10-4		990	
47	2503	9.5x 1075	· · .	980	A.
50.	2616	9.9×10-5		875	0
51	4365	1. 7x 10 -4.		865	50.
54	2,544	9.6x10-5	Έ.	733	
.55	6624	3.1×10-4	· P.	710	7
58	5829	2.2×10-4	E.	654	W W
59.	3054	lilix 10-4	E	646.	
62	68.81	3.2×10-4	P.	6.19	•
63	1536	5.8×10-5	· E	615	
		G-88		•	97



......

AEROJET-GENEBAL CORPORATION

AZUSA, CALIFORNIA

PAGE_	30	_ OF	 _PAGES
DATE			

SUBJECT_

.

WORK ORDER

MATE	R.: TANTA	LUM	· · · · · · · · · · · · · · · · · · ·		
EL, #	EFF. STRESS PSI	EFF. STRAIN	RANGE	TOF	40°CATION
6.6	7.5.43	5.2×10-4	Р. <u>:</u>	5.83	
67	3538	1:3×10-4	E	565	,
70	8120	4.0×10+4	p.	539	
. 71 .	2480	9.3×10-5	Ē	546	
74.	6.8.53	2.6×10-4		533	
7.5		4.4×10-5		598	
78	5586	2.1.10-4		522	
79	1033	3.9×10-5		524	
80	5180	1.9×10-4		514	Ĵ.
83	1791	6.7x10=5		515	. 2
84	45.52	1.7.10-4		505	
	1656	6.2 + 10-5		.5.18	Ţ.
.86	4100	1.5×10 74		506	
87	1475	5.5×10-5		521	.0.
.88	3883	1.4×10-4	•••	506	5
82	. 17.06	6.4×10-5		526	1.1
90	1867	7.0×10 75		520	. 7
91.	3842	1.4×10-4		.510	
92	4206	1.6-10-4	· · · · ·	510	
.93.	: 4275 :::	1:6×10-4		511	
94.	3023	1.1.10-4		516	
.95	25.63	9.6×10-5	: E :	523	Ţ., '

. G-89



_____ BY____

-

AEROJET-GENERAL CORPORATION

AZUSA. CALIFORNIA

OF____PAGES PAGE DATE:

SUBJECT___

WORK ORDER_

MATER: TANTALUM					
EL: #	EFF, STRESS PSI	EFF. STRAIN	RANGE	TOF	LOCATION
96	1055	3.9 × 10-5	Ė.	531	
. 97.	10.84	4.0×10-5	·	533	-
. 98 .	1.044	3.9×10-5	; ., .	536	1
99 .	1449	5.4×10.75	_ ÷	543	
. 100	894	3.3×10-5	, ,	539	X.
. 101 .	1356	5.1×10-5		547	3
102	1499	5.6×10-5		5.47	5
103:	1317	4.9×10-5		558	
10:4	288	- 1.1x10-5		563	77
105	1947	7.3×10-5		551	·
106		8.4.10-6		571	
. 10.7.	. 1902	7.1x10-5		5.60	
:108.	. 801	3.0×10.5	••	584	
:109	20.79	7.8×10-5		574	
110	2755	1.0×10-4	. : '	601	
11.1	3.876	1.4x10-4		591] <u> </u>
.112	6240	2:3×10-4	- <i>E</i> , :	617	
113	77.64	8.1×10-4	P	607	
114	8278	1.5×10-3	· . P	623	
115	9869	2:9×10-3	· P	613	
•	· · · · ·				
	4			1.1	-

SUBJECT____

QUADRILLE WORK SHEET

٠



.

AEROJET-GENERAL CORPORATION

AZUSA. CALIFORNIA

Ē.₽Υ,

PAGE_	32_ or_	PAGES
DATE_		

_____ WORK ORDER_____

MATE	R.: TANTA	ILUM.	·····		
EL. #	EFF, STRÆSS PSI	EPF, STRAIN	RANGE	7.0 #	40CA710H
11.7	12/01	5.3,10-3	P	621.	
118	12955	6.2×10-3		610	
121	14627	7.9x10-3		617	
122	15.993	9.2×10-3		599	
.1.29	15575	8.7×10-3		593	
130	17897	101x.10-2.		578]]17
134	: 16410	9.0 + 10-3		563	a l
135	18571	1.1×10-2		552	11
141	16386	- 8-4+10-3	• •	534	i.
142	18575	1.0×10+2		521	· · ·
148	.16191	7.3×10-3		485	1
149	-18308	9.2×10-3		474	
152	16056	6.2×10-3		435	
.1.53	17919	7.8x.10-3		424	I,
156	15702	5.1×10-3		3.95	
157	17360	6.6×10-3	· · · ·	385	U
160	15.336	4.0×10-3	•	355	N/
161	. 16780 .	5.2×10-3		345	p. M
164	15044	3.1×10-2	•	.325	
165	16218	4.1×10-3		315	
168	14820	2.5×10-3		305	
169	15766	3.3×10-3	P	295	

G-91

SUBJECT____

QUÁDRILLE WORK SHEET



______BY___

AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA

3. OF PAGES PAGE 3 . DATE WORK ORDER_

MATER .: TANTALUM						
EL, #	EFF, STRESS FSI	EFF. STRAIN	RANGE	7.0 5	40CATION	
172	14718	2.1×10-3	::: <i>P</i>	285		
173	15505	2.7x10-3	· ·	2.75	717	
176	14698	1.7×10-2		265	0	
177	15376	2.2×10-3	, , , , , , , , , , , , , , , , , , ,	254		
180	14674	1.3×10-3		246	1~	
181	15280	1.6×10-3		231	\mathcal{Q}^{+}	
184	14645	8.7. 10-4		223	イン	
185	15124	1.0x10-3	· P :	206	61	
	and a second second second second second second second second second second second second second second second				ME	
					, m	
				* *	Se 1 .	
			· · · ·			
					• -	
			· · · ·			
					s.	
· · ·		· · · ·		· · ·	-	
.:						
					·	
	· · · · ·					
•	· · · · · · · · · · · · · · · · · · ·		-			
					:	

_G-92

•



AEROJET-GENERAL CORPORATION.

AZUSA, CALIFORNIA

PAGE 34 OF PAGES . . . JATE.

SUBJECT____

		فتستقا المترجي ويهواب البسباني ويغبب	the second second second second second second second second second second second second second second second s
	-	•	
		•	
	· · WORK	ORDER	,
· · · · · · · · · · · · · · · · · · ·	 		

MATE	R.: 3/6 53				
EL:#	EFF, STRESS PSI	EPF, STRAIN	RANGE	T°F.	40CATION
116:	20358	1.4×10.73	Ē	6.84	
119	17501	7.0×10-4		740	
120	14352	5.6×10=4		680	
124	19061	9.9×10-4	- 1 - 1 	906	
125	17344	7.1.810-4		848	
12.6	13796	. 5. 6x 10-4.		790	
1.27	19978	9.1×10-4	· · · · ·	735	.収
128	22257	1.5×10-4		655	. Q.
131	19685	7.9×10-4		7.65	2
132	2.0481	8.6.10-4	E	720	·
133	. 23037	1.7× 10.3	Þ.	636	· '.
13.6	19231	9.9×1074	Ë	8.89	
137	: 13969	5.7×10-4	Í	824	1
138-	11.093	4.4x10-4		731	5
139	21443	9.6×10-4	· .	6.58	
140:	23.67.4	1.8×10-3	E	591.	W.
143	19827	1.2×10-3	P	870	X
144	20175	1.0 × 10-3	P	801	Ìè
145	19103	7.5×10-4	E	694	
146:	2.0848	8.4×10-4	E.	.588	
147	. 23990	1:4×10-4.	P	:520	
.148	16191	7.3×10-3	E	4.85] .

SUBJECT

QUADRILLE WORK SHEET



AEROJET-GENERAL CORPORATION

AZUSA. CALIFORNIA

BY_

OF____PAGES PAGE DATE **1** - 1 - WORK ORDER.

MATE	ER. 1 316 S	S			
EL; #	EFF. STRESS FSI	EFF, STRAIN	RANGE	TOF	LOCATION
151	16.59.0	6. 3×10-4	Ē	4.68	
154	21599	1.0×10-3		4.66	
155	4495	1.7.10-4		421	10
162	17700	6.6×10+4		355	: Q
163	10367	3.8×10-4		340	
170	13001	4.8×10-4		305	
171	. 1.119.7	H.1x10=4	· · ·	2.95	
174	11035	4.0×10-4		280	
17.5	11250	4.1x10-4		273	N N
182	8457	3.1×10-4		238	K
183	12668	4.6×10+4		233	U.
186	13210	4.8×10-4		2.08	
18.7.	17017	6.2×10-4	Ę	200	
					•
		29			
			· •		
			······································		
· · ·	· · · · ·		· · · ·		
ļ		· · · · · · · · ·		· · · · · ·	
					-

_**G-9**4



AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA

36	
PAGE	OFPAGES

SUBJECT.

WORK ORDER_____

DATE

Fatigue life

Max loaded elements will be chieved for fatigue life. Method of attack : 5.5. Mausau's unversal slope equation for multraxial straim.

BY

Max loaded elements are located in the bimetallic tube.

Tautalum

element # 142

in the plastic range

316 55

element # 133

in the plastic range



AEROJET-GENERAL CORPORATION

AZUSA. CALIFORNIA

PAGE_	<u>37</u> of	PAGES
DATE_		

SUBJECT

Fatigue life of the eleureut # 142 Material: Tautalum Temperature: 521°F $\frac{1}{E} = 26.85 \times 10^{\circ} \qquad F_{H_{H}} = 25000 \text{ PSI}$ reduction in area RA = .98 effective straim: Esr = . 0103 "/" Ductility: $D = l_{H} \frac{100}{100 - DA} = 3.9$ D.6 = 2.259 V = F+ = 25000 PSI Nr - number of cycles 18, = E FFF =. 0103 Modified universal slope equation: $\Delta \mathcal{E}_{\mu} = 3.03 \frac{V_{\mu}}{F} N_{\mu}^{-.12} + D^{.6} N_{\mu}^{-.6}$

SUBJECT.

QUADRILLE WORK SHEET



AEROJET-GENERAL CORPORATION

AZUSA. CALIFORNIA

PAGE_	38	OF	<u></u>	PAGES
DATE_			····,·	
WORK	ORDER			

 $\Delta \mathcal{E}_{\tau} = 3.03 \frac{25000}{26.85^{2}} 10^{-6} N_{F}^{-.12} + 2.259 N_{F}^{-.6}$ pt-

.0103 = .00282 $N_{F}^{-.12} + 2.259 N_{F}^{-.6}$ Solution of the above equation is shown on pg. 39 $N_{F} = 9200$ Moder to account day proposition

In order to account for creep using "10% rule" we reduce the number of cycles to 920

Costimated number of cycles for max -Coaded Tautalum element: 920



AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA

r	BY WORK ORDER	
•	,	
	ی سے سو میں استان سے میں میں استان ہے۔ اس میں استان میں ایک ایک ایک ایک ایک ایک ایک ایک ایک ایک	
V		
	· · · ·	
\square		·
		•
<u>``</u>		
	ma, sign on 7474 krikopulo	
ļ		
<u>`</u>		
·	·	
`		
	ma, sign on: 7974, krikopulo	
	ACKN01/LEDGED AT 15:10 10-14-70	
~	$\frac{1}{1} = 2 \frac{22}{20} - \frac{3}{20} \frac{1}{12} + 2 \frac{250}{10} \frac{1}{10} + \frac{1}{10} \frac{1}{10} + \frac{1}{10} 1$	
••••••	<u>2 x=x+300</u>	
	= x = 8000.	
, 	X = 8.00000E+03	
, ,	$2 = 0:(2,1,4) \times 15$	
5	p:3	
	ACKHOULEDGED	
ž	X = 8.300000E + 03 A = 1.101192E - 02	
	X = 8.899999E + 03 A = 1.059140E - 02	
J	$X = 9.199999E + 03 \qquad A = 1.039779E - 02$	
	$X = 9.500000E+03$ $\Lambda = 1.021388E-02$	٠
• • •	$X = 9.800000E+03 \qquad A = 1.003896E-02$	
-	X = 1.010000E+04 A = 9.872384E+03 $X = 1.039999E+04 A = 0.713485E+03$	
	X = 1.069999E+04 A = 9.561706E-03	
·-/	X = 1.100000E+04 A =9.416554E-03	
	X = 1.130000E+04 A = $9.277556E-03$	
	$\frac{1}{2} = \frac{1}{2} \frac{1591991}{1000} + \frac{1}{1000}	
·	X = 1.139999E+04 $X = 9.0104701(-0.5)X = 1.220000E+01$ $A = 9.803560E=03$	
-	-X = 1.250000E+04 A = $8.775416E-03$	
	EXECUTION COMPLETED	•
<u>نب</u>	$ \cdot$ \cdot \cdot \cdot \cdot	
¥		
نہ ۔۔۔۔	$\frac{\text{sign off}}{\text{sign off}} = \frac{1}{10} = \frac$	



AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA

PAGE_	40	OF_	 P	AGES
DATE_			 	

BUBJECT

WORK ORDER

Fatience life of the element # 133

Materiale: 31655 Temperature: 636° F. Material properties at 640°F E = 25.9 × 1000 Fty = 70000 PSI reduction in area RA=.59 iffective strain: EEFF = . 00174 "/" Ductility : $D = lin \frac{100}{100 - RA} = .892$ D.6=.933 V = Ff = 70000 PS/ NF - number of cycles $\Delta \mathcal{E}_{r} = \mathcal{E}_{EFF} = .00174$ Modified universal slope equation: $4E_{F} = 3.03 \frac{U_{H}}{E} N_{F}^{-.12} + D^{.6} N_{F}^{-.12}$

QUADRILLE	WORK	SHEET	AEHOJET	AERDIET-GENERAL CORPORATION AZUSA, CALIFORNIA	PAGEOFPAGES
SUBJECT			<u> </u>	BY	WORK ORDER
4	E ₇ = 3	.03 -	70000 10-	6N= .12 + . 933NF	6 OE

.00174 = .0082 Nr + . 933 Nr . 6 Solution of the above equation is shown ou pg. 42 N= = 1000000

"norder to account for creep using "10% rule" we reduce the number of cycles to 100000

Coaded 316 55 clement 7 100000



AEROJET-GENERAL CORPORATION

AZUSA. CALIFORNIA

PAGE_42	OF.	PAGES
---------	-----	-------

	DATE
	WORK ORDER
SUBJECT	BT BT HORR ORDER
	م الا ما ماجوام المان ماند. المان المان المان المان المان المان المان المان المان المان المان المان الم
بر بر بر	· · · ·
· -	
г n —	
أبيعا	· · · · · · · · · · · · · · · · · · ·
U	ma, sign on: 7974, krikopulo
	ACKNOWLEDGED AT 9:23 10-15-70
\sim	$\frac{1}{2} = \frac{3 + 2}{2} = 3 $
, 	x = 700000
×.' _	$\bar{X} = 7.00000E + 05$
	<u>3</u> e:(2,1,4)*20
·E	<u>4 print x,a</u>
\sim	
	X = 7.149999E + 05 A = 1.913276E - 03
·	$X = 7.300000E \pm 05$ A = 1.905680E - 03
	X = 7.449999E+05 $A = 1.898291E-03$
	X = 7.600000E+05 A = 1.891099E-03
<u> </u>	X = 7.00000E+05 $A = 1.0000E+05X = 7.00000E+05$ $A = 1.0770E=03$
	X = 8.050000E+05 A = 1.370617E-03
- 2 - 2	X = 8.199999E+05 A = 1.864129E-03
i ($X = 8.350000E \pm 05$ A = $1.857795E - 03$
a	X = 8.500000E+05 A = 1.851612E-03
e v	X = 8.649999E + 05 $A = 1.845574E - 03$
-	X = 8.30000000000 A = 1.33007000000000000000000000000000000000
ι.,	X = 9.100000E+05 $A = 1.828265E-03$
	X = 0.250000E+05 A = 1.822746E-03
-	$X = 9.399999E+05$ $\Lambda = 1.317345E-03$
\sim	$X_{\rm c} = 0.550000E+05$ A = 1.812059E-03
	$\frac{\chi = 9.699999E+05}{\chi = 0.800800E+05} = 1.800800E+03$
ł	X = 9.8500000000000 M = 1.8010000000000000000000000000000000000
· -	EXECUTION COMPLETED
•	
\smile	sign off:
	<u>SIGNED OFF AT 9:27 10-15-79</u>
	-
•	
	· · · · · · · · · · · · · · · · · · ·
-	·
	· .
<u> </u>	



SNAP-8

1475-02-0402 EDF SERIAL NO. D7993-70-0485

ENGINEERING DESIGN FILE

SUBJECT:

W. O.

Conceptual Boiler Mounting Configuration, PCS, SNAP-8

ABSTRACT:

A conceptual boiler mounting configuration was determined by means of the MEC-21 piping flexibility analysis program. The PCS S-shaped boiler configuration is defined by Drawing AGC-1268489 N/C.

Various mounting methods were analyzed considering allowable boiler attachment points and PCS frame mounting locations. The objective of the mounting study was to obtain a configuration that distributed the boiler weight as evenly as possible on the supports, provided low thermal loads on the supports, and produced boiler shell stresses below the maximum allowable stress during operation. The maximum operating temperature was considered to be 1300° F and the boiler shell is constructed from 316 stainless steel. A maximum allowable thermal stress of 5,140 psi was calculated from data contained in AGC-10650, H-100, and the nuclear power piping code - USAS B31.7. The moment of inertia for the boiler (outer shell, static NaK oval tubes, and inner liner) was calculated to be 30.436 in.⁴. For the MEC-21 program, a 7.5 in. 0.D. x 0.188 in. wall pipe with a moment of inertia of 28.5 in.⁴ was used. The wet weight of the boiler including insulation was calculated to be 1109.5 lb. The mounting configuration that satisfied the requirements is shown in Figure 1 and described as follows:

The boiler is anchored at Point A to eliminate load interactions between the TAA Hg inlet and the boiler through the vapor line due to boiler thermal movement. The boiler is cold sprung at Point D, 0.5 in. in the -X direction and -1.0 in. in the -Y direction to reduce operating thermal stresses.

Individual support description:

- (a) Support A is fixed in all directions.
- (b) Support B is a saddle-type support which allows the boiler to move in the +Y direction, +X direction, and rotate about the X and Z axes.
- (c) Support C is a spring support providing an initial force of 500 lb on the boiler in the +Y direction and having a spring rate of 300 lb/in. The

DISTRIBUTION: B Breindel, ES Chalpin, H Derow, JN Hodgson, AH Kreeger, GL Lombard, LP Lopez, RW Marshall, UA Pineda, JR Pope, JC Shen, RL Tome', DR Ward, W Weleff BR Fanton

KEY WORDS: MEC-21 piping flexibility analysis program; boiler, PCS; boiler supports, PCS; cold springing, stress analysis, PCS.

AUTHOR DATE	REVIEWED	DATE	APPROVED K / DATE
R.L. Tome K.J. Jone 9/3/70			B.Breindel

Engine	ering Design File		Engrg. File: PCS-G-S-403.0
Dato:	26 August 1970	-21	EDF Ser. No.: D7993-70-0485

support allows the boller to move in the $\pm X$ direction, $\pm X$ direction, and rotate about the Z axis.

(d) Support D allows the boiler to rotate about the Z axis.



APPENDIX H

.

FAILURE MODES AND EFFECTS ANALYSIS

POWER SYTE DIVISION FAILURE MODES AND EFFECTS ANALYSIS

PART NO. <u>1268600</u> PART NAME <u>BRDC Boiler #5</u> LOOP ITEM NO			DESCRIPTION OF FUNCTION: TRANSMIT HEAT FROM NAK LOOP TO Hg RANKINE LOOP OF SNAP-8 PCS				PAGE 1 OF <u>3</u> DATE 21 Sept. 1970 INITIAL REVISION X					
	1	2	3 EFFECT ON	SNAP-8	4	PROBABIL 5	ITY OF OCCURRENCE* CRITICALITY OF FAILURE**					
	FAILURE, MODE	FAILURE CAUSE	COMPONENT	SYSTEM	····		REMARKS AND RECOMMENDATIONS					
	A. Boiler shell or tee failure	Cracks due to thermal stress or interface loads.	repair or replacement required	Shutdown; can be significan hazard	High t	Critical	Thorough thermal analysis indicates that use of honeycomb in end housings and other design changes will significantly relieve thermal gradients.					
,		Material, fabrication, or weld defect.	same as above	same as above	Low	Critical	Thorough inspection and non- destructive testing of parts and assemblies, use of adequate cleaning procedures					
н-2	B. Boiler center tube failure	same as (A.)	repair or replace at opportune time	could cause replacement of vacuum with flowing NaK inventory	Low .	Major Critica	Same as (A)					
	C. Static NaK tube failu	re thermal stress; interface loads	repair or replace at opportune time	no effect if n other failure	o Mod.	Minor	Changes in end housing shoul reduce probability of recurrence.					
	•	material fabrication, or weld defect	same as above	same as above	Low	Minor	Thorough inspection and non- destructive testing of part and ass'ys.					
	<pre>* HIGH - Two or more occurrences of failure mode in</pre>											
	MAJOR - A failure or MINOR - Failures othe of the system	performance degradation r than critical or major , to perform its primary l	n excess of to r which have no / function.	significant eff	ect on th	ne ability						

POWER SYTEM DIVISION FAILURE MODES AND EFFECTS ANALYSIS

PART NO. 1268600 PAGE 2 OF 3 DESCRIPTION OF FUNCTION: PART NAME BRDC Boiler #5 DATE 21 Sept. 1970 ITEM NO. TOOP INITIAL [7] REVISION X PROBABILITY OF OCCURRENCE* 2 l EFFECT ON SNAP-8 Ъ CRITICALITY OF FAILURE** 5 6 FAILURE MODE FAILURE CAUSE COMPONENT SYSTEM REMARKS AND RECOMMENDATIONS Repair or May adversely Low Minor/ Adequate design inspection. D. Static NaK leak at end Thermal stress: interaffect heat and test should reduce face loads: material replace major housing fab., or weld defect. transfer by probability of occurrence. causing gradients. Thermal stress; faulty Repair or Minor/ May adversely LOW Adequate design and inspect-E. Leak in vacuum ion should reduce probabil. chamber in end housmaterial or fab. replace affect heat Major ity of occurrence. transfer by ing. causing thermal grad ients Critical Adequate design should keep F. Tantalum (Hg) tube Thermal stress or Replacement shutdown Low probability low. interface loads required failure Same as above Critical Adequate inspection and non-Material, fabrication, Same as above Low or weld defect destructive tests should keep probability low. Design or fabrication Repair Poor performance Mod. Major Adequate design and fab. G. Excessive Hg side or shutdown should reduce probability Pressure drop deficiency Originally clean loop will Contamination (mass Clean or Poor performance Low Major transfer deposits replace or shutdown prevent occurrence or dirty loop) * HIGH - Two or more occurrences of failure mode in .testing. MODerate - One recorded occurrence. LOW - No recorded occurrences. ** CRITICAL - Failure which aborts the test in progress or creates an intolerable safety hazard. MAJOR - A failure or performance degradation in excess of tolerance limits. MINOR - Failures other than critical or major which have no significant effect on the ability of the to perform its primary function.

н-3

POWER SYTE DIVISION FAILURE MODES AND EFFECTS ANALYSIS

PART NO. 1268600 DESCRIPTION OF FUNCTION: PAGE 3 OF											
	PART NAME BRDC Boiler # LOOP ITE	5 M NO				DATE 21 Sept. 1970					
		2	3	<u></u>		PROBABI	LITY OF OCCURRENCE*				
	-	-	EFFECT ON SNAP-8		4		CRITICALITY OF FAILURE**				
	FAILURE MODE	FAILURE CAUSE	COMPONENT	SYSTEM		2	6 REMARKS AND RECOMMENDATIONS				
	H. Deconditioned boiler	Hg loop contamination	Clean or replace	Poor performan or shutdown	e High	Major	Loop or test failure not chargable to boiler; (no known mat'l. to overcome contamination effects)				
	I. Excessive NaK side pressure drop	Design or fabrication deficiency, loose swirl wire	Clean or replac	e Poor per- formance or shutdown	Low	Major	Adequate design and fab. should prevent' occurrence				
H-H	J. Plugged Hg tubes	Contamination, mass transfer	Replace	Poor perfor- mance or shut down	Low	Minor/ Major	Adequate loop cleanliness should keep prob. low.				
1-	K. Excessive corrosion or erosion	Oxide contamination	May lead to rupture, replace	Can lead to premature wea out	Low c-	Major	Latest materials should reduce incidence, loop clean- liness is significant factor				
	L. Bimetal tube debond	Fab. deficiency	Reduced life	Reduced life	Low	Major	No evidence to date; continue C-scan and other inspection				
	M. Manufacturing problems leading to fab. deficiencies	Complexity of design	Difficult to manufacture	Program delay	Low	Minor	Detailed evaluation by Mfg. Eng. to establish optimum mfg. procedures.				
	<pre>* HIGH - Two or more occurrences of failure mode in testing. MODerate - One recorded occurrence. LOW - No recorded occurrences.</pre>										
	<pre>** CRITICAL - Failure which aborts the test in progress or creates an intolerable safety hazard. MAJOR - A failure or performance degradation in excess of tolerance limits. MINOR - Failures other than critical or major which have no significant effect on the ability of the to perform its primary function.</pre>										

.

APPENDIX I

DESIGN REVIEW CHECK LIST

Enclosure (1) No. I-A6c Page 1 of 12

POWER SYSTEMS DIVISION

DESIGN REVIEW CHECK LIST.

SUBJECT UNDER REVIEW (Name, Part No.): BRDC BOILER # 5 Ph 1268600

This Design Review Check List is an integral part of the design review documentation package, required by Power Systems Division Procedure I-A6c, "Design Review Plan."

The items specified on the Design Review Check List provide the basis for a comprehensive review. However, they are not necessarily all inclusive. The design engineer shall be guided by the basic requirement for a thorough and detailed evaluation of a design, as stated under Section 3, "SCOPE," of this procedure, and shall expand the list where necessary.

Check List entries shown herein provide current information on the design under review and are intended to reflect the basis for and readiness of the design for entry into its next evolutionary phase.

REVIEWED BY:

PRESENTED BY:

Date

Black 3 Spt. 1970 Design Engineer Date

DESIGN APPROVAL:

Department Manager

Date

4925:66:107

_	PSD DESIGN REVIEW CHECK LIST			age	2 of 12
SUBJE	CT NAME: BRDC BOILER #5	YES	NO	n/A	REFERENCE DOCUMENT
DE	P/N_1268600 ESIGN ENGINEER: <u>AS Chalpus</u> DATE 2 Sept 1970				
Item	No. General				
1.	Is the basic design objective clearly defined?	X			appendix A
2.	Are the performance parameters and output requirements definitive and not subject to misinterpretation?	×			11
3.	Are performance tolerances delineated?	X			
<u>4</u> .	Are failure criteria delineated?	×			oppendix H
5.	Were alternate designs considered in selecting the present design?	×			meno 7961-70-0567 "16 June 1970 Preliminary mentional Recign Reises
6.	Were redundancy needs analyzed and results used in the design?	X			BEDCHS Boilin
7.	Were simplification techniques applied?	X	,		
8.	Was a failure modes and effects analysis made?	×	-		appendix +
9.	Have adequate safety margins been incorporated for each important failure mode?	X			a.^. D
10.	If item has a limited life, is it so designated?	X			appender n
11.	Have maintainability requirements been considered?	X			Owg. 1268600
12.	Have previous test data and failure reports been reviewed and results used in the design?	X			appendix c
13.	Is the method of component identification specified? (The method of marking and location must be compatible with use-environment.)	×			Dwg 1268600
14.	If documentation of inspection findings is required, are the characteristics to be observed and their frequency and method of inspection defined?			×	
15.	If operational or functional acceptance testing is required, are the parameters, mode of testing, and equipment defined?		×		
1					
4925	τ-3 Τ-3				
		•	-	-	

	PSD DESIGN REVIEW CHECK LIST		.]	Page	3 of 12
SUBJE	TT NAME: BROC BOILER #5	YES	NO	N/A	REFERENCE DOCUMENT
	P/N 1268600				
DE	SIGN ENGINEER: <u>ls Chalpus</u> DATE <u>9-3-70</u>				
Item	No. <u>General</u>			,	
16.	Are required special inspection equipments, tools, and gages defined?	X			Dwg. 1268600
17.	Has a procurement plan for this material been *			×	LERC Fab.
18.	Have qualified and preferred parts been used where applicable?	X		- '	appendige F.
19.	Is the design notebook and file up to date and ready for audit?	. ×			
20.	Have provisions been made for preservation, packaging, handling, storage, and shipping?	. X			Drawing 1268600
21.	Were trade-off studies made and utilized in selecting the design?	X			memo 7961-70-0587
22.	Does the design minimize the probability of human errors during installation, checkout, and operation, such as reversed connections, parts installed backward, no lubrication during startup, etc.?	×			
23.	Does the design make appropriate use of "fail-safe" devices or techniques?	×		•	
24.	Does the design comply with all applicable specifica- tions?	X			
25.	Were the action items from the previous Design Review carried out?			X	
26.	Is the design compatible with the requirements of the end item?	X			Dwg 1268 489
4925	:66:107				

PSD DESIGN REVIEW CHECK LIST]	Page	4 of 12
SUBJECT NAME: BRDC BOILER #5	YES	NO	N/A	REFERENCE DOCUMENTS
P/N 1268600	_		1	
DESIGN ENGINEER: Chalpus DATE 9-3-20	_			
Item No. Mechanical				
1. Has a stress analysis been made?	X			appendix G.
2. Wave areas of high stress concentrations such as sharp corners, radii, and re-entrant angles been eliminated?	×			
3. Has a thermal analysis been made?	X			appendix B
4. Is thermal expansion likely to have adverse effects on dimensions and tolerances?		X		appendix A
5. Has a tolerance analysis been made to verify proper fitting of parts under extremes of tolerance buildup?	X			
6. Did the tolerance analysis consider operating loads and temperatures?	×	,		appendix G.
7. Were static, dynamic and magnetic balances and their tolerances considered?			X	
8. Has a wearout analysis for all rubbing and rolling part been made?	s		X	
9. Have the installation torques and tolerances of all fasteners and their stress effects been evaluated?		.	X	
10. Is the inspectability of the component assured? (Are the true positioning and contour requirements designed to enable inspection of part?)	X			
11. Has the mechanical compatibility with the complete system been verified?	X			Appendise A
12. Does mechanical design reflect simplest method, from	.X			
13. Were environmental effects (including those of nuclear radiation) considered along with safety requirements during design?	X			
4925:66:107		.		
I~5				

	PSD DESIGN REVIEW CHECK LIST		P	age	5 of 12	
SUBJ	ECT NAME: BRDC BOILER #5	YES	NO	n/A	REFERENCE	DOCUMENTS
	P/N 1268600					
D.	ESIGN ENGINEER: <u>18 Chalpin</u> DATE <u>9-3-70</u>					
Item	No. Electrical					
l.	Are the design essentials adequately defined, including performance, longevity, and repetitive operation requirements?			X		
2 . -	Is the design compatible with the life cycle conditions to which the equipment will be exposed?			\times		
3.	Have the stability and drift requirements and the effects of environments on these characteristics been considered?			X		
4.	Was a simplification study made and applied?			$ $ \times		
5.	Is redundancy employed where beneficial; are possible side effects taken into consideration?			$ \times$		
6,	Were reliability characteristics considered and documented in parts and materials selection?	•		×		
7.	Are the part tolerances consistent with design requirements?		-	\times		
8.	Was adequate derating employed, including sufficient margin for transients and other excessive stresses?		ļ	X		
9,.	Can the parts operation result in undesirable conditions of temperature, voltage, current, or RFI for other parts or assemblies? If so, was this info used in the design?	~		×		
10.	Are the dielectric breakdown and insulation resistance properties adequate for the most severe environments?			×		
11.	Is hermetic sealing employed where beneficial?			X		
12.	Are type of connections employed reliable?	-				
		. 				
4925	5:66:107					

PSD DESIGN REVIEW CHECK LIST

Page 6 of 12

SUBJECT NAME: BRDC BOILER #5	YES	NO	N/A	REFERENCE	DOCUMENTS
P/N 1268600	.			2	
DESIGN ENGINEER: <u>El Chalpen</u> DATE 9-3-70				 	
Item NO. Electrical					
13. Have all applicable specifications been called out?			X		
14. Have the preferred parts lists (JPL Specification No. 2006LC and CSFC-PPL-1) been used?			X		
15. Has expected hot spot temperatures been determined and considered?					
16. Has effect of component operation on primary power wave form been considered?			X		
17. Has nuclear radiation environment effects been considered?	.		$\left \times\right $		
NOTE: The following electrical characteristics should be considered: inductance, capacitance, resistance, sensitivity, leakage, insulation, shielding; distortion, gain, phase, attenuation; slope, harmonics, eddy currents; time, spikes, peaks, contact resistance, contact rating, torque, wire size					
925:66:107					
I-7				}	

	PSD DESIGN REVIEW CHECK LIST		Pe	age	7 of 12
SUBJI	CT NAME: BRAC BOILER #5	YES	NO	n/A	REFERENCE DOCUME
	P/N 1268600				
D	SIGN ENGINEER: <u>Chalpus</u> DATE <u>9-3-70</u>				
Item	No. Materials				
L.	Are all materials adequately identified by MIL, Fed, AGC, or comparable specifications?*	X			Awy 1265600
2.	Is the source of supply specified for qualified/ preferred materials?			X	LERC FAB,
3.	Are the strength characteristics of the materials including tensile, compressive, shear, yield, bending, creep, and fatigue satisfactory for intended use?	×			appendix G.
+.	Is each material employed within limits defined by its endurance limit curve?	×			**
5 •	Have adequate safety margins been used to provide protection from failure due to corrosion, vibration, shock, fatigue, and other stress factors?	×			41
6.	Are the hardness, ductility, and other characteristics suitable for both the manufacturing processes and application?	×	 		
7.	Will the material characteristics be significantly changed by exposure to environments, particularly radiation?		×		
8.	Are the special inspection and test processes compatible with the parts and materials?	×			appendix F.
9.	Are the thermal expansion characteristics suitable for the intended use?	×			appendix G.
10.	Will the materials be compatible with mating parts, fluids, and gases and not act as catalytic agents?	×			Reference (d)
11:.	Does each material have suitable electrical and magnetic properties for its application?			X	
* Th MI	e order of precedence for specifications must meet L-STD-143 requirements.				
4925	:66:107				

.

PSD DESIGN REVIEW CHECK LIST					Page 8 of 12						
SUBJ	ECT NAME: BROC BOILER #5	YES	NO	N/A	REFERENCE DOCUMENTS						
·	P/N 1268600										
: I	ESIGN ENGINEER: <u>El Chalpus</u> DATE 9-3-70			 							
Iter	No. <u>Materials</u>	·	Γ								
12.	Have adequate metallurgical controls been imposed to assure that each material conforms to its specification?	×			Dwg. 1268600						
13.	Are all tolerances specified and are they compatible with the materials and required manufacturing methods?	X			<i>L</i> i						
14.	If mechanical, metallurgical, and/or chemical testing is required, are the necessary samples, coupons, or test bars defined, and test methods established?			×.							
			-								
		•									
		:									
				•							
492	5:66:107	ļ									
	1 - 9	1	r -	ŧ.	•						

PSD DESIGN REVIEW CHECK LIST

Page 9 of 12

SUBI	BOT NAME: BROC BOILDR #5	VES	NO		REFERENCE DOCIMENTS
	D/M DAGAMO			1.1 T	LUPLICENCE DOUBLINED
E	ESIGN ENGINEER: <u>Schelpus</u> DATE <u>9-3-70</u>				
Item	No. Manufacturing Processes				· · · · · · · · · · · · · · · · · · ·
1.	Are the specified fabrication methods suited to the design and materials?	X		 	BEDC Boiler #-4
2	Are the process capabilities consistent with component requirements?	X			11
3.	Is heat treating, stress relief, nitriting, flame hardening, or other special process required?		X		
4.	Will processing and assembly affect the dimensions?		X		
5•	Are process specifications and tolerances designated?	X			Dwg 1268600
6.	Are requirements after processing and assembly specified?	×			21
7	Have joining methods (welding, brazing, soldering, fastening) been selected to minimize effect on tolerances and part variations?	×			11
8.	Are special inspection and test processes such as radiograph, helium leak test, and penetrant dye check required?	X			Jurg. 1268600
9•.	If so, are acceptance criteria specified?	X			//
10.	Has the most suitable cleaning method been specified?	X			11
11.	Is a protective coating required?		X		
12.	If so, will protective coating affect mating parts?			X	
13.	Are special assembly requirements such as slignment, torque, lock wiring, static balancing, or dynamic balancing defined and documented?			X	
14.	Is there an assembly instruction or specification?		X		
4925	:66:107 I-10				

.

PSD DESIGN REVIEW CHECK LIST

Page 10 of 12

.

					<u> </u>	
SUBJ	ECT NAME: BROC BOILER #5	YES	no	n/A	 REFERENCE	DOCUMENTS
	P/N 1268600					
: D	ESIGN ENGINEER: <u>Collaboration Date 9-3-70</u>					
<u></u>		<u>†</u>		<u> </u>		
<u>Item</u>	No. Manufacturing Processes					_
15.	Are the clean room environmental characteristics defined (such as maximum particle size, count, temperature, flow rate, etc.)?			×	LeRC	FAB,
16.	Are there special packaging, handling, or storage requirements?	X			Queg. 126	\$600
17.	Are the special process operator and equipment qualification requirements specified?	×				1
18.	Are the surface finish, waviness, and lay adequately defined?			×		. 9 4 633
19.	Are workmanship acceptance standards defined?	X			dug 12	86.000
20.	Are the applicable workmanship specifications referenced?	×			et.	
21.	Is a Build-up and Assembly Log required?		X			
		·				
		1.	1			
הסק						
·•)c,		·				
	PSD DESIGN REVIEW CHECK LIST	-		Page	11 of 12	
---	--	----------	---	------	---	
SUBJECT NAME: BRDC BOILER #5 P/N 1268600				n/A	REFERENCE DOCUMENT	
. 1	DESIGN ENGINEER: <u>US Chalpus</u> DATE 9-3-70					
Iter	No. Environment			· ·		
1.	Have the environmental exposures, levels, and durations been fully determined?	X			AGC-10680	
2.	Have the environmental effects on component performance, longevity, and reliability been evaluated?	× -			meno 4923;69:9180 "Effect of Twelear	
3.	Does operation of the component generate environments which are detrimental to the component or to other assemblies or subsystems?		×		Galilung mattheals "	
4.	Can the component withstand external and self- generated environments without employment of isolation devices?	7				
5.	Is adequate protection from environments specified in detail where required?	Х			rigure 5	
6.	Were the relationships between environments and modes of failure considered in the failure mode and effects enalysis?	X			appendix H	
NOTE	E: The following environments should be considered: heat, cold, thermal shock, high pressure, vacuum, pressure shock, humidity; vibration, acoustic noise, acceleration, shock, RFI-radiated, RFI- conducted, RFI-susceptibility; explosive atmosphere, solar radiation, nuclear radiation, salt atmosphere, fungus, meteoroids, zero-gravity, sand, dust, wind.					
492	5:66:107					
	т10	1	l	1	1	

	PSD DESIGN REVIEW CHECK LIST			Page	12 of 12
SUB	ECT NAME: BROC BOILER #5	YES	NO	N/A	REFERENCE DOCUMEN
·	P/N 1268600				
1	JESIGN ENGINEER: <u>PS Chalpin</u> DATE <u>9-3-70</u>		ļ.	·	
Iter	No. Instrumentation				
1.	Have accuracy: and precision requirements been specified for performance paremeters?			X	
2,	Have provisions been made for instrumentation to meet these requirements?			X	
3.	Have sensor installation requirements, including hermetic sealing and removal or replacement, been considered?			X	-
4.	Will the insertion of sensors affect the operation of the component?			X	
5.	Is adequate instrumentation available for anticipated operating conditions?			X	
6 . ′	Is an instrumentation development program necessary?				
7.	Are written calibration instructions available for the calibration of data gathering equipment?				
8.	Has an adequate and reliable instrumentation wiring system been defined?				
		-			
					· ¢
		4			1
492	5:66:107				
		1	ľ		