

General Disclaimer

One or more of the Following Statements may affect this Document

- This document has been reproduced from the best copy furnished by the organizational source. It is being released in the interest of making available as much information as possible.
- This document may contain data, which exceeds the sheet parameters. It was furnished in this condition by the organizational source and is the best copy available.
- This document may contain tone-on-tone or color graphs, charts and/or pictures, which have been reproduced in black and white.
- This document is paginated as submitted by the original source.
- Portions of this document are not fully legible due to the historical nature of some of the material. However, it is the best reproduction available from the original submission.

DOE/NASA CONTRACTOR REPORT

DOE/NASA CR-150506

THERMAL PERFORMANCE OF MSFC HOT AIR COLLECTORS UNDER NATURAL AND SIMULATED CONDITIONS

Prepared by Wyle Laboratories, Solar Energy Systems Division, Huntsville, Ala.

Under sub-contract with

IBM Corporation
Federal Systems Division
Huntsville, Alabama 35805

Contract NAS8-32036

National Aeronautics and Space Administration
George C. Marshall Space Flight Center, Alabama 35812
for the U. S. Department of Energy



(NASA-CR-150506) THERMAL PERFORMANCE OF
MSFC HOT AIR COLLECTORS UNDER NATURAL AND
SIMULATED CONDITIONS (Wyle Labs., Inc.)
39 p HC A03/MF A01

N78-18525

CSCL 10A

Unclas
G3/44 05985

U.S. Department of Energy



Solar Energy

NOTICE

This report was prepared to document work sponsored by the United States Government. Neither the United States nor its agents the United States Department of Energy, the United States National Aeronautics and Space Administration, nor any federal employees, nor any of their contractors, subcontractors or their employees, make any warranty, express or implied, or assume any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product or process disclosed, or represent that its use would not infringe privately owned rights.


1. REPORT NO. DOE/NASA CR 150506	2. GOVERNMENT ACCESSION NO.	3. RECIPIENT'S CATALOG NO.	
4. TITLE AND SUBTITLE Thermal Performance of MSFC Hot Air Collectors under Natural and Simulated Conditions		5. REPORT DATE November 1977	
		6. PERFORMING ORGANIZATION CODE	
7. AUTHOR(S) K. Shih, Sr.		8. PERFORMING ORGANIZATION REPORT # WYLE TR-531-05, Rev A	
9. PERFORMING ORGANIZATION NAME AND ADDRESS Wyle Laboratories Scientific Services and Systems Group, Solar Energy Sys Div Huntsville, Alabama 35805		10. WORK UNIT, NO.	
		11. CONTRACT OR GRANT NO. NAS8-32036	
12. SPONSORING AGENCY NAME AND ADDRESS National Aeronautics and Space Administration Washington, D. C. 20546		13. TYPE OF REPORT & PERIOD COVERED Contractor Report	
		14. SPONSORING AGENCY CODE	
15. SUPPLEMENTARY NOTES This work was done under the technical supervision of Charles N. Thomas of the Marshall Space Flight Center.			
16. ABSTRACT This report presents the procedures used and the results obtained from an evaluation test program conducted to determine the thermal performance and structural characteristics of selected MSFC-designed hot air collectors under both real and simulated environmental conditions. Five collectors, serial numbers 5, 6, 8, 10 and 11, were tested in the three-phased program. Phase one consisted of a series of outdoor tests to determine stagnation temperatures on a typical bright day and to determine each collector's ability to withstand these temperatures. Two of the collectors, S/N's 5 and 6, experienced structural deformation sufficient to eliminate them from the remainder of the test program. Of the three remaining collectors, S/N 10 was selected as the test article for the last two phases of the program. Phase two consisted of a series of outdoor tests to evaluate the thermal performance of collector S/N 10 under certain test conditions. The final phase of the program consisted of a series of indoor tests to evaluate the thermal performance of the collector under closely controlled simulated conditions.			
17. INDEX WORDS		18. DISTRIBUTION STATEMENT Unclassified-Unlimited  William A. Brooksbank, Jr. Manager Solar Heating & Cooling Project Office	
19. SECURITY CLASSIF. (of this report) Unclassified	20. SECURITY CLASSIF. (of this page) Unclassified	21. NO. OF PAGES 39	22. PRICE NTIS

TABLE OF CONTENTS

		<u>Page Number</u>
1.0	PURPOSE	1
2.0	REFERENCES	1
3.0	MANUFACTURER	1
	3.1 Description of Test Specimens	1
4.0	SUMMARY	2
5.0	TEST CONDITIONS AND TEST EQUIPMENT	3
	5.1 Location	3
	5.2 Ambient Conditions	3
	5.3 Instrumentation and Equipment	3
6.0	REQUIREMENTS, PROCEDURES AND RESULTS	5
	6.1 Outdoor Stagnation Tests	5
	6.2 Outdoor Thermal Performance Test	6
	6.3 Solar Simulator Thermal Performance Test	7
7.0	ANALYSIS	9
8.0	COMPARISON AND CONCLUSIONS	12
FIGURE 1	Comparison of Outdoor and Indoor Collector Efficiency at 50 SCFM	13
FIGURE 2	Comparison of Outdoor and Indoor Collector Efficiency at 90 SCFM	14
FIGURE 3	Comparison of Outdoor and Indoor Collector Efficiency at 120 SCFM	15
FIGURE 4	Comparison of Outdoor and Indoor Collector Efficiency at 200 SCFM	16
FIGURE 5	Location of the Outdoor Thermal Performance Tests on MSFC Hot Air Collector S/N 10	17
TABLE I	Stagnation Test Results Summary	18
TABLE II	Outdoor Test Conditions for MSFC Hot Air Collector S/N 10	19

TABLE OF CONTENTS (Continued)

		<u>Page Number</u>
TABLE III	Outdoor Performance Test Data at 50 SCFM	20
TABLE IV	Outdoor Performance Test Data at 90 SCFM	21
TABLE V	Outdoor Performance Test Data at 120 SCFM	22
TABLE VI	Outdoor Performance Test Data at 200 SCFM	23
TABLE VII	Outdoor Thermal Efficiencies of MSFC Hot Air Collector S/N 10	24
TABLE VIII	Indoor Test Conditions for MSFC Hot Air Collector #10	25
TABLE IX	Indoor Performance Test Data at 50 SCFM and 250 BTU/Ft ² -Hr (No Wind)	26
TABLE X	Indoor Performance Test Data at 90 SCFM and 250 BTU/Ft ² -Hr (No Wind)	27
TABLE XI	Indoor Performance Test Data at 120 SCFM and 250 BTU/Ft ² -Hr (No Wind)	28
TABLE XII	Indoor Performance Test Data at 200 SCFM and 250 BTU/Ft ² -Hr (No Wind)	29
TABLE XIII	Indoor Performance Test Data at 90 SCFM and 250 BTU/Ft ² -Hr (With Wind)	30
TABLE XIV	Indoor Performance Test Data at 120 SCFM and 250 BTU/Ft ² -Hr (With Wind)	31
TABLE XV	Indoor Performance Test Data at 200 SCFM and 250 BTU/Ft ² -Hr (With Wind)	32
TABLE XVI	Indoor Performance Test Data at 90 SCFM and 275 BTU/Ft ² -Hr (With Wind)	33
TABLE XVII	Indoor Performance Test Data at 120 SCFM and 275 BTU/Ft ² -Hr (With Wind)	34
TABLE XVIII	Indoor Performance Tests Results and Analysis Summary	35

1.0

PURPOSE

The purpose of this report is to present the procedures used and the results obtained during the performance of an evaluation test program. The test program was conducted to determine the thermal performance and structural characteristics of selected MSFC designed hot air collectors under both real and simulated environmental conditions. The stagnation tests and outdoor performance tests were conducted under the direct supervision of MSFC ET-44 without benefit of a written procedure. The indoor performance tests were conducted in accordance with References 2.2 and 2.3. All tests were conducted in response to Reference 2.1.

2.0

REFERENCES

- 2.1 EP12-(75-23) Testing of the MSFC Hot Air Collectors
- 2.2 MTCP-DC-SHAC-403 Test Procedure for the MSFC Solar Simulator Performance Test of MSFC Hot Air Collector S/N 10
- 2.3 MTCP-FA-SHAC-400 Procedure for Operation of the MSFC Solar Simulator
- 2.4 MSFC MMI-5300.4C Metrology and Calibration

3.0

MANUFACTURER

National Aeronautics and Space Administration
Marshall Space Flight Center
Huntsville, Alabama

3.1

Description of Test Specimens

MSFC Hot Air Collectors, Serial Numbers 5, 6, 8, 10 and 11. The five collectors were identical except for the materials used to form the body. Collectors 5 and 6 were constructed of Olin 4 lb. foam while collectors 8, 10 and 11 were made of FSC 6850 foam. Absorber plates were 0.02" sheet metal coated with Caldwell black paint and each collector had a single cover made of standard glass. Each collector weighed approximately 21 pounds and had the following dimensions:

Width	38-1/8"
Length	74"
Depth	7"
Inlet and Outlet Ducts	3-5/8" by 15"

SUMMARY

Five MSFC designed hot air collectors, serial numbers 5, 6, 8, 10 and 11, were subjected to an Evaluation Test Program as described in detail in this report. The test program was conducted in three phases. Phase one consisted of a series of outdoor tests to determine stagnation temperatures experienced on a typical bright day and each collector's ability to withstand these temperatures. Two of the collectors, S/N's 5 and 6, experienced structural deformation sufficient to eliminate them from the remainder of the test program (See Table I). Of the three remaining collectors, S/N 10 was selected as the test article for the last two phases of the test program. Phase two consisted of a series of outdoor tests to evaluate the thermal performance of collector S/N 10 under the test conditions described in Table II. The results of these tests are shown in Tables III through VII. The final phase of the program consisted of a series of indoor tests to evaluate the thermal performance of the collector under closely controlled simulated conditions described in Table VIII. The results of these tests are shown in Tables IX through XVIII. A graphic presentation of the performance analysis of both indoor and outdoor test data is contained in Figures 1 through 4.

5.0 TEST CONDITIONS AND TEST EQUIPMENT

5.1 Location

Outdoor tests were conducted on the south side of Building 4620 and indoor tests were conducted with the solar simulator in Building 4619 at Marshall Space Flight Center, Huntsville, Alabama.

5.2 Ambient Conditions

All tests were performed at atmospheric pressures and temperatures existing at the test location during the period the test was being conducted.

5.3 Instrumentation and Equipment

All test equipment and instrumentation used for the performance of this test program complies with the requirements set forth in MSFC MMI-5300.4C, Metrology and Calibration. A listing of the equipment used for testing is as follows:

Stagnation Tests:

<u>Apparatus</u>	<u>Manufacturer/Model</u>	<u>Range/Accuracy</u>
32°F Reference Junction	KAYE/Model PRJR	32°F $\pm$ 0.09°F
Thermocouple	Type T	-300°F to + 700°F $\pm$ 1.8°F
LVDT	Moxon/Model D110-3-4	+5 in. to -0.5 in. $\pm$ 0.01 in.
Pyranometer	Eppley/Model 8-48	0 to 400 BTU/ Ft ² -Hr.

Outdoor Performance Test:

<u>Apparatus</u>	<u>Manufacturer/Model</u>	<u>Range/Accuracy</u>
32° Reference Junction	KAYE/Model PRJR	32°F $\pm$ 0.09°F
Thermocouple	Type T	-300°F to + 700°F $\pm$ 1.8°F
Flowmeter	Cox/Model GL32	30 to 250 ACFM $\pm$ 2%
Pressure Gauge	Wallace/Model FA145	0 to 50 PSI

TEST CONDITIONS AND TEST EQUIPMENT (Continued)

Pyranometer	Eppley/Model 8-48	0 to 400 BTU/ Ft ² -Hr. <u>±</u> 5%
-------------	-------------------	---

Anemometer	Weather Measurer/ W121-SD	0 to 100 MPH <u>±</u> 2.5 MPH
------------	------------------------------	----------------------------------

Indoor Performance Tests:

<u>Apparatus</u>	<u>Manufacturer</u>	<u>Range/Accuracy</u>
150°F Reference Junction	Pace/Model 150	150°F <u>±</u> 1°F
Thermocouple	Type T	-300°F to +700°F <u>±</u> 1.8°F
Flowmeter	Cox/Model GL32	30 to 250 ACFM <u>±</u> 2%
Pyranometer	Eppley/Model 8-48	0-400 BTU/Ft ² -Hr. <u>±</u> 5%
Pressure Gauge	Wallace/Model FA145	0 to 50 PSI
Anemometer	Weather Measure/ W121-50	0 to 100 MPH <u>±</u> 2.5 MPH

6.0 REQUIREMENTS, PROCEDURES AND RESULTS

6.1 Outdoor Stagnation Tests on MSFC Hot Air Collectors.

6.1.1 Requirements

The requirements of these tests were to obtain stagnation temperature data on MSFC Hot Air Collectors. An additional task was to monitor the dimensions of the collector during testing.

The following data was recorded for each stagnation test:

- 1) Solar Flux (BTU/Ft²-Hr.)
- 2) Collector Absorber Plate temperature (°F) - 3 locations.
- 3) Collector Air Temperature between the absorber plate and the cover (°F).
- 4) Collector dimensional change (in.) - 6 locations.

6.1.2 Procedure

The outdoor stagnation tests on MSFC Hot Air Collectors were conducted without a written procedure at the direction and under the supervision of ET-44.

The directions given were to mount the collectors outdoors facing south at an angle to allow the solar radiation to be normal on the collector surface and expose the collector for at least three bright sunny days. The inlet and outlet ports were plugged and internal temperatures were to be measured at locations defined by Reference 2.1. Also, the dimensional changes of the collectors were to be monitored.

6.1.3 Results

A summary of the results of the stagnation tests is shown in Table I.

If the collector's dimension did not change significantly, the collector passed the stagnation test. However, if the collector's dimension changed enough to break seals and allow the transfer media to escape, then the collector was considered to have failed.

Two collectors, S/N 5 and S/N 6, failed the tests when exposed to solar fluxes typical on a bright day (240 BTU/Ft²-Hr to 290 BTU/Ft²-Hr).

6.0 REQUIREMENTS, PROCEDURES AND RESULTS (Continued)

6.2 Outdoor Thermal Performance Test of the MSFC Hot Air Collector S/N 10.

6.2.1 Requirements

The requirements of this test were to obtain thermal performance data under conditions described in Table II. (A)

The following data was recorded for each test condition:

- 1) Collector inlet air temperature (°F)
- 2) Collector outlet air temperature (°F)
- 3) Collector absorber plate temperature (°F) -
3 locations.
- 4) Collector air temperature between the absorber
plate and the cover (°F)
- 5) Flow rate through collector (ACFM)
- 6) Flowmeter air temperature (°F)
- 7) Ambient air temperature (°F)
- 8) Wind velocity (MPH)
- 9) Wind direction (Degrees)
- 10) Solar flux (total) (BTU/Ft²-Hr.)

6.2.2 Procedure

The outdoor thermal performance tests on the MSFC Hot Air Collector S/N 10 were conducted under the supervision of MSFC ET-44 without a written procedure.

6.2.3 Results

The results of this test are depicted in Tables III through VII. The values shown for each data point were determined by averaging the data recorded for that point over a 15 minute period during which all test requirements were continuously met.

6.0 REQUIREMENTS, PROCEDURES AND RESULTS (Continued)

6.3 Solar Simulator Thermal Performance Test of MSFC Hot Air Collector S/N 10.

6.3.1 Requirements

The requirements of this test were to obtain thermal performance data under the conditions described in Table VIII. The following data was recorded for each condition.

- 1) Collector inlet air temperature (°F).
- 2) Collector outlet air temperature (°F).
- 3) Absorber plate temperature - 3 points (°F).
- 4) Air temperature between absorber plate and cover (°F).
- 5) Collector air flow rate (ACFM).
- 6) Flowmeter air temperature (°F).
- 7) Ambient temperature (°F).
- 8) Wind velocity (MPH).
- 9) Simulator flux (BTU/Ft²-Hr.)

6.3.2 Procedure

- 1) Complete all pre-test requirements specified in Reference 2.2 and Reference 2.3.
- 2) Mount collector on simulator test table.
- 3) Connect instrument leads as prescribed in Reference 2.2 and assure data system is ready to accept and record data.
- 4) Connect and insulate ducting.
- 5) Assure that test table is aligned properly and is set at a 45° angle with respect to the floor.
- 6) Assure that lamp array is set at a 45° angle with respect to the floor.
- 7) Establish desired flow rate and inlet temperature.
- 8) Power-up simulator to obtain required solar flux level.
- 9) Record data for 5 minutes in stabilized condition.
- 10) Repeat steps 7, 8 and 9 until all test requirements have been met.

NOTE: At end of each daily test period, secure the simulator and assure proper log book entries are made.

When resuming operation of the simulator, assure compliance with Reference 2.3 and repeat Procedure steps as required to complete the test series.

6.3.3

Results

The results of this test are depicted in Tables IX through XVIII. The values shown for each data point were determined by averaging the data recorded for that point over a 15 minute period during which all test requirements were continuously met.

ANALYSIS

The analysis of the data contained in this report is in accordance with the National Bureau of Standards and ASHRAE recommended approach.

The efficiency of a collector is:

$$\eta = \frac{q_u/A}{I} = \frac{\dot{m} C_{tf} (t_{f,e} - t_{f,i})}{I} \quad (1)$$

where

- q_u = rate of useful energy extracted from the solar collector (BTU/hr)
- A = overall cross sectional area of collector (ft²)
- I = total solar energy incident upon the plant of the solar collector per unit time per unit area (BTU/Hr-Ft²)
- $\dot{m}$ = mass flow rate of the transfer fluid through the collector per unit gross-sectional area of the collector (Lb/Ft²-Hr)
- C_{tf} = specific heat of the transfer fluid (BTU/Lb °F)
- $t_{f,e}$ = temperature of the transfer fluid leaving the collector (°F)
- $t_{f,i}$ = temperature of the transfer fluid entering the collector (°F)

Rewriting equation (1) in terms of the collector area, we get:

$$\eta = \frac{(\dot{m}A) C_{tf} (t_{f,e} - t_{f,i})}{IA} = \frac{\dot{M} C_{tf} (t_{f,e} - t_{f,i})}{P_i} \quad (2)$$

Notice that

- P_i = IA = total power incident on the collector (BTU/Hr)
- $\dot{M}$ = $\dot{m}A$ = total mass flow rate through the collector (Lb/Hr)

For an air collector system, the mass flow rate is obtained by multiplying the density of the air with the volume flow rate of the air through collector.

$$\dot{M} = \int \rho_{tf} \dot{V} \quad (3)$$

where

- ρ_{tf} = Density of the transfer fluid (Lb/Ft³)
- $\dot{V}$ = Volume flow rate (SCFM)

ORIGINAL PAGE IS
OF POOR QUALITY

Since $\dot{M} C_{tf} (t_{f,e} - t_{f,i})$ = total power collected by the collector
the collector efficiency can be expressed in

$$\eta = \frac{P_{abs}}{P_{inc}} \quad (4)$$

where

P_{abs} = total absorbed power

P_{inc} = total incident power

The present collector efficiency is defined as

$$\eta_{eff} = \frac{\dot{M} C_{tf} (t_{f,e} - t_{f,i})}{P_i} * 100 \quad (5)$$

In order to compare the performance of different collectors, the efficiency curve is plotted against a normalized factor

$$x = \frac{(T_{ave} - T_{amb})}{I} \quad (6)$$

where

$$T_{ave} = \frac{T_{f,i} + T_{f,e}}{2} \quad (^\circ F)$$

$$T_{amb} = \text{Ambient temperature} \quad (^\circ F)$$

$$I = \text{Solar flux} \quad (\text{BTU}/\text{Ft}^2\text{-Hr})$$

The efficiency calculations were made for all test data and are presented in Table VII for outdoor test data and Table XVIII, indoor test data. A second order least square curve is usually fitted to the data at each flow rate due to variations in efficiency because of wind. However, due to the lack of sufficient wind data, no curve fitting will be attempted for the outdoor data. A second order fit was performed on the indoor data and is as follows. (A)

The second order polynomial expressing collector efficiency as a function of the normalized factor is defined as:

$$\eta(x) = a_0 + a_1 x + a_2 x^2$$

where $\eta(x)$ is the collector efficiency

x is the normalized factor

a_0, a_1, a_2 are the coefficients to be determined by the curve fit to test data.

A computer program was used to calculate the polynomial coefficients for each set of data presented in Table XVIII.

(A)

Figures 2 through 5 present plots of efficiency versus the normalized factor for each flow condition. The curves plotted are for the data from the indoor tests. Only the data points for the outdoor test are shown on these plots.

ORIGINAL PAGE IS
OF POOR QUALITY


COMPARISON AND CONCLUSIONS

It was hoped that a direct comparison of the outdoor to indoor test data could be made; however, several factors make this very difficult. These are:

- . The type of collector is extremely sensitive to wind variations.
- . The anemometer was not very accurate, and its placement was questionable.
- . The close proximity of structures to the test set up made determination of wind direction and velocity almost impossible. (See Figure 5.)


In addition to the problems with the outdoor data, the indoor flux is not as accurate as it needs to be for comparison. The reason for this is that the tests were run on the solar simulator with lamps near the end of their expected life. Consequently, lamps burned out at an increasing rate as the test progressed and for other than the initial test run the flux was an approximation based on the number of lamps burned out and the initial flux value as determined by a field map.

These two factors would make any conclusion comparing indoor to outdoor testing questionable; therefore, no such comparison was attempted.



90 SCFM

- Simulator without wind 250 BTU/ft²·hr
- Simulator with 3-4 MPH wind 250 BTU/ft²·hr
- Simulator with 3-4 MPH wind 275 BTU/ft²·hr
- △ Outdoor Data




$\frac{T_{ave} - T_{amb}}{T}$

FIGURE 2. Comparison of Outdoor and Indoor Collector Efficiency at 90 SCFM.

90 SCFM

- Simulator without wind 250 BTU/Ft²·HR
- Simulator with 3-4 MPH Wind 250 BTU/Ft²·HR
- Simulator with 3-4 MPH Wind 275 BTU/Ft²·HR
- △ Outdoor Data



$\frac{T_{ave} - T_{amb}}{T}$

FIGURE 2. Comparison of Outdoor and Indoor Collector Efficiency at 90 SCFM.

120 SCFM

- Simulator without wind 250 BTU/ft²·hr
- Simulator with 3-4 MPH wind 250 BTU/ft²·hr
- Simulator with 3-4 MPH wind 275 BTU/ft²·hr
- △ Outdoor Data




FIGURE 3. Comparison of Outdoor and Indoor Collector Efficiency at 120 SCFM.




FIGURE 4. Comparison of Outdoor and Indoor Collector Efficiency at 200 SCFM.

$$\frac{T_{ave} - T_{amb}}{I}$$




FIGURE 5. Location of the Outdoor Thermal Performance Tests on MSFC Hot Air Collector S/N 10

TABLE I.
STAGNATION TEST RESULTS SUMMARY

Collector S/N	Maximum Absorber Temp. (°F)	Status	Comments
5	258	Failed	Foam expanded away from cover.
6	273	Failed	Foam expanded away from cover.
8	282	Passed	No visible change.
10	263	Passed	No visible change.
11	269	Passed	No visible change.

TABLE II.
OUTDOOR TEST CONDITIONS FOR MSFC HOT AIR COLLECTOR S/N 10

Inlet Temperature (°F)	Flow Rate (SCFM)	Solar Flux BTU/F ² -Hr
80, 110, 140, 170	50	240 to 300 Testing from 2 hours before Solar Noon to 2 hours after Solar Noon.
	90	
	120	
	200	

ORIGINAL PAGE IS
OF POOR QUALITY

TABLE III

OUTDOOR PERFORMANCE DATA AT 50 SCFM

INLET TEMPERATURE REQUIREMENTS	80°F*	110°F	140°F	170°F
Collector Inlet Temperature (°F)		110.2	140.0	169.4
Collector Outlet Temperature (°F)		138.5	163.2	181.9
Collector Outlet-Inlet Temperature (°F)		28.3	23.2	12.5
Air Flow Rate (SCFM)		49.7	49.8	50.0
Ambient Temperature (°F)		80.0	81.4	83.4
Absorber Plate Temperature A (°F)		171.8	192.2	202.5
Absorber Plate Temperature B (°F)		181.0	200.9	209.4
Absorber Plate Temperature C (°F)		189.0	208.2	212.6
Air Temperature Between Cover and Plate D (°F)		176.4	188.9	190.2
Solar Flux (BTU/Ft ² -Hr)		265.4	279.0	250.2

* Note: The collector outlet temperature sensor was improperly located, the data was considered invalid. A retest was not possible due to scheduling.

TABLE IV
OUTDOOR PERFORMANCE TEST DATA AT 90 SCFM

INLET TEMPERATURE REQUIREMENTS	80°F*	110°F	140°F	170°F
Collector Inlet Temperature (°F)		110.1	140.0	170.4
Collector Outlet Temperature (°F)		123.5	152.2	180.7
Collector Outlet-Inlet Temperature (°F)		13.4	12.1	10.3
Air Flow Rate (SCFM)		90.1	90.1	90.1
Ambient Temperature (°F)		78.4	80.5	83.2
Absorber Plate Temperature A (°F)		151.8	178.2	201.8
Absorber Plate Temperature B (°F)		158.2	185.2	213.9
Absorber Plate Temperature C (°F)		173.1	195.2	216.8
Air Temperature Between Cover and Plate D (°F)		158.1	170.5	195.7
Solar Flux (BTU/Ft ² -Hr.)		248.6	273.7	276.7

*Note: The collector outlet temperature sensor was improperly located; the data was considered invalid. A retest was not possible due to scheduling.

TABLE V

OUTDOOR PERFORMANCE TEST DATA AT 120 SCFM

INLET TEMPERATURE REQUIREMENTS	80°F	110°F	140°F	170°F
Collector Inlet Temperature (°F)	80.5	109.9	139.6	169.7
Collector Outlet Temperature (°F)	96.1	124.1	148.4	177.9
Collector Outlet-Inlet Temperature (°F)	15.6	14.1	8.7	8.2
Air Flow Rate (SCFM)	120.1	121.1	119.7	120.2
Ambient Temperature (°F)	76.0	78.6	77.4	79.6
Absorber Plate Temperature A (°F)	125.0	150.9	168.2	198.1
Absorber Plate Temperature B (°F)	143.5	169.3	184.1	209.2
Absorber Plate Temperature C (°F)	152.3	175.4	183.0	211.7
Air Temperature Between Cover and Plate	151.5	167.9	161.7	193.2
Solar Flux (BTU/Ft ² -Hr)	255.4	276.0	251.8	290

ORIGINAL PAGE IS
OF POOR QUALITY

TABLE VI

OUTDOOR PERFORMANCE TEST DATA AT 200 SCFM

INLET TEMPERATURE REQUIREMENTS	80°F	110°F	140°F	170°F
Collector Inlet Temperature (°F)	78.0	109.8	140.2	170.0
Collector Outlet Temperature (°F)	88.0	118.8	148.9	174.4
Collector Outlet-Inlet Temperature (°F)	10.0	9.1	8.7	4.4
Air Flow Rate (SCFM)	198.2	198.8	199.6	199.1
Ambient Temperature (°F)	81.1	80.9	84.0	77.3
Absorber Plate Temperature A (°F)	113.0	140.9	167.9	188.5
Absorber Plate Temperature B (°F)	116.6	145.5	181.7	198.3
Absorber Plate Temperature C (°F)	133.3	157.8	184.9	196.8
Air Temperature Between Cover and Plate D (°F)	130.5	148.0	174.9	176.0
Solar Flux (BTU/Ft ² -Hr)	283.2	283.6	286.2	275.1

TABLE VII
OUTDOOR THERMAL EFFICIENCIES OF MSFC HOT AIR COLLECTOR S/N 10

FLOW RATE (SCFM)	INLET TEMP. (°F)	$(^{\circ}\text{F}-Ft^2\text{-Hr}/\text{BTU})^x$	Efficiency η (%)
50	110	0.167	31.5
	140	0.252	24.6
	170	0.369	14.8
90	110	0.154	28.8
	140	0.240	23.6
	170	0.334	19.9
120	80	0.048	43.5
	110	0.139	36.7
	140	0.264	24.6
	170	0.325	20.2
200	80	0.007	41.6
	110	0.117	37.9
	140	0.211	36.0
	170	0.345	18.7

ORIGINAL PAGE IS
OF POOR QUALITY

TABLE VIII
INDOOR TEST CONDITIONS FOR MSFC HOT AIR COLLECTOR #10

Inlet Temperature (°F)	Flow Rate (SCFM)	Solar Flux BTU/Ft ² -Hr	Wind Velocity MPH
80, 110, 140, 170	50	250	0
	90	250	0, 3 - 4
		275	3 - 4
	120	250	0, 3 - 4
		275	3 - 4
	200	250	0, 3 - 4

TABLE IX

INDOOR PERFORMANCE TEST DATA AT 50 SCFM
AND 250 BTU/Ft²-HR. (NO WIND)

INLET TEMPERATURE REQUIREMENTS	80°F	110°F	140°F	170°F
Collector Inlet Temperature (°F)	79.8	109.9	139.9	169.6
Collector Outlet Temperature (°F)	112.4	133.1	155.9	178.7
Collector Outlet-Inlet Temperature Difference (°F)	32.6	23.2	16.0	9.1
Air Flow Rate (SCFM)	49.9	49.7	49.8	49.7
Ambient Temperature (°F)	67.7	67.3	70.2	73.2
Absorber Plate Temperature (°F)	157.5	173.1	191.1	208.9
Absorber Plate Temperature (°F)	155.3	171.3	190.6	208.1
Absorber Plate Temperature (°F)	175.7	191.2	207.0	222.1
Air Temperature Between Cover and Plate (°F)	183.1	187.8	197.2	205.6
Solar Flux (BTU/Ft ² -Hr)	252.0	252.0	249.0	249.0
Wind Velocity* (MPH)	0	0	0	0

* Note: Measured at Three Locations.

ORIGINAL PAGE IS
OF POOR QUALITY

TABLE X

INDOOR PERFORMANCE TEST DATA AT 90 SCFM
AND 250 BTU/FT²-HR. (NO WIND)

INLET TEMPERATURE REQUIREMENTS	80°F	110°F	140°F	170°F
Collector Inlet Temperature (°F)	80.5	110.3	140.5	170.1
Collector Outlet Temperature (°F)	103.9	127.2	152.1	177.5
Collector Outlet-Inlet Temperature Difference (°F)	23.4	16.9	11.6	7.4
Air Flow Rate (SCFM)	90.6	90.0	89.9	89.3
Ambient Temperature (°F)	75.1	68.5	71.9	75.8
Absorber Plate Temperature (°F)	139.2	158.1	180.6	202.0
Absorber Plate Temperature (°F)	149.6	166.3	186.4	206.0
Absorber Plate Temperature (°F)	165.2	177.9	194.7	212.8
Air Temperature Between Cover and Plate (°F)	169.6	176.2	187.6	201.1
Solar Flux (BTU/FT ² -Hr)	249.0	249.0	249.0	249.0
Wind Velocity* (MPH)	0	0	0	0

* Note: Measured at Three Locations.

TABLE XI

INDOOR PERFORMANCE TEST DATA AT 120 SCFM
AND 250 BTU/FT²-HR. (NO WIND)

INLET TEMPERATURE REQUIREMENTS	80°F	110°F	140°F	170°F
Collector Inlet Temperature (°F)	80.1	110.6	140.4	170.0
Collector Outlet Temperature (°F)	97.7	124.4	149.4	174.8
Collector Outlet-Inlet Temperature Difference (°F)	17.6	13.8	9.0	4.8
Air Flow Rate (SCFM)	120.0	120.0	120.2	120.1
Ambient Temperature (°F)	67.2	67.2	67.6	67.7
Absorber Plate Temperature (°F)	129.2	151.9	174.1	195.3
Absorber Plate Temperature (°F)	137.8	160.7	179.6	199.0
Absorber Plate Temperature (°F)	147.1	166.9	184.3	203.6
Air Temperature Between Cover and Plate (°F)	157.6	171.4	180.4	192.3
Solar Flux (BTU/FT ² -HR)	252.0	252.0	252.0	252.0
Wind Velocity* (MPH)	0	0	0	0

* Note: Measured at Three Locations.

ORIGINAL PAGE IS
OF POOR QUALITY

TABLE XII

INDOOR PERFORMANCE TEST DATA AT 200 SCFM
AND 250 BTU/FT²-HR. (NO WIND)

INLET TEMPERATURE REQUIREMENTS	80°F	110°F	140°F	170°F
Collector Inlet Temperature (°F)	80.7	110.4	140.3	170.2
Collector Outlet Temperature (°F)	92.7	119.5	146.3	174.3
Collector Outlet-Inlet Temperature Difference (°F)	12.0	9.1	6.0	4.1
Air Flow Rate (SCFM)	200.4	199.8	199.1	198.8
Ambient Temperature (°F)	69.7	70.5	72.2	78.7
Absorber Plate Temperature (°F)	117.2	142.1	166.2	192.5
Absorber Plate Temperature	123.1	146.4	169.7	193.2
Absorber Plate Temperature (°F)	128.5	151.5	172.9	197.5
Air Temperature Between Cover and Plate (°F)	144.7	160.1	173.6	193.6
Solar Flux (BTU/Ft ² -Hr)	249.0	240.0	240.0	249.0
Wind Velocity* (MPH)	0	0	0	0

*Note: Measured at Three Locations.

TABLE XIII

INDOOR PERFORMANCE TEST DATA AT 90 SCFM
AND 250 BTU/FT²-HR. (WITH WIND)

INLET TEMPERATURE REQUIREMENTS	80°F	110°F	140°F	170°F
Collector Inlet Temperature (°F)	80.4	110.2	139.2	169.4
Collector Outlet Temperature (°F)	101.1	125.1	148.6	172.1
Collector Outlet-Inlet Temperature Difference (°F)	20.7	14.9	9.4	2.7
Air Flow Rate (SCFM)	90.5	89.5	90.3	90.2
Ambient Temperature (°F)	70.6	70.5	70.2	69.2
Absorber Plate Temperature (°F)	134.9	155.7	173.7	192.4
Absorber Plate Temperature (°F)	146.2	164.5	180.9	195.9
Absorber Plate Temperature (°F)	157.5	179.2	186.2	201.0
Air Temperature Between Cover and Plate (°F)	153.2	163.2	172.0	179.8
Solar Flux (BTU/Ft ² -Hr)	250.0	250.0	250.0	250.0
Wind Velocity* (MPH)	3 - 4	3 - 4	3 - 4	3 - 4

* Note: Measured at Three Locations

TABLE XIV

INDOOR PERFORMANCE TEST DATA AT 120 SCFM
AND 250 BTU/FT²-HR. (WITH WIND)

INLET TEMPERATURE REQUIREMENTS	80°F	110°F	140°F	170°F
Collector Inlet Temperature (°F)	80.6	110.2	140.0	169.9
Collector Outlet Temperature (°F)	96.0	121.7	146.5	171.8
Collector Outlet-Inlet Temperature Difference (°F)	15.4	11.5	6.5	1.9
Air Flow Rate (SCFM)	119.4	120.3	120.3	119.5
Ambient Temperature (°F)	66.1	67.2	68.2	69.0
Absorber Plate Temperature (°F)	127.2	147.1	168.7	190.1
Absorber Plate Temperature (°F)	136.4	158.1	175.6	193.1
Absorber Plate Temperature (°F)	141.7	161.4	178.4	196.3
Air Temperature Between Cover and Plate (°F)	140.9	154.9	165.8	176.7
Solar Flux (BTU/FT ² -Hr)	250.0	250.0	250.0	250.0
Wind Velocity* (MPH)	3 - 4	3 - 4	3 - 4	3 - 4

* Note: Measured at Three Locations.

ORIGINAL PAGE IS
OF POOR QUALITY

TABLE XV

INDOOR PERFORMANCE TEST DATA AT 200 SCFH AND
250 BTU/FT²-HR. (WITH WIND)

INLET TEMPERATURE REQUIREMENTS	80°F	110°F	140°F	170°F
Collector inlet Temperature (°F)	80.2	109.9	139.9	170.1
Collector Outlet Temperature (°F)	90.9	117.5	144.3	171.4
Collector Outlet-Inlet Temperature Difference (°F)	10.7	7.6	4.4	1.3
Air Flow Rate (SCFH)	199.3	199.5	198.8	199.5
Ambient Temperature (°F)	62.1	63.7	65.2	67.8
Absorber Plate Temperature (°F)	113.0	136.4	159.9	183.9
Absorber Plate Temperature (°F)	117.9	138.7	160.0	182.2
Absorber Plate Temperature (°F)	122.9	144.3	166.3	187.8
Air Temperature Between Cover and Plate (°F)	129.5	143.2	156.5	169.9
Solar Flux (BTU/FT ² -Hr.)	250.0	250.0	250.0	250.0
Wind Velocity* (MPH)	3 - 4	3 - 4	3 - 4	3 - 4

*Note: Measured at Three Locations.

TABLE XVI

INDOOR PERFORMANCE TEST DATA AT 90 SCFM
AND 275 BTU/FT²-HR. (WITH WIND)

INLET TEMPERATURE REQUIREMENTS	80°F	110°F	140°F	170°F
Collector Inlet Temperature (°F)	80.4	110.2	140.5	170.4
Collector Outlet Temperature (°F)	101.6	125.4	149.9	174.2
Collector Outlet-Inlet Temperature Difference (°F)	21.2	15.2	9.4	3.8
Air Flow Rate (SCFM)	89.0	89.9	89.6	89.5
Ambient Temperature (°F)	70.6	72.6	73.9	75.6
Absorber Plate Temperature (°F)	136.5	156.4	176.5	196.4
Absorber Plate Temperature (°F)	147.9	165.7	183.5	200.9
Absorber Plate Temperature (°F)	161.0	176.1	191.3	207.4
Air Temperature Between Cover and Plate (°F)	156.8	167.1	177.0	185.3
Solar Flux (BTU/FT ² -Hr.)	275.0	275.0	275.0	275.0
Wind Velocity* (MPH)	3 - 4	3 - 4	3 - 4	3 - 4

* Note: Measured at Three Locations.

TABLE XVII

INDOOR PERFORMANCE TEST DATA AT 120 SCFM
AND 275 BTU/FT²-HR. (WITH WIND)

INLET TEMPERATURE REQUIREMENTS	80°F	110°F	140°F	170°F
Collector Inlet Temperature (°F)	80.3	110.7	140.0	170.2
Collector Outlet Temperature (°F)	98.0	123.5	149.5	174.3
Collector Outlet-Inlet Temperature Difference (°F)	17.7	12.8	9.5	4.1
Air Flow Rate (SCFM)	120.3	120.4	120.0	119.7
Ambient Temperature (°F)	69.7	71.3	77.0	76.8
Absorber Plate Temperature (°F)	129.4	141.5	171.9	194.2
Absorber Plate Temperature (°F)	144.2	163.4	180.0	198.0
Absorber Plate Temperature (°F)	148.8	167.2	186.0	203.3
Air Temperature Between Cover and Plate (°F)	150.3	162.3	172.6	183.0
Solar Flux (BTU/FT ² -Hr.)	275.0	275.0	275.0	275.0
Wind Velocity* (MPH)	3 - 4	3 - 4	3 - 4	3 - 4

* Note: Measured at Three Locations.

ORIGINAL PAGE IS
OF POOR QUALITY

TABLE XVIII

INDOOR PERFORMANCE TESTS RESULTS AND ANALYSIS SUMMARY

Flow Rate SCFM	Solar Flux BTU/Ft ² -Hr	Inlet Temp. °F	$\frac{T_{ave}-T_a}{I}$	Tested Eff. %	Calc. Eff. %	Coefficient $\eta = (a_0 + a_1x + a_2x^2)$
200	250	80	.068	57.3	57.4	$a_0 = .643$
		110	.185	44.7	44.3	$a_1 = .974$
		140	.296	29.7	30.2	$a_2 = .601$
		170	.377	19.3	19.1	
200	250*	80	.094	50.3	50.3	$a_0 = .631$
		110	.200	35.7	35.7	$a_1 = -1.363$
		140	.308	20.8	20.8	
		170	.412	6.3	6.3	$a_2 = -.039$
120**	250*	80	.088	44.3	45.6	$a_0 = .514$
		110	.194	32.8	32.6	
		140	.300	18.7	19.8	
		170	.400	5.2	6.1	
	275*	80	.077	45.4	44.7	$a_1 = -.819$
		110	.174	33.1	34.8	
		140	.279	24.6	22.5	
		170	.375	10.5	9.7	
120	250	80	.086	49.9	50.2	$a_0 = .591$
		110	.199	39.0	38.0	$a_1 = -1.019$
		140	.306	24.9	25.9	$a_2 = -.218$
		170	.416	13.3	13.0	

* 3 - 4 MPH Wind

** Use Eight Points to Determine the Coefficients

ORIGINAL PAGE IS
OF POOR QUALITY

TABLE XVIII (Continued)

INDOOR PERFORMANCE TESTS RESULTS AND ANALYSIS SUMMARY

Flow Rate SCFM	Solar Flux BTU/Ft ² -Hr	Inlet Temp. °F	$\frac{T_{ave}-T_a}{I}$	Tested Eff. %	Calc. Eff. %	Coefficient $\eta = (a_0 + a_1x + a_2x^2)$
90	250	80	.069	51.0	51.1	$a_0 = .591$
		110	.202	36.4	36.0	$a_1 = -1.178$
		140	.299	24.9	25.4	$a_2 = .161$
		170	.393	15.5	15.3	
90**	275*	80	.084	40.7	42.2	$a_0 = .525$
		110	.174	29.3	31.3	
		140	.269	18.2	20.2	
		170	.372	7.5	8.5	
	250*	80	.080	44.3	42.7	$a_1 = -1.247$
		110	.188	31.7	29.7	
		140	.290	20.3	17.8	
		170	.400	5.8	5.4	
90	250	80	.113	38.5	38.4	$a_0 = .522$
		110	.215	27.1	27.5	$a_1 = -1.309$
		140	.312	19.1	18.7	
		170	.404	11.4	11.6	$a_2 = .751$

* 3 - 4 MPH Wind

** Use Eight Points To Determine the Coefficients