

## N O T I C E

THIS DOCUMENT HAS BEEN REPRODUCED FROM  
MICROFICHE. ALTHOUGH IT IS RECOGNIZED THAT  
CERTAIN PORTIONS ARE ILLEGIBLE, IT IS BEING RELEASED  
IN THE INTEREST OF MAKING AVAILABLE AS MUCH  
INFORMATION AS POSSIBLE

DOE/NASA/0031-80/6  
NASA CR-159770  
GE80ET0105

# **COGENERATION TECHNOLOGY ALTERNATIVES STUDY (CTAS)**

**GENERAL ELECTRIC COMPANY  
FINAL REPORT**

**VOLUME VI - COMPUTER DATA**

**PART 1 - Coal-Fired Nocogeneration Process Boiler**

W.F. Knightly

**Section A**

May, 1980

PREPARED FOR  
National Aeronautics Space Administration  
Lewis Research Center  
Under Contract DEN3-31

FOR

U.S. Department of Energy  
Office of Energy Technology  
Division of Fossil Fuel Utilization

**(NASA-CR-159770-Pt-1-A) COGENERATION  
TECHNOLOGY ALTERNATIVES STUDY (CTAS).  
VOLUME 6: COMPUTER DATA. PART 1:  
COAL-FIRED NOCOGENERATION PROCESS BOILER,  
SECTION A Final Report (General Electric**

**N80-30888**

**Unclas  
63/44 28460**

DOE/NASA/0031-80/6  
NASA CR-159770  
GE80ET0105

# **COGENERATION TECHNOLOGY ALTERNATIVES STUDY (CTAS)**

**GENERAL ELECTRIC COMPANY  
FINAL REPORT**

**VOLUME VI - COMPUTER DATA**

**PART 1 - Coal-Fired Cogeneration Process Boiler**

W.F. Knightly

**Section A**

May, 1980

PREPARED FOR  
National Aeronautics Space Administration  
Lewis Research Center  
Under Contract DEN3-31

FOR

U.S. Department of Energy  
Office of Energy Technology  
Division of Fossil Fuel Utilization

## FOREWORD

The Cogeneration Technology Alternatives Study (CTAS) was performed by the National Aeronautics and Space Administration, Lewis Research Center, for the Department of Energy, Division of Fossil Fuel Utilization. CTAS was aimed at providing information which will assist the Department of Energy in establishing research and development funding priorities and emphasis in the area of advanced energy conversion system technology for advanced industrial cogeneration applications. CTAS included two Department of Energy-sponsored/NASA-contracted studies conducted in parallel by industrial teams along with analyses and evaluations by the National Aeronautics and Space Administration's Lewis Research Center.

This document describes the work conducted by the Energy Technology Operation of the General Electric Company under National Aeronautics and Space Administration contract DEN3-31.

The General Electric Company contractor report for the CTAS study is contained in six volumes:

Cogeneration Technology Alternatives Study (CTAS), General Electric Company Final Report

<u>Title</u>	<u>DOE Number</u>	<u>NASA Contract Report No.</u>
GE Vol. 1 - Summary Report	DOE/NASA/0031-80/1	CR-159765
Vol. 2 - Analytic Approach	DOE/NASA/0031-80/2	CR-159766
Vol. 3 - Industrial Process Characteristics	DOE/NASA-0031-80/3	CR-159767
Vol. 4 - Energy Conversion System Characteristics	DOE/NASA-0031-80/4	CR-159768
Vol. 5 - Cogeneration System Results	DOE/NASA-0031-80/5	CR-159769
Vol. 6 - Computer Data	DOE/NASA-0031-80/6	CR-159770

Members of the technical staffs of the following organizations have developed and provided information for the General Electric Company Cogeneration Technology Alternatives Study. The contributions of these people in time, effort, and knowledge are gratefully appreciated.

General Electric Company

Corporate Research and Development  
 Energy Systems Programs Department  
 Energy Technology Operation  
 Gas Turbine Division  
 Industrial and Marine Steam Turbine Division  
 Industrial Turbine Sales and Engineering Operation  
 Installation and Service Engineering Business Division  
 Space Division  
 TEMPO  
 Lamp Components Division

DeLaval

Dow Chemical

General Energy Associates

Institute of Gas Technology

J.E. Sirrine

Kaiser Engineers

N.A. Philips

This General Electric Company contractor report is one of a set of reports describing CTAS results. The other reports are the following:

Cogeneration Technology Alternatives Study (CTAS), Vol. I, Summary Report, NASA TM-81400.

Cogeneration Technology Alternatives Study (CTAS), Vol. II, Comparison and Evaluation of Results, NASA TM-81401

Cogeneration Technology Alternatives Study (CTAS) - United Technologies Corporation Final Report

<u>Title</u>	<u>DOE Number</u>	<u>NASA Contract Report No.</u>
UTC Vol. 1 - Summary	DOE/NASA/0030-80/1	CR-159759
Vol. 2 - Industrial Process Characteristics	DOE/NASA-0030-80/2	CR-159760
Vol. 3 - Energy Conversion System Characteristics	DOE/NASA-0030-80/3	CR-159761
Vol. 4 - Heat Sources, Balance of Plant and Auxiliary Systems	DOE/NASA-0030-80/4	CR-159762
Vol. 5 - Analytic Approach & Results	DOE/NASA-0030-80/5	CR-159763
Vol. 6 - Computer Data	DOE/NASA-0030-80/6	CR-159764

TABLE OF CONTENTS  
Volume I - Summary Report

Section

- 1      SUMMARY
  - Objectives
  - Scope
  - Results
- 2      INTRODUCTION
  - Background
  - Objective, Overall Scope, and Methodology
- 3      STUDY GROUND RULES AND ASSUMPTIONS
  - Industrial Process Characteristics
  - Definition of Energy Conversion Systems (ECS)
  - Matching of Energy Conversion Systems (ECS) to Industrial Processes
  - Economic Evaluation of Energy Conversion System-Industrial Process Matches
  - National Savings Analysis
- 4      INDUSTRIAL PROCESSES
  - Industrial Data Subcontractors
  - Industrial Process Selection
  - Data Summary
- 5      ENERGY CONVERSION SYSTEMS
  - Introduction
  - Energy Conversion System Data Sources
  - Fuel Considerations
  - ECS Characterization
  - Steam Turbine ECS
  - Gas Turbine - Open-Cycle ECS
  - Diesel ECS
  - Combined Gas Turbine-Steam Turbine ECS
  - Closed-Cycle Gas Turbine ECS
  - Stirling Cycle ECS
  - Thermionic ECS

TABLE OF CONTENTS (Cont'd)  
Volume I - Summary Report (Cont'd)

Section

- 5 ENERGY CONVERSION SYSTEMS (Cont'd)  
Phosphoric Acid Fuel Cell  
Molten Carbonate Fuel Cell  
Overview  
Reference
- 6 CAPITAL COSTS  
Capital Cost Methodology  
Data Sources  
Cost Comparisons  
References
- 7 SIGNIFICANT GENERIC DEVELOPMENTS  
High Temperature Air Preheaters  
DC to AC Energy Conversion  
Coal Gasification, Fuel Gas Cleanup  
NO<sub>x</sub> From Coal-Derived Liquid Fuels  
Fluidized Bed Combustion
- 8 ECS-INDUSTRIAL PROCESS MATCHING  
General  
Nocogeneration Case  
Cogeneration Case  
ECS-Process Matching  
Fuel Energy Uses
- 9 COGENERATION SYSTEMS PERFORMANCE  
Fuel Energy Savings Potential of Selected Energy Conversion  
Systems  
Energy and Emissions Savings Results for Representative  
Matches of ECS's and Industrial Processes
- 10 ECONOMIC EVALUATION OF COGENERATION SYSTEMS  
Introduction  
Return on Investment (ROI) Analysis  
Selection of Cogeneration Systems Based on Economic Criteria  
Sensitivity of ROI to Changes in Costs

TABLE OF CONTENTS (Cont'd)  
Volume I - Summary Report (Cont'd)

Section

- 11 NATIONAL CONSIDERATIONS
  - Methodology
  - National Fuel Energy Saved
  - National Emissions Saved
  - Levelized Annual Energy Cost Savings
- 12 RESULTS AND OBSERVATIONS
  - Background
  - Results and Observations
  - Significant Development Requirements



TABLE OF CONTENTS  
Volume II - Analytical Approach

<u>Section</u>		<u>Page</u>
1	SUMMARY	
	Objectives	
	Scope	
	Results	
2	INTRODUCTION	
	Background	
	Objective, Overall Scope, and Methodology	
3	ASSUMPTIONS AND APPROACH	
	Groundrules & Assumptions	
	Approach Used & Factors Considered	
	References	
4	COMPUTER SYSTEM ANALYSIS	
	Introduction	
	Process Data Base	
	Economics Data Base	
	 Volume III - Industrial Process Characteristics	
1	SUMMARY	
	Objectives	
	Scope	
	Results	
2	INTRODUCTION	
	Background	
	Objective, Overall Scope, and Methodology	
5	INDUSTRIAL PROCESSES	
	Selection Process	
	Data Summary	
	Process Definition and Data	
	Estimated National Projections	
	Appendix A	
	Appendix B	

## TABLE OF CONTENTS

### Volume IV - Energy Conversion System Characteristics

#### Section

- 1 SUMMARY  
    Objectives  
    Scope  
    Results
- 2 INTRODUCTION  
    Background  
    Objective, Overall Scope, and Methodology
- 6 ENERGY CONVERSION SYSTEMS (ECS)  
    Introduction  
    Energy Conversion System Data Sources  
    Fuel Considerations  
    ECS Parameters and Characterization  
    ECS Performance and Descriptions  
    Performance and Data Summary  
    Cogeneration Fuel Saved Windows  
    Environmental, Natural Resource, and Operational Factors  
    Significant Developments Requirements  
    References for Section 6
- 7 CAPITAL COSTS  
    Capital Cost Methodology  
    Data Sources  
    Capital Cost Summaries  
    Cost Corroboration  
    References

### Volume V - Cogeneration System Results

- 1 SUMMARY  
    Objectives  
    Scope  
    Results
- 2 INTRODUCTION  
    Background  
    Objective, Overall Scope, and Methodology

**TABLE OF CONTENTS**  
**Volume V - Cogeneration System Results (Cont'd)**

<u>Section</u>		<u>Page</u>
8	<b>PERFORMANCE OF MATCHES</b>	
	Methodology	
	Assumptions/Groundrules	
	Fuel Energy Savings Potential of Cogeneration	
	Fuel Energy Savings for Selected Energy Conversion Systems	
	By-Product or Waste Fuel	
	Matches of ECS's and Industrial Processes	
9	<b>ECONOMIC EVALUATION</b>	
	Introduction	
	Methodology and Groundrules	
	Return on Investment (ROI) Analysis	
	Levelized Annual Energy Cost (LAEC) Analysis	
10	<b>NATIONAL CONSIDERATIONS</b>	
	Methodology	
	Sample Calculation	
	National Fuel Energy Saved	
	Levelized Annual Energy Cost Savings	
	Appendix - Scaling Methodology	
11	<b>RESULTS AND OBSERVATIONS</b>	

**Volume VI - Computer Data**

1	<b>SUMMARY</b>	
	Objectives	1-1
	Scope	1-2
	Results	1-4
2	<b>INTRODUCTION</b>	
	Background	2-1
	Objective, Overall Scope, and Methodology	2-3



## LIST OF ILLUSTRATIONS

<u>Figure</u>		<u>Page</u>
2-1	GE-CTAS Project Organization	2-6
12-1	Industrial Process Data Handling - Data Base Creating, Updating and Reporting	12-3
12-2	Typical Data Base Report	12-6
12-3	Typical Summary Data by SIC Code	12-7
12-4	Fuel Saved and Capital Cost Data Handling - Process and Performance Matching and Capital Costing	12-8
12-5	Energy Conversion System Characteristics	12-14
12-6	CTAS Matching of Process Model to Energy Conversion Systems Performance Maps	12-16
12-7	Fuel Energy Saved Report	12-17
12-8	CTAS Capital Cost of ECS Components	12-19
12-9	Sample Capital Cost Report	12-24
12-10	Data Handling - Economics and Potential National Savings	12-26
12-11	CTAS Operating and Maintenance Factors Table for $10^6$ \$/Yr	12-29
12-12	Sample Economic Sensitivity Report	12-31
12-13	Sample Economic Sensitivity	12-32
12-14	Sample Fuel Saved by Type + Economics Report	12-33
12-15	Sample of National Fuel and Emissions Savings Report	12-35
12-16	Sample of ECS-Process Fuel & Emissions Report	12-36

## LIST OF TABLES

<u>Table</u>		<u>Page</u>
2-1	GE-CTAS Advanced Technology Cogeneration Energy Conversion Systems Matched to Fuels	2-4
2-2	GE-CTAS State of Art Cogeneration Energy Conversion Matched to Fuels	2-4
12-1	Contents of CTAS Industrial Process Data Base	12-4
12-2	CTAS Process Data Input Form	12-5
12-3	Contents of Extract of Process Data Base for ECS Matching	12-9
12-4	Selected Industry Processes & Summary of Energy Requirements	12-10
12-5	Contents of ECS Characteristics Table	12-13
12-6	Glossary of Abbreviations	12-15
12-7	Contents of Component Cost Table	12-21
12-8	NASA Approved Selected Cases	12-25
12-9	Economic Analysis Groundrules	12-27
12-10	Contents of Operating and Maintenance Table	12-28
12-11	Contents of Emissions by ECS and Fuel	12-37
12-12	Contents of National Energy Use	12-37

## Section 1

### SUMMARY

Cogeneration systems in industry simultaneously generate electric power and thermal energy. Conventional nocogeneration installations use separate boilers or furnaces to produce the required thermal energy and purchase electric power from a utility which rejects heat to the outside environment. Cogeneration systems offer significant savings in fuel but their wide spread implementation by industry has been generally limited by economics and institutional and regulatory factors. Because of potential savings to the nation, the Department of Energy, Office of Energy Technology sponsored the Cogeneration Technology Alternatives Study (CTAS). The National Aeronautics & Space Administration, Lewis Research Center, conducted CTAS for the Department of Energy with the support of Jet Propulsion Laboratory and study contracts with the General Electric Company and the United Technologies Corporation.

### OBJECTIVES

The objective of the CTAS is to determine if advanced technology cogeneration systems have significant payoff over current cogeneration systems which could result in more widespread implementation in industry and to determine which advanced cogeneration technologies warrant major research and development efforts.

Specifically, the objectives of CTAS are:

1. Identify and evaluate the most attractive advanced energy conversion systems for implementation in industrial cogeneration systems for the 1985-2000 time period which permit use of coal and coal-derived fuels.
2. Quantify and assess the advantages of using advanced technology systems in industrial cogeneration.

## SCOPE

The following nine energy conversion system (ECS) types were evaluated in CTAS:

1. Steam turbine
2. Diesel engines
3. Open-cycle gas turbines
4. Combined gas turbine/steam turbine cycles
5. Stirling engines
6. Closed-cycle gas turbines
7. Phosphoric acid fuel cells
8. Molten carbonate fuel cells
9. Thermionics

In the advanced technology systems variations in temperature, pressure ratio, heat exchanger effectiveness and other changes to a basic cycle were made to determine desirable parameters for many of the advanced systems. Since coal and coal-derived fuels were emphasized, atmospheric and pressurized fluid bed and integrated gasifiers were evaluated.

For comparison, currently available non-condensing steam turbines with coal-fired boilers and flue gas desulfurization, gas turbines with heat recovery steam generators burning residual and distillate petroleum fuel and medium speed diesels burning petroleum distillate fuel were used as a basis of comparison with the advanced technologies.

In selecting the cogeneration energy conversion system configurations to be evaluated, primary emphasis was placed on system concepts fired by coal and coal-derived fuels. Economic evaluations were based on industrial ownership of the cogeneration system. Solutions to institutional and regulatory problems which impact the use of cogeneration were not addressed in this study.

Over fifty industrial processes and a similar number of state-of-the-art and advanced technology cogeneration systems were matched by



General Electric to evaluate their comparative performance. The industrial processes were selected as potentially suited to cogeneration primarily from the six largest energy consuming sectors in the nation. Advanced and current technology cogeneration energy conversion systems, which could be made commercially available in the 1985 to 2000 year time frame, were defined on a consistent basis. These processes and systems were matched to determine their effectiveness in reducing fuel requirements, saving petroleum, cutting the annual costs of supplying energy, reducing emissions, and improving the industry's return on investment.

Detailed data were gathered on 80 process plants with major emphasis on the following industry sectors:

1. SIC20 - Food and Kindred Products
2. SIC26 - Pulp and Paper Products
3. SIC28 - Chemicals
4. SIC29 - Petroleum Refineries
5. SIC32 - Stone, Clay and Glass
6. SIC33 - Primary Metals

In addition, four processes were selected from SIC22 - Textile Mill Products and SIC24 - Lumber and Wood Products. The industry data includes current fuel types, peak and average process temperature and heat requirements, plant operation in hours per year, waste fuel availability, electric power requirements, projected growth rates to the year 2000, and other factors needed in evaluating cogeneration systems. From this data approximately fifty plants were selected on the basis of: energy consumption, suitability for cogeneration, availability of data, diversity of types such as temperatures, load factors, etc., and range of ratio of process power over process heat requirements.

Based on the industrial process requirements and the ECS characteristics, the performance and capital cost of each cogeneration system and its annual cost, including fuel and operating costs, were compared with nocogeneration systems as currently used. The ECS was either sized to

match the process heat requirements (heat match) and electricity either bought or sold or sized to match the electric power (power match) in which case an auxiliary boiler is usually required to supply the remaining heat needs. Cases where there was excess heat when matching the power were excluded from the study. With the fuel variations studied there are 51 ECS/fuel combinations and over 50 processes to be potentially matched in both heat and power resulting in a total of approximately 5000 matches calculated. Some matches were excluded for various reasons; e.g., the ECS out of temperature range or excess heat produced, resulting in approximately 3100 matches carried through the economic evaluation. Results from these matches were extrapolated to the national level to provide additional perspective on the comparison of advanced systems.

## RESULTS

A comparison of the results for these specific matches lead to the following observations on the various conversion technologies:

1. The atmospheric and pressurized fluidized bed steam turbine systems give payoff compared to conventional boiler with flue gas desulfurization-steam turbine systems which already appear attractive in low and medium power over heat ratio industrial processes.
2. Open-cycle gas turbine and combined gas turbine/steam turbine systems are well suited to medium and high power over heat ratio industrial processes based on the fuel prices used in CTAS. Regenerative and steam injected gas turbines do not appear to have as much potential as the above systems, based on GE results. Solving low grade coal-derived fuel and NO<sub>x</sub> emission problems should be emphasized. There is payoff in these advanced systems for increasing firing temperature.
3. The closed-cycle gas turbine systems studied by GE have higher capital cost and poorer performance than the more promising technologies.
4. Combined-cycle molten carbonate fuel cell and gas turbine/steam turbine cycles using integrated gasifier, and heat matched to medium and high power over heat ratio industrial processes and exporting surplus power to the utility give high fuel savings. Because of their high capital cost, these systems may be more suited to utility or joint utility-industry ownership.

5. Distillate-fired fuel cells did not appear attractive because of their poor economics due to the low effectiveness of the cycle configurations studied by GE and the higher price of distillate fuel.
6. The very high power over heat ratio and moderate fuel effectiveness characteristics of diesel engines limit their industrial cogeneration applications. Development of an open cycle heat pump to increase use of jacket water for additional process heat would increase their range of potential applications.

To determine the effect of the national fuel consumption and growth rates of the various industrial processes together with their distribution of power to heat ratios, process steam temperatures and load factors, each energy conversion system was assumed implemented without competition and its national fuel, emissions, and cost of energy estimated. In this calculation it was assumed that the total savings possible were due to implementing the cogeneration systems in new plants added because of needed growth in capacity or to replace old, unserviceable process boilers in the period from 1985 to 1990. Also, only those cogeneration systems giving an energy cost savings compared with nocogeneration were included in estimating the national savings. Observations on these results are:

1. There are significant fuel, emissions, and energy cost savings realized by pursuing development of some of the advanced technologies.
2. The greatest payoff when both fuel energy savings and economics are considered lies in the steam turbine systems using atmospheric and pressurized fluidized beds. In a comparison of the national fuel and energy cost savings for heat matched cases, the atmospheric fluidized bed showed an 11% increase in fuel saved and 60% additional savings in levelized annual energy cost savings over steam turbine systems using conventional boilers with flue gas desulfurization whose fuel savings would be, if implemented, 0.84 quads/year and cost savings \$1.9 billion/year. The same comparison for the pressurized fluidized bed showed a 73% increase in fuel savings and a 29% increase in energy cost savings.
3. Open-cycle gas turbines and combined-cycles have less wide application but offer significant savings. The advanced residual-fired open-cycle gas turbine with heat recovery steam generator and firing temperature of 2200 F were estimated to have a potential national saving of 39% fuel and 27% energy cost compared to currently available residual-fired gas turbines whose fuel savings would be, if implemented, 0.18 quads/year and cost savings \$0.33 billions/year.

4. Fuel and energy cost savings are several times higher when the cogeneration systems are heat matched and surplus power exported to the utility than when the systems are power matched.

Other important observations made during the course of performing CTAS were:

1. Comparison of the cogeneration systems which are heat matched and usually exporting power to the utility with the power matched systems shows the systems exporting power have a much higher energy savings, often reaching two to five times the power match cases. In the past, with few exceptions, cogeneration systems have been matched to the industrial process so as not to export power because of numerous load management, reliability, regulatory, economic and institutional reasons. A concerted effort is now underway by a number of government agencies, industries, and utilities to overcome these impediments and it should be encouraged if the nation is to receive the full potential of industrial cogeneration.
2. The economics of industrially owned cogeneration plants are very sensitive to fuel and electric power costs or revenues. Increased price differentials between liquid fuels and coal would make integrated gasifier fuel cell or combined-cycle systems attractive for high power over heat industrial processes.
3. Almost 75% of the fuel consumed by industrial processes studied in CTAS, which are representative of the national industrial distribution, have power over heat ratios less than 0.25. As a result energy conversion systems, such as the steam turbine using the atmospheric or pressurized fluidized bed, which exhibit good performance and economics when heat matched in the low power over heat ratio range, give the largest national savings.

## Section 2

### INTRODUCTION

#### BACKGROUND

Cogeneration is broadly defined as the simultaneous production of electricity or shaft power and useful thermal energy. Industrial cogeneration in the context of this study refers specifically to the simultaneous production of electricity and process steam or hot water at an individual industrial plant site. A number of studies addressing various aspects of cogeneration as applied to industry have been made in the last few years. Most of these focused on the potential benefits of the cogeneration concept. CTAS, however, was concerned exclusively with providing technical, cost, and economic comparisons of advanced technology systems with each other and with currently available technologies as applied to industrial processes rather than the merits of the concept of cogeneration.

While recognizing that institutional and regulatory factors strongly impact the feasibility of widespread implementation of cogeneration, the CTAS did not attempt to investigate, provide solutions, or limit the technologies evaluated because of these factors. For example, cogeneration systems which were matched to provide the required industrial process heat and export excess power to the utilities were evaluated (although this has usually not been the practice in the past) as well as systems matched to provide only the amount of power required by the process. Also, no attempt was made to modify the industrial processes to make them more suitable for cogeneration. The processes were defined to be representative of practices to be employed in the 1985 to 2000 time frame.

The cogeneration concept has been applied in a limited fashion to power plants since the turn of the century. Their principal advantage is that they offer a significant saving in fuel over the conventional method of supplying the energy requirements of an industrial plant by purchasing power from the utility and obtaining steam from an on-site process boiler.

The saving in fuel by a cogeneration system can be seen by taking a simple example of an industrial process requiring 20 units of power and 100 units of process steam energy. A steam turbine cogeneration system (assuming it is perfectly matched, which is rarely the case) can provide these energy needs with fuel effectiveness or power plus heat over input fuel ratio of 0.85 resulting in a fuel input of 141 units. In the conventional nocogeneration system the utility with an efficiency of 33% requires 60 units of fuel to produce the 20 units of power and the process boiler with an efficiency of 85% requires 118 units of fuel to produce the required steam making a total fuel required of 178 units. Thus the cogeneration system has a fuel saved ratio of 37 over 178 or 21%.

In spite of this advantage of saving significant amounts of fuel, the percentage of industrial power generated by cogeneration, rather than being purchased from a utility, has steadily dropped until it is now less than 5% of the total industrial power consumed. Why has this happened? The answer is primarily one of economics. The utilities with their mix in ages and capital cost of plants, relative low cost of fuel, steadily improving efficiency and increasing size of power plants all made it possible to offer industrial power at rates more attractive than industry could produce it themselves in new cogeneration plants.

Now with long term prospects of fuel prices increasing more rapidly than capital costs, the increased use of waste fuels by industry and the need to conserve scarce fuels, the fuel savings advantage of cogenerating will lead to its wider implementation. The CTAS was sponsored by the US Department of Energy to obtain the input needed to establish R&D funding priorities for advanced energy conversion systems which could be used in industrial cogeneration applications. Many issues, technical, institutional

and regulatory, need to be addressed if industrial cogeneration is to realize its full potential benefits to the nation. However, the CTAS concentrated on one portion of these issues, namely, to determine from a technical and economic standpoint the payoff of advanced technologies compared to currently available equipments in increasing the implementation of cogeneration by industry.

#### OBJECTIVE, OVERALL SCOPE, AND METHODOLOGY

The objectives of the CTAS effort were to:

1. Identify and evaluate the most attractive advanced conversion systems for implementation in industrial cogeneration systems for the 1985-2000 time period which permit increased use of coal or coal-derived fuels.
2. Quantify and assess the advantages of using advanced technology systems in industrial cogeneration.

To select the most attractive advanced cogeneration energy conversion systems incorporating the nine technologies to be studied in the CTAS, a large number of configurations and cycle variations were identified and screened for detail study. The systems selected showed desirable cogeneration characteristics and the capability of being developed for commercialization in the 1985 to 2000 year time frame. The advanced energy conversion system-fuel combinations selected for study are shown in Table 2-1 and the currently available systems used as a basis of comparison are shown in Table 2-2. These energy conversion systems were then heat matched and power matched to over 50 specific industrial processes selected primarily from the six major energy consuming industrial sectors of food; paper and pulp; chemicals; petroleum refineries; stone, clay and glass; and primary metals. Several processes were also included from wood products and textiles.

On each of these matches analyses were performed to evaluate and compare the advanced technology systems on such factors as:

- Fuel Energy Saved
- Flexibility in Fuel Use

Table 2-1

GE-CTAS ADVANCED TECHNOLOGY COGENERATION ENERGY CONVERSION SYSTEMS MATCHED TO FUELS

	Coal	Coal Derived Liquids	
		Residual	Distillate
Steam Turbine	AFB*	Yes	---
Pressurized Fluid Bed	Yes	---	---
Gas Turbine			
Open Cycle-HRSG	---	Yes	Yes
Regenerative	---	---	Yes
Steam Injected	---	Yes	---
Combined Gas Turbine/Steam Turbine Cycle			
Liquid Fired	---	Yes	---
Integrated Gasifier Combined Cycle	Yes	---	---
Closed Cycle-Helium Gas Turbine	AFB	---	---
Thermionic			
HRSG	FGD*	Yes	---
Steam Turbine Bottomed	FGD	Yes	---
Stirling	FGD	Yes	Yes
Diesels			
Medium Speed	---	Yes	Yes
Heat Pump	---	Yes	Yes
Phosphoric Acid Fuel Cell Reformer	---	---	Yes
Molten Carbonate Fuel Cell			
Reformer	---	---	Yes
Integrated Gasifier			
HRSG	Yes	---	---
Steam Turbine Bottoming	Yes	---	---

\* AFB - Atmospheric Fluidized Bed  
FGD - Flue Gas Desulfurization

Table 2-2

GE-CTAS STATE OF ART COGENERATION ENERGY CONVERSION MATCHED TO FUELS

	Coal	Petroleum Derived	
		Residual	Distillate
Steam Turbine	FGD	Yes	---
Gas Turbine	---	Yes	Yes
Diesel	---	Yes	Yes



- Capital Costs
- Return on Investment and Annual Energy Cost Saved
- Emissions
- Applicability to a Number of Industries.

These matches were evaluated, both on a specific process site basis, and on a national level where it was assumed that each ECS is applied without competition nationwide to all new applicable industrial plants.

Because of the many different types of conversion systems studied and myriad of possible combinations of conversion system and process options, key features of the study were:

- The use of consistent and simplified but realistic characterizations of cogeneration systems
- Use of the computer to match the systems and evaluate the characteristics of the matches.

A major effort was made to strive for consistency in the performance, capital cost, emissions, and installation requirements of the many advanced cogeneration energy conversion systems. This was accomplished first by NASA-LeRC establishing a uniform set of study groundrules for selection and characterization of the ECS's and industrial processes, calculation of fuel and emissions saved and analysis of economic parameters such as levelized annual energy cost and return on investment. These groundrules and assumptions are described in Section 3. Second, in organizing the study, as shown in Figure 2-1, GE made a small group called Cogeneration Systems Technology responsible for establishing the configuration of all the ECS's and obtaining consistent performance, cost and emission characteristics for the advanced components from the GE organizations or subcontractors developing these components. This team, using a standard set of models for the remaining subsystems or components, then prepared the performance, capital costs, and other characteristics of the overall ECS's. As a result, any component or subsystem, such as fuel storage and handling, heat recovery steam generator or steam turbine, appearing in




Figure 2-1. GE-CTAS Project Organization

more than one type ECS is based on the same model. This method reduces the area of possible inconsistency to the advanced component which, in many ECS's, is a small fraction of the total system. The characterization of the ECS's is described in Sections 5 and 6. The functions of obtaining consistent data on industrial processes from the industrial A&E subcontractors was the responsibility of the Industrial Applications Technology group and is described in Section 4. Matching of the ECS's and processes and making the overall performance and economic evaluations and comparisons was the responsibility of Cogeneration Systems Criteria and Evaluation. The methodology of matching the cogeneration systems is detailed in Section 8, the results of the performance analysis in Section 9, economic analysis in Section 10, the national savings in Section 11, and overall results and observations in Section 12.

## Section 12

This volume contains a description of the computer system analysis and the final version of all the principal computer analysis reports prepared on the GE-CTAS. The computer system analysis section discusses how the computer system was used in this study and describes the industrial process, energy conversion system performance and capital cost and economic data bases. The computer program logic and system flow charts are described where necessary and the system output reports are discussed. Part I of the computer reports uses a coal-fired process boiler with flue gas desulfurization as the nocogeneration system base of comparison except for processes with small steam requirements and Part 2 uses a residual-fired process boiler as the nocogeneration base. These reports contain an immense amount of data on fuel consumption, fuel saved and economics of the ECS's matched to the various industrial process and serve as a consistent data base not only for the evaluations performed during CTAS but for future studies.

### COMPUTER SYSTEMS ANALYSIS & OUTPUT REPORT DESCRIPTIONS

#### INTRODUCTION

The computer system designed for CTAS was used extensively for the analysis of all cogeneration options addressed in the study. The objective of this section is to describe how the computer system was used in this study. In the discussion that follows the process and economic data bases are described, the computer program logic and system flow charts are described where necessary, and typical reports are shown.

#### INDUSTRIAL PROCESS DATA BASE

An extremely large volume of data was gathered during the industrial process characterization. The computer system flow chart for handling

the process data is shown in Figure 12-1. Specific items (Table 12-1) needed for the systems analysis were extracted from this data and entered into the process data base using the form shown in Table 12-2.

#### Creating and Updating

The computer program NEWPROC creates the data base by using questions and answers at a timesharing terminal. Updates to the data base utilize the same input form (Table 12-2) and are processed through program CHGPROC. This results in specific changes to specific processes. The output of this program contains only those process descriptions updated so that the updated processes may be verified before merging with the entire data base. Program PROCMA5 updates each process with a general change.

#### Reports From Process Data

Two reports are generated from the process data base. Program GEN2.1 generates a detailed report of all data stored for this process. Figure 12-2 shows a typical page from this report. This program (GEN2.1) operates on the entire data base or on a portion of the data base containing only those processes recently updated.

Program GEN2.2 generates a summary report of the process data to be used in matching the ECS performance curves. Figure 12-3 shows one page of this summary report. The contents of this report are described in Table 12-3. This program reads a file created by a program (BART) that reads the process data base, accesses the steam tables and generates the reduced process data file for ECS matching. The computer process data file used in preparing the computer reports in this volume is shown in Table 12-4.




Figure 12-1. Industrial Process Data Handling - Data Base Creating, Updating and Reporting

Table 12-1

CONTENTS OF CTAS INDUSTRIAL PROCESS DATA BASE

SIC Code.

Process Description.

Product.

Plant Size.

Steam Requirements (maximum of 3): flow, psig, % return, temperature of return.

Other Heat to Process: Description, Btu/hr, temperature.

Operational Time: Hr/yr.

Large Horsepower Loads: Number, horsepower, type drive.

Waste Heat Streams (maximum of 3): Type, flow, temperature, service.

Fuel: Type and quantity (maximum of 2).

By-Product Fuel: Type and quantity.

Number of New Plants.

Process Status.

Anticipated Changes.

Plant Size in 1978 and 2000.

Economic Criteria for Investment and Hurdle Rate.

Industrial Investment Level in 1985 to 2000.

National Capacity in 1978 and 2000.

National Energy Consumed in 1978, 1985 and 2000.

Cost of Energy as Percent of Operating Cost.



GENERAL ELECTRIC CO.

DATE 11/10/78 TIME 17.00  
10SE ADV DESIGN ENGR

SIC CODE 2011

CTAB INDUSTRIAL PROCESS DATA BANK INFORMATION

PROCESS 1

PROCESS DESCRIPTION HEAT-PACKING PRODUCTS HEAT-LARD SIZE 100 TPD

SYSTEM LOADS

FUELS-PROCESS-PLANT-STATUS

ECONOMIC-NATIONAL FACTOR

KILOWATTS AVG 1840 KILOWATTS PEAK 2330

STEAM REQUIREMENTS-PROCESS-HEATING-

FUEL MILLIONS BTU/HR  
TYPE QUANTITY

	FLOW LB/HR 10**3	PSIG	PERCENT RETURN	TEMP RETURN
1.	24.	18.	26.	180.
2.	0.	0.	0.	0.
3.	0.	0.	0.	0.

	FUEL TYPE	MILLIONS BTU/HR QUANTITY
1.	PRIMARY GAS	27.0
2.	SECONDARY OTHER	18.0
3.	BY-PRODUCT 0	0.

ECONOMIC CRITERIA DRN  
EXPECTED ROI 0.  
INVESTMENT LEVEL  
1985-2000\*  
\$ BILLIONS\* 2.80H

OTHER HEAT TO PROCESS  
DIRECT

NATIONAL CAPACITY

MILLIONS OF BTU/HR  
TEMPERATURE 2.  
000.

NUMBER OF NEW PLANTS 30

MILLIONS OF TPD

OPERATIONAL HOURS PER YEAR 2100

PROCESS STATUS- OLD

1978 18.001

LARGE HORSEPOWER LOADS

ANTICIPATED PROCESS CHANGES  
NONE

2000 29.00H

NUMBER 1  
TOTAL HP 320  
TYPE DRIVE MOTOR

PLANT SIZE TPD  
1978 100  
2000 180

WASTE HEAT STREAMS

TYPE	FLOW LB/HR 10**3	TEMP	SERVICE
1. AIR	120.	450.	BOILER-S
2. VAPOR	34.	200.	COOK
3. AIR	26.	475.	COOK-STA

NATIONAL ENERGY CONSUMED  
TRILLIONS BTU PER YEAR  
1978 117.000  
1985 132.000  
2000 187.000

COST OF ENERGY AS %  
OF OPERATING COST 8.8

12-6

ORIGINAL PAGE IS  
OF POOR QUALITY

Figure 12-2. Typical Data Base Report



DATE 11/18/78 TIME 8.75  
BASE-ADV. DESIGN ENGR.

GENERAL ELECTRIC CO.  
COGENERATION TECHNOLOGY  
ALTERNATIVES STUDY (CTAS)

PAGE 3

SUMMARY OF DATA USED FOR  
ENERGY CONVERSION SYSTEM MATCHING  
IN THE  
LUMBER AND WOOD PRODUCTS  
INDUSTRY

SIC CODE	PROC. NO.	PROCESS DESCRIPTION	PROCESS POWER		PROCESS HEAT TEMP			POWER /HEAT RATIO	LOAD FACTOR HRS/YR	PRIMARY FUEL
			MWE	MBTU /HR	MBTU /HR	F PEAK	F AVG			
2421	I	SOFTWOOD-LUM	1.500	5.123	30.	353.	353.	0.17	4000	0
2436	I	SOFT-PLYWOOD	3.000	10.245	75.	406.	406.	0.14	6000	0
2492	I	PARTICLE-BOA	5.000	17.075	37.	406.	406.	0.46	8000	NAT-GAS

Figure 12-3. Typical Summary Data by SIC Code




Figure 12-4. Fuel Saved and Capital Cost Data Handling - Process and Performance Matching and Capital Costing

Table 12-3

CONTENTS OF EXTRACT OF PROCESS DATA BASE FOR ECS MATCHING

SIC Code  
Process Number  
Process Description  
Process Power Requirements  
Process Heat Requirements  
Operational Hours Per Year  
Primary Fuel  
By-Product Fuel Type and Quantity\*  
Hot Water Requirements\*

\* Added directly to programs later as needed.

ECONOMICS DATA BASE

The Economics Data Base is developed in three steps:

1. Fuel savings evaluation
2. Capital Cost estimating
3. Return on Investment (ROI) and Levelized Annual Energy Costs (LAEC) analysis

The computer system flow chart for steps 1 and 2 is shown in Figure 12-4.

Fuel Savings Analysis

The first step in establishing the economics data base is matching each process against each potential ECS-fuel combination (computer program MAPANL). (Each match of a process and ECS-fuel combination is called a case.)

Table 12-4

## SELECTED INDUSTRY PROCESSES &amp; SUMMARY OF ENERGY REQUIREMENTS

SIC Code	Process No.	Description	Process Electric Power		Process Steam MBtu/hr	% Hot Water	Temperature		Power /Heat Ratio	Load Factor hrs/yr	Primary Fuel	By-Product or Waste Fuel Avail MBtu/hr
			MW <sub>e</sub>	MBtu/hr			°F Peak	°F Avg.				
20 FOOD AND KINDRED PRODUCTS												
2011	1	Meat-Packing	1.940	6.625	24	40	250	250	0.28	2100	Gas	
2026	1	Fluid Milk	1.310	4.474	11	50	250	250	0.41	2100	Gas	
2046	1	Wet Corn Milling	28.500	97.327	659		250	250	0.15	6600	Gas	
2063	1	Beet Sugar Refining	4.700	16.050	301		250	250	0.05	2800	Gas	76.47
2082	1	Malt Beverage	6.040	20.627	86	60	250	250	0.24	6600	Gas	
22 TEXTILE MILL PRODUCTS												
2260	1	Textile Finishing	6.200	21.173	158		341	331	0.13	6240	Coal	
24 LUMBER AND WOOD PRODUCTS												
2421	1	Soft Wood-Lumber Sawmill	1.500	5.123	30		353	353	0.17	4000	Bark-Sawdust	41.2
2436	1	Soft Wood-Plywood/Veneer	3.000	10.245	75		406	406	0.14	6000	Bark	100.0
2492	1	Particle Board	5.000	17.075	37		406	406	0.46	8000	Natural Gas	41.2
26 PAPER & ALLIED PRODUCTS												
2621	2	Bleached Kraft	50.000	170.750	780		366	340	0.22	8400	Coal	353
2621	4	Unbleached Kraft	29.000	99.035	610		366	328	0.16	8400	Coal	259
2621	6	Neutral Sulfide Semichemical	20.000	68.300	307		366	345	0.22	8400	Coal	
2621	7	Thermo-Mechanical Pulping	31.300	106.889	183		366	355	0.58	8400	Coal	
2621	8	Waste Paper	15.000	51.225	224		366	355	0.21	8400	Coal	
28 CHEMICAL & ALLIED PRODUCTS												
2800	1	Small Integrated Power Plant	32.500	110.923	1100			366	0.101	8760		
2800	2	Medium Integrated Power Plant	77.200	263.484	1054			366	0.25	8760		
2800	3	Large Integrated Power Plant	97.200	331.744	947			366	0.35	8760		
2812	1	Chlorine - Caustic Sods	120.000	409.800	265		338	311	1.55	8500	Any	
2813	1	Cryogenic Oxygen	34.000	116.110	0		0	0	999.99	8400	Electric	
2819	1	Alumina	30.290	103.440	980		495	434	0.11	8136	Coal-Oil	
2821	2	Vinyl Chloride	4.000	13.660	207		422	373	0.07	8300	Gas	
2821	3	Low Density Polyethylene Resin	55.000	187.825	16		448	448	11.74	7900	Any	

Table 12-4 (Cont'd)

## SELECTED INDUSTRY PROCESSES &amp; SUMMARY OF ENERGY REQUIREMENTS

SIC Code	Process No.	Description	Process Electric Power		Process Steam MBtu/hr	% Hot Water	Temperature		Power /Heat Ratio	Load Factor hrs/yr	Primary Fuel	By-Product or Waste Fuel Avail MBtu/hr
			MW <sub>e</sub>	MBtu/hr			°F Peak	°F Avg.				
28 CHEMICAL & ALLIED PRODUCTS (Cont'd)												
2822	1	Styrene-Butadiene Rubber	7.500	25.612	35		338	338	0.73	7900	Any	
2824	1	Polyester Fibre	32.000	109.280	30		406	406	3.64	7900	Gas-Oil	
2824	2	Nylon Fibre	11.000	37.565	23		274	274	1.63	8760	Any	
2865	2	Cumene-Benzene	0.600	2.049	0		0	0	999.99	8400	Gas-Oil	
2865	3	Phenol/Acetone	6.000	20.490	300		489	398	0.07	8200	Any	
2865	4	Ethylbenzene	0.700	2.390	220		489	489	0.01	7500	Oil-Gas	
2869	1	Methanol Synthesis	1.500	5.123	133		574	538	0.04	7880	Feedstock	352.9
2869	4	Ethanol	3.300	11.270	400		460	460	0.03	7900	Gas-Oil	70.6
2873	1	Ammonia Synthesis	3.500	11.952	640		598	598	0.02	8400	Gas-Oil	
2874	1	Phosphoric Acid	4.000	13.660	92		353	292	0.15	7900	Gas-Oil	
2895	1	Carbon Black	4.000	13.660	20		298	298	0.68	7900	Oil-Gas	
29 PETROLEUM REFINING												
2911	1	Small Refinery	14.000	47.810	375		470	389	0.13	8760	Oil-Der	
2911	2	Medium Refinery	52.000	177.580	1333		470	395	0.13	8760	Oil-Der	
2911	3	Large Refinery	126.000	430.290	3042		470	385	0.14	8760	Oil	
32 STONE, CLAY AND GLASS												
3211	1	Flat-Glass	5.600	19.124	0		0	0	999.99	7500	Nat-Gas	
3221	1	Glass Containers	5.100	17.416	0		0	0	999.99	7500	Nat-Gas	
3229	1	Press-Blown Glass	1.100	3.756	0		0	0	999.99	7500	Nat-Gas	
3241	1	Cement	20.316	69.379	0		0	0	999.99	7920	Coal	
33 PRIMARY METALS												
3312	1	Specialty Steel	60.000	204.900	93		448	446	2.20	6700	Nat-Gas	
3325	1	Integrated Steel	280.000	956.200	912		448	445	1.05	8400	Cok-Coal	529.4
3325	4	Mini-Steel	40.000	136.600	91		448	446	1.50	6700	Nat-Gas	
3331	1	Copper-Fire Smelted	24.800	84.692	0		0	0	999.99	8400	Oil	
3331	4	Copper Anode Smelted	10.100	34.491	40		364	364	0.86	7620	Oil	
3334	1	Aluminum	756.000	2581.740	0		0	0	999.99	8760	Oil	

## ECS Characteristics Table

The data for each ECS is described in Table 12-5 and reported in Figure 12-5. A glossary of the ECS abbreviations used on this figure and the computer output reports is shown in Table 12-6. Process temperatures that exceeded the highest allowable temperature for the ECS were deleted from the economic data base during capital costing. All cases where the power generated on-site was lower than the minimum size for the ECS were flagged but not deleted.

Report 5.1 - Fuel Savings Evaluation Program MAPANL. For every process a nocogeneration base case consisting of an on-site process boiler supplying all process heat and a utility supplying all process power is established. For each cogeneration case the ECS is matched to the process in two ways: a power match and a heat match. In the power match case, the ECS is required to generate all process power, completely replacing the utility. The heat generated by this match is then used to satisfy process heat requirements. If insufficient heat is generated by the ECS an auxiliary boiler is added to make up the deficiency. If excess heat is generated the match is flagged and deleted during capital costing.

In the heat match case, the ECS is required to supply all process heat. Power generated in this match replaces utility power. If excess power is generated, it is exported to the grid. (In this case a new equivalent nocogeneration case requires that the utility be evaluated as if it were generating as much power as the ECS in this heat match case (all process power plus all power exported).) If insufficient power is generated, the shortfall is purchased from the utility. The methodology for this matching is shown in Figure 12-6.

Almost 7200 cases were evaluated and for each case detailed fuel usage reports, entitled Report 5.1: Fuel Energy Saved by Process and ECS, were generated. A sample page from this report is shown in Fig. 12-7. The complete Report 5.1 is included in Volume VI, Part 1, and the results, since they are in Btu/hr, apply to both the coal-fired nocogeneration process boiler case as shown in Part 1, and the oil-fired nocogeneration base case as shown in

Table 12-5

CONTENTS OF ECS CHARACTERISTICS TABLE

ECS number

Short ECS Description

Long ECS Description

Minimum Size - MW (for information only)

Maximum Size - MW (for information only)

Expected Date of Commercialization (for information only)

Fuel Options

PTR = Petroleum based

Coal = Coal based

D = Distillate

R = Residual

F = Coal with flue gas desulfurization (FGD)

A = Coal with atmospheric fluidized bed (AFB)

P = Coal with pressurized fluidized bed (PFB)

X = Plain Coal

If a "Y" appears under these options it means that fuel can be used in that ECS. An "N" means it cannot be used.

Heat Equation

The factors  $A_1$ ,  $B_1$ , and  $C_1$  in the table are used in the following equation to determine the fraction of fuel that is converted to heat:

$$A_1 + B_1 * (\text{Temperature}) + C_1 * (\text{Temperature})^2$$

Power Equation

The factors  $A_2$ ,  $B_2$ , and  $C_2$  are used in the following equation to determine the fraction of fuel that is converted to electric power:

$$A_2 + B_2 * (\text{Temperature}) + C_2 * (\text{Temperature})^2$$

Maximum and Minimum Temperatures for Application of this ECS

Date Revised.

ECS	ECS	PTR	DATE	SIZE	MIN	MAX	MW	FUEL		AI	HEAT		CI	A2	POWER		C2	ECS	MIN	MAX	DATE
								DR	DR		BI	BI			D2	D2					
1	SIH141	STM-TURB-1465/10	1978	7.5	100.0	100.0	100.0	Y	Y	N	0.5159	0.5380	0.0500	0.3341	0.5380	0.5380	0.0500	250	500	11-16-70	
2	SINR00	SIM-TURB-065/025	1978	5.0	50.0	50.0	50.0	Y	Y	N	0.5469	0.5452	0.0600	0.2031	0.5452	0.0600	0.0600	250	450	11-20-70	
3	PFBS10	FFB-STMB-1465/1	1990	13.0	600.0	600.0	600.0	Y	Y	N	0.4733	0.4645	0.0000	0.3833	0.4645	0.0000	0.0000	250	600	11-20-70	
4	TISINT	TI-STMB-1465/10	1995	12.0	300.0	300.0	300.0	Y	Y	N	0.4281	0.4310	0.0664	0.4149	0.4310	0.0664	0.0664	250	500	11-20-78	
5	TIHRSC	THERMIONIC-IRSC	1995	3.0	100.0	100.0	100.0	Y	Y	N	0.7071	0.0000	0.0000	0.1407	0.0000	0.0000	0.0000	250	650	11-20-73	
6	STIRL	STIRLING-1472F	1990	0.5	2.0	2.0	2.0	Y	Y	N	0.4172	0.0891	0.2037	0.3077	0.0660	0.0000	0.0000	228	500	11-16-78	
7	HEGTAS	HELIUM-GT-85-REC	1970	50.0	300.0	300.0	300.0	Y	Y	N	0.4468	0.2737	1.7050	0.3210	0.0000	0.0000	0.0000	250	400	01-04-79	
8	HEGT00	HELIUM-GT-60-REC	1970	50.0	300.0	300.0	300.0	Y	Y	N	0.4297	0.1910	1.5600	0.2590	0.0000	0.0000	0.0000	250	550	01-04-79	
9	HEGT00	HELIUM-GT-00-REC	1970	50.0	300.0	300.0	300.0	Y	Y	N	0.6044	0.4000	0.2270	0.1760	0.0000	0.0000	0.0000	250	600	01-04-79	
10	FCNCL	FUEL-CL-MOLTCAR8	1970	100.0	1000.0	1000.0	1000.0	Y	Y	N	0.4783	0.0046	0.0245	0.3040	0.0000	0.0000	0.0000	250	650	11-16-78	
11	FCNCL	FUEL-CL-STMTB-CO	1970	125.0	1250.0	1250.0	1250.0	Y	Y	N	0.2873	0.3150	0.0000	0.4910	0.3150	0.0000	0.0000	250	500	04-22-79	
12	ICGTST	INT-GAS-GTST-12/	1970	80.0	500.0	500.0	500.0	Y	Y	N	0.3100	0.3225	0.0000	0.4000	0.3225	0.0000	0.0000	250	600	11-16-78	
13	GTSDAR	GT-IRSC-10/1750R	1978	10.0	60.0	60.0	60.0	Y	Y	N	0.4941	0.0820	0.2989	0.2900	0.0000	0.0000	0.0000	250	600	11-16-73	
14	GTACR8	GT-IRSC-R8/2200R	1985	14.0	136.0	136.0	136.0	Y	Y	N	0.4803	0.1564	0.1715	0.2700	0.0000	0.0000	0.0000	250	600	11-16-73	
15	GTAC12	GT-IRSC-12/2200R	1985	14.0	143.0	143.0	143.0	Y	Y	N	0.5161	0.2437	0.2703	0.3050	0.0000	0.0000	0.0000	250	600	11-16-73	
16	GTAC16	GT-IRSC-16/2200R	1970	14.0	143.0	143.0	143.0	Y	Y	N	0.5021	0.2609	0.1929	0.3230	0.0000	0.0000	0.0000	250	600	11-16-78	
17	GTAC16	GT-IRSC-16/2600R	1970	20.0	200.0	200.0	200.0	Y	Y	N	0.3991	0.0209	0.0155	0.3150	0.0000	0.0000	0.0000	250	600	11-16-78	
18	CC1626	GTST-16/2600/146	1970	20.0	197.0	197.0	197.0	Y	Y	N	0.2260	0.2355	0.0220	0.4616	0.2355	0.0220	0.0220	250	450	11-16-78	
19	CC1622	GTST-16/2200/146	1970	26.0	165.0	165.0	165.0	Y	Y	N	0.2504	0.2496	0.0275	0.4619	0.2496	0.0275	0.0275	250	450	11-16-73	
20	CC1222	GTST-12/2200/146	1985	14.0	143.0	143.0	143.0	Y	Y	N	0.2499	0.2604	0.0293	0.4665	0.2604	0.0243	0.0243	250	450	11-16-73	
21	CC0822	GTST-08/2200/146	1985	14.0	136.0	136.0	136.0	Y	Y	N	0.2957	0.3082	0.0200	0.4613	0.3082	0.0289	0.0289	250	450	11-16-78	
22	STIG15	STIG-15-16/2200F	1970	22.0	220.0	220.0	220.0	Y	Y	N	0.0130	0.0000	0.0000	0.3810	0.0000	0.0000	0.0000	250	430	11-16-78	
23	STIG10	STIG-10-16/2200F	1970	19.0	190.0	190.0	190.0	Y	Y	N	0.1325	0.0000	0.0000	0.3591	0.0000	0.0000	0.0000	250	430	11-16-78	
24	STIG10	STIG-10-16/2200F	1970	19.0	190.0	190.0	190.0	Y	Y	N	0.2100	0.0000	0.0000	0.3352	0.0000	0.0000	0.0000	250	450	11-20-78	
25	DEADV3	DIESEL-ADVANCED-	1970	2.0	15.0	15.0	15.0	Y	Y	N	0.3598	0.4230	0.0000	0.3710	0.0000	0.0000	0.0000	229	249	11-16-78	
26	DEADV2	DIESEL-ADVANCED-	1970	2.0	15.0	15.0	15.0	Y	Y	N	0.2540	0.0000	0.0000	0.3710	0.0000	0.0000	0.0000	229	249	11-16-78	
27	DEADV1	DIESEL-ADVANCED-	1970	2.0	15.0	15.0	15.0	Y	Y	N	0.3910	0.0000	0.0000	0.3710	0.0000	0.0000	0.0000	150	227	11-16-78	
28	DEH01	ADV-DIESEL-HEAT-	1970	2.0	15.0	15.0	15.0	Y	Y	N	0.5092	0.4036	0.5000	0.4012	0.0197	0.5000	0.0000	220	500	11-16-78	
29	DES0A3	DIESEL-SOA-3	1978	0.3	10.0	10.0	10.0	Y	Y	N	0.3258	0.4230	0.0000	0.3610	0.0000	0.0000	0.0000	250	450	11-16-78	
30	DES0A2	DIESEL-SOA-2	1978	0.3	10.0	10.0	10.0	Y	Y	N	0.4010	0.0000	0.0000	0.3610	0.0000	0.0000	0.0000	100	154	11-16-78	
31	DES0A1	DIESEL-SOA-1	1978	0.3	10.0	10.0	10.0	Y	Y	N	0.5383	0.3296	0.3167	0.2920	0.0000	0.0000	0.0000	250	600	11-16-78	
32	GTSDAD	GT-IRSC-10/2000R	1978	13.0	72.0	72.0	72.0	Y	Y	N	0.4030	0.0554	0.6556	0.3570	0.0000	0.0000	0.0000	250	600	11-16-73	
33	GTR003	GT-85RE-08/2200R	1985	13.0	130.0	130.0	130.0	Y	Y	N	0.4030	0.0554	0.6556	0.3570	0.0000	0.0000	0.0000	250	600	11-16-73	
34	GTR012	GT-85RE-12/2200R	1985	14.0	137.0	137.0	137.0	Y	Y	N	0.4077	0.0897	0.5019	0.3580	0.0000	0.0000	0.0000	250	600	11-16-78	
35	GTR016	GT-85RE-16/2200R	1985	14.0	138.0	138.0	138.0	Y	Y	N	0.4251	0.0315	0.3023	0.3490	0.0000	0.0000	0.0000	250	600	11-16-78	
36	GTR005	GT-60RE-08/2200R	1985	13.0	130.0	130.0	130.0	Y	Y	N	0.4722	0.1399	0.1411	0.3200	0.0000	0.0000	0.0000	250	600	11-16-78	
37	GTR212	GT-60RE-12/2200R	1985	13.0	130.0	130.0	130.0	Y	Y	N	0.4475	0.0998	0.1818	0.3300	0.0000	0.0000	0.0000	250	600	11-16-78	
38	GTR216	GT-60RE-16/2200R	1970	14.0	139.0	139.0	139.0	Y	Y	N	0.4465	0.0983	0.2117	0.3370	0.0000	0.0000	0.0000	250	600	11-16-73	
39	GTR008	GT-85RE-08/2600R	1970	17.0	169.0	169.0	169.0	Y	Y	N	0.3302	0.0246	0.4617	0.3510	0.0000	0.0000	0.0000	250	600	11-16-73	
40	GTR012	GT-85RE-12/2600R	1970	19.0	180.0	180.0	180.0	Y	Y	N	0.3330	0.0106	0.3486	0.3640	0.0000	0.0000	0.0000	250	600	11-16-73	
41	GTR016	GT-85RE-16/2600R	1970	19.0	180.0	180.0	180.0	Y	Y	N	0.3503	0.0560	0.2182	0.3570	0.0000	0.0000	0.0000	250	600	11-16-78	
42	GTR008	GT-60RE-08/2600R	1970	17.0	170.0	170.0	170.0	Y	Y	N	0.4497	0.3540	0.0124	0.3100	0.0000	0.0000	0.0000	250	600	11-16-73	
43	GTR312	GT-60RE-12/2600R	1970	19.0	190.0	190.0	190.0	Y	Y	N	0.3816	0.1419	0.0133	0.3420	0.0000	0.0000	0.0000	250	600	11-16-78	
44	GTR316	GT-60RE-16/2600R	1970	19.0	190.0	190.0	190.0	Y	Y	N	0.3844	0.1486	0.0270	0.3390	0.0000	0.0000	0.0000	250	600	11-16-78	
45	FCPADS	FUEL-CL-FINOSACID	1985	1.0	10.0	10.0	10.0	Y	Y	N	0.1700	0.0000	0.0000	0.3900	0.0000	0.0000	0.0000	160	600	04-22-79	
46	FCNCLS	FUEL-CL-MOLTCARD	1970	4.4	25.0	25.0	25.0	Y	Y	N	0.2330	0.0000	0.0000	0.4120	0.0000	0.0000	0.0000	200	650	11-16-73	

Figure 12-5. Energy Conversion System Characteristics

ORIGINAL PAGE IS  
OF GOOD QUALITY




Table 12-6

GLOSSARY OF ABBREVIATIONS  
ENERGY CONVERSION SYSTEMS (ECS) AND FUELS

ECS - Fuel Abbreviation	ECS TYPE	DESCRIPTION	FUEL & UTILIZATION SYSTEM	ECS Performance Characteristics Number	STATUS (State of Art or Advanced)
STM141-Coal F	Steam Turbine	Throttle P=1465 psia; T=1000°F	Coal-Flue Gas Desulfurization	1	SOA
STM141-Coal A	"	"	Coal-Atmospheric Fluidized Bed	1	ADV
STM141-Residual	"	"	Residual-Petroleum or Coal Derived	1	SOA
STM088-Coal F	"	P=865 psia; T=825°F	Coal-Flue Gas Desulfurization	2	SOA
STM088-Coal A	"	"	Coal-Atmospheric Fluidized Bed	2	SOA
STM088-Residual	"	"	Residual-Petroleum or Coal Derived	2	ADV
PFBSTM	PFB Steam Turbine	Gas Turbine T=1000°F Steam Turbine P=1465 psia, T=1000°F	Coal-Pressurized Fluidized Bed	3	ADV
TISTMI-Coal F	Thermionic-Steam Turbine	"	Coal-Flue Gas Desulfurization	4	ADV
TISTMT-Residual	"	"	Residual-Petroleum or Coal Derived	4	ADV
TIHRSG-Coal F	Thermionic and HRSG(1)	"	Coal-Flue Gas Desulfurization	5	ADV
TIHRSG-Residual	"	"	Residual-Petroleum or Coal Derived	5	ADV
STIRL-Coal	Stirling Engine	Helium @ T=1472°F	Coal-Flue Gas Desulfurization	6	ADV
STIRL-Residual	"	"	Residual-Petroleum or Coal Derived	6	ADV
STIRL-Distillate	"	"	Distillate-	6	ADV
HEGT85-Coal A	Closed Cycle Gas Turbine	Helium @ T=1500°F; Regen. Eff.=85%	Coal-Atmospheric Fluidized Bed	7	ADV
HEGT60-Coal A	"	"	"	8	ADV
HEGT0-Coal A	"	"	"	9	ADV
FCMCL-Coal	Fuel Cell, Molten Carbonate, HRSG	"	Coal-Integrated Gasifier	10	ADV
FCSTCL-Coal	"	Steam Turbine P=1465 psia; T=1000°F	"	11	ADV
FCMCD5-Distillate	"	HRSG	Distillate-Petroleum & Coal Derived	46	ADV
FCPAD5-Distillate	"	Phosphoric Acid, HRSG	"	45	ADV
GTSOAR-Residual	Gas Turbine AC(2) with	HRSG, P/P=10, T=1750°F	Residual -	13	SOA
GTSOAR-Distillate	"	"	Distillate-	32	SOA
GIAC08-Residual(4)	"	"	Residual -	14	ADV
GTAC12-Residual	"	"	"	15	ADV
GTAC16-Residual	"	"	"	16	ADV
GTWC16-Residual	"	WC(3)	"	17	ADV
CC1622-Residual	Combined Cycle, AC, P/P=16, T=2200; STM TURB P=865, T=825°F	"	"	19	ADV
CC1222-Residual	"	P/P=12, T=2200; P=1465, T=1000°F	"	20	ADV
CC0822-Residual	"	P/P=8, T=2200; P=1465, T=1000°F	"	21	ADV
CC1626-Residual	"	MC, P/P=16, T=2600; P=1465, T=1000°F	"	18	ADV
IG GT ST-Coal	"	AC, P/P=12, T=2100; P=1465, T=1000°F	Coal, Integrated Gasifier	12	ADV
STIG15-Residual	Steam Injected Gas Turbine, AC, HRSG, P/P=16, T=2200, 15% Super. Steam	"	Residual-Petroleum or Coal Derived	22	ADV
STIG10-Residual	"	"	"	23	ADV
STIG15-Residual	"	"	"	24	ADV
GTRA08-Distillate	Gas Turbine, AC, w/HRSG, Reg. Eff.=85%, P/P=8, T=2200°F	"	Distillate,	33	ADV
GTRA12-Distillate	"	"	"	34	ADV
GTRA16-Distillate	"	"	"	35	ADV
GTR208-Distillate	"	=60%, P/P=8, T=2200°F	"	36	ADV
GTR212-Distillate	"	"	"	37	ADV
GTR216-Distillate	"	"	"	38	ADV
GTRW08-Distillate	"	MC, =85%, P/P=8, T=2600°F	"	39	ADV
GTRW12-Distillate	"	"	"	40	ADV
GTRW16-Distillate	"	"	"	41	ADV
GTR308-Distillate	"	"	"	42	ADV
GIR312-3-Distillate	"	"	"	43	ADV
GIR316-3-Distillate	"	"	"	44	ADV
DESOA1-3-Distillate	Medium Speed Diesel with 175°F Jacket Water	"	"	29-31	SOA
DESOA 7-3-Residual	"	"	Residual,	29-31	SOA
DESAD1-3-Residual	"	250°F	"	25-27	ADV
DEINPM-Residual	"	"	w/Vapor Compression Heat Pump	28	ADV

(1) HRSG - Heat Recovery Steam Generator  
(2) AC - Air Cooled

(3) WC - Water Cooled  
(4) Detailed analysis of the effect of cycle variations on simple, steam injected and regenerative gas turbines and combined cycles are shown in Volume VI - Computer Data.



• ECS=ENERGY CONVERSION SYSTEM

Figure 12-6. CTAS Matching of Process Model to Energy Conversion Systems Performance Maps

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

1 SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND EGCS\*\*

INDUSTRY 20461 MW 26.50 PROCESS MILLIONS BTU/HR 659.0 PROCESS TEMP(F) 250. PRODUCT NET-CORN-MIL HOURS PER YEAR 6600.

UTILITY FUEL	COAL	POWER TO HEAT RATIO 0.148		WASTE FUEL		COGEN		COGEN		AUX		UTILIT		TOTAL		NET* TOTAL	FESR	POWER	HEAT		
		BTU/HR	10000	BTU/HR	10000	BTU/HR	10000	BTU/HR	10000	BTU/HR	10000	BTU/HR	10000	BTU/HR	10000					BTU/HR	10000
0 DIUCON N 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
1 ST1141 3TH-TURB-1	POWR	0	189	405	323	87	28	305	0	0	0	0	0	0	0	0	0	0	0	0	
1 ST1141 3TH-TURB-1	HEAT	0	386	1008	659	198	58	0	-318	1008	RESIDUAL	693	0	0	0	0	0	0	0	0	0
1 ST1141 3TH-TURB-1	POWR	0	189	499	323	87	28	399	0	0	0	0	0	0	0	0	0	0	0	0	
1 ST1141 3TH-TURB-1	HEAT	0	386	1008	659	198	58	0	-318	1008	COAL-FOD	693	0	0	0	0	0	0	0	0	0
1 ST1141 3TH-TURB-1	POWR	0	189	499	323	87	28	399	0	0	0	0	0	0	0	0	0	0	0	0	
1 ST1141 3TH-TURB-1	HEAT	0	386	1008	659	198	58	0	-318	1008	COAL-AFB	693	0	0	0	0	0	0	0	0	0
2 ST1100B 3TH-TURB-8	POWR	0	189	598	410	97	28	293	0	0	0	0	0	0	0	0	0	0	0	0	
2 ST1100B 3TH-TURB-8	HEAT	0	386	1008	659	198	58	0	-318	1008	RESIDUAL	774	0	0	0	0	0	0	0	0	0
2 ST1100B 3TH-TURB-8	POWR	0	189	598	410	97	28	293	0	0	0	0	0	0	0	0	0	0	0	0	
2 ST1100B 3TH-TURB-8	HEAT	0	386	1008	659	198	58	0	-318	1008	COAL-FOD	774	0	0	0	0	0	0	0	0	0
2 ST1100B 3TH-TURB-8	POWR	0	189	598	410	97	28	293	0	0	0	0	0	0	0	0	0	0	0	0	
2 ST1100B 3TH-TURB-8	HEAT	0	386	1008	659	198	58	0	-318	1008	COAL-AFB	774	0	0	0	0	0	0	0	0	0
3 PFD5TH PFB-3THTB-	POWR	0	189	378	223	87	28	619	0	0	0	0	0	0	0	0	0	0	0	0	
3 PFD5TH PFB-3THTB-	HEAT	0	659	1118	659	287	84	0	-884	1118	COAL-PFB	924	0	0	0	0	0	0	0	0	0
4 T15TH11 T1-3THTB-1	POWR	0	187	321	179	87	28	671	0	0	0	0	0	0	0	0	0	0	0	0	
4 T15TH11 T1-3THTB-1	HEAT	0	710	1220	639	370	108	0	-832	1220	RESIDUAL	982	0	0	0	0	0	0	0	0	0
4 T15TH11 T1-3THTB-1	POWR	0	187	321	179	87	28	671	0	0	0	0	0	0	0	0	0	0	0	0	
4 T15TH11 T1-3THTB-1	HEAT	0	710	1220	639	370	108	0	-832	1220	COAL	982	0	0	0	0	0	0	0	0	0
5 T11R50 THERMIONIC	POWR	0	164	691	489	87	28	224	0	0	0	0	0	0	0	0	0	0	0	0	
5 T11R50 THERMIONIC	HEAT	0	231	671	659	137	40	0	-862	1220	COAL	916	0	0	0	0	0	0	0	0	0
5 T11R50 THERMIONIC	POWR	0	164	691	489	87	28	224	0	0	0	0	0	0	0	0	0	0	0	0	
5 T11R50 THERMIONIC	HEAT	0	231	671	659	137	40	0	-862	1220	RESIDUAL	916	0	0	0	0	0	0	0	0	0
6 ST1RL STIRLING-1	POWR	0	139	352	199	87	28	668	0	0	0	0	0	0	0	0	0	0	0	0	
6 ST1RL STIRLING-1	HEAT	0	677	1457	659	403	118	0	-885	1457	DISTILLA	940	0	0	0	0	0	0	0	0	0
6 ST1RL STIRLING-1	POWR	0	139	352	199	87	28	668	0	0	0	0	0	0	0	0	0	0	0	0	
6 ST1RL STIRLING-1	HEAT	0	677	1457	659	403	118	0	-885	1457	DISTILLA	940	0	0	0	0	0	0	0	0	0

Figure 12-7. Fuel Energy Saved Report

Part 2. This report is organized by industrial process; e.g., industry 20461, a wet corn milling process, and then data for each ECS-fuel combination and both power and heat matches. The first line listed in each process is for the nocogeneration matched to the process.

The Report 5.1 heading on each page gives data on the industrial process being matched including waste fuel which is available to the ECS from the process. The column headed "Waste Fuel Used" shows the actual amount of fuel used in the ECS. "AUX PROCESS BOILER" is the process or auxiliary boiler fuel. All of the fuel columns except "Waste Fuel Use" give the combined total of fossil and waste fuel. The fuel energy saved ratio, "FESR", which is equal to total nocogeneration fuel minus cogeneration fuel all divided by the total cogeneration fuel shown in the "NET = TOTAL + UTILITY" column. In a heat match case where excess power is exported to the utility (indicated by a negative value for "UTILITY FUEL USED") the absolute value of this displaced utility fuel must be added to both nocogeneration and cogeneration "NET = TOTAL + UTILITY" fuel values in calculating the FESR. The values given in the columns labelled "POWER FACTOR" and "HEAT FACTOR" did not prove useful in the study. A 1 in the fail column indicates that the ECS cannot supply heat at the required temperature and a 10 indicates that the ECS is outside the size range for which the cost data is considered accurate.

### Report 5.3 - Capital Cost Estimating

The second step in establishing the economic data base is capital cost estimating for each case that was not previously flagged for having exceeded the temperature limits of the ECS or for having excess heat generated.

Component Cost Table. The Component Cost Table, Figure 12-8, contains all major components used in each ECS. A component may be part of many different ECS's, but it occurs only once on this table. This provides a consistent estimate for that component independent of ECS application. The component cost table is described in Table 12-7. A list of the components making up each on-site nocogeneration or cogeneration system

Island	Major Comp.	Comp.	Component Name	Units of		Component 103		Fraction Material		Fraction Labor	
				Meas.	Size	Min.	Max.	Min.	Max.	Min.	Max.
2	21	1	158PSI-OIL-BOILER-FE	1.00	353.00	16.90	59.30	0.41	0.40	0.32	0.31
2	21	2	895PSI-OIL-BOILER-FE	1.00	284.00	21.40	74.90	0.39	0.38	0.30	0.29
2	21	3	152PSI-OIL-BOILER-F	1.00	298.00	19.70	68.90	0.42	0.40	0.32	0.31
2	21	4	158PSI-OIL-BOILER-PK	1.00	50.00	15.02	64.81	0.71	0.71	0.64	0.64
2	21	5	895PSI-OIL-BOILER-PK	1.00	100.00	0.47	20.43	0.70	0.70	0.65	0.65
2	21	6	152PSI-OIL-BOILER-PK	1.00	125.00	20.43	80.24	0.70	0.70	0.65	0.65
2	21	7	158PSI-COAL-BOILER-F	1.00	227.00	0.15	1.16	0.10	0.10	0.15	0.15
2	22	8	895PSI-COAL-BOILER-F	1.00	280.00	3.50	13.00	0.11	0.08	0.08	0.04
2	22	9	152PSI-COAL-BOILER	1.00	200.00						
2	22	10	COAL-HNDL	1.00	50.00						
1	1	2	OIL-HNDL	1.00	50.00						
1	1	11	AFB-HECT85	2.00	50.00						
2	23	12	AFB-HECT85	2.00	50.00						
2	23	13	AFB-HECT100	2.00	50.00						
2	23	14	AFB-HECT160	2.00	50.00						
2	25	15	GASIFIER-MCFC	1.00	1122.00						
2	25	16	SMALL-TEXACO-GASIFIE	1.00	510.00						
2	25	17	LARGE-TEXACO-GASIFIE	1.00	2040.00						
2	28	18	REFORMER-DIST-OIL	1.00	9.00						
2	28	19	GT-STM-INJECTED	2.00	20.00						
3	31	26	GT-STM-850PSI	2.00	5.00						
3	30	31	STM-TURB-1450	2.00	7.50						
3	30	32	STM-TURB-1450	2.00	5.00						
2	24	33	PFB-SMALL-BOILER	1.00	984.00						
2	24	34	PFB-LARGE-BOILER	1.00	1268.00						
2	24	35	EXPANSION-TG-SMALL	2.00	26.00						
4	43	36	EXPANSION-TG-LARGE	2.00	52.00						
4	43	37	LIMESTONE-SMALL	1.00	985.00						
1	1	3	LIMESTONE-LARGE	1.00	1959.00						
1	1	3	LIMESTONE-LARGE	1.00	7870.00						
3	31	39	SIIG-WATER-COND	5.00	100.00						
4	40	40	HRSG-800F-158	1.00	60.00						
4	40	41	HRSG-800F-420	1.00	57.00						
4	40	42	HRSG-1000F-158	1.00	90.00						
4	40	43	HRSG-1000F-420	1.00	86.00						
4	40	44	HRSG-1000F-630	1.00	83.00						
4	40	45	HRSG-1000F-895	1.00	79.00						
4	40	46	HRSG-1200F-158	1.00	115.00						
4	40	47	HRSG-1200F-420	1.00	114.00						
4	40	48	HRSG-1200F-630	1.00	118.00						
4	40	49	HRSG-1200F-895	1.00	109.00						
4	40	50	HRSG-1200F-1525	1.00	120.00						
4	40	51	HRSG-1400F-158	1.00	150.00						
4	40	52	HRSG-1400F-420	1.00	148.00						
4	40	53	HRSG-1400F-630	1.00	148.00						
4	40	54	HRSG-1400F-895	1.00	146.00						
4	40	55	HRSG-1400F-1525	1.00	139.00						
5	51	56	PUMPS-CIRC-WATER	1.00	10.00						
5	52	57	SURFACE-CONDENSERS	1.00	10.00						
5	53	58	VAPOR-CONDENSERS	1.00	0.50						
5	53	59	COOLING-TOWERS	4.00	5.00						
5	50	60	GAS-TURB-HECT85	2.00	50.00						
3	31	61	GAS-TURB-HECT100	2.00	50.00						
3	31	62	GAS-TURB-HECT160	2.00	50.00						

DATA OMITTED BECAUSE OF PROPRIETARY NATURE

DATA OMITTED BECAUSE OF PROPRIETARY NATURE

ORIGINAL PAGE IS OF POOR QUALITY

Figure 12-8. CTAS Capital Cost of ECS Components

Island	Major Comp.	Comp.	Component Name	Units of		Size		Component 10 <sup>3</sup> \$		Fraction Material		Fraction Labor	
				Meas.	Max.	Min.	Max.	Min.	Max.	Min.	Max.	Min.	Max.
3	31	66	GAS-TURB-CC-OXT	2.00	31.50	94.50	4.40	11.21	0.11	0.03	0.10	0.06	
3	31	67	GAS-TURB-CC-30XT	2.00	28.70	86.20	4.23	10.77	0.11	0.08	0.10	0.06	
3	32	68	DIESEL-DIST	2.00	0.30	1.00	0.11	0.35	0.19	0.19	0.19	0.19	
3	32	69	DIESEL-ADV-SMALL	2.00	1.00	15.00	0.97	5.06	0.12	0.09	0.12	0.09	
3	32	70	DIESEL-ADV-LARGE	2.00	15.00	30.00	5.06	10.12	0.09	0.09	0.09	0.09	
7	70	71	HX-STEAM-WATER	1.00	79.50	800.00	0.84	3.65	0.65	0.55	0.65	0.55	
7	70	72	HX-THERMIONIC	1.00	960.40	3357.00	0.83	6.94	0.50	0.40	0.50	0.40	
3	32	73	HEATPUMP-ADV-DIESEL	2.00	0.01	3.00	0.01	0.30	0.12	0.12	0.11	0.11	
2	23	74	AFB-1465-100AF										
2	23	75	AFB-865-825F										
2	23	76	AFB-PROCESS-STEAM										
3	33	77	THERMIONIC-COAL-SMAL	1.00	200.00	1220.00	6.54	33.42	1.69	1.18	1.53	1.07	
3	33	78	THERMIONIC-COAL-LRG	1.00	1220.00	2456.00	33.42	66.84	1.18	0.76	1.07	0.37	
8	80	80	MASTER-CONTROL-SYSTE	2.00	5.00	500.00	0.08	1.50	0.15	0.15	0.25	0.25	
8	81	81	ELECTRIC-PLANT	2.00	5.00	500.00	0.08	1.50	0.03	2.00	0.03	2.00	
8	82	82	PIPING-DUCTING-WIRIN	2.00	5.00	500.00	0.08	1.50	0.06	3.75	0.06	3.75	
8	83	83	STRUCTURES-MISC	2.00	5.00	500.00	0.08	1.50	0.07	3.75	0.07	3.75	
8	84	84	POWER-PLANT-STRUCTUR	2.00	5.00	500.00	0.08	1.50	0.07	4.00	0.07	3.50	
5	50	89	COOL-TOWERS-HELIUM-A	2.00	50.00	300.00	0.96	3.00	0.15	0.10	0.50	0.40	
2	29	90	STIRLING-SMALL-RESID	1.00	6.17	24.68	0.01	0.03	0.17	0.12	0.17	0.12	
2	29	91	STIRLING-LARGE-RESID	1.00	24.68	49.36	0.03	0.06	0.12	0.12	0.12	0.12	
2	29	92	STIRLING-SMALL-DIST	1.00	6.17	24.68	0.01	0.03	0.17	0.12	0.17	0.12	
2	29	93	STIRLING-LARGE-DIST	1.00	24.68	49.36	0.03	0.06	0.12	0.12	0.12	0.12	
2	29	94	STIRLING-COAL-SMALL	1.00	6.17	24.68	0.37	0.87	0.15	0.09	0.20	0.14	
2	29	95	STIRLING-COAL-LARGE	1.00	24.68	100.00	0.37	2.25	0.12	0.12	0.20	0.14	
2	29	96	STIRLING-GEN-SMALL	1.00	6.17	24.68	0.15	0.56	0.17	0.12	0.19	0.12	
2	29	97	STIRLING-GEN-LARGE	1.00	24.68	49.36	0.56	1.12	0.12	0.12	0.12	0.12	
3	35	98	MOLTEN-CARBON-TCG	2.00	100.00	1000.00	17.30	114.30	0.10	0.30	0.15	0.15	
3	35	99	PHOSPH-CARBON-FCMCS	2.00	4.41	25.00	0.37	4.63	0.10	0.10	0.15	0.15	
3	36	100	PHOSPH-ACID-FC	1.00	90.00	90.00	0.16	1.91	0.10	0.10	0.15	0.15	
3	31	101	GT50AR	2.00	10.00	100.00	2.58	14.75	0.14	0.10	0.03	0.04	
3	31	102	GT50AD	2.00	12.00	120.00	1.98	13.10	0.14	0.10	0.03	0.04	
3	31	103	GTAC08	2.00	13.00	130.00	2.25	15.50	0.14	0.10	0.03	0.04	
3	31	104	GTAC12	2.00	13.60	136.00	2.45	18.00	0.14	0.10	0.03	0.04	
3	31	105	GTAC16	2.00	13.60	136.00	2.70	19.70	0.14	0.10	0.03	0.04	
3	31	106	GTAC16	2.00	18.20	182.00	3.50	20.70	0.14	0.10	0.03	0.04	
3	31	107	GTR08	2.00	12.30	123.00	2.86	18.70	0.14	0.10	0.03	0.04	
3	31	108	GTR12	2.00	13.00	130.00	3.10	20.50	0.14	0.10	0.03	0.04	
3	31	109	GTR16	2.00	13.20	132.00	3.40	22.30	0.14	0.10	0.03	0.04	
3	31	110	GTR08	2.00	15.60	156.00	3.55	20.00	0.14	0.10	0.03	0.04	
3	31	111	GTRW12	2.00	17.40	174.00	3.85	21.70	0.14	0.10	0.03	0.04	
3	31	112	GTRW16	2.00	17.50	175.00	4.10	23.00	0.14	0.10	0.03	0.04	
3	31	113	GTR208	2.00	12.40	124.00	2.60	17.50	0.14	0.10	0.03	0.04	
3	31	114	GTR212	2.00	13.10	131.00	2.90	19.20	0.14	0.10	0.03	0.04	
3	31	115	GTR216	2.00	13.20	131.00	3.10	21.00	0.14	0.10	0.03	0.04	
3	31	116	GTR308	2.00	15.80	158.00	3.25	19.10	0.14	0.10	0.03	0.04	
3	31	117	GTR312	2.00	17.50	175.00	3.50	20.60	0.14	0.10	0.03	0.04	
3	31	118	GTR316	2.00	17.70	177.00	3.80	22.00	0.14	0.10	0.03	0.04	
3	33	119	THERMIONIC-OIL-SMALL	1.00	200.00	1220.00	5.67	30.30	1.41	0.94	1.27	0.91	
3	33	120	THERMIONIC-OIL-LARGE	1.00	1220.00	2456.00	30.30	60.60	0.94	0.76	0.71	0.74	

DATA OMITTED BECAUSE OF PROPRIETARY NATURE

Figure 12-8 (Cont'd). CTAS Capital Cost of ECS Components

Table 12-7

CONTENTS OF COMPONENT COST TABLE

Island Number:	Groups components into specific costing areas.
Component Number:	Unique number assigned to this component.
Component Name:	For information only.
Unit of Measure:	Determines basis for cost function.
	1 = millions Btu/hr
	2 = Megawatts. (This code is an indicator and for special components may be overridden in COSTANL.)
Minimum & Maximum Size:	In the same units as the unit of measure. When the maximum size is exceeded, multiple units are used. When unit is below minimum, no special actions are taken.
Component Cost:	Cost of major component (a function of size).
Material Cost:	Cost of installation material as a fraction of component cost (a function of size).
Labor Cost:	Cost of installed labor as a fraction of component cost (a function of size).

ECS-fuel type is contained in Component Logic Table included in the computer program. When a component is to be costed and its size has been determined in terms of Units of Measure, its cost as an exponential function of size is calculated from the data in Figure 12-8 Component Cost Table. For example, if the component list called for a "COMP" 101, a residual-fired state-of-the-art gas turbine, "GTSOAR" and the matching routine called for a size of 50 MW, the component equipment cost is:

$$C = C_{MAX} \left( \frac{S}{S_{MAX}} \right)^X$$

where

$$X = \frac{\log \left( \frac{C_{MAX}}{C_{MIN}} \right)}{\log \left( \frac{S_{MAX}}{S_{MIN}} \right)} = \frac{\log \left( \frac{14.75}{2.28} \right)}{\log \left( \frac{100}{0} \right)} = 0.811$$

$$C_{\text{MIN}} = \text{component cost for min size} = \$2.28 \times 10^6$$

$$C_{\text{MAX}} = \text{component cost for max size} = \$14.75 \times 10^6$$

$$S_{\text{MIN}} = \text{min size} = 10 \text{ MW}$$

$$S_{\text{MAX}} = \text{max size} = 100 \text{ MW}$$

$$S = \text{size to be costed} = 50 \text{ MW}$$

$$C = \text{component equipment cost} = 14.75 \times 10^6 \left( \frac{50}{100} \right)^{.811} = \$8.41 \times 10^6$$

or \$168/kW

The fraction,  $f_M$ , of the equipment cost that is installation material cost is also assumed to vary exponentially with size and in the above example is:

$$f_M = .10 \left( \frac{50}{100} \right)^{-.146} = 0.111$$

where

$$x = \frac{\log \left( \frac{.14}{.10} \right)}{\log \left( \frac{10}{100} \right)} = -0.146$$

and the installation material cost =  $.111 \times 8.41 \times 10^6 = \$0.931 \times 10^6$ . In a similar fashion, the fraction,  $f_L$ , of the equipment cost that is installation labor is:

$$f_L = .06 \left( \frac{50}{100} \right)^{-.125} = 0.065$$

where

$$x = \frac{\log \left( \frac{.08}{.06} \right)}{\log \left( \frac{10}{100} \right)} = -0.125$$

and the installation direct labor cost =  $.065 \times 8.41 \times 10^6 = \$0.550 \times 10^6$ . The indirect labor field cost is 0.9 times the installation direct labor or  $0.9 \times .550 \times 10^6 = \$0.495 \times 10^6$ .



Cost Analysis Program - COSTANL. The Component Cost Table and Component Logic Tables are used in program COSTANL to update the economic data base with the total installed capital cost. A sample page from a Report 5.3 cost report generated in this program is shown in Figure 12-9.

For each case the Component Logic Table is interrogated and each component specified is sized and costed as shown above. Requirements that exceed the component maximum size result in multiple units of that component. The special logic indicators direct the program to specific equations for sizing components, such as heat recovery steam generators and prime movers. Fuel handling systems and boilers are selected, as required, to be compatible with the fuel used on-site. Indirect costs are added to the total direct costs to give the total installed cost.

Report 5.3: Capital Costs by Island for Selected Process-ECS Matches is contained in Volume VI, Part 1. Table 12-8 shows the cogeneration ECS-process matches which were selected as representative by NASA and GE and included in the report. At the beginning of each process matched, a nocogeneration coal-fired process boiler capital cost by island breakdown is included. The capital costs of all matched systems was calculated but only the total costs are shown in Reports 5.2 and 5.4 with the coal-fired nocogeneration matches in Volume VI, Part 1, and for oil-fired nocogeneration in Part 2.

#### Report 5.4 - Return on Investment (ROI) and Levelized Annual Energy Costs (LAEC) Analysis

The third and last step in developing the economic data base is the calculation of the percentage Return On Investment (ROI) and Levelized Annual Energy Costs (LAEC). The computer system flow chart for step 3 is shown in Figure 12-10. These calculations use data already in the economics data base, such as the capital costs and the on-site fuel use, power generation, power requirements and auxiliary boiler requirements.

Economic groundrules used in this calculation are shown in Table 12-9.

DATE 03/31/79  
I SE-PEO ADV. DES. ENGRG.

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.3  
CAPITAL COSTS BY ISLAND FOR SELECTED PROCESS-ECS MATCHES

PROCESS 20111

ECS DEADW3      PROCESS MEGAWATTS      1.94      PROCESS TEMP.      250.      PROCESS HEAT(BTU\*10\*\*6)      24.  
DIESEL-ADVANCED-3      SITE FUEL= RESIDUAL      COGEN FUEL BTU\*10\*\*6=      18.      KW FUEL=      5226.

ISLAND DESCRIPTION	COMPONENT DESCRIPTION	*****COSTS - MILLIONS 1978*****						TOTAL	TOTAL	SPER-KW FUEL
		MAJOR EQUIPMNT	INSTALL MAT'L	INSTALL LABOR	INDRCT FLD CST	TOTAL INSTALLED	TOTAL			
1. FUEL-HANDLING	1. FUEL-OIL-UNLOADING-S ISLAND TOTAL	0.035 0.035	0.007 0.007	0.042 0.042	0.037 0.037	0.086 0.086	0.121 0.121	0.121 0.121	23.081 23.081	
3. ENERGY-CONVERSION	32. DIESEL-ENGINE-GENERA ISLAND TOTAL	1.453 1.453	0.163 0.163	0.163 0.163	0.146 0.146	0.471 0.471	1.925 1.925	1.925 1.925	368.094 368.094	
2. FUEL-UTILIZATION-CLE	21. OIL-FIRED-BOILER ISLAND TOTAL	0.095 0.095	0.196 0.196	0.299 0.299	0.269 0.269	0.764 0.764	0.859 0.859	0.859 0.859	164.319 164.319	
8. BALANCE-OF-PLANT	84. POWER-PLANT-STRUCTUR	0.	0.064	0.056	0.050	0.169	0.169	0.169	32.400	
	80. MASTER-CONTROL	0.070	0.010	0.017	0.018	0.043	0.113	0.113	21.626	
	81. ELECTRIC-SWITCHGEAR-	0.	0.013	0.013	0.011	0.037	0.037	0.037	7.018	
	82. INTERCONNECTING-PIPI	0.	0.025	0.025	0.022	0.071	0.071	0.071	13.666	
	83. STRUCTURES-MISCELLAN ISLAND TOTAL	0. 0.070	0.056 0.167	0.047 0.157	0.042 0.142	0.145 0.468	0.145 0.536	0.145 102.431	27.721	
TOTAL THIS CASE		1.652	0.532	0.661	0.595	1.788	3.440	3.440	113.746	
INDIRECT COSTS										
	SPARES							0.033		
	START UP							0.028		
	SPARES+STARTUP							0.061		
	CONTINGENCY							0.525		
	ENGINEERING SERVICES							0.210		
	A-E FEE							0.175		
***GRAND TOTAL***								4.412		

12-24

Figure 12-9. Sample Capital Cost Report






Figure 12-10. Data Handling - Economics and Potential National Savings

Table 12-9

**ECONOMIC ANALYSIS GROUND RULES**  
 (All Costs are in 1978 Constant Dollars)

<u>Factor</u>	<u>Value</u>
Annual inflation rate	0
Cost of debt (before taxes) above inflation	3%
Fraction of debt in capital	30%
Cost of preferred equity above inflation	-
Fraction of preferred equity in capital	0
Cost of common equity above inflation	7%
Fraction of common equity in capital	70%
Federal & State income tax rate	50%
Tax depreciation method	Sum of Years Digits
Tax depreciation life	15 Years
Salvage value	0
Investment tax credit	10%
Local real estate taxes and insurance	3%
Useful life of investment	30 Years
First full year of operation	1990
Capital cost escalation rate above inflation	0

Cost of Fuels, Power & Expendables for 1985 in 1978 \$'s

Coal	\$1.80/10 <sup>6</sup> Btu
Distillate Oil (Petroleum or Coal Derived)	\$3.80/10 <sup>6</sup> Btu
Residual Oil (Petroleum or Coal Derived)	\$3.10/10 <sup>6</sup> Btu
Natural Gas	\$2.40/10 <sup>6</sup> Btu
Purchased Power	\$0.033/kWh
Limestone	\$10.00/Ton
Dolomite	\$12.50/Ton

Escalation of Fuels & Power Above Inflation

Coal	1%
Distillate Oil (Petroleum or Coal Derived)	1%
Residual Oil (Petroleum or Coal Derived)	1%
Natural Gas	4.6% (1985-2000)
	1.0% (2000- )
Purchased & Exported Power	1%
Limestone	0
Dolomite	0

Price of surplus power exported to utility = 0.6 x purchased power rate =  
 0.6 x 0.033 = \$0.0198/kWh.

Operating and Maintenance Costs. The operating and maintenance costs were established as a function of ECS and type of fuel used as described in Table 12-10 and shown in Figure 12-11.

Table 12-10

CONTENTS OF OPERATING AND MAINTENANCE TABLE

O&M Costs =  $L*(\text{fuel flow})M + N*(\text{Capital Cost}) + P*(\text{fuel flow}*\text{operating hrs/yr})$

$L*(\text{fuel flow})M$  is cost of operating labor in  $10^6$  \$/yr with fuel flow in Btu/hr.

$N*(\text{Capital Cost})$  is cost of parts for maintenance and major replacements in  $10^6$  \$/yr with capital cost in  $10^6$  \$.

$P*(\text{fuel flow}*\text{operating hrs/yr})$  is cost of limestone, dolomite, ZnO, and water in  $10^6$  \$/yr with fuel flow in  $10^6$  Btu/hr.

L, M, N, and P are stored on this table along with the time for construction. These values depend on the ECS and fuel type.

ROI Analysis Program (CCROI). This program evaluates the year by year cash flow of each case. The cash flow of the nocogeneration case is compared to the cash flow of the cogeneration case, and the discount rate (ROI) is determined that makes the difference in cash flows of these two cases equal to their difference in capital cost. Due to the groundrules established in this study, some cases yield infinite ROI's because both the cogeneration capital cost and annual costs are less than the nocogeneration capital cost and annual costs. Other cases resulted in negative ROI's. These negative values were caused by capital costs favoring cogeneration, but with the cogeneration annual costs exceeding the nocogeneration annual costs. Levelized Annual Energy Costs (LAEC) are not based on incremental costs or cash flows and thus are more continuous than ROI. Levelized capital, taxes and insurance, operating and maintenance, fuel, purchased electricity, and revenue are the components of

RUMH

01/20/79

FUNCTION?	ECS	← DISTILLATE & RESIDUE →			← FGD, PFB, PULVERIZED & GASIFIED →			← AFB →								
		Const. Yrs.	OPM Labor Factor Expon. L	Maint. Mat'l P	Const. Yrs.	OPM Labor Factor Expon. L	Maint. Mat'l P	Const. Yrs.	OPM Labor Factor Expon. L	Maint. Mat'l P						
1530 140	1	2.5	1174.	0.300	0.025	0.	3.0	1751.	0.300	0.025	0.082	3.0	1463.	0.300	0.025	0.119
1540 140	2	2.5	1174.	0.300	0.025	0.	3.0	1751.	0.300	0.025	0.075	3.0	1463.	0.300	0.025	0.119
1550 140	3	0.	0.	0.	0.	0.	2.5	1463.	0.300	0.025	0.272	0.	0.	0.	0.	0.
1560 140	4	2.5	1174.	0.300	0.025	0.006	3.0	1751.	0.300	0.025	0.075	0.	0.	0.	0.	0.
1570 140	5	2.0	270.	0.360	0.025	0.	2.5	536.	0.350	0.025	0.075	0.	0.	0.	0.	0.
1580 140	6	1.5	324.	0.360	0.025	0.	2.0	489.	0.360	0.025	0.075	0.	0.	0.	0.	0.
1590 140	7	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	2.5	355.	0.350	0.025	0.119
1600 140	8	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	2.5	355.	0.350	0.025	0.119
1610 140	9	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	2.5	355.	0.350	0.025	0.119
1620 140	10	0.	0.	0.	0.	0.	3.5	508.	0.340	0.025	0.303	0.	0.	0.	0.	0.
1630 140	11	0.	0.	0.	0.	0.	4.0	1401.	0.300	0.025	0.306	0.	0.	0.	0.	0.
1640 140	12	0.	0.	0.	0.	0.	4.0	1751.	0.300	0.025	0.	0.	0.	0.	0.	0.
1650 140	13	1.5	270.	0.360	0.025	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
1660 140	14	1.5	270.	0.360	0.025	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
1670 140	15	1.5	270.	0.360	0.025	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
1680 140	16	1.5	270.	0.360	0.025	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
1690 140	17	1.5	270.	0.360	0.025	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
1700 140	18	2.5	1174.	0.300	0.025	0.003	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
1710 140	19	2.5	1174.	0.300	0.025	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
1720 140	20	2.5	1174.	0.300	0.025	0.003	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
1730 140	21	1.5	1174.	0.300	0.025	0.003	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
1740 140	22	1.5	270.	0.360	0.025	0.071	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
1750 140	23	1.5	270.	0.360	0.025	0.071	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
1760 140	24	1.5	324.	0.360	0.025	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
1770 140	25	1.5	324.	0.360	0.025	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
1780 140	26	1.5	324.	0.360	0.025	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
1790 140	27	1.5	324.	0.360	0.025	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
1800 140	28	1.5	378.	0.360	0.025	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
1810 140	29	1.5	324.	0.360	0.025	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
1820 140	30	1.5	324.	0.360	0.025	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
1830 140	31	1.5	324.	0.360	0.025	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
1840 140	32	1.5	270.	0.360	0.025	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
1850 140	33	1.5	270.	0.360	0.025	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
1860 140	34	1.5	270.	0.160	0.025	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
1870 140	35	1.5	270.	0.360	0.025	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
1880 140	36	1.5	270.	0.360	0.025	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
1890 140	37	1.5	270.	0.360	0.025	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
1900 140	38	1.5	270.	0.350	0.025	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
1910 140	39	1.5	270.	0.360	0.025	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
1920 140	40	1.5	270.	0.360	0.025	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
1930 140	41	1.5	270.	0.360	0.025	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
1940 140	42	1.5	270.	0.360	0.025	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
1950 140	43	1.5	270.	0.360	0.025	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
1960 140	44	1.5	270.	0.360	0.025	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
1970 140	45	1.5	171.	0.360	0.025	1.236	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
1980 140	46	1.5	171.	0.360	0.025	1.236	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
1990 140	47	1.5	622.	0.320	0.025	0.	3.0	1402.	0.320	0.025	0.075	3.0	1163.	0.300	0.025	0.119

Figure 12-11. CTAS Operating and Maintenance Factors Table for 10<sup>6</sup>\$/Yr

the total LAEC. The ratio of this cogeneration LAEC divided by the no-cogeneration LAEC is shown under the NORML column. Besides LAEC and ROI, the present worth of the investment at a 15% discount rate, and the net payback are calculated. Figure 12-12 shows the format of the output of Report 5.4 with capital costs at the base (0% change from calculated) values. Report 5.4 in the format of Figure 12-12 for base (0% change) groundrule costs for the coal-fired nocogeneration process boiler base case and all of the ECS-process matches is included in Volume VI, Part 1. Volume VI, Part 2 contains Report 5.4 results for the oil-fired nocogeneration process boiler base case.

Other calculations show the sensitivity to changes in the various factors. Figure 12-13, for example, shows the sensitivities of economic factors to capital cost, fuel cost, and power cost in graphical form. These sensitivities for LAEC were calculated on the selected matches shown in Table 12-8 for the coal-fired nocogeneration process boiler base case. The graphical results are included behind Report 5.4, Part 1. An attempt was made to use this computer routine to calculate these sensitivities on ROI, but because of the many matches where a positive ROI does not exist and the rapid change in ROI to changes in costs, very limited results were obtained. The sensitivity of these cost changes on ROI are best understood and calculated by using the methodology described in Volume V, Sections 9.5 and 9.6.

#### Report 5.2 - Summary of Fuel Saved by Type and Economics

This summary Report 5.2 shows the fuel saved by type and the economics of the process and ECS matches. A sample page is shown in Figure 12-14. The report accounts for fuel differences in both type and quantity in  $10^6$  Btu/hr used between the nocogeneration case, and the cogeneration case including the displacement of utility fuel that occurs due to on-site power generation. In the cogeneration case any fuel burned on-site is added to any utility fuel burned due to a shortfall of on-site power. The fuel savings (nocogen-cogen heading on the report) shows what fuel was saved (positive quantity in the column under the appropriate fuel)



ECONOMIC SENSITIVITY REPORT FOR SELECTED PROCESS-ECS MATCHES

SENSITIVITY OF CAPITAL COST										PERCENT OF ORIGINAL COST 100						
ENERGY CONV SYSTEM	SITE- FUEL	POWER REGRD MW	POWER GEN/ REGRD	FESRPOWER /HEAT COST RATIO *10**8	CAPITAL COST	CAPITAL TAXES		GANDM	FUEL	PURCHD ELEC	REVENUE	TOTAL	NORML PRESENT WORTH \$	ROI %	GROSS PAY BACK	
						INSNG	INSNG									
10101 ONCOGN COAL-F0	10.	0.	0.	0.25	12.3	0.93	0.40	0.83	0.74	3.09	0.	5.97	1.000	0.	0	0
10101 STM141 RESIDUA	10.	0.99	0.439	0.25	8.3	0.83	0.27	0.67	2.42	0.03	0.	3.93	0.858	8.	999	0
10101 STM141 COAL-F0	10.	0.99	0.439	0.25	19.2	1.29	0.92	1.09	1.41	0.03	0.	4.27	0.713	3.	28	4
10101 STM141 COAL-AF	10.	0.99	0.439	0.25	12.8	0.95	0.40	0.98	1.41	0.03	0.	3.74	0.828	7.	999	1
10101 STM088 RESIDUA	10.	0.78	0.333	0.25	7.4	0.86	0.24	0.84	2.18	0.78	0.	4.28	0.713	8.	999	0
10101 STM088 COAL-F0	10.	0.78	0.333	0.25	14.9	1.13	0.48	1.02	1.25	0.78	0.	4.68	0.778	3.	31	4
10101 STM088 COAL-AF	10.	0.78	0.333	0.25	11.8	0.89	0.38	0.92	1.25	0.78	0.	4.20	0.704	6.	952	0
10101 PFBSTH COAL-PF	10.	1.50	0.436	0.25	20.8	1.58	0.67	1.89	1.43	0.	0.	8.27	0.882	-2.	10	8
10101 PFBSTH COAL-PF	10.	1.52	0.464	0.25	19.9	1.51	0.64	1.48	1.78	0.	-0.88	4.44	0.744	1.	17	8
10101 T1STMT RESIDUA	10.	1.00	0.187	0.25	29.8	2.28	0.98	1.27	3.85	0.	0.	8.02	1.344	-18.	0	83
10101 T1STMT RESIDUA	10.	0.84	0.236	0.25	20.8	1.58	0.66	1.31	1.91	1.42	0.	6.58	1.099	-2.	0	999
10101 T1STMT COAL	10.	1.00	0.436	0.25	41.4	3.14	1.34	1.98	1.43	0.	0.	7.88	1.318	-20.	0	999
10101 T1STMT COAL	10.	1.99	0.510	0.25	87.1	4.33	1.84	2.15	2.12	0.	-1.83	8.61	1.441	-80.	0	999
10101 TIHR90 RESIDUA	10.	0.23	0.083	0.25	17.6	1.30	0.55	0.84	1.82	2.37	0.	6.68	1.119	-8.	0	68
10101 TIHR90 COAL	10.	0.85	0.308	0.25	46.1	3.85	1.89	1.78	1.49	0.47	0.	8.92	1.494	-28.	0	999
10101 STIRL DISTILL	10.	1.00	0.148	0.25	11.1	0.82	0.35	0.77	4.68	0.	0.	8.81	1.090	-1.	-26	0
10101 STIRL DISTILL	10.	0.83	0.201	0.25	9.3	0.89	0.29	0.70	2.68	1.18	0.	8.68	0.953	2.	999	0
10101 STIRL RESIDUA	10.	1.00	0.148	0.25	11.1	0.83	0.35	0.77	3.72	0.	0.	8.67	0.948	2.	999	0
10101 STIRL RESIDUA	10.	0.63	0.201	0.25	9.3	0.89	0.29	0.70	2.33	1.18	0.	8.18	0.883	4.	999	0
10101 STIRL COAL	10.	1.00	0.321	0.25	21.8	1.82	0.69	1.44	1.72	0.	0.	8.47	0.917	-3.	9	10
10101 STIRL COAL	10.	2.32	0.388	0.25	28.1	2.08	0.88	1.43	3.02	0.	-2.43	4.98	0.834	-4.	8	8
10101 HEGT85 COAL-AF	10.	1.00	0.178	0.25	38.4	2.88	1.14	1.89	2.09	0.	0.	7.80	1.273	-18.	0	999
10101 HEGT85 COAL-AF	10.	0.10	0.235	0.25	91.7	8.96	2.98	3.34	8.97	0.	-9.43	12.80	2.144	-80.	0	999
10101 HEGT60 COAL-AF	10.	1.00	0.191	0.25	31.0	2.68	1.10	1.68	2.08	0.	0.	7.38	1.237	-18.	0	999
10101 HEGT60 COAL-AF	10.	3.00	0.238	0.25	85.1	4.18	1.78	2.12	4.89	0.	-3.70	8.08	1.820	-30.	0	999
10101 HEGT00 COAL-AF	10.	1.00	0.168	0.25	31.2	2.37	1.01	1.88	2.07	0.	0.	7.01	1.173	-12.	0	999
10101 HEGT00 COAL-AF	10.	1.45	0.203	0.25	33.4	2.53	1.08	1.41	2.60	0.	-0.74	6.88	1.192	-13.	0	26
10101 FCMCCL COAL	10.	1.00	0.403	0.25	29.8	2.32	0.99	1.72	3.66	0.	0.	8.58	1.437	-17.	0	74
10101 FCMCCL COAL	10.	2.87	0.092	0.25	40.3	3.13	1.33	2.09	4.88	0.	-2.80	8.63	1.428	-22.	0	999
10101 FCSTCL COAL	10.	1.00	0.388	0.25	29.0	2.28	0.96	1.73	3.82	0.	0.	8.47	1.418	-18.	0	74
10101 FCSTCL COAL	10.	4.18	0.266	0.25	50.3	3.91	1.66	2.68	6.08	0.	-5.67	8.41	1.408	-27.	0	999
10101 J00TST COAL	10.	1.00	0.465	0.25	28.8	2.28	0.96	1.81	3.72	0.	0.	8.63	1.428	-18.	0	72
10101 J00TST COAL	10.	2.95	0.068	0.25	40.4	3.14	1.34	1.84	5.68	0.	-3.80	8.18	1.370	-21.	0	999
10101 G190AR RESIDUA	10.	1.00	0.218	0.25	10.8	0.78	0.33	0.71	3.42	0.	0.	8.25	0.878	3.	999	0
10101 G190AR RESIDUA	10.	0.71	0.238	0.25	9.8	0.71	0.30	0.87	2.43	0.88	0.	8.00	0.838	4.	999	0
10101 G1AC08 RESIDUA	10.	1.00	0.188	0.25	9.8	0.71	0.30	0.88	3.68	0.	0.	8.37	0.889	3.	999	0
10101 G1AC08 RESIDUA	10.	0.87	0.215	0.25	8.3	0.82	0.28	0.83	2.10	1.32	0.	4.93	0.828	8.	999	0
10101 G1AC12 RESIDUA	10.	1.00	0.265	0.25	9.8	0.72	0.31	0.88	3.28	0.	0.	4.97	0.832	4.	999	0
10101 G1AC12 RESIDUA	10.	0.71	0.265	0.25	8.8	0.85	0.28	0.88	2.30	0.80	0.	4.78	0.801	8.	912	0
10101 G1AC18 RESIDUA	10.	1.00	0.296	0.25	10.1	0.78	0.32	0.89	3.07	0.	0.	4.83	0.810	8.	999	0
10101 G1AC18 RESIDUA	10.	0.79	0.298	0.25	9.4	0.70	0.30	0.88	2.44	0.83	0.	4.73	0.782	8.	999	0
10101 G1WC18 RESIDUA	10.	1.00	0.278	0.25	10.4	0.77	0.33	0.70	3.18	0.	0.	4.95	0.830	4.	999	0
10101 G1WC18 RESIDUA	10.	0.85	0.280	0.25	9.8	0.73	0.31	0.88	2.87	0.48	0.	4.87	0.818	8.	999	0

12-31


Figure 12-12. Sample Economic Sensitivity Report

COGENERATION TECHNOLOGY ALTERNATIVES STUDY

SENSITIVITY STUDY

PROCESS 26217

ECS CC1020



BASE CASE

PROCESS	NO COGENERATION	COGENERATION
MW- 31		CAPITAL COST- 10.1
PROCESS HEAT- 103 (BTU*10**6)	CAPITAL COST- 14.0	LAEC - 15.150
WASTE FUEL- 0	LAEC - 10.517	ROI - 27
(BTU*10**6)	FUEL - COAL-FGD	MW(GEN) - 31
POWER/HEAT- 0.504		FUEL - RESIDUAL
■ — — ■	CAPITAL COST	
● — — ●	ELECTRIC POWER	
▲ — — ▲	NO-CGN FUEL	
+ — — +	ECS FUEL	

Figure 12-13. Sample Economic Sensitivity

-----FUEL USE IN BTU\*10\*\*\*-----  
\*\*COGENERATION CASE\*\* \*\*NOCOGEN\*\* - COGEN\*\*

EC9	PROCS	DISTIL	RESID	COAL	DISTIL	RESID	COAL	POWER RECD	COGEN POWER	Q H	POWER FEER /HEAT	CAPITAL COST	NORM COST	\$/KW FUEL	ROI (%)	LEVEL CHRG	NORM ENRG	WRTH ENRG
OMOCN	10101	0.	20.	120.	0.	0.	0.	F 10.	0.	0.83	0.25 0.	12.3	1.00	200.1	0	6.0	1.00	80
STM141	10101	0.	84.	1.	0.	-59.	126.	10.	10.	0.87	0.25 0.44	8.3	0.88	141.8	999	3.8	0.68	178
STM141	10101	0.	0.	84.	0.	24.	42.	F 10.	10.	1.08	0.25 0.44	16.2	1.32	275.2	29	4.3	0.71	180
STM141	10101	0.	0.	84.	0.	24.	42.	A 10.	10.	0.98	0.25 0.44	12.5	1.01	211.8	999	3.7	0.63	164
STM088	10101	0.	80.	20.	0.	-55.	108.	10.	8.	0.84	0.25 0.33	7.4	0.80	132.8	999	4.3	0.71	166
STM088	10101	0.	8.	84.	0.	18.	32.	F 10.	8.	1.02	0.25 0.33	14.8	1.22	288.8	31	4.8	0.76	150
STM088	10101	0.	8.	84.	0.	18.	32.	A 10.	8.	0.92	0.25 0.33	11.9	0.99	209.8	999	4.2	0.70	154
PFBSTM	10101	0.	0.	85.	0.	25.	41.	10.	10.	1.08	0.25 0.44	20.8	1.69	351.2	10	8.3	0.88	169
PFBSTM	10101	0.	0.	108.	0.	37.	62.	10.	18.	1.48	0.25 0.48	18.8	1.42	304.3	17	4.4	0.74	180
T1STMT	10101	0.	122.	0.	0.	-87.	128.	10.	10.	1.27	0.25 0.18	28.6	2.41	488.8	0	8.0	1.34	143
T1STMT	10101	0.	77.	38.	0.	-52.	88.	10.	8.	1.01	0.25 0.23	20.8	1.87	381.1	0	8.8	1.10	138
T1STMT	10101	0.	0.	85.	0.	25.	41.	10.	10.	1.08	0.25 0.44	41.4	3.37	698.8	0	7.8	1.32	168
T1STMT	10101	0.	0.	128.	0.	48.	82.	10.	20.	2.18	0.25 0.81	87.1	4.88	800.8	0	8.8	1.44	180
T1HRS9	10101	0.	74.	83.	0.	-50.	82.	10.	8.	0.84	0.25 0.08	17.8	1.43	348.8	0	8.7	1.12	112
T1HRS9	10101	0.	4.	101.	0.	21.	25.	10.	8.	1.78	0.25 0.31	48.1	3.92	798.3	0	8.8	1.48	143
STIRL	10101	128.	0.	0.	-128.	28.	128.	10.	10.	0.77	0.25 0.18	11.1	0.81	173.1	-28	8.8	1.08	183
STIRL	10101	80.	8.	31.	-80.	18.	88.	10.	8.	0.70	0.25 0.20	8.3	0.78	180.7	999	8.7	0.85	148
STIRL	10101	0.	128.	0.	-103.	128.	10.	10.	10.	0.77	0.25 0.18	11.1	0.81	173.3	999	8.7	0.85	150
STIRL	10101	0.	88.	31.	0.	-85.	83.	10.	8.	0.70	0.25 0.20	8.3	0.78	180.8	999	8.8	0.86	7
STIRL	10101	0.	0.	102.	0.	25.	24.	10.	10.	1.44	0.25 0.32	21.8	1.78	340.8	8	8.8	0.82	7
STIRL	10101	0.	0.	178.	0.	87.	88.	10.	23.	1.43	0.25 0.38	28.1	2.28	323.2	8	8.0	0.83	7
HEGT85	10101	0.	0.	123.	0.	3.	2.	A 10.	10.	1.88	0.25 0.18	38.4	2.88	800.8	0	7.8	1.27	37
HEGT85	10101	0.	0.	531.	0.	120.	14.	A 10.	81.	3.34	0.25 0.24	81.7	7.48	482.4	0	12.8	2.1	13
HEGT80	10101	0.	0.	122.	0.	28.	4.	A 10.	10.	1.88	0.25 0.18	34.0	2.78	484.4	0	7.4	1.24	138
HEGT80	10101	0.	0.	278.	0.	74.	18.	A 10.	30.	2.12	0.25 0.24	88.1	4.48	478.1	0	8.1	1.52	120
HEGT00	10101	0.	0.	122.	0.	28.	3.	A 10.	10.	1.88	0.25 0.18	31.2	2.84	444.8	0	7.0	1.17	138
HEGT00	10101	0.	0.	184.	0.	34.	8.	A 10.	14.	1.41	0.25 0.20	33.4	2.72	418.8	0	8.8	1.18	128
FCMCL	10101	0.	0.	211.	0.	28.	-88.	10.	10.	1.72	0.25 -0.40	28.8	2.43	483.1	0	8.8	1.44	71
FCMCL	10101	0.	0.	289.	0.	83.	-34.	10.	28.	2.08	0.25 0.08	40.3	3.28	478.4	0	8.8	1.43	107
FCSTCL	10101	0.	0.	208.	0.	28.	-83.	10.	10.	1.73	0.25 -0.38	28.0	2.38	474.8	0	8.8	1.42	73
FCSTCL	10101	0.	0.	389.	0.	102.	28.	10.	42.	2.85	0.25 0.27	80.3	4.08	478.2	0	8.4	1.41	113
IGGTST	10101	0.	0.	220.	0.	28.	-84.	10.	10.	1.81	0.25 -0.47	28.8	2.38	448.2	0	8.8	1.43	84
IGGTST	10101	0.	0.	338.	0.	72.	-48.	10.	28.	1.84	0.25 0.08	40.4	3.28	412.3	0	8.2	1.37	88
GTSOAR	10101	0.	118.	0.	0.	-83.	128.	10.	10.	0.71	0.25 0.22	10.8	0.88	188.2	999	8.3	0.88	188
GTSOAR	10101	0.	81.	24.	0.	-85.	102.	10.	7.	0.87	0.25 0.24	8.8	0.78	182.0	999	8.0	0.84	151
GTAC08	10101	0.	128.	0.	0.	-182.	128.	10.	10.	0.88	0.25 0.18	8.8	0.78	183.0	999	8.4	0.80	154
GTAC08	10101	0.	83.	38.	0.	-88.	80.	10.	8.	0.83	0.25 0.21	8.3	0.88	148.7	999	4.8	0.83	150
GTAC12	10101	0.	112.	0.	0.	-87.	128.	10.	10.	0.88	0.25 0.28	8.8	0.80	187.8	999	8.0	0.83	164
GTAC12	10101	0.	88.	24.	0.	-82.	102.	10.	7.	0.85	0.25 0.27	8.8	0.72	183.2	999	4.8	0.80	185
GTAC18	10101	0.	108.	0.	0.	-81.	128.	10.	10.	0.88	0.25 0.30	10.1	0.82	182.8	999	4.8	0.81	187
GTAC18	10101	0.	88.	17.	0.	-84.	108.	10.	8.	0.88	0.25 0.30	8.4	0.78	188.0	999	4.7	0.78	158
GTWC18	10101	0.	108.	0.	0.	-84.	128.	10.	10.	0.70	0.25 0.28	10.4	0.85	182.8	999	8.8	0.83	168
GTWC18	10101	0.	88.	13.	0.	-71.	112.	10.	8.	0.88	0.25 0.28	8.8	0.80	181.1	999	4.8	0.82	183

12-33

Figure 12-14. Sample Fuel Saved By Type + Economics Report

and how much. The single letters F and A appearing after the cogen coal column in Figure 12-14 indicate FGD or AFB coal systems. On other pages of the report P indicates a PFB coal system.

Other data included in Report 5.2 are the process power requirements (POWER REQD), on-site cogeneration power produced (COGEN POWER), the process power over heat ratio (POWER/HEAT), the fuel energy saved ratio (FESR) and summary economic parameters. These parameters include the operating and maintenance cost in  $10^6$  dollars (CAPITAL COST), the ratio of the on-site cogeneration ECS over the nocogeneration process boiler capital costs (NORM COST), return on investment (ROI), levelized annual energy cost (LEVL CHRG) and the ratio of cogeneration over nocogeneration LAEC (NORM ENGR). The parameters in the columns "\$/kW EQVL" and "WRTH" did not prove useful and should be ignored.

#### Report 6.1 - Fuel and Emissions Savings

Figure 12-15 shows an example of computer report 6.1, the Fuel and Emissions Savings by type, emissions saved ratio (EMSR), capital saving, total export megawatt hours, cost of electricity and LAEC savings for process-ECS matches and Figure 12-16 on a national basis.

Input requirements for this program include the Emissions by ECS and Fuel (Table 12-11) and a table on National Energy Use by SIC (Table 12-12).

The FESR is scaled by multipliers discussed in Section 10 (Volume V) so that

$$\begin{array}{l} \text{FESR} \\ \text{(2-digit)} \end{array} = \begin{array}{l} \text{FESR} \\ \text{(CTAS)} \end{array} * \begin{array}{l} \text{Multiplier} \\ \text{(Process to 2-digit)} \end{array}$$

$$\begin{array}{l} \text{FESR} \\ \text{(National)} \end{array} = \begin{array}{l} \text{FESR} \\ \text{(2-digit)} \end{array} * \begin{array}{l} \text{Multiplier} \\ \text{(2-digit to National)} \end{array}$$

DATE 04/24/79  
ISE PEO AES

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 8.1 FUEL AND EMISSIONS SAVINGS  
TIME 1990 LEVEL ALL

PAGE 1

FUEL UNITS = Quads  
EMISSION UNITS = 1000 tons/hr  
COST \*\*10\*\*9

(SAVINGS ARE POSITIVE)

TYPE MATCH=HEAT

PROCS	ECS	*****FUEL SAVINGS*****										*****EMISSIONS SAVINGS*****			CAPITL--ELECTRIC POWER---			
		*****DIRECT*****			*****TOTAL*****			*****DIRECT*****			*****TOTAL*****			EMSR SAVING	TOTAL EXPORT	SVNG LAEC SAVED		
		FUEL	OIL+GAS	COAL	OIL+GAS	CCAL	NOX	SOX	PART	NOX	SOX	PART	MWH					
20	STM141	COAL-A	0.121	-0.229	0.188	-0.009	0.43	38.	-88.	-8.	131.	71.	18.	0.41	-1.	8.	284.	-497.
22	STM141	COAL-A	0.	-0.004	0.003	0.005	0.14	4.	-3.	-0.	8.	4.	0.	0.38	0.	0.	2.	28.
24	STM141	COAL-A	0.	-0.018	0.062	0.188	-0.82	-2.	-11.	-1.	84.	138.	18.	0.78	-2.	2.	248.	-285.
28	STM141	COAL-A	0.	-0.043	0.120	0.048	0.13	28.	-28.	-2.	83.	37.	8.	0.38	1.	1.	4.	304.
28	STM141	COAL-A	0.028	-0.211	0.140	0.181	0.81	214.	-118.	-9.	372.	180.	21.	0.32	8.	18.	31.	1091.
29	STM141	COAL-A	0.	-0.025	0.018	0.028	0.10	30.	-18.	-1.	82.	21.	3.	0.35	1.	1.	2.	178.
33	STM141	COAL-A	0.	-0.008	0.004	0.006	0.01	4.	-3.	-0.	8.	8.	1.	0.08	0.	0.	0.	47.
ALL	STM141	COAL-A	0.178	-0.829	0.812	0.497	0.18	370.	-307.	-23.	842.	488.	71.	0.34	4.	38.	848.	1037.
20	STM141	COAL-F	0.121	-0.228	0.188	-0.009	0.43	-87.	-88.	-8.	35.	71.	18.	0.28	-3.	8.	283.	-828.
22	STM141	COAL-F	0.	-0.004	0.003	0.005	0.14	-2.	-3.	-0.	2.	4.	0.	0.21	0.	0.	2.	15.
24	STM141	COAL-F	0.	-0.018	0.062	0.188	-0.82	-7.	-11.	-1.	78.	136.	18.	0.77	-8.	2.	248.	-718.
28	STM141	COAL-F	0.	-0.043	0.026	0.045	0.13	-18.	-28.	-2.	22.	37.	8.	0.23	1.	1.	4.	238.
28	STM141	COAL-F	0.028	-0.211	0.140	0.181	0.81	-78.	-118.	-8.	81.	180.	21.	0.18	3.	18.	31.	788.
29	STM141	COAL-F	0.	-0.025	0.018	0.028	0.10	-8.	-18.	-1.	13.	21.	3.	0.17	0.	1.	2.	138.
33	STM141	COAL-F	0.	-0.008	0.004	0.006	0.01	-4.	-3.	-0.	1.	8.	1.	0.04	0.	0.	0.	28.
ALL	STM141	COAL-F	0.178	-0.829	0.812	0.497	0.18	-188.	-307.	-23.	274.	488.	71.	0.18	-8.	38.	847.	-838.
20	STM141	RESIDU	-0.328	0.218	-0.289	0.437	0.43	-87.	1.	-8.	32.	147.	-2.	0.34	4.	8.	288.	-343.
22	STM141	RESIDU	-0.028	0.021	-0.022	0.030	0.14	-2.	2.	-0.	2.	8.	-1.	0.30	0.	0.	2.	2.
24	STM141	RESIDU	-0.021	0.003	0.041	0.209	0.82	-7.	-7.	-1.	78.	138.	14.	0.78	3.	2.	280.	818.
28	STM141	RESIDU	-0.181	0.148	-0.164	0.235	0.13	-18.	12.	-2.	20.	88.	-3.	0.32	2.	1.	4.	101.
28	STM141	RESIDU	-1.317	1.135	-1.208	1.807	0.81	-78.	184.	-8.	71.	378.	-33.	0.25	7.	18.	32.	-401.
29	STM141	RESIDU	-0.181	0.158	-0.168	0.207	0.10	-8.	21.	-1.	11.	82.	-8.	0.27	1.	1.	2.	-43.
33	STM141	RESIDU	-0.038	0.030	-0.032	0.042	0.01	-4.	4.	-0.	1.	11.	-1.	0.07	0.	0.	0.	14.
ALL	STM141	RESIDU	-2.468	2.012	-2.128	3.138	0.18	-188.	221.	-23.	284.	847.	-38.	0.27	20.	38.	883.	-88.
20	STM088	COAL-A	0.127	-0.220	0.184	-0.028	0.38	45.	-81.	-8.	128.	88.	18.	0.38	-1.	8.	238.	-488.
22	STM088	COAL-A	0.	-0.004	0.002	0.004	0.11	4.	-2.	-0.	8.	3.	0.	0.35	0.	0.	2.	28.
24	STM088	COAL-A	0.	-0.005	0.043	0.141	0.81	-1.	-3.	-0.	80.	101.	11.	0.58	-3.	0.	205.	-427.
28	STM088	COAL-A	0.	-0.032	0.020	0.034	0.10	28.	-18.	-2.	88.	28.	3.	0.33	1.	0.	4.	282.
28	STM088	COAL-A	0.020	-0.108	0.073	0.089	0.24	148.	-88.	-4.	221.	70.	10.	0.28	2.	8.	18.	888.
29	STM088	COAL-A	0.	-0.017	0.011	0.018	0.07	33.	-10.	-1.	48.	18.	2.	0.30	1.	0.	1.	144.
33	STM088	COAL-A	0.	-0.004	0.002	0.004	0.00	8.	-2.	-0.	8.	3.	0.	0.08	0.	0.	0.	38.
ALL	STM088	COAL-A	0.180	-0.422	0.364	0.262	0.12	288.	-188.	-13.	873.	301.	48.	0.30	0.	13.	807.	141.
20	STM088	COAL-F	0.127	-0.220	0.184	-0.028	0.38	-85.	-81.	-8.	28.	88.	18.	0.21	-3.	8.	235.	-884.

12-35

Figure 12-15. Sample of National Fuel and Emissions Savings Report

DATE 06/12/79

GENERAL ELECTRIC COMPANY

PAGE 21

ISE PEO AES

10<sup>6</sup> Btu/hr

COGENERATION TECHNOLOGY

ALTERNATIVES STUDY

FUEL UNITS =

REPORT 6.1 FUEL AND EMISSIONS SAVINGS

(SAVINGS ARE POSITIVE)

EMISSION UNITS = 10<sup>-3</sup> Tons/hr

TIME 1990

LEVEL ALL

COST

= \$\*10\*\*9

TYPE MATCH=POWER

PROCS	ECS	FUEL SAVINGS			EMISSIONS SAVINGS			CAPITL--ELECTRIC POWER--										
		FUEL OIL+GAS	COAL OIL+GAS	COAL	NOX	SOX	PART	NOX	SOX	PART	EMSR SAVING	TOTAL EXPORT	COST LAEC SAVED					
28214	DES0A3	RESIDU	-0.589	0.385	-0.589	0.645	0.12	22.	17.	18.	105.	189.	30.	0.47	18.	0.	27.	-3.
28214	DES0A3	RESIDU	-1.918	0.385	-1.918	2.547	0.25	-6768.	-490.	4.	-8073.	892.	132.	-2.20	32.	178.	43.	-32.
28214	OTS0AD	DISTIL	-0.518	0.385	-0.518	0.645	0.20	110.	147.	18.	190.	274.	14.	0.76	35.	0.	8.	-3.
28214	OTS0AD	DISTIL	-0.711	0.385	-0.711	1.034	0.31	31.	118.	18.	234.	449.	29.	0.72	67.	37.	17.	-4.
28214	OTRA08	DISTIL	0.	-0.141	0.	0.118	0.18	11.	83.	10.	95.	225.	28.	0.55	32.	0.	13.	-4.
28214	OTRA08	DISTIL	0.	-0.589	0.	0.498	0.34	-218.	-43.	3.	132.	581.	67.	0.54	86.	78.	26.	-9.
28214	OTRA12	DISTIL	0.	-0.138	0.	0.122	0.19	12.	84.	10.	98.	226.	26.	0.55	31.	0.	13.	-1.
28214	OTRA12	DISTIL	0.	-0.561	0.	0.498	0.34	-207.	-35.	3.	134.	544.	68.	0.54	83.	75.	25.	-8.
28214	OTRA18	DISTIL	0.	-0.137	0.	0.123	0.19	11.	84.	10.	95.	226.	26.	0.55	31.	0.	13.	-4.
28214	OTRA18	DISTIL	0.	-0.519	0.	0.487	0.34	-190.	-23.	4.	127.	518.	62.	0.54	78.	68.	28.	-8.
28214	OTR208	DISTIL	0.	-0.137	0.	0.123	0.19	8.	84.	10.	91.	228.	26.	0.55	33.	0.	12.	-4.
28214	OTR208	DISTIL	0.	-0.429	0.	0.385	0.32	-184.	2.	8.	108.	447.	54.	0.53	71.	52.	23.	-7.
28214	OTR212	DISTIL	0.	-0.137	0.	0.122	0.19	8.	84.	10.	92.	226.	26.	0.55	32.	0.	12.	-4.
28214	OTR212	DISTIL	0.	-0.462	0.	0.412	0.33	-187.	-7.	8.	114.	471.	57.	0.54	73.	58.	23.	-7.
28214	OTR218	DISTIL	0.	-0.138	0.	0.125	0.19	10.	85.	10.	94.	227.	26.	0.55	31.	0.	12.	-4.
28214	OTR218	DISTIL	0.	-0.485	0.	0.431	0.34	-188.	-8.	8.	120.	482.	58.	0.54	73.	60.	24.	-7.
28214	OTRW08	DISTIL	0.	-0.150	0.	0.100	0.18	8.	78.	10.	90.	220.	25.	0.53	32.	0.	18.	-5.
28214	OTRW08	DISTIL	0.	-0.798	0.	0.500	0.30	-301.	-101.	-1.	118.	607.	78.	0.50	103.	97.	28.	-14.
28214	OTRW12	DISTIL	0.	-0.152	0.	0.108	0.17	8.	80.	10.	93.	222.	26.	0.54	32.	0.	15.	-8.
28214	OTRW12	DISTIL	0.	-0.770	0.	0.544	0.32	-290.	-94.	-0.	133.	625.	77.	0.52	104.	99.	27.	-12.
28214	OTRW18	DISTIL	0.	-0.160	0.	0.109	0.17	8.	80.	10.	93.	222.	26.	0.54	31.	0.	18.	-8.
28214	OTRW18	DISTIL	0.	-0.704	0.	0.511	0.32	-284.	-78.	1.	127.	589.	73.	0.52	88.	90.	27.	-12.
28214	OTR308	DISTIL	0.	-0.167	0.	0.093	0.14	-1.	78.	10.	83.	218.	25.	0.52	33.	0.	17.	-8.
28214	OTR308	DISTIL	0.	-0.838	0.	0.353	0.28	-237.	-88.	2.	82.	485.	60.	0.48	85.	68.	28.	-12.
28214	OTR312	DISTIL	0.	-0.148	0.	0.111	0.17	8.	81.	10.	91.	223.	26.	0.54	33.	0.	13.	-8.
28214	OTR312	DISTIL	0.	-0.603	0.	0.483	0.31	-224.	-47.	2.	118.	531.	65.	0.52	88.	78.	25.	-10.
28214	OTR318	DISTIL	0.	-0.149	0.	0.111	0.17	7.	81.	10.	91.	223.	26.	0.54	32.	0.	14.	-8.
28214	OTR318	DISTIL	0.	-0.698	0.	0.444	0.31	-221.	-48.	3.	114.	524.	64.	0.52	88.	73.	28.	-10.
28214	FCPAD9	DISTIL	0.	-0.175	0.	0.085	0.13	8.	74.	10.	90.	218.	25.	0.53	28.	0.	35.	-8.
28214	FCPAD9	DISTIL	0.	-1.542	0.	0.747	0.28	-248.	170.	18.	488.	1422.	181.	0.82	91.	190.	82.	-82.
28214	FCHCD9	DISTIL	0.	-0.148	0.	0.113	0.18	13.	82.	10.	98.	224.	26.	0.55	24.	0.	31.	-8.
28214	FCHCD9	DISTIL	0.	-1.021	0.	0.790	0.36	-813.	168.	-2.	-230.	1158.	105.	0.50	89.	145.	47.	-40.
28218	STM141	RESIDU	0.	-0.061	0.	0.101	0.21	-21.	38.	-3.	28.	114.	-8.	0.29	22.	0.	8.	0.
28218	STM141	COAL-F	0.	-0.061	0.	0.101	0.21	-21.	-37.	-3.	31.	82.	7.	0.19	8.	0.	21.	4.
28218	STM141	COAL-A	0.	-0.081	0.	0.101	0.21	87.	-37.	-3.	108.	82.	7.	0.38	18.	0.	11.	5.
28218	STM088	RESIDU	0.	-0.044	0.	0.073	0.15	-15.	43.	-2.	20.	97.	-9.	0.23	18.	0.	16.	-1.
28218	STM088	COAL-F	0.	-0.044	0.	0.073	0.15	-15.	-28.	-2.	22.	38.	5.	0.14	8.	0.	27.	3.
28218	STM088	COAL-A	0.	-0.044	0.	0.073	0.15	89.	-28.	-2.	97.	38.	5.	0.30	13.	0.	18.	3.
28218	PFBSTM	COAL-P	0.	-0.070	0.	0.109	0.23	72.	-42.	8.	130.	86.	17.	0.43	3.	0.	32.	2.
28218	PFBSTM	COAL-P	0.	-0.104	0.	0.182	0.29	76.	-82.	9.	181.	83.	25.	0.49	12.	8.	23.	4.
28218	T1STHT	RESIDU	0.	-0.089	0.	0.110	0.23	-24.	33.	-3.	31.	120.	-8.	0.30	-15.	0.	88.	-5.
28218	T1STHT	RESIDU	0.	-0.138	0.	0.218	0.33	-48.	8.	-7.	83.	187.	-3.	0.39	-27.	17.	84.	-7.
28218	T1STHT	COAL	0.	-0.069	0.	0.110	0.23	-24.	-42.	-3.	33.	86.	7.	0.21	-36.	0.	83.	-2.
28218	T1STHT	COAL	0.	-0.138	0.	0.218	0.33	-48.	-83.	-7.	88.	112.	14.	0.30	-48.	17.	88.	-3.
28218	T1HRSO	RESIDU	0.	-0.098	0.	0.090	0.17	-34.	22.	-8.	20.	108.	-10.	0.28	-33.	0.	88.	-8.
28218	T1HRSO	COAL	0.	-0.098	0.	0.090	0.17	-34.	-88.	-5.	23.	38.	6.	0.14	-83.	0.	108.	-8.

Figure 12-16. Sample of ECS-Process Fuel &amp; Emissions Report

12-36  
ORIGINAL PAGE IS  
OF POOR QUALITY

Table 12-11

CONTENTS OF EMISSIONS BY ECS AND FUEL

ECS Number: For matching to appropriate ECS  
ECS Description: For information only  
Same as Number: Refers ECS back to other ECS with identical emissions  
NO<sub>x</sub>: Pounds emitted per million Btu  
SO<sub>2</sub>: Pounds emitted per million Btu  
Particulate: Pounds emitted per million Btu

(NO<sub>x</sub>, SO<sub>2</sub> and Particulate data for each possible fuel type for each ECS)

Table 12-12

CONTENTS OF NATIONAL ENERGY USE

SIC Cod  
CTAS Process Number  
Power Match FESR multiplier to next highest level  
Heat Match FESR multiplier to next highest level  
Energy Consumption 1985  
Energy Consumption 2000  
Levels: At CTAS process level next highest level is 2-digit SIC.  
: At 2-digit SIC next highest level is national.

All other factors are scaled by market size

$$\text{Scalar - 2-digit} = \frac{\text{FESR}(2\text{-digit}) * \text{Market}(2\text{-digit})}{\text{FESR}(\text{CTAS}) * \text{Market}(\text{CTAS})}$$

$$\text{Scalar - National} = \frac{\text{FESR}(\text{National}) * \text{Market}(\text{National})}{\text{FESR}(2\text{-digit}) * \text{Market}(2\text{-digit})}$$

These scaling factors account for the fact that

1. All process in a 4-digit SIC code are not represented in CTAS.
2. All 4-digit SIC codes in a 2-digit SIC code are not represented in CTAS.
3. All 2-digit SIC codes in the nation are not represented in CTAS.

Report 6.1, Fuel and Emissions Savings, is presented in two parts - (1) for each process-ECS match, and (2) an estimate of the total national savings for each ECS assumed to be implemented without competition in all new plants added because of new capacity required or to replace unserviceable plants.

In Report 6.1 by process the units of fuel saved are  $10^6$  Btu/hr and the emissions saved units are  $10^{-3}$  tons/hr. DIRECT savings are on-site and TOTAL include the utility. FESR is the fuel energy saved ratio and EMSR is the emission saved ratio defined as nocogeneration minus cogeneration all over nocogeneration. LAEC SAVED are in  $10^6$  \$/yr. Data under the headings of CAPITL SAVING & ELECTRIC POWER were not used in this study.

Report 6.1 data for individual process plants is presented for the coal nocogeneration base case in Volume VI, Part 1 and for the oil nocogeneration base case in Part 2. For the coal nocogeneration base case the national savings for the 2-digit SIC industrial sector and "ALL" industry were calculated for each cogeneration ECS. The national emissions saved are given in  $10^6$  tons/yr and the fuel saved in quads/yr. These results are shown in Volume VI, Part 1 for the coal nocogeneration base case and in Volume VI, Part 2 for the residual nocogeneration base case.



**COAL-FIRED NCOGENERATION PROCESS BOILER**

**REPORT 5.1 - FUEL ENERGY SAVED BY PROCESS  
& ECS**

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 1

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 10101 MW 10.00 PROCESS MILLIONS BTU/HR 137.0 PROCESS TEMP(F) 300. PRODUCT NASA-CLBR#1 HOURS PER YEAR 8000.

POWER TO HEAT RATIO 0.249

UTILITY FUEL COAL WASTE FUEL EQV BTU\*10\*\*6= 118. HOT WATER BTU\*10\*\*6= 0.

	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
0 ONCOGN N O C O G O N	118.	0.	0.	0.	0.	0.	161.	107.	161.	COAL-FGD	268.	0	0.	0.13	0.51
1 STM141 STM-TURB-1 POWR	118.	65.	203.	138.	34.	10.	-2.	0.	203.	RESIDUAL	203.	0	0.43	0.17	0.68
1 STM141 STM-TURB-1 HEAT	118.	66.	201.	137.	34.	10.	0.	1.	201.	RESIDUAL	202.	0	0.44	0.17	0.68
1 STM141 STM-TURB-1 POWR	118.	65.	203.	138.	34.	10.	-2.	0.	203.	COAL-FGD	203.	0	0.43	0.17	0.68
1 STM141 STM-TURB-1 HEAT	118.	66.	201.	137.	34.	10.	0.	1.	201.	COAL-FGD	202.	0	0.44	0.17	0.68
1 STM141 STM-TURB-1 POWR	118.	65.	203.	138.	34.	10.	-2.	0.	203.	COAL-AFB	203.	0	0.43	0.17	0.58
1 STM141 STM-TURB-1 HEAT	118.	66.	201.	137.	34.	10.	0.	1.	201.	COAL-AFB	202.	0	0.44	0.17	0.68
2 STM088 STM-TURB-8 POWR	118.	13.	254.	182.	34.	10.	-53.	0.	254.	RESIDUAL	254.	0	0.09	0.13	0.54
2 STM088 STM-TURB-8 HEAT	118.	50.	191.	137.	26.	8.	0.	26.	191.	RESIDUAL	218.	0	0.33	0.12	0.63
2 STM088 STM-TURB-8 POWR	118.	13.	254.	182.	34.	10.	-53.	0.	254.	COAL-FGD	254.	0	0.09	0.13	0.54
2 STM088 STM-TURB-8 HEAT	118.	50.	191.	137.	26.	8.	0.	26.	191.	COAL-FGD	218.	0	0.33	0.12	0.63
2 STM088 STM-TURB-8 POWR	118.	13.	254.	182.	34.	10.	-53.	0.	254.	COAL-AFB	254.	0	0.09	0.13	0.54
2 STM088 STM-TURB-8 HEAT	118.	50.	191.	137.	26.	8.	0.	26.	191.	COAL-AFB	218.	0	0.33	0.12	0.63
3 PFBSTM PFB-STMTB- POWR	118.	66.	147.	90.	34.	10.	55.	0.	202.	COAL-PFB	202.	10	0.44	0.17	0.68
3 PFBSTM PFB-STMTB- HEAT	118.	100.	224.	137.	52.	15.	0.	-55.	224.	COAL-PFB	168.	0	0.48	0.23	0.61
4 TISTMT TI-STMTB-1 POWR	80.	65.	122.	69.	34.	10.	80.	0.	202.	RESIDUAL	202.	10	0.19	0.17	0.68
4 TISTMT TI-STMTB-1 HEAT	118.	35.	66.	37.	18.	5.	118.	49.	183.	RESIDUAL	233.	10	0.23	0.08	0.59
4 TISTMT TI-STMTB-1 POWR	118.	65.	122.	69.	34.	10.	80.	0.	202.	COAL	202.	10	0.44	0.17	0.68
4 TISTMT TI-STMTB-1 HEAT	118.	130.	243.	137.	68.	20.	0.	-106.	243.	COAL	137.	0	0.51	0.28	0.56
5 TIHRSG THERMIONIC POWR	0.	25.	243.	161.	34.	10.	-29.	0.	243.	RESIDUAL	243.	0	-0.52	0.14	0.56
5 TIHRSG THERMIONIC HEAT	118.	12.	56.	37.	8.	2.	118.	82.	173.	RESIDUAL	255.	10	0.08	0.03	0.54
5 TIHRSG THERMIONIC POWR	118.	25.	243.	161.	34.	10.	-29.	0.	243.	COAL	243.	0	0.17	0.14	0.56
5 TIHRSG THERMIONIC HEAT	118.	46.	206.	137.	29.	8.	0.	16.	208.	COAL	222.	0	0.31	0.13	0.62
6 STIRL STIRLING-1 POWR	92.	48.	128.	59.	34.	10.	92.	0.	220.	DISTILLA	220.	0	0.15	0.16	0.62
6 STIRL STIRLING-1 HEAT	118.	30.	80.	37.	21.	6.	118.	40.	198.	DISTILLA	238.	0	0.20	0.09	0.58

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 2

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 10101 MW 10.00 PROCESS MILLIONS BTU/HR 137.0 PROCESS TEMP(F) 300. PRODUCT NASA-CLBR#1 HOURS PER YEAR 8000.

POWER TO HEAT RATIO 0.249

UTILITY FUEL COAL

WASTE FUEL EQV BTU\*10\*\*6= 118. HOT WATER BTU\*10\*\*6= 0.

			WASTE FUEL USED 10**6 BTU/HR	FUEL NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL 10**6 BTU/HR	TOTAL FUEL 10**6 BTU/HR	SITE FUEL 10**6 BTU/HR	NET+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
6 STIRL	STIRLING-1	POWR	92.	48.	128.	59.	34.	10.	92.	0.	220.	RESIDUAL	220.	0	0.15	0.16	0.62
6 STIRL	STIRLING-1	HEAT	118.	30.	80.	37.	21.	6.	118.	40.	198.	RESIDUAL	238.	0	0.20	0.09	0.58
6 STIRL	STIRLING-1	POWR	118.	48.	128.	59.	34.	10.	92.	0.	220.	COAL	220.	0	0.32	0.16	0.62
6 STIRL	STIRLING-1	HEAT	118.	112.	296.	137.	79.	23.	0.	-140.	296.	COAL	156.	0	0.38	0.27	0.46
7 HEGT85	HELIUM-GT-	POWR	118.	27.	106.	22.	34.	10.	135.	0.	241.	COAL-AFB	241.	10	0.18	0.14	0.57
7 HEGT85	HELIUM-GT-	HEAT	118.	163.	649.	137.	208.	61.	0.	-544.	649.	COAL-AFB	105.	0	0.24	0.32	0.21
8 HEGT60	HELIUM-GT-	POWR	118.	29.	132.	46.	34.	10.	107.	0.	239.	COAL-AFB	239.	10	0.19	0.14	0.57
8 HEGT60	HELIUM-GT-	HEAT	118.	86.	395.	137.	102.	30.	0.	-213.	395.	COAL-AFB	182.	10	0.24	0.26	0.35
9 HEGT00	HELIUM-GT-	POWR	118.	28.	194.	98.	34.	10.	46.	0.	240.	COAL-AFB	240.	10	0.19	0.14	0.57
9 HEGT00	HELIUM-GT-	HEAT	118.	39.	271.	137.	48.	14.	0.	-43.	271.	COAL-AFB	229.	10	0.20	0.18	0.50
10 FCMCCL	FUEL-CL-MO	POWR	0.	57.	112.	53.	34.	10.	98.	0.	211.	COAL	211.	10	-0.40	0.16	0.65
10 FCMCCL	FUEL-CL-MO	HEAT	0.	147.	289.	137.	88.	26.	0.	-188.	289.	COAL	121.	10	0.09	0.30	0.47
11 FCSTCL	FUEL-CL-ST	POWR	0.	59.	86.	33.	34.	10.	123.	0.	208.	COAL	208.	10	-0.39	0.16	0.66
11 FCSTCL	FUEL-CL-ST	HEAT	0.	248.	359.	137.	143.	42.	0.	-339.	359.	COAL	20.	10	0.27	0.40	0.38
12 IGGTST	INT-GAS-GT	POWR	0.	48.	114.	46.	34.	10.	106.	0.	220.	COAL	220.	10	-0.47	0.16	0.62
12 IGGTST	INT-GAS-GT	HEAT	0.	141.	335.	137.	101.	29.	0.	-208.	335.	COAL	127.	10	0.06	0.30	0.41
13 GTSOAR	GT-HRSG-10	POWR	100.	50.	118.	52.	34.	10.	100.	0.	218.	RESIDUAL	218.	0	0.22	0.16	0.63
13 GTSOAR	GT-HRSG-10	HEAT	118.	36.	84.	37.	24.	7.	118.	31.	201.	RESIDUAL	232.	10	0.24	0.10	0.59
14 GTAC08	GT-HRSG-08	POWR	85.	56.	126.	65.	34.	10.	85.	0.	211.	RESIDUAL	211.	10	0.16	0.16	0.65
14 GTAC08	GT-HRSG-08	HEAT	118.	32.	72.	37.	20.	6.	118.	46.	190.	RESIDUAL	236.	10	0.21	0.08	0.58
15 GTAC12	GT-HRSG-12	POWR	100.	56.	112.	52.	34.	10.	100.	0.	211.	RESIDUAL	211.	10	0.25	0.16	0.65
15 GTAC12	GT-HRSG-12	HEAT	118.	40.	79.	37.	24.	7.	118.	31.	197.	RESIDUAL	228.	10	0.27	0.11	0.60
16 GTAC16	GT-HRSG-16	POWR	106.	56.	106.	47.			106.	0.	212.	RESIDUAL	212.	10	0.30	0.16	0.65
16 GTAC16	GT-HRSG-16	HEAT	118.	44.	84.	37.			118.	22.	202.	RESIDUAL	223.	10	0.30	0.12	0.61
17 GTWC16	GT-HRSG-16	POWR	110.	50.	108.	44.			110.	0.	218.	RESIDUAL	216.	10	0.28	0.16	0.63
17 GTWC16	GT-HRSG-16	HEAT	118.	42.	92.	37.			118.	16.	209.	RESIDUAL	226.	10	0.28	0.13	0.61

ORIGINAL PAGE IS  
OF POOR QUALITY

HONEYWELL PAGE PRINTING SYSTEM - P1185-02

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 10101 MW 10.00 PROCESS MILLIONS BTU/HR 137.0 PROCESS TEMP(F) 300. PRODUCT NASA-CLBR#1 HOURS PER YEAR 8000.

		POWER TO HEAT RATIO 0.249 WASTE FUEL EQV BTU*10**6= 118. HOT WATER BTU*10**6= 0.																
UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET* TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR		
18	CC1626	GTST-16/26	POWR	118.	50.	88.	26.	34.	10.	130.	0.	218.	RESIDUAL	218.	10	0.33	0.16	0.63
18	CC1626	GTST-16/26	HEAT	118.	70.	124.	37.	48.	14.	118.	-44.	242.	RESIDUAL	198.	10	0.36	0.20	0.57
19	CC1622	GTST-16/22	POWR	118.	52.	89.	29.	34.	10.	127.	0.	216.	RESIDUAL	216.	10	0.35	0.16	0.64
19	CC1622	GTST-16/22	HEAT	118.	66.	113.	37.	43.	13.	118.	-29.	231.	RESIDUAL	202.	10	0.37	0.19	0.59
20	CC1222	GTST-12/22	POWR	118.	53.	88.	29.	34.	10.	127.	0.	215.	RESIDUAL	215.	10	0.35	0.16	0.64
20	CC1222	GTST-12/22	HEAT	118.	67.	112.	37.	43.	13.	118.	-29.	230.	RESIDUAL	201.	10	0.37	0.19	0.60
21	CC0822	GTST-08/22	POWR	118.	56.	93.	36.	34.	10.	118.	0.	212.	RESIDUAL	212.	10	0.37	0.16	0.65
21	CC0822	GTST-08/22	HEAT	118.	57.	95.	37.	35.	10.	118.	-2.	212.	RESIDUAL	211.	10	0.38	0.16	0.65
22	STIG15	STIG-15-16	POWR	118.	18.	90.	1.	34.	10.	160.	0.	249.	RESIDUAL	249.	10	0.12	0.14	0.55
22	STIG15	STIG-15-16	HEAT	118.	586.	2846.	37.	1084.	318.	118.	-3282.	2964.	RESIDUAL	-318.	0	0.17	0.37	0.05
23	STIG10	STIG-10-16	POWR	118.	26.	95.	13.	34.	10.	146.	0.	241.	RESIDUAL	241.	10	0.18	0.14	0.57
23	STIG10	STIG-10-16	HEAT	118.	78.	279.	37.	100.	29.	118.	-207.	397.	RESIDUAL	190.	0	0.22	0.25	0.35
24	STIG1S	STIG-1S-16	POWR	118.	30.	102.	21.	34.	10.	136.	0.	238.	RESIDUAL	238.	10	0.20	0.14	0.58
24	STIG1S	STIG-1S-16	HEAT	118.	52.	176.	37.	59.	17.	118.	-77.	293.	RESIDUAL	216.	10	0.23	0.20	0.47
25	DEADV3	DIESEL-ADV	POWR	118.	40.	92.	21.	34.	10.	136.	0.	228.	RESIDUAL	228.	0	0.27	0.15	0.60
25	DEADV3	DIESEL-ADV	HEAT	118.	69.	159.	37.	59.	17.	118.	-78.	277.	RESIDUAL	199.	0	0.30	0.21	0.50
26	DEADV2	DIESEL-ADV	POWR	118.	42.	92.	23.	34.	10.	134.	0.	226.	RESIDUAL	226.	1	0.28	0.15	0.61
26	DEADV2	DIESEL-ADV	HEAT	118.	67.	146.	37.	54.	16.	118.	-62.	263.	RESIDUAL	201.	1	0.31	0.21	0.52
27	DEADV1	DIESEL-ADV	POWR	118.	57.	92.	36.	34.	10.	119.	0.	211.	RESIDUAL	211.	1	0.38	0.16	0.65
27	DEADV1	DIESEL-ADV	HEAT	118.	59.	95.	37.	35.	10.	118.	-3.	212.	RESIDUAL	209.	1	0.38	0.17	0.65
28	DEHTPM	ADV-DIESEL	POWR	112.	59.	97.	42.	34.	10.	112.	0.	209.	RESIDUAL	209.	0	0.35	0.16	0.66
28	DEHTPM	ADV-DIESEL	HEAT	118.	52.	85.	37.	39.	9.	118.	13.	203.	RESIDUAL	216.	0	0.34	0.14	0.63
29	DESOA3	DIESEL-SOA	POWR	118.	34.	95.	19.	34.	10.	139.	0.	234.	DISTILLA	234.	0	0.23	0.15	0.59
29	DESOA3	DIESEL-SOA	HEAT	118.	67.	186.	37.	67.	20.	118.	-103.	304.	DISTILLA	200.	0	0.27	0.22	0.45
29	DESOA3	DIESEL-SOA	POWR	118.	34.	95.	19.	34.	10.	139.	0.	234.	RESIDUAL	234.	0	0.23	0.15	0.59
29	DESOA3	DIESEL-SOA	HEAT	118.	67.	186.	37.	67.	20.	118.	-103.	304.	RESIDUAL	200.	0	0.27	0.22	0.45

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 4

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 10101 MW 10.00 PROCESS MILLIONS BTU/HR 137.0 PROCESS TEMP(F) 300. PRODUCT NASA-CLBR#1 HOURS PER YEAR 8000.

POWER TO HEAT RATIO 0.249

WASTE FUEL EQV BTU\*10\*\*6= 118. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	AUX MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
30 DES0A2 DIESEL-SOA POWR		118.	37.	95.	21.	34.	10.	137.	0.	231.	DISTILLA	231.	1	0.24	0.15	0.59
30 DES0A2 DIESEL-SOA HEAT		118.	65.	168.	37.	61.	18.	118.	-83.	286.	DISTILLA	203.	1	0.28	0.21	0.48
30 DES0A2 DIESEL-SOA POWR		118.	37.	95.	21.	34.	10.	137.	0.	231.	RESIDUAL	231.	1	0.24	0.15	0.59
30 DES0A2 DIESEL-SOA HEAT		118.	65.	168.	37.	61.	18.	118.	-83.	286.	RESIDUAL	203.	1	0.28	0.21	0.48
31 DES0A1 DIESEL-SOA POWR		117.	57.	95.	38.	34.	10.	117.	0.	211.	DISTILLA	211.	1	0.37	0.16	0.65
31 DES0A1 DIESEL-SOA HEAT		118.	55.	92.	37.	33.	10.	118.	3.	210.	DISTILLA	212.	1	0.37	0.16	0.64
31 DES0A1 DIESEL-SOA POWR		117.	57.	95.	38.	34.	10.	117.	0.	211.	RESIDUAL	211.	1	0.37	0.16	0.65
31 DES0A1 DIESEL-SOA HEAT		118.	55.	92.	37.	33.	10.	118.	3.	210.	RESIDUAL	212.	1	0.37	0.16	0.64
32 GTS0AD GT-HRSG-10 POWR		97.	54.	117.	55.	34.	10.	97.	0.	214.	DISTILLA	214.	10	0.22	0.18	0.64
32 GTS0AD GT-HRSG-10 HEAT		118.	37.	79.	37.	23.	7.	118.	35.	197.	DISTILLA	231.	10	0.24	0.10	0.59
33 GTRA08 GT-85RE-08 POWR		118.	52.	96.	35.	34.	10.	121.	0.	216.	DISTILLA	216.	10	0.34	0.16	0.63
33 GTRA08 GT-85RE-08 HEAT		118.	55.	102.	37.	37.	11.	118.	-8.	220.	DISTILLA	212.	10	0.35	0.17	0.62
34 GTRA12 GT-85RE-12 POWR		118.	53.	95.	35.	34.	10.	120.	0.	215.	DISTILLA	215.	10	0.35	0.16	0.64
34 GTRA12 GT-85RE-12 HEAT		118.	55.	101.	37.	36.	11.	118.	-6.	218.	DISTILLA	212.	10	0.36	0.17	0.63
35 GTRA16 GT-85RE-16 POWR		117.	53.	98.	37.	34.	10.	117.	0.	215.	DISTILLA	215.	10	0.35	0.16	0.64
35 GTRA16 GT-85RE-16 HEAT		118.	52.	97.	37.	34.	10.	118.	1.	215.	DISTILLA	215.	10	0.35	0.16	0.64
36 GTR208 GT-60RE-08 POWR		109.	52.	107.	45.	34.	10.	109.	0.	215.	DISTILLA	215.	10	0.29	0.16	0.64
36 GTR208 GT-60RE-08 HEAT		118.	44.	89.	37.	28.	8.	118.	18.	206.	DISTILLA	224.	10	0.29	0.13	0.61
37 GTR212 GT-60RE-12 POWR		112.	52.	103.	41.	34.	10.	112.	0.	216.	DISTILLA	216.	10	0.31	0.16	0.63
37 GTR212 GT-60RE-12 HEAT		118.	46.	92.	37.	30.	9.	118.	12.	210.	DISTILLA	221.	10	0.31	0.14	0.62
38 GTR216 GT-60RE-16 POWR		113.	53.	101.	41.	34.	10.	113.	0.	215.	DISTILLA	215.	10	0.33	0.16	0.64
38 GTR216 GT-60RE-16 HEAT		118.	48.	92.	37.	31.	9.	118.	9.	210.	DISTILLA	219.	10	0.32	0.14	0.62
39 GTRW08 GT-85RE-08 POWR		118.	43.	97.	29.	34.	10.	127.	0.	225.	DISTILLA	225.	10	0.29	0.15	0.61
39 GTRW08 GT-85RE-08 HEAT		118.	56.	125.	37.	44.	13.	118.	-30.	243.	DISTILLA	212.	10	0.31	0.18	0.56
40 GTRW12 GT-85RE-12 POWR		118.	46.	94.	28.	34.	10.	128.	0.	222.	DISTILLA	222.	10	0.31	0.15	0.62
40 GTRW12 GT-85RE-12 HEAT		118.	61.	124.	37.	45.	13.	118.	-34.	241.	DISTILLA	207.	10	0.33	0.13	0.57

MONEYWELL PAGE PRINTING SYSTEM- P1185-02

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 5

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 10101 MW 10.00 PROCESS MILLIONS BTU/HR 137.0 PROCESS TEMP(F) 300. PRODUCT NASA-CLBR#1 HOURS PER YEAR 8000.

UTILITY FUEL		COAL		POWER TO HEAT RATIO 0.249										WASTE FUEL EQV BTU*10**6= 118. HOT WATER BTU*10**6= 0.			
WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED-NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TCTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR		
41 GTRW16 GT-85RE-16 POWR	118.	46.	96.	30.	34.	10.	126.	0.	221.	DISTILLA	221.	10	0.31	0.15	0.62		
41 GTRW16 GT-85RE-16 HEAT	118.	57.	118.	37.	42.	12.	118.	-25.	236.	DISTILLA	211.	10	0.33	0.18	0.58		
42 GTR308 GT-60RE-08 POWR	117.	41.	110.	38.	34.	10.	117.	0.	227.	DISTILLA	227.	10	0.27	0.15	0.60		
42 GTR308 GT-60RE-08 HEAT	118.	40.	108.	37.	33.	10.	118.	2.	225.	DISTILLA	228.	10	0.27	0.15	0.60		
43 GTR312 GT-60RE-12 POWR	118.	47.	100.	34.	34.	10.	121.	0.	221.	DISTILLA	221.	10	0.31	0.15	0.62		
43 GTR312 GT-60RE-12 HEAT	118.	51.	109.	37.	37.	11.	118.	-10.	226.	DISTILLA	217.	10	0.32	0.16	0.61		
44 GTR316 GT-60RE-16 POWR	118.	47.	101.	34.	34.	10.	121.	0.	221.	DISTILLA	221.	10	0.31	0.15	0.62		
44 GTR316 GT-60RE-16 HEAT	118.	50.	108.	37.	37.	11.	118.	-8.	226.	DISTILLA	218.	10	0.32	0.16	0.61		
45 FCPADS FUEL-CL-PH POWR	118.	35.	90.	13.	34.	10.	143.	0.	233.	DISTILLA	233.	0	0.23	0.15	0.59		
45 FCPADS FUEL-CL-PH HEAT	118.	84.	218.	37.	83.	24.	118.	-152.	335.	DISTILLA	183.	0	0.28	0.25	0.41		
46 FCMCDS FUEL-CL-MO POWR	118.	47.	83.	19.	34.	10.	138.	0.	221.	DISTILLA	221.	0	0.31	0.15	0.62		
46 FCMCDS FUEL-CL-MO HEAT	118.	89.	159.	37.	65.	19.	118.	-98.	276.	DISTILLA	179.	0	0.36	0.24	0.50		

BASE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 10102 MW 30.00 PROCESS MILLIONS BTU/HR 410.0 PROCESS TEMP(F) 300. PRODUCT NASA-CLBR#2 HOURS PER YEAR 8000.

UTILITY FUEL		COAL		POWER TO HEAT RATIO 0.250										WASTE FUEL EQV BTU*10**6= 0.		HOT WATER BTU*10**6= 0.	
		WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
0	ONCOGN N O C O G O N	0.	0.	0.	0.	0.	0.	482.	320.	482.	COAL-FGD	802.	0	0.	0.13	0.51	
1	STM141 STM-TURB-1 POWR	0.	194.	609.	415.	102.	30.	-6.	0.	609.	RESIDUAL	609.	0	0.24	0.17	0.67	
1	STM141 STM-TURB-1 HEAT	0.	197.	601.	410.	101.	30.	0.	4.	601.	RESIDUAL	605.	0	0.25	0.17	0.68	
1	STM141 STM-TURB-1 POWR	0.	194.	609.	415.	102.	30.	-6.	0.	609.	COAL-FGD	609.	0	0.24	0.17	0.67	
1	STM141 STM-TURB-1 HEAT	0.	197.	601.	410.	101.	30.	0.	4.	601.	COAL-FGD	605.	0	0.25	0.17	0.68	
1	STM141 STM-TURB-1 POWR	0.	194.	609.	415.	102.	30.	-6.	0.	609.	COAL-AFB	609.	0	0.24	0.17	0.67	
1	STM141 STM-TURB-1 HEAT	0.	197.	601.	410.	101.	30.	0.	4.	601.	COAL-AFB	605.	0	0.25	0.17	0.68	
2	STM088 STM-TURB-8 POWR	0.	39.	763.	546.	102.	30.	-160.	0.	763.	RESIDUAL	763.	0	0.05	0.13	0.54	
2	STM088 STM-TURB-8 HEAT	0.	150.	573.	410.	77.	23.	0.	80.	573.	RESIDUAL	653.	0	0.19	0.12	0.63	
2	STM088 STM-TURB-8 POWR	0.	39.	763.	546.	102.	30.	-160.	0.	763.	COAL-FGD	763.	0	0.05	0.13	0.54	
2	STM088 STM-TURB-8 HEAT	0.	150.	573.	410.	77.	23.	0.	80.	573.	COAL-FGD	653.	0	0.19	0.12	0.63	
2	STM088 STM-TURB-8 POWR	0.	39.	763.	546.	102.	30.	-160.	0.	763.	COAL-AFB	763.	0	0.05	0.13	0.54	
2	STM088 STM-TURB-8 HEAT	0.	150.	573.	410.	77.	23.	0.	80.	573.	COAL-AFB	653.	0	0.19	0.12	0.63	
3	PFBSTM PFB-STMTB- POWR	0.	197.	442.	271.	102.	30.	164.	0.	606.	COAL-PFB	606.	0	0.25	0.17	0.68	
3	PFBSTM PFB-STMTB- HEAT	0.	298.	669.	410.	155.	45.	0.	-165.	669.	COAL-PFB	504.	0	0.31	0.23	0.61	
4	TISTMT TI-STMTB-1 POWR	0.	196.	366.	206.	102.	30.	240.	0.	606.	RESIDUAL	606.	0	0.24	0.17	0.68	
4	TISTMT TI-STMTB-1 HEAT	0.	391.	728.	410.	203.	60.	0.	-316.	728.	RESIDUAL	412.	0	0.35	0.28	0.56	
4	TISTMT TI-STMTB-1 POWR	0.	196.	366.	206.	102.	30.	240.	0.	606.	COAL	606.	0	0.24	0.17	0.68	
4	TISTMT TI-STMTB-1 HEAT	0.	391.	728.	410.	203.	60.	0.	-316.	728.	COAL	412.	0	0.35	0.28	0.56	
5	TIHRSG THERMIONIC POWR	0.	75.	728.	484.	102.	30.	-88.	0.	728.	RESIDUAL	728.	0	0.09	0.14	0.56	
5	TIHRSG THERMIONIC HEAT	0.	137.	616.	410.	87.	25.	0.	49.	616.	RESIDUAL	665.	0	0.17	0.13	0.62	
5	TIHRSG THERMIONIC POWR	0.	75.	728.	484.	102.	30.	-88.	0.	728.	COAL	728.	0	0.09	0.14	0.56	
5	TIHRSG THERMIONIC HEAT	0.	137.	616.	410.	87.	25.	0.	49.	616.	COAL	665.	0	0.17	0.13	0.62	
6	STIRL STIRLING-1 POWR	0.	145.	384.	177.	102.	30.	274.	0.	657.	DISTILLA	657.	0	0.18	0.16	0.62	
6	STIRL STIRLING-1 HEAT	0.	335.	687.	410.	237.	69.	0.	-419.	687.	DISTILLA	468.	0	0.27	0.27	0.46	

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 7

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 10102 MW 30.00 PROCESS MILLIONS BTU/HR 410.0 PROCESS TEMP(F) 300. PRODUCT NASA-CLBR#2 HOURS PER YEAR 8000.

POWER TO HEAT RATIO 0.250

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET USED 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN ELECT 10**6 BTU/HR	AUX BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	NET* TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
6 STIRL	STIRLING-1 POWR	0.	145.	384.	177.	102.	30.	274.	0.	657.	RESIDUAL	657.	0	0.18	0.16	0.62
6 STIRL	STIRLING-1 HEAT	0.	335.	887.	410.	237.	69.	0.	-419.	887.	RESIDUAL	468.	0	0.27	0.27	0.46
6 STIRL	STIRLING-1 POWR	0.	145.	384.	177.	102.	30.	274.	0.	657.	COAL	657.	0	0.18	0.16	0.62
6 STIRL	STIRLING-1 HEAT	0.	335.	887.	410.	237.	69.	0.	-419.	887.	COAL	468.	0	0.27	0.27	0.46
7 HEGT85	HELIUM-GT- POWR	0.	80.	319.	67.	102.	30.	403.	0.	722.	COAL-AFB	722.	10	0.10	0.14	0.57
7 HEGT85	HELIUM-GT- HEAT	0.	488.	1941.	410.	623.	183.	0.	-1627.	1941.	COAL-AFB	314.	0	0.20	0.32	0.21
8 HEGT60	HELIUM-GT- POWR	0.	86.	395.	137.	102.	30.	321.	0.	716.	COAL-AFB	716.	10	0.11	0.14	0.57
8 HEGT60	HELIUM-GT- HEAT	0.	257.	1183.	410.	306.	90.	0.	-638.	1183.	COAL-AFB	545.	0	0.18	0.26	0.35
9 HEGT00	HELIUM-GT- POWR	0.	84.	582.	294.	102.	30.	137.	0.	719.	COAL-AFB	719.	10	0.10	0.14	0.57
9 HEGT00	HELIUM-GT- HEAT	0.	117.	812.	410.	143.	42.	0.	-127.	812.	COAL-AFB	685.	10	0.13	0.18	0.50
10 FCMCCL	FUEL-CL-MO POWR	0.	171.	337.	160.	102.	30.	294.	0.	631.	COAL	631.	10	0.21	0.16	0.65
10 FCMCCL	FUEL-CL-MO HEAT	0.	439.	864.	410.	263.	77.	0.	-501.	864.	COAL	363.	10	0.34	0.30	0.47
11 FCSTCL	FUEL-CL-ST POWR	0.	178.	258.	98.	102.	30.	367.	0.	624.	COAL	624.	10	0.22	0.16	0.66
11 FCSTCL	FUEL-CL-ST HEAT	0.	742.	1074.	410.	427.	125.	0.	-1013.	1074.	COAL	60.	0	0.41	0.40	0.38
12 IGGTST	INT-GAS-GT POWR	0.	143.	341.	139.	102.	30.	318.	0.	659.	COAL	659.	10	0.18	0.16	0.62
12 IGGTST	INT-GAS-GT HEAT	0.	421.	1001.	410.	301.	88.	0.	-621.	1001.	COAL	381.	0	0.30	0.30	0.41
13 GTSOAR	GT-HRSG-10 POWR	0.	151.	353.	156.	102.	30.	299.	0.	652.	RESIDUAL	652.	0	0.19	0.16	0.63
13 GTSOAR	GT-HRSG-10 HEAT	0.	396.	926.	410.	269.	79.	0.	-520.	926.	RESIDUAL	407.	0	0.30	0.29	0.44
14 GTAC08	GT-HRSG-08 POWR	0.	169.	379.	194.	102.	30.	254.	0.	633.	RESIDUAL	633.	0	0.21	0.16	0.65
14 GTAC08	GT-HRSG-08 HEAT	0.	357.	901.	410.	218.	63.	0.	-356.	801.	RESIDUAL	445.	0	0.31	0.27	0.51
15 GTAC12	GT-HRSG-12 POWR	0.	169.	336.	157.	102.	30.	298.	0.	633.	RESIDUAL	633.	0	0.21	0.16	0.65
15 GTAC12	GT-HRSG-12 HEAT	0.	441.	876.	410.	267.	78.	0.	-515.	876.	RESIDUAL	361.	0	0.33	0.31	0.47
16 GTAC16	GT-HRSG-16 POWR	0.	167.	317.	140.	102.	30.	318.	0.	635.	RESIDUAL	635.	0	0.21	0.16	0.65
16 GTAC16	GT-HRSG-16 HEAT	0.	491.	929.	410.	300.	88.	0.	-618.	929.	RESIDUAL	311.	0	0.35	0.32	0.44
17 GTWC16	GT-HRSG-16 POWR	0.	149.	325.	131.	102.	30.	328.	0.	653.	RESIDUAL	653.	0	0.19	0.16	0.63
17 GTWC16	GT-HRSG-16 HEAT	0.	466.	1015.	410.	320.	94.	0.	-679.	1015.	RESIDUAL	336.	0	0.31	0.32	0.40



I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 10102 MW 30.00 PROCESS MILLIONS BTU/HR 410.0 PROCESS TEMP(F) 300. PRODUCT NASA-CLBR#2 HOURS PER YEAR 8000.

UTILITY FUEL COAL POWER TO HEAT RATIO 0.250  
WASTE FUEL EGW BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED 10**6 BTU/HR	COGEN USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES ELECT 10**6 BTU/HR	COGEN MM ELECT 10**6 BTU/HR	AUX BOILER 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL USED 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET TOTAL UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR
18 CC1626 GTST-16/26 POWR	0.	149.	263.	79.	102.	30.	390.	0.	653.	RESIDUAL	653.	0	0.19	0.16
18 CC1626 GTST-16/26 HEAT	0.	778.	1373.	410.	534.	157.	0.	-1349.	1373.	RESIDUAL	24.	0	0.36	0.39
19 CC1622 GTST-16/22 POWR	0.	156.	266.	87.	102.	30.	380.	0.	646.	RESIDUAL	646.	0	0.19	0.16
19 CC1622 GTST-16/22 HEAT	0.	735.	1251.	410.	481.	141.	0.	-1183.	1251.	RESIDUAL	68.	0	0.37	0.38
20 CC1222 GTST-12/22 POWR	0.	158.	265.	88.	102.	30.	379.	0.	644.	RESIDUAL	644.	0	0.20	0.16
20 CC1222 GTST-12/22 HEAT	0.	739.	1242.	410.	479.	141.	0.	-1179.	1242.	RESIDUAL	63.	0	0.37	0.39
21 CC0822 GTST-08/22 POWR	0.	169.	279.	109.	102.	30.	354.	0.	633.	RESIDUAL	633.	0	0.21	0.16
21 CC0822 GTST-08/22 HEAT	0.	634.	1049.	410.	384.	113.	0.	-881.	1049.	RESIDUAL	168.	0	0.38	0.37
22 STIG15 STIG-15-16 POWR	0.	55.	269.	3.	102.	30.	478.	0.	747.	RESIDUAL	747.	0	0.07	0.14
22 STIG15 STIG-15-16 HEAT	0.	6494.	31538.	410.	12016.	3522.	0.	-37231.	31538.	RESIDUAL	-5692.	0	0.17	0.38
23 STIG10 STIG-10-16 POWR	0.	79.	285.	38.	102.	30.	438.	0.	723.	RESIDUAL	723.	0	0.10	0.14
23 STIG10 STIG-10-16 HEAT	0.	860.	3094.	410.	1111.	326.	0.	-3153.	3094.	RESIDUAL	-58.	0	0.22	0.36
24 STIG15 STIG-15-16 POWR	0.	90.	305.	64.	102.	30.	407.	0.	712.	RESIDUAL	712.	0	0.11	0.14
24 STIG15 STIG-15-16 HEAT	0.	575.	1945.	410.	652.	191.	0.	-1717.	1945.	RESIDUAL	227.	0	0.23	0.34
25 DEADV3 DIESEL-ADV POWR	0.	120.	276.	64.	102.	30.	407.	0.	683.	RESIDUAL	683.	0	0.15	0.15
25 DEADV3 DIESEL-ADV HEAT	0.	763.	1760.	410.	653.	191.	0.	-1721.	1760.	RESIDUAL	39.	0	0.30	0.37
26 DEADV2 DIESEL-ADV POWR	0.	126.	276.	70.	102.	30.	400.	0.	676.	RESIDUAL	676.	1	0.16	0.15
26 DEADV2 DIESEL-ADV HEAT	0.	740.	1614.	410.	599.	176.	0.	-1592.	1614.	RESIDUAL	63.	1	0.31	0.37
27 DEADV1 DIESEL-ADV POWR	0.	171.	276.	108.	102.	30.	355.	0.	631.	RESIDUAL	631.	1	0.21	0.16
27 DEADV1 DIESEL-ADV HEAT	0.	649.	1049.	410.	389.	114.	0.	-896.	1049.	RESIDUAL	153.	1	0.38	0.37
28 DEHTPM ADV-DIESEL POWR	0.	177.	292.	127.	102.	30.	333.	0.	626.	RESIDUAL	626.	0	0.22	0.16
28 DEHTPM ADV-DIESEL HEAT	0.	572.	947.	410.	332.	97.	0.	-716.	947.	RESIDUAL	230.	0	0.38	0.35
29 DESO3 DIESEL-SO3 POWR	0.	103.	284.	56.	102.	30.	416.	0.	700.	DISTILLA	700.	0	0.13	0.15
29 DESO3 DIESEL-SO3 HEAT	0.	746.	2061.	410.	744.	218.	0.	-2006.	2061.	DISTILLA	56.	0	0.27	0.36
29 DESO3 DIESEL-SO3 POWR	0.	103.	284.	56.	102.	30.	416.	0.	700.	RESIDUAL	700.	0	0.13	0.15
29 DESO3 DIESEL-SO3 HEAT	0.	746.	2061.	410.	744.	218.	0.	-2006.	2061.	RESIDUAL	56.	0	0.27	0.36

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 9

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 10102 MW 30.00 PROCESS MILLIONS BTU/HR 410.0 PROCESS TEMP(F) 300. PRODUCT NASA-CLBR#2 HOURS PER YEAR 8000.

		POWER TO HEAT RATIO 0.250														
		WASTE FUEL					EQV BTU*10**6=					HOT WATER BTU*10**6=				
UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	AUX MW ELECT	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET* TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
30 DES0A2 DIESEL-S0A	POWR	0.	110.	284.	62.	102.	30.	409.	0.	693.	DISTILLA	693.	1	0.14	0.15	0.59
30 DES0A2 DIESEL-S0A	HEAT	0.	721.	1864.	410.	673.	197.	0.	-1783.	1864.	DISTILLA	81.	1	0.28	0.36	0.22
30 DES0A2 DIESEL-S0A	POWR	0.	110.	284.	62.	102.	30.	409.	0.	693.	RESIDUAL	693.	1	0.14	0.15	0.59
30 DES0A2 DIESEL-S0A	HEAT	0.	721.	1864.	410.	673.	197.	0.	-1783.	1864.	RESIDUAL	81.	1	0.28	0.36	0.22
31 DES0A1 DIESEL-S0A	POWR	0.	170.	284.	114.	102.	30.	349.	0.	632.	DISTILLA	632.	1	0.21	0.16	0.65
31 DES0A1 DIESEL-S0A	HEAT	0.	613.	1022.	410.	369.	108.	0.	-834.	1022.	DISTILLA	189.	1	0.37	0.36	0.40
31 DES0A1 DIESEL-S0A	POWR	0.	170.	284.	114.	102.	30.	349.	0.	632.	RESIDUAL	632.	1	0.21	0.16	0.65
31 DES0A1 DIESEL-S0A	HEAT	0.	613.	1022.	410.	369.	108.	0.	-834.	1022.	RESIDUAL	189.	1	0.37	0.36	0.40
32 GTS0AD GT-HRSG-10	POWR	0.	163.	351.	164.	102.	30.	289.	0.	640.	DISTILLA	640.	0	0.20	0.16	0.64
32 GTS0AD GT-HRSG-10	HEAT	0.	406.	875.	410.	256.	75.	0.	-479.	875.	DISTILLA	396.	0	0.32	0.29	0.47
33 GTRA08 GT-85RE-08	POWR	0.	155.	287.	104.	102.	30.	360.	0.	647.	DISTILLA	647.	0	0.19	0.16	0.63
33 GTRA08 GT-85RE-08	HEAT	0.	614.	1134.	410.	405.	119.	0.	-946.	1134.	DISTILLA	189.	0	0.35	0.36	0.36
34 GTRA12 GT-85RE-12	POWR	0.	158.	286.	105.	102.	30.	359.	0.	645.	DISTILLA	645.	0	0.20	0.16	0.64
34 GTRA12 GT-85RE-12	HEAT	0.	615.	1115.	410.	399.	117.	0.	-928.	1115.	DISTILLA	187.	0	0.36	0.36	0.37
35 GTRA16 GT-85RE-16	POWR	0.	159.	293.	112.	102.	30.	351.	0.	644.	DISTILLA	644.	0	0.20	0.16	0.64
35 GTRA16 GT-85RE-16	HEAT	0.	580.	1075.	410.	375.	110.	0.	-853.	1075.	DISTILLA	222.	0	0.35	0.35	0.38
36 GTR208 GT-60RE-08	POWR	0.	157.	320.	134.	102.	30.	325.	0.	645.	DISTILLA	645.	0	0.20	0.16	0.64
36 GTR208 GT-60RE-08	HEAT	0.	482.	982.	410.	314.	92.	0.	-662.	982.	DISTILLA	320.	0	0.33	0.32	0.42
37 GTR212 GT-60RE-12	POWR	0.	156.	310.	124.	102.	30.	336.	0.	646.	DISTILLA	646.	0	0.19	0.16	0.63
37 GTR212 GT-60RE-12	HEAT	0.	514.	1022.	410.	337.	99.	0.	-734.	1022.	DISTILLA	288.	0	0.33	0.33	0.40
38 GTR216 GT-60RE-16	POWR	0.	159.	304.	122.	102.	30.	339.	0.	643.	DISTILLA	643.	0	0.20	0.16	0.64
38 GTR216 GT-60RE-16	HEAT	0.	537.	1024.	410.	345.	101.	0.	-759.	1024.	DISTILLA	265.	0	0.34	0.34	0.40
39 GTRW08 GT-85RE-08	POWR	0.	130.	292.	86.	102.	30.	381.	0.	672.	DISTILLA	672.	0	0.16	0.15	0.61
39 GTRW08 GT-85RE-08	HEAT	0.	617.	1385.	410.	486.	142.	0.	-1199.	1385.	DISTILLA	186.	0	0.31	0.35	0.30
40 GTRW12 GT-85RE-12	POWR	0.	138.	281.	84.	102.	30.	383.	0.	665.	DISTILLA	665.	0	0.17	0.15	0.62
40 GTRW12 GT-85RE-12	HEAT	0.	671.	1370.	410.	499.	146.	0.	-1239.	1370.	DISTILLA	131.	0	0.33	0.36	0.30

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 10102 MW 30.00 PROCESS MILLIONS BTU/HR 410.0 PROCESS TEMP(F) 300. PRODUCT NASA-CLBR#2 HOURS PER YEAR 8000.

UTILITY FUEL		COAL		POWER TO HEAT RATIO 0.250										WASTE FUEL EGV BTU*10**6=		0.		HOT WATER BTU*10**6=		0.	
WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED-NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR							
41 GTRW16	GT-85RE-16	POWR	0.	139.	287.	90.	102.	30.	376.	0.	663.	DISTILLA	663.	0	0.17	0.15	0.62				
41 GTRW16	GT-85RE-16	HEAT	0.	633.	1306.	410.	466.	137.	0.	-1137.	1306.	DISTILLA	169.	0	0.33	0.36	0.31				
42 GTR308	GT-60RE-08	POWR	0.	123.	330.	113.	102.	30.	349.	0.	679.	DISTILLA	679.	0	0.15	0.15	0.60				
42 GTR308	GT-60RE-08	HEAT	0.	445.	1193.	410.	370.	108.	0.	-836.	1193.	DISTILLA	357.	0	0.27	0.31	0.34				
43 GTR312	GT-60RE-12	POWR	0.	140.	299.	102.	102.	30.	363.	0.	662.	DISTILLA	662.	0	0.17	0.15	0.62				
43 GTR312	GT-60RE-12	HEAT	0.	565.	1205.	410.	412.	121.	0.	-968.	1205.	DISTILLA	237.	0	0.32	0.34	0.34				
44 GTR316	GT-60RE-16	POWR	0.	140.	302.	103.	102.	30.	361.	0.	663.	DISTILLA	663.	0	0.17	0.15	0.62				
44 GTR316	GT-60RE-16	HEAT	0.	553.	1198.	410.	406.	119.	0.	-949.	1198.	DISTILLA	249.	0	0.32	0.34	0.34				
45 FCPADS	FUEL-CL-PH	POWR	0.	104.	269.	46.	102.	30.	428.	0.	698.	DISTILLA	698.	0	0.13	0.15	0.59				
45 FCPADS	FUEL-CL-PH	HEAT	0.	935.	2412.	410.	916.	269.	0.	-2544.	2412.	DISTILLA	-132.	0	0.28	0.38	0.17				
46 FCMCDS	FUEL-CL-MO	POWR	0.	140.	248.	58.	102.	30.	414.	0.	663.	DISTILLA	663.	0	0.17	0.15	0.62				
46 FCMCDS	FUEL-CL-MO	HEAT	0.	988.	1760.	410.	725.	212.	0.	-1946.	1760.	DISTILLA	-186.	0	0.36	0.41	0.23				

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 20111 MW 1.94 PROCESS MILLIONS BTU/HR 24.0 PROCESS TEMP(F) 250. PRODUCT MEAT-PACKING HOURS PER YEAR 2100.

UTILITY FUEL		COAL		POWER TO HEAT RATIO 0.276 WASTE FUEL EQV BTU*10**6= 0. HOT WATER BTU*10**6= 10.												
		WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED- NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
0	ONOCGN N O C O G O N	0.	0.	0.	0.	0.	0.	28.	21.	28.	RESIDUAL	49.	0	0.	0.14	0.49
1	STM141 STM-TURB-1 POWR	0.	13.	34.	22.	7.	2.	2.	0.	36.	RESIDUAL	36.	10	0.26	0.18	0.67
1	STM141 STM-TURB-1 HEAT	0.	14.	37.	24.	7.	2.	0.	-2.	37.	RESIDUAL	35.	10	0.26	0.20	0.65
1	STM141 STM-TURB-1 POWR	0.	13.	34.	22.	7.	2.	2.	0.	36.	COAL-FGD	36.	10	0.26	0.18	0.67
1	STM141 STM-TURB-1 HEAT	0.	14.	37.	24.	7.	2.	0.	-2.	37.	COAL-FGD	35.	10	0.26	0.20	0.65
1	STM141 STM-TURB-1 POWR	0.	13.	34.	22.	7.	2.	2.	0.	36.	COAL-AFB	36.	10	0.26	0.18	0.67
1	STM141 STM-TURB-1 HEAT	0.	14.	37.	24.	7.	2.	0.	-2.	37.	COAL-AFB	35.	10	0.26	0.20	0.65
2	STM088 STM-TURB-8 POWR	0.	8.	41.	28.	7.	2.	-5.	0.	41.	RESIDUAL	41.	10	0.17	0.16	0.59
2	STM088 STM-TURB-8 HEAT	0.	11.	35.	24.	6.	2.	0.	3.	35.	RESIDUAL	38.	10	0.23	0.15	0.63
2	STM088 STM-TURB-8 POWR	0.	8.	41.	28.	7.	2.	-5.	0.	41.	COAL-FGD	41.	10	0.17	0.16	0.59
2	STM088 STM-TURB-8 HEAT	0.	11.	35.	24.	6.	2.	0.	3.	35.	COAL-FGD	38.	10	0.23	0.15	0.63
2	STM088 STM-TURB-8 POWR	0.	8.	41.	28.	7.	2.	-5.	0.	41.	COAL-AFB	41.	10	0.17	0.16	0.59
2	STM088 STM-TURB-8 HEAT	0.	11.	35.	24.	6.	2.	0.	3.	35.	COAL-AFB	38.	10	0.23	0.15	0.63
3	PFBSTM PFB-STMTB- POWR	0.	13.	26.	15.	7.	2.	10.	0.	36.	COAL-PFB	36.	10	0.26	0.18	0.66
3	PFBSTM PFB-STMTB- HEAT	0.	20.	41.	24.	10.	3.	0.	-12.	41.	COAL-PFB	29.	10	0.33	0.26	0.59
4	TISTMT TI-STMTB-1 POWR	0.	13.	22.	12.	7.	2.	14.	0.	36.	RESIDUAL	36.	10	0.26	0.18	0.66
4	TISTMT TI-STMTB-1 HEAT	0.	26.	44.	24.	13.	4.	0.	-21.	44.	RESIDUAL	23.	10	0.37	0.30	0.54
4	TISTMT TI-STMTB-1 POWR	0.	13.	22.	12.	7.	2.	14.	0.	36.	COAL	36.	10	0.26	0.18	0.66
4	TISTMT TI-STMTB-1 HEAT	0.	26.	44.	24.	13.	4.	0.	-21.	44.	COAL	23.	10	0.37	0.30	0.54
5	TIHRSG THERMIONIC POWR	0.	2.	47.	32.	7.	2.	-9.	0.	47.	RESIDUAL	47.	10	0.04	0.14	0.51
5	TIHRSG THERMIONIC HEAT	0.	8.	35.	24.	5.	1.	0.	5.	35.	RESIDUAL	41.	10	0.17	0.12	0.59
5	TIHRSG THERMIONIC POWR	0.	2.	47.	32.	7.	2.	-9.	0.	47.	COAL	47.	10	0.04	0.14	0.51
5	TIHRSG THERMIONIC HEAT	0.	8.	35.	24.	5.	1.	0.	5.	35.	COAL	41.	10	0.17	0.12	0.59
6	STIRL STIRLING-1 POWR	0.	10.	22.	10.	7.	2.	17.	0.	38.	DISTILLA	38.	0	0.21	0.17	0.62
6	STIRL STIRLING-1 HEAT	0.	25.	53.	24.	16.	5.	0.	-29.	53.	DISTILLA	24.	0	0.32	0.30	0.45

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 12

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 20111 MW 1.94 PROCESS MILLIONS BTU/HR 24.0 PROCESS TEMP(F) 250. PRODUCT MEAT-PACKING HOURS PER YEAR 2100.

POWER TO HEAT RATIO 0.276

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 10.

UTILITY FUEL COAL

			WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED- NO-NET BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BTU/HR	UTILIT FUEL 10**6 BTU/HR	TOTAL FUEL 10**6 BTU/HR	SITE FUEL 10**6 BTU/HR	NET+ TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
6	STIRL	STIRLING-1	POWR	0.	10.	22.	10.	7.	2.	17.	0.	38. RESIDUAL	38.	0	0.21	0.17	0.62
6	STIRL	STIRLING-1	HEAT	0.	25.	53.	24.	16.	5.	0.	-29.	53. RESIDUAL	24.	0	0.32	0.30	0.45
6	STIRL	STIRLING-1	POWR	0.	10.	22.	10.	7.	2.	17.	0.	38. COAL	38.	0	0.21	0.17	0.62
6	STIRL	STIRLING-1	HEAT	0.	25.	53.	24.	16.	5.	0.	-29.	53. COAL	24.	0	0.32	0.30	0.45
7	HEGT85	HELIUM-GT-	POWR	0.	9.	21.	8.	7.	2.	19.	0.	40. COAL-AFB	40.	10	0.19	0.17	0.60
7	HEGT85	HELIUM-GT-	HEAT	0.	28.	64.	24.	21.	6.	0.	-43.	64. COAL-AFB	20.	10	0.31	0.32	0.38
8	HEGT60	HELIUM-GT-	POWR	0.	7.	26.	10.	7.	2.	17.	0.	42. COAL-AFB	42.	10	0.13	0.16	0.57
8	HEGT60	HELIUM-GT-	HEAT	0.	16.	63.	24.	16.	5.	0.	-30.	63. COAL-AFB	33.	10	0.20	0.26	0.38
9	HEGT00	HELIUM-GT-	POWR	0.	6.	38.	20.	7.	2.	5.	0.	43. COAL-AFB	43.	10	0.12	0.15	0.56
9	HEGT00	HELIUM-GT-	HEAT	0.	7.	46.	24.	8.	2.	0.	-5.	46. COAL-AFB	42.	10	0.14	0.18	0.52
10	FCMCL	FUEL-CL-MO	POWR	0.	11.	22.	10.	7.	2.	16.	0.	38. COAL	38.	10	0.23	0.17	0.63
10	FCMCL	FUEL-CL-MO	HEAT	0.	26.	50.	24.	15.	4.	0.	-27.	50. COAL	23.	10	0.34	0.30	0.48
11	FCSTCL	FUEL-CL-ST	POWR	0.	12.	16.	6.	7.	2.	21.	0.	37. COAL	37.	10	0.24	0.18	0.64
11	FCSTCL	FUEL-CL-ST	HEAT	0.	47.	66.	24.	27.	8.	0.	-64.	66. COAL	2.	10	0.42	0.41	0.37
12	IGGTST	INT-GAS-GT	POWR	0.	9.	21.	8.	7.	2.	19.	0.	39. COAL	39.	10	0.19	0.17	0.61
12	IGGTST	INT-GAS-GT	HEAT	0.	28.	61.	24.	19.	6.	0.	-40.	61. COAL	21.	10	0.31	0.32	0.39
13	GTSCAR	GT-HRSG-10	POWR	0.	10.	23.	10.	7.	2.	16.	0.	39. RESIDUAL	39.	10	0.21	0.17	0.62
13	GTSCAR	GT-HRSG-10	HEAT	0.	23.	53.	24.	15.	4.	0.	-27.	53. RESIDUAL	26.	10	0.31	0.29	0.45
14	GTAC08	GT-HRSG-08	POWR	0.	11.	25.	12.	7.	2.	14.	0.	38. RESIDUAL	38.	10	0.22	0.17	0.63
14	GTAC08	GT-HRSG-08	HEAT	0.	21.	47.	24.	13.	4.	0.	-13.	47. RESIDUAL	28.	10	0.31	0.27	0.51
15	GTAC12	GT-HRSG-12	POWR	0.	11.	22.	10.	7.	2.	16.	0.	38. RESIDUAL	38.	10	0.23	0.17	0.63
15	GTAC12	GT-HRSG-12	HEAT	0.	26.	51.	24.	15.	5.	0.	-28.	51. RESIDUAL	23.	10	0.34	0.31	0.47
16	GTAC16	GT-HRSG-16	POWR	0.	11.	20.	9.	7.	2.	17.	0.	38. RESIDUAL	38.	10	0.23	0.17	0.63
16	GTAC16	GT-HRSG-16	HEAT	0.	29.	53.	24.	17.	5.	0.	-33.	53. RESIDUAL	20.	10	0.35	0.32	0.45
17	GTWC16	GT-HRSG-16	POWR	0.	10.	21.	8.	7.	2.	16.	0.	39. RESIDUAL	39.	10	0.20	0.17	0.61
17	GTWC16	GT-HRSG-16	HEAT	0.	27.	60.	24.	19.	5.	0.	-38.	60. RESIDUAL	22.	10	0.31	0.32	0.40

ORIGINAL PAGE IS  
OF POOR QUALITY

HONEYWELL PAGE PRINTING SYSTEM- P1185-02

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 20111 MW 1.94 PROCESS MILLIONS BTU/HR 24.0 PROCESS TEMP(F) 250. PRODUCT MEAT-PACKING HOURS PER YEAR 2100.

		POWER TO HEAT RATIO 0.276															
UTILITY FUEL		COAL		WASTE FUEL EQV BTU*10**6= 0. HOT WATER BTU*10**6= 10.													
		WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
18	CC1626 GTST-16/26 POWR	0.	10.	16.	5.	7.	2.	23.	0.	39.	RESIDUAL	39.	10	0.20	0.17	0.61	
18	CC1626 GTST-16/26 HEAT	0.	50.	84.	24.	34.	10.	0.	-84.	84.	RESIDUAL	-1.	10	0.37	0.40	0.29	
19	CC1622 GTST-16/22 POWR	0.	10.	17.	5.	7.	2.	22.	0.	39.	RESIDUAL	39.	10	0.21	0.17	0.62	
19	CC1622 GTST-16/22 HEAT	0.	47.	76.	24.	30.	9.	0.	-74.	76.	RESIDUAL	2.	10	0.38	0.40	0.31	
20	CC1222 GTST-12/22 POWR	0.	10.	17.	5.	7.	2.	22.	0.	39.	RESIDUAL	39.	10	0.21	0.17	0.62	
20	CC1222 GTST-12/22 HEAT	0.	47.	76.	24.	30.	9.	0.	-74.	76.	RESIDUAL	2.	10	0.38	0.40	0.32	
21	CC0822 GTST-08/22 POWR	0.	11.	17.	6.	7.	2.	21.	0.	38.	RESIDUAL	38.	10	0.22	0.17	0.63	
21	CC0822 GTST-08/22 HEAT	0.	41.	64.	24.	25.	7.	0.	-56.	64.	RESIDUAL	8.	10	0.39	0.38	0.37	
22	STIG15 STIG-15-16 POWR	0.	4.	17.	0.	7.	2.	28.	0.	45.	RESIDUAL	45.	10	0.07	0.15	0.53	
22	STIG15 STIG-15-16 HEAT	0.	380.	1846.	24.	703.	206.	0.	-2177.	1846.	RESIDUAL	-331.	0	0.17	0.38	0.01	
23	STIG10 STIG-10-16 POWR	0.	5.	18.	2.	7.	2.	25.	0.	44.	RESIDUAL	44.	10	0.10	0.15	0.55	
23	STIG10 STIG-10-16 HEAT	0.	50.	181.	24.	65.	19.	0.	-183.	181.	RESIDUAL	-1.	0	0.22	0.36	0.13	
24	STIG1S STIG-1S-16 POWR	0.	6.	20.	4.	7.	2.	23.	0.	43.	RESIDUAL	43.	10	0.12	0.15	0.56	
24	STIG1S STIG-1S-16 HEAT	0.	34.	114.	24.	38.	11.	0.	-99.	114.	RESIDUAL	15.	10	0.23	0.34	0.21	
25	DEADV3 DIESEL-ADV POWR	0.	10.	18.	6.	7.	2.	21.	0.	39.	RESIDUAL	39.	10	0.20	0.17	0.61	
25	DEADV3 DIESEL-ADV HEAT	0.	40.	72.	24.	27.	8.	0.	-63.	72.	RESIDUAL	9.	0	0.36	0.37	0.33	
26	DEADV2 DIESEL-ADV POWR	0.	10.	18.	6.	7.	2.	21.	0.	39.	RESIDUAL	39.	11	0.20	0.17	0.61	
26	DEADV2 DIESEL-ADV HEAT	0.	40.	72.	24.	27.	8.	0.	-63.	72.	RESIDUAL	9.	1	0.36	0.37	0.33	
27	DEADV1 DIESEL-ADV POWR	0.	12.	18.	7.	7.	2.	20.	0.	37.	RESIDUAL	37.	11	0.24	0.18	0.64	
27	DEADV1 DIESEL-ADV HEAT	0.	37.	56.	24.	21.	6.	0.	-46.	56.	RESIDUAL	11.	1	0.39	0.37	0.41	
28	DEHTPM ADV-DIESEL POWR	0.	12.	18.	8.	7.	2.	19.	0.	37.	RESIDUAL	37.	10	0.24	0.18	0.65	
28	DEHTPM ADV-DIESEL HEAT	0.	36.	55.	24.	20.	6.	0.	-42.	55.	RESIDUAL	13.	0	0.40	0.37	0.44	
29	DESOA3 DIESEL-SOA POWR	0.	9.	18.	6.	7.	2.	21.	0.	40.	DISTILLA	40.	0	0.19	0.17	0.60	
29	DESOA3 DIESEL-SOA HEAT	0.	38.	76.	24.	27.	8.	0.	-65.	76.	DISTILLA	11.	0	0.33	0.36	0.32	
29	DESOA3 DIESEL-SOA POWR	0.	9.	18.	6.	7.	2.	21.	0.	40.	RESIDUAL	40.	0	0.19	0.17	0.60	
29	DESOA3 DIESEL-SOA HEAT	0.	38.	76.	24.	27.	8.	0.	-65.	76.	RESIDUAL	11.	0	0.33	0.36	0.32	

HONEYWELL PAGE PRINTING SYSTEM - P1185-02

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 20111 MW 1.94 PROCESS MILLIONS BTU/HR 24.0 PROCESS TEMP(F) 250. PRODUCT MEAT-PACKING HOURS PER YEAR 2100.

POWER TO HEAT RATIO 0.276

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 10.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
30 DES0A2 DIESEL-S0A POWR		0.	9.	18.	6.	7.	2.	21.	0.	40.	DISTILLA	40.	1	0.19	0.17	0.60
30 DES0A2 DIESEL-S0A HEAT		0.	38.	76.	24.	27.	8.	0.	-65.	76.	DISTILLA	11.	1	0.33	0.36	0.32
30 DES0A2 DIESEL-S0A POWR		0.	9.	18.	6.	7.	2.	21.	0.	40.	RESIDUAL	40.	1	0.19	0.17	0.60
30 DES0A2 DIESEL-S0A HEAT		0.	38.	76.	24.	27.	8.	0.	-65.	76.	RESIDUAL	11.	1	0.33	0.36	0.32
31 DES0A1 DIESEL-S0A POWR		0.	12.	18.	8.	7.	2.	19.	0.	37.	DISTILLA	37.	1	0.24	0.18	0.64
31 DES0A1 DIESEL-S0A HEAT		0.	35.	57.	24.	20.	6.	0.	-43.	57.	DISTILLA	13.	1	0.39	0.36	0.42
31 DES0A1 DIESEL-S0A POWR		0.	12.	18.	8.	7.	2.	19.	0.	37.	RESIDUAL	37.	1	0.24	0.18	0.64
31 DES0A1 DIESEL-S0A HEAT		0.	35.	57.	24.	20.	6.	0.	-43.	57.	RESIDUAL	13.	1	0.39	0.36	0.42
32 GTS0AD GT-HRSG-10 POWR		0.	11.	23.	11.	7.	2.	16.	0.	38.	DISTILLA	38.	10	0.22	0.17	0.63
32 GTS0AD GT-HRSG-10 HEAT		0.	24.	50.	24.	15.	4.	0.	-25.	50.	DISTILLA	25.	10	0.32	0.29	0.48
33 GTRA08 GT-85RE-08 POWR		0.	10.	19.	7.	7.	2.	20.	0.	39.	DISTILLA	39.	10	0.21	0.17	0.62
33 GTRA08 GT-85RE-08 HEAT		0.	36.	64.	24.	23.	7.	0.	-50.	64.	DISTILLA	13.	10	0.36	0.36	0.38
34 GTRA12 GT-85RE-12 POWR		0.	10.	18.	7.	7.	2.	20.	0.	38.	DISTILLA	38.	10	0.21	0.17	0.62
34 GTRA12 GT-85RE-12 HEAT		0.	36.	63.	24.	23.	7.	0.	-50.	63.	DISTILLA	13.	10	0.36	0.36	0.38
35 GTRA16 GT-85RE-16 POWR		0.	10.	19.	7.	7.	2.	19.	0.	38.	DISTILLA	38.	10	0.21	0.17	0.62
35 GTRA16 GT-85RE-16 HEAT		0.	34.	61.	24.	21.	6.	0.	-46.	61.	DISTILLA	15.	10	0.36	0.35	0.39
36 GTR208 GT-60RE-08 POWR		0.	10.	21.	9.	7.	2.	18.	0.	38.	DISTILLA	38.	10	0.21	0.17	0.62
36 GTR208 GT-60RE-08 HEAT		0.	28.	56.	24.	18.	5.	0.	-35.	56.	DISTILLA	21.	10	0.34	0.32	0.43
37 GTR212 GT-60RE-12 POWR		0.	10.	20.	8.	7.	2.	19.	0.	39.	DISTILLA	39.	10	0.21	0.17	0.62
37 GTR212 GT-60RE-12 HEAT		0.	30.	58.	24.	19.	6.	0.	-40.	58.	DISTILLA	19.	10	0.34	0.33	0.41
38 GTR216 GT-60RE-16 POWR		0.	11.	20.	8.	7.	2.	19.	0.	38.	DISTILLA	38.	10	0.22	0.17	0.63
38 GTR216 GT-60RE-16 HEAT		0.	31.	58.	24.	20.	6.	0.	-41.	58.	DISTILLA	18.	10	0.35	0.34	0.41
39 GTRW08 GT-85RE-08 POWR		0.	9.	19.	6.	7.	2.	21.	0.	40.	DISTILLA	40.	10	0.18	0.16	0.60
39 GTRW08 GT-85RE-08 HEAT		0.	36.	78.	24.	27.	8.	0.	-65.	78.	DISTILLA	13.	10	0.31	0.35	0.31
40 GTRW12 GT-85RE-12 POWR		0.	9.	18.	6.	7.	2.	22.	0.	40.	DISTILLA	40.	10	0.19	0.17	0.60
40 GTRW12 GT-85RE-12 HEAT		0.	39.	78.	24.	28.	8.	0.	-68.	78.	DISTILLA	10.	10	0.33	0.36	0.31

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 20111 MW 1.94 PROCESS MILLIONS BTU/HR 24.0 PROCESS TEMP(F) 250. PRODUCT MEAT-PACKING HOURS PER YEAR 2100.

UTILITY FUEL COAL POWER TO HEAT RATIO 0.276 WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 10.

WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED-NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET* TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
------------------------------	--------------------------------	------------------------------	--------------------------------	---------------------------------	----------------	-------------------------------	-------------------------------	------------------------------	-----------------------------	---------------------------------	------	------	-------------	------------

41	GTRW16	GT-85RE-16	POWR	0.	9.	19.	6.	7.	2.	21.	0.	40.	DISTILLA	40.	10	0.19	0.17	0.60
41	GTRW16	GT-85RE-16	HEAT	0.	37.	74.	24.	27.	8.	0.	-62.	74.	DISTILLA	12.	10	0.33	0.36	0.32
42	GTR308	GT-60RE-08	POWR	0.	8.	21.	8.	7.	2.	19.	0.	41.	DISTILLA	41.	10	0.17	0.16	0.59
42	GTR308	GT-60RE-08	HEAT	0.	26.	66.	24.	21.	6.	0.	-44.	66.	DISTILLA	23.	10	0.28	0.31	0.36
43	GTR312	GT-60RE-12	POWR	0.	9.	19.	7.	7.	2.	20.	0.	40.	DISTILLA	40.	10	0.19	0.17	0.60
43	GTR312	GT-60RE-12	HEAT	0.	33.	69.	24.	24.	7.	0.	-53.	69.	DISTILLA	16.	10	0.32	0.34	0.35
44	GTR316	GT-60RE-16	POWR	0.	9.	20.	7.	7.	2.	20.	0.	40.	DISTILLA	40.	10	0.19	0.17	0.60
44	GTR316	GT-60RE-16	HEAT	0.	32.	69.	24.	23.	7.	0.	-52.	69.	DISTILLA	17.	10	0.32	0.34	0.35
45	FCPADS	FUEL-CL-PH	POWR	0.	9.	17.	5.	7.	2.	22.	0.	40.	DISTILLA	40.	0	0.19	0.17	0.61
45	FCPADS	FUEL-CL-PH	HEAT	0.	43.	81.	24.	31.	9.	0.	-76.	81.	DISTILLA	5.	0	0.35	0.38	0.29
46	FCMCDS	FUEL-CL-MO	POWR	0.	9.	16.	4.	7.	2.	24.	0.	40.	DISTILLA	40.	10	0.18	0.17	0.60
46	FCMCDS	FUEL-CL-MO	HEAT	0.	58.	103.	24.	42.	12.	0.	-112.	103.	DISTILLA	-9.	0	0.36	0.41	0.23

HONEYWELL PAGE PRINTING SYSTEM- P1185-02



I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 20261 MW 1.31 PROCESS MILLIONS BTU/HR 11.0 PROCESS TEMP(F) 250. PRODUCT FLUID-MILK HOURS PER YEAR 2100.

POWER TO HEAT RATIO 0.406

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 6.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	AUX COGEN ELECT MW	UTILIT FUEL BOILR USED 10**6 BTU/HR	TOTAL FUEL SITE USED 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
0 ONCOGN N O C O G O N		0.	0.	0.	0.	0.	0.	13.	14.	13.	RESIDUAL	27.	0	0.	0.17	0.41
1 STM141 STM-TURB-1 POWR		0.	4.	23.	15.	4.	1.	-5.	0.	23.	RESIDUAL	23.	10	0.15	0.20	0.48
1 STM141 STM-TURB-1 HEAT		0.	6.	17.	11.	3.	1.	0.	4.	17.	RESIDUAL	20.	10	0.24	0.16	0.54
1 STM141 STM-TURB-1 POWR		0.	4.	23.	15.	4.	1.	-5.	0.	23.	COAL-FGD	23.	10	0.15	0.20	0.48
1 STM141 STM-TURB-1 HEAT		0.	6.	17.	11.	3.	1.	0.	4.	17.	COAL-FGD	20.	10	0.24	0.16	0.54
1 STM141 STM-TURB-1 POWR		0.	4.	23.	15.	4.	1.	-5.	0.	23.	COAL-AFB	23.	10	0.15	0.20	0.48
1 STM141 STM-TURB-1 HEAT		0.	6.	17.	11.	3.	1.	0.	4.	17.	COAL-AFB	20.	10	0.24	0.16	0.54
2 STM088 STM-TURB-8 POWR		0.	-1.	27.	19.	4.	1.	-9.	0.	27.	RESIDUAL	27.	10	-0.02	0.16	0.40
2 STM088 STM-TURB-8 HEAT		0.	5.	16.	11.	3.	1.	0.	6.	16.	RESIDUAL	22.	10	0.19	0.12	0.50
2 STM088 STM-TURB-8 POWR		0.	-1.	27.	19.	4.	1.	-9.	0.	27.	COAL-FGD	27.	10	-0.02	0.16	0.40
2 STM088 STM-TURB-8 HEAT		0.	5.	16.	11.	3.	1.	0.	6.	16.	COAL-FGD	22.	10	0.19	0.12	0.50
2 STM088 STM-TURB-8 POWR		0.	-1.	27.	19.	4.	1.	-9.	0.	27.	COAL-AFB	27.	10	-0.02	0.16	0.40
2 STM088 STM-TURB-8 HEAT		0.	5.	16.	11.	3.	1.	0.	6.	16.	COAL-AFB	22.	10	0.19	0.12	0.50
3 PFBSTM PFB-STMTB- POWR		0.	9.	17.	10.	4.	1.	1.	0.	18.	COAL-PFB	18.	10	0.32	0.24	0.60
3 PFBSTM PFB-STMTB- HEAT		0.	9.	19.	11.	5.	1.	0.	-1.	19.	COAL-PFB	18.	10	0.33	0.26	0.59
4 T1STMT TI-STMTB-1 POWR		0.	9.	15.	8.	4.	1.	4.	0.	18.	RESIDUAL	18.	10	0.32	0.24	0.60
4 T1STMT TI-STMTB-1 HEAT		0.	12.	20.	11.	6.	2.	0.	-5.	20.	RESIDUAL	15.	10	0.37	0.30	0.54
4 T1STMT TI-STMTB-1 POWR		0.	9.	15.	8.	4.	1.	4.	0.	18.	COAL	18.	10	0.32	0.24	0.60
4 T1STMT TI-STMTB-1 HEAT		0.	12.	20.	11.	6.	2.	0.	-5.	20.	COAL	15.	10	0.37	0.30	0.54
5 TIHRSG THERMIONIC POWR		0.	-5.	32.	22.	4.	1.	-12.	0.	32.	RESIDUAL	32.	10	-0.18	0.14	0.35
5 TIHRSG THERMIONIC HEAT		0.	4.	16.	11.	2.	1.	0.	7.	16.	RESIDUAL	23.	10	0.14	0.10	0.48
5 TIHRSG THERMIONIC POWR		0.	-5.	32.	22.	4.	1.	-12.	0.	32.	COAL	32.	10	-0.18	0.14	0.35
5 TIHRSG THERMIONIC HEAT		0.	4.	16.	11.	2.	1.	0.	7.	16.	COAL	23.	10	0.14	0.10	0.48
6 STIRL STIRLING-1 POWR		0.	7.	14.	7.	4.	1.	5.	0.	20.	DISTILLA	20.	0	0.27	0.23	0.56
6 STIRL STIRLING-1 HEAT		0.	12.	24.	11.	7.	2.	0.	-9.	24.	DISTILLA	15.	0	0.33	0.31	0.45

HONEYWELL PAGE PRINTING SYSTEM- P185-02

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 17

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 20261 MW 1.31 PROCESS MILLIONS BTU/HR 11.0 PROCESS TEMP(F) 250. PRODUCT FLUID-MILK HOURS PER YEAR 2100.

POWER TO HEAT RATIO 0.406

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 6.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET USED 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
6 STIRL STIRLING-1 POWR		0.	7.	14.	7.	4.	1.	5.	0.	20.	RESIDUAL	20.	0	0.27	0.23	0.56
6 STIRL STIRLING-1 HEAT		0.	12.	24.	11.	7.	2.	0.	-9.	24.	RESIDUAL	15.	0	0.33	0.31	0.45
6 STIRL STIRLING-1 POWR		0.	7.	14.	7.	4.	1.	5.	0.	20.	COAL	20.	0	0.27	0.23	0.56
6 STIRL STIRLING-1 HEAT		0.	12.	24.	11.	7.	2.	0.	-9.	24.	COAL	15.	0	0.33	0.31	0.45
7 HEGT85 HELIUM-GT- POWR		0.	7.	14.	6.	4.	1.	6.	0.	20.	COAL-AFB	20.	10	0.25	0.22	0.54
7 HEGT85 HELIUM-GT- HEAT		0.	13.	27.	11.	9.	3.	0.	-13.	27.	COAL-AFB	14.	10	0.32	0.32	0.40
8 HEGT60 HELIUM-GT- POWR		0.	4.	17.	7.	4.	1.	5.	0.	22.	COAL-AFB	22.	10	0.16	0.20	0.49
8 HEGT60 HELIUM-GT- HEAT		0.	7.	29.	11.	7.	2.	0.	-9.	29.	COAL-AFB	19.	10	0.20	0.26	0.38
9 HEGT00 HELIUM-GT- POWR		0.	2.	25.	13.	4.	1.	-3.	0.	25.	COAL-AFB	25.	10	0.06	0.18	0.43
9 HEGT00 HELIUM-GT- HEAT		0.	3.	21.	11.	4.	1.	0.	2.	21.	COAL-AFB	24.	10	0.13	0.16	0.47
10 FCMCCL FUEL-CL-MO POWR		0.	7.	15.	7.	4.	1.	5.	0.	19.	COAL	19.	10	0.28	0.23	0.57
10 FCMCCL FUEL-CL-MO HEAT		0.	12.	23.	11.	7.	2.	0.	-8.	23.	COAL	15.	10	0.34	0.30	0.48
11 FCSTCL FUEL-CL-ST POWR		0.	8.	11.	4.	4.	1.	8.	0.	19.	COAL	19.	10	0.29	0.23	0.58
11 FCSTCL FUEL-CL-ST HEAT		0.	22.	30.	11.	12.	4.	0.	-25.	30.	COAL	5.	10	0.42	0.41	0.37
12 IGGTST INT-GAS-GT POWR		0.	6.	14.	6.	4.	1.	6.	0.	21.	COAL	21.	10	0.24	0.22	0.54
12 IGGTST INT-GAS-GT HEAT		0.	13.	28.	11.	9.	3.	0.	-14.	28.	COAL	14.	10	0.31	0.32	0.39
13 GTSOAR GT-HRSG-10 POWR		0.	7.	15.	7.	4.	1.	5.	0.	20.	RESIDUAL	20.	10	0.25	0.22	0.55
13 GTSOAR GT-HRSG-10 HEAT		0.	11.	24.	11.	7.	2.	0.	-8.	24.	RESIDUAL	16.	10	0.31	0.29	0.45
14 GTAC08 GT-HRSG-08 POWR		0.	7.	17.	8.	4.	1.	3.	0.	20.	RESIDUAL	20.	10	0.27	0.23	0.56
14 GTAC08 GT-HRSG-08 HEAT		0.	10.	22.	11.	8.	2.	0.	-4.	22.	RESIDUAL	17.	10	0.31	0.27	0.51
15 GTAC12 GT-HRSG-12 POWR		0.	7.	15.	7.	4.	1.	5.	0.	19.	RESIDUAL	19.	10	0.28	0.23	0.57
15 GTAC12 GT-HRSG-12 HEAT		0.	12.	23.	11.	7.	2.	0.	-8.	23.	RESIDUAL	15.	10	0.34	0.31	0.47
16 GTAC16 GT-HRSG-16 POWR		0.	7.	14.	6.	4.	1.	6.	0.	19.	RESIDUAL	19.	10	0.28	0.23	0.56
16 GTAC16 GT-HRSG-16 HEAT		0.	13.	25.	11.	8.	2.	0.	-11.	25.	RESIDUAL	14.	10	0.35	0.32	0.45
17 GTWC16 GT-HRSG-16 POWR		0.	7.	14.	6.	4.	1.	6.	0.	20.	RESIDUAL	20.	10	0.24	0.22	0.54
17 GTWC16 GT-HRSG-16 HEAT		0.	13.	27.	11.	9.	3.	0.	-13.	27.	RESIDUAL	14.	10	0.31	0.32	0.40

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 20261 MW 1.31 PROCESS MILLIONS BTU/HR 11.0 PROCESS TEMP(F) 250. PRODUCT FLUID-MILK HOURS PER YEAR 2100.

POWER TO HEAT RATIO 0.406

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 6.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
18 CC1626 GTST-16/26 POWR		0.	7.	11.	3.	4.	1.	9.	0.	20. RESIDUAL		20.	10	0.24	0.22	0.54
18 CC1626 GTST-16/26 HEAT		0.	23.	38.	11.	15.	5.	0.	-34.	38. RESIDUAL		4.	10	0.37	0.40	0.29
19 CC1622 GTST-16/22 POWR		0.	7.	11.	4.	4.	1.	9.	0.	20. RESIDUAL		20.	10	0.26	0.22	0.55
19 CC1622 GTST-16/22 HEAT		0.	21.	35.	11.	14.	4.	0.	-30.	35. RESIDUAL		5.	10	0.38	0.40	0.31
20 CC1222 GTST-12/22 POWR		0.	7.	11.	4.	4.	1.	9.	0.	20. RESIDUAL		20.	10	0.26	0.22	0.55
20 CC1222 GTST-12/22 HEAT		0.	22.	35.	11.	14.	4.	0.	-29.	35. RESIDUAL		5.	10	0.38	0.40	0.32
21 CC0822 GTST-08/22 POWR		0.	7.	12.	4.	4.	1.	8.	0.	19. RESIDUAL		19.	10	0.28	0.23	0.56
21 CC0822 GTST-08/22 HEAT		0.	19.	29.	11.	11.	3.	0.	-21.	29. RESIDUAL		8.	10	0.39	0.38	0.37
22 ST1015 STIG-15-16 POWR		0.	2.	12.	0.	4.	1.	13.	0.	24. RESIDUAL		24.	10	0.09	0.18	0.45
22 ST1015 STIG-15-16 HEAT		0.	174.	846.	11.	322.	94.	0.	-993.	846. RESIDUAL		-147.	0	0.17	0.38	0.01
23 ST1010 STIG-10-16 POWR		0.	3.	12.	2.	4.	1.	11.	0.	23. RESIDUAL		23.	10	0.13	0.19	0.47
23 ST1010 STIG-10-16 HEAT		0.	23.	83.	11.	30.	9.	0.	-79.	83. RESIDUAL		4.	10	0.22	0.36	0.13
24 ST101S STIG-1S-16 POWR		0.	4.	13.	3.	4.	1.	10.	0.	23. RESIDUAL		23.	10	0.15	0.19	0.48
24 ST101S STIG-1S-16 HEAT		0.	15.	52.	11.	17.	5.	0.	-41.	52. RESIDUAL		11.	10	0.23	0.34	0.21
25 DEADV3 DIESEL-ADV POWR		0.	7.	12.	4.	4.	1.	8.	0.	20. RESIDUAL		20.	10	0.26	0.22	0.55
25 DEADV3 DIESEL-ADV HEAT		0.	18.	31.	11.	12.	3.	0.	-22.	31. RESIDUAL		9.	0	0.37	0.37	0.35
26 DEADV2 DIESEL-ADV POWR		0.	7.	12.	4.	4.	1.	8.	0.	20. RESIDUAL		20.	11	0.26	0.22	0.55
26 DEADV2 DIESEL-ADV HEAT		0.	18.	31.	11.	12.	3.	0.	-22.	31. RESIDUAL		9.	1	0.37	0.37	0.35
27 DEADV1 DIESEL-ADV POWR		0.	8.	12.	5.	4.	1.	7.	0.	19. RESIDUAL		19.	11	0.29	0.23	0.58
27 DEADV1 DIESEL-ADV HEAT		0.	17.	26.	11.	10.	3.	0.	-16.	26. RESIDUAL		10.	1	0.40	0.37	0.42
28 DEHTPM ADV-DIESEL POWR		0.	8.	12.	5.	4.	1.	7.	0.	19. RESIDUAL		19.	10	0.30	0.24	0.58
28 DEHTPM ADV-DIESEL HEAT		0.	16.	25.	11.	9.	3.	0.	-15.	25. RESIDUAL		10.	0	0.40	0.37	0.44
29 DES0A3 DIESEL-S0A POWR		0.	7.	12.	4.	4.	1.	8.	0.	20. DISTILLA		20.	0	0.24	0.22	0.54
29 DES0A3 DIESEL-S0A HEAT		0.	17.	32.	11.	12.	3.	0.	-22.	32. DISTILLA		10.	0	0.35	0.36	0.34
29 DES0A3 DIESEL-S0A POWR		0.	7.	12.	4.	4.	1.	8.	0.	20. RESIDUAL		20.	0	0.24	0.22	0.54
29 DES0A3 DIESEL-S0A HEAT		0.	17.	32.	11.	12.	3.	0.	-22.	32. RESIDUAL		10.	0	0.35	0.36	0.34

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 19

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 20261 MW 1.31 PROCESS MILLIONS BTU/HR 11.0 PROCESS TEMP(F) 250. PRODUCT FLUID-MILK HOURS PER YEAR 2100.

POWER TO HEAT RATIO 0.406

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 6.

UTILITY FUEL COAL

	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED-NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET* TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
--	------------------------------	--------------------------------	------------------------------	-------------------------	--------------------------	----------------	-------------------------------	-------------------------------	------------------------------	----------------	---------------------------------	------	------	-------------	------------

30 DES0A2 DIESEL-S0A POWR	0.	7.	12.	4.	4.	1.	8.	0.	20.	DISTILLA	20.	1	0.24	0.22	0.54
30 DES0A2 DIESEL-S0A HEAT	0.	17.	32.	11.	12.	3.	0.	-22.	32.	DISTILLA	10.	1	0.35	0.36	0.34
30 DES0A2 DIESEL-S0A POWR	0.	7.	12.	4.	4.	1.	8.	0.	20.	RESIDUAL	20.	1	0.24	0.22	0.54
30 DES0A2 DIESEL-S0A HEAT	0.	17.	32.	11.	12.	3.	0.	-22.	32.	RESIDUAL	10.	1	0.35	0.36	0.34
31 DES0A1 DIESEL-S0A POWR	0.	8.	12.	5.	4.	1.	7.	0.	19.	DISTILLA	19.	1	0.29	0.23	0.58
31 DES0A1 DIESEL-S0A HEAT	0.	16.	26.	11.	9.	3.	0.	-15.	26.	DISTILLA	11.	1	0.39	0.36	0.43
31 DES0A1 DIESEL-S0A POWR	0.	8.	12.	5.	4.	1.	7.	0.	19.	RESIDUAL	19.	1	0.29	0.23	0.58
31 DES0A1 DIESEL-S0A HEAT	0.	16.	26.	11.	9.	3.	0.	-15.	26.	RESIDUAL	11.	1	0.39	0.36	0.43
32 GTS0AD GT-HRS0-10 POWR	0.	7.	15.	7.	4.	1.	4.	0.	20.	DISTILLA	20.	10	0.27	0.23	0.56
32 GTS0AD GT-HRS0-10 HEAT	0.	11.	23.	11.	7.	2.	0.	-7.	23.	DISTILLA	16.	10	0.32	0.29	0.48
33 GTRA08 GT-85RE-08 POWR	0.	7.	13.	5.	4.	1.	7.	0.	20.	DISTILLA	20.	10	0.26	0.22	0.55
33 GTRA08 GT-85RE-08 HEAT	0.	16.	29.	11.	10.	3.	0.	-19.	29.	DISTILLA	11.	10	0.36	0.38	0.38
34 GTRA12 GT-85RE-12 POWR	0.	7.	12.	5.	4.	1.	7.	0.	20.	DISTILLA	20.	10	0.26	0.23	0.55
34 GTRA12 GT-85RE-12 HEAT	0.	16.	29.	11.	10.	3.	0.	-18.	29.	DISTILLA	11.	10	0.36	0.36	0.38
35 GTRA16 GT-85RE-16 POWR	0.	7.	13.	5.	4.	1.	7.	0.	20.	DISTILLA	20.	10	0.26	0.23	0.55
35 GTRA16 GT-85RE-16 HEAT	0.	15.	28.	11.	10.	3.	0.	-17.	28.	DISTILLA	11.	10	0.36	0.35	0.39
36 GTR208 GT-60RE-08 POWR	0.	7.	14.	6.	4.	1.	6.	0.	20.	DISTILLA	20.	10	0.26	0.22	0.55
36 GTR208 GT-60RE-08 HEAT	0.	13.	26.	11.	8.	2.	0.	-12.	26.	DISTILLA	14.	10	0.34	0.32	0.43
37 GTR212 GT-60RE-12 POWR	0.	7.	14.	6.	4.	1.	6.	0.	20.	DISTILLA	20.	10	0.26	0.22	0.55
37 GTR212 GT-60RE-12 HEAT	0.	14.	27.	11.	9.	3.	0.	-14.	27.	DISTILLA	13.	10	0.34	0.33	0.41
38 GTR216 GT-60RE-16 POWR	0.	7.	13.	5.	4.	1.	7.	0.	20.	DISTILLA	20.	10	0.26	0.23	0.56
38 GTR216 GT-60RE-16 HEAT	0.	14.	27.	11.	9.	3.	0.	-14.	27.	DISTILLA	13.	10	0.35	0.34	0.41
39 GTRW08 GT-85RE-08 POWR	0.	6.	13.	4.	4.	1.	8.	0.	21.	DISTILLA	21.	10	0.22	0.21	0.52
39 GTRW08 GT-85RE-08 HEAT	0.	16.	36.	11.	13.	4.	0.	-25.	36.	DISTILLA	11.	10	0.31	0.35	0.31
40 GTRW12 GT-85RE-12 POWR	0.	6.	12.	4.	4.	1.	8.	0.	21.	DISTILLA	21.	10	0.23	0.22	0.53
40 GTRW12 GT-85RE-12 HEAT	0.	18.	36.	11.	13.	4.	0.	-27.	36.	DISTILLA	9.	10	0.33	0.36	0.31

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 20

I&amp;SE P&amp;O ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 20261 MW 1.31 PROCESS MILLIONS BTU/HR 11.0 PROCESS TEMP(F) 250. PRODUCT FLUID-MILK HOURS PER YEAR 2100.

POWER TO HEAT RATIO 0.406

UTILITY FUEL COAL WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 6.

			WASTE FUEL USED 10**6 BTU/HR	SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41	GTRW16	GT-85RE-16	POWR	0.	6.	13.	4.	4.	1.	8.	0.	21.DISTILLA	21.	10	0.23	0.22	0.53
41	GTRW16	GT-85RE-16	HEAT	0.	17.	34.	11.	12.	4.	0.	-24.	34.DISTILLA	10.	10	0.33	0.36	0.32
42	GTR308	GT-60RE-08	POWR	0.	6.	14.	5.	4.	1.	7.	0.	21.DISTILLA	21.	10	0.21	0.21	0.52
42	GTR308	GT-60RE-08	HEAT	0.	12.	30.	11.	9.	3.	0.	-16.	30.DISTILLA	15.	10	0.28	0.3	0.36
43	GTR312	GT-60RE-12	POWR	0.	6.	13.	5.	4.	1.	8.	0.	21.DISTILLA	21.	10	0.23	0.22	0.53
43	GTR312	GT-60RE-12	HEAT	0.	15.	32.	11.	11.	3.	0.	-20.	32.DISTILLA	12.	10	0.32	0.34	0.35
44	GTR316	GT-60RE-16	POWR	0.	6.	13.	5.	4.	1.	8.	0.	21.DISTILLA	21.	10	0.23	0.22	0.53
44	GTR316	GT-60RE-16	HEAT	0.	15.	32.	11.	11.	3.	0.	-19.	32.DISTILLA	12.	10	0.32	0.34	0.35
45	FCPADS	FUEL-CL-PH	POWR	0.	7.	12.	4.	4.	1.	8.	0.	20.DISTILLA	20.	0	0.25	0.22	0.55
45	FCPADS	FUEL-CL-PH	HEAT	0.	19.	34.	11.	13.	4.	0.	-26.	34.DISTILLA	8.	0	0.36	0.38	0.33
46	FCMCDS	FUEL-CL-MO	POWR	0.	6.	11.	3.	4.	1.	10.	0.	21.DISTILLA	21.	10	0.23	0.21	0.53
46	FCMCDS	FUEL-CL-MO	HEAT	0.	27.	47.	11.	19.	6.	0.	-47.	47.DISTILLA	0.	0	0.36	0.41	0.23

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 20461 MW 28.50 PROCESS MILLIONS BTU/HR 659.0 PROCESS TEMP(F) 250. PRODUCT WET-CORN-MIL HOURS PER YEAR 6600.

		POWER TO HEAT RATIO 0.148														
UTILITY FUEL		COAL		WASTE FUEL EQV BTU*10**6= 0. HOT WATER BTU*10**6= 0.												
		WASTE FUEL USED	FUEL SAVED= NO-NET	COGEN FUEL USED	COGEN PROCES HEAT	COGEN PROCES POWER	COGEN MW ELECT	AUX PROCES BOILR	UTILIT FUEL USED	TOTAL FUEL SITE	SITE FUEL USED	NET= TOTAL+ UTILIT	FAIL	FESR	POWER FACTR	HEAT FACTR
		10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR		10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR				
0	ONCOGN N O C O G O N	0.	0.	0.	0.	0.	0.	775.	304.	775.	COAL-FGD	1079.	0	0.	0.09	0.61
1	STM141 STM-TURB-1 POWR	0.	189.	495.	323.	97.	29.	395.	0.	890.	RESIDUAL	890.	0	0.18	0.11	0.74
1	STM141 STM-TURB-1 HEAT	0.	386.	1008.	659.	198.	58.	0.	-315.	1008.	RESIDUAL	693.	0	0.28	0.20	0.65
1	STM141 STM-TURB-1 POWR	0.	189.	495.	323.	97.	29.	395.	0.	890.	COAL-FGD	890.	0	0.18	0.11	0.74
1	STM141 STM-TURB-1 HEAT	0.	386.	1008.	659.	198.	58.	0.	-315.	1008.	COAL-FGD	693.	0	0.28	0.20	0.65
1	STM141 STM-TURB-1 POWR	0.	189.	495.	323.	97.	29.	395.	0.	890.	COAL-AFB	890.	0	0.18	0.11	0.74
1	STM141 STM-TURB-1 HEAT	0.	386.	1008.	659.	198.	58.	0.	-315.	1008.	COAL-AFB	693.	0	0.28	0.20	0.65
2	STM088 STM-TURB-8 POWR	0.	189.	596.	410.	97.	29.	293.	0.	890.	RESIDUAL	890.	0	0.18	0.11	0.74
2	STM088 STM-TURB-8 HEAT	0.	305.	959.	659.	156.	46.	0.	-185.	959.	RESIDUAL	774.	0	0.24	0.16	0.69
2	STM088 STM-TURB-8 POWR	0.	189.	596.	410.	97.	29.	293.	0.	890.	COAL-FGD	890.	0	0.18	0.11	0.74
2	STM088 STM-TURB-8 HEAT	0.	305.	959.	659.	156.	46.	0.	-185.	959.	COAL-FGD	774.	0	0.24	0.16	0.69
2	STM088 STM-TURB-8 POWR	0.	189.	596.	410.	97.	29.	293.	0.	890.	COAL-AFB	890.	0	0.18	0.11	0.74
2	STM088 STM-TURB-8 HEAT	0.	305.	959.	659.	156.	46.	0.	-185.	959.	COAL-AFB	774.	0	0.24	0.16	0.69
3	PFBSTM PFB-STMTB- POWR	0.	188.	378.	223.	97.	29.	513.	0.	91.	COAL-PFB	891.	0	0.17	0.11	0.74
3	PFBSTM PFB-STMTB- HEAT	0.	555.	1118.	659.	287.	84.	0.	-594.	1118.	COAL-PFB	524.	0	0.33	0.26	0.59
4	TISTMT TI-STMTB-1 POWR	0.	187.	321.	173.	97.	29.	571.	0.	892.	RESIDUAL	892.	0	0.17	0.11	0.74
4	TISTMT TI-STMTB-1 HEAT	0.	710.	1220.	659.	370.	108.	0.	-852.	1220.	RESIDUAL	369.	0	0.37	0.30	0.54
4	TISTMT TI-STMTB-1 POWR	0.	187.	321.	173.	97.	29.	571.	0.	892.	COAL	892.	0	0.17	0.11	0.74
4	TISTMT TI-STMTB-1 HEAT	0.	710.	1220.	659.	370.	108.	0.	-852.	1220.	COAL	369.	0	0.37	0.30	0.54
5	TIHRSG THERMIONIC POWR	0.	164.	691.	469.	97.	29.	224.	0.	915.	RESIDUAL	915.	0	0.15	0.11	0.72
5	TIHRSG THERMIONIC HEAT	0.	231.	971.	659.	137.	40.	0.	-123.	971.	RESIDUAL	848.	0	0.19	0.14	0.68
5	TIHRSG THERMIONIC POWR	0.	164.	691.	469.	97.	29.	224.	0.	915.	COAL	915.	0	0.15	0.11	0.72
5	TIHRSG THERMIONIC HEAT	0.	231.	971.	659.	137.	40.	0.	-123.	971.	COAL	848.	0	0.19	0.14	0.68
6	STIRL STIRLING-1 POWR	0.	139.	352.	159.	97.	29.	588.	0.	940.	DISTILLA	940.	0	0.13	0.10	0.70
6	STIRL STIRLING-1 HEAT	0.	577.	1457.	659.	403.	118.	0.	-955.	1457.	DISTILLA	502.	0	0.28	0.28	0.45

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 22

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 20461 MW 28.50 PROCESS MILLIONS BTU/HR 659.0 PROCESS TEMP(F) 250. PRODUCT WET-CORN-MIL HOURS PER YEAR 6600.

POWER TO HEAT RATIO 0.148

WASTE FUEL EQV BTU\*10\*\*6= 0.

HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL COAL

		WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
6 STIRL	STIRLING-1 POWR	0.	139.	352.	159.	97.	29.	588.	0.	940.	RESIDUAL	940.	0	0.13	0.10	0.70
6 STIRL	STIRLING-1 HEAT	0.	577.	1457.	659.	403.	118.	0.	-955.	1457.	RESIDUAL	502.	0	0.28	0.28	0.45
6 STIRL	STIRLING-1 POWR	0.	139.	352.	159.	97.	29.	588.	0.	940.	COAL	940.	0	0.13	0.10	0.70
6 STIRL	STIRLING-1 HEAT	0.	577.	1457.	659.	403.	118.	0.	-955.	1457.	COAL	502.	0	0.28	0.28	0.45
7 HEGT85	HELIUM-GT- POWR	0.	98.	303.	82.	97.	29.	678.	0.	981.	COAL-AFB	981.	10	0.09	0.10	0.67
7 HEGT85	HELIUM-GT- HEAT	0.	783.	2424.	659.	778.	228.	0.	-2128.	2424.	COAL-AFB	296.	0	0.24	0.32	0.27
8 HEGT60	HELIUM-GT- POWR	0.	96.	375.	143.	97.	29.	607.	0.	983.	COAL-AFB	983.	10	0.09	0.10	0.67
8 HEGT60	HELIUM-GT- HEAT	0.	445.	1734.	659.	449.	132.	0.	-1100.	1734.	COAL-AFB	635.	0	0.20	0.26	0.38
9 HEGT00	HELIUM-GT- POWR	0.	88.	553.	267.	97.	29.	438.	0.	991.	COAL-AFB	991.	10	0.08	0.10	0.67
9 HEGT00	HELIUM-GT- HEAT	0.	203.	1271.	659.	224.	66.	0.	-395.	1271.	COAL-AFB	876.	0	0.14	0.18	0.52
10 FCMCC	FUEL-CL-MO POWR	0.	163.	320.	152.	97.	29.	596.	0.	916.	COAL	916.	10	0.15	0.11	0.72
10 FCMCC	FUEL-CL-MO HEAT	0.	706.	1386.	659.	421.	123.	0.	-1012.	1386.	COAL	373.	0	0.34	0.30	0.48
11 FCSTCL	FUEL-CL-ST POWR	0.	170.	235.	86.	97.	29.	674.	0.	909.	COAL	909.	10	0.16	0.11	0.72
11 FCSTCL	FUEL-CL-ST HEAT	0.	1299.	1800.	659.	744.	218.	0.	-2020.	1800.	COAL	-220.	0	0.42	0.41	0.37
12 IGGTST	INT-GAS-GT POWR	0.	139.	306.	120.	97.	29.	634.	0.	940.	COAL	940.	10	0.13	0.10	0.70
12 IGGTST	INT-GAS-GT HEAT	0.	762.	1679.	659.	533.	156.	0.	-1382.	1679.	COAL	317.	0	0.31	0.32	0.39
13 GTSOAR	GT-HRSO-10 POWR	0.	148.	335.	153.	97.	29.	596.	0.	931.	RESIDUAL	931.	0	0.14	0.10	0.71
13 GTSOAR	GT-HRSO-10 HEAT	0.	639.	1449.	659.	420.	123.	0.	-1009.	1449.	RESIDUAL	440.	0	0.31	0.29	0.45
14 GTAC08	GT-HRSO-08 POWR	0.	159.	360.	183.	97.	29.	560.	0.	920.	RESIDUAL	920.	0	0.15	0.11	0.72
14 GTAC08	GT-HRSO-08 HEAT	0.	573.	1296.	659.	350.	103.	0.	-789.	1296.	RESIDUAL	506.	0	0.31	0.27	0.51
15 GTAC12	GT-HRSO-12 POWR	0.	162.	319.	151.	97.	29.	598.	0.	917.	RESIDUAL	917.	0	0.15	0.11	0.72
15 GTAC12	GT-HRSO-12 HEAT	0.	710.	1395.	659.	425.	125.	0.	-1025.	1395.	RESIDUAL	369.	0	0.34	0.31	0.47
16 GTAC16	GT-HRSO-16 POWR	0.	162.	301.	135.	97.	29.	616.	0.	917.	RESIDUAL	917.	0	0.15	0.11	0.72
16 GTAC16	GT-HRSO-16 HEAT	0.	789.	1468.	659.	474.	139.	0.	-1178.	1468.	RESIDUAL	290.	0	0.35	0.32	0.45
17 GTWC16	GT-HRSO-16 POWR	0.	142.	309.	125.	97.	29.	629.	0.	938.	RESIDUAL	938.	0	0.13	0.10	0.70
17 GTWC16	GT-HRSO-16 HEAT	0.	750.	1634.	659.	515.	151.	0.	-1304.	1634.	RESIDUAL	329.	0	0.31	0.32	0.40

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 20461 MW 28.50 PROCESS MILLIONS BTU/HR 659.0 PROCESS TEMP(F) 250. PRODUCT WET-CORN-MIL HOURS PER YEAR 6600.

		POWER TO HEAT RATIO 0.148														
		WASTE FUEL EQV BTU*10**6= 0.										HOT WATER BTU*10**6= 0.				
UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
18	CC1626 GTST-16/26 POWR	0.	143.	242.	69.	97.	29.	694.	0.	936.	RESIDUAL	936.	0	0.13	0.10	0.70
18	CC1626 GTST-16/26 HEAT	0.	1361.	2302.	659.	924.	271.	0.	-2584.	2302.	RESIDUAL	-281.	0	0.37	0.40	0.29
19	CC1622 GTST-16/22 POWR	0.	150.	244.	77.	97.	29.	685.	0.	929.	RESIDUAL	929.	0	0.14	0.10	0.71
19	CC1622 GTST-16/22 HEAT	0.	1285.	2095.	659.	833.	244.	0.	-2301.	2095.	RESIDUAL	-205.	0	0.38	0.40	0.31
20	CC1222 GTST-12/22 POWR	0.	151.	243.	77.	97.	29.	685.	0.	928.	RESIDUAL	928.	0	0.14	0.10	0.71
20	CC1222 GTST-12/22 HEAT	0.	1295.	2082.	659.	833.	244.	0.	-2298.	2082.	RESIDUAL	-216.	0	0.38	0.40	0.32
21	CC0822 GTST-08/22 POWR	0.	162.	254.	95.	97.	29.	663.	0.	918.	RESIDUAL	918.	0	0.15	0.11	0.72
21	CC0822 GTST-08/22 HEAT	0.	1119.	1759.	659.	673.	197.	0.	-1799.	1759.	RESIDUAL	-39.	0	0.39	0.38	0.37
22	ST1015 STIG-15-16 POWR	0.	53.	255.	3.	97.	29.	771.	0.	1027.	RESIDUAL	1027.	0	0.05	0.09	0.64
22	ST1015 STIG-15-16 HEAT	0.	10439.	50692.	659.	19314.	5661.	0.	-60652.	50692.	RESIDUAL	-9359.	0	0.17	0.38	0.01
23	ST1010 STIG-10-16 POWR	0.	75.	271.	36.	97.	29.	733.	0.	1004.	RESIDUAL	1004.	0	0.07	0.10	0.66
23	ST1010 STIG-10-16 HEAT	0.	1383.	4974.	659.	1786.	523.	0.	-5277.	4974.	RESIDUAL	-304.	0	0.22	0.36	0.13
24	ST1015 STIG-15-16 POWR	0.	86.	290.	61.	97.	29.	703.	0.	993.	RESIDUAL	993.	0	0.08	0.10	0.66
24	ST1015 STIG-15-16 HEAT	0.	924.	3126.	659.	1048.	307.	0.	-2971.	3126.	RESIDUAL	155.	0	0.23	0.34	0.21
25	DEADV3 DIESEL-ADV POWR	0.	120.	262.	67.	97.	29.	697.	0.	959.	RESIDUAL	959.	0	0.11	0.10	0.69
25	DEADV3 DIESEL-ADV HEAT	0.	1189.	2594.	659.	962.	282.	0.	-2704.	2594.	RESIDUAL	-110.	0	0.31	0.37	0.25
26	DEADV2 DIESEL-ADV POWR	0.	120.	262.	67.	97.	29.	697.	0.	959.	RESIDUAL	959.	1	0.11	0.10	0.69
26	DEADV2 DIESEL-ADV HEAT	0.	1189.	2594.	659.	963.	282.	0.	-2704.	2594.	RESIDUAL	-110.	1	0.31	0.37	0.25
27	DEADV1 DIESEL-ADV POWR	0.	162.	262.	102.	97.	29.	655.	0.	917.	RESIDUAL	917.	1	0.15	0.11	0.72
27	DEADV1 DIESEL-ADV HEAT	0.	1044.	1685.	659.	625.	183.	0.	-1650.	1685.	RESIDUAL	35.	1	0.38	0.37	0.39
28	DEHTPM ADV-DIESEL POWR	0.	175.	266.	117.	97.	29.	638.	0.	904.	RESIDUAL	904.	0	0.16	0.11	0.73
28	DEHTPM ADV-DIESEL HEAT	0.	986.	1499.	659.	547.	160.	0.	-1406.	1499.	RESIDUAL	93.	0	0.40	0.37	0.44
29	DESOA3 DIESEL-SOA POWR	0.	104.	269.	59.	97.	29.	706.	0.	975.	DISTILLA	975.	0	0.10	0.10	0.68
29	DESOA3 DIESEL-SOA HEAT	0.	1159.	2995.	659.	1081.	317.	0.	-3075.	2995.	DISTILLA	-80.	0	0.28	0.36	0.22
29	DESOA3 DIESEL-SOA POWR	0.	104.	269.	59.	97.	29.	706.	0.	975.	RESIDUAL	975.	0	0.10	0.10	0.68
29	DESOA3 DIESEL-SOA HEAT	0.	1159.	2995.	659.	1081.	317.	0.	-3075.	2995.	RESIDUAL	-80.	0	0.28	0.36	0.22



DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 24

I&amp;SE PEC ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 20461 MW 28.50 PROCESS MILLIONS BTU/HR 659.0 PROCESS TEMP(F) 250. PRODUCT WET-CORN-MIL HOURS PER YEAR 6600.

UTILITY FUEL		COAL		POWER TO HEAT RATIO 0.148 WASTE FUEL EQV BTU*10**6= 0. HOT WATER BTU*10**6= 0.											
	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED-NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
30 DES0A2 DIESEL-S0A POWR	0.	104.	269.	59.	97.	29.	706.	0.	975.	DISTILLA	975.	1	0.10	0.10	0.68
30 DES0A2 DIESEL-S0A HEAT	0.	1159.	2995.	659.	1081.	317.	0.	-3075.	2995.	DISTILLA	-80.	1	0.28	0.36	0.22
30 DES0A2 DIESEL-S0A POWR	0.	104.	269.	59.	97.	29.	706.	0.	975.	RESIDUAL	975.	1	0.10	0.10	0.68
30 DES0A2 DIESEL-S0A HEAT	0.	1159.	2995.	659.	1081.	317.	0.	-3075.	2995.	RESIDUAL	-80.	1	0.28	0.36	0.22
31 DES0A1 DIESEL-S0A POWR	0.	162.	269.	108.	97.	29.	648.	0.	918.	DISTILLA	918.	1	0.15	0.11	0.72
31 DES0A1 DIESEL-S0A HEAT	0.	986.	1643.	659.	593.	174.	0.	-1550.	1643.	DISTILLA	93.	1	0.37	0.36	0.40
31 DES0A1 DIESEL-S0A POWR	0.	162.	269.	108.	97.	29.	648.	0.	918.	RESIDUAL	918.	1	0.15	0.11	0.72
31 DES0A1 DIESEL-S0A HEAT	0.	986.	1643.	659.	593.	174.	0.	-1550.	1643.	RESIDUAL	93.	1	0.37	0.36	0.40
32 GTS0AD GT-HRSG-10 POWR	0.	157.	333.	159.	97.	29.	589.	0.	922.	DISTILLA	922.	0	0.15	0.11	0.71
32 GTS0AD GT-HRSG-10 HEAT	0.	654.	1384.	659.	404.	118.	0.	-959.	1384.	DISTILLA	425.	0	0.32	0.29	0.48
33 GTRA08 GT-85RE-08 POWR	0.	152.	272.	103.	97.	29.	655.	0.	927.	DISTILLA	927.	0	0.14	0.10	0.71
33 GTRA08 GT-85RE-08 HEAT	0.	978.	1750.	659.	625.	183.	0.	-1648.	1750.	DISTILLA	102.	0	0.36	0.36	0.38
34 GTRA12 GT-85RE-12 POWR	0.	154.	272.	103.	97.	29.	654.	0.	925.	DISTILLA	925.	0	0.14	0.11	0.71
34 GTRA12 GT-85RE-12 HEAT	0.	981.	1730.	659.	619.	182.	0.	-1631.	1730.	DISTILLA	98.	0	0.36	0.36	0.38
35 GTRA16 GT-85RE-16 POWR	0.	154.	279.	110.	97.	29.	646.	0.	925.	DISTILLA	925.	0	0.14	0.11	0.71
35 GTRA16 GT-85RE-16 HEAT	0.	927.	1675.	659.	585.	171.	0.	-1523.	1675.	DISTILLA	152.	0	0.36	0.35	0.39
36 GTR208 GT-60RE-08 POWR	0.	153.	304.	130.	97.	29.	622.	0.	926.	DISTILLA	926.	0	0.14	0.11	0.71
36 GTR208 GT-60RE-08 HEAT	0.	775.	1538.	659.	492.	144.	0.	-1234.	1538.	DISTILLA	304.	0	0.34	0.32	0.43
37 GTR212 GT-60RE-12 POWR	0.	152.	295.	121.	97.	29.	633.	0.	927.	DISTILLA	927.	0	0.14	0.10	0.71
37 GTR212 GT-60RE-12 HEAT	0.	825.	1603.	659.	529.	155.	0.	-1349.	1603.	DISTILLA	254.	0	0.34	0.33	0.41
38 GTR216 GT-60RE-16 POWR	0.	155.	289.	119.	97.	29.	636.	0.	924.	DISTILLA	924.	0	0.14	0.11	0.71
38 GTR216 GT-60RE-16 HEAT	0.	861.	1605.	659.	541.	158.	0.	-1386.	1605.	DISTILLA	219.	0	0.35	0.34	0.41
39 GTRW08 GT-85RE-08 POWR	0.	127.	277.	85.	97.	29.	675.	0.	952.	DISTILLA	952.	0	0.12	0.10	0.69
39 GTRW08 GT-85RE-08 HEAT	0.	983.	2143.	659.	752.	220.	0.	-2047.	2143.	DISTILLA	96.	0	0.31	0.35	0.31
40 GTRW12 GT-85RE-12 POWR	0.	134.	267.	83.	97.	29.	678.	0.	945.	DISTILLA	945.	0	0.12	0.10	0.70
40 GTRW12 GT-85RE-12 HEAT	0.	1068.	2132.	659.	776.	227.	0.	-2122.	2132.	DISTILLA	11.	0	0.33	0.36	0.31

HONEYWELL PAGE PRINTING SYSTEM-PI188-02

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 20461 MW 28.50 PROCESS MILLIONS BTU/HR 659.0 PROCESS TEMP(F) 250. PRODUCT WET-CORN-MIL HOURS PER YEAR 6600.

UTILITY FUEL		COAL		POWER TO HEAT RATIO 0.148 WASTE FUEL EQV BTU*10**6= 0. HOT WATER BTU*10**6= 0.												
		WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41	GTRW16 GT-85RE-16 POWR	0.	135.	272.	88.	97.	29.	672.	0.	944.	DISTILLA	944.	0	0.12	0.10	0.70
41	GTRW16 GT-85RE-16 HEAT	0.	1011.	2042.	659.	729.	214.	0.	-1975.	2042.	DISTILLA	68.	0	0.33	0.36	0.32
42	GTR308 GT-60RE-08 POWR	0.	123.	314.	113.	97.	29.	642.	0.	956.	DISTILLA	956.	0	0.11	0.10	0.69
42	GTR308 GT-60RE-08 HEAT	0.	718.	1826.	659.	566.	166.	0.	-1485.	1826.	DISTILLA	361.	0	0.28	0.31	0.36
43	GTR312 GT-60RE-12 POWR	0.	136.	284.	99.	97.	29.	659.	0.	944.	DISTILLA	944.	0	0.13	0.10	0.70
43	GTR312 GT-60RE-12 HEAT	0.	906.	1899.	659.	650.	190.	0.	-1726.	1899.	DISTILLA	173.	0	0.32	0.34	0.35
44	GTR316 GT-60RE-16 POWR	0.	135.	287.	100.	97.	29.	658.	0.	944.	DISTILLA	944.	0	0.12	0.10	0.70
44	GTR316 GT-60RE-16 HEAT	0.	887.	1888.	659.	640.	188.	0.	-1697.	1888.	DISTILLA	192.	0	0.32	0.34	0.35
45	FCPADS FUEL-CL-PH POWR	0.	99.	256.	44.	97.	29.	724.	0.	980.	DISTILLA	980.	0	0.09	0.10	0.67
45	FCPADS FUEL-CL-PH HEAT	0.	1502.	3875.	659.	1473.	432.	0.	-4299.	3876.	DISTILLA	-423.	0	0.28	0.38	0.17
46	FCMCDS FUEL-CL-MO POWR	0.	133.	236.	55.	97.	29.	711.	0.	947.	DISTILLA	947.	0	0.12	0.10	0.70
46	FCMCDS FUEL-CL-MO HEAT	0.	1588.	2828.	659.	1165.	342.	0.	-3338.	2828.	DISTILLA	-509.	0	0.36	0.41	0.23

ORIGINAL PAGE IS  
OF POOR QUALITY

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 20631 MW 4.70 PROCESS MILLIONS BTU/HR 301.0 PROCESS TEMP(F) 250. PRODUCT BEET-SUGAR HOURS PER YEAR 2800.

UTILITY FUEL		COAL		POWER TO HEAT RATIO 0.053 WASTE FUEL EQV BTU*10**6= 76. HOT WATER BTU*10**6= 0.												
		WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED-NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
0	ONCOGN N O C O G O N	76.	0.	0.	0.	0.	0.	354.	50.	354.	COAL-FGD	404.	0	0.	0.04	0.74
1	STM141 STM-TURB-1 POWR	76.	31.	82.	53.	16.	5.	291.	0.	373.	RESIDUAL	373.	10	0.10	0.04	0.81
1	STM141 STM-TURB-1 HEAT	76.	176.	461.	301.	90.	27.	0.	-233.	461.	RESIDUAL	228.	0	0.31	0.20	0.65
1	STM141 STM-TURB-1 POWR	76.	31.	82.	53.	16.	5.	291.	0.	373.	COAL-FGD	373.	10	0.10	0.04	0.81
1	STM141 STM-TURB-1 HEAT	76.	176.	461.	301.	90.	27.	0.	-233.	461.	COAL-FGD	228.	0	0.31	0.20	0.65
1	STM141 STM-TURB-1 POWR	76.	31.	82.	53.	16.	5.	291.	0.	373.	COAL-AFB	373.	10	0.10	0.04	0.81
1	STM141 STM-TURB-1 HEAT	76.	176.	461.	301.	90.	27.	0.	-233.	461.	COAL-AFB	228.	0	0.31	0.20	0.65
2	STM088 STM-TURB-8 POWR	76.	31.	98.	68.	16.	5.	275.	0.	373.	RESIDUAL	373.	10	0.10	0.04	0.81
2	STM088 STM-TURB-8 HEAT	76.	139.	438.	301.	71.	21.	0.	-173.	438.	RESIDUAL	265.	0	0.28	0.16	0.69
2	STM088 STM-TURB-8 POWR	76.	31.	98.	68.	16.	5.	275.	0.	373.	COAL-FGD	373.	10	0.10	0.04	0.81
2	STM088 STM-TURB-8 HEAT	76.	139.	438.	301.	71.	21.	0.	-173.	438.	COAL-FGD	265.	0	0.28	0.16	0.69
2	STM088 STM-TURB-8 POWR	76.	31.	98.	68.	16.	5.	275.	0.	373.	COAL-AFB	373.	10	0.10	0.04	0.81
2	STM088 STM-TURB-8 HEAT	76.	139.	438.	301.	71.	21.	0.	-173.	438.	COAL-AFB	265.	0	0.28	0.16	0.69
3	PFBSTM PFB-STMTB- POWR	76.	31.	62.	37.	16.	5.	311.	0.	373.	COAL-PFB	373.	10	0.09	0.04	0.81
3	PFBSTM PFB-STMTB- HEAT	76.	254.	511.	301.	131.	38.	0.	-360.	511.	COAL-PFB	151.	0	0.37	0.26	0.59
4	TISTMT TI-STMTB-1 POWR	76.	31.	53.	29.	16.	5.	320.	0.	373.	RESIDUAL	373.	10	0.09	0.04	0.81
4	TISTMT TI-STMTB-1 HEAT	76.	254.	437.	236.	132.	39.	76.	-364.	514.	RESIDUAL	150.	0	0.37	0.26	0.59
4	TISTMT TI-STMTB-1 POWR	76.	31.	53.	29.	16.	5.	320.	0.	373.	COAL	373.	10	0.09	0.04	0.81
4	TISTMT TI-STMTB-1 HEAT	76.	325.	557.	301.	169.	50.	0.	-478.	557.	COAL	80.	0	0.40	0.30	0.54
5	TIHRSG THERMIONIC POWR	76.	27.	114.	77.	16.	5.	263.	0.	377.	RESIDUAL	377.	0	0.08	0.04	0.80
5	TIHRSG THERMIONIC HEAT	76.	83.	348.	236.	49.	14.	76.	-103.	424.	RESIDUAL	321.	0	0.19	0.12	0.71
5	TIHRSG THERMIONIC POWR	76.	27.	114.	77.	16.	5.	263.	0.	377.	COAL	377.	0	0.08	0.04	0.80
5	TIHRSG THERMIONIC HEAT	76.	106.	444.	301.	62.	18.	0.	-145.	444.	COAL	299.	0	0.22	0.14	0.68
6	STIRL STIRLING-1 POWR	76.	23.	58.	26.	16.	5.	323.	0.	381.	DISTILLA	381.	0	0.07	0.04	0.79
6	STIRL STIRLING-1 HEAT	76.	207.	522.	236.	144.	42.	76.	-401.	598.	DISTILLA	198.	0	0.28	0.24	0.50

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 27

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 20631 MW 4.70 PROCESS MILLIONS BTU/HR 301.0 PROCESS TEMP(F) 250. PRODUCT BEET-SUGAR HOURS PER YEAR 2800.

UTILITY FUEL		COAL		POWER TO HEAT RATIO 0.053 WASTE FUEL EQV BTU*10**6= 76. HOT WATER BTU*10**6= 0.												
		WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED-NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
6	STIRL STIRLING-1 POWR	76.	23.	58.	26.	16.	5.	323.	0.	381.	RESIDUAL	381.	0	0.07	0.04	0.79
6	STIRL STIRLING-1 HEAT	76.	207.	522.	236.	144.	42.	76.	-401.	598.	RESIDUAL	198.	0	0.28	0.24	0.50
6	STIRL STIRLING-1 POWR	76.	23.	58.	26.	16.	5.	323.	0.	381.	COAL	381.	0	0.07	0.04	0.79
6	STIRL STIRLING-1 HEAT	76.	264.	666.	301.	184.	54.	0.	-525.	666.	COAL	141.	0	0.31	0.28	0.45
7	HEGT85 HELIUM-GT- POWR	76.	16.	50.	14.	16.	5.	338.	0.	388.	COAL-AFB	388.	10	0.05	0.04	0.78
7	HEGT85 HELIUM-GT- HEAT	76.	358.	1107.	301.	355.	104.	0.	-1061.	1107.	COAL-AFB	47.	0	0.26	0.32	0.27
8	HEGT60 HELIUM-GT- POWR	76.	16.	62.	24.	16.	5.	326.	0.	388.	COAL-AFB	388.	10	0.05	0.04	0.78
8	HEGT60 HELIUM-GT- HEAT	76.	203.	792.	301.	205.	60.	0.	-591.	792.	COAL-AFB	201.	0	0.22	0.26	0.38
9	HEGT00 HELIUM-GT- POWR	76.	15.	91.	47.	16.	5.	299.	0.	390.	COAL-AFB	390.	10	0.04	0.04	0.77
9	HEGT00 HELIUM-GT- HEAT	76.	93.	580.	301.	102.	30.	0.	-269.	580.	COAL-AFB	311.	10	0.16	0.18	0.52
10	FCMCCL FUEL-CL-MO POWR	0.	27.	53.	25.	16.	5.	325.	0.	377.	COAL	377.	10	-0.15	0.04	0.80
10	FCMCCL FUEL-CL-MO HEAT	0.	322.	633.	301.	192.	56.	0.	-551.	633.	COAL	82.	10	0.28	0.30	0.48
11	FCSTCL FUEL-CL-ST POWR	0.	28.	39.	14.	16.	5.	337.	0.	376.	COAL	376.	10	-0.15	0.04	0.80
11	FCSTCL FUEL-CL-ST HEAT	0.	593.	822.	301.	340.	100.	0.	-1011.	822.	COAL	-189.	10	0.39	0.41	0.37
12	IGGTST INT-GAS-GT POWR	0.	23.	51.	20.	16.	5.	331.	0.	381.	COAL	381.	10	-0.16	0.04	0.79
12	IGGTST INT-GAS-GT HEAT	0.	348.	767.	301.	243.	71.	0.	-711.	767.	COAL	56.	10	0.26	0.32	0.39
13	GTSOAR GT-HRSG-10 POWR	76.	24.	55.	25.	16.	5.	325.	0.	330.	RESIDUAL	380.	10	0.07	0.04	0.79
13	GTSOAR GT-HRSG-10 HEAT	76.	229.	519.	236.	150.	44.	76.	-420.	595.	RESIDUAL	175.	0	0.31	0.25	0.51
14	GTAC08 GT-HRSG-08 POWR	76.	26.	59.	30.	16.	5.	319.	0.	378.	RESIDUAL	378.	10	0.08	0.04	0.80
14	GTAC08 GT-HRSG-08 HEAT	76.	205.	464.	236.	125.	37.	76.	-341.	540.	RESIDUAL	199.	0	0.31	0.23	0.56
15	GTAC12 GT-HRSG-12 POWR	76.	27.	53.	25.	16.	5.	325.	0.	377.	RESIDUAL	377.	10	0.08	0.04	0.80
15	GTAC12 GT-HRSG-12 HEAT	76.	254.	499.	236.	152.	45.	76.	-426.	576.	RESIDUAL	150.	0	0.34	0.26	0.52
16	GTAC16 GT-HRSG-16 POWR	76.	27.	50.	22.	16.	5.	328.	0.	378.	RESIDUAL	378.	10	0.08	0.04	0.80
16	GTAC16 GT-HRSG-16 HEAT	76.	283.	526.	236.	170.	50.	76.	-481.	602.	RESIDUAL	122.	0	0.35	0.28	0.50
17	GTWC16 GT-HRSG-16 POWR	76.	23.	51.	21.	16.	5.	330.	0.	381.	RESIDUAL	381.	10	0.07	0.04	0.79
17	GTWC16 GT-HRSG-16 HEAT	76.	269.	585.	236.	184.	54.	76.	-526.	662.	RESIDUAL	136.	0	0.31	0.28	0.45

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 20631 MW 4.70 PROCESS MILLIONS BTU/HR 301.0 PROCESS TEMP(F) 250. PRODUCT BEET-SUGAR HOURS PER YEAR 2800.

UTILITY FUEL		COAL		POWER TO HEAT RATIO 0.053										WASTE FUEL EQV BTU*10**6= 76. HOT WATER BTU*10**6= 0.			
		WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
18	CC1626 GTST-16/26 POWR	76.	24.	40.	11.	16.	5.	341.	0.	381.	RESIDUAL	381.	10	0.07	0.04	0.79	
18	CC1626 GTST-16/26 HEAT	76.	487.	824.	236.	331.	97.	76.	-984.	901.	RESIDUAL	-83.	0	0.37	0.37	0.33	
19	CC1622 GTST-16/22 POWR	76.	25.	40.	13.	16.	5.	339.	0.	380.	RESIDUAL	380.	10	0.08	0.04	0.79	
19	CC1622 GTST-16/22 HEAT	76.	460.	750.	236.	298.	87.	76.	-883.	827.	RESIDUAL	-56.	0	0.38	0.36	0.36	
20	CC1222 GTST-12/22 POWR	76.	25.	40.	13.	16.	5.	339.	0.	379.	RESIDUAL	379.	10	0.08	0.04	0.79	
20	CC1222 GTST-12/22 HEAT	76.	464.	746.	236.	298.	87.	76.	-882.	822.	RESIDUAL	-60.	0	0.38	0.36	0.37	
21	CC0822 GTST-08/22 POWR	76.	27.	42.	16.	16.	5.	336.	0.	378.	RESIDUAL	378.	10	0.08	0.04	0.80	
21	CC0822 GTST-08/22 HEAT	76.	401.	630.	236.	241.	71.	76.	-703.	707.	RESIDUAL	4.	0	0.39	0.34	0.43	
22	STIG15 STIG-15-16 POWR	76.	9.	42	1.	16.	5.	353.	0.	396.	RESIDUAL	396.	10	0.03	0.04	0.76	
22	STIG15 STIG-15-16 HEAT	76.	3738.	18154.	236.	6917.	2027.	76.	-21564.	18230.	RESIDUAL	-3334.	0	0.17	0.38	0.02	
23	STIG10 STIG-10-16 POWR	76.	12.	45.	6.	16.	5.	347.	0.	392.	RESIDUAL	392.	10	0.04	0.04	0.77	
23	STIG10 STIG-10-16 HEAT	76.	495.	1781.	236.	640.	187.	76.	-1949.	1858.	RESIDUAL	-91.	0	0.22	0.34	0.16	
24	STIG1S STIG-1S-16 POWR	76.	14.	48.	10.	16.	5.	342.	0.	390.	RESIDUAL	390.	10	0.04	0.04	0.77	
24	STIG1S STIG-1S-16 HEAT	76.	331.	1120.	236.	375.	110.	76.	-1123.	1196.	RESIDUAL	73.	0	0.23	0.31	0.25	
25	DEADV3 DIESEL-ADV POWR	76.	20.	43.	11.	16.	5.	341.	0.	384.	RESIDUAL	384.	0	0.06	0.04	0.78	
25	DEADV3 DIESEL-ADV HEAT	76.	426.	929.	236.	345.	101.	76.	-1027.	1005.	RESIDUAL	-21.	0	0.31	0.34	0.30	
26	DEADV2 DIESEL-ADV POWR	76.	20.	43.	11.	16.	5.	341.	0.	384.	RESIDUAL	384.	1	0.06	0.04	0.78	
26	DEADV2 DIESEL-ADV HEAT	76.	426.	929.	236.	345.	101.	76.	-1027.	1006.	RESIDUAL	-21.	1	0.31	0.34	0.30	
27	DEADV1 DIESEL-ADV POWR	76.	27.	43.	17.	16.	5.	334.	0.	377.	RESIDUAL	377.	1	0.08	0.04	0.80	
27	DEADV1 DIESEL-ADV HEAT	76.	374.	604.	236.	224.	66.	76.	-650.	680.	RESIDUAL	30.	1	0.38	0.33	0.44	
28	DEHTPM ADV-DIESEL POWR	76.	29.	44.	19.	16.	5.	331.	0.	375.	RESIDUAL	375.	0	0.09	0.04	0.80	
28	DEHTPM ADV-DIESEL HEAT	76.	353.	537.	236.	196.	57.	76.	-562.	613.	RESIDUAL	51.	0	0.40	0.32	0.49	
29	DES0A3 DIESEL-S0A POWR	76.	17.	44.	10.	16.	5.	343.	0.	387.	DISTILLA	387.	0	0.05	0.04	0.78	
29	DES0A3 DIESEL-S0A HEAT	76.	415.	1072.	236.	387.	113.	76.	-1180.	1149.	DISTILLA	-11.	0	0.28	0.34	0.26	
29	DES0A3 DIESEL-S0A POWR	76.	17.	44.	10.	16.	5.	343.	0.	387.	RESIDUAL	387.	0	0.05	0.04	0.78	
29	DES0A3 DIESEL-S0A HEAT	76.	415.	1072.	236.	387.	113.	76.	-1180.	1149.	RESIDUAL	-11.	0	0.28	0.34	0.26	

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 29

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 20631 MW 4.70 PROCESS MILLIONS BTU/HR 301.0 PROCESS TEMP(F) 250. PRODUCT BEET-SUGAR HOURS PER YEAR 2800.

		POWER TO HEAT RATIO 0.053														
		WASTE FUEL EQV BTU*10**6= 76.										HOT WATER BTU*10**6= 0.				
UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
30 DES0A2 DIESEL-S0A	POWR	76.	17.	44.	10.	16.	5.	343.	0.	387.	DISTILLA	387.	1	0.05	0.04	0.78
30 DES0A2 DIESEL-S0A	HEAT	76.	415.	1073.	236.	387.	113.	76.	-1160.	1149.	DISTILLA	-11.	1	0.28	0.34	0.26
30 DES0A2 DIESEL-S0A	POWR	76.	17.	44.	10.	16.	5.	343.	0.	387.	RESIDUAL	387.	1	0.05	0.04	0.78
30 DES0A2 DIESEL-S0A	HEAT	76.	415.	1073.	236.	387.	113.	76.	-1160.	1149.	RESIDUAL	-11.	1	0.28	0.34	0.26
31 DES0A1 DIESEL-S0A	POWR	76.	27.	44.	18.	16.	5.	333.	0.	378.	DISTILLA	378.	1	0.08	0.04	0.80
31 DES0A1 DIESEL-S0A	HEAT	76.	353.	589.	236.	212.	62.	76.	-614.	665.	DISTILLA	51.	1	0.37	0.32	0.45
31 DES0A1 DIESEL-S0A	POWR	76.	27.	44.	18.	16.	5.	333.	0.	378.	RESIDUAL	378.	1	0.08	0.04	0.80
31 DES0A1 DIESEL-S0A	HEAT	76.	353.	589.	236.	212.	62.	76.	-614.	665.	RESIDUAL	51.	1	0.37	0.32	0.45
32 GTS0AD GT-HRSG-10	POWR	76.	26.	55.	26.	16.	5.	323.	0.	378.	DISTILLA	378.	10	0.08	0.04	0.80
32 GTS0AD GT-HRSG-10	HEAT	76.	234.	496.	236.	145.	42.	76.	-402.	572.	DISTILLA	170.	0	0.32	0.25	0.53
33 GTRA08 GT-85RE-08	POWR	76.	25.	45.	17.	16.	5.	334.	0.	379.	DISTILLA	379.	10	0.08	0.04	0.79
33 GTRA08 GT-85RE-08	HEAT	76.	350.	627.	236.	224.	66.	76.	-649.	703.	DISTILLA	54.	0	0.36	0.32	0.43
34 GTRA12 GT-85RE-12	POWR	76.	25.	45.	17.	16.	5.	334.	0.	379.	DISTILLA	379.	10	0.08	0.04	0.79
34 GTRA12 GT-85RE-12	HEAT	76.	351.	620.	236.	222.	65.	76.	-643.	696.	DISTILLA	53.	0	0.36	0.32	0.43
35 GTRA16 GT-85RE-16	POWR	76.	25.	46.	18.	16.	5.	333.	0.	379.	DISTILLA	379.	10	0.08	0.04	0.79
35 GTRA16 GT-85RE-16	HEAT	76.	332.	600.	236.	209.	61.	76.	-604.	676.	DISTILLA	72.	0	0.36	0.31	0.44
36 GTR208 GT-60RE-08	POWR	76.	25.	50.	21.	16.	5.	329.	0.	379.	DISTILLA	379.	10	0.08	0.04	0.79
36 GTR208 GT-60RE-08	HEAT	76.	278.	551.	236.	176.	52.	76.	-501.	627.	DISTILLA	127.	0	0.34	0.28	0.48
37 GTR212 GT-60RE-12	POWR	76.	25.	49.	20.	16.	5.	331.	0.	379.	DISTILLA	379.	10	0.08	0.04	0.79
37 GTR212 GT-60RE-12	HEAT	76.	296.	574.	236.	189.	56.	76.	-542.	650.	DISTILLA	109.	0	0.34	0.29	0.46
38 GTR216 GT-60RE-16	POWR	76.	26.	48.	20.	16.	5.	331.	0.	379.	DISTILLA	379.	10	0.08	0.04	0.79
38 GTR216 GT-60RE-16	HEAT	76.	308.	575.	236.	194.	57.	76.	-555.	651.	DISTILLA	96.	0	0.35	0.30	0.46
39 GTRW08 GT-85RE-08	POWR	76.	21.	46.	14.	16.	5.	338.	0.	383.	DISTILLA	383.	10	0.06	0.04	0.79
39 GTRW08 GT-85RE-08	HEAT	76.	352.	767.	236.	269.	79.	76.	-792.	844.	DISTILLA	52.	0	0.31	0.32	0.36
40 GTRW12 GT-85RE-12	POWR	76.	22.	44.	14.	16.	5.	338.	0.	382.	DISTILLA	382.	10	0.07	0.04	0.79
40 GTRW12 GT-85RE-12	HEAT	76.	383.	764.	236.	278.	81.	76.	-818.	840.	DISTILLA	22.	0	0.33	0.33	0.36

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 20631 MW 4.70 PROCESS MILLIONS BTU/HR 301.0 PROCESS TEMP(F) 250. PRODUCT BEET-SUGAR HOURS PER YEAR 2800.

POWER TO HEAT RATIO 0.053

WASTE FUEL EQV BTU\*10\*\*6= 76. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL COAL

	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET* TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41 GTRW16 GT-85RE-16 POWR	76.	22.	45.	14.	16.	5.	337.	0.	382.	DISTILLA	382.	10	0.07	0.04	0.79
41 GTRW16 GT-85RE-16 HEAT	76.	362.	731.	236.	261.	77.	76.	-766.	808.	DISTILLA	42.	0	0.33	0.32	0.37
42 GTR308 GT-60RE-08 POWR	76.	20.	52.	19.	16.	5.	332.	0.	384.	DISTILLA	384.	10	0.06	0.04	0.78
42 GTR308 GT-60RE-08 HEAT	76.	257.	654.	236.	203.	59.	76.	-583.	730.	DISTILLA	147.	0	0.28	0.28	0.41
43 GTR312 GT-60RE-12 POWR	76.	22.	47.	16.	16.	5.	335.	0.	382.	DISTILLA	382.	10	0.07	0.04	0.79
43 GTR312 GT-60RE-12 HEAT	76.	324.	680.	236.	233.	68.	76.	-677.	757.	DISTILLA	80.	0	0.32	0.31	0.40
44 GTR316 GT-60RE-16 POWR	76.	22.	47.	17.	16.	5.	335.	0.	382.	DISTILLA	382.	10	0.07	0.04	0.79
44 GTR316 GT-60RE-16 HEAT	76.	318.	676.	236.	229.	67.	76.	-666.	733.	DISTILLA	86.	0	0.32	0.30	0.40
45 FCPADS FUEL-CL-PH POWR	76.	16.	42.	7.	16.	5.	346.	0.	388.	DISTILLA	388.	0	0.05	0.04	0.78
45 FCPADS FUEL-CL-PH HEAT	76.	538.	1388.	236.	528.	155.	76.	-1598.	1465.	DISTILLA	-134.	0	0.28	0.36	0.21
46 FCMCDS FUEL-CL-MO POWR	76.	22.	39.	9.	16.	5.	343.	0.	382.	DISTILLA	382.	0	0.07	0.04	0.79
46 FCMCDS FUEL-CL-MO HEAT	76.	569.	1013.	236.	417.	122.	76.	-1254.	1089.	DISTILLA	-165.	0	0.36	0.38	0.28

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 20821 MW 6.04 PROCESS MILLIONS BTU/HR 88.0 PROCESS TEMP(F) 250. PRODUCT MALT-BEVERAG HOURS PER YEAR 6600.

		POWER TO HEAT RATIO 0.240																
UTILITY FUEL		COAL		WASTE FUEL EQV BTU*10**6= 0. HOT WATER BTU*10**6= 52.														
		WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET* TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR		
0	COGEN NO COG ON	0.	0.	0.	0.	0.	0.	101.	64.	101.	COAL-AFB	166.	0	0.	0.12	0.52		
1	STM141 STM-TURB-1 POWR	0.	40.	105.	69.	21.	6.	21.	0.	125.	RESIDUAL	125.	10	0.24	0.16	0.69		
1	STM141 STM-TURB-1 HEAT	0.	50.	132.	86.	26.	8.	0.	-16.	132.	RESIDUAL	115.	0	0.28	0.20	0.65		
1	STM141 STM-TURB-1 POWR	0.	40.	105.	69.	21.	6.	21.	0.	125.	COAL-FGD	125.	10	0.24	0.16	0.69		
1	STM141 STM-TURB-1 HEAT	0.	50.	132.	86.	26.	8.	0.	-16.	132.	COAL-FGD	115.	0	0.28	0.20	0.65		
1	STM141 STM-TURB-1 POWR	0.	40.	105.	69.	21.	6.	21.	0.	125.	COAL-AFB	125.	10	0.24	0.16	0.69		
1	STM141 STM-TURB-1 HEAT	0.	50.	132.	86.	26.	8.	0.	-16.	132.	COAL-AFB	115.	0	0.28	0.20	0.65		
2	STM088 STM-TURB-8 POWR	0.	39.	126.	87.	21.	6.	-1.	0.	126.	RESIDUAL	126.	0	0.24	0.16	0.68		
2	STM088 STM-TURB-8 HEAT	0.	40.	125.	86.	20.	6.	0.	1.	125.	RESIDUAL	126.	0	0.24	0.16	0.68		
2	STM088 STM-TURB-8 POWR	0.	39.	126.	87.	21.	6.	-1.	0.	126.	COAL-FGD	126.	0	0.24	0.16	0.68		
2	STM088 STM-TURB-8 HEAT	0.	40.	125.	86.	20.	6.	0.	1.	125.	COAL-FGD	126.	0	0.24	0.16	0.68		
2	STM088 STM-TURB-8 POWR	0.	39.	126.	87.	21.	6.	-1.	0.	126.	COAL-AFB	126.	0	0.24	0.16	0.68		
2	STM088 STM-TURB-8 HEAT	0.	40.	125.	86.	20.	6.	0.	1.	125.	COAL-AFB	126.	0	0.24	0.16	0.68		
3	PFBSTM PFB-STMTB- POWR	0.	40.	80.	47.	21.	6.	46.	0.	126.	COAL-PFB	126.	10	0.24	0.16	0.66		
3	PFBSTM PFB-STMTB- HEAT	0.	72.	146.	86.	38.	11.	0.	-53.	146.	COAL-PFB	93.	10	0.33	0.26	0.59		
4	TISTMT TI-STMTB-1 POWR	0.	40.	68.	37.	21.	6.	58.	0.	126.	RESIDUAL	126.	10	0.24	0.16	0.68		
4	TISTMT TI-STMTB-1 HEAT	0.	93.	159.	86.	48.	14.	0.	-86.	159.	RESIDUAL	73.	0	0.37	0.30	0.54		
4	TISTMT TI-STMTB-1 POWR	0.	40.	68.	37.	21.	6.	58.	0.	126.	COAL	126.	10	0.24	0.16	0.68		
4	TISTMT TI-STMTB-1 HEAT	0.	93.	159.	86.	48.	14.	0.	-86.	159.	COAL	73.	0	0.37	0.30	0.54		
5	TIHRSG THERMIONIC POWR	0.	19.	146.	99.	21.	6.	-16.	0.	146.	RESIDUAL	146.	0	0.12	0.14	0.59		
5	TIHRSG THERMIONIC HEAT	0.	30.	127.	86.	18.	5.	0.	9.	127.	RESIDUAL	135.	0	0.18	0.13	0.64		
5	TIHRSG THERMIONIC POWR	0.	19.	146.	99.	21.	6.	-16.	0.	146.	COAL	146.	0	0.12	0.14	0.59		
5	TIHRSG THERMIONIC HEAT	0.	30.	127.	86.	18.	5.	0.	9.	127.	COAL	135.	0	0.18	0.13	0.64		
6	STIRL STIRLING-1 POWR	0.	34.	65.	30.	21.	6.	66.	0.	132.	DISTILLA	132.	0	0.20	0.16	0.65		
6	STIRL STIRLING-1 HEAT	0.	98.	190.	86.	60.	18.	0.	-122.	190.	DISTILLA	67.	0	0.34	0.32	0.45		



DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 32

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 20821 MW 6.04 PROCESS MILLIONS BTU/HR 86.0 PROCESS TEMP(F) 250. PRODUCT MALT-BEVERAG HOURS PER YEAR 6600.

POWER TO HEAT RATIO 0.240

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 52.

UTILITY FUEL COAL

			WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
6 STIRL	STIRLING-1	POWR	0.	34.	65.	30.	21.	6.	66.	0.	132. RESIDUAL	132.	0	0.20	0.16	0.65
6 STIRL	STIRLING-1	HEAT	0.	98.	190.	86.	60.	18.	0.	-122.	190. RESIDUAL	67.	0	0.34	0.32	0.45
6 STIRL	STIRLING-1	POWR	0.	34.	65.	30.	21.	6.	66.	0.	132. COAL	132.	0	0.20	0.16	0.65
6 STIRL	STIRLING-1	HEAT	0.	98.	190.	86.	60.	18.	0.	-122.	190. COAL	67.	0	0.34	0.32	0.45
7 HEGT85	HELIUM-GT-	POWR	0.	33.	64.	28.	21.	6.	69.	0.	133. COAL-AFB	133.	10	0.20	0.15	0.65
7 HEGT85	HELIUM-GT-	HEAT	0.	102.	201.	86.	64.	19.	0.	-137.	201. COAL-AFB	64.	10	0.34	0.32	0.43
8 HEGT60	HELIUM-GT-	POWR	0.	20.	80.	30.	21.	6.	66.	0.	145. COAL-AFB	145.	10	0.12	0.14	0.59
8 HEGT60	HELIUM-GT-	HEAT	0.	58.	226.	86.	59.	17.	0.	-119.	226. COAL-AFB	108.	10	0.20	0.26	0.38
9 HEGT00	HELIUM-GT-	POWR	0.	19.	117.	61.	21.	6.	30.	0.	147. COAL-AFB	147.	10	0.11	0.14	0.59
9 HEGT00	HELIUM-GT-	HEAT	0.	27.	166.	86.	29.	9.	0.	-27.	166. COAL-AFB	139.	10	0.14	0.18	0.52
10 FCMCCL	FUEL-CL-MO	POWR	0.	35.	68.	32.	21.	6.	63.	0.	131. COAL	131.	10	0.21	0.16	0.66
10 FCMCCL	FUEL-CL-MO	HEAT	0.	92.	181.	86.	55.	16.	0.	-107.	181. COAL	73.	10	0.34	0.30	0.48
11 FCSTCL	FUEL-CL-ST	POWR	0.	36.	50.	18.	21.	6.	80.	0.	130. COAL	130.	10	0.22	0.16	0.66
11 FCSTCL	FUEL-CL-ST	HEAT	0.	169.	235.	86.	97.	28.	0.	-239.	235. COAL	-4.	10	0.42	0.41	0.37
12 IGGTST	INT-GAS-GT	POWR	0.	29.	65.	25.	21.	6.	71.	0.	136. COAL	136.	10	0.18	0.15	0.63
12 IGGTST	INT-GAS-GT	HEAT	0.	99.	219.	86.	70.	20.	0.	-153.	219. COAL	66.	10	0.31	0.32	0.39
13 GTSOAR	GT-HRSG-10	POWR	0.	31.	71.	32.	21.	6.	63.	0.	134. RESIDUAL	134.	10	0.19	0.15	0.64
13 GTSOAR	GT-HRSG-10	HEAT	0.	83.	189.	86.	55.	16.	0.	-107.	189. RESIDUAL	82.	0	0.31	0.29	0.45
14 GTAC08	GT-HRSG-08	POWR	0.	34.	76.	39.	21.	6.	55.	0.	132. RESIDUAL	132.	10	0.20	0.16	0.65
14 GTAC08	GT-HRSG-08	HEAT	0.	75.	169.	86.	46.	13.	0.	-78.	169. RESIDUAL	91.	10	0.31	0.27	0.51
15 GTAC12	GT-HRSG-12	POWR	0.	34.	68.	32.	21.	6.	64.	0.	131. RESIDUAL	131.	10	0.21	0.16	0.66
15 GTAC12	GT-HRSG-12	HEAT	0.	93.	182.	86.	56.	16.	0.	-109.	182. RESIDUAL	73.	0	0.34	0.31	0.47
16 GTAC16	GT-HRSG-16	POWR	0.	34.	64.	29.	21.	6.	67.	0.	131. RESIDUAL	131.	10	0.21	0.16	0.66
16 GTAC16	GT-HRSG-16	HEAT	0.	103.	192.	86.	62.	18.	0.	-129.	192. RESIDUAL	63.	0	0.35	0.32	0.45
17 GTWC16	GT-HRSG-16	POWR	0.	30.	65.	26.	21.	6.	70.	0.	136. RESIDUAL	136.	10	0.18	0.15	0.63
17 GTWC16	GT-HRSG-16	HEAT	0.	98.	213.	86.	67.	20.	0.	-145.	213. RESIDUAL	88.	10	0.31	0.32	0.40

I&amp;SE PEC ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 20821 MW 6.04 PROCESS MILLIONS BTU/HR 86.0 PROCESS TEMP(F) 250. PRODUCT MALT-BEVERAG HOURS PER YEAR 6600.

POWER TO HEAT RATIO 0.240

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 52.

UTILITY FUEL COAL

			WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER HEAT FACTR	HEAT FACTR	
18	CC1626	GTST-16/26	POWR	0.	30.	51.	15.	21.	6.	84.	0.	135.	RESIDUAL	135.	10	0.18	0.15	0.64
18	CC1626	GTST-16/26	HEAT	0.	178.	300.	96.	121.	35.	0.	-312.	300.	RESIDUAL	-12.	0	0.37	0.40	0.29
19	CC1622	GTST-16/22	POWR	0.	32.	52.	16.	21.	6.	92.	0.	134.	RESIDUAL	134.	10	0.19	0.15	0.64
19	CC1622	GTST-16/22	HEAT	0.	168.	273.	86.	109.	32.	0.	-275.	273.	RESIDUAL	-2.	0	0.38	0.40	0.31
20	CC1222	GTST-12/22	POWR	0.	32.	52.	16.	21.	6.	82.	0.	134.	RESIDUAL	134.	10	0.19	0.15	0.64
20	CC1222	GTST-12/22	HEAT	0.	169.	272.	86.	109.	32.	0.	-275.	272.	RESIDUAL	-3.	0	0.38	0.40	0.32
21	CC0822	GTST-08/22	POWR	0.	34.	54.	20.	21.	6.	77.	0.	131.	RESIDUAL	131.	10	0.21	0.16	0.65
21	CC0822	GTST-08/22	HEAT	0.	146.	230.	86.	88.	26.	0.	-210.	230.	RESIDUAL	20.	0	0.39	0.38	0.37
22	STIG15	STIG-15-16	POWR	0.	11.	54.	1.	21.	6.	100.	0.	154.	RESIDUAL	154.	10	0.07	0.13	0.56
22	STIG15	STIG-15-16	HEAT	0.	1362.	6615.	86.	2520.	739.	0.	-7812.	6615.	RESIDUAL	-1197.	0	0.17	0.38	0.01
23	STIG10	STIG-10-16	POWR	0.	16.	57.	8.	21.	6.	92.	0.	150.	RESIDUAL	150.	10	0.10	0.14	0.57
23	STIG10	STIG-10-16	HEAT	0.	180.	649.	86.	233.	68.	0.	-664.	649.	RESIDUAL	-15.	0	0.22	0.36	0.13
24	STIG1S	STIG-1S-16	POWR	0.	18.	61.	13.	21.	6.	86.	0.	147.	RESIDUAL	147.	10	0.11	0.14	0.58
24	STIG1S	STIG-1S-16	HEAT	0.	121.	408.	86.	137.	40.	0.	-363.	408.	RESIDUAL	45.	0	0.23	0.34	0.21
25	DEADV3	DIESEL-ADV	POWR	0.	33	56.	21.	21.	6.	77.	0.	132.	RESIDUAL	132.	0	0.20	0.16	0.65
25	DEADV3	DIESEL-ADV	HEAT	0.	136.	231.	86.	86.	25.	0.	-203.	231.	RESIDUAL	28.	0	0.37	0.37	0.37
26	DEADV2	DIESEL-ADV	POWR	0.	53.	56.	21.	21.	6.	77.	0.	132.	RESIDUAL	132.	1	0.20	0.16	0.65
26	DEADV2	DIESEL-ADV	HEAT	0.	138.	231.	86.	86.	25.	0.	-203.	231.	RESIDUAL	28.	1	0.37	0.37	0.37
27	DEADV1	DIESEL-ADV	POWR	0.	37.	56.	24.	21.	6.	73.	0.	129.	RESIDUAL	129.	1	0.22	0.16	0.67
27	DEADV1	DIESEL-ADV	HEAT	0.	133.	202.	86.	75.	22.	0.	-169.	202.	RESIDUAL	32.	1	0.40	0.37	0.43
28	DEHTPM	ADV-DIESEL	POWR	0.	37.	56.	25.	21.	6.	72.	0.	128.	RESIDUAL	128.	0	0.22	0.16	0.67
28	DEHTPM	ADV-DIESEL	HEAT	0.	129.	196.	86.	71.	21.	0.	-159.	196.	RESIDUAL	37.	0	0.40	0.37	0.44
29	DESOA3	DIESEL-SOA	POWR	0.	32.	57.	21.	21.	6.	77.	0.	134.	DISTILLA	134.	0	0.19	0.15	0.64
29	DESOA3	DIESEL-SOA	HEAT	0.	131.	235.	86.	85.	25.	0.	-201.	235.	DISTILLA	34.	0	0.36	0.36	0.37
29	DESOA3	DIESEL-SOA	POWR	0.	32.	57.	21.	21.	6.	77.	0.	134.	RESIDUAL	134.	0	0.19	0.15	0.64
29	DESOA3	DIESEL-SOA	HEAT	0.	131.	235.	86.	85.	25.	0.	-201.	235.	RESIDUAL	34.	0	0.36	0.36	0.37

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 20821 MW 6.04 PROCESS MILLIONS BTU/HR 86.0 PROCESS TEMP(F) 250. PRODUCT MALT-BEVERAG HOURS PER YEAR 6600.

POWER TO HEAT RATIO 0.240

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 52.

UTILITY FUEL COAL

	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
30 DES0A2 DIESEL-S0A POWR	0.	32.	57.	21.	21.	6.	77.	0.	134.	DISTILLA	134.	1	0.19	0.15	0.64
30 DES0A2 DIESEL-S0A HEAT	0.	131.	235.	86.	85.	25.	0.	-201.	235.	DISTILLA	34.	1	0.36	0.36	0.37
30 DES0A2 DIESEL-S0A POWR	0.	32.	57.	21.	21.	6.	77.	0.	134.	RESIDUAL	134.	1	0.19	0.15	0.64
30 DES0A2 DIESEL-S0A HEAT	0.	131.	235.	86.	85.	25.	0.	-201.	235.	RESIDUAL	34.	1	0.36	0.36	0.37
31 DES0A1 DIESEL-S0A POWR	0.	37.	57.	25.	21.	6.	72.	0.	129.	DISTILLA	129.	1	0.22	0.16	0.67
31 DES0A1 DIESEL-S0A HEAT	0.	126.	197.	86.	71.	21.	0.	-158.	197.	DISTILLA	39.	1	0.39	0.36	0.44
31 DES0A1 DIESEL-S0A POWR	0.	37.	57.	25.	21.	6.	72.	0.	129.	RESIDUAL	129.	1	0.22	0.16	0.67
31 DES0A1 DIESEL-S0A HEAT	0.	126.	197.	86.	71.	21.	0.	-158.	197.	RESIDUAL	39.	1	0.39	0.36	0.44
32 GTS0AD GT-HRSG-10 POWR	0.	33.	71.	34.	21.	6.	62.	0.	132.	DISTILLA	132.	10	0.20	0.16	0.65
32 GTS0AD GT-HRSG-10 HEAT	0.	85.	181.	86.	53.	15.	0.	-100.	181.	DISTILLA	80.	0	0.32	0.29	0.48
33 GTRA08 GT-85RE-08 POWR	0.	32.	58.	22.	21.	6.	76.	0.	133.	DISTILLA	133.	10	0.19	0.15	0.65
33 GTRA08 GT-85RE-08 HEAT	0.	128.	228.	86.	82.	24.	0.	-190.	228.	DISTILLA	38.	0	0.36	0.36	0.38
34 GTRA12 GT-85RE-12 POWR	0.	33.	58.	22.	21.	6.	75.	0.	133.	DISTILLA	133.	10	0.20	0.16	0.65
34 GTRA12 GT-85RE-12 HEAT	0.	128.	226.	86.	81.	24.	0.	-188.	226.	DISTILLA	38.	0	0.36	0.36	0.38
35 GTRA16 GT-85RE-16 POWR	0.	33.	59.	23.	21.	6.	74.	0.	133.	DISTILLA	133.	10	0.20	0.16	0.65
35 GTRA16 GT-85RE-16 HEAT	0.	121.	219.	86.	75.	22.	0.	-174.	219.	DISTILLA	45.	0	0.36	0.35	0.39
36 GTR208 GT-60RE-08 POWR	0.	32.	64.	28.	21.	6.	69.	0.	133.	DISTILLA	133.	10	0.20	0.15	0.65
36 GTR208 GT-60RE-08 HEAT	0.	101.	201.	86.	64.	19.	0.	-136.	201.	DISTILLA	64.	0	0.34	0.32	0.43
37 GTR212 GT-60RE-12 POWR	0.	32.	62.	26.	21.	6.	71.	0.	133.	DISTILLA	133.	10	0.19	0.15	0.64
37 GTR212 GT-60RE-12 HEAT	0.	108.	209.	86.	69.	20.	0.	-151.	209.	DISTILLA	58.	0	0.34	0.33	0.41
38 GTR216 GT-60RE-16 POWR	0.	33.	61.	25.	21.	6.	72.	0.	133.	DISTILLA	133.	10	0.20	0.16	0.65
38 GTR216 GT-60RE-16 HEAT	0.	112.	209.	86.	71.	21.	0.	-156.	209.	DISTILLA	53.	0	0.35	0.34	0.41
39 GTRW08 GT-85RE-08 POWR	0.	27.	59.	18.	21.	6.	80.	0.	139.	DISTILLA	139.	10	0.16	0.15	0.62
39 GTRW08 GT-85RE-08 HEAT	0.	128.	280.	86.	98.	29.	0.	-242.	280.	DISTILLA	37.	0	0.31	0.35	0.31
40 GTRW12 GT-85RE-12 POWR	0.	28.	57.	17.	21.	6.	81.	0.	137.	DISTILLA	137.	10	0.17	0.15	0.63
40 GTRW12 GT-85RE-12 HEAT	0.	139.	278.	86.	101.	30.	0.	-252.	278.	DISTILLA	26.	0	0.33	0.36	0.31

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 20821 MW 6.04 PROCESS MILLIONS BTU/HR 86.0 PROCESS TEMP(F) 250. PRODUCT MALT-BEVERAG HOURS PER YEAR 6600.

POWER TO HEAT RATIO 0.240

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 52.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED-NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41 GTRW16 GT-85RE-16	POWR	0.	29.	58.	19.	21.	6.	79.	0.	137.	DISTILLA	137.	10	0.17	0.15	0.63
41 GTRW16 GT-85RE-16	HEAT	0.	132.	267.	86.	95.	28.	0.	-233.	267.	DISTILLA	34.	0	0.33	0.36	0.32
42 GTR308 GT-60RE-08	POWR	0.	26.	66.	24.	21.	6.	73.	0.	139.	DISTILLA	139.	10	0.17	0.15	0.62
42 GTR308 GT-60RE-08	HEAT	0.	94.	238.	86.	74.	22.	0.	-166.	238.	DISTILLA	72.	0	0.28	0.31	0.36
43 GTR312 GT-60RE-12	POWR	0.	29.	60.	21.	21.	6.	77.	0.	137.	DISTILLA	137.	10	0.17	0.15	0.63
43 GTR312 GT-60RE-12	HEAT	0.	118.	248.	86.	85.	25.	0.	-201.	248.	DISTILLA	47.	0	0.32	0.34	0.35
44 GTR316 GT-60RE-16	POWR	0.	29.	61.	21.	21.	6.	76.	0.	137.	DISTILLA	137.	10	0.17	0.15	0.63
44 GTR316 GT-60RE-16	HEAT	0.	116.	246.	86.	84.	24.	0.	-197.	246.	DISTILLA	50.	0	0.32	0.34	0.35
45 FCPADS FUEL-CL-PH	POWR	0.	33.	54.	19.	21.	6.	78.	0.	133.	DISTILLA	133.	0	0.20	0.16	0.65
45 FCPADS FUEL-CL-PH	HEAT	0.	146.	240.	86.	91.	27.	0.	-221.	240.	DISTILLA	19.	0	0.38	0.38	0.36
46 FCMCDS FUEL-CL-MO	POWR	0.	28.	50.	12.	21.	6.	87.	0.	137.	DISTILLA	137.	0	0.17	0.15	0.63
46 FCMCDS FUEL-CL-MO	HEAT	0.	207.	369.	86.	152.	45.	0.	-411.	369.	DISTILLA	-42.	0	0.36	0.41	0.23

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 22601 MW 6.20 PROCESS MILLIONS BTU/HR 158.0 PROCESS TEMP(F) 341. PRODUCT TEXTILE-FINI HOURS PER YEAR 6240.

POWER TO HEAT RATIO 0.134

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
0 ONCOGN N O C O G O N		0.	0.	0.	0.	0.	0.	186.	66.	186.	COAL-FGD	252.	0	0.	0.08	0.63
1 STM141 STM-TURB-1 PCWR		0.	41.	141.	98.	21.	6.	70.	0.	211.	RESIDUAL	211.	10	0.16	0.10	0.75
1 STM141 STM-TURB-1 HEAT		0.	66.	226.	158.	34.	10.	0.	-40.	226.	RESIDUAL	186.	0	0.23	0.15	0.70
1 STM141 STM-TURB-1 POWR		0.	41.	141.	98.	21.	6.	70.	0.	211.	COAL-FGD	211.	10	0.16	0.10	0.75
1 STM141 STM-TURB-1 HEAT		0.	66.	226.	158.	34.	10.	0.	-40.	226.	COAL-FGD	186.	0	0.23	0.15	0.70
1 STM141 STM-TURB-1 POWR		0.	41.	141.	98.	21.	6.	70.	0.	211.	COAL-AFB	211.	10	0.16	0.10	0.75
1 STM141 STM-TURB-1 HEAT		0.	66.	226.	158.	34.	10.	0.	-40.	226.	COAL-AFB	186.	0	0.23	0.15	0.70
2 STM088 STM-TURB-8 POWR		0.	41.	182.	134.	21.	6.	29.	0.	211.	RESIDUAL	211.	0	0.16	0.10	0.75
2 STM088 STM-TURB-8 HEAT		0.	49.	215.	158.	25.	7.	0.	-12.	215.	RESIDUAL	203.	0	0.18	0.12	0.73
2 STM088 STM-TURB-8 POWR		0.	41.	182.	134.	21.	6.	29.	0.	211.	COAL-FGD	211.	0	0.16	0.10	0.75
2 STM088 STM-TURB-8 HEAT		0.	49.	215.	158.	25.	7.	0.	-12.	215.	COAL-FGD	203.	0	0.18	0.12	0.73
2 STM088 STM-TURB-8 POWR		0.	41.	182.	134.	21.	6.	29.	0.	211.	COAL-AFB	211.	0	0.16	0.10	0.75
2 STM088 STM-TURB-8 HEAT		0.	49.	215.	158.	25.	7.	0.	-12.	215.	COAL-AFB	203.	0	0.18	0.12	0.73
3 PFBSTM PFB-STMTB- POWR		0.	40.	98.	61.	21.	6.	114.	0.	212.	COAL-PFB	212.	10	0.16	0.10	0.75
3 PFBSTM PFB-STMTB- HEAT		0.	104.	252.	158.	54.	16.	0.	-104.	252.	COAL-PFB	148.	0	0.29	0.22	0.63
4 TISTMT TI-STMTB-1 POWR		0.	41.	80.	46.	21.	6.	132.	0.	211.	RESIDUAL	211.	10	0.16	0.10	0.75
4 TISTMT TI-STMTB-1 HEAT		0.	139.	273.	158.	72.	21.	0.	-180.	273.	RESIDUAL	113.	0	0.34	0.26	0.58
4 TISTMT TI-STMTB-1 POWR		0.	41.	80.	46.	21.	6.	132.	0.	211.	COAL	211.	10	0.16	0.10	0.75
4 TISTMT TI-STMTB-1 HEAT		0.	139.	273.	158.	72.	21.	0.	-180.	273.	COAL	113.	0	0.34	0.26	0.58
5 TIHRSG THERMIONIC POWR		0.	31.	150.	98.	21.	6.	70.	0.	221.	RESIDUAL	221.	0	0.12	0.10	0.72
5 TIHRSG THERMIONIC HEAT		0.	50.	242.	158.	34.	10.	0.	-40.	242.	RESIDUAL	202.	0	0.17	0.14	0.65
5 TIHRSG THERMIONIC POWR		0.	31.	150.	98.	21.	6.	70.	0.	221.	COAL	221.	0	0.12	0.10	0.72
5 TIHRSG THERMIONIC HEAT		0.	50.	242.	158.	34.	10.	0.	-40.	242.	COAL	202.	0	0.17	0.14	0.65
6 STIRL STIRLING-1 POWR		0.	30.	82.	39.	21.	6.	140.	0.	222.	DISTILLA	222.	0	0.12	0.10	0.71
6 STIRL STIRLING-1 HEAT		0.	121.	335.	158.	86.	25.	0.	-204.	335.	DISTILLA	131.	0	0.26	0.26	0.47

I&amp;SE PEG ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 22601 MW 6.20 PROCESS MILLIONS BTU/HR 158.0 PROCESS TEMP(F) 341. PRODUCT TEXTILE-FINI HOURS PER YEAR 6240.

POWER TO HEAT RATIO 0.134

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED-NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN ELECT 10**6 BTU/HR	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
6 STIRL	STIRLING-1	POWR	0.	30.	82.	39.	21.	6.	140.	0.	222.	RESIDUAL	222.	0	0.12	0.10	0.71
6 STIRL	STIRLING-1	HEAT	0.	121.	335.	158.	86.	25.	0.	-204.	335.	RESIDUAL	131.	0	0.26	0.26	0.47
6 STIRL	STIRLING-1	POWR	0.	30.	82.	39.	21.	6.	140.	0.	222.	COAL	222.	0	0.12	0.10	0.71
6 STIRL	STIRLING-1	HEAT	0.	121.	335.	158.	86.	25.	0.	-204.	335.	COAL	131.	0	0.26	0.26	0.47
7 HEGT85	HELIUM-GT-	POWR	0.	12.	66.	10.	21.	6.	174.	0.	240.	COAL-AFB	240.	10	0.05	0.09	0.66
7 HEGT85	HELIUM-GT-	HEAT	0.	189.	1018.	158.	327.	96.	0.	-955.	1018.	COAL-AFB	63.	0	0.16	0.32	0.16
8 HEGT60	HELIUM-GT-	POWR	0.	15.	82.	26.	21.	6.	156.	0.	237.	COAL-AFB	237.	10	0.06	0.09	0.67
8 HEGT60	HELIUM-GT-	HEAT	0.	90.	504.	158.	131.	38.	0.	-342.	504.	COAL-AFB	162.	10	0.15	0.26	0.31
9 HEGT00	HELIUM-GT-	POWR	0.	16.	120.	59.	21.	6.	116.	0.	236.	COAL-AFB	236.	10	0.06	0.09	0.67
9 HEGT00	HELIUM-GT-	HEAT	0.	42.	320.	158.	56.	16.	0.	-110.	320.	COAL-AFB	210.	10	0.12	0.18	0.49
10 FCMCCL	FUEL-CL-MO	POWR	0.	35.	70.	33.	21.	6.	147.	0.	217.	COAL	217.	10	0.14	0.10	0.73
10 FCMCCL	FUEL-CL-MO	HEAT	0.	169.	333.	158.	101.	30.	0.	-251.	333.	COAL	83.	10	0.34	0.30	0.47
11 FCSTCL	FUEL-CL-ST	POWR	0.	37.	55.	21.	21.	6.	161.	0.	215.	COAL	215.	10	0.15	0.10	0.73
11 FCSTCL	FUEL-CL-ST	HEAT	0.	271.	404.	158.	156.	46.	0.	-423.	404.	COAL	-19.	10	0.40	0.39	0.39
12 IGGTST	INT-GAS-GT	POWR	0.	29.	73.	31.	21.	6.	150.	0.	223.	COAL	223.	10	0.12	0.09	0.71
12 IGGTST	INT-GAS-GT	HEAT	0.	151.	376.	158.	109.	32.	0.	-275.	376.	COAL	101.	10	0.29	0.29	0.42
13 GTSOAR	GT-HRSG-10	POWR	0.	30.	73.	31.	21.	6.	149.	0.	222.	RESIDUAL	222.	10	0.12	0.10	0.71
13 GTSOAR	GT-HRSG-10	HEAT	0.	152.	366.	158.	106.	31.	0.	-266.	366.	RESIDUAL	100.	0	0.29	0.29	0.43
14 GTAC08	GT-HRSG-08	POWR	0.	35.	78.	40.	21.	6.	139.	0.	217.	RESIDUAL	217.	10	0.14	0.10	0.73
14 GTAC08	GT-HRSG-08	HEAT	0.	138.	308.	158.	83.	24.	0.	-193.	308.	RESIDUAL	114.	0	0.31	0.27	0.51
15 GTAC12	GT-HRSG-12	POWR	0.	35.	69.	32.	21.	6.	148.	0.	217.	RESIDUAL	217.	10	0.14	0.10	0.73
15 GTAC12	GT-HRSG-12	HEAT	0.	170.	340.	158.	104.	30.	0.	-257.	340.	RESIDUAL	82.	0	0.33	0.31	0.47
16 GTAC16	GT-HRSG-16	POWR	0.	34.	65.	29.	21.	6.	152.	0.	218.	RESIDUAL	218.	10	0.14	0.10	0.73
16 GTAC16	GT-HRSG-16	HEAT	0.	189.	363.	158.	117.	34.	0.	-300.	363.	RESIDUAL	63.	0	0.34	0.32	0.44
17 GTWC16	GT-HRSG-16	POWR	0.	31.	67.	27.	21.	6.	154.	0.	221.	RESIDUAL	221.	10	0.12	0.10	0.71
17 GTWC16	GT-HRSG-16	HEAT	0.	180.	391.	158.	123.	36.	0.	-318.	391.	RESIDUAL	72.	0	0.32	0.32	0.40

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 22601 MW 6.20 PROCESS MILLIONS BTU/HR 158.0 PROCESS TEMP(F) 341. PRODUCT TEXTILE-FINI HOURS PER YEAR 6240.

POWER TO HEAT RATIO 0.134

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
18 CC1626 GTST-16/26 POWR		0.	31.	55.	17.	21.	6.	166.	0.	221.	RESIDUAL	221.	10	0.12	0.10	0.71
18 CC1626 GTST-16/26 HEAT		0.	285.	516.	158.	197.	58.	0.	-548.	516.	RESIDUAL	-33.	0	0.36	0.38	0.31
19 CC1622 GTST-16/22 POWR		0.	32.	56.	19.	21.	6.	164.	0.	220.	RESIDUAL	220.	10	0.13	0.10	0.72
19 CC1622 GTST-16/22 HEAT		0.	269.	470.	158.	177.	52.	0.	-487.	470.	RESIDUAL	-17.	0	0.36	0.38	0.34
20 CC1222 GTST-12/22 POWR		0.	32.	56.	19.	21.	6.	164.	0.	220.	RESIDUAL	220.	10	0.13	0.10	0.72
20 CC1222 GTST-12/22 HEAT		0.	270.	466.	158.	176.	52.	0.	-484.	466.	RESIDUAL	-18.	0	0.37	0.38	0.34
21 CC0822 GTST-08/22 POWR		0.	35.	59.	24.	21.	6.	158.	0.	217.	RESIDUAL	217.	10	0.14	0.10	0.73
21 CC0822 GTST-08/22 HEAT		0.	230.	394.	158.	140.	41.	0.	-373.	394.	RESIDUAL	22.	0	0.37	0.36	0.40
22 STIG15 STIG-15-16 POWR		0.	11.	56.	1.	21.	6.	185.	0.	241.	RESIDUAL	241.	10	0.05	0.09	0.66
22 STIG15 STIG-15-16 HEAT		0.	2503.	12154.	158.	4631.	1357.	0.	-14405.	12154.	RESIDUAL	-2251.	0	0.17	0.38	0.01
23 STIG10 STIG-10-16 POWR		0.	16.	59.	8.	21.	6.	177.	0.	236.	RESIDUAL	236.	10	0.07	0.09	0.67
23 STIG10 STIG-10-16 HEAT		0.	332.	1192.	158.	428.	126.	0.	-1272.	1192.	RESIDUAL	-80.	0	0.22	0.36	0.13
24 STIG15 STIG-15-16 POWR		0.	19.	63.	13.	21.	6.	170.	0.	233.	RESIDUAL	233.	10	0.07	0.09	0.68
24 STIG15 STIG-15-16 HEAT		0.	221.	750.	158.	251.	74.	0.	-719.	750.	RESIDUAL	31.	0	0.23	0.34	0.21
25 DEADV3 DIESEL-ADV POWR		0.	24.	57.	12.	21.	6.	171.	0.	228.	RESIDUAL	228.	0	0.09	0.09	0.69
25 DEADV3 DIESEL-ADV HEAT		0.	303.	733.	158.	272.	80.	0.	-784.	733.	RESIDUAL	-51.	0	0.29	0.37	0.22
26 DEADV2 DIESEL-ADV POWR		0.	26.	57.	14.	21.	6.	169.	0.	226.	RESIDUAL	226.	1	0.10	0.09	0.70
26 DEADV2 DIESEL-ADV HEAT		0.	285.	622.	158.	231.	68.	0.	-655.	622.	RESIDUAL	-33.	1	0.31	0.37	0.25
27 DEADV1 DIESEL-ADV POWR		0.	35.	57.	22.	21.	6.	160.	0.	217.	RESIDUAL	217.	1	0.14	0.10	0.73
27 DEADV1 DIESEL-ADV HEAT		0.	250.	404.	158.	150.	44.	0.	-402.	404.	RESIDUAL	2.	1	0.38	0.37	0.39
28 DEHTPM ADV-DIESEL POWR		0.	35.	63.	27.	21.	6.	154.	0.	217.	RESIDUAL	217.	0	0.14	0.10	0.73
28 DEHTPM ADV-DIESEL HEAT		0.	205.	368.	158.	124.	36.	0.	-320.	368.	RESIDUAL	47.	0	0.36	0.34	0.43
29 DESOA3 DIESEL-SOA POWR		0.	20.	59.	11.	21.	6.	173.	0.	232.	DISTILLA	232.	0	0.08	0.09	0.68
29 DESOA3 DIESEL-SOA HEAT		0.	297.	870.	158.	314.	92.	0.	-916.	870.	DISTILLA	-45.	0	0.25	0.36	0.18
29 DESOA3 DIESEL-SOA POWR		0.	20.	59.	11.	21.	6.	173.	0.	232.	RESIDUAL	232.	0	0.08	0.09	0.68
29 DESOA3 DIESEL-SOA HEAT		0.	297.	870.	158.	314.	92.	0.	-916.	870.	RESIDUAL	-45.	0	0.25	0.36	0.18

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 39

I&amp;SE PEG ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 22601 MW 6.20 PROCESS MILLIONS BTU/HR 158.0 PROCESS TEMP(F) 341. PRODUCT TEXTILE-FINI HOURS PER YEAR 6240.

POWER TO HEAT RATIO 0.134

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET USED 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
30 DES0A2 DIESEL-S0A POWR		0.	23.	59.	13.	21.	6.	171.	0.	229.	DISTILLA	229.	1	0.09	0.09	0.69
30 DES0A2 DIESEL-S0A HEAT		0.	278.	718.	158.	259.	76.	0.	-744.	718.	DISTILLA	-26.	1	0.28	0.36	0.22
30 DES0A2 DIESEL-S0A POWR		0.	23.	59.	13.	21.	6.	171.	0.	229.	RESIDUAL	229.	1	0.09	0.09	0.69
30 DES0A2 DIESEL-S0A HEAT		0.	278.	716.	158.	259.	76.	0.	-744.	718.	RESIDUAL	-26.	1	0.28	0.36	0.22
31 DES0A1 DIESEL-S0A POWR		0.	35.	59.	23.	21.	6.	158.	0.	217.	DISTILLA	217.	1	0.14	0.10	0.73
31 DES0A1 DIESEL-S0A HEAT		0.	236.	394.	158.	142.	42.	0.	-378.	394.	DISTILLA	16.	1	0.37	0.36	0.40
31 DES0A1 DIESEL-S0A POWR		0.	35.	59.	23.	21.	6.	158.	0.	217.	RESIDUAL	217.	1	0.14	0.10	0.73
31 DES0A1 DIESEL-S0A HEAT		0.	236.	394.	158.	142.	42.	0.	-378.	394.	RESIDUAL	16.	1	0.37	0.36	0.40
32 GTS0AD GT-HRS0-10 POWR		0.	33.	72.	34.	21.	6.	146.	0.	219.	DISTILLA	219.	10	0.13	0.10	0.72
32 GTS0AD GT-HRS0-10 HEAT		0.	156.	341.	158.	100.	29.	0	-245.	341.	DISTILLA	96.	0	0.31	0.29	0.46
33 GTRA08 GT-85RE-08 POWR		0.	31.	59.	21.	21.	6.	162.	0.	221.	DISTILLA	221.	10	0.12	0.10	0.71
33 GTRA08 GT-85RE-08 HEAT		0.	239.	456.	158.	163.	48.	0.	-443.	456.	DISTILLA	13.	0	0.34	0.36	0.35
34 GTRA12 GT-85RE-12 POWR		0.	32.	59.	21.	21.	6.	161.	0.	220.	DISTILLA	220.	10	0.13	0.10	0.72
34 GTRA12 GT-85RE-12 HEAT		0.	239.	445.	158.	159.	47.	0.	-432.	445.	DISTILLA	13.	0	0.35	0.36	0.35
35 GTRA16 GT-85RE-16 POWR		0.	32.	61.	22.	21.	6.	160.	0.	220.	DISTILLA	220.	10	0.13	0.10	0.72
35 GTRA16 GT-85RE-16 HEAT		0.	225.	427.	158.	149.	44.	0.	-400.	427.	DISTILLA	27.	0	0.34	0.35	0.37
36 GTR208 GT-60RE-08 POWR		0.	32.	66.	27.	21.	6.	154.	0.	220.	DISTILLA	220.	10	0.13	0.10	0.72
36 GTR208 GT-60RE-08 HEAT		0.	186.	387.	158.	124.	36.	0.	-321.	387.	DISTILLA	66.	0	0.32	0.32	0.41
37 GTR212 GT-60RE-12 POWR		0.	32.	64.	25.	21.	6.	156.	0.	220.	DISTILLA	220.	10	0.13	0.10	0.72
37 GTR212 GT-60RE-12 HEAT		0.	198.	403.	158.	133.	39.	0.	-349.	403.	DISTILLA	54.	0	0.33	0.33	0.39
38 GTR216 GT-60RE-16 POWR		0.	32.	63.	25.	21.	6.	157.	0.	220.	DISTILLA	220.	10	0.13	0.10	0.72
38 GTR216 GT-60RE-16 HEAT		0.	207.	404.	158.	136.	40.	0.	-359.	404.	DISTILLA	45.	0	0.34	0.34	0.39
39 GTRW08 GT-85RE-08 POWR		0.	26.	60.	17.	21.	6.	166.	0.	226.	DISTILLA	226.	10	0.10	0.09	0.70
39 GTRW08 GT-85RE-08 HEAT		0.	240.	555.	158.	195.	57.	0.	-542.	555.	DISTILLA	12.	0	0.30	0.35	0.28
40 GTRW12 GT-85RE-12 POWR		0.	28.	58.	17.	21.	6.	166.	0.	224.	DISTILLA	224.	10	0.11	0.09	0.70
40 GTRW12 GT-85RE-12 HEAT		0.	261.	545.	158.	198.	58.	0.	-554.	545.	DISTILLA	-9.	0	0.32	0.36	0.29



DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 40

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 22601 MW 6.20 PROCESS MILLIONS BTU/HR 158.0 PROCESS TEMP(F) 341. PRODUCT TEXTILE-FINI HOURS PER YEAR 6240.

POWER TO HEAT RATIO 0.134

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL COAL

	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET* TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41 GTRW16 GT-85RE-16 POWR	0.	28.	59.	18.	21.	6.	165.	0.	224.	DISTILLA	224.	10	0.11	0.09	0.71
41 GTRW16 GT-85RE-16 HEAT	0.	246.	517.	158.	184.	54.	0.	-510.	517.	DISTILLA	6.	0	0.32	0.36	0.31
42 GTR308 GT-60RE-08 POWR	0.	24.	68.	22.	21.	6.	159.	0.	228.	DISTILLA	228.	10	0.10	0.09	0.59
42 GTR308 GT-60RE-08 HEAT	0.	171.	480.	158.	149.	44.	0.	-399.	480.	DISTILLA	81.	0	0.26	0.31	0.33
43 GTR312 GT-60RE-12 POWR	0.	29.	62.	21.	21.	6.	162.	0.	223.	DISTILLA	223.	10	0.11	0.09	0.71
43 GTR312 GT-60RE-12 HEAT	0.	218.	472.	158.	161.	47.	0.	-438.	472.	DISTILLA	34.	0	0.32	0.34	0.33
44 GTR316 GT-60RE-16 POWR	0.	28.	62.	21.	21.	6.	161.	0.	224.	DISTILLA	224.	10	0.11	0.09	0.71
44 GTR316 GT-60RE-16 HEAT	0.	214.	469.	158.	159.	47.	0.	-431.	469.	DISTILLA	38.	0	0.31	0.34	0.34
45 FCPADS FUEL-CL-PH POWR	0.	22.	56.	9.	21.	6.	175.	0.	230.	DISTILLA	230.	0	0.09	0.09	0.69
45 FCPADS FUEL-CL-PH HEAT	0.	360.	929.	158.	353.	104.	0.	-1038.	929.	DISTILLA	-108.	0	0.28	0.38	0.17
46 FCMCDS FUEL-CL-MO POWR	0.	29.	51.	12.	21.	6.	172.	0.	223.	DISTILLA	223.	0	0.11	0.09	0.71
46 FCMCDS FUEL-CL-MO HEAT	0.	381.	678.	158.	279.	82.	0.	-807.	678.	DISTILLA	-129.	0	0.36	0.41	0.23

ORIGINAL PAGE IS  
NOT QUALITY

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 24211 MW 1.50 PROCESS MILLIONS BTU/HR 30.0 PROCESS TEMP(F) 353. PRODUCT SOFTWOOD-LUM HOURS PER YEAR 4000.

POWER TO HEAT RATIO 0.171

WASTE FUEL EQV BTU\*10\*\*6= 41. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL COAL

WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
------------------------------	---------------------------------	------------------------------	--------------------------------	---------------------------------	----------------	-------------------------------	-------------------------------	------------------------------	----------------	---------------------------------	------	------	-------------	------------

0 ONOCGN N O C O G O N	35.	0.	0.	0.	0.	0.	35.	16.	35.	RESIDUAL	51.	0	0.	0.10 0.58
1 STM141 STM-TURB-1 POWR	41.	10.	37.	26.	5.	2.	4.	0.	41.	RESIDUAL	41.	10	0.99	0.12 0.73
1 STM141 STM-TURB-1 HEAT	41.	11.	42.	30.	6.	2.	0.	-2.	42.	RESIDUAL	40.	10	0.95	0.14 0.71
1 STM141 STM-TURB-1 POWR	41.	10.	37.	26.	5.	2.	4.	0.	41.	COAL-FGD	41.	10	0.99	0.12 0.73
1 STM141 STM-TURB-1 HEAT	41.	11.	42.	30.	6.	2.	0.	-2.	42.	COAL-FGD	40.	10	0.95	0.14 0.71
1 STM141 STM-TURB-1 POWR	41.	10.	37.	26.	5.	2.	4.	0.	41.	COAL-AFB	41.	10	0.99	0.12 0.73
1 STM141 STM-TURB-1 HEAT	41.	11.	42.	30.	6.	2.	0.	-2.	42.	COAL-AFB	40.	10	0.95	0.14 0.71
2 STM088 STM-TURB-8 POWR	41.	2.	50.	37.	5.	2.	-8.	0.	50.	RESIDUAL	50.	10	0.47	0.10 0.60
2 STM088 STM-TURB-8 HEAT	40.	8.	40.	30.	4.	1.	0.	3.	40.	RESIDUAL	43.	10	0.81	0.10 0.69
2 STM088 STM-TURB-8 POWR	41.	2.	50.	37.	5.	2.	-8.	0.	50.	COAL-FGD	50.	10	0.47	0.10 0.60
2 STM088 STM-TURB-8 HEAT	40.	8.	40.	30.	4.	1.	0.	3.	40.	COAL-FGD	43.	10	0.81	0.10 0.69
2 STM088 STM-TURB-8 POWR	41.	2.	50.	37.	5.	2.	-8.	0.	50.	COAL-AFB	50.	10	0.47	0.10 0.60
2 STM088 STM-TURB-8 HEAT	40.	8.	40.	30.	4.	1.	0.	3.	40.	COAL-AFB	43.	10	0.81	0.10 0.69
3 PFBSTM PFB-STMTB- POWR	41.	10.	25.	16.	5.	2.	17.	0.	42.	COAL-PFB	42.	10	0.98	0.12 0.72
3 PFBSTM PFB-STMTB- HEAT	41.	18.	47.	30.	10.	3.	0.	-14.	47.	COAL-PFB	33.	10	0.80	0.20 0.64
4 TISTMT TI-STMTB-1 POWR	21.	10.	20.	12.	5.	2.	21.	0.	41.	RESIDUAL	41.	10	-0.26	0.12 0.72
4 TISTMT TI-STMTB-1 HEAT	35.	0.	0.	0.	0.	0.	35.	16.	35.	RESIDUAL	51.	110	0.00	0. 0.58
4 TISTMT TI-STMTB-1 POWR	41.	10.	20.	12.	5.	2.	21.	0.	41.	COAL	41.	10	0.98	0.12 0.72
4 TISTMT TI-STMTB-1 HEAT	41.	25.	51.	30.	13.	4.	0.	-25.	51.	COAL	26.	10	0.76	0.25 0.59
5 TIHRSG THERMIONIC POWR	7.	7.	36.	24.	5.	2.	7.	0.	44.	RESIDUAL	44.	10	-1.27	0.12 0.68
5 TIHRSG THERMIONIC HEAT	35.	0.	0.	0.	0.	0.	35.	16.	35.	RESIDUAL	51.	110	0.00	0. 0.58
5 TIHRSG THERMIONIC POWR	41.	7.	36.	24.	5.	2.	7.	0.	44.	COAL	44.	10	0.83	0.12 0.68
5 TIHRSG THERMIONIC HEAT	41.	9.	46.	30.	6.	2.	0.	-4.	46.	COAL	42.	10	0.75	0.14 0.65
6 STIRL STIRLING-1 POWR	24.	7.	20.	10.	5.	2.	24.	0.	44.	DISTILLA	44.	0	-0.25	0.12 0.68
6 STIRL STIRLING-1 HEAT	35.	0.	0.	0.	0.	0.	35.	16.	35.	DISTILLA	51.	110	0.00	0. 0.58

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 24211 MW 1.50 PROCESS MILLIONS BTU/HR 30.0 PROCESS TEMP(F) 353. PRODUCT SOFTWOOD-LUM HOURS PER YEAR 4000.

POWER TO HEAT RATIO 0.171

WASTE FUEL EQV BTU\*10\*\*6= 41. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
6 STIRL	STIRLING-1 POWR	24.	7.	20.	10.	5.	2.	24.	0.	44.	RESIDUAL	44.	0	-0.25	0.12	0.68
6 STIRL	STIRLING-1 HEAT	35.	0.	0.	0.	0.	0.	35.	16.	35.	RESIDUAL	51.	110	0.00	0.	0.58
6 STIRL	STIRLING-1 POWR	41.	7.	20.	10.	5.	2.	24.	0.	44.	COAL	44.	0	0.81	0.12	0.68
6 STIRL	STIRLING-1 HEAT	41.	22.	63.	30.	16.	5.	0.	-34.	63.	COAL	29.	0	0.56	0.26	0.47
7 HEGT85	HELIUM-GT- POWR	41.	3.	16.	2.	5.	2.	33.	0.	49.	COAL-AFB	49.	10	0.53	0.11	0.62
7 HEGT85	HELIUM-GT- HEAT	41.	36.	218.	30.	70.	20.	0.	-203.	218.	COAL-AFB	15.	10	0.19	0.32	0.14
8 HEGT60	HELIUM-GT- POWR	41.	3.	20.	6.	5.	2.	28.	0.	48.	COAL-AFB	48.	10	0.57	0.11	0.62
8 HEGT60	HELIUM-GT- HEAT	41.	16.	99.	30.	26.	8.	0.	-64.	99.	COAL-AFB	35.	10	0.28	0.26	0.30
9 HEGT00	HELIUM-GT- POWR	41.	4.	29.	14.	5.	2.	18.	0.	48.	COAL-AFB	48.	10	0.60	0.11	0.63
9 HEGT00	HELIUM-GT- HEAT	41.	3.	61.	30.	11.	3.	0.	-18.	61.	COAL-AFB	43.	10	0.41	0.18	0.49
10 FCMCCL	FUEL-CL-MO POWR	0.	9.	17.	8.	5.	2.	26.	0.	43.	COAL	43.	10	-1.67	0.12	0.70
10 FCMCCL	FUEL-CL-MO HEAT	0.	32.	63.	30.	19.	6.	0.	-44.	63.	COAL	19.	10	-0.05	0.30	0.47
11 FCSTCL	FUEL-CL-ST POWR	0.	9.	13.	5.	5.	2.	29.	0.	42.	COAL	42.	10	-1.65	0.12	0.71
11 FCSTCL	FUEL-CL-ST HEAT	0.	50.	75.	30.	29.	8.	0.	-74.	75.	COAL	2.	10	0.16	0.38	0.40
12 IGGTST	INT-GAS-GT POWR	0.	7.	18.	8.	5.	2.	26.	0.	44.	COAL	44.	10	-1.77	0.12	0.68
12 IGGTST	INT-GAS-GT HEAT	0.	27.	70.	30.	20.	6.	0.	-46.	70.	COAL	24.	10	-0.13	0.28	0.43
13 GTSOAR	GT-HRSG-10 POWR	26.	7.	18.	8.	5.	2.	26.	0.	44.	RESIDUAL	44.	10	-0.10	0.12	0.68
13 GTSOAR	GT-HRSG-10 HEAT	35.	0.	0.	0.	0.	0.	35.	16.	35.	RESIDUAL	51.	110	0.00	0.	0.58
14 GTAC08	GT-HRSG-08 POWR	24.	9.	19.	10.	5.	2.	24.	0.	43.	RESIDUAL	43.	10	-0.19	0.12	0.70
14 GTAC08	GT-HRSG-08 HEAT	35.	0.	0.	0.	0.	0.	35.	16.	35.	RESIDUAL	51.	110	0.00	0.	0.58
15 GTAC12	GT-HRSG-12 POWR	26.	8.	17.	8.	5.	2.	26.	0.	43.	RESIDUAL	43.	10	-0.05	0.12	0.70
15 GTAC12	GT-HRSG-12 HEAT	35.	0.	0.	0.	0.	0.	35.	16.	35.	RESIDUAL	51.	110	0.00	0.	0.58
16 GTAC16	GT-HRSG-16 POWR	27.	8.	16.	7.	5.	2.	27.	0.	43.	RESIDUAL	43.	10	0.01	0.12	0.70
16 GTAC16	GT-HRSG-16 HEAT	35.	0.	0.	0.	0.	0.	35.	16.	35.	RESIDUAL	51.	110	0.00	0.	0.58
17 GTWC16	GT-HRSG-16 POWR	28.	7.	16.	7.	5.	2.	28.	0.	44.	RESIDUAL	44.	10	-0.02	0.12	0.68
17 GTWC16	GT-HRSG-16 HEAT	35.	0.	0.	0.	0.	0.	35.	16.	35.	RESIDUAL	51.	110	0.00	0.	0.58

I&SE PEG ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 24211 MW 1.50 PROCESS MILLIONS BTU/HR 30.0 PROCESS TEMP(F) 353. PRODUCT SOFTWOOD-LUM HOURS PER YEAR 4000.

POWER TO HEAT RATIO 0.171

WASTE FUEL EQV BTU\*10\*\*6= 41. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED-NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
18 CC1626	GTST-16/26	POWR	30.	7.	14.	4.	5.	2.	30.	0.	44. RESIDUAL	44.	10	0.15	0.12	0.68
18 CC1626	GTST-16/26	HEAT	35.	0.	0.	0.	0.	0.	35.	16.	35. RESIDUAL	51.	110	0.00	0.	0.58
19 CC1622	GTST-16/22	POWR	30.	8.	14.	5.	5.	2.	30.	0.	44. RESIDUAL	44.	10	0.14	0.12	0.69
19 CC1622	GTST-16/22	HEAT	35.	0.	0.	0.	0.	0.	35.	16.	35. RESIDUAL	51.	110	0.00	0.	0.58
20 CC1222	GTST-12/22	POWR	30.	8.	14.	5.	5.	2.	30.	0.	43. RESIDUAL	43.	10	0.14	0.12	0.69
20 CC1222	GTST-12/22	HEAT	35.	0.	0.	0.	0.	0.	35.	16.	35. RESIDUAL	51.	110	0.00	0.	0.58
21 CC0822	GTST-08/22	POWR	28.	8.	15.	6.	5.	2.	28.	0.	43. RESIDUAL	43.	10	0.08	0.12	0.70
21 CC0822	GTST-08/22	HEAT	35.	0.	0.	0.	0.	0.	35.	16.	35. RESIDUAL	51.	110	0.00	0.	0.58
22 STIG15	STIG-15-16	POWR	35.	3.	13.	0.	5.	2.	35.	0.	49. RESIDUAL	49.	10	0.16	0.11	0.62
22 STIG15	STIG-15-16	HEAT	35.	0.	0.	0.	0.	0.	35.	16.	35. RESIDUAL	51.	110	0.00	0.	0.58
23 STIG10	STIG-10-16	POWR	33.	4.	14.	2.	5.	2.	33.	0.	47. RESIDUAL	47.	10	0.11	0.11	0.63
23 STIG10	STIG-10-16	HEAT	35.	0.	0.	0.	0.	0.	35.	16.	35. RESIDUAL	51.	110	0.00	0.	0.58
24 STIG1S	STIG-1S-16	POWR	32.	5.	15.	3.	5.	2.	32.	0.	47. RESIDUAL	47.	10	0.05	0.11	0.64
24 STIG1S	STIG-1S-16	HEAT	35.	0.	0.	0.	0.	0.	35.	16.	35. RESIDUAL	51.	110	0.00	0.	0.58
25 DEADV3	DIESEL-ADV	POWR	32.	6.	14.	3.	5.	2.	32.	0.	46. RESIDUAL	46.	10	0.14	0.11	0.66
25 DEADV3	DIESEL-ADV	HEAT	35.	0.	0.	0.	0.	0.	35.	16.	35. RESIDUAL	51.	110	0.00	0.	0.58
26 DEADV2	DIESEL-ADV	POWR	31.	6.	14.	4.	5.	2.	31.	0.	45. RESIDUAL	45.	11	0.14	0.11	0.67
26 DEADV2	DIESEL-ADV	HEAT	35.	0.	0.	0.	0.	0.	35.	16.	35. RESIDUAL	51.	111	0.00	0.	0.58
27 DEADV1	DIESEL-ADV	POWR	29.	9.	14.	5.	5.	2.	29.	0.	43. RESIDUAL	43.	11	0.14	0.12	0.70
27 DEADV1	DIESEL-ADV	HEAT	35.	0.	0.	0.	0.	0.	35.	16.	35. RESIDUAL	51.	111	0.00	0.	0.58
28 DEHTPM	ADV-DIESEL	POWR	28.	8.	15.	7.	5.	2.	28.	0.	43. RESIDUAL	43.	10	0.04	0.12	0.70
28 DEHTPM	ADV-DIESEL	HEAT	35.	0.	0.	0.	0.	0.	35.	16.	35. RESIDUAL	51.	110	0.00	0.	0.58
29 DESOA3	DIESEL-SOA	POWR	32.	5.	14.	3.	5.	2.	32.	0.	47. DISTILLA	47.	0	0.11	0.11	0.64
29 DESOA3	DIESEL-SOA	HEAT	35.	0.	0.	0.	0.	0.	35.	16.	35. DISTILLA	51.	110	0.00	0.	0.58
29 DESOA3	DIESEL-SOA	POWR	32.	5.	14.	3.	5.	2.	32.	0.	47. RESIDUAL	47.	0	0.11	0.11	0.64
29 DESOA3	DIESEL-SOA	HEAT	35.	0.	0.	0.	0.	0.	35.	16.	35. RESIDUAL	51.	110	0.00	0.	0.58

HONEYWELL PAGE PRINTING SYSTEM- P1189-02

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 24211 MW 1.50 PROCESS MILLIONS BTU/HR 30.0 PROCESS TEMP(F) 353. PRODUCT SOFTWOOD-LUM HOURS PER YEAR 4000.

POWER TO HEAT RATIO 0.171

WASTE FUEL EQV BTU\*10\*\*6= 41. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
30 DES0A2 DIESEL-S0A	POWR	32.	5.	14.	3.	5.	2.	32.	0.	46.	DISTILLA	46.	1	0.11	0.11	0.65
30 DES0A2 DIESEL-S0A	HEAT	35.	0.	0.	0.	0.	0.	35.	16.	35.	DISTILLA	51.	111	0.00	0.	0.58
30 DES0A2 DIESEL-S0A	POWR	32.	5.	14.	3.	5.	2.	32.	0.	46.	RESIDUAL	46.	1	0.11	0.11	0.65
30 DES0A2 DIESEL-S0A	HEAT	35.	0.	0.	0.	0.	0.	35.	16.	35.	RESIDUAL	51.	111	0.00	0.	0.58
31 DES0A1 DIESEL-S0A	POWR	29.	9.	14.	6.	5.	2.	29.	0.	43.	DISTILLA	43.	1	0.11	0.12	0.70
31 DES0A1 DIESEL-S0A	HEAT	35.	0.	0.	0.	0.	0.	35.	16.	35.	DISTILLA	51.	111	0.00	0.	0.58
31 DES0A1 DIESEL-S0A	POWR	29.	9.	14.	6.	5.	2.	29.	0.	43.	RESIDUAL	43.	1	0.11	0.12	0.70
31 DES0A1 DIESEL-S0A	HEAT	35.	0.	0.	0.	0.	0.	35.	16.	35.	RESIDUAL	51.	111	0.00	0.	0.58
32 GTS0AD GT-HRS0-10	POWR	26.	8.	18.	8.	5.	2.	26.	0.	43.	DISTILLA	43.	10	-0.10	0.12	0.69
32 GTS0AD GT-HRS0-10	HEAT	35.	0.	0.	0.	0.	0.	35.	16.	35.	DISTILLA	51.	110	0.00	0.	0.58
33 GTRA08 GT-85RE-08	POWR	30.	7.	14.	5.	5.	2.	30.	0.	44.	DISTILLA	44.	10	0.10	0.12	0.68
33 GTRA08 GT-85RE-08	HEAT	35.	0.	0.	0.	0.	0.	35.	16.	35.	DISTILLA	51.	110	0.00	0.	0.58
34 GTRA12 GT-85RE-12	POWR	29.	9.	14.	5.	5.	2.	29.	0.	44.	DISTILLA	44.	10	0.11	0.12	0.69
34 GTRA12 GT-85RE-12	HEAT	35.	0.	0.	0.	0.	0.	35.	16.	35.	DISTILLA	51.	110	0.00	0.	0.58
35 GTRA16 GT-85RE-16	POWR	29.	8.	15.	5.	5.	2.	29.	0.	44.	DISTILLA	44.	10	0.08	0.12	0.69
35 GTRA16 GT-85RE-16	HEAT	35.	0.	0.	0.	0.	0.	35.	16.	35.	DISTILLA	51.	110	0.00	0.	0.58
36 GTR208 GT-60RE-08	POWR	28.	8.	16.	6.	5.	2.	28.	0.	44.	DISTILLA	44.	10	0.00	0.12	0.69
36 GTR208 GT-60RE-08	HEAT	35.	0.	0.	0.	0.	0.	35.	16.	35.	DISTILLA	51.	110	0.00	0.	0.58
37 GTR212 GT-60RE-12	POWR	29.	8.	16.	6.	5.	2.	28.	0.	44.	DISTILLA	44.	10	0.03	0.12	0.69
37 GTR212 GT-60RE-12	HEAT	35.	0.	0.	0.	0.	0.	35.	16.	35.	DISTILLA	51.	110	0.00	0.	0.58
38 GTR216 GT-60RE-16	POWR	28.	8.	15.	6.	5.	2.	28.	0.	44.	DISTILLA	44.	10	0.05	0.12	0.69
38 GTR216 GT-60RE-16	HEAT	35.	0.	0.	0.	0.	0.	35.	16.	35.	DISTILLA	51.	110	0.00	0.	0.58
39 GTRW08 GT-85RE-08	POWR	30.	6.	15.	4.	5.	2.	30.	0.	45.	DISTILLA	45.	10	0.09	0.11	0.67
39 GTRW08 GT-85RE-08	HEAT	35.	0.	0.	0.	0.	0.	35.	16.	35.	DISTILLA	51.	110	0.00	0.	0.58
40 GTRW12 GT-85RE-12	POWR	31.	7.	14.	4.	5.	2.	31.	0.	45.	DISTILLA	45.	10	0.12	0.11	0.67
40 GTRW12 GT-85RE-12	HEAT	35.	0.	0.	0.	0.	0.	35.	16.	35.	DISTILLA	51.	110	0.00	0.	0.58

HONEYWELL PAGE PRINTING SYSTEM- P1185-02

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 45

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 24211 MW 1.50 PROCESS MILLIONS BTU/HR 30.0 PROCESS TEMP(F) 353. PRODUCT SOFTWOOD-LUM HOURS PER YEAR 4000.

UTILITY FUEL COAL POWER TO HEAT RATIO 0.171  
WASTE FUEL EQV BTU\*10\*\*6= 41. HOT WATER BTU\*10\*\*6= 0.

	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN ELECT 10**6 BTU/HR	AUX BOILER 10**6 BTU/HR	PROCES FUEL USED 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL USED 10**6 BTU/HR	NET+ UTILIT 10**6 BTU/HR	FAIL	POWER FACTR
41 GTRW16 GT-85RE-16 POWR	30.	7.	14.	4.	5.	2.	30.	0.	0.	45.DISTILLA	45.	10	0.10
41 GTRW16 GT-85RE-16 HEAT	35.	0.	0.	0.	0.	0.	35.	16.	16.	35.DISTILLA	51.	110	0.60
42 GTR308 GT-60RE-08 POWR	29.	6.	17.	5.	5.	2.	29.	0.	0.	45.DISTILLA	45.	10	0.03
42 GTR308 GT-60RE-08 HEAT	35.	0.	0.	0.	0.	0.	35.	16.	16.	35.DISTILLA	51.	110	0.00
43 GTR312 GT-60RE-12 POWR	29.	7.	15.	5.	5.	2.	29.	0.	0.	44.DISTILLA	44.	10	0.06
43 GTR312 GT-60RE-12 HEAT	35.	0.	0.	0.	0.	0.	35.	16.	16.	35.DISTILLA	51.	110	0.00
44 GTR316 GT-60RE-16 POWR	29.	7.	15.	5.	5.	2.	29.	0.	0.	44.DISTILLA	44.	10	0.06
44 GTR316 GT-60RE-16 HEAT	35.	0.	0.	0.	0.	0.	35.	16.	16.	35.DISTILLA	51.	110	0.00
45 FCPADS FUEL-CL-PH POWR	33.	5.	13.	2.	5.	2.	33.	0.	0.	46.DISTILLA	46.	0	0.16
45 FCPADS FUEL-CL-PH HEAT	35.	0.	0.	0.	0.	0.	35.	16.	16.	35.DISTILLA	51.	110	0.00
46 FCMCDS FUEL-CL-MO POWR	32.	7.	12.	3.	5.	2.	32.	0.	0.	44.DISTILLA	44.	10	0.22
46 FCMCDS FUEL-CL-MO HEAT	35.	0.	0.	0.	0.	0.	35.	16.	16.	35.DISTILLA	51.	110	0.00

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 46

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 24361 MW 3.00 PROCESS MILLIONS BTU/HR 75.0 PROCESS TEMP(F) 406. PRODUCT SOFT-PLYWOOD HOURS PER YEAR 6000.

POWER TO HEAT RATIO 0.136

WASTE FUEL EQV BTU\*10\*\*6= 100. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
0 ONOCGN N C O G D N		88.	0.	0.	0.	0.	0.	88.	32.	88. COAL-AFB	120.	0	0.	0.09	0.62
1 STM141 STM-TURB-1 POWR		100.	20.	95.	71.	10.	3.	5.	0.	100. RESIDUAL	100.	10	0.99	0.10	0.75
1 STM141 STM-TURB-1 HEAT		100.	21.	101.	75.	11.	3.	0.	-2.	101. RESIDUAL	99.	10	0.97	0.11	0.74
1 STM141 STM-TURB-1 POWR		100.	20.	95.	71.	10.	3.	5.	0.	100. COAL-FGD	100.	10	0.99	0.10	0.75
1 STM141 STM-TURB-1 HEAT		100.	21.	101.	75.	11.	3.	0.	-2.	101. COAL-FGD	99.	10	0.97	0.11	0.74
1 STM141 STM-TURB-1 POWR		100.	20.	95.	71.	10.	3.	5.	0.	100. COAL-AFB	100.	10	0.99	0.10	0.75
1 STM141 STM-TURB-1 HEAT		100.	21.	101.	75.	11.	3.	0.	-2.	101. COAL-AFB	99.	10	0.97	0.11	0.74
2 STM088 STM-TURB-8 POWR		100.	-22.	142.	111.	10.	3.	-42.	0.	142. RESIDUAL	142.	10	-0.33	0.07	0.53
2 STM088 STM-TURB-8 HEAT		96.	13.	96.	75.	7.	2.	0.	10.	96. RESIDUAL	107.	10	0.68	0.06	0.70
2 STM088 STM-TURB-8 POWR		100.	-22.	142.	111.	10.	3.	-42.	0.	142. COAL-FGD	142.	10	-0.33	0.07	0.53
2 STM088 STM-TURB-8 HEAT		96.	13.	96.	75.	7.	2.	0.	10.	96. COAL-FGD	107.	10	0.68	0.06	0.70
2 STM088 STM-TURB-8 POWR		100.	-22.	142.	111.	10.	3.	-42.	0.	142. COAL-AFB	142.	10	-0.33	0.07	0.53
2 STM088 STM-TURB-8 HEAT		96.	13.	96.	75.	7.	2.	0.	10.	96. COAL-AFB	107.	10	0.68	0.06	0.70
3 PFBSTM PFB-STMTB- POWR		100.	13.	57.	38.	10.	3.	44.	0.	101. COAL-PFB	101.	10	0.97	0.10	0.74
3 PFBSTM PFB-STMTB- HEAT		100.	38.	113.	75.	20.	6.	0.	-31.	113. COAL-PFB	82.	10	0.79	0.18	0.66
4 TISTMT TI-STMTB-1 POWR		56.	20.	45.	27.	10.	3.	56.	0.	101. RESIDUAL	101.	10	-0.40	0.10	0.75
4 TISTMT TI-STMTB-1 HEAT		88.	0.	0.	0.	0.	0.	88.	32.	88. RESIDUAL	120.	110	-0.00	0.	0.62
4 TISTMT TI-STMTB-1 POWR		100.	20.	45.	27.	10.	3.	56.	0.	101. COAL	101.	10	0.98	0.10	0.75
4 TISTMT TI-STMTB-1 HEAT		100.	53.	122.	75.	28.	8.	0.	-55.	122. COAL	67.	10	0.75	0.23	0.61
5 TIHRSG THERMIONIC POWR		34.	13.	73.	46.	10.	3.	34.	0.	107. RESIDUAL	107.	0	-1.27	0.10	0.70
5 TIHRSG THERMIONIC HEAT		88.	0.	0.	0.	0.	0.	88.	32.	88. RESIDUAL	120.	110	-0.00	0.	0.62
5 TIHRSG THERMIONIC POWR		100.	13.	73.	46.	10.	3.	34.	0.	107. COAL	107.	0	0.78	0.10	0.70
5 TIHRSG THERMIONIC HEAT		100.	22.	119.	75.	17.	5.	0.	-20.	119. COAL	99.	0	0.64	0.14	0.63
6 STIRL STIRLING-1 POWR		64.	14.	42.	21.	10.	3.	64.	0.	106. DISTILLA	106.	0	-0.32	0.10	0.71
6 STIRL STIRLING-1 HEAT		88.	0.	0.	0.	0.	0.	88.	32.	88. DISTILLA	120.	110	-0.00	0.	0.62

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 24361 M<sup>3</sup> 3.00 PROCESS MILLIONS BTU/HR 75.0 PROCESS TEMP(F) 406. PRODUCT SOFT-PLYWOOD HOURS PER YEAR 6000.

POWER TO HEAT RATIO 0.136

WASTE FUEL EQV BTU\*10\*\*6= 100. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL COAL

			WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
6 STIRL	STIRLING-1	POWR	64.	14.	42.	21.	10.	3.	64.	0.	106.	RESIDUAL	106.	0	-0.32	0.10	0.71
6 STIRL	STIRLING-1	HEAT	88.	0.	0.	0.	0.	0.	88.	32.	88.	RESIDUAL	120.	110	-0.00	0.	0.62
6 STIRL	STIRLING-1	POWR	100.	14.	42.	21.	10.	3.	64.	0.	106.	COAL	106.	0	0.80	0.10	0.71
6 STIRL	STIRLING-1	HEAT	100.	51.	154.	75.	37.	11.	0.	-85.	154.	COAL	70.	0	0.54	0.24	0.49
7 HEGT85	HELIUM-GT-	POWR	100.	2.	32.	2.	10.	3.	86.	0.	118.	COAL-AFB	118.	11	0.43	0.09	0.64
7 HEGT85	HELIUM-GT-	HEAT	100.	93.	1373.	75.	441.	129.	0.	-1345.	1373.	COAL-AFB	28.	1	0.08	0.32	0.05
8 HEGT60	HELIUM-GT-	POWR	100.	4.	40.	10.	10.	3.	77.	0.	116.	COAL-AFB	116.	10	0.50	0.09	0.65
8 HEGT60	HELIUM-GT-	HEAT	100.	31.	300.	75.	78.	23.	0.	-211.	300.	COAL-AFB	89.	10	0.18	0.26	0.25
9 HEGT00	HELIUM-GT-	POWR	100.	7.	58.	28.	10.	3.	55.	0.	114.	COAL-AFB	114.	10	0.58	0.09	0.66
9 HEGT00	HELIUM-GT-	HEAT	100.	18.	156.	75.	28.	8.	0.	-54.	156.	COAL-AFB	102.	10	0.34	0.18	0.48
10 FCMCCL	FUEL-CL-MO	POWR	0.	17.	34.	16.	10.	3.	70.	0.	103.	COAL	103.	10	-2.23	0.10	0.73
10 FCMCCL	FUEL-CL-MO	HEAT	0.	80.	159.	75.	48.	14.	0.	-119.	159.	COAL	40.	10	-0.05	0.30	0.47
11 FCSTCL	FUEL-CL-ST	POWR	0.	18.	28.	12.	10.	3.	74.	0.	103.	COAL	103.	10	-2.21	0.10	0.73
11 FCSTCL	FUEL-CL-ST	HEAT	0.	113.	181.	75.	66.	19.	0.	-173.	181.	COAL	7.	10	0.12	0.36	0.42
12 IGGTST	INT-GAS-GT	POWR	0.	14.	39.	17.	10.	3.	68.	0.	107.	COAL	107.	10	-2.33	0.10	0.70
12 IGGTST	INT-GAS-GT	HEAT	0.	59.	168.	75.	44.	13.	0.	-107.	168.	COAL	61.	10	-0.21	0.26	0.45
13 GTSOAR	GT-HRSG-10	POWR	71.	14.	35.	15.	10.	3.	71.	0.	106.	RESIDUAL	106.	10	-0.10	0.10	0.70
13 GTSOAR	GT-HRSG-10	HEAT	88.	0.	0.	0.	0.	0.	88.	32.	88.	RESIDUAL	120.	110	-0.00	0.	0.62
14 GTAC08	GT-HRSG-08	POWR	65.	17.	38.	20.	10.	3.	65.	0.	103.	RESIDUAL	103.	10	-0.19	0.10	0.73
14 GTAC08	GT-HRSG-08	HEAT	88.	0.	0.	0.	0.	0.	88.	32.	88.	RESIDUAL	120.	110	-0.00	0.	0.62
15 GTAC12	GT-HRSG-12	POWR	70.	17.	34.	16.	10.	3.	70.	0.	104.	RESIDUAL	104.	10	-0.05	0.10	0.72
15 GTAC12	GT-HRSG-12	HEAT	88.	0.	0.	0.	0.	0.	88.	32.	88.	RESIDUAL	120.	110	-0.00	0.	0.62
16 GTAC16	GT-HRSG-16	POWR	72.	16.	32.	14.	10.	3.	72.	0.	104.	RESIDUAL	104.	10	0.01	0.10	0.72
16 GTAC16	GT-HRSG-16	HEAT	88.	0.	0.	0.	0.	0.	88.	32.	88.	RESIDUAL	120.	110	-0.00	0.	0.62
17 GTWC16	GT-HRSG-16	POWR	73.	15.	32.	13.	10.	3.	73.	0.	105.	RESIDUAL	105.	10	-0.02	0.10	0.71
17 GTWC16	GT-HRSG-16	HEAT	88.	0.	0.	0.	0.	0.	88.	32.	88.	RESIDUAL	120.	110	-0.00	0.	0.62



I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 24361 MW 3.00 PROCESS MILLIONS BTU/HR 75.0 PROCESS TEMP(F) 406. PRODUCT SOFT-PLYWOOD HOURS PER YEAR 6000.

POWER TO HEAT RATIO 0.136

WASTE FUEL EQV BTU\*10\*\*6= 100. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
18 CC1626	GTST-16/26	POWR	77.	15.	28.	9.	10.	3.	77.	0.	106.	RESIDUAL	106.	10	0.12	0.10	0.71
18 CC1626	GTST-16/26	HEAT	88.	0.	0.	0.	0.	0.	88.	32.	88.	RESIDUAL	120.	110	-0.00	0.	0.62
19 CC1622	GTST-16/22	POWR	76.	15.	29.	10.	10.	3.	76.	0.	105.	RESIDUAL	105.	10	0.10	0.10	0.71
19 CC1622	GTST-16/22	HEAT	88.	0.	0.	0.	0.	0.	88.	32.	88.	RESIDUAL	120.	110	-0.00	0.	0.62
20 CC1222	GTST-12/22	POWR	76.	15.	29.	10.	10.	3.	76.	0.	105.	RESIDUAL	105.	10	0.10	0.10	0.72
20 CC1222	GTST-12/22	HEAT	88.	0.	0.	0.	0.	0.	88.	32.	88.	RESIDUAL	120.	110	-0.00	0.	0.62
21 CC0822	GTST-08/22	POWR	73.	17.	31.	13.	10.	3.	73.	0.	104.	RESIDUAL	104.	10	0.03	0.10	0.72
21 CC0822	GTST-08/22	HEAT	88.	0.	0.	0.	0.	0.	88.	32.	88.	RESIDUAL	120.	110	-0.00	0.	0.62
22 STIG15	STIG-15-16	POWR	88.	6.	27.	0.	10.	3.	88.	0.	115.	RESIDUAL	115.	10	0.16	0.09	0.65
22 STIG15	STIG-15-16	HEAT	88.	0.	0.	0.	0.	0.	88.	32.	88.	RESIDUAL	120.	110	-0.00	0.	0.62
23 STIG10	STIG-10-16	POWR	84.	8.	29.	4.	10.	3.	84.	0.	112.	RESIDUAL	112.	10	0.11	0.09	0.67
23 STIG10	STIG-10-16	HEAT	88.	0.	0.	0.	0.	0.	88.	32.	88.	RESIDUAL	120.	110	-0.00	0.	0.62
24 STIG1S	STIG-1S-16	POWR	81.	9.	31.	6.	10.	3.	81.	0.	111.	RESIDUAL	111.	10	0.05	0.09	0.67
24 STIG1S	STIG-1S-16	HEAT	88.	0.	0.	0.	0.	0.	88.	32.	88.	RESIDUAL	120.	110	-0.00	0.	0.62
25 DEADV3	DIESEL-ADV	POWR	82.	11.	28.	5.	10.	3.	82.	0.	110.	RESIDUAL	110.	0	0.14	0.09	0.68
25 DEADV3	DIESEL-ADV	HEAT	88.	0.	0.	0.	0.	0.	88.	32.	88.	RESIDUAL	120.	110	-0.00	0.	0.62
26 DEADV2	DIESEL-ADV	POWR	80.	13.	28.	7.	10.	3.	80.	0.	108.	RESIDUAL	108.	1	0.14	0.10	0.70
26 DEADV2	DIESEL-ADV	HEAT	88.	0.	0.	0.	0.	0.	88.	32.	88.	RESIDUAL	120.	111	-0.00	0.	0.62
27 DEADV1	DIESEL-ADV	POWR	76.	17.	28.	11.	10.	3.	76.	0.	103.	RESIDUAL	103.	1	0.14	0.10	0.73
27 DEADV1	DIESEL-ADV	HEAT	88.	0.	0.	0.	0.	0.	88.	32.	88.	RESIDUAL	120.	111	-0.00	0.	0.62
28 DEHTPM	ADV-DIESEL	POWR	72.	16.	33.	14.	10.	3.	72.	0.	105.	RESIDUAL	105.	0	-0.03	0.10	0.72
28 DEHTPM	ADV-DIESEL	HEAT	88.	0.	0.	0.	0.	0.	88.	32.	88.	RESIDUAL	120.	110	-0.00	0.	0.62
29 DESOA3	DIESEL-SOA	POWR	83.	9.	28.	4.	10.	3.	83.	0.	111.	DISTILLA	111.	0	0.11	0.09	0.67
29 DESOA3	DIESEL-SOA	HEAT	88.	0.	0.	0.	0.	0.	88.	32.	88.	DISTILLA	120.	110	-0.00	0.	0.62
29 DESOA3	DIESEL-SOA	POWR	83.	9.	28.	4.	10.	3.	83.	0.	111.	RESIDUAL	111.	0	0.11	0.09	0.67
29 DESOA3	DIESEL-SOA	HEAT	88.	0.	0.	0.	0.	0.	88.	32.	88.	RESIDUAL	120.	110	-0.00	0.	0.62



I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 24361 MW 3.00 PROCESS MILLIONS BTU/HR 75.0 PROCESS TEMP(F) 406. PRODUCT SOFT-PLYWOOD HOURS PER YEAR 6000.

POWER TO HEAT RATIO 0.136

WASTE FUEL EQV BTU\*10\*\*6= 100. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL COAL

	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41 GTRW16 GT-85RE-16 POWR	78.	13.	29.	8.	10.	3.	78.	0.	107.DISTILLA	107.	10	0.10	0.10	0.70	
41 GTRW16 GT-85RE-16 HEAT	88.	0.	0.	0.	0.	0.	88.	32.	88.DISTILLA	120.	110	-0.00	0.	0.62	
42 GTR308 GT-60RE-08 POWR	76.	11.	33.	10.	10.	3.	76.	0.	109.DISTILLA	109.	10	-0.03	0.09	0.69	
42 GTR308 GT-60RE-08 HEAT	88.	0.	0.	0.	0.	0.	88.	32.	88.DISTILLA	120.	110	-0.00	0.	0.62	
43 GTR312 GT-60RE-12 POWR	77.	14.	30.	10.	10.	3.	77.	0.	107.DISTILLA	107.	10	0.06	0.10	0.70	
43 GTR312 GT-60RE-12 HEAT	88.	0.	0.	0.	0.	0.	88.	32.	88.DISTILLA	120.	110	-0.00	0.	0.62	
44 GTR316 GT-60RE-16 POWR	77.	13.	30.	10.	10.	3.	77.	0.	107.DISTILLA	107.	10	0.06	0.10	0.70	
44 GTR316 GT-60RE-16 HEAT	88.	0.	0.	0.	0.	0.	88.	32.	88.DISTILLA	120.	110	-0.00	0.	0.62	
45 FCPADS FUEL-CL-PH POWR	83.	10.	27.	5.	10.	3.	83.	0.	110.DISTILLA	110.	0	0.16	0.09	0.68	
45 FCPADS FUEL-CL-PH HEAT	88.	0.	0.	0.	0.	0.	88.	32.	88.DISTILLA	120.	110	-0.00	0.	0.62	
46 FCMCDS FUEL-CL-MO POWR	81.	14.	25.	6.	10.	3.	81.	0.	106.DISTILLA	106.	10	0.22	0.10	0.71	
46 FCMCDS FUEL-CL-MO HEAT	88.	0.	0.	0.	0.	0.	88.	32.	88.DISTILLA	120.	110	-0.00	0.	0.62	

ORIGINAL PAGE IS  
OF POOR QUALITY

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 51

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 24921 MW 5.00 PROCESS MILLIONS BTU/HR 37.0 PROCESS TEMP(F) 406. PRODUCT PARTICLE-BOA HOURS PER YEAR 8000.

POWER TO HEAT RATIO 0.461

WASTE FUEL EQV BTU\*10\*\*6= 41. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	AUX MW ELECT	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
0 ONOCGN N O C O G O N		41.	0.	0.	0.	0.	0.	44.	53.	44. COAL-AFB	97.	0	0.	0.18	0.38
1 STM141 STM-TURB-1 POWR		41.	-62.	159.	118.	17.	5.	-95.	0.	159. RESIDUAL	159.	10	-1.11	0.11	0.23
1 STM141 STM-TURB-1 HEAT		41.	10.	50.	37.	5.	2.	0.	37.	50. RESIDUAL	86.	10	0.19	0.06	0.43
1 STM141 STM-TURB-1 POWR		41.	-62.	159.	118.	17.	5.	-95.	0.	159. COAL-FGD	159.	10	-1.11	0.11	0.23
1 STM141 STM-TURB-1 HEAT		41.	10.	50.	37.	5.	2.	0.	37.	50. COAL-FGD	86.	10	0.19	0.06	0.43
1 STM141 STM-TURB-1 POWR		41.	-62.	159.	118.	17.	5.	-95.	0.	159. COAL-AFB	159.	10	-1.11	0.11	0.23
1 STM141 STM-TURB-1 HEAT		41.	10.	50.	37.	5.	2.	0.	37.	50. COAL-AFB	86.	10	0.19	0.06	0.43
2 STM088 STM-TURB-8 POWR		41.	-141.	237.	185.	17.	5.	-174.	0.	237. RESIDUAL	237.	0	-2.53	0.07	0.16
2 STM088 STM-TURB-8 HEAT		41.	7.	48.	37.	3.	1.	0.	43.	48. RESIDUAL	90.	10	0.12	0.04	0.41
2 STM088 STM-TURB-8 POWR		41.	-141.	237.	185.	17.	5.	-174.	0.	237. COAL-FGD	237.	0	-2.53	0.07	0.16
2 STM088 STM-TURB-8 HEAT		41.	7.	48.	37.	3.	1.	0.	43.	48. COAL-FGD	90.	10	0.12	0.04	0.41
2 STM088 STM-TURB-8 POWR		41.	-141.	237.	185.	17.	5.	-174.	0.	237. COAL-AFB	237.	0	-2.53	0.07	0.16
2 STM088 STM-TURB-8 HEAT		41.	7.	48.	37.	3.	1.	0.	43.	48. COAL-AFB	90.	10	0.12	0.04	0.41
3 PFBSTM PFB-STMTB- POWR		41.	1.	96.	63.	17.	5.	-31.	0.	96. COAL-PFB	96.	10	0.02	0.18	0.39
3 PFBSTM PFB-STMTB- HEAT		41.	19.	56.	37.	10.	3.	0.	22.	56. COAL-PFB	78.	10	0.34	0.13	0.47
4 T1STMT TI-STMTB-1 POWR		0.	22.	75.	46.	17.	5.	-10.	0.	75. RESIDUAL	75.	10	-0.34	0.23	0.50
4 T1STMT TI-STMTB-1 HEAT		41.	1.	3.	2.	1.	0.	41.	51.	44. RESIDUAL	95.	10	0.03	0.01	0.39
4 T1STMT TI-STMTB-1 POWR		41.	22.	75.	46.	17.	5.	-10.	0.	75. COAL	75.	10	0.40	0.23	0.50
4 T1STMT TI-STMTB-1 HEAT		41.	26.	60.	37.	14.	4.	0.	10.	60. COAL	70.	10	0.47	0.20	0.53
5 TIHRSG THERMIONIC POWR		0.	-24.	121.	77.	17.	5.	-47.	0.	121. RESIDUAL	121.	0	-1.18	0.14	0.31
5 TIHRSG THERMIONIC HEAT		41.	1.	3.	2.	0.	0.	41.	52.	44. RESIDUAL	96.	10	0.01	0.00	0.38
5 TIHRSG THERMIONIC POWR		41.	-24.	121.	77.	17.	5.	-47.	0.	121. COAL	121.	0	-0.44	0.14	0.31
5 TIHRSG THERMIONIC HEAT		41.	11.	59.	37.	8.	2.	0.	28.	59. COAL	86.	10	0.19	0.10	0.43
6 STIRL STIRLING-1 POWR		3.	23.	70.	34.	17.	5.	3.	0.	74. DISTILLA	74.	0	-0.27	0.23	0.50
6 STIRL STIRLING-1 HEAT		41.	1.	4.	2.	1.	0.	41.	50.	45. DISTILLA	95.	10	0.02	0.01	0.39

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 24921 MW 5.00 PROCESS MILLIONS BTU/HR 37.0 PROCESS TEMP(F) 406. PRODUCT PARTICLE-BOA HOURS PER YEAR 8000.

UTILITY FUEL		COAL		POWER TO HEAT RATIO 0.461 WASTE FUEL EQV BTU*10**6= 41. HOT WATER BTU*10**6= 0.												
		WASTE FUEL USED 10**6 BTU/HR	SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET* TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
6 STIRL	STIRLING-1 POWR	3.	23.	70.	34.	17.	5.	3.	0.	74.	RESIDUAL	74.	0	-0.27	0.23	0.50
6 STIRL	STIRLING-1 HEAT	41.	1.	4.	2.	1.	0.	41.	50.	45.	RESIDUAL	95.	10	0.02	0.01	0.39
6 STIRL	STIRLING-1 POWR	41.	23.	70.	34.	17.	5.	3.	0.	74.	COAL	74.	0	0.42	0.23	0.50
6 STIRL	STIRLING-1 HEAT	41.	25.	76.	37.	18.	5.	0.	-4.	76.	COAL	72.	0	0.42	0.24	0.49
7 HEGT85	HELIUM-GT- POWR	41.	4.	53.	3.	17.	5.	40.	0.	93.	COAL-AFB	93.	11	0.06	0.18	0.40
7 HEGT85	HELIUM-GT- HEAT	41.	46.	677.	37.	217.	64.	0.	-626.	677.	COAL-AFB	51.	1	0.07	0.32	0.05
8 HEGT60	HELIUM-GT- POWR	41.	7.	66.	16.	17.	5.	24.	0.	90.	COAL-AFB	90.	10	0.12	0.19	0.41
8 HEGT60	HELIUM-GT- HEAT	41.	15.	148.	37.	38.	11.	0.	-66.	148.	COAL-AFB	82.	10	0.13	0.26	0.25
9 HEGT00	HELIUM-GT- POWR	41.	-0.	97.	46.	17.	5.	-11.	0.	97.	COAL-AFB	97.	10	-0.00	0.18	0.38
9 HEGT00	HELIUM-GT- HEAT	41.	9.	77.	37.	14.	4.	0.	11.	77.	COAL-AFB	88.	10	0.16	0.15	0.42
10 FCMCCL	FUEL-CL-MO POWR	0.	28.	56.	27.	17.	5.	12.	0.	68.	COAL	68.	10	-0.23	0.25	0.54
10 FCMCCL	FUEL-CL-MO HEAT	0.	40.	78.	37.	24.	7.	0.	-21.	78.	COAL	57.	10	-0.02	0.30	0.47
11 FCSTCL	FUEL-CL-ST POWR	0.	29.	47.	19.	17.	5.	21.	0.	68.	COAL	68.	10	-0.21	0.25	0.55
11 FCSTCL	FUEL-CL-ST HEAT	0.	56.	89.	37.	32.	10.	0.	-48.	89.	COAL	41.	10	0.14	0.36	0.42
12 IGGTST	INT-GAS-GT POWR	0.	23.	65.	29.	17.	5.	10.	0.	74.	COAL	74.	10	-0.33	0.23	0.50
12 IGGTST	INT-GAS-GT HEAT	0.	29.	83.	37.	22.	6.	0.	-15.	83.	COAL	68.	10	-0.17	0.26	0.45
13 GTSOAR	GT-HRSG-10 POWR	15.	23.	59.	24.	17.	5.	15.	0.	74.	RESIDUAL	74.	10	-0.06	0.23	0.50
13 GTSOAR	GT-HRSG-10 HEAT	41.	2.	5.	2.	1.	0.	41.	49.	46.	RESIDUAL	95.	10	0.03	0.01	0.39
14 GTAC08	GT-HRSG-08 POWR	5.	28.	63.	33.	17.	5.	5.	0.	68.	RESIDUAL	68.	10	-0.14	0.25	0.54
14 GTAC08	GT-HRSG-08 HEAT	41.	2.	4.	2.	1.	0.	41.	50.	45.	RESIDUAL	95.	10	0.03	0.01	0.39
15 GTAC12	GT-HRSG-12 POWR	13.	28.	56.	26.	17.	5.	13.	0.	69.	RESIDUAL	69.	10	-0.00	0.25	0.54
15 GTAC12	GT-HRSG-12 HEAT	41.	2.	4.	2.	1.	0.	41.	49.	45.	RESIDUAL	95.	10	0.04	0.01	0.39
16 GTAC16	GT-HRSG-16 POWR	17.	27.	53.	23.	17.	5.	17.	0.	70.	RESIDUAL	70.	10	0.05	0.24	0.53
16 GTAC16	GT-HRSG-16 HEAT	41.	2.	5.	2.	2.	0.	41.	49.	46.	RESIDUAL	94.	10	0.04	0.02	0.39
17 GTWC16	GT-HRSG-16 POWR	18.	25.	54.	22.	17.	5.	18.	0.	72.	RESIDUAL	72.	10	0.03	0.24	0.51
17 GTWC16	GT-HRSG-16 HEAT	41.	2.	5.	2.	2.	0.	41.	48.	46.	RESIDUAL	95.	10	0.04	0.02	0.39

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 24921 MW 5.00 PROCESS MILLIONS BTU/HR 37.0 PROCESS TEMP(F) 406. PRODUCT PARTICLE-BOA HOURS PER YEAR 8000.

POWER TO HEAT RATIO 0.461

WASTE FUEL EQV BTU\*10\*\*6= 41. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
18	CC1626	GTST-16/26	POWR	26.	24.	47.	15.	17.	5.	26.	0.	73. RESIDUAL	73.	10	0.15	0.24	0.51
18	CC1626	GTST-16/26	HEAT	41.	3.	6.	2.	2.	1.	41.	46.	47. RESIDUAL	94.	10	0.06	0.02	0.39
19	CC1622	GTST-16/22	POWR	23.	25.	48.	17.	17.	5.	23.	0.	71. RESIDUAL	71.	10	0.14	0.24	0.52
19	CC1622	GTST-16/22	HEAT	41.	3.	6.	2.	2.	1.	41.	47.	47. RESIDUAL	94.	10	0.05	0.02	0.39
20	CC1222	GTST-12/22	POWR	23.	26.	48.	17.	17.	5.	23.	0.	71. RESIDUAL	71.	10	0.14	0.24	0.52
20	CC1222	GTST-12/22	HEAT	41.	3.	6.	2.	2.	1.	41.	47.	47. RESIDUAL	94.	10	0.05	0.02	0.39
21	CC0822	GTST-08/22	POWR	18.	28.	51.	22.	17.	5.	18.	0.	69. RESIDUAL	69.	10	0.08	0.25	0.53
21	CC0822	GTST-08/22	HEAT	41.	3.	5.	2.	2.	0.	41.	48.	46. RESIDUAL	94.	10	0.05	0.02	0.39
22	ST1015	STIG-15-16	POWR	41.	9.	45.	1.	17.	5.	43.	0.	88. RESIDUAL	83.	10	0.17	0.19	0.42
22	ST1015	STIG-15-16	HEAT	41.	32.	154.	2.	59.	17.	41.	-130.	195. RESIDUAL	65.	10	0.17	0.30	0.19
23	ST1010	STIG-10-16	POWR	36.	13.	48.	6.	17.	5.	36.	0.	84. RESIDUAL	84.	10	0.15	0.20	0.44
23	ST1010	STIG-10-16	HEAT	41.	4.	15.	2.	5.	2.	41.	36.	56. RESIDUAL	93.	10	0.08	0.06	0.40
24	ST101S	STIG-1S-16	POWR	31.	15.	51.	11.	17.	5.	31.	0.	82. RESIDUAL	82.	10	0.09	0.21	0.45
24	ST101S	STIG-1S-16	HEAT	41.	3.	9.	2.	3.	1.	41.	43.	51. RESIDUAL	94.	10	0.05	0.03	0.39
25	DEADV3	DIESEL-ADV	POWR	33.	18.	46.	9.	17.	5.	33.	0.	79. RESIDUAL	79.	0	0.17	0.22	0.47
25	DEADV3	DIESEL-ADV	HEAT	41.	4.	11.	2.	4.	1.	41.	41.	52. RESIDUAL	93.	10	0.07	0.04	0.40
26	DEADV2	DIESEL-ADV	POWR	30.	21.	46.	12.	17.	5.	30.	0.	76. RESIDUAL	76.	1	0.17	0.23	0.49
26	DEADV2	DIESEL-ADV	HEAT	41.	4.	8.	2.	3.	1.	41.	44.	49. RESIDUAL	93.	11	0.06	0.03	0.40
27	DEADV1	DIESEL-ADV	POWR	22.	28.	46.	18.	17.	5.	22.	0.	68. RESIDUAL	68.	1	0.17	0.25	0.54
27	DEADV1	DIESEL-ADV	HEAT	41.	3.	5.	2.	2.	1.	41.	47.	46. RESIDUAL	94.	11	0.06	0.02	0.39
28	DEHTPM	ADV-DIESEL	POWR	16.	26.	55.	23.	17.	5.	16.	0.	71. RESIDUAL	71.	0	0.01	0.24	0.52
28	DEHTPM	ADV-DIESEL	HEAT	41.	2.	5.	2.	1.	0.	41.	49.	46. RESIDUAL	95.	10	0.04	0.02	0.39
29	DESQA3	DIESEL-SQA	POWR	35.	15.	47.	7.	17.	5.	35.	0.	82. DISTILLA	82.	0	0.15	0.21	0.45
29	DESQA3	DIESEL-SQA	HEAT	41.	4.	13.	2.	5.	1.	41.	39.	54. DISTILLA	93.	0	0.07	0.05	0.40
29	DESQA3	DIESEL-SQA	POWR	35.	15.	47.	7.	17.	5.	35.	0.	82. RESIDUAL	82.	0	0.15	0.21	0.45
29	DESQA3	DIESEL-SQA	HEAT	41.	4.	13.	2.	5.	1.	41.	39.	54. RESIDUAL	93.	0	0.07	0.05	0.40

HONEYWELL PAGE PRINTING SYSTEM - P1185-02

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 24921 MW 5.00 PROCESS MILLIONS BTU/HR 37.0 PROCESS TEMP(F) 406. PRODUCT PARTICLE-BOA HOURS PER YEAR 8000.

POWER TO HEAT RATIO 0.461

WASTE FUEL EQW BTU\*10\*\*6= 41. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
30 DES0A2 DIESEL-S0A POWR		31.	18.	47.	10.	17.	5.	31.	0.	79.	DISTILLA	79.	1	0.15	0.22	0.47
30 DES0A2 DIESEL-S0A HEAT		41.	4.	9.	2.	3.	1.	41.	43.	50.	DISTILLA	93.	1	0.06	0.04	0.40
30 DES0A2 DIESEL-S0A POWR		31.	18.	47.	10.	17.	5.	31.	0.	79.	RESIDUAL	79.	1	0.15	0.22	0.47
30 DES0A2 DIESEL-S0A HEAT		41.	4.	9.	2.	3.	1.	41.	43.	50.	RESIDUAL	93.	1	0.06	0.04	0.40
31 DES0A1 DIESEL-S0A POWR		21.	28.	47.	19.	17.	5.	21.	0.	68.	DISTILLA	68.	1	0.15	0.25	0.54
31 DES0A1 DIESEL-S0A HEAT		41.	3.	5.	2.	2.	1.	41.	48.	46.	DISTILLA	94.	1	0.05	0.02	0.39
31 DES0A1 DIESEL-S0A POWR		21.	28.	47.	19.	17.	5.	21.	0.	68.	RESIDUAL	68.	1	0.15	0.25	0.54
31 DES0A1 DIESEL-S0A HEAT		41.	3.	5.	2.	2.	1.	41.	48.	46.	RESIDUAL	94.	1	0.05	0.02	0.39
32 GTS0AD GT-HRS0-10 POWR		12.	26.	58.	27.	17.	5.	12.	0.	71.	DISTILLA	71.	10	-0.05	0.24	0.52
32 GTS0AD GT-HRS0-10 HEAT		41.	2.	4.	2.	1.	0.	41.	49.	46.	DISTILLA	95.	10	0.04	0.01	0.39
33 GTRA08 GT-85RE-08 POWR		26.	23.	48.	15.	17.	5.	26.	0.	73.	DISTILLA	73.	10	0.14	0.23	0.50
33 GTRA08 GT-85RE-08 HEAT		41.	3.	6.	2.	2.	1.	41.	46.	47.	DISTILLA	94.	10	0.06	0.02	0.39
34 GTRA12 GT-85RE-12 POWR		25.	24.	48.	16.	17.	5.	25.	0.	73.	DISTILLA	73.	10	0.14	0.23	0.51
34 GTRA12 GT-85RE-12 HEAT		41.	3.	6.	2.	2.	1.	41.	47.	47.	DISTILLA	94.	10	0.06	0.02	0.39
35 GTRA16 GT-85RE-16 POWR		23.	25.	49.	17.	17.	5.	23.	0.	72.	DISTILLA	72.	10	0.12	0.24	0.51
35 GTRA16 GT-85RE-16 HEAT		41.	3.	6.	2.	2.	1.	41.	47.	47.	DISTILLA	94.	10	0.05	0.02	0.39
36 GTR208 GT-60RE-08 POWR		19.	25.	53.	21.	17.	5.	19.	0.	72.	DISTILLA	72.	10	0.04	0.24	0.51
36 GTR208 GT-60RE-08 HEAT		41.	2.	5.	2.	2.	0.	41.	48.	46.	DISTILLA	94.	10	0.04	0.02	0.39
37 GTR212 GT-60RE-12 POWR		21.	25.	52.	19.	17.	5.	21.	0.	72.	DISTILLA	72.	10	0.07	0.24	0.51
37 GTR212 GT-60RE-12 HEAT		41.	3.	5.	2.	2.	1.	41.	48.	46.	DISTILLA	94.	10	0.05	0.02	0.39
38 GTR216 GT-60RE-16 POWR		21.	25.	51.	19.	17.	5.	21.	0.	72.	DISTILLA	72.	10	0.09	0.24	0.52
38 GTR216 GT-60RE-16 HEAT		41.	3.	5.	2.	2.	1.	41.	48.	47.	DISTILLA	94.	10	0.05	0.02	0.39
39 GTRW08 GT-85RE-08 POWR		28.	20.	49.	13.	17.	5.	28.	0.	77.	DISTILLA	77.	10	0.13	0.22	0.48
39 GTRW08 GT-85RE-08 HEAT		41.	3.	8.	2.	3.	1.	41.	45.	49.	DISTILLA	94.	10	0.06	0.03	0.39
40 GTRW12 GT-85RE-12 POWR		29.	21.	47.	13.	17.	5.	29.	0.	75.	DISTILLA	75.	10	0.16	0.23	0.49
40 GTRW12 GT-85RE-12 HEAT		41.	3.	7.	2.	3.	1.	41.	45.	49.	DISTILLA	93.	10	0.06	0.03	0.40

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
 COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
 REPORT 5.1

PAGE 55

I&SE PEG ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 24921 MW 5.00 PROCESS MILLIONS BTU/HR 37.0 PROCESS TEMP(F) 406. PRODUCT PARTICLE-BOA HOURS PER YEAR 8000.

POWER TO HEAT RATIO 0.461

WASTE FUEL EQV BTU\*10\*\*6= 41. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED-NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET* TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41 GTRW16 GT-85RE-16 POWR		27.	22.	48.	14.	17.	5.	27.	0.	75.DISTILLA		75.	10	0.14	0.23	0.49
41 GTRW16 GT-85RE-16 HEAT		41.	3.	7.	2.	2.	1.	41.	46.	48.DISTILLA		94.	10	0.06	0.03	0.39
42 GTR308 GT-60RE-08 POWR		24.	18.	55.	17.	17.	5.	24.	0.	79.DISTILLA		79.	10	0.01	0.22	0.47
42 GTR308 GT-60RE-08 HEAT		41.	2.	7.	2.	2.	1.	41.	47.	48.DISTILLA		95.	10	0.04	0.02	0.39
43 GTR312 GT-60RE-12 POWR		24.	23.	50.	16.	17.	5.	24.	0.	74.DISTILLA		74.	10	0.10	0.23	0.50
43 GTR312 GT-60RE-12 HEAT		41.	3.	6.	2.	2.	1.	41.	47.	47.DISTILLA		94.	10	0.05	0.02	0.39
44 GTR316 GT-60RE-16 POWR		24.	22.	50.	17.	17.	5.	24.	0.	74.DISTILLA		74.	10	0.10	0.23	0.50
44 GTR316 GT-60RE-16 HEAT		41.	3.	6.	2.	2.	1.	41.	47.	47.DISTILLA		94.	10	0.05	0.02	0.39
45 FCPADS FUEL-CL-PH POWR		35.	17.	45.	8.	17.	5.	35.	0.	79.DISTILLA		79.	0	0.19	0.21	0.47
45 FCPADS FUEL-CL-PH HEAT		41.	5.	12.	2.	4.	1.	41.	39.	53.DISTILLA		92.	0	0.08	0.05	0.40
46 FCMCDS FUEL-CL-MO POWR		32.	23.	41.	10.	17.	5.	32.	0.	74.DISTILLA		74.	0	0.26	0.23	0.50
46 FCMCDS FUEL-CL-MO HEAT		41.	5.	9.	2.	4.	1.	41.	42.	50.DISTILLA		92.	10	0.09	0.04	0.40



I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 26212 MW 50.00 PROCESS MILLIONS BTU/HR 780.0 PROCESS TEMP(F) 366. PRODUCT BLEACHED-KRA HOURS PER YEAR 8400.

UTILITY FUEL		COAL		POWER TO HEAT RATIO 0.219 WASTE FUEL EQV BTU*10**6= 353. HOT WATER BTU*10**6= 0.												
		WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL 10**6 BTU/HR	SITE FUEL USED	NET* TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
0	ONCOGN N C C O O N	353.	0.	0.	0.	0.	0.	918.	533.	918.	COAL-FGD	1451.	0	0.	0.12	0.54
1	STM141 STM-TURB-1 POWR	353.	277.	1173.	827.	171.	50.	-55.	0.	1173.	RESIDUAL	1173.	0	0.25	0.15	0.66
1	STM141 STM-TURB-1 HEAT	353.	314.	1107.	780.	161.	47.	0.	30.	1107.	RESIDUAL	1137.	0	0.29	0.14	0.69
1	STM141 STM-TURB-1 POWR	353.	277.	1173.	827.	171.	50.	-55.	0.	1173.	COAL-FGD	1173.	0	0.25	0.15	0.66
1	STM141 STM-TURB-1 HEAT	353.	314.	1107.	780.	161.	47.	0.	30.	1107.	COAL-FGD	1137.	0	0.29	0.14	0.69
1	STM141 STM-TURB-1 POWR	353.	277.	1173.	827.	171.	50.	-55.	0.	1173.	COAL-AFB	1173.	0	0.25	0.15	0.66
1	STM141 STM-TURB-1 HEAT	353.	314.	1107.	780.	161.	47.	0.	30.	1107.	COAL-AFB	1137.	0	0.29	0.14	0.69
2	STM088 STM-TURB-8 POWR	353.	-89.	1540.	1138.	171.	50.	-421.	0.	1540.	RESIDUAL	1540.	0	-0.08	0.11	0.51
2	STM088 STM-TURB-8 HEAT	353.	228.	1055.	780.	117.	34.	0.	188.	1055.	RESIDUAL	1223.	0	0.21	0.10	0.64
2	STM088 STM-TURB-8 POWR	353.	-89.	1540.	1138.	171.	50.	-421.	0.	1540.	COAL-FGD	1540.	0	-0.08	0.11	0.51
2	STM088 STM-TURB-8 HEAT	353.	228.	1055.	780.	117.	34.	0.	188.	1055.	COAL-FGD	1223.	0	0.21	0.10	0.64
2	STM088 STM-TURB-8 POWR	353.	-89.	1540.	1138.	171.	50.	-421.	0.	1540.	COAL-AFB	1540.	0	-0.08	0.11	0.51
2	STM088 STM-TURB-8 HEAT	353.	228.	1055.	780.	117.	34.	0.	188.	1055.	COAL-AFB	1223.	0	0.21	0.10	0.64
3	PFBSTM PFB-STMTB- POWR	353.	326.	806.	509.	171.	50.	319.	0.	1125.	COAL-PFB	1125.	0	0.30	0.15	0.69
3	PFBSTM PFB-STMTB- HEAT	353.	499.	1236.	780.	261.	77.	0.	-284.	1236.	COAL-PFB	952.	0	0.36	0.21	0.63
4	TISTMT TI-STMTB-1 POWR	353.	327.	654.	381.	171.	50.	469.	0.	1124.	RESIDUAL	1124.	0	0.30	0.15	0.69
4	TISTMT TI-STMTB-1 HEAT	353.	412.	824.	480.	215.	63.	353.	-138.	1177.	RESIDUAL	1039.	0	0.33	0.18	0.66
4	TISTMT TI-STMTB-1 POWR	353.	327.	654.	381.	171.	50.	469.	0.	1124.	COAL	1124.	0	0.30	0.15	0.69
4	TISTMT TI-STMTB-1 HEAT	353.	669.	1329.	780.	349.	102.	0.	-558.	1339.	COAL	781.	0	0.40	0.26	0.58
5	TIHRSG THERMIONIC POWR	0.	238.	1213.	783.	171.	50.	-4.	0.	1213.	RESIDUAL	1213.	0	-0.10	0.14	0.64
5	TIHRSG THERMIONIC HEAT	353.	148.	743.	480.	105.	31.	353.	206.	1096.	RESIDUAL	1303.	0	0.14	0.08	0.60
5	TIHRSG THERMIONIC POWR	353.	238.	1213.	783.	171.	50.	-4.	0.	1213.	COAL	1213.	0	0.22	0.14	0.64
5	TIHRSG THERMIONIC HEAT	353.	241.	1208.	780.	170.	50.	0.	2.	1208.	COAL	1210.	0	0.22	0.14	0.64
6	STIRL STIRLING-1 POWR	353.	236.	677.	323.	171.	50.	538.	0.	1215.	DISTILLA	1215.	0	0.22	0.14	0.64
6	STIRL STIRLING-1 HEAT	353.	351.	1006.	480.	253.	74.	353.	-259.	1359.	DISTILLA	1100.	0	0.26	0.19	0.57

HONEYWELL PAGE PRINTING SYSTEM - P1185-02

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 26212 MW 50.00 PROCESS MILLIONS BTU/HR 780.0 PROCESS TEMP(F) 366. PRODUCT BLEACHED-KRA HOURS PER YEAR 8400.

POWER TO HEAT RATIO 0.219

WASTE FUEL EQV BTU\*10\*\*6= 353. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL COAL

			WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX BUTLR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
6	STIRL	STIRLING-1	POWR	353.	236.	677.	323.	171.	50.	538.	0.	1215.	RESIDUAL	1215.	0	0.22	0.14	0.64
6	STIRL	STIRLING-1	HEAT	353.	351.	1006.	480.	253.	74.	353.	-259.	1359.	RESIDUAL	1100.	0	0.26	0.19	0.57
6	STIRL	STIRLING-1	POWR	353.	236.	677.	323.	171.	50.	538.	0.	1215.	COAL	1215.	0	0.22	0.14	0.64
6	STIRL	STIRLING-1	HEAT	353.	570.	1635.	780.	412.	121.	0.	-754.	1635.	COAL	881.	0	0.31	0.25	0.48
7	HEGT85	HELIUM-GT-	POWR	353.	76.	531.	63.	171.	50.	844.	0.	1375.	COAL-AFB	1375.	0	0.07	0.12	0.57
7	HEGT85	HELIUM-GT-	HEAT	353.	938.	6597.	780.	2118.	621.	0.	-6085.	6597.	COAL-AFB	513.	0	0.13	0.32	0.12
8	HEGT60	HELIUM-GT-	POWR	353.	100.	659.	191.	171.	50.	692.	0.	1351.	COAL-AFB	1351.	0	0.09	0.13	0.58
8	HEGT60	HELIUM-GT-	HEAT	353.	406.	2684.	780.	695.	204.	0.	-1639.	2684.	COAL-AFB	1045.	0	0.15	0.26	0.29
9	HEGT00	HELIUM-GT-	POWR	353.	121.	969.	473.	171.	50.	361.	0.	1330.	COAL-AFB	1330.	0	0.11	0.13	0.59
9	HEGT00	HELIUM-GT-	HEAT	353.	199.	1597.	780.	281.	82.	0.	-345.	1597.	COAL-AFB	1252.	0	0.14	0.18	0.49
10	FCMCCL	FUEL-CL-MO	POWR	0.	284.	561.	266.	171.	50.	605.	0.	1166.	COAL	1166.	10	-0.06	0.15	0.67
10	FCMCCL	FUEL-CL-MO	HEAT	0.	835.	1648.	780.	501.	147.	0.	-1032.	1648.	COAL	616.	0	0.23	0.30	0.47
11	FCSTCL	FUEL-CL-ST	POWR	0.	295.	443.	175.	171.	50.	712.	0.	1155.	COAL	1155.	10	-0.05	0.15	0.68
11	FCSTCL	FUEL-CL-ST	HEAT	0.	1318.	1978.	780.	761.	223.	0.	-1844.	1978.	COAL	133.	0	0.33	0.38	0.39
12	IGGTST	INT-GAS-GT	POWR	0.	234.	595.	252.	171.	50.	622.	0.	1216.	COAL	1216.	10	-0.11	0.14	0.64
12	IGGTST	INT-GAS-GT	HEAT	0.	727.	1843.	780.	529.	155.	0.	-1120.	1843.	COAL	724.	0	0.17	0.29	0.42
13	GTSCAR	GT-HRSO-10	POWR	353.	238.	588.	249.	171.	50.	624.	0.	1212.	RESIDUAL	1212.	0	0.22	0.14	0.64
13	GTSCAR	GT-HRSO-10	HEAT	353.	459.	1132.	480.	328.	96.	353.	-493.	1485.	RESIDUAL	992.	0	0.29	0.22	0.53
14	GTAC08	GT-HRSO-08	POWR	353.	284.	632.	325.	171.	50.	535.	0.	1167.	RESIDUAL	1167.	0	0.26	0.15	0.67
14	GTAC08	GT-HRSO-08	HEAT	353.	419.	933.	480.	252.	74.	353.	-254.	1286.	RESIDUAL	1032.	0	0.31	0.20	0.61
15	GTAC12	GT-HRSO-12	POWR	353.	279.	559.	260.	171.	50.	612.	0.	1172.	RESIDUAL	1172.	0	0.25	0.15	0.67
15	GTAC12	GT-HRSO-12	HEAT	353.	516.	1034.	480.	315.	92.	353.	-452.	1387.	RESIDUAL	935.	0	0.33	0.23	0.56
16	GTAC16	GT-HRSO-16	POWR	353.	274.	528.	228.	171.	50.	649.	0.	1177.	RESIDUAL	1177.	0	0.25	0.14	0.66
16	GTAC16	GT-HRSO-16	HEAT	353.	575.	1110.	480.	359.	105.	353.	-587.	1463.	RESIDUAL	876.	0	0.34	0.25	0.53
17	GTWC16	GT-HRSO-16	POWR	353.	249.	542.	219.	171.	50.	660.	0.	1201.	RESIDUAL	1201.	0	0.23	0.14	0.65
17	GTWC16	GT-HRSO-16	HEAT	353.	546.	1186.	480.	374.	110.	353.	-635.	1539.	RESIDUAL	905.	0	0.32	0.24	0.51

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 26212 MW 50.00 PROCESS MILLIONS BTU/HR 780.0 PROCESS TEMP(F) 366. PRODUCT BLEACHED-KRA HOURS PER YEAR 8400.

UTILITY FUEL COAL  
POWER TO HEAT RATIO 0.219  
WASTE FUEL EQV BTU\*10\*\*6= 353. HOT WATER BTU\*10\*\*6= 0.

UNIT	FUEL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN ELECT 10**6 BTU/HR	AUX PROCES BOILER 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL USED 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET* TOTAL UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT
18	CC1626	GTST-16/26	POWR	353.	246.	452.	50.	754.	0.	1204.	RESIDUAL	1204.	0	0.22	0.14	0.65
18	CC1626	GTST-16/26	HEAT	353.	351.	1555.	173.	353.	-1309.	1908.	RESIDUAL	599.	0	0.35	0.31	0.41
19	CC1622	GTST-16/22	POWR	353.	258.	456.	50.	736.	0.	1192.	RESIDUAL	1192.	0	0.24	0.14	0.65
19	CC1622	GTST-16/22	HEAT	353.	803.	1418.	155.	353.	-1124.	1771.	RESIDUAL	647.	0	0.36	0.30	0.44
20	CC1222	GTST-12/22	POWR	353.	261.	455.	50.	735.	0.	1190.	RESIDUAL	1190.	0	0.24	0.14	0.66
20	CC1222	GTST-12/22	HEAT	353.	807.	1407.	155.	353.	-1116.	1759.	RESIDUAL	644.	0	0.36	0.30	0.44
21	CC0822	GTST-08/22	POWR	353.	280.	483.	50.	688.	0.	1171.	RESIDUAL	1171.	0	0.25	0.15	0.67
21	CC0822	GTST-08/22	HEAT	353.	688.	1189.	123.	353.	-779.	1542.	RESIDUAL	763.	0	0.37	0.27	0.51
22	ST1015	ST10-15-16	POWR	353.	92.	448.	6.	171.	0.	1359.	RESIDUAL	1359.	0	0.08	0.13	0.57
22	ST1015	ST10-15-16	HEAT	353.	7603.	36923.	480.	14068.	4123.	37276.	RESIDUAL	-6152.	0	0.17	0.38	0.02
23	ST1010	ST10-10-16	POWR	353.	132.	475.	63.	171.	0.	1319.	RESIDUAL	1319.	0	0.12	0.13	0.59
23	ST1010	ST10-10-16	HEAT	353.	1007.	3623.	480.	1301.	381.	3976.	RESIDUAL	443.	0	0.22	0.33	0.20
24	ST1015	ST10-15-16	POWR	353.	150.	509.	107.	171.	0.	1300.	RESIDUAL	1300.	0	0.14	0.13	0.60
24	ST1015	ST10-15-16	HEAT	353.	673.	2277.	480.	763.	224.	2630.	RESIDUAL	778.	0	0.23	0.29	0.30
25	DEADV3	DIESEL-ADV	POWR	353.	184.	460.	94.	171.	0.	1267.	RESIDUAL	1267.	0	0.17	0.13	0.62
25	DEADV3	DIESEL-ADV	HEAT	353.	938.	2342.	480.	869.	255.	2695.	RESIDUAL	513.	0	0.29	0.32	0.29
26	DEADV2	DIESEL-ADV	POWR	353.	211.	460.	117.	171.	0.	1240.	RESIDUAL	1240.	1	0.19	0.14	0.63
26	DEADV2	DIESEL-ADV	HEAT	353.	866.	1890.	480.	701.	205.	2243.	RESIDUAL	585.	1	0.31	0.31	0.35
27	DEADV1	DIESEL-ADV	POWR	353.	285.	460.	180.	171.	0.	1166.	RESIDUAL	1166.	1	0.26	0.15	0.67
27	DEADV1	DIESEL-ADV	HEAT	353.	760.	1228.	480.	455.	133.	1581.	RESIDUAL	690.	1	0.38	0.29	0.49
28	DEHTPM	ADV-DIESEL	POWR	353.	274.	522.	224.	171.	0.	1176.	RESIDUAL	1176.	0	0.25	0.15	0.66
28	DEHTPM	ADV-DIESEL	HEAT	353.	589.	1120.	480.	366.	107.	1473.	RESIDUAL	862.	0	0.34	0.25	0.53
29	DESOA3	DIESEL-SOA	POWR	353.	156.	473.	81.	171.	0.	1295.	DISTILLA	1295.	0	0.14	0.13	0.60
29	DESOA3	DIESEL-SOA	HEAT	353.	924.	2807.	480.	1013.	297.	3160.	DISTILLA	526.	0	0.25	0.32	0.25
29	DESOA3	DIESEL-SOA	POWR	353.	156.	473.	81.	171.	0.	1295.	RESIDUAL	1295.	0	0.14	0.13	0.60
29	DESOA3	DIESEL-SOA	HEAT	353.	924.	2807.	480.	1013.	297.	3160.	RESIDUAL	526.	0	0.25	0.32	0.25

ORIGINAL PAGE IS  
OF POOR QUALITY

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 59

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 26212 MW 50.00 PROCESS MILLIONS BTU/HR 780.0 PROCESS TEMP(F) 366. PRODUCT BLEACHED-KRA HOURS PER YEAR 8400.

UTILITY FUEL		COAL		POWER TO HEAT RATIO 0.219 WASTE FUEL EQV BTU*10**6= 353. HOT WATER BTU*10**6= 0.												
		WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
30	DESOA2 DIESEL-SOA POWR	353.	183.	473.	104.	171.	50.	795.	0.	1268.	DISTILLA	1268.	1	0.17	0.13	0.62
30	DESOA2 DIESEL-SOA HEAT	353.	844.	2162.	480.	788.	231.	353.	-1928.	2535.	DISTILLA	607.	1	0.28	0.31	0.31
30	DESOA2 DIESEL-SOA POWR	353.	183.	473.	104.	171.	50.	795.	0.	1268.	RESIDUAL	1268.	1	0.17	0.13	0.62
30	DESOA2 DIESEL-SOA HEAT	353.	844.	2182.	480.	788.	231.	353.	-1928.	2535.	RESIDUAL	607.	1	0.28	0.31	0.31
31	DESOA1 DIESEL-SOA POWR	353.	283.	473.	190.	171.	50.	695.	0.	1167.	DISTILLA	1167.	1	0.26	0.15	0.67
31	DESOA1 DIESEL-SOA HEAT	353.	718.	1197.	480.	432.	127.	353.	-817.	1550.	DISTILLA	733.	1	0.37	0.28	0.50
31	DESOA1 DIESEL-SOA POWR	353.	283.	473.	190.	171.	50.	695.	0.	1167.	RESIDUAL	1167.	1	0.26	0.15	0.67
31	DESOA1 DIESEL-SOA HEAT	353.	718.	1197.	480.	432.	127.	353.	-817.	1550.	RESIDUAL	733.	1	0.37	0.28	0.50
32	GTSOAD GT-HRSG-10 POWR	353.	265.	384.	269.	171.	50.	601.	0.	1185.	DISTILLA	1185.	0	0.24	0.14	0.66
32	GTSOAD GT-HRSG-10 HEAT	353.	474.	1042.	480.	304.	89.	353.	-418.	1395.	DISTILLA	977.	0	0.31	0.22	0.56
33	GTRA08 GT-85RE-08 POWR	353.	244.	478.	161.	171.	50.	729.	0.	1206.	DISTILLA	1206.	0	0.22	0.14	0.65
33	GTRA08 GT-85RE-08 HEAT	353.	730.	1428.	480.	510.	149.	353.	-1059.	1780.	DISTILLA	721.	0	0.34	0.29	0.44
34	GTRA12 GT-85RE-12 POWR	353.	251.	477.	165.	171.	50.	724.	0.	1200.	DISTILLA	1200.	0	0.23	0.14	0.65
34	GTRA12 GT-85RE-12 HEAT	353.	729.	1386.	480.	496.	145.	353.	-1018.	1739.	DISTILLA	721.	0	0.34	0.29	0.45
35	GTRA16 GT-85RE-16 POWR	353.	253.	489.	177.	171.	50.	709.	0.	1198.	DISTILLA	1198.	0	0.23	0.14	0.65
35	GTRA16 GT-85RE-16 HEAT	353.	685.	1325.	480.	462.	135.	353.	-912.	1678.	DISTILLA	766.	0	0.34	0.28	0.46
36	GTR208 GT-60RE-08 POWR	353.	252.	533.	214.	171.	50.	665.	0.	1199.	DISTILLA	1199.	0	0.23	0.14	0.65
36	GTR208 GT-60RE-08 HEAT	353.	565.	1194.	480.	382.	112.	353.	-681.	1547.	DISTILLA	886.	0	0.32	0.25	0.50
37	GTR212 GT-60RE-12 POWR	353.	251.	517.	200.	171.	50.	683.	0.	1199.	DISTILLA	1199.	0	0.23	0.14	0.65
37	GTR212 GT-60RE-12 HEAT	353.	604.	1242.	480.	410.	120.	353.	-747.	1594.	DISTILLA	847.	0	0.33	0.26	0.49
38	GTR216 GT-60RE-16 POWR	353.	256.	506.	195.	171.	50.	688.	0.	1195.	DISTILLA	1195.	0	0.23	0.14	0.65
38	GTR216 GT-60RE-16 HEAT	353.	631.	1247.	480.	420.	123.	353.	-780.	1600.	DISTILLA	820.	0	0.34	0.26	0.49
39	GTRW08 GT-85RE-08 POWR	353.	206.	486.	135.	171.	50.	759.	0.	1245.	DISTILLA	1245.	0	0.19	0.14	0.63
39	GTRW08 GT-85RE-08 HEAT	353.	732.	1731.	480.	607.	178.	353.	-1365.	2084.	DISTILLA	718.	0	0.30	0.29	0.37
40	GTRW12 GT-85RE-12 POWR	353.	221.	469.	133.	171.	50.	761.	0.	1230.	DISTILLA	1230.	0	0.20	0.14	0.63
40	GTRW12 GT-85RE-12 HEAT	353.	798.	1693.	480.	616.	181.	353.	-1393.	2046.	DISTILLA	653.	0	0.32	0.30	0.38

HONEYWELL PAGE PRINTING SYSTEM P1185-02

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 26212 MW 50.00 PROCESS MILLIONS BTU/HR 780.0 PROCESS TEMP(F) 366. PRODUCT BLEACHED-KRA HOURS PER YEAR 8400.

POWER TO HEAT RATIO 0.219

WASTE FUEL EQV BTU\*10\*\*6= 353. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41	GTRW16 GT-85RE-16 POWR	353.	224.	478.	144.	171.	50.	749.	0.	1227.	DISTILLA	1227.	0	0.20	0.14	0.64
41	GTRW16 GT-85RE-16 HEAT	353.	749.	1597.	480.	570.	167.	353.	-1248.	1950.	DISTILLA	701.	0	0.32	0.29	0.40
42	GTR308 GT-60RE-08 POWR	353.	190.	550.	177.	171.	50.	710.	0.	1260.	DISTILLA	1260.	0	0.17	0.14	0.62
42	GTR308 GT-60RE-08 HEAT	353.	518.	1496.	480.	464.	136.	353.	-916.	1849.	DISTILLA	933.	0	0.26	0.25	0.42
43	GTR312 GT-60RE-12 POWR	353.	229.	499.	165.	171.	50.	723.	0.	1222.	DISTILLA	1222.	0	0.21	0.14	0.64
43	GTR312 GT-60RE-12 HEAT	353.	664.	1448.	480.	495.	145.	353.	-1015.	1801.	DISTILLA	787.	0	0.31	0.27	0.43
44	GTR316 GT-60RE-16 POWR	353.	227.	503.	168.	171.	50.	720.	0.	1223.	DISTILLA	1223.	0	0.21	0.14	0.64
44	GTR316 GT-60RE-16 HEAT	353.	650.	1438.	480.	488.	143.	353.	-991.	1791.	DISTILLA	801.	0	0.31	0.27	0.44
45	FCPADS FUEL-CL-PH POWR	353.	174.	449.	76.	171.	50.	828.	0.	1277.	DISTILLA	1277.	0	0.16	0.13	0.61
45	FCPADS FUEL-CL-PH HEAT	353.	1094.	2824.	480.	1073.	314.	353.	-2820.	3176.	DISTILLA	357.	0	0.28	0.34	0.25
46	FCMCDS FUEL-CL-MO POWR	353.	233.	414.	96.	171.	50.	804.	0.	1218.	DISTILLA	1218.	0	0.21	0.14	0.64
46	FCMCDS FUEL-CL-MO HEAT	353.	1157.	2060.	480.	849.	249.	353.	-2119.	2413.	DISTILLA	294.	0	0.36	0.35	0.32

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 26214 MW 29.00 PROCESS MILLIONS BTU/HR 610.0 PROCESS TEMP(F) 366. PRODUCT UNBLEACHED-K HOURS PER YEAR 8400.

POWER TO HEAT RATIO 0.162

WASTE FUEL EQV BTU\*10\*\*6= 259. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
0	ONCOGN N O C O O N	259.	0.	0.	0.	0.	0.	718.	309.	718.	COAL-FGD	1027.	0	0.	0.10	0.59
1	STM141 STM-TURB-1 POWR	259.	193.	650.	453.	99.	29.	184.	0.	834.	RESIDUAL	834.	0	0.25	0.12	0.73
1	STM141 STM-TURB-1 HEAT	259.	259.	874.	610.	133.	39.	0.	-107.	874.	RESIDUAL	767.	0	0.30	0.15	0.70
1	STM141 STM-TURB-1 POWR	259.	193.	650.	453.	99.	29.	184.	0.	834.	COAL-FGD	834.	0	0.25	0.12	0.73
1	STM141 STM-TURB-1 HEAT	259.	259.	874.	610.	133.	39.	0.	-107.	874.	COAL-FGD	767.	0	0.30	0.15	0.70
1	STM141 STM-TURB-1 POWR	259.	193.	650.	453.	99.	29.	184.	0.	834.	COAL-AFB	834.	0	0.25	0.12	0.73
1	STM141 STM-TURB-1 HEAT	259.	259.	874.	610.	133.	39.	0.	-107.	874.	COAL-AFB	767.	0	0.30	0.15	0.70
2	STM088 STM-TURB-8 POWR	259.	187.	840.	615.	99.	29.	-6.	0.	840.	RESIDUAL	840.	0	0.24	0.12	0.73
2	STM088 STM-TURB-8 HEAT	259.	191.	833.	610.	98.	29.	0.	2.	833.	RESIDUAL	836.	0	0.25	0.12	0.73
2	STM088 STM-TURB-8 POWR	259.	187.	840.	615.	99.	29.	-6.	0.	840.	COAL-FGD	840.	0	0.24	0.12	0.73
2	STM088 STM-TURB-8 HEAT	259.	191.	833.	610.	98.	29.	0.	2.	833.	COAL-FGD	836.	0	0.25	0.12	0.73
2	STM088 STM-TURB-8 POWR	259.	187.	840.	615.	99.	29.	-6.	0.	840.	COAL-AFB	840.	0	0.24	0.12	0.73
2	STM088 STM-TURB-8 HEAT	259.	191.	833.	610.	98.	29.	0.	2.	833.	COAL-AFB	836.	0	0.25	0.12	0.73
3	PFBSTM PFB-STMTB- POWR	259.	189.	455.	284.	99.	29.	383.	0.	838.	COAL-PFB	838.	0	0.25	0.12	0.73
3	PFBSTM PFB-STMTB- HEAT	259.	406.	975.	610.	212.	62.	0.	-354.	975.	COAL-PFB	621.	0	0.36	0.22	0.63
4	TISTMT TI-STMTB-1 POWR	259.	190.	371.	214.	99.	29.	466.	0.	837.	RESIDUAL	837.	0	0.25	0.12	0.73
4	TISTMT TI-STMTB-1 HEAT	259.	346.	676.	390.	180.	53.	259.	-254.	935.	RESIDUAL	681.	0	0.34	0.19	0.65
4	TISTMT TI-STMTB-1 POWR	259.	190.	371.	214.	99.	29.	466.	0.	837.	COAL	837.	0	0.25	0.12	0.73
4	TISTMT TI-STMTB-1 HEAT	259.	540.	1058.	610.	282.	83.	0.	-571.	1058.	COAL	486.	0	0.40	0.27	0.58
5	TI' THERMIONIC POWR	183.	140.	703.	454.	99.	29.	183.	0.	887.	RESIDUAL	887.	0	0.08	0.11	0.69
5	TI' THERMIONIC HEAT	259.	120.	604.	390.	85.	25.	259.	44.	863.	RESIDUAL	906.	0	0.16	0.09	0.67
5	TIHRSO THERMIONIC POWR	259.	140.	703.	454.	99.	29.	183.	0.	887.	COAL	887.	0	0.18	0.11	0.69
5	TIHRSO THERMIONIC HEAT	259.	188.	945.	610.	133.	39.	0.	-106.	945.	COAL	838.	0	0.22	0.14	0.65
6	STIRL STIRLING-1 POWR	259.	137.	393.	187.	99.	29.	497.	0.	890.	DISTILLA	890.	0	0.18	0.11	0.69
6	STIRL STIRLING-1 HEAT	259.	285.	817.	390.	206.	60.	259.	-334.	1076.	DISTILLA	742.	0	0.26	0.19	0.57

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 26214 MW 29.00 PROCESS MILLIONS BTU/HR 610.0 PROCESS TEMP(F) 366. PRODUCT UNBLEACHED-K HOURS PER YEAR 8400.

POWER TO HEAT RATIO 0.162

WASTE FUEL EQV BTU\*10\*\*6= 259. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET USED 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	NET* TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
6 STIRL	STIRLING-1 POWR	259.	137.	393.	187.	99.	29.	497.	0.	890. RESIDUAL	890.	0	0.18	0.11	0.69
6 STIRL	STIRLING-1 HEAT	259.	285.	817.	390.	206.	60.	259.	-334.	1076. RESIDUAL	742.	0	0.26	0.19	0.57
6 STIRL	STIRLING-1 POWR	259.	137.	393.	187.	99.	29.	497.	0.	890. COAL	890.	0	0.18	0.11	0.69
6 STIRL	STIRLING-1 HEAT	259.	446.	1279.	610.	322.	94.	0.	-697.	1279. COAL	581.	0	0.30	0.25	0.48
7 HEGT85	HELIUM-GT- POWR	259.	44.	308.	36.	99.	29.	675.	0.	983. COAL-AFB	983.	10	0.06	0.10	0.62
7 HEGT85	HELIUM-GT- HEAT	259.	734.	5159.	610.	1656.	485.	0.	-4866.	5159. COAL-AFB	293.	0	0.13	0.32	0.12
8 HEGT60	HELIUM-GT- POWR	259.	58.	382.	111.	99.	29.	587.	0.	969. COAL-AFB	969.	10	0.08	0.10	0.63
8 HEGT60	HELIUM-GT- HEAT	259.	318.	2099.	610.	544.	159.	0.	-1390.	2099. COAL-AFB	709.	0	0.15	0.26	0.29
9 HEGT00	HELIUM-GT- POWR	259.	70.	562.	275.	99.	29.	395.	0.	957. COAL-AFB	957.	10	0.09	0.10	0.64
9 HEGT00	HELIUM-GT- HEAT	259.	156.	1249.	610.	220.	64.	0.	-378.	1249. COAL-AFB	871.	0	0.14	0.18	0.49
10 FCMCCL	FUEL-CL-MO POWR	0.	165.	325.	154.	99.	29.	536.	0.	862. COAL	862.	10	-0.12	0.11	0.71
10 FCMCCL	FUEL-CL-MO HEAT	0.	653.	1289.	610.	392.	115.	0.	-915.	1289. COAL	374.	0	0.23	0.30	0.47
11 FCSTCL	FUEL-CL-ST POWR	0.	172.	255.	99.	99.	29.	601.	0.	855. COAL	855.	10	-0.11	0.12	0.71
11 FCSTCL	FUEL-CL-ST HEAT	0.	1052.	1562.	610.	607.	178.	0.	-1587.	1562. COAL	-25.	0	0.34	0.39	0.39
12 IGBTST	INT-GAS-GT POWR	0.	137.	340.	142.	99.	29.	550.	0.	890. COAL	890.	10	-0.16	0.11	0.69
12 IGBTST	INT-GAS-GT HEAT	0.	586.	1456.	610.	424.	124.	0.	-1015.	1456. COAL	441.	0	0.18	0.29	0.42
13 GTSOAR	GT-HRSG-10 POWR	259.	138.	341.	145.	99.	29.	547.	0.	889. RESIDUAL	889.	0	0.18	0.11	0.69
13 GTSOAR	GT-HRSG-10 HEAT	259.	373.	920.	390.	267.	78.	259.	-524.	1179. RESIDUAL	654.	0	0.29	0.23	0.52
14 GTAC08	GT-HRSG-08 POWR	259.	165.	366.	189.	99.	29.	496.	0.	862. RESIDUAL	862.	0	0.21	0.11	0.71
14 GTAC08	GT-HRSG-08 HEAT	259.	340.	758.	390.	205.	60.	259.	-330.	1017. RESIDUAL	686.	0	0.31	0.20	0.60
15 GTAC12	GT-HRSG-12 POWR	259.	162.	324.	151.	99.	29.	540.	0.	865. RESIDUAL	865.	0	0.21	0.11	0.71
15 GTAC12	GT-HRSG-12 HEAT	259.	419.	840.	390.	256.	75.	259.	-492.	1099. RESIDUAL	607.	0	0.33	0.23	0.56
16 GTAC16	GT-HRSG-16 POWR	259.	159.	306.	132.	99.	29.	562.	0.	868. RESIDUAL	868.	0	0.21	0.11	0.70
16 GTAC16	GT-HRSG-16 HEAT	259.	467.	902.	390.	291.	85.	259.	-601.	1161. RESIDUAL	560.	0	0.34	0.25	0.53
17 GTWC16	GT-HRSG-16 POWR	259.	145.	314.	127.	99.	29.	568.	0.	882. RESIDUAL	882.	0	0.19	0.11	0.69
17 GTWC16	GT-HRSG-16 HEAT	259.	444.	964.	390.	304.	89.	259.	-640.	1223. RESIDUAL	583.	0	0.32	0.25	0.50

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 63

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 26214 MW 29.00 PROCESS MILLIONS BTU/HR 610.0 PROCESS TEMP(F) 366. PRODUCT UNBLEACHED-K HOURS PER YEAR 8400.

POWER TO HEAT RATIO 0.162

WASTE FUEL EQV BTU\*10\*\*6= 259. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL COAL

			WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	AUX COGEN ELECT 10**6 BTU/HR	UTILIT PROCES BOILR 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR		
18	CC1626	GTST-16/26	POWR	259.	143.	259.	79.	99.	29.	625.	0.	884.	RESIDUAL	884.	0	0.19	0.11	0.69
18	CC1626	GTST-16/26	HEAT	259.	706.	1276.	390.	487.	143.	259.	-1214.	1535.	RESIDUAL	321.	0	0.36	0.32	0.40
19	CC1622	GTST-16/22	POWR	259.	150.	262.	88.	99.	29.	614.	0.	877.	RESIDUAL	877.	0	0.20	0.11	0.70
19	CC1622	GTST-16/22	HEAT	259.	666.	1163.	390.	439.	129.	259.	-1062.	1422.	RESIDUAL	361.	0	0.36	0.31	0.43
20	CC1222	GTST-12/22	POWR	259.	152.	261.	88.	99.	29.	614.	0.	875.	RESIDUAL	875.	0	0.20	0.11	0.70
20	CC1222	GTST-12/22	HEAT	259.	670.	1154.	390.	437.	128.	259.	-1056.	1413.	RESIDUAL	357.	0	0.37	0.31	0.43
21	CC0822	GTST-08/22	POWR	259.	162.	277.	111.	99.	29.	587.	0.	864.	RESIDUAL	864.	0	0.21	0.11	0.71
21	CC0822	GTST-08/22	HEAT	259.	572.	975.	390.	348.	102.	259.	-779.	1234.	RESIDUAL	455.	0	0.37	0.28	0.49
22	STIG15	STIG-15-16	POWR	259.	53.	260.	3.	99.	29.	714.	0.	973.	RESIDUAL	973.	0	0.07	0.10	0.63
22	STIG15	STIG-15-16	HEAT	259.	6178.	30000.	390.	11430.	3350.	259.	-35410.	30259.	RESIDUAL	-5151.	0	0.17	0.38	0.02
23	STIG10	STIG-10-16	POWR	259.	77.	276.	37.	99.	29.	675.	0.	950.	RESIDUAL	950.	0	0.10	0.10	0.64
23	STIG10	STIG-10-16	HEAT	259.	818.	2943.	390.	1057.	310.	259.	-2994.	3202.	RESIDUAL	208.	0	0.22	0.33	0.19
24	STIG1S	STIG-1S-16	POWR	259.	87.	295.	62.	99.	29.	644.	0.	940.	RESIDUAL	940.	0	0.11	0.11	0.65
24	STIG1S	STIG-1S-16	HEAT	259.	547.	1850.	390.	620.	182.	259.	-1629.	2109.	RESIDUAL	480.	0	0.23	0.29	0.29
25	DEADV3	DIESEL-ADV	POWR	259.	107.	267.	55.	99.	29.	653.	0.	920.	RESIDUAL	920.	0	0.14	0.11	0.66
25	DEADV3	DIESEL-ADV	HEAT	259.	762.	1903.	390.	706.	207.	259.	-1897.	2161.	RESIDUAL	265.	0	0.29	0.33	0.28
26	DEADV2	DIESEL-ADV	POWR	259.	122.	267.	68.	99.	29.	638.	0.	905.	RESIDUAL	905.	1	0.16	0.11	0.67
26	DEADV2	DIESEL-ADV	HEAT	259.	704.	1535.	390.	570.	167.	259.	-1471.	1794.	RESIDUAL	323.	1	0.31	0.32	0.34
27	DEADV1	DIESEL-ADV	POWR	259.	165.	267.	104.	99.	29.	595.	0.	862.	RESIDUAL	862.	1	0.22	0.11	0.71
27	DEADV1	DIESEL-ADV	HEAT	259.	618.	997.	390.	370.	108.	259.	-847.	1258.	RESIDUAL	409.	1	0.38	0.29	0.49
28	DEHTPM	ADV-DIESEL	POWR	259.	159.	303.	130.	99.	29.	565.	0.	868.	RESIDUAL	868.	0	0.21	0.11	0.70
28	DEHTPM	ADV-DIESEL	HEAT	259.	479.	910.	390.	298.	87.	259.	-621.	1169.	RESIDUAL	548.	0	0.34	0.25	0.52
29	DES0A3	DIESEL-S0A	POWR	259.	90.	274.	47.	99.	29.	663.	0.	937.	DISTILLA	937.	0	0.12	0.11	0.65
29	DES0A3	DIESEL-S0A	HEAT	259.	751.	2281.	390.	823.	241.	259.	-2264.	2540.	DISTILLA	276.	0	0.25	0.32	0.24
29	DES0A3	DIESEL-S0A	POWR	259.	90.	274.	47.	99.	29.	663.	0.	937.	RESIDUAL	937.	0	0.12	0.11	0.65
29	DES0A3	DIESEL-S0A	HEAT	259.	751.	2281.	390.	823.	241.	259.	-2264.	2540.	RESIDUAL	276.	0	0.25	0.32	0.24



I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 26214 MW 29.00 PROCESS MILLIONS BTU/HR 610.0 PROCESS TEMP(F) 366. PRODUCT UNBLEACHED-K HOURS PER YEAR 8400.

POWER TO HEAT RATIO 0.162

WASTE FUEL EQV BTU\*10\*\*6= 259. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL COAL

			WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	AUX COGEN ELECT BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED BTU/HR	NET* TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR		
30	DESOA2	DIESEL-SOA	POWR	259.	106.	274.	60.	99.	29.	647.	0.	921.	DISTILLA	921.	1	0.14	0.11	0.66
30	DESOA2	DIESEL-SOA	HEAT	259.	685.	1773.	390.	640.	188.	259.	-1691.	2032.	DISTILLA	341.	1	0.28	0.32	0.30
30	DESOA2	DIESEL-SOA	POWR	259.	106.	274.	60.	99.	29.	647.	0.	921.	RESIDUAL	921.	1	0.14	0.11	0.66
30	DESOA2	DIESEL-SOA	HEAT	259.	686.	1773.	390.	640.	188.	259.	-1691.	2032.	RESIDUAL	341.	1	0.28	0.32	0.30
31	DESOA1	DIESEL-SOA	POWR	259.	164.	274.	110.	99.	29.	588.	0.	862.	DISTILLA	862.	1	0.21	0.11	0.71
31	DESOA1	DIESEL-SOA	HEAT	259.	583.	973.	390.	351.	103.	259.	-788.	1231.	DISTILLA	443.	1	0.37	0.29	0.50
31	DESOA1	DIESEL-SOA	POWR	259.	164.	274.	110.	99.	29.	588.	0.	862.	RESIDUAL	862.	1	0.21	0.11	0.71
31	DESOA1	DIESEL-SOA	HEAT	259.	583.	973.	390.	351.	103.	259.	-788.	1231.	RESIDUAL	443.	1	0.37	0.29	0.50
32	GTSOAD	GT-HRSG-10	POWR	259.	154.	339.	156.	59.	29.	534.	0.	873.	DISTILLA	873.	0	0.20	0.11	0.70
32	GTSOAD	GT-HRSG-10	HEAT	259.	385.	847.	390.	247.	72.	259.	-463.	1106.	DISTILLA	642.	0	0.31	0.22	0.55
33	GTRA08	GT-85RE-08	POWR	259.	142.	277.	93.	99.	29.	608.	0.	985.	DISTILLA	885.	0	0.18	0.11	0.69
33	GTRA08	GT-85RE-08	HEAT	259.	593.	1160.	390.	414.	121.	259.	-985.	1419.	DISTILLA	434.	0	0.34	0.29	0.43
34	GTRA12	GT-85RE-12	POWR	259.	145.	276.	96.	99.	29.	605.	0.	881.	DISTILLA	881.	0	0.19	0.11	0.69
34	GTRA12	GT-85RE-12	HEAT	259.	593.	1127.	390.	403.	118.	259.	-951.	1385.	DISTILLA	434.	0	0.34	0.29	0.44
35	GTRA16	GT-85RE-16	POWR	259.	147.	284.	103.	99.	29.	597.	0.	880.	DISTILLA	880.	0	0.19	0.11	0.69
35	GTRA16	GT-85RE-16	HEAT	259.	556.	1076.	390.	376.	110.	259.	-865.	1335.	DISTILLA	471.	0	0.34	0.28	0.46
36	GTR208	GT-60RE-08	POWR	259.	146.	309.	124.	99.	29.	571.	0.	881.	DISTILLA	881.	0	0.19	0.11	0.69
36	GTR208	GT-60RE-08	HEAT	259.	459.	970.	390.	310.	91.	259.	-661.	1229.	DISTILLA	568.	0	0.32	0.25	0.50
37	GTR212	GT-60RE-12	POWR	259.	146.	300.	116.	99.	29.	581.	0.	881.	DISTILLA	881.	0	0.19	0.11	0.69
37	GTR212	GT-60RE-12	HEAT	259.	490.	1009.	390.	333.	98.	259.	-731.	1268.	DISTILLA	537.	0	0.33	0.26	0.48
38	GTR216	GT-60RE-16	POWR	259.	149.	294.	113.	99.	29.	585.	0.	878.	DISTILLA	878.	0	0.19	0.11	0.69
38	GTR216	GT-60RE-16	HEAT	259.	513.	1013.	390.	341.	100.	259.	-757.	1272.	DISTILLA	514.	0	0.34	0.27	0.48
39	GTRW08	GT-85RE-08	POWR	259.	119.	282.	78.	99.	29.	626.	0.	908.	DISTILLA	908.	0	0.16	0.11	0.67
39	GTRW08	GT-85RE-08	HEAT	259.	595.	1406.	390.	494.	145.	259.	-1233.	1665.	DISTILLA	432.	0	0.30	0.30	0.37
40	GTRW12	GT-85RE-12	POWR	259.	128.	272.	77.	99.	29.	627.	0.	899.	DISTILLA	899.	0	0.17	0.11	0.68
40	GTRW12	GT-85RE-12	HEAT	259.	648.	1376.	390.	501.	147.	259.	-1256.	1635.	DISTILLA	379.	0	0.32	0.31	0.37

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 65

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 26214 MW 29.00 PROCESS MILLIONS BTU/HR 610.0 PROCESS TEMP(F) 366. PRODUCT UNBLEACHED-K HOURS PER YEAR 8400.

POWER TO HEAT RATIO 0.162

UTILITY FUEL COAL

WASTE FUEL EQV BTU\*10\*\*6= 259. HOT WATER BTU\*10\*\*6= 0.

			WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET* TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
41	GTRW16	GT-85RE-16	POWR	259.	130.	277.	83.	99.	29.	620.	0.	897.	DISTILLA	897.	0	0.17	0.11	0.68
41	GTRW16	GT-85RE-16	HEAT	259.	609.	1297.	390.	463.	136.	259.	-1138.	1556.	DISTILLA	418.	0	0.32	0.30	0.39
42	GTR308	GT-60RE-08	POWR	259.	110.	319.	102.	99.	29.	597.	0.	916.	DISTILLA	916.	0	0.14	0.11	0.67
42	GTR308	GT-60RE-08	HEAT	259.	421.	1216.	390.	377.	110.	259.	-869.	1475.	DISTILLA	606.	0	0.26	0.26	0.41
43	GTR312	GT-60RE-12	POWR	259.	133.	289.	96.	99.	29.	605.	0.	894.	DISTILLA	894.	0	0.17	0.11	0.68
43	GTR312	GT-60RE-12	HEAT	259.	540.	1177.	390.	402.	118.	259.	-948.	1435.	DISTILLA	487.	0	0.31	0.28	0.42
44	GTR316	GT-60RE-16	POWR	259.	132.	292.	97.	99.	29.	603.	0.	895.	DISTILLA	895.	0	0.17	0.11	0.68
44	GTR316	GT-60RE-16	HEAT	259.	528.	1169.	390.	396.	116.	259.	-929.	1427.	DISTILLA	499.	0	0.31	0.28	0.43
45	FCPADS	FUEL-CL-PH	POWR	259.	101.	260.	44.	99.	29.	666.	0.	928.	DISTILLA	928.	0	0.13	0.11	0.66
45	FCPADS	FUEL-CL-PH	HEAT	259.	889.	2294.	390.	872.	255.	259.	-2415.	2553.	DISTILLA	138.	0	0.28	0.34	0.24
46	FCMCDS	FUEL-CL-MO	POWR	259.	135.	240.	56.	99.	29.	652.	0.	892.	DISTILLA	892.	0	0.18	0.11	0.68
46	FCMCDS	FUEL-CL-MO	HEAT	259.	940.	1674.	390.	690.	202.	259.	-1846.	1933.	DISTILLA	87.	0	0.36	0.36	0.32

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 66

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 26216 MW 20.00 PROCESS MILLIONS BTU/HR 307.0 PROCESS TEMP(F) 366. PRODUCT NEUT-SU-SCHE HOURS PER YEAR 8400.

		POWER TO HEAT RATIO 0.222																
UTILITY FUEL		COAL		WASTE FUEL EQV BTU*10**6= 0. HOT WATER BTU*10**6= 0.														
		WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED-NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR		
0	ONOCGN N O C O G O N	0.	0.	0.	0.	0.	0.	361.	213.	361.	COAL-FGD	574.	0	0.	0.12	0.53		
1	STM141 STM-TURB-1 POWR	0.	96.	479.	339.	68.	20.	-37.	0.	479.	RESIDUAL	479.	0	0.17	0.14	0.64		
1	STM141 STM-TURB-1 HEAT	0.	121.	434.	307.	62.	18.	0.	20.	434.	RESIDUAL	454.	0	0.21	0.14	0.68		
1	STM141 STM-TURB-1 POWR	0.	96.	479.	339.	68.	20.	-37.	0.	479.	COAL-FGD	479.	0	0.17	0.14	0.64		
1	STM141 STM-TURB-1 HEAT	0.	121.	434.	307.	62.	18.	0.	20.	434.	COAL-FGD	454.	0	0.21	0.14	0.68		
1	STM141 STM-TURB-1 POWR	0.	96.	479.	339.	68.	20.	-37.	0.	479.	COAL-AFB	479.	0	0.17	0.14	0.64		
1	STM141 STM-TURB-1 HEAT	0.	121.	434.	307.	62.	18.	0.	20.	434.	COAL-AFB	454.	0	0.21	0.14	0.68		
2	STM088 STM-TURB-8 POWR	0.	-58.	633.	470.	68.	20.	-191.	0.	633.	RESIDUAL	633.	0	-0.10	0.11	0.49		
2	STM088 STM-TURB-8 HEAT	0.	87.	414.	307.	45.	13.	0.	74.	414.	RESIDUAL	487.	0	0.15	0.09	0.63		
2	STM088 STM-TURB-8 POWR	0.	-58.	633.	470.	68.	20.	-191.	0.	633.	COAL-FGD	633.	0	-0.10	0.11	0.49		
2	STM088 STM-TURB-8 HEAT	0.	87.	414.	307.	45.	13.	0.	74.	414.	COAL-FGD	487.	0	0.15	0.09	0.63		
2	STM088 STM-TURB-8 POWR	0.	-58.	633.	470.	68.	20.	-191.	0.	633.	COAL-AFB	633.	0	-0.10	0.11	0.49		
2	STM088 STM-TURB-8 HEAT	0.	87.	414.	307.	45.	13.	0.	74.	414.	COAL-AFB	487.	0	0.15	0.09	0.63		
3	PFBSTM PFB-STMTB- POWR	0.	130.	326.	207.	68.	20.	118.	0.	444.	COAL-PFB	444.	0	0.23	0.15	0.69		
3	PFBSTM PFB-STMTB- HEAT	0.	193.	485.	307.	101.	30.	0.	-103.	485.	COAL-PFB	381.	0	0.29	0.21	0.63		
4	TISTMT TI-STMTB-1 POWR	0.	131.	264.	154.	68.	20.	179.	0.	444.	RESIDUAL	444.	0	0.23	0.15	0.69		
4	TISTMT TI-STMTB-1 HEAT	0.	260.	525.	307.	136.	40.	0.	-211.	525.	RESIDUAL	314.	0	0.33	0.26	0.58		
4	TISTMT TI-STMTB-1 POWR	0.	131.	264.	154.	68.	20.	179.	0.	444.	COAL	444.	0	0.23	0.15	0.69		
4	TISTMT TI-STMTB-1 HEAT	0.	260.	525.	307.	136.	40.	0.	-211.	525.	COAL	314.	0	0.33	0.26	0.58		
5	TIHRSG THERMIONIC POWR	0.	89.	485.	313.	68.	20.	-7.	0.	485.	RESIDUAL	485.	0	0.16	0.14	0.63		
5	TIHRSG THERMIONIC HEAT	0.	95.	475.	307.	67.	20.	0.	4.	475.	RESIDUAL	480.	0	0.17	0.14	0.64		
5	TIHRSG THERMIONIC POWR	0.	89.	485.	313.	68.	20.	-7.	0.	485.	COAL	485.	0	0.16	0.14	0.63		
5	TIHRSG THERMIONIC HEAT	0.	95.	475.	307.	67.	20.	0.	4.	475.	COAL	480.	0	0.17	0.14	0.64		
6	STIRL STIRLING-1 POWR	0.	94.	271.	129.	68.	20.	209.	0.	480.	DISTILLA	480.	0	0.16	0.14	0.64		
6	STIRL STIRLING-1 HEAT	0.	224.	643.	307.	162.	48.	0.	-293.	643.	DISTILLA	350.	0	0.26	0.25	0.48		

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 26216 MW 20.00 PROCESS MILLIONS BTU/HR 307.0 PROCESS TEMP(F) 366. PRODUCT NEUT-SU-SCHE HOURS PER YEAR 8400.

UTILITY FUEL		COAL	POWER TO HEAT RATIO 0.222										WASTE FUEL EQV BTU*10**6= 0. HOT WATER BTU*10**6= 0.			
WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET+ TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR		
6 STIRL	STIRLING-1 POWR	0.	94.	271.	129.	68.	20.	209.	0.	480.	RESIDUAL	480.	0	0.16	0.14	0.64
6 STIRL	STIRLING-1 HEAT	0.	224.	643.	307.	162.	48.	0.	-293.	643.	RESIDUAL	350.	0	0.26	0.25	0.48
6 STIRL	STIRLING-1 POWR	0.	94.	271.	129.	68.	20.	209.	0.	480.	COAL	480.	0	0.16	0.14	0.64
6 STIRL	STIRLING-1 HEAT	0.	224.	643.	307.	162.	48.	0.	-293.	643.	COAL	350.	0	0.26	0.25	0.48
7 HEGT85	HELIUM-GT- POWR	0.	30.	213.	25.	68.	20.	332.	0.	544.	COAL-AFB	544.	10	0.05	0.13	0.56
7 HEGT85	HELIUM-GT- HEAT	0.	369.	2597.	307.	834.	244.	0.	-2391.	2597.	COAL-AFB	205.	0	0.12	0.32	0.12
8 HEGT60	HELIUM-GT- POWR	0.	40.	263.	77.	68.	20.	271.	0.	535.	COAL-AFB	535.	10	0.07	0.13	0.57
8 HEGT60	HELIUM-GT- HEAT	0.	160.	1056.	307.	274.	80.	0.	-642.	1056.	COAL-AFB	415.	0	0.13	0.26	0.29
9 HEGT00	HELIUM-GT- POWR	0.	48.	388.	189.	68.	20.	138.	0.	526.	COAL-AFB	526.	10	0.08	0.13	0.58
9 HEGT00	HELIUM-GT- HEAT	0.	78.	629.	307.	111.	32.	0.	-132.	629.	COAL-AFB	496.	10	0.11	0.18	0.49
10 FCMCCL	FUEL-CL-MO POWR	0.	114.	224.	106.	68.	20.	236.	0.	461.	COAL	461.	10	0.20	0.15	0.67
10 FCMCCL	FUEL-CL-MO HEAT	0.	329.	649.	307.	197.	58.	0.	-403.	649.	COAL	246.	10	0.34	0.30	0.47
11 FCSTCL	FUEL-CL-ST POWR	0.	118.	178.	71.	68.	20.	278.	0.	456.	COAL	456.	10	0.21	0.15	0.67
11 FCSTCL	FUEL-CL-ST HEAT	0.	514.	775.	307.	297.	87.	0.	-715.	775.	COAL	60.	10	0.40	0.38	0.40
12 IGGTST	INT-GAS-GT POWR	0.	94.	239.	102.	68.	20.	242.	0.	481.	COAL	481.	10	0.16	0.14	0.64
12 IGGTST	INT-GAS-GT HEAT	0.	283.	723.	307.	206.	60.	0.	-431.	723.	COAL	292.	10	0.28	0.29	0.42
13 GTSOAR	GT-HRSG-10 POWR	0.	95.	235.	100.	68.	20.	244.	0.	479.	RESIDUAL	479.	0	0.17	0.14	0.64
13 GTSOAR	GT-HRSG-10 HEAT	0.	293.	724.	307.	210.	62.	0.	-443.	724.	RESIDUAL	281.	0	0.29	0.29	0.42
14 GTAC08	GT-HRSG-08 POWR	0.	114.	253.	130.	68.	20.	208.	0.	461.	RESIDUAL	461.	0	0.20	0.15	0.67
14 GTAC08	GT-HRSG-08 HEAT	0.	268.	597.	307.	161.	47.	0.	-290.	597.	RESIDUAL	306.	0	0.31	0.27	0.51
15 GTAC12	GT-HRSG-12 POWR	0.	112.	224.	104.	68.	20.	239.	0.	463.	RESIDUAL	463.	0	0.19	0.15	0.66
15 GTAC12	GT-HRSG-12 HEAT	0.	330.	661.	307.	202.	59.	0.	-417.	661.	RESIDUAL	244.	0	0.33	0.31	0.46
16 GTAC16	GT-HRSG-16 POWR	0.	109.	211.	91.	68.	20.	254.	0.	465.	RESIDUAL	465.	0	0.19	0.15	0.66
16 GTAC16	GT-HRSG-16 HEAT	0.	368.	710.	307.	229.	67.	0.	-503.	710.	RESIDUAL	207.	0	0.34	0.32	0.43
17 GTWC16	GT-HRSG-16 POWR	0.	100.	217.	88.	68.	20.	258.	0.	475.	RESIDUAL	475.	0	0.17	0.14	0.65
17 GTWC16	GT-HRSG-16 HEAT	0.	349.	759.	307.	239.	70.	0.	-534.	759.	RESIDUAL	225.	0	0.32	0.32	0.40

HONEYWELL PAGE PRINTING SYSTEM- P1185-02

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 68

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 26216 MW 20.00 PROCESS MILLIONS BTU/HR 307.0 PROCESS TEMP(F) 366. PRODUCT NEUT-SU-SCHE HOURS PER YEAR 8400.

POWER TO HEAT RATIO 0.222  
WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

	UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
18	CC1626	GTST-16/26	POWR	0.	98.	181.	56.	68.	20.	295.	0.	476.	RESIDUAL	476.	0	0.17	0.14	0.64
18	CC1626	GTST-16/26	HEAT	0.	540.	991.	307.	374.	110.	0.	-956.	991.	RESIDUAL	35.	0	0.35	0.38	0.31
19	CC1622	GTST-16/22	POWR	0.	103.	183.	62.	68.	20.	288.	0.	471.	RESIDUAL	471.	10	0.18	0.14	0.65
19	CC1622	GTST-16/22	HEAT	0.	509.	904.	307.	337.	99.	0.	-839.	904.	RESIDUAL	65.	0	0.36	0.37	0.34
20	CC1222	GTST-12/22	POWR	0.	104.	183.	63.	68.	20.	288.	0.	470.	RESIDUAL	470.	0	0.18	0.15	0.65
20	CC1222	GTST-12/22	HEAT	0.	512.	896.	307.	335.	98.	0.	-833.	896.	RESIDUAL	63.	0	0.36	0.37	0.34
21	CC0822	GTST-08/22	POWR	0.	112.	194.	79.	68.	20.	269.	0.	463.	RESIDUAL	463.	0	0.19	0.15	0.66
21	CC0822	GTST-08/22	HEAT	0.	436.	757.	307.	266.	78.	0.	-619.	757.	RESIDUAL	139.	0	0.37	0.35	0.41
22	STIG15	STIG-15-16	POWR	0.	37.	179.	2.	68.	20.	358.	0.	538.	RESIDUAL	538.	10	0.06	0.13	0.57
22	STIG15	STIG-15-16	HEAT	0.	4863.	23615.	307.	8997.	2637.	0.	-27904.	23615.	RESIDUAL	-4288.	0	0.17	0.38	0.01
23	STIG10	STIG-10-16	POWR	0.	53.	190.	25.	68.	20.	332.	0.	522.	RESIDUAL	522.	0	0.09	0.13	0.59
23	STIG10	STIG-10-16	HEAT	0.	644.	2317.	307.	832.	244.	0.	-2387.	2317.	RESIDUAL	-70.	0	0.22	0.36	0.13
24	STIG1S	STIG-1S-16	POWR	0.	60.	204.	43.	68.	20.	311.	0.	514.	RESIDUAL	514.	0	0.10	0.13	0.60
24	STIG1S	STIG-1S-16	HEAT	0.	430.	1456.	307.	488.	143.	0.	-1312.	1456.	RESIDUAL	144.	0	0.23	0.34	0.21
25	DEADV3	DIESEL-ADV	POWR	0.	74.	184.	38.	68.	20.	317.	0.	501.	RESIDUAL	501.	0	0.13	0.14	0.61
25	DEADV3	DIESEL-ADV	HEAT	0.	600.	1498.	307.	556.	163.	0.	-1523.	1498.	RESIDUAL	-25.	0	0.29	0.37	0.20
26	DEADV2	DIESEL-ADV	POWR	0.	84.	184.	47.	68.	20.	306.	0.	490.	RESIDUAL	490.	1	0.15	0.14	0.63
26	DEADV2	DIESEL-ADV	HEAT	0.	554.	1209.	307.	448.	131.	0.	-1188.	1209.	RESIDUAL	21.	1	0.31	0.37	0.25
27	DEADV1	DIESEL-ADV	POWR	0.	114.	184.	72.	68.	20.	277.	0.	461.	RESIDUAL	461.	1	0.20	0.15	0.67
27	DEADV1	DIESEL-ADV	HEAT	0.	486.	785.	307.	291.	85.	0.	-697.	785.	RESIDUAL	88.	1	0.38	0.37	0.39
28	DEHTPM	ADV-DIESEL	POWR	0.	110.	209.	89.	68.	20.	256.	0.	465.	RESIDUAL	465.	0	0.19	0.15	0.66
28	DEHTPM	ADV-DIESEL	HEAT	0.	377.	717.	307.	234.	69.	0.	-519.	717.	RESIDUAL	198.	0	0.34	0.33	0.43
29	DES0A3	DIESEL-S0A	POWR	0.	62.	189.	32.	68.	20.	323.	0.	512.	DISTILLA	512.	0	0.11	0.13	0.60
29	DES0A3	DIESEL-S0A	HEAT	0.	591.	1796.	307.	648.	190.	0.	-1812.	1796.	DISTILLA	-17.	0	0.25	0.36	0.17
29	DES0A3	DIESEL-S0A	POWR	0.	62.	189.	32.	68.	20.	323.	0.	512.	RESIDUAL	512.	0	0.11	0.13	0.60
29	DES0A3	DIESEL-S0A	HEAT	0.	591.	1796.	307.	648.	190.	0.	-1812.	1796.	RESIDUAL	-17.	0	0.25	0.36	0.17

DATE 06/06/79

I&SE PEQ ADV DESIGN ENGR

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 69

INDUSTRY 26216 MW 20.00 PROCESS MILLIONS BTU/HR 307.0 PROCESS TEMP(F) 366. PRODUCT NEUT-SU-SCHE HOURS PER YEAR 8400.

UTILITY FUEL COAL

POWER TO HEAT RATIO 0.222

WASTE FUEL EGV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN ELECT 10**6 BTU/HR	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	UTILIT SITE USED 10**6 BTU/HR	TOTAL FUEL USED 10**6 BTU/HR	NET= TOTAL UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	
30 DES0A2 DIESEL-S0A POWR	0.	73.	189.	42.	68.	20.	312.	0.	501.	501.	501.	1	0.13	0.14	0.61
30 DES0A2 DIESEL-S0A HEAT	0.	540.	1395.	307.	504.	148.	0.	-1361.	1395.	34.	34.	1	0.28	0.36	0.22
30 DES0A2 DIESEL-S0A POWR	0.	73.	189.	42.	68.	20.	312.	0.	501.	501.	501.	1	0.13	0.14	0.61
30 DES0A2 DIESEL-S0A HEAT	0.	540.	1395.	307.	504.	148.	0.	-1361.	1395.	34.	34.	1	0.28	0.36	0.22
31 DES0A1 DIESEL-S0A POWR	0.	113.	189.	76.	68.	20.	272.	0.	461.	461.	461.	1	0.20	0.15	0.67
31 DES0A1 DIESEL-S0A HEAT	0.	459.	766.	307.	276.	81.	0.	-650.	766.	115.	115.	1	0.37	0.36	0.40
31 DES0A1 DIESEL-S0A POWR	0.	113.	189.	76.	68.	20.	272.	0.	461.	461.	461.	1	0.20	0.15	0.67
31 DES0A1 DIESEL-S0A HEAT	0.	459.	766.	307.	276.	81.	0.	-650.	766.	115.	115.	1	0.37	0.36	0.40
32 GTS0AD GT-HRSG-10 POWR	0.	106.	234.	108.	68.	20.	235.	0.	468.	468.	468.	0	0.18	0.15	0.66
32 GTS0AD GT-HRSG-10 HEAT	0.	303.	667.	307.	195.	57.	0.	-395.	667.	272.	272.	0	0.31	0.29	0.46
33 GTRA08 GT-85RE-08 POWR	0.	98.	191.	64.	68.	20.	286.	0.	477.	477.	477.	0	0.17	0.14	0.64
33 GTRA08 GT-85RE-08 HEAT	0.	467.	913.	307.	325.	96.	0.	-805.	913.	108.	108.	0	0.34	0.36	0.34
34 GTRA12 GT-85RE-12 POWR	0.	100.	191.	66.	68.	20.	284.	0.	474.	474.	474.	0	0.17	0.14	0.65
34 GTRA12 GT-85RE-12 HEAT	0.	466.	887.	307.	317.	93.	0.	-779.	887.	108.	108.	0	0.34	0.36	0.35
35 GTRA16 GT-85RE-16 POWR	0.	101.	196.	71.	68.	20.	278.	0.	473.	473.	473.	0	0.18	0.14	0.65
35 GTRA16 GT-85RE-16 HEAT	0.	438.	847.	307.	296.	87.	0.	-711.	847.	136.	136.	0	0.34	0.35	0.36
36 GTR208 GT-60RE-08 POWR	0.	101.	213.	86.	68.	20.	260.	0.	474.	474.	474.	0	0.18	0.14	0.65
36 GTR208 GT-60RE-08 HEAT	0.	361.	764.	307.	244.	72.	0.	-550.	764.	213.	213.	0	0.32	0.32	0.40
37 GTR212 GT-60RE-12 POWR	0.	101.	207.	80.	68.	20.	267.	0.	474.	474.	474.	0	0.17	0.14	0.65
37 GTR212 GT-60RE-12 HEAT	0.	386.	794.	307.	262.	77.	0.	-606.	794.	188.	188.	0	0.33	0.33	0.39
38 GTR216 GT-60RE-16 POWR	0.	102.	202.	78.	68.	20.	269.	0.	472.	472.	472.	0	0.18	0.14	0.65
38 GTR216 GT-60RE-16 HEAT	0.	404.	797.	307.	269.	79.	0.	-626.	797.	171.	171.	0	0.34	0.34	0.39
39 GTRW08 GT-85RE-08 POWR	0.	82.	194.	54.	68.	20.	298.	0.	492.	492.	492.	0	0.14	0.14	0.62
39 GTRW08 GT-85RE-08 HEAT	0.	468.	1107.	307.	389.	114.	0.	-1001.	1107.	106.	106.	0	0.30	0.35	0.28
40 GTRW12 GT-85RE-12 POWR	0.	88.	187.	53.	68.	20.	299.	0.	486.	486.	486.	0	0.15	0.14	0.63
40 GTRW12 GT-85RE-12 HEAT	0.	510.	1083.	307.	394.	116.	0.	-1019.	1083.	64.	64.	0	0.32	0.36	0.28

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 70

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 26216 MW 20.00 PROCESS MILLIONS BTU/HR 307.0 PROCESS TEMP(F) 366. PRODUCT NEUT-SU-SCHE HOURS PER YEAR 8400.

POWER TO HEAT RATIO 0.222

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL COAL

	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41 GTRW16 GT-85RE-16 POWR	0.	90.	191.	57.	68.	20.	294.	0.	485.DISTILLA	485.	0	0.16	0.14	0.63	
41 GTRW16 GT-85RE-16 HEAT	0.	479.	1021.	307.	365.	107.	0.	-926.	1021.DISTILLA	95.	0	0.32	0.36	0.30	
42 GTR308 GT-60RE-08 POWR	0.	76.	220.	71.	68.	20.	278.	0.	498.DISTILLA	498.	0	0.13	0.14	0.62	
42 GTR308 GT-60RE-08 HEAT	0.	331.	957.	307.	297.	87.	0.	-714.	957.DISTILLA	243.	0	0.26	0.31	0.32	
43 GTR312 GT-60RE-12 POWR	0.	92.	200.	66.	68.	20.	283.	0.	483.DISTILLA	483.	0	0.16	0.14	0.64	
43 GTR312 GT-60RE-12 HEAT	0.	425.	926.	307.	317.	93.	0.	-777.	926.DISTILLA	150.	0	0.31	0.34	0.33	
44 GTR316 GT-60RE-16 POWR	0.	91.	201.	67.	68.	20.	282.	0.	483.DISTILLA	483.	0	0.16	0.14	0.64	
44 GTR316 GT-60RE-16 HEAT	0.	416.	920.	307.	312.	91.	0.	-761.	920.DISTILLA	159.	0	0.31	0.34	0.33	
45 FCPADS FUEL-CL-PH POWR	0.	70.	180.	31.	68.	20.	325.	0.	505.DISTILLA	505.	0	0.12	0.14	0.61	
45 FCPADS FUEL-CL-PH HEAT	0.	700.	1806.	307.	686.	201.	0.	-1931.	1806.DISTILLA	-125.	0	0.28	0.38	0.17	
46 FCMCDS FUEL-CL-MO POWR	0.	93.	166.	39.	68.	20.	316.	0.	481.DISTILLA	481.	0	0.16	0.14	0.64	
46 FCMCDS FUEL-CL-MO HEAT	0.	740.	1318.	307.	543.	159.	0.	-1483.	1318.DISTILLA	-165.	0	0.36	0.41	0.23	

HONEYWELL PAGE PRINTING SYSTEM- P1188-02

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 26217 MW 31.30 PROCESS MILLIONS BTU/HR 183.0 PROCESS TEMP(F) 366. PRODUCT THERMO-MECH- HOURS PER YEAR 8400.

UTILITY FUEL		COAL		POWER TO HEAT RATIO 0.584										WASTE FUEL EQV BTU*10**6= 0.		HOT WATER BTU*10**6= 0.	
WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN PROCES MW ELECT	AUX BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR			
0 ONOCGN N O C O G O N	0.	0.	0.	0.	0.	0.	215.	334.	215.	COAL-FGD	549.	0	0.	0.19	0.33		
1 STM141 STM-TURB-1 POWR	0.	-262.	811.	583.	107.	31.	-470.	0.	811.	RESIDUAL	811.	0	-0.48	0.13	0.23		
1 STM141 STM-TURB-1 HEAT	0.	65.	255.	183.	34.	10.	0.	229.	255.	RESIDUAL	484.	0	0.12	0.07	0.38		
1 STM141 STM-TURB-1 POWR	0.	-262.	811.	583.	107.	31.	-470.	0.	811.	COAL-FGD	811.	0	-0.48	0.13	0.23		
1 STM141 STM-TURB-1 HEAT	0.	65.	255.	183.	34.	10.	0.	229.	255.	COAL-FGD	484.	0	0.12	0.07	0.38		
1 STM141 STM-TURB-1 POWR	0.	-262.	811.	583.	107.	31.	-470.	0.	811.	COAL-AFB	811.	0	-0.48	0.13	0.23		
1 STM141 STM-TURB-1 HEAT	0.	65.	255.	183.	34.	10.	0.	229.	255.	COAL-AFB	484.	0	0.12	0.07	0.38		
2 STM088 STM-TURB-8 POWR	0.	-555.	1104.	832.	107.	31.	-763.	0.	1104.	RESIDUAL	1104.	0	-1.01	0.10	0.17		
2 STM088 STM-TURB-8 HEAT	0.	46.	243.	183.	23.	7.	0.	260.	243.	RESIDUAL	503.	0	0.08	0.05	0.36		
2 STM088 STM-TURB-8 POWR	0.	-555.	1104.	832.	107.	31.	-763.	0.	1104.	COAL-FGD	1104.	0	-1.01	0.10	0.17		
2 STM088 STM-TURB-8 HEAT	0.	46.	243.	183.	23.	7.	0.	260.	243.	COAL-FGD	503.	0	0.08	0.05	0.36		
2 STM088 STM-TURB-8 POWR	0.	-555.	1104.	832.	107.	31.	-763.	0.	1104.	COAL-AFB	1104.	0	-1.01	0.10	0.17		
2 STM088 STM-TURB-8 HEAT	0.	46.	243.	183.	23.	7.	0.	260.	243.	COAL-AFB	503.	0	0.08	0.05	0.36		
3 PFBSTM PFB-STMTB- POWR	0.	14.	535.	344.	107.	31.	-189.	0.	535.	COAL-PFB	535.	0	0.02	0.20	0.34		
3 PFBSTM PFB-STMTB- HEAT	0.	108.	285.	183.	57.	17.	0.	156.	285.	COAL-PFB	441.	0	0.20	0.13	0.41		
4 T1STMT TI-STMTB-1 POWR	0.	121.	429.	254.	107.	31.	-84.	0.	429.	RESIDUAL	429.	0	0.22	0.25	0.43		
4 T1STMT TI-STMTB-1 HEAT	0.	147.	308.	183.	77.	23.	0.	94.	308.	RESIDUAL	402.	0	0.27	0.19	0.46		
4 T1STMT TI-STMTB-1 POWR	0.	121.	429.	254.	107.	31.	-84.	0.	429.	COAL	429.	0	0.22	0.25	0.43		
4 T1STMT TI-STMTB-1 HEAT	0.	147.	308.	183.	77.	23.	0.	94.	308.	COAL	402.	0	0.27	0.19	0.46		
5 TIHRSG THERMIONIC POWR	0.	-210.	759.	490.	107.	31.	-361.	0.	759.	RESIDUAL	759.	0	-0.38	0.14	0.24		
5 TIHRSG THERMIONIC HEAT	0.	57.	283.	183.	40.	12.	0.	209.	283.	RESIDUAL	493.	0	0.10	0.08	0.37		
5 TIHRSG THERMIONIC POWR	0.	-210.	759.	490.	107.	31.	-361.	0.	759.	COAL	759.	0	-0.38	0.14	0.24		
5 TIHRSG THERMIONIC HEAT	0.	57.	283.	183.	40.	12.	0.	209.	283.	COAL	493.	0	0.10	0.08	0.37		
6 STIRL STIRLING-1 POWR	0.	125.	424.	202.	107.	31.	-23.	0.	424.	DISTILLA	424.	0	0.23	0.25	0.43		
6 STIRL STIRLING-1 HEAT	0.	134.	384.	183.	97.	28.	0.	32.	384.	DISTILLA	415.	0	0.24	0.23	0.44		

HONEYWELL PAGE PRINTING SYSTEM- P1188-02



I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 26217 MW 31.30 PROCESS MILLIONS BTU/HR 183.0 PROCESS TEMP(F) 366. PRODUCT THERMO-MECH- HOURS PER YEAR 8400.

POWER TO HEAT RATIO 0.584

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= FUEL NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
6 STIRL	STIRLING-1 POWR	0.	125.	424.	202.	107.	31.	-23.	0.	424.	RESIDUAL	424.	0	0.23	0.25	0.43
6 STIRL	STIRLING-1 HEAT	0.	134.	384.	183.	97.	28.	0.	32.	384.	RESIDUAL	415.	0	0.24	0.23	0.44
6 STIRL	STIRLING-1 POWR	0.	125.	424.	202.	107.	31.	-23.	0.	424.	COAL	424.	0	0.23	0.25	0.43
6 STIRL	STIRLING-1 HEAT	0.	134.	384.	183.	97.	28.	0.	32.	384.	COAL	415.	0	0.24	0.23	0.44
7 HEGT85	HELIUM-GT- POWR	0.	47.	333.	39.	107.	31.	169.	0.	502.	COAL-AFB	502.	10	0.09	0.21	0.36
7 HEGT85	HELIUM-GT- HEAT	0.	220.	1548.	183.	497.	146.	0.	-1219.	1548.	COAL-AFB	329.	0	0.12	0.32	0.12
8 HEGT60	HELIUM-GT- POWR	0.	62.	412.	120.	107.	31.	74.	0.	487.	COAL-AFB	487.	10	0.11	0.22	0.38
8 HEGT60	HELIUM-GT- HEAT	0.	95.	630.	183.	163.	48.	0.	-176.	630.	COAL-AFB	454.	10	0.13	0.26	0.29
9 HEGT00	HELIUM-GT- POWR	0.	-58.	607.	296.	107.	31.	-133.	0.	607.	COAL-AFB	607.	10	-0.11	0.18	0.30
9 HEGT00	HELIUM-GT- HEAT	0.	47.	375.	183.	66.	19.	0.	128.	375.	COAL-AFB	502.	10	0.09	0.13	0.36
10 FCMCCL	FUEL-CL-MO POWR	0.	178.	351.	166.	107.	31.	20.	0.	371.	COAL	371.	10	0.32	0.29	0.49
10 FCMCCL	FUEL-CL-MO HEAT	0.	196.	387.	183.	118.	34.	0.	-34.	387.	COAL	353.	10	0.34	0.30	0.47
11 FCSTCL	FUEL-CL-ST POWR	0.	184.	283.	114.	107.	31.	81.	0.	365.	COAL	365.	10	0.34	0.29	0.50
11 FCSTCL	FUEL-CL-ST HEAT	0.	297.	455.	183.	172.	50.	0.	-203.	455.	COAL	252.	10	0.39	0.38	0.40
12 IGGTST	INT-GAS-GT POWR	0.	145.	383.	165.	107.	31.	21.	0.	404.	COAL	404.	10	0.26	0.26	0.45
12 IGGTST	INT-GAS-GT HEAT	0.	160.	424.	183.	118.	35.	0.	-36.	424.	COAL	389.	10	0.27	0.28	0.43
13 GTSOAR	GT-HRSG-10 POWR	0.	149.	368.	156.	107.	31.	32.	0.	400.	RESIDUAL	400.	0	0.27	0.27	0.46
13 GTSOAR	GT-HRSG-10 HEAT	0.	175.	432.	183.	125.	37.	0.	-57.	432.	RESIDUAL	374.	0	0.29	0.29	0.42
14 GTAC08	GT-HRSG-08 POWR	0.	153.	396.	204.	107.	31.	-24.	0.	396.	RESIDUAL	396.	0	0.28	0.27	0.46
14 GTAC08	GT-HRSG-08 HEAT	0.	160.	356.	183.	96.	28.	0.	34.	356.	RESIDUAL	389.	0	0.29	0.25	0.47
15 GTAC12	GT-HRSG-12 POWR	0.	175.	350.	163.	107.	31.	24.	0.	374.	RESIDUAL	374.	0	0.32	0.29	0.49
15 GTAC12	GT-HRSG-12 HEAT	0.	197.	394.	183.	120.	35.	0.	-42.	394.	RESIDUAL	352.	0	0.33	0.31	0.46
16 GTAC16	GT-HRSG-16 POWR	0.	171.	331.	143.	107.	31.	47.	0.	378.	RESIDUAL	378.	0	0.31	0.28	0.48
16 GTAC16	GT-HRSG-16 HEAT	0.	219.	423.	183.	137.	40.	0.	-93.	423.	RESIDUAL	330.	0	0.34	0.32	0.43
17 GTWC16	GT-HRSG-16 POWR	0.	156.	339.	137.	107.	31.	54.	0.	393.	RESIDUAL	393.	0	0.28	0.27	0.47
17 GTWC16	GT-HRSG-16 HEAT	0.	208.	452.	183.	142.	42.	0.	-111.	452.	RESIDUAL	341.	0	0.32	0.32	0.40

HONEYWELL PAGE PRINTING SYSTEM- P1189-02

ORIGINAL PAGE IS  
OF POOR QUALITY

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 73

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 26217 MW 31.30 PROCESS MILLIONS BTU/HR 183.0 PROCESS TEMP(F) 366. PRODUCT THERMO-MECH- HOURS PER YEAR 8400.

		POWER TO HEAT RATIO 0.584															
UTILITY FUEL		COAL		WASTE FUEL EQV BTU*10**6= 0.										HOT WATER BTU*10**6= 0.			
		WASTE FUEL USED	FUEL SAVED= NO-NET	COGEN FUEL USED	COGEN PROCES HEAT	COGEN PROCES POWER	COGEN MW ELECT	AUX PROCES BOILR	UTILIT FUEL USED	TOTAL FUEL SITE	SITE FUEL USED	NET= TOTAL+ UTILIT	FAIL	FESR	POWER FACTR	HEAT FACTR	
		10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR		10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR					
18	CC1626 GTST-16/26 POWR	0.	153.	286.	90.	107.	31.	109.	0.	396.	RESIDUAL	396.	0	0.28	0.27	0.46	
18	CC1626 GTST-16/26 HEAT	0.	312.	582.	183.	217.	64.	0.	-344.	582.	RESIDUAL	237.	0	0.35	0.37	0.31	
19	CC1622 GTST-16/22 POWR	0.	161.	291.	100.	107.	31.	97.	0.	388.	RESIDUAL	388.	0	0.29	0.28	0.47	
19	CC1622 GTST-16/22 HEAT	0.	294.	531.	183.	195.	57.	0.	-275.	531.	RESIDUAL	255.	0	0.36	0.37	0.34	
20	CC1222 GTST-12/22 POWR	0.	163.	290.	101.	107.	31.	97.	0.	386.	RESIDUAL	386.	0	0.30	0.28	0.47	
20	CC1222 GTST-12/22 HEAT	0.	295.	526.	183.	194.	57.	0.	-272.	526.	RESIDUAL	254.	0	0.36	0.37	0.35	
21	CC0822 GTST-08/22 POWR	0.	174.	309.	127.	107.	31.	65.	0.	375.	RESIDUAL	375.	0	0.32	0.28	0.49	
21	CC0822 GTST-08/22 HEAT	0.	250.	444.	183.	153.	45.	0.	-146.	444.	RESIDUAL	299.	0	0.36	0.35	0.41	
22	STIG15 STIG-15-16 POWR	0.	58.	280.	4.	107.	31.	211.	0.	491.	RESIDUAL	491.	0	0.11	0.22	0.37	
22	STIG15 STIG-15-16 HEAT	0.	2399.	14077.	183.	5363.	1572.	0.	-16427.	14077.	RESIDUAL	-2350.	0	0.17	0.38	0.01	
23	STIG10 STIG-10-16 POWR	0.	83.	297.	39.	107.	31.	169.	0.	466.	RESIDUAL	466.	0	0.15	0.23	0.39	
23	STIG10 STIG-10-16 HEAT	0.	384.	1381.	183.	496.	145.	0.	-1216.	1381.	RESIDUAL	165.	0	0.22	0.36	0.13	
24	STIG1S STIG-1S-16 POWR	0.	94.	319.	67.	107.	31.	136.	0.	455.	RESIDUAL	455.	0	0.17	0.23	0.40	
24	STIG1S STIG-1S-16 HEAT	0.	257.	868.	183.	291.	85.	0.	-576.	868.	RESIDUAL	293.	0	0.23	0.34	0.21	
25	DEADV3 DIESEL-ADV POWR	0.	115.	288.	59.	107.	31.	146.	0.	434.	RESIDUAL	434.	0	0.21	0.25	0.42	
25	DEADV3 DIESEL-ADV HEAT	0.	358.	893.	183.	331.	97.	0.	-701.	893.	RESIDUAL	191.	0	0.29	0.37	0.20	
26	DEADV2 DIESEL-ADV POWR	0.	132.	288.	73.	107.	31.	129.	0.	417.	RESIDUAL	417.	1	0.24	0.26	0.44	
26	DEADV2 DIESEL-ADV HEAT	0.	330.	720.	183.	267.	78.	0.	-502.	720.	RESIDUAL	219.	1	0.31	0.37	0.25	
27	DEADV1 DIESEL-ADV POWR	0.	178.	288.	113.	107.	31.	83.	0.	371.	RESIDUAL	371.	1	0.32	0.29	0.49	
27	DEADV1 DIESEL-ADV HEAT	0.	290.	468.	183.	174.	51.	0.	-209.	468.	RESIDUAL	259.	1	0.38	0.37	0.39	
28	DEHTPM ADV-DIESEL POWR	0.	172.	327.	140.	107.	31.	51.	0.	377.	RESIDUAL	377.	0	0.31	0.28	0.49	
28	DEHTPM ADV-DIESEL HEAT	0.	225.	427.	183.	140.	41.	0.	-103.	427.	RESIDUAL	324.	0	0.34	0.33	0.43	
29	DES0A3 DIESEL-S0A POWR	0.	97.	296.	51.	107.	31.	156.	0.	452.	DISTILLA	452.	0	0.18	0.24	0.41	
29	DES0A3 DIESEL-S0A HEAT	0.	352.	1070.	183.	386.	113.	0.	-874.	1070.	DISTILLA	197.	0	0.25	0.36	0.17	
29	DES0A3 DIESEL-S0A POWR	0.	97.	296.	51.	107.	31.	156.	0.	452.	RESIDUAL	452.	0	0.18	0.24	0.41	
29	DES0A3 DIESEL-S0A HEAT	0.	352.	1070.	183.	386.	113.	0.	-874.	1070.	RESIDUAL	197.	0	0.25	0.36	0.17	

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 26217 MW 31.30 PROCESS MILLIONS BTU/HR 183.0 PROCESS TEMP(F) 366. PRODUCT THERMO-MECH- HOURS PER YEAR 6400.

		POWER TO HEAT RATIO 0.584														
UTILITY FUEL COAL		WASTE FUEL EQV BTU*10**6= 0.										HOT WATER BTU*10**6= 0.				
		WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET* TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
30	DESOA2 DIESEL-SOA POWR	0.	114.	296.	65.	107.	31.	139.	0.	435.	DISTILLA	435.	1	0.21	0.25	0.42
30	DESOA2 DIESEL-SOA HEAT	0.	322.	832.	183.	300.	88.	0.	-605.	832.	DISTILLA	227.	1	0.28	0.36	0.22
30	DESOA2 DIESEL-SOA POWR	0.	114.	296.	65.	107.	31.	139.	0.	435.	RESIDUAL	435.	1	0.21	0.25	0.42
30	DESOA2 DIESEL-SOA HEAT	0.	322.	832.	183.	300.	88.	0.	-605.	832.	RESIDUAL	227.	1	0.28	0.36	0.22
31	DESOA1 DIESEL-SOA POWR	0.	177.	296.	119.	107.	31.	76.	0.	372.	DISTILLA	372.	1	0.32	0.29	0.49
31	DESOA1 DIESEL-SOA HEAT	0.	274.	456.	183.	165.	48.	0.	-181.	456.	DISTILLA	275.	1	0.37	0.36	0.40
31	DESOA1 DIESEL-SOA POWR	0.	177.	296.	119.	107.	31.	76.	0.	372.	RESIDUAL	372.	1	0.32	0.29	0.49
31	DESOA1 DIESEL-SOA HEAT	0.	274.	456.	183.	165.	48.	0.	-181.	456.	RESIDUAL	275.	1	0.37	0.36	0.40
32	GTSOAD GT-HRSG-10 POWR	0.	166.	366.	168.	107.	31.	17.	0.	383.	DISTILLA	383.	0	0.30	0.28	0.48
32	GTSOAD GT-HRSG-10 HEAT	0.	181.	397.	183.	116.	34.	0.	-29.	397.	DISTILLA	369.	0	0.31	0.29	0.46
33	GTRA08 GT-85RE-08 POWR	0.	153.	299.	101.	107.	31.	97.	0.	396.	DISTILLA	396.	0	0.28	0.27	0.46
33	GTRA08 GT-85RE-08 HEAT	0.	278.	544.	183.	194.	57.	0.	-273.	544.	DISTILLA	271.	0	0.34	0.36	0.34
34	GTRA12 GT-85RE-12 POWR	0.	157.	298.	103.	107.	31.	94.	0.	392.	DISTILLA	392.	0	0.29	0.27	0.47
34	GTRA12 GT-85RE-12 HEAT	0.	278.	529.	183.	189.	55.	0.	-258.	529.	DISTILLA	271.	0	0.31	0.36	0.35
35	GTRA16 GT-85RE-16 POWR	0.	158.	306.	111.	107.	31.	85.	0.	391.	DISTILLA	391.	0	0.29	0.27	0.47
35	GTRA16 GT-85RE-16 HEAT	0.	261.	505.	183.	176.	52.	0.	-217.	505.	DISTILLA	288.	0	0.34	0.35	0.36
36	GTR208 GT-60RE-08 POWR	0.	158.	334.	134.	107.	31.	57.	0.	391.	DISTILLA	391.	0	0.29	0.27	0.47
36	GTR208 GT-60RE-08 HEAT	0.	215.	455.	183.	146.	43.	0.	-121.	455.	DISTILLA	334.	0	0.32	0.32	0.40
37	GTR212 GT-60RE-12 POWR	0.	157.	324.	125.	107.	31.	68.	0.	392.	DISTILLA	392.	0	0.29	0.27	0.47
37	GTR212 GT-60RE-12 HEAT	0.	230.	473.	183.	156.	46.	0.	-154.	473.	DISTILLA	319.	0	0.33	0.33	0.39
38	GTR216 GT-60RE-16 POWR	0.	160.	317.	122.	107.	31.	72.	0.	385.	DISTILLA	389.	0	0.29	0.27	0.47
38	GTR216 GT-60RE-16 HEAT	0.	241.	475.	183.	160.	47.	0.	-187.	475.	DISTILLA	308.	0	0.34	0.34	0.39
39	GTRW08 GT-85RE-08 POWR	0.	129.	304.	84.	107.	31.	116.	0.	420.	DISTILLA	420.	0	0.23	0.25	0.44
39	GTRW08 GT-85RE-08 HEAT	0.	279.	660.	183.	232.	68.	0.	-390.	660.	DISTILLA	270.	0	0.30	0.35	0.28
40	GTRW12 GT-85RE-12 POWR	0.	138.	293.	83.	107.	31.	117.	0.	411.	DISTILLA	411.	0	0.25	0.26	0.45
40	GTRW12 GT-85RE-12 HEAT	0.	304.	646.	183.	235.	69.	0.	-401.	646.	DISTILLA	245.	0	0.32	0.36	0.28

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 75

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 26217 MW 31.30 PROCESS MILLIONS BTU/HR 183.0 PROCESS TEMP(F) 366. PRODUCT THERMO-MECH- HOURS PER YEAR 8400.

POWER TO HEAT RATIO 0.584

UTILITY FUEL COAL

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED- NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET* TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41 GTRW18 GT-85RE-16 POWR	0.	140.	299.	90.	107.	31.	110.	0.	409.	DISTILLA	409.	0	0.26	0.26	0.45
41 GTRW16 GT-85RE-16 HEAT	0.	286.	609.	183.	217.	64.	0.	-345.	609.	DISTILLA	263.	0	0.32	0.36	0.30
42 GTR308 GT-60RE-08 POWR	0.	119.	345.	111.	107.	31.	85.	0.	430.	DISTILLA	430.	0	0.22	0.25	0.43
42 GTR308 GT-60RE-08 HEAT	0.	197.	570.	183.	177.	52.	0.	-219.	570.	DISTILLA	352.	0	0.26	0.31	0.32
43 GTR312 GT-60RE-12 POWR	0.	143.	312.	103.	107.	31.	94.	0.	406.	DISTILLA	406.	0	0.26	0.26	0.45
43 GTR312 GT-60RE-12 HEAT	0.	253.	552.	183.	189.	55.	0.	-256.	552.	DISTILLA	296.	0	0.31	0.34	0.33
44 GTR316 GT-60RE-16 POWR	0.	142.	315.	105.	107.	31.	92.	0.	407.	DISTILLA	407.	0	0.26	0.26	0.45
44 GTR316 GT-60RE-16 HEAT	0.	248.	548.	183.	186.	54.	0.	-247.	548.	DISTILLA	301.	0	0.31	0.34	0.33
45 FCPADS FUEL-CL-PH POWR	0.	109.	281.	48.	107.	31.	159.	0.	440.	DISTILLA	440.	0	0.20	0.24	0.42
45 FCPADS FUEL-CL-PH HEAT	0.	417.	1076.	183.	409.	120.	0.	-945.	1076.	DISTILLA	132.	0	0.28	0.38	0.17
46 FCMCDS FUEL-CL-MO POWR	0.	146.	259.	60.	107.	31.	144.	0.	403.	DISTILLA	403.	0	0.27	0.26	0.45
46 FCMCDS FUEL-CL-MO HEAT	0.	441.	785.	183.	324.	95.	0.	-677.	785.	DISTILLA	108.	0	0.36	0.41	0.23

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 76

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 26218 MW 15.00 PROCESS MILLIONS BTU/HR 244.0 PROCESS TEMP(F) 366. PRODUCT WASTE-PAPER HOURS PER YEAR 8400.

POWER TO HEAT RATIO 0.210

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
0	ONCOGN N O C O G O N	0.	0.	0.	0.	0.	0.	287.	180.	287.	COAL-FGD	447.	0	0.	0.11	0.55
1	STM141 STM-TURB-1 POWR	0.	73.	374.	267.	51.	15.	-27.	0.	374.	RESIDUAL	374.	0	0.16	0.14	0.65
1	STM141 STM-TURB-1 HEAT	0.	91.	342.	244.	47.	14.	0.	14.	342.	RESIDUAL	356.	0	0.20	0.13	0.69
1	STM141 STM-TURB-1 POWR	0.	73.	374.	267.	51.	15.	-27.	0.	374.	COAL-FGD	374.	0	0.16	0.14	0.65
1	STM141 STM-TURB-1 HEAT	0.	91.	342.	244.	47.	14.	0.	14.	342.	COAL-FGD	356.	0	0.20	0.13	0.69
1	STM141 STM-TURB-1 POWR	0.	73.	374.	267.	51.	15.	-27.	0.	374.	COAL-AFB	374.	0	0.16	0.14	0.65
1	STM141 STM-TURB-1 HEAT	0.	91.	342.	244.	47.	14.	0.	14.	342.	COAL-AFB	356.	0	0.20	0.13	0.69
2	STM088 STM-TURB-8 POWR	0.	-55.	502.	375.	51.	15.	-155.	0.	502.	RESIDUAL	502.	0	-0.12	0.10	0.49
2	STM088 STM-TURB-8 HEAT	0.	65.	326.	244.	33.	10.	0.	56.	326.	RESIDUAL	382.	0	0.15	0.09	0.64
2	STM088 STM-TURB-8 POWR	0.	-55.	502.	375.	51.	15.	-155.	0.	502.	COAL-FGD	502.	0	-0.12	0.10	0.49
2	STM088 STM-TURB-8 HEAT	0.	65.	326.	244.	33.	10.	0.	56.	326.	COAL-FGD	382.	0	0.15	0.09	0.64
2	STM088 STM-TURB-8 POWR	0.	-55.	502.	375.	51.	15.	-155.	0.	502.	COAL-AFB	502.	0	-0.12	0.10	0.49
2	STM088 STM-TURB-8 HEAT	0.	65.	326.	244.	33.	10.	0.	56.	326.	COAL-AFB	382.	0	0.15	0.09	0.64
3	PFBSTM PFB-STMTB- POWR	0.	97.	251.	160.	51.	15.	99.	0.	350.	COAL-PFB	350.	0	0.22	0.15	0.70
3	PFBSTM PFB-STMTB- HEAT	0.	148.	382.	244.	78.	23.	0.	-64.	382.	COAL-PFB	299.	0	0.28	0.20	0.64
4	TISTMT TI-STMTB-1 POWR	0.	98.	202.	119.	51.	15.	147.	0.	349.	RESIDUAL	349.	0	0.22	0.15	0.70
4	TISTMT TI-STMTB-1 HEAT	0.	201.	414.	244.	105.	31.	0.	-168.	414.	RESIDUAL	246.	0	0.33	0.25	0.59
4	TISTMT TI-STMTB-1 POWR	0.	98.	202.	119.	51.	15.	147.	0.	349.	COAL	349.	0	0.22	0.15	0.70
4	TISTMT TI-STMTB-1 HEAT	0.	201.	414.	244.	105.	31.	0.	-168.	414.	COAL	246.	0	0.33	0.25	0.59
5	TIHRSG THERMIONIC POWR	0.	73.	364.	235.	51.	15.	11.	0.	374.	RESIDUAL	374.	0	0.16	0.14	0.65
5	TIHRSG THERMIONIC HEAT	0.	75.	378.	244.	53.	16.	0.	-6.	378.	RESIDUAL	372.	0	0.17	0.14	0.65
5	TIHRSG THERMIONIC POWR	0.	73.	364.	235.	51.	15.	11.	0.	374.	COAL	374.	0	0.16	0.14	0.65
5	TIHRSG THERMIONIC HEAT	0.	75.	378.	244.	53.	16.	0.	-6.	378.	COAL	372.	0	0.17	0.14	0.65
6	STIRL STIRLING-1 POWR	0.	71.	203.	97.	51.	15.	173.	0.	376.	DISTILLA	376.	0	0.16	0.14	0.65
6	STIRL STIRLING-1 HEAT	0.	178.	511.	244.	129.	38.	0.	-243.	511.	DISTILLA	269.	0	0.26	0.25	0.48

HONEYWELL PAGE PRINTING SYSTEM- P118B-02

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 26218 MW 15.00 PROCESS MILLIONS BTU/HR 244.0 PROCESS TEMP(F) 366. PRODUCT WASTE-PAPER HOURS PER YEAR 8400.

POWER TO HEAT RATIO 0.210

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
6 STIRL	STIRLING-1 POWR	0.	71.	203.	97.	51.	15.	173.	0.	376. RESIDUAL	376.	0	0.16	0.14	0.65
6 STIRL	STIRLING-1 HEAT	0.	178.	511.	244.	129.	38.	0.	-243.	511. RESIDUAL	269.	0	0.26	0.25	0.48
6 STIRL	STIRLING-1 POWR	0.	71.	203.	97.	51.	15.	173.	0.	376. COAL	376.	0	0.16	0.14	0.65
6 STIRL	STIRLING-1 HEAT	0.	178.	511.	244.	129.	38.	0.	-243.	511. COAL	269.	0	0.26	0.25	0.48
7 HEGT85	HELIUM-GT- POWR	0.	23.	159.	19.	51.	15.	265.	0.	424. COAL-AFB	424.	10	0.05	0.12	0.58
7 HEGT85	HELIUM-GT- HEAT	0.	294.	2064.	244.	662.	194.	0.	-1910.	2064. COAL-AFB	153.	0	0.12	0.32	0.12
8 HEGT60	HELIUM-GT- POWR	0.	30.	198.	57.	51.	15.	219.	0.	417. COAL-AFB	417.	10	0.07	0.12	0.58
8 HEGT60	HELIUM-GT- HEAT	0.	127.	840.	244.	217.	64.	0.	-520.	840. COAL-AFB	320.	0	0.13	0.26	0.29
9 HEGT00	HELIUM-GT- POWR	0.	36.	291.	142.	51.	15.	120.	0.	411. COAL-AFB	411.	10	0.08	0.12	0.59
9 HEGT00	HELIUM-GT- HEAT	0.	62.	500.	244.	88.	26.	0.	-115.	500. COAL-AFB	385.	10	0.11	0.18	0.49
10 FCMCCL	FUEL-CL-MO POWR	0.	85.	168.	80.	51.	15.	193.	0.	362. COAL	362.	10	0.19	0.14	0.67
10 FCMCCL	FUEL-CL-MO HEAT	0.	261.	515.	244.	157.	46.	0.	-330.	515. COAL	186.	10	0.34	0.30	0.47
11 FCSTCL	FUEL-CL-ST POWR	0.	88.	135.	54.	51.	15.	224.	0.	359. COAL	359.	10	0.20	0.14	0.68
11 FCSTCL	FUEL-CL-ST HEAT	0.	402.	611.	244.	232.	68.	0.	-566.	611. COAL	45.	10	0.40	0.38	0.40
12 IGGTST	INT-GAS-GT POWR	0.	70.	182.	78.	51.	15.	196.	0.	377. COAL	377.	10	0.16	0.14	0.65
12 IGGTST	INT-GAS-GT HEAT	0.	219.	570.	244.	161.	47.	0.	-342.	570. COAL	228.	10	0.28	0.28	0.43
13 GTSOAR	GT-HRSG-10 POWR	0.	71.	176.	75.	51.	15.	199.	0.	375. RESIDUAL	375.	0	0.16	0.14	0.65
13 GTSOAR	GT-HRSG-10 HEAT	0.	233.	575.	244.	167.	49.	0.	-362.	575. RESIDUAL	214.	0	0.29	0.29	0.42
14 GTAC08	GT-HRSG-08 POWR	0.	85.	190.	96.	51.	15.	172.	0.	362. RESIDUAL	362.	0	0.19	0.14	0.67
14 GTAC08	GT-HRSG-08 HEAT	0.	213.	474.	244.	128.	38.	0.	-240.	474. RESIDUAL	234.	0	0.31	0.27	0.51
15 GTAC12	GT-HRSG-12 POWR	0.	84.	168.	78.	51.	15.	195.	0.	363. RESIDUAL	363.	0	0.19	0.14	0.67
15 GTAC12	GT-HRSG-12 HEAT	0.	262.	526.	244.	160.	47.	0.	-341.	526. RESIDUAL	185.	0	0.33	0.31	0.46
16 GTAC16	GT-HRSG-16 POWR	0.	82.	158.	69.	51.	15.	206.	0.	365. RESIDUAL	365.	0	0.18	0.14	0.67
16 GTAC16	GT-HRSG-16 HEAT	0.	292.	564.	244.	182.	53.	0.	-410.	564. RESIDUAL	155.	0	0.34	0.32	0.43
17 GTWC16	GT-HRSG-16 POWR	0.	75.	162.	66.	51.	15.	210.	0.	372. RESIDUAL	372.	10	0.17	0.14	0.66
17 GTWC16	GT-HRSG-16 HEAT	0.	278.	603.	244.	190.	56.	0.	-434.	603. RESIDUAL	169.	0	0.32	0.32	0.40

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 26218 MW 15.00 PROCESS MILLIONS BTU/HR 244.0 PROCESS TEMP(F) 366. PRODUCT WASTE-PAPER HOURS PER YEAR 8400.

		POWER TO HEAT RATIO 0.210															
UTILITY FUEL		COAL		WASTE FUEL EQV BTU*10**6= 0. HOT WATER BTU*10**6= 0.													
		WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
18	CC1626 GTST-16/26 POWR	0.	74.	136.	43.	51.	15.	237.	0.	373.	RESIDUAL	373.	10	0.16	0.14	0.65	
18	CC1626 GTST-16/26 HEAT	0.	422.	781.	244.	293.	86.	0.	-756.	781.	RESIDUAL	25.	0	0.35	0.38	0.31	
19	CC1622 GTST-16/22 POWR	0.	77.	138.	47.	51.	15.	231.	0.	370.	RESIDUAL	370.	10	0.17	0.14	0.66	
19	CC1622 GTST-16/22 HEAT	0.	398.	712.	244.	263.	77.	0.	-663.	712.	RESIDUAL	49.	0	0.36	0.37	0.34	
20	CC1222 GTST-12/22 POWR	0.	78.	138.	48.	51.	15.	231.	0.	369.	RESIDUAL	369.	0	0.17	0.14	0.66	
20	CC1222 GTST-12/22 HEAT	0.	400.	706.	244.	262.	77.	0.	-659.	706.	RESIDUAL	47.	0	0.36	0.37	0.35	
21	CC0822 GTST-08/22 POWR	0.	84.	147.	60.	51.	15.	216.	0.	363.	RESIDUAL	363.	0	0.19	0.14	0.67	
21	CC0822 GTST-08/22 HEAT	0.	340.	597.	244.	209.	61.	0.	-490.	597.	RESIDUAL	107.	0	0.36	0.35	0.41	
22	STIG15 STIG-15-16 POWR	0.	28.	134.	2.	51.	15.	285.	0.	419.	RESIDUAL	419.	10	0.06	0.12	0.58	
22	STIG15 STIG-15-16 HEAT	0.	3865.	18769.	244.	7151.	2096.	0.	-22187.	18769.	RESIDUAL	-3418.	0	0.17	0.38	0.01	
23	STIG10 STIG-10-16 POWR	0.	40.	143.	19.	51.	15.	265.	0.	407.	RESIDUAL	407.	10	0.09	0.13	0.60	
23	STIG10 STIG-10-16 HEAT	0.	512.	1842.	244.	661.	194.	0.	-1907.	1842.	RESIDUAL	-65.	0	0.22	0.36	0.13	
24	STIG1S STIG-1S-16 POWR	0.	45.	153.	32.	51.	15.	249.	0.	402.	RESIDUAL	402.	10	0.10	0.13	0.61	
24	STIG1S STIG-1S-16 HEAT	0.	342.	1157.	244.	388.	114.	0.	-1053.	1157.	RESIDUAL	105.	0	0.23	0.34	0.21	
25	DEADV3 DIESEL-ADV POWR	0.	55.	138.	28.	51.	15.	254.	0.	392.	RESIDUAL	392.	0	0.12	0.13	0.62	
25	DEADV3 DIESEL-ADV HEAT	0.	477.	1190.	244.	442.	129.	0.	-1220.	1190.	RESIDUAL	-30.	0	0.29	0.37	0.20	
26	DEADV2 DIESEL-ADV POWR	0.	63.	138.	35.	51.	15.	246.	0.	384.	RESIDUAL	384.	1	0.14	0.13	0.64	
26	DEADV2 DIESEL-ADV HEAT	0.	440.	961.	244.	356.	104.	0.	-954.	961.	RESIDUAL	7.	1	0.31	0.37	0.25	
27	DEADV1 DIESEL-ADV POWR	0.	85.	138.	54.	51.	15.	224.	0.	362.	RESIDUAL	362.	1	0.19	0.14	0.67	
27	DEADV1 DIESEL-ADV HEAT	0.	387.	624.	244.	232.	68.	0.	-564.	624.	RESIDUAL	60.	1	0.38	0.37	0.39	
28	DEHTPM ADV-DIESEL POWR	0.	82.	157.	67.	51.	15.	208.	0.	365.	RESIDUAL	365.	0	0.18	0.14	0.67	
28	DEHTPM ADV-DIESEL HEAT	0.	300.	569.	244.	186.	55.	0.	-422.	569.	RESIDUAL	147.	0	0.34	0.33	0.43	
29	DESCA3 DIESEL-SOA POWR	0.	47.	142.	24.	51.	15.	259.	0.	400.	DISTILLA	400.	0	0.10	0.13	0.61	
29	DESCA3 DIESEL-SOA HEAT	0.	470.	1427.	244.	515.	151.	0.	-1450.	1427.	DISTILLA	-23.	0	0.25	0.36	0.17	
29	DESCA3 DIESEL-SOA POWR	0.	47.	142.	24.	51.	15.	259.	0.	400.	RESIDUAL	400.	0	0.10	0.13	0.61	
29	DESCA3 DIESEL-SOA HEAT	0.	470.	1427.	244.	515.	151.	0.	-1450.	1427.	RESIDUAL	-23.	0	0.25	0.36	0.17	

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 26218 MW 15.00 PROCESS MILLIONS BTU/HR 244.0 PROCESS TEMP(F) 366. PRODUCT WASTE-PAPER HOURS PER YEAR 8400.

UTILITY FUEL		COAL		POWER TO HEAT RATIO 0.210					WASTE FUEL EQV BTU*10**6=		HOT WATER BTU*10**6=					
WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR		
30 DES0A2 DIESEL-S0A POWR	0.	55.	142.	31.	51.	15.	250.	0.	392.	DISTILLA	392.	1	0.12	0.13	0.62	
30 DES0A2 DIESEL-S0A HEAT	0.	429.	1109.	244.	400.	117.	0.	-1091.	1109.	DISTILLA	18.	1	0.28	0.36	0.22	
30 DES0A2 DIESEL-S0A POWR	0.	55.	142.	31.	51.	15.	250.	0.	392.	RESIDUAL	392.	1	0.12	0.13	0.62	
30 DES0A2 DIESEL-S0A HEAT	0.	429.	1109.	244.	400.	117.	0.	-1091.	1109.	RESIDUAL	18.	1	0.28	0.36	0.22	
31 DES0A1 DIESEL-S0A POWR	0.	85.	142.	57.	51.	15.	220.	0.	362.	DISTILLA	362.	1	0.19	0.14	0.67	
31 DES0A1 DIESEL-S0A HEAT	0.	365.	608.	244.	220.	64.	0.	-527.	608.	DISTILLA	82.	1	0.37	0.36	0.40	
31 DES0A1 DIESEL-S0A POWR	0.	85.	142.	57.	51.	15.	220.	0.	362.	RESIDUAL	362.	1	0.19	0.14	0.67	
31 DES0A1 DIESEL-S0A HEAT	0.	365.	608.	244.	220.	64.	0.	-527.	608.	RESIDUAL	82.	1	0.37	0.36	0.40	
32 GTS0AD GT-HRSG-10 POWR	0.	80.	175.	81.	51.	15.	192.	0.	367.	DISTILLA	367.	0	0.18	0.14	0.66	
32 GTS0AD GT-HRSG-10 HEAT	0.	241.	530.	244.	155.	45.	0.	-323.	530.	DISTILLA	206.	0	0.31	0.29	0.46	
33 GTRA08 GT-85RE-08 POWR	0.	73.	143.	48.	51.	15.	230.	0.	374.	DISTILLA	374.	0	0.16	0.14	0.65	
33 GTRA08 GT-85RE-08 HEAT	0.	371.	726.	244.	259.	76.	0.	-650.	726.	DISTILLA	76.	0	0.34	0.36	0.34	
34 GTRA12 GT-85RE-12 POWR	0.	75.	143.	49.	51.	15.	229.	0.	372.	DISTILLA	372.	0	0.17	0.14	0.66	
34 GTRA12 GT-85RE-12 HEAT	0.	371.	705.	244.	252.	74.	0.	-629.	705.	DISTILLA	76.	0	0.34	0.36	0.35	
35 GTRA16 GT-85RE-16 POWR	0.	76.	147.	53.	51.	15.	225.	0.	371.	DISTILLA	371.	0	0.17	0.14	0.66	
35 GTRA16 GT-85RE-16 HEAT	0.	348.	673.	244.	235.	69.	0.	-574.	673.	DISTILLA	99.	0	0.34	0.35	0.36	
36 GTR208 GT-60RE-08 POWR	0.	76.	160.	64.	51.	15.	211.	0.	371.	DISTILLA	371.	0	0.17	0.14	0.66	
36 GTR208 GT-60RE-08 HEAT	0.	287.	607.	244.	194.	57.	0.	-447.	607.	DISTILLA	160.	0	0.32	0.32	0.40	
37 GTR212 GT-60RE-12 POWR	0.	75.	155.	60.	51.	15.	217.	0.	372.	DISTILLA	372.	0	0.17	0.14	0.66	
37 GTR212 GT-60RE-12 HEAT	0.	307.	631.	244.	208.	61.	0.	-491.	631.	DISTILLA	140.	0	0.33	0.33	0.39	
38 GTR216 GT-60RE-16 POWR	0.	77.	152.	58.	51.	15.	218.	0.	370.	DISTILLA	370.	0	0.17	0.14	0.66	
38 GTR216 GT-60RE-16 HEAT	0.	321.	634.	244.	214.	63.	0.	-507.	634.	DISTILLA	126.	0	0.34	0.34	0.39	
39 GTRW08 GT-85RE-08 POWR	0.	62.	146.	40.	51.	15.	239.	0.	385.	DISTILLA	385.	10	0.14	0.13	0.63	
39 GTRW08 GT-85RE-08 HEAT	0.	372.	880.	244.	309.	90.	0.	-805.	880.	DISTILLA	75.	0	0.30	0.35	0.28	
40 GTRW12 GT-85RE-12 POWR	0.	66.	141.	40.	51.	15.	240.	0.	381.	DISTILLA	381.	10	0.15	0.13	0.64	
40 GTRW12 GT-85RE-12 HEAT	0.	405.	861.	244.	313.	92.	0.	-819.	861.	DISTILLA	42.	0	0.32	0.36	0.28	



DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 80

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 26218 MW 15.00 PROCESS MILLIONS BTU/HR 244.0 PROCESS TEMP(F) 366. PRODUCT WASTE-PAPER HOURS PER YEAR 8400.

UTILITY FUEL		COAL		POWER TO HEAT RATIO 0.210										WASTE FUEL EQV BTU*10**6= 0.		HOT WATER BTU*10**6= 0.	
WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR			
41 GTRW16 GT-85RE-16 POWR	0.	67.	143.	43.	51.	15.	236.	0.	380.	DISTILLA	380.	10	0.15	0.13	0.64		
41 GTRW16 GT-85RE-16 HEAT	0.	381.	812.	244.	290.	85.	0.	-746.	812.	DISTILLA	66.	0	0.32	0.36	0.30		
42 GTR308 GT-60RE-08 POWR	0.	57.	165.	53.	51.	15.	225.	0.	390.	DISTILLA	390.	10	0.13	0.13	0.63		
42 GTR308 GT-60RE-08 HEAT	0.	263.	761.	244.	236.	69.	0.	-577.	761.	DISTILLA	184.	0	0.26	0.31	0.32		
43 GTR312 GT-60RE-12 POWR	0.	69.	150.	50.	51.	15.	229.	0.	378.	DISTILLA	378.	10	0.15	0.14	0.64		
43 GTR312 GT-60RE-12 HEAT	0.	338.	736.	244.	252.	74.	0.	-627.	736.	DISTILLA	109.	0	0.31	0.34	0.33		
44 GTR316 GT-60RE-16 POWR	0.	68.	151.	50.	51.	15.	228.	0.	379.	DISTILLA	379.	10	0.15	0.14	0.64		
44 GTR316 GT-60RE-16 HEAT	0.	330.	731.	244.	248.	73.	0.	-615.	731.	DISTILLA	117.	0	0.31	0.34	0.33		
45 FCPADS FUEL-CL-PH POWR	0.	52.	135.	23.	51.	15.	260.	0.	395.	DISTILLA	395.	0	0.12	0.13	0.62		
45 FCPADS FUEL-CL-PH HEAT	0.	556.	1435.	244.	545.	160.	0.	-1544.	1435.	DISTILLA	-109.	0	0.28	0.38	0.17		
46 FCMCDS FUEL-CL-MO POWR	0.	70.	124.	29.	51.	15.	253.	0.	377.	DISTILLA	377.	0	0.16	0.14	0.65		
46 FCMCDS FUEL-CL-MO HEAT	0.	588.	1047.	244.	431.	126.	0.	-1188.	1047.	DISTILLA	-141.	0	0.26	0.41	0.23		

ORIGINAL PAGE IS  
OF POOR QUALITY

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 81

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28001 MW 32.50 PROCESS MILLIONS BTU/HR 1100.0 PROCESS TEMP(F) 366. PRODUCT CHEM HOURS PER YEAR 8760.

UTILITY FUEL COAL POWER TO HEAT RATIO 0.101  
WASTE FUEL EQV BTU=10\*\*6= 0. HOT WATER BTU=10\*\*6= 0.

	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
--	------------------------------------	---------------------------------------	------------------------------------	--------------------------------------	---------------------------------------	----------------	------------------------------	-------------------------------------	------------------------------------	-----------------------------------	---------------------------------------	------	------	-------------	------------

0 ONCOGN N O C O G O N	0.	0.	0.	0.	0.	0.	1294.	347.	1294.	COAL-FGD	1641.	0	0.	0.07	0.67
1 STM141 STM-TURB-1 POWR	0.	216.	850.	611.	111.	33.	575.	0.	1425.	RESIDUAL	1425.	0	0.13	0.08	0.77
1 STM141 STM-TURB-1 HEAT	0.	389.	1529.	1100.	200.	58.	0.	-277.	1529.	RESIDUAL	1252.	0	0.20	0.13	0.72
1 STM141 STM-TURB-1 POWR	0.	216.	850.	611.	111.	33.	575.	0.	1425.	COAL-FGD	1425.	0	0.13	0.08	0.77
1 STM141 STM-TURB-1 HEAT	0.	389.	1529.	1100.	200.	58.	0.	-277.	1529.	COAL-FGD	1252.	0	0.20	0.13	0.72
1 STM141 STM-TURB-1 POWR	0.	216.	850.	611.	111.	33.	575.	0.	1425.	COAL-AFB	1425.	0	0.13	0.08	0.77
1 STM141 STM-TURB-1 HEAT	0.	389.	1529.	1100.	200.	58.	0.	-277.	1529.	COAL-AFB	1252.	0	0.20	0.13	0.72
2 STM088 STM-TURB-8 POWR	0.	216.	1161.	876.	111.	33.	264.	0.	1425.	RESIDUAL	1425.	0	0.13	0.08	0.77
2 STM088 STM-TURB-8 HEAT	0.	271.	1458.	1100.	139.	41.	0.	-89.	1458.	RESIDUAL	1369.	0	0.16	0.10	0.75
2 STM088 STM-TURB-8 POWR	0.	216.	1161.	876.	111.	33.	264.	0.	1425.	COAL-FGD	1425.	0	0.13	0.08	0.77
2 STM088 STM-TURB-8 HEAT	0.	271.	1458.	1100.	139.	41.	0.	-89.	1458.	COAL-FGD	1369.	0	0.16	0.10	0.75
2 STM088 STM-TURB-8 POWR	0.	216.	1161.	876.	111.	33.	264.	0.	1425.	COAL-AFB	1425.	0	0.13	0.08	0.77
2 STM088 STM-TURB-8 HEAT	0.	271.	1458.	1100.	139.	41.	0.	-89.	1458.	COAL-AFB	1369.	0	0.16	0.10	0.75
3 PFBSTM PFB-STMTB- POWR	0.	211.	559.	359.	111.	33.	871.	0.	1430.	COAL-PFB	1430.	0	0.13	0.08	0.77
3 PFBSTM PFB-STMTB- HEAT	0.	645.	1710.	1100.	339.	99.	0.	-714.	1710.	COAL-PFB	996.	0	0.27	0.20	0.64
4 TISTMT TI-STMTB-1 POWR	0.	212.	447.	266.	111.	33.	982.	0.	1428.	RESIDUAL	1428.	0	0.13	0.08	0.77
4 TISTMT TI-STMTB-1 HEAT	0.	879.	1850.	1100.	459.	135.	0.	-1088.	1850.	RESIDUAL	761.	0	0.32	0.25	0.59
4 TISTMT TI-STMTB-1 POWR	0.	212.	447.	266.	111.	33.	982.	0.	1428.	COAL	1428.	0	0.13	0.08	0.77
4 TISTMT TI-STMTB-1 HEAT	0.	879.	1850.	1100.	459.	135.	0.	-1088.	1850.	COAL	761.	0	0.32	0.25	0.59
5 TIHRSG THERMIONIC POWR	0.	157.	788.	509.	111.	33.	695.	0.	1483.	RESIDUAL	1483.	0	0.10	0.07	0.74
5 TIHRSG THERMIONIC HEAT	0.	340.	1703.	1100.	240.	70.	0.	-402.	1703.	RESIDUAL	1301.	0	0.17	0.14	0.65
5 TIHRSG THERMIONIC POWR	0.	157.	788.	509.	111.	33.	695.	0.	1483.	COAL	1483.	0	0.10	0.07	0.74
5 TIHRSG THERMIONIC HEAT	0.	340.	1703.	1100.	240.	70.	0.	-402.	1703.	COAL	1301.	0	0.17	0.14	0.65
6 STIRL STIRLING-1 POWR	0.	153.	440.	210.	111.	33.	1047.	0.	1487.	DISTILLA	1487.	0	0.09	0.07	0.74
6 STIRL STIRLING-1 HEAT	0.	804.	2306.	1100.	581.	170.	0.	-1489.	2306.	DISTILLA	837.	0	0.26	0.25	0.48

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28001 MW 32.50 PROCESS MILLIONS BTU/HR 1100.0 PROCESS TEMP(F) 366. PRODUCT CHEM HOURS PER YEAR 8760.

POWER TO HEAT RATIO 0.101

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL COAL

			WASTE FUEL USED 10**6 BTU/HR	COGEN COGEN USED 10**6 BTU/HR	COGEN COGEN HEAT 10**6 BTU/HR	COGEN COGEN POWER 10**6 BTU/HR	AUX ELECT MW	UTILIT TOTAL FUEL 10**6 BTU/HR	SITE FUEL 10**6 BTU/HR	NET+ TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR			
6 STIRL	STIRLING-1	POWR	0.	153.	440.	210.	111.	33.	1047.	0.	1487.	RESIDUAL	1487.	0	0.09	0.07	0.74
6 STIRL	STIRLING-1	HEAT	0.	804.	2306.	1100.	581.	170.	0.	-1469.	2306.	RESIDUAL	837.	0	0.26	0.25	0.48
6 STIRL	STIRLING-1	POWR	0.	153.	440.	210.	111.	33.	1047.	0.	1487.	COAL	1487.	0	0.09	0.07	0.74
6 STIRL	STIRLING-1	HEAT	0.	804.	2306.	1100.	581.	170.	0.	-1469.	2306.	COAL	837.	0	0.26	0.25	0.48
7 HEGT85	HELIUM-GT-	POWR	0.	49.	345.	41.	111.	33.	1246.	0.	1592.	COAL-AFB	1592.	10	0.03	0.07	0.69
7 HEGT85	HELIUM-GT-	HEAT	0.	1323.	9304.	1100.	2987.	875.	0.	-8986.	9304.	COAL-AFB	317.	0	0.12	0.32	0.12
8 HEGT60	HELIUM-GT-	POWR	0.	65.	428.	124.	111.	33.	1148.	0.	1576.	COAL-AFB	1576.	10	0.04	0.07	0.70
8 HEGT60	HELIUM-GT-	HEAT	0.	573.	3785.	1100.	980.	287.	0.	-2717.	3785.	COAL-AFB	1068.	0	0.13	0.26	0.29
9 HEGT00	HELIUM-GT-	POWR	0.	79.	630.	308.	111.	33.	932.	0.	1562.	COAL-AFB	1562.	10	0.05	0.07	0.70
9 HEGT00	HELIUM-GT-	HEAT	0.	281.	2252.	1100.	396.	116.	0.	-892.	2252.	COAL-AFB	1360.	0	0.11	0.18	0.49
10 FCMCCL	FUEL-CL-M0	POWR	0.	185.	365.	173.	111.	33.	1091.	0.	1456.	COAL	1456.	10	0.11	0.08	0.76
10 FCMCCL	FUEL-CL-M0	HEAT	0.	1178.	2324.	1100.	706.	207.	0.	-1861.	2324.	COAL	463.	0	0.34	0.30	0.47
11 FCSTCL	FUEL-CL-ST	POWR	0.	192.	295.	119.	111.	33.	1155.	0.	1449.	COAL	1449.	10	0.12	0.08	0.76
11 FCSTCL	FUEL-CL-ST	HEAT	0.	1777.	2732.	1100.	1029.	302.	0.	-2868.	2732.	COAL	-136.	0	0.39	0.38	0.40
12 IGGTST	INT-GAS-GT	POWR	0.	150.	399.	172.	111.	33.	1091.	0.	1490.	COAL	1490.	10	0.09	0.07	0.74
12 IGGTST	INT-GAS-GT	HEAT	0.	960.	2546.	1100.	708.	207.	0.	-1865.	2546.	COAL	681.	0	0.27	0.28	0.43
13 GTS0AR	GT-HRSG-10	POWR	0.	155.	382.	162.	111.	33.	1103.	0.	1486.	RESIDUAL	1486.	0	0.09	0.07	0.74
13 GTS0AR	GT-HRSG-10	HEAT	0.	1051.	2594.	1100.	752.	220.	0.	-2004.	2594.	RESIDUAL	590.	0	0.29	0.29	0.42
14 GTAC08	GT-HRSG-08	POWR	0.	184.	411.	211.	111.	33.	1045.	0.	1456.	RESIDUAL	1456.	0	0.11	0.08	0.76
14 GTAC08	GT-HRSG-08	HEAT	0.	960.	2138.	1100.	577.	169.	0.	-1457.	2138.	RESIDUAL	681.	0	0.31	0.27	0.51
15 GTAC12	GT-HRSG-12	POWR	0.	182.	364.	169.	111.	33.	1096.	0.	1459.	RESIDUAL	1459.	0	0.11	0.08	0.75
15 GTAC12	GT-HRSG-12	HEAT	0.	1183.	2370.	1100.	723.	212.	0.	-1912.	2370.	RESIDUAL	458.	0	0.33	0.31	0.46
16 GTAC16	GT-HRSG-16	POWR	0.	178.	343.	148.	111.	33.	1119.	0.	1463.	RESIDUAL	1463.	0	0.11	0.08	0.75
16 GTAC16	GT-HRSG-16	HEAT	0.	1318.	2544.	1100.	822.	241.	0.	-2221.	2544.	RESIDUAL	323.	0	0.34	0.32	0.43
17 GTWC16	GT-HRSG-16	POWR	0.	162.	352.	142.	111.	33.	1127.	0.	1479.	RESIDUAL	1479.	0	0.10	0.07	0.74
17 GTWC16	GT-HRSG-16	HEAT	0.	1252.	2718.	1100.	856.	251.	0.	-2329.	2718.	RESIDUAL	389.	0	0.32	0.32	0.40

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 83

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28001 MW 32.50 PROCESS MILLIONS BTU/HR 1100.0 PROCESS TEMP(F) 366. PRODUCT CHEM HOURS PER YEAR 8760.

POWER TO HEAT RATIO 0.101

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
18 CC1626	GTST-16/26	POWR	0.	159.	298.	94.	111.	33.	1184.	0.	1481.	RESIDUAL	1481.	0	0.10	0.07	0.74
18 CC1626	GTST-16/26	HEAT	0.	1866.	3490.	1100.	1300.	381.	0.	-3716.	3490.	RESIDUAL	-226.	0	0.35	0.37	0.32
19 CC1622	GTST-16/22	POWR	0.	167.	302.	104.	111.	33.	1171.	0.	1474.	RESIDUAL	1474.	0	0.10	0.08	0.75
19 CC1622	GTST-16/22	HEAT	0.	1760.	3184.	1100.	1168.	342.	0.	-3304.	3184.	RESIDUAL	-120.	0	0.36	0.37	0.35
20 CC1222	GTST-12/22	POWR	0.	169.	301.	105.	111.	33.	1171.	0.	1472.	RESIDUAL	1472.	0	0.10	0.08	0.75
20 CC1222	GTST-12/22	HEAT	0.	1767.	3157.	1100.	1161.	340.	0.	-3283.	3157.	RESIDUAL	-126.	0	0.36	0.37	0.35
21 CC0822	GTST-08/22	POWR	0.	181.	322.	133.	111.	33.	1138.	0.	1460.	RESIDUAL	1460.	0	0.11	0.08	0.75
21 CC0822	GTST-08/22	HEAT	0.	1500.	2668.	1100.	919.	269.	0.	-2526.	2668.	RESIDUAL	141.	0	0.36	0.34	0.41
22 ST1015	STIG-15-16	POWR	0.	60.	291.	4.	111.	33.	1290.	0.	1581.	RESIDUAL	1581.	0	0.04	0.07	0.70
22 ST1015	STIG-15-16	HEAT	0.	17424.	84615.	1100.	32238.	9449.	0.	*****	84615.	RESIDUAL	-15783.	0	0.17	0.38	0.01
23 ST1010	STIG-10-16	POWR	0.	86.	309.	41.	111.	33.	1246.	0.	1555.	RESIDUAL	1555.	0	0.05	0.07	0.71
23 ST1010	STIG-10-16	HEAT	0.	2309.	8302.	1100.	2981.	874.	0.	-8970.	8302.	RESIDUAL	-668.	0	0.22	0.36	0.13
24 ST101S	STIG-1S-16	POWR	0.	98.	331.	70.	111.	33.	1212.	0.	1543.	RESIDUAL	1543.	0	0.06	0.07	0.71
24 ST101S	STIG-1S-16	HEAT	0.	1542.	5218.	1100.	1749.	513.	0.	-5120.	5218.	RESIDUAL	99.	0	0.23	0.34	0.21
25 DEADV3	DIESEL-ADV	POWR	0.	120.	299.	61.	111.	33.	1222.	0.	1521.	RESIDUAL	1521.	0	0.07	0.07	0.72
25 DEADV3	DIESEL-ADV	HEAT	0.	2149.	5366.	1100.	1991.	584.	0.	-5875.	5366.	RESIDUAL	-509.	0	0.29	0.37	0.20
26 DEADV2	DIESEL-ADV	POWR	0.	137.	299.	76.	111.	33.	1205.	0.	1504.	RESIDUAL	1504.	1	0.08	0.07	0.73
26 DEADV2	DIESEL-ADV	HEAT	0.	1984.	4331.	1100.	1607.	471.	0.	-4674.	4331.	RESIDUAL	-344.	1	0.31	0.37	0.25
27 DEADV1	DIESEL-ADV	POWR	0.	185.	299.	117.	111.	33.	1157.	0.	1456.	RESIDUAL	1456.	1	0.11	0.08	0.76
27 DEADV1	DIESEL-ADV	HEAT	0.	1742.	2813.	1100.	1044.	306.	0.	-2915.	2813.	RESIDUAL	-102.	1	0.38	0.37	0.39
28 DEHTFM	ADV-DIESEL	POWR	0.	178.	339.	145.	111.	33.	1123.	0.	1462.	RESIDUAL	1462.	0	0.11	0.08	0.75
28 DEHTFM	ADV-DIESEL	HEAT	0.	1350.	2567.	1100.	840.	246.	0.	-2277.	2567.	RESIDUAL	290.	0	0.34	0.33	0.43
29 DES0A3	DIESEL-S0A	POWR	0.	101.	307.	53.	111.	33.	1232.	0.	1540.	DISTILLA	1540.	0	0.06	0.07	0.71
29 DES0A3	DIESEL-S0A	HEAT	0.	2118.	6433.	1100.	2322.	681.	0.	-6911.	6433.	DISTILLA	-478.	0	0.25	0.36	0.17
29 DES0A3	DIESEL-S0A	POWR	0.	101.	307.	53.	111.	33.	1232.	0.	1540.	RESIDUAL	1540.	0	0.06	0.07	0.71
29 DES0A3	DIESEL-S0A	HEAT	0.	2118.	6433.	1100.	2322.	681.	0.	-6911.	6433.	RESIDUAL	-478.	0	0.25	0.36	0.17

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28001 MW 32.50 PROCESS MILLIONS BTU/HR 1100.0 PROCESS TEMP(F) 366. PRODUCT CHEM HOURS PER YEAR 8760.

UTILITY FUEL COAL POWER TO HEAT RATIO 0.101 WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN ELECT 10**6 BTU/HR	AUX BOILER 10**6 BTU/HR	PROCES FUEL USED 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	FUEL SITE USED 10**6 BTU/HR	TOTAL FUEL USED 10**6 BTU/HR	NET+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT
30 DES0A2 DIESEL-S0A POWR	0.	119.	307.	68.	111.	33.	1215.	0.	1522.	DISTILLA	1522.	1	0.07	0.07	0.72	
30 DES0A2 DIESEL-S0A HEAT	0.	1935.	5000.	1100.	1805.	529.	0.	-5294.	5000.	DISTILLA	-294.	1	0.28	0.36	0.22	
30 DES0A2 DIESEL-S0A POWR	0.	119.	307.	68.	111.	33.	1215.	0.	1522.	RESIDUAL	1522.	1	0.07	0.07	0.72	
30 DES0A2 DIESEL-S0A HEAT	0.	1935.	5000.	1100.	1805.	529.	0.	-5294.	5000.	RESIDUAL	-294.	1	0.28	0.36	0.22	
31 DES0A1 DIESEL-S0A POWR	0.	184.	307.	123.	111.	33.	1149.	0.	1456.	DISTILLA	1456.	1	0.11	0.08	0.76	
31 DES0A1 DIESEL-S0A HEAT	0.	1646.	2743.	1100.	990.	290.	0.	-2748.	2743.	DISTILLA	-5.	1	0.37	0.36	0.40	
31 DES0A1 DIESEL-S0A POWR	0.	184.	307.	123.	111.	33.	1149.	0.	1456.	RESIDUAL	1456.	1	0.11	0.08	0.76	
31 DES0A1 DIESEL-S0A HEAT	0.	1646.	2743.	1100.	990.	290.	0.	-2748.	2743.	RESIDUAL	-5.	1	0.37	0.36	0.40	
32 GTSC0D GT-HRSG-10 POWR	0.	173.	380.	175.	111.	33.	1088.	0.	1468.	DISTILLA	1468.	0	0.11	0.08	0.75	
32 GTSC0D GT-HRSG-10 HEAT	0.	1085.	2386.	1100.	697.	204.	0.	-1833.	2386.	DISTILLA	556.	0	0.31	0.29	0.46	
33 GTRA08 GT-85RE-08 POWR	0.	159.	311.	104.	111.	33.	1171.	0.	1482.	DISTILLA	1482.	0	0.10	0.07	0.74	
33 GTRA08 GT-85RE-08 HEAT	0.	1672.	3271.	1100.	1168.	342.	0.	-3303.	3271.	DISTILLA	-32.	0	0.34	0.36	0.34	
34 GTRA12 GT-85RE-12 POWR	0.	163.	310.	107.	111.	33.	1168.	0.	1476.	DISTILLA	1476.	0	0.10	0.08	0.74	
34 GTRA12 GT-85RE-12 HEAT	0.	1671.	3177.	1100.	1137.	333.	0.	-3208.	3177.	DISTILLA	-31.	0	0.34	0.36	0.35	
35 GTRA16 GT-85RE-16 POWR	0.	164.	318.	115.	111.	33.	1159.	0.	1476.	DISTILLA	1476.	0	0.10	0.08	0.75	
35 GTRA16 GT-85RE-16 HEAT	0.	1569.	3036.	1100.	1059.	310.	0.	-2964.	3036.	DISTILLA	71.	0	0.34	0.35	0.36	
36 GTR208 GT-60RE-08 POWR	0.	164.	347.	139.	111.	33.	1130.	0.	1477.	DISTILLA	1477.	0	0.10	0.08	0.74	
36 GTR208 GT-60RE-08 HEAT	0.	1294.	2736.	1100.	875.	257.	0.	-2389.	2736.	DISTILLA	347.	0	0.32	0.32	0.40	
37 GTR212 GT-60RE-12 POWR	0.	163.	336.	130.	111.	33.	1141.	0.	1477.	DISTILLA	1477.	0	0.10	0.08	0.74	
37 GTR212 GT-60RE-12 HEAT	0.	1383.	2845.	1100.	939.	275.	0.	-2587.	2845.	DISTILLA	258.	0	0.33	0.33	0.39	
38 GTR216 GT-60RE-16 POWR	0.	167.	329.	127.	111.	33.	1145.	0.	1474.	DISTILLA	1474.	0	0.10	0.08	0.75	
38 GTR216 GT-60RE-16 HEAT	0.	1446.	2857.	1100.	963.	282.	0.	-2662.	2857.	DISTILLA	195.	0	0.34	0.34	0.39	
39 GTRV08 GT-85RE-08 POWR	0.	134.	316.	88.	111.	33.	1191.	0.	1507.	DISTILLA	1507.	0	0.08	0.07	0.73	
39 GTRV08 GT-85RE-08 HEAT	0.	1678.	3966.	1100.	1332.	408.	0.	-4004.	3966.	DISTILLA	-38.	0	0.30	0.35	0.28	
40 GTRW12 GT-85RE-12 POWR	0.	143.	305.	86.	111.	33.	1193.	0.	1497.	DISTILLA	1497.	0	0.09	0.07	0.73	
40 GTRW12 GT-85RE-12 HEAT	0.	1928.	3880.	1100.	1412.	414.	0.	-4067.	3880.	DISTILLA	-167.	0	0.32	0.36	0.28	

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 85

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28001 MW 32.50 PROCESS MILLIONS BTU/HR 1100.0 PROCESS TEMP(F) 366. PRODUCT CHEM HOURS PER YEAR 8760.

		POWER TO HEAT RATIO 0.101										WASTE FUEL EQV BTU*10**6= 0.		HOT WATER BTU*10**6= 0.	
UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET USED 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	AUX MW ELECT	UTILIT PROCES BOILR 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41	QTRW16 GT-85RE-16 POWR	0.	146.	311.	93.	111.	33.	1184.	0.	1495.	DISTILLA 1495.	0	0.09	0.07	0.74
41	QTRW16 GT-85RE-16 HEAT	0.	1717.	3659.	1100.	1306.	383.	0.	-3736.	3659.	DISTILLA -77.	0	0.32	0.36	0.30
42	QTR308 GT-60RE-08 POWR	0.	124.	358.	115.	111.	33.	1159.	0.	1517.	DISTILLA 1517.	0	0.08	0.07	0.73
42	QTR308 GT-60RE-08 HEAT	0.	1187.	3429.	1100.	1063.	312.	0.	-2975.	3429.	DISTILLA 454.	0	0.26	0.31	0.32
43	QTR312 GT-60RE-12 POWR	0.	149.	324.	107.	111.	33.	1168.	0.	1492.	DISTILLA 1492.	0	0.09	0.07	0.74
43	QTR312 GT-60RE-12 HEAT	0.	1522.	3319.	1100.	1135.	333.	0.	-3200.	3319.	DISTILLA 118.	0	0.31	0.34	0.33
44	QTR316 GT-60RE-16 POWR	0.	148.	327.	109.	111.	33.	1166.	0.	1493.	DISTILLA 1493.	0	0.09	0.07	0.74
44	QTR316 GT-60RE-16 HEAT	0.	1490.	3296.	1100.	1117.	327.	0.	-3145.	3296.	DISTILLA 151.	0	0.31	0.34	0.33
45	FCPADS FUEL-CL-PH POWR	0.	113.	292.	50.	111.	33.	1236.	0.	1528.	DISTILLA 1528.	0	0.07	0.07	0.72
45	FCPADS FUEL-CL-PH HEAT	0.	2507.	6471.	1100.	2459.	721.	0.	-7337.	6471.	DISTILLA -867.	0	0.28	0.38	0.17
46	FCMCDS FUEL-CL-MO POWR	0.	151.	269.	63.	111.	33.	1220.	0.	1489.	DISTILLA 1489.	0	0.09	0.07	0.74
46	FCMCDS FUEL-CL-MO HEAT	0.	2651.	4721.	1100.	1945.	570.	0.	-5732.	4721.	DISTILLA -1011.	0	0.36	0.41	0.23

HONEYWELL PAGE PRINTING SYSTEM- P1185-02

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 06

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28002 MW 77.20 PROCESS MILLIONS BTU/HR 1054.0 PROCESS TEMP(F) 366. PRODUCT CHEM HOURS PER YEAR 8760.

POWER TO HEAT RATIO 0.250

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED- NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	AUX MW	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
0 ONOCGN N O C O O Q N		0.	0.	0.	0.	0.	1240.	823.	1240.	COAL-FGD	2063.	0	0.	0.13	0.51	
1 STM141 STM-TURB-1 POWR		0.	45.	2019.	1452.	263.	77.	-469.	0.	2019.	RESIDUAL	2019.	0	0.02	0.13	0.52
1 STM141 STM-TURB-1 HEAT		0.	372.	1465.	1054.	191.	56.	0.	226.	1465.	RESIDUAL	1691.	0	0.18	0.11	0.62
1 STM141 STM-TURB-1 POWR		0.	45.	2019.	1452.	263.	77.	-469.	0.	2019.	COAL-FGD	2019.	0	0.02	0.13	0.52
1 STM141 STM-TURB-1 HEAT		0.	372.	1465.	1054.	191.	56.	0.	226.	1465.	COAL-FGD	1691.	0	0.18	0.11	0.62
1 STM141 STM-TURB-1 POWR		0.	45.	2019.	1452.	263.	77.	-469.	0.	2019.	COAL-AFB	2019.	0	0.02	0.13	0.52
1 STM141 STM-TURB-1 HEAT		0.	372.	1465.	1054.	191.	56.	0.	226.	1465.	COAL-AFB	1691.	0	0.18	0.11	0.62
2 STM088 STM-TURB-8 POWR		0.	-694.	2758.	2081.	263.	77.	-1208.	0.	2758.	RESIDUAL	2758.	0	-0.34	0.10	0.38
2 STM088 STM-TURB-8 HEAT		0.	260.	1397.	1054.	133.	39.	0.	406.	1397.	RESIDUAL	1803.	0	0.13	0.07	0.58
2 STM088 STM-TURB-8 POWR		0.	-694.	2758.	2081.	263.	77.	-1208.	0.	2758.	COAL-FGD	2758.	0	-0.34	0.10	0.38
2 STM088 STM-TURB-8 HEAT		0.	260.	1397.	1054.	133.	39.	0.	406.	1397.	COAL-FGD	1803.	0	0.13	0.07	0.58
2 STM088 STM-TURB-8 POWR		0.	-694.	2758.	2081.	263.	77.	-1208.	0.	2758.	COAL-AFB	2758.	0	-0.34	0.10	0.38
2 STM088 STM-TURB-8 HEAT		0.	260.	1397.	1054.	133.	39.	0.	406.	1397.	COAL-AFB	1803.	0	0.13	0.07	0.58
3 PFBSTM PFB-STMTB- POWR		0.	500.	1327.	854.	263.	77.	235.	0.	1563.	COAL-PFB	1563.	0	0.24	0.17	0.67
3 PFBSTM PFB-STMTB- HEAT		0.	618.	1638.	1054.	325.	95.	0.	-193.	1638.	COAL-PFB	1446.	0	0.27	0.20	0.64
4 TISTMT TI-STMTB-1 POWR		0.	505.	1061.	631.	263.	77.	498.	0.	1559.	RESIDUAL	1559.	0	0.24	0.17	0.68
4 TISTMT TI-STMTB-1 HEAT		0.	843.	1772.	1054.	440.	129.	0.	-552.	1772.	RESIDUAL	1220.	0	0.32	0.25	0.59
4 TISTMT TI-STMTB-1 POWR		0.	505.	1061.	631.	263.	77.	498.	0.	1559.	COAL	1559.	0	0.24	0.17	0.68
4 TISTMT TI-STMTB-1 HEAT		0.	843.	1772.	1054.	440.	129.	0.	-552.	1772.	COAL	1220.	0	0.32	0.25	0.59
5 TIHRSG THERMIONIC POWR		0.	191.	1872.	1209.	263.	77.	-182.	0.	1872.	RESIDUAL	1872.	0	0.09	0.14	0.56
5 TIHRSG THERMIONIC HEAT		0.	325.	1632.	1054.	230.	67.	0.	106.	1632.	RESIDUAL	1738.	0	0.16	0.13	0.61
5 TIHRSG THERMIONIC POWR		0.	191.	1872.	1209.	263.	77.	-182.	0.	1872.	COAL	1872.	0	0.09	0.14	0.56
5 TIHRSG THERMIONIC HEAT		0.	325.	1632.	1054.	230.	67.	0.	106.	1632.	COAL	1738.	0	0.16	0.13	0.61
6 STIRL STIRLING-1 POWR		0.	365.	1045.	499.	263.	77.	653.	0.	1699.	DISTILLA	1699.	0	0.18	0.16	0.62
6 STIRL STIRLING-1 HEAT		0.	770.	2209.	1054.	557.	163.	0.	-916.	2209.	DISTILLA	1293.	0	0.26	0.25	0.48

ORIGINAL PAGE 1  
OF POOR QUALITY

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28002 MW 77.20 PROCESS MILLIONS BTU/HR 1054.0 PROCESS TEMP(F) 366. PRODUCT CHEM HOURS PER YEAR 8760.

UTILITY FUEL		COAL	POWER TO HEAT RATIO 0.250										WASTE FUEL EQV BTU*10**6= 0. HOT WATER BTU*10**6= 0.			
WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL 10**6 BTU/HR	SITE FUEL USED	NET* TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR		
6 STIRL	STIRLING-1 POWR	0.	365.	1045.	499.	263.	77.	653.	0.	1699.	RESIDUAL	1699.	0	0.18	0.16	0.62
6 STIRL	STIRLING-1 HEAT	0.	770.	2209.	1054.	557.	163.	0.	-916.	2209.	RESIDUAL	1293.	0	0.26	0.25	0.48
6 STIRL	STIRLING-1 POWR	0.	365.	1045.	499.	263.	77.	653.	0.	1699.	COAL	1699.	0	0.18	0.16	0.62
6 STIRL	STIRLING-1 HEAT	0.	770.	2209.	1054.	557.	163.	0.	-916.	2209.	COAL	1293.	0	0.26	0.25	0.48
7 HEGT85	HELIUM-GT- POWR	0.	117.	821.	97.	263.	77.	1126.	0.	1946.	COAL-AFB	1946.	0	0.06	0.14	0.54
7 HEGT85	HELIUM-GT- HEAT	0.	1268.	8915.	1054.	2862.	839.	0.	-8119.	8915.	COAL-AFB	795.	0	0.12	0.32	0.12
8 HEGT60	HELIUM-GT- POWR	0.	154.	1017.	296.	263.	77.	892.	0.	1909.	COAL-AFB	1909.	0	0.07	0.14	0.55
8 HEGT60	HELIUM-GT- HEAT	0.	549.	3627.	1054.	939.	275.	0.	-2112.	3627.	COAL-AFB	1514.	0	0.13	0.26	0.29
9 HEGT00	HELIUM-GT- POWR	0.	186.	1497.	731.	263.	77.	380.	0.	1877.	COAL-AFB	1877.	0	0.09	0.14	0.56
9 HEGT00	HELIUM-GT- HEAT	0.	269.	2158.	1054.	380.	111.	0.	-364.	2158.	COAL-AFB	1794.	0	0.11	0.18	0.49
10 FCMCCL	FUEL-CL-MO POWR	0.	439.	866.	410.	263.	77.	757.	0.	1624.	COAL	1624.	10	0.21	0.16	0.65
10 FCMCCL	FUEL-CL-MO HEAT	0.	1129.	2227.	1054.	677.	198.	0.	-1292.	2227.	COAL	934.	0	0.34	0.30	0.47
11 FCSTCL	FUEL-CL-ST POWR	0.	455.	700.	282.	263.	77.	909.	0.	1608.	COAL	1608.	10	0.22	0.16	0.66
11 FCSTCL	FUEL-CL-ST HEAT	0.	1702.	2618.	1054.	986.	289.	0.	-2257.	2618.	COAL	361.	0	0.39	0.38	0.40
12 IGGTST	INT-GAS-GT POWR	0.	357.	948.	409.	263.	77.	758.	0.	1706.	COAL	1706.	10	0.17	0.15	0.62
12 IGGTST	INT-GAS-GT HEAT	0.	919.	2440.	1054.	678.	199.	0.	-1296.	2440.	COAL	1144.	0	0.27	0.28	0.43
13 GTSOAR	GT-HRSG-10 POWR	0.	368.	908.	385.	263.	77.	787.	0.	1695.	RESIDUAL	1695.	0	0.18	0.16	0.62
13 GTSOAR	GT-HRSG-10 HEAT	0.	1007.	2486.	1054.	721.	211.	0.	-1429.	2486.	RESIDUAL	1056.	0	0.29	0.29	0.42
14 GTAC08	GT-HRSG-08 POWR	0.	438.	976.	502.	263.	77.	649.	0.	1625.	RESIDUAL	1625.	0	0.21	0.16	0.65
14 GTAC08	GT-HRSG-08 HEAT	0.	920.	2048.	1054.	553.	162.	0.	-905.	2048.	RESIDUAL	1143.	0	0.31	0.27	0.51
15 GTAC12	GT-HRSG-12 POWR	0.	431.	864.	401.	263.	77.	768.	0.	1632.	RESIDUAL	1632.	0	0.21	0.16	0.65
15 GTAC12	GT-HRSG-12 HEAT	0.	1134.	2271.	1054.	693.	203.	0.	-1341.	2271.	RESIDUAL	930.	0	0.33	0.31	0.46
16 GTAC16	GT-HRSG-16 POWR	0.	423.	815.	353.	263.	77.	825.	0.	1641.	RESIDUAL	1641.	0	0.20	0.16	0.64
16 GTAC16	GT-HRSG-16 HEAT	0.	1263.	2437.	1054.	787.	231.	0.	-1637.	2437.	RESIDUAL	800.	0	0.34	0.32	0.43
17 GTWC16	GT-HRSG-16 POWR	0.	385.	836.	338.	263.	77.	842.	0.	1678.	RESIDUAL	1678.	0	0.19	0.16	0.63
17 GTWC16	GT-HRSG-16 HEAT	0.	1199.	2605.	1054.	820.	240.	0.	-1741.	2605.	RESIDUAL	864.	0	0.32	0.32	0.40



DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 88

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28002 MW 77.20 PROCESS MILLIONS BTU/HR 1054.0 PROCESS TEMP(F) 366. PRODUCT CHEM HOURS PER YEAR 8760.

POWER TO HEAT RATIO 0.250

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET* TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
18 CC1626 GTST-16/28	POWR	0.	378.	707.	223.	263.	77.	978.	0.	1685.	RESIDUAL	1685.	0	0.18	0.16	0.63
18 CC1626 GTST-16/28	HEAT	0.	1788.	3344.	1054.	1246.	365.	0.	-3070.	3344.	RESIDUAL	275.	0	0.35	0.37	0.32
19 CC1622 GTST-16/22	POWR	0.	397.	718.	248.	263.	77.	948.	0.	1666.	RESIDUAL	1666.	0	0.19	0.16	0.63
19 CC1622 GTST-16/22	HEAT	0.	1687.	3051.	1054.	1119.	328.	0.	-2675.	3051.	RESIDUAL	376.	0	0.36	0.37	0.35
20 CC1222 GTST-12/22	POWR	0.	401.	716.	249.	263.	77.	946.	0.	1662.	RESIDUAL	1662.	0	0.19	0.16	0.63
20 CC1222 GTST-12/22	HEAT	0.	1693.	3025.	1054.	1113.	326.	0.	-2654.	3025.	RESIDUAL	370.	0	0.36	0.37	0.35
21 CC0822 GTST-08/22	POWR	0.	430.	764.	315.	263.	77.	869.	0.	1634.	RESIDUAL	1634.	0	0.21	0.16	0.65
21 CC0822 GTST-08/22	HEAT	0.	1437.	2556.	1054.	881.	258.	0.	-1930.	2556.	RESIDUAL	626.	0	0.36	0.34	0.41
22 ST1015 STIG-15-16	POWR	0.	142.	691.	9.	263.	77.	1229.	0.	1921.	RESIDUAL	1921.	0	0.07	0.14	0.55
22 ST1015 STIG-15-16	HEAT	0.	16695.	81077.	1054.	30890.	9053.	0.	-95709.	81077.	RESIDUAL	-14632.	0	0.17	0.38	0.01
23 ST1010 STIG-10-16	POWR	0.	204.	734.	97.	263.	77.	1126.	0.	1859.	RESIDUAL	1859.	0	0.10	0.14	0.57
23 ST1010 STIG-10-16	HEAT	0.	2212.	7955.	1054.	2857.	837.	0.	-8104.	7955.	RESIDUAL	-149.	0	0.22	0.36	0.13
24 ST101S STIG-1S-16	POWR	0.	232.	786.	166.	263.	77.	1045.	0.	1831.	RESIDUAL	1831.	0	0.11	0.14	0.58
24 ST101S STIG-1S-16	HEAT	0.	1478.	5000.	1054.	1676.	491.	0.	-4414.	5000.	RESIDUAL	586.	0	0.23	0.34	0.21
25 DEADV3 DIESEL-ADV	POWR	0.	284.	710.	146.	263.	77.	1069.	0.	1779.	RESIDUAL	1779.	0	0.14	0.15	0.59
25 DEADV3 DIESEL-ADV	HEAT	0.	2059.	5142.	1054.	1908.	559.	0.	-5138.	5142.	RESIDUAL	4.	0	0.29	0.37	0.20
26 DEADV2 DIESEL-ADV	POWR	0.	325.	710.	180.	263.	77.	1028.	0.	1738.	RESIDUAL	1738.	1	0.16	0.15	0.61
26 DEADV2 DIESEL-ADV	HEAT	0.	1901.	4150.	1054.	1540.	451.	0.	-3988.	4150.	RESIDUAL	162.	1	0.31	0.37	0.25
27 DEADV1 DIESEL-ADV	POWR	0.	440.	710.	278.	263.	77.	913.	0.	1623.	RESIDUAL	1623.	1	0.21	0.16	0.65
27 DEADV1 DIESEL-ADV	HEAT	0.	1670.	2696.	1054.	1000.	293.	0.	-2302.	2696.	RESIDUAL	394.	1	0.38	0.37	0.39
28 DEHTPM ADV-DIESEL	POWR	0.	424.	805.	345.	263.	77.	834.	0.	1639.	RESIDUAL	1639.	0	0.21	0.16	0.64
28 DEHTPM ADV-DIESEL	HEAT	0.	1294.	2460.	1054.	804.	236.	0.	-1691.	2460.	RESIDUAL	769.	0	0.34	0.33	0.43
29 DES0A3 DIESEL-SOA	POWR	0.	240.	730.	125.	263.	77.	1093.	0.	1823.	DISTILLA	1823.	0	0.12	0.14	0.58
29 DES0A3 DIESEL-SOA	HEAT	0.	2030.	6164.	1054.	2225.	652.	0.	-6131.	6164.	DISTILLA	33.	0	0.25	0.36	0.17
29 DES0A3 DIESEL-SOA	POWR	0.	240.	730.	125.	263.	77.	1093.	0.	1823.	RESIDUAL	1823.	0	0.12	0.14	0.58
29 DES0A3 DIESEL-SOA	HEAT	0.	2030.	6164.	1054.	2225.	652.	0.	-6131.	6164.	RESIDUAL	33.	0	0.25	0.36	0.17

HONEYWELL PAGE PRINTING SYSTEM- P188-02

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 89

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28002 MW 77.20 PROCESS MILLIONS BTU/HR 1054.0 PROCESS TEMP(F) 366. PRODUCT CHEM HOURS PER YEAR 8760.

POWER TO HEAT RATIO 0.250

WASTE FUEL EQV BTU\*10\*\*6= 0.

HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
30 DES0A2 DIESEL-S0A POWR		0.	282.	730.	161.	263.	77.	1051.	0.	1781.DISTILLA		1781.	1	0.14	0.15	0.59
30 DES0A2 DIESEL-S0A HEAT		0.	1854.	4791.	1054.	1730.	507.	0.	-4582.	4791.DISTILLA		209.	1	0.28	0.36	0.22
30 DES0A2 DIESEL-S0A POWR		0.	282.	730.	161.	263.	77.	1051.	0.	1781.RESIDUAL		1781.	1	0.14	0.15	0.59
30 DES0A2 DIESEL-S0A HEAT		0.	1854.	4791.	1054.	1730.	507.	0.	-4582.	4791.RESIDUAL		209.	1	0.28	0.36	0.22
31 DES0A1 DIESEL-S0A POWR		0.	438.	730.	293.	263.	77.	896.	0.	1625.DISTILLA		1625.	1	0.21	0.16	0.65
31 DES0A1 DIESEL-S0A HEAT		0.	1577.	2628.	1054.	949.	278.	0.	-2142.	2628.DISTILLA		486.	1	0.37	0.36	0.40
31 DES0A1 DIESEL-S0A POWR		0.	438.	730.	293.	263.	77.	896.	0.	1625.RESIDUAL		1625.	1	0.21	0.16	0.65
31 DES0A1 DIESEL-S0A HEAT		0.	1577.	2628.	1054.	949.	278.	0.	-2142.	2628.RESIDUAL		486.	1	0.37	0.36	0.40
32 GTS0AD GT-HRS0-10 POWR		0.	410.	902.	415.	263.	77.	751.	0.	1653.DISTILLA		1653.	0	0.20	0.16	0.64
32 GTS0AD GT-HRS0-10 HEAT		0.	1040.	2288.	1054.	668.	196.	0.	-1265.	2288.DISTILLA		1023.	0	0.31	0.29	0.46
33 GTRA08 GT-85RE-08 POWR		0.	377.	738.	248.	263.	77.	948.	0.	1686.DISTILLA		1686.	0	0.18	0.16	0.63
33 GTRA08 GT-85RE-08 HEAT		0.	1602.	3135.	1054.	1119.	328.	0.	-2674.	3135.DISTILLA		461.	0	0.34	0.36	0.34
34 GTRA12 GT-85RE-12 POWR		0.	387.	736.	255.	263.	77.	940.	0.	1676.DISTILLA		1676.	0	0.19	0.16	0.63
34 GTRA12 GT-85RE-12 HEAT		0.	1602.	3044.	1054.	1090.	319.	0.	-2583.	3044.DISTILLA		462.	0	0.34	0.36	0.35
35 GTRA16 GT-85RE-16 POWR		0.	390.	755.	273.	263.	77.	918.	0.	1673.DISTILLA		1673.	0	0.19	0.16	0.63
35 GTRA16 GT-85RE-16 HEAT		0.	1504.	2909.	1054.	1015.	298.	0.	-2349.	2909.DISTILLA		560.	0	0.34	0.35	0.36
36 GTR203 GT-60RE-08 POWR		0.	389.	823.	331.	263.	77.	851.	0.	1674.DISTILLA		1674.	0	0.19	0.16	0.63
36 GTR203 GT-60RE-08 HEAT		0.	1240.	2621.	1054.	839.	246.	0.	-1798.	2621.DISTILLA		823.	0	0.32	0.32	0.40
37 GTR212 GT-60RE-12 POWR		0.	388.	798.	309.	263.	77.	877.	0.	1675.DISTILLA		1675.	0	0.19	0.16	0.63
37 GTR212 GT-60RE-12 HEAT		0.	1325.	2726.	1054.	900.	264.	0.	-1988.	2726.DISTILLA		738.	0	0.33	0.33	0.39
38 GTR216 GT-60RE-16 POWR		0.	396.	782.	301.	263.	77.	885.	0.	1668.DISTILLA		1668.	0	0.19	0.16	0.63
38 GTR216 GT-60RE-16 HEAT		0.	1385.	2737.	1054.	922.	270.	0.	-2060.	2737.DISTILLA		677.	0	0.34	0.34	0.39
39 GTRW08 GT-85RE-08 POWR		0.	318.	750.	208.	263.	77.	995.	0.	1746.DISTILLA		1746.	0	0.15	0.15	0.60
39 GTRW08 GT-85RE-08 HEAT		0.	1608.	3800.	1054.	1334.	391.	0.	-3345.	3800.DISTILLA		455.	0	0.30	0.35	0.28
40 GTRW12 GT-85RE-12 POWR		0.	341.	724.	205.	263.	77.	999.	0.	1722.DISTILLA		1722.	0	0.17	0.15	0.61
40 GTRW12 GT-85RE-12 HEAT		0.	1751.	3718.	1054.	1353.	397.	0.	-3406.	3718.DISTILLA		312.	0	0.32	0.36	0.28

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 90

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28002 MW 77.20 PROCESS MILLIONS BTU/HR 1054.0 PROCESS TEMP(F) 366. PRODUCT CHEM HOURS PER YEAR 8760.

UTILITY FUEL		COAL		POWER TO HEAT RATIO 0.250										WASTE FUEL EQV BTU*10**6=		0.		HOT WATER BTU*10**6=		0.	
WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED-NG 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW	AUX BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR							
41 GTRW16 GT-85RE-16 POWR	0.	346.	738.	222.	263.	77.	979.	0.	1717.	DISTILLA	1717.	0	0.17	0.15	0.61						
41 GTRW16 GT-85RE-16 HEAT	0.	1645.	3506.	1054.	1252.	367.	0.	-3089.	3506.	DISTILLA	418.	0	0.32	0.36	0.30						
42 GTR308 GT-60RE-08 POWR	0.	294.	850.	273.	263.	77.	919.	0.	1769.	DISTILLA	1769.	0	0.14	0.15	0.60						
42 GTR308 GT-60RE-08 HEAT	0.	1137.	3286.	1054.	1019.	299.	0.	-2360.	3286.	DISTILLA	926.	0	0.26	0.31	0.32						
43 GTR312 GT-60RE-12 POWR	0.	353.	770.	255.	263.	77.	940.	0.	1710.	DISTILLA	1710.	0	0.17	0.15	0.62						
43 GTR312 GT-60RE-12 HEAT	0.	1459.	3180.	1054.	1088.	319.	0.	-2576.	3190.	DISTILLA	605.	0	0.31	0.34	0.33						
44 GTR316 GT-60RE-16 POWR	0.	351.	777.	259.	263.	77.	935.	0.	1712.	DISTILLA	1712.	0	0.17	0.15	0.62						
44 GTR316 GT-60RE-16 HEAT	0.	1428.	3158.	1054.	1071.	314.	0.	-2523.	3158.	DISTILLA	636.	0	0.31	0.34	0.33						
45 FCPADS FUEL-CL-PH POWR	0.	269.	693.	118.	263.	77.	1101.	0.	1795.	DISTILLA	1795.	0	0.13	0.15	0.59						
45 FCPADS FUEL-CL-PH HEAT	0.	2403.	6200.	1054.	2356.	691.	0.	-6539.	6200.	DISTILLA	-339.	0	0.28	0.38	0.17						
46 FCMCDS FUEL-CL-MO POWR	0.	359.	639.	149.	263.	77.	1065.	0.	1704.	DISTILLA	1704.	0	0.17	0.15	0.62						
46 FCMCDS FUEL-CL-MO HEAT	0.	2541.	4524.	1054.	1864.	546.	0.	-5001.	4524.	DISTILLA	-477.	0	0.36	0.41	0.23						

11188-02

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28003 MW 97.20 PROCESS MILLIONS BTU/HR 947.0 PROCESS TEMP(F) 366. PRODUCT CHEM HOURS PER YEAR 8760.

UTILITY FUEL		COAL		POWER TO HEAT RATIO 0.350										WASTE FUEL EQV BTU*10**6=		0.		HOT WATER BTU*10**6=		0.	
WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET* TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR							
0 ONOCGN N O C O B O N	0.	0.	0.	0.	0.	0.	1114.	1036.	1114.	COAL-FGD	2151.	0	0.	0.15	0.44						
1 STM141 STM-TURB-1 POWR	0.	-391.	2541.	1829.	352.	97.	-1037.	0.	2541.	RESIDUAL	2541.	0	-0.18	0.13	0.37						
1 STM141 STM-TURB-1 HEAT	0.	335.	1316.	947.	172.	50.	0.	500.	1316.	RESIDUAL	1816.	0	0.16	0.09	0.52						
1 STM141 STM-TURB-1 POWR	0.	-391.	2541.	1829.	332.	97.	-1037.	0.	2541.	COAL-FGD	2541.	0	-0.18	0.13	0.37						
1 STM141 STM-TURB-1 HEAT	0.	335.	1316.	947.	172.	50.	0.	500.	1316.	COAL-FGD	1816.	0	0.16	0.09	0.52						
1 STM141 STM-TURB-1 POWR	0.	-391.	2541.	1829.	332.	97.	-1037.	0.	2541.	COAL-AFB	2541.	0	-0.18	0.13	0.37						
1 STM141 STM-TURB-1 HEAT	0.	335.	1316.	947.	172.	50.	0.	500.	1316.	COAL-AFB	1816.	0	0.16	0.09	0.52						
2 STM088 STM-TURB-8 POWR	0.	-1322.	3472.	2620.	332.	97.	-1968.	0.	3472.	RESIDUAL	3472.	0	-0.61	0.10	0.27						
2 STM088 STM-TURB-8 HEAT	0.	234.	1255.	947.	120.	35.	0.	662.	1255.	RESIDUAL	1917.	0	0.11	0.06	0.49						
2 STM088 STM-TURB-8 POWR	0.	-1322.	3472.	2620.	332.	97.	-1968.	0.	3472.	COAL-FGD	3472.	0	-0.61	0.10	0.27						
2 STM088 STM-TURB-8 HEAT	0.	234.	1255.	947.	120.	35.	0.	662.	1255.	COAL-FGD	1917.	0	0.11	0.06	0.49						
2 STM088 STM-TURB-8 POWR	0.	-1322.	3472.	2620.	332.	97.	-1968.	0.	3472.	COAL-AFB	3472.	0	-0.61	0.10	0.27						
2 STM088 STM-TURB-8 HEAT	0.	234.	1255.	947.	120.	35.	0.	662.	1255.	COAL-AFB	1917.	0	0.11	0.06	0.49						
3 PFBSTM PFB-STMTB- POWR	0.	479.	1671.	1075.	332.	97.	-151.	0.	1671.	COAL-PFB	1671.	0	0.22	0.20	0.57						
3 PFBSTM PFB-STMTB- HEAT	0.	555.	1472.	947.	292.	86.	0.	124.	1472.	COAL-PFB	1596.	0	0.26	0.18	0.59						
4 TISTMT TI-STMTB-1 POWR	0.	635.	1336.	795.	332.	97.	179.	0.	1515.	RESIDUAL	1515.	0	0.30	0.22	0.62						
4 TISTMT TI-STMTB-1 HEAT	0.	757.	1592.	947.	395.	116.	0.	-199.	1592.	RESIDUAL	1393.	0	0.32	0.25	0.59						
4 TISTMT TI-STMTB-1 POWR	0.	635.	1336.	795.	332.	97.	179.	0.	1515.	COAL	1515.	0	0.30	0.22	0.62						
4 TISTMT TI-STMTB-1 HEAT	0.	757.	1592.	947.	395.	116.	0.	-199.	1592.	COAL	1393.	0	0.32	0.25	0.59						
5 TIHRSG THERMIONIC POWR	0.	-207.	2357.	1522.	332.	97.	-677.	0.	2357.	RESIDUAL	2357.	0	-0.10	0.14	0.40						
5 TIHRSG THERMIONIC HEAT	0.	292.	1466.	947.	206.	60.	0.	392.	1466.	RESIDUAL	1858.	0	0.14	0.11	0.51						
5 TIHRSG THERMIONIC POWR	0.	-207.	2357.	1522.	332.	97.	-677.	0.	2357.	COAL	2357.	0	-0.10	0.14	0.40						
5 TIHRSG THERMIONIC HEAT	0.	292.	1466.	947.	206.	60.	0.	392.	1466.	COAL	1858.	0	0.14	0.11	0.51						
6 STIRL STIRLING-1 POWR	0.	459.	1316.	628.	332.	97.	375.	0.	1692.	DISTILLA	1692.	0	0.21	0.20	0.56						
6 STIRL STIRLING-1 HEAT	0.	692.	1985.	947.	500.	147.	0.	-526.	1985.	DISTILLA	1458.	0	0.26	0.25	0.48						

I&amp;SE PEO ADV DESIGN ENGR

## \*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28003 MW 97.20 PROCESS MILLIONS BTU/HR 947.0 PROCESS TEMP(F) 366. PRODUCT CHEM HOURS PER YEAR 8760.

POWER TO HEAT RATIO 0.350

WASTE FUEL EQV BTU=10\*\*6= 0. HOT WATER BTU=10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	NET* TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
6 STIRL STIRLING-1 POWR		0.	459.	1316.	628.	332.	97.	375.	0.	1692.	RESIDUAL 1692.	0	0.21	0.20	0.55
6 STIRL STIRLING-1 HEAT		0.	692.	1985.	947.	500.	147.	0.	-526.	1985.	RESIDUAL 1458.	0	0.26	0.25	0.48
6 STIRL STIRLING-1 POWR		0.	459.	1316.	628.	332.	97.	375.	0.	1692.	COAL 1692.	0	0.21	0.20	0.56
6 STIRL STIRLING-1 HEAT		0.	692.	1985.	947.	500.	147.	0.	-526.	1985.	COAL 1458.	0	0.26	0.25	0.48
7 HEGT85 HELIUM-GT- POWR		0.	147.	1033.	122.	332.	97.	970.	0.	2004.	COAL-AFB 2004.	0	0.07	0.17	0.47
7 HEGT85 HELIUM-GT- HEAT		0.	1139.	8010.	947.	2571.	754.	0.	-6998.	8010.	COAL-AFB 1011.	0	0.12	0.32	0.12
8 HEGT60 HELIUM-GT- POWR		0.	194.	1280.	372.	332.	97.	676.	0.	1957.	COAL-AFB 1957.	0	0.09	0.17	0.48
8 HEGT60 HELIUM-GT- HEAT		0.	493.	3258.	947.	844.	247.	0.	-1601.	3258.	COAL-AFB 1658.	0	0.13	0.26	0.29
9 HEGT00 HELIUM-GT- POWR		0.	235.	1884.	920.	332.	97.	31.	0.	1916.	COAL-AFB 1916.	0	0.11	0.17	0.49
9 HEGT00 HELIUM-GT- HEAT		0.	242.	1939.	947.	341.	100.	0.	-30.	1939.	COAL-AFB 1909.	0	0.11	0.18	0.49
10 FCMCCL FUEL-CL-MO POWR		0.	553.	1091.	516.	332.	97.	507.	0.	1598.	COAL 1598.	10	0.26	0.21	0.59
10 FCMCCL FUEL-CL-MO HEAT		0.	1014.	2001.	947.	608.	178.	0.	-864.	2001.	COAL 1136.	0	0.34	0.30	0.47
11 FCSTCL FUEL-CL-ST POWR		0.	573.	881.	355.	332.	97.	697.	0.	1578.	COAL 1578.	10	0.27	0.21	0.60
11 FCSTCL FUEL-CL-ST HEAT		0.	1530.	2352.	947.	886.	260.	0.	-1731.	2352.	COAL 621.	0	0.39	0.38	0.40
12 IGGTST INT-GAS-GT POWR		0.	450.	1193.	516.	332.	97.	508.	0.	1701.	COAL 1701.	0	0.21	0.19	0.56
12 IGGTST INT-GAS-GT HEAT		0.	826.	2192.	947.	609.	179.	0.	-867.	2192.	COAL 1324.	0	0.27	0.28	0.43
13 GTSOAR GT-HRSG-10 POWR		0.	463.	1144.	485.	332.	97.	544.	0.	1687.	RESIDUAL 1687.	0	0.22	0.20	0.56
13 GTSOAR GT-HRSG-10 HEAT		0.	905.	2233.	947.	648.	190.	0.	-987.	2233.	RESIDUAL 1246.	0	0.29	0.29	0.42
14 GTAC08 GT-HRSG-08 POWR		0.	552.	1228.	632.	332.	97.	371.	0.	1599.	RESIDUAL 1599.	0	0.26	0.21	0.59
14 GTAC08 GT-HRSG-08 HEAT		0.	827.	1840.	947.	497.	146.	0.	-516.	1840.	RESIDUAL 1324.	0	0.31	0.27	0.51
15 GTAC12 GT-HRSG-12 POWR		0.	543.	1087.	505.	332.	97.	520.	0.	1608.	RESIDUAL 1608.	0	0.25	0.21	0.59
15 GTAC12 GT-HRSG-12 HEAT		0.	1018.	2040.	947.	622.	182.	0.	-908.	2040.	RESIDUAL 1132.	0	0.33	0.31	0.46
16 GTAC16 GT-HRSG-16 POWR		0.	532.	1027.	444.	332.	97.	592.	0.	1619.	RESIDUAL 1619.	0	0.25	0.20	0.59
16 GTAC16 GT-HRSG-16 HEAT		0.	1135.	2190.	947.	707.	207.	0.	-1174.	2190.	RESIDUAL 1016.	0	0.34	0.32	0.43
17 GTWC16 GT-HRSG-16 POWR		0.	485.	1053.	426.	332.	97.	613.	0.	1666.	RESIDUAL 1666.	0	0.23	0.20	0.57
17 GTWC16 GT-HRSG-16 HEAT		0.	1078.	2340.	947.	737.	216.	0.	-1287.	2340.	RESIDUAL 1073.	0	0.32	0.32	0.40

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28003 MW 97.20 PROCESS MILLIONS BTU/HR 947.0 PROCESS TEMP(F) 366. PRODUCT CHEM HOURS PER YEAR 8760.

POWER TO HEAT RATIO 0.350

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	AUX MW ELECT	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET* TOTAL* UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
18 CC1626 GTST-16/26 POWR		0.	476.	890.	281.	332.	97.	784.	0.	1674.	RESIDUAL 1674.	0	0.22	0.20	0.57
18 CC1626 GTST-16/26 HEAT		0.	1607.	3005.	947.	1119.	328.	0.	-2461.	3005.	RESIDUAL 544.	0	0.35	0.37	0.32
19 CC1622 GTST-16/22 POWR		0.	500.	904.	312.	332.	97.	747.	0.	1651.	RESIDUAL 1651.	0	0.23	0.20	0.57
19 CC1622 GTST-16/22 HEAT		0.	1516.	2741.	947.	1006.	295.	0.	-2106.	2741.	RESIDUAL 635.	0	0.36	0.37	0.35
20 CC1222 GTST-12/22 POWR		0.	505.	901.	314.	332.	97.	745.	0.	1646.	RESIDUAL 1646.	0	0.23	0.20	0.58
20 CC1222 GTST-12/22 HEAT		0.	1521.	2718.	947.	1000.	293.	0.	-2088.	2718.	RESIDUAL 629.	0	0.36	0.37	0.35
21 CC0822 GTST-08/22 POWR		0.	541.	962.	397.	332.	97.	647.	0.	1610.	RESIDUAL 1610.	0	0.25	0.21	0.59
21 CC0822 GTST-08/22 HEAT		0.	1291.	2297.	947.	791.	232.	0.	-1437.	2297.	RESIDUAL 860.	0	0.36	0.34	0.41
22 STIG15 STIG-15-16 POWR		0.	179.	870.	11.	332.	97.	1101.	0.	1971.	RESIDUAL 1971.	0	0.08	0.17	0.48
22 STIG15 STIG-15-16 HEAT		0.	15000.	72846.	947.	27754.	8134.	0.	-85696.	72846.	RESIDUAL -12850.	0	0.17	0.38	0.01
23 STIG10 STIG-10-16 POWR		0.	257.	924.	122.	332.	97.	970.	0.	1894.	RESIDUAL 1894.	0	0.12	0.18	0.50
23 STIG10 STIG-10-16 HEAT		0.	1987.	7147.	947.	2567.	752.	0.	-6984.	7147.	RESIDUAL 163.	0	0.22	0.36	0.13
24 STIG1S STIG-1S-16 POWR		0.	292.	989.	209.	332.	97.	869.	0.	1858.	RESIDUAL 1858.	0	0.14	0.18	0.51
24 STIG1S STIG-1S-16 HEAT		0.	1328.	4492.	947.	1506.	441.	0.	-3669.	4492.	RESIDUAL 823.	0	0.23	0.34	0.21
25 DEADV3 DIESEL-ADV POWR		0.	358.	894.	183.	332.	97.	899.	0.	1792.	RESIDUAL 1792.	0	0.17	0.19	0.53
25 DEADV3 DIESEL-ADV HEAT		0.	1850.	4620.	947.	1714.	502.	0.	-4320.	4620.	RESIDUAL 300.	0	0.29	0.37	0.20
26 DEADV2 DIESEL-ADV POWR		0.	410.	894.	227.	332.	97.	847.	0.	1741.	RESIDUAL 1741.	1	0.19	0.19	0.54
26 DEADV2 DIESEL-ADV HEAT		0.	1708.	3728.	947.	1383.	405.	0.	-3286.	3728.	RESIDUAL 442.	1	0.31	0.37	0.25
27 DEADV1 DIESEL-ADV POWR		0.	554.	894.	350.	332.	97.	703.	0.	1597.	RESIDUAL 1597.	1	0.26	0.21	0.59
27 DEADV1 DIESEL-ADV HEAT		0.	1500.	2422.	947.	899.	263.	0.	-1772.	2422.	RESIDUAL 650.	1	0.38	0.37	0.39
28 DEHTPM ADV-DIESEL POWR		0.	533.	1014.	435.	332.	97.	603.	0.	1617.	RESIDUAL 1617.	0	0.25	0.21	0.59
28 DEHTPM ADV-DIESEL HEAT		0.	1163.	2210.	947.	723.	212.	0.	-1222.	2210.	RESIDUAL 988.	0	0.34	0.33	0.43
29 DESOA3 DIESEL-SOA POWR		0.	303.	919.	157.	332.	97.	929.	0.	1848.	DISTILLA 1848.	0	0.14	0.18	0.51
29 DESOA3 DIESEL-SOA HEAT		0.	1824.	5539.	947.	1999.	586.	0.	-5212.	5539.	DISTILLA 327.	0	0.25	0.36	0.17
29 DESOA3 DIESEL-SOA POWR		0.	303.	919.	157.	332.	97.	929.	0.	1848.	RESIDUAL 1848.	0	0.14	0.18	0.51
29 DESOA3 DIESEL-SOA HEAT		0.	1824.	5539.	947.	1999.	586.	0.	-5212.	5539.	RESIDUAL 327.	0	0.25	0.36	0.17

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 94

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28003 MW 97.20 PROCESS MILLIONS BTU/HR 947.0 PROCESS TEMP(F) 366. PRODUCT CHEM HOURS PER YEAR 8760.

POWER TO HEAT RATIO 0.350

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	SAVED= FUEL NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
30 DES0A2 DIESEL-S0A POWR		0.	355.	919.	202.	332.	97.	876.	0.	1795.	DISTILLA	1795.	1	0.17	0.18	0.53
30 DES0A2 DIESEL-S0A HEAT		0.	1666.	4305.	947.	1554.	455.	0.	-3820.	4305.	DISTILLA	485.	1	0.28	0.36	0.22
30 DES0A2 DIESEL-S0A POWR		0.	355.	919.	202.	332.	97.	876.	0.	1795.	RESIDUAL	1795.	1	0.17	0.18	0.53
30 DES0A2 DIESEL-S0A HEAT		0.	1666.	4305.	947.	1554.	455.	0.	-3820.	4305.	RESIDUAL	485.	1	0.28	0.36	0.22
31 DES0A1 DIESEL-S0A POWR		0.	551.	919.	368.	332.	97.	681.	0.	1599.	DISTILLA	1599.	1	0.26	0.21	0.59
31 DES0A1 DIESEL-S0A HEAT		0.	1417.	2362.	947.	853.	250.	0.	-1628.	2362.	DISTILLA	734.	1	0.37	0.36	0.40
31 DES0A1 DIESEL-S0A POWR		0.	551.	919.	368.	332.	97.	681.	0.	1599.	RESIDUAL	1599.	1	0.26	0.21	0.59
31 DES0A1 DIESEL-S0A HEAT		0.	1417.	2362.	947.	853.	250.	0.	-1628.	2362.	RESIDUAL	734.	1	0.37	0.36	0.40
32 GTS0AD GT-HRSG-10 POWR		0.	516.	1136.	523.	332.	97.	499.	0.	1634.	DISTILLA	1634.	0	0.24	0.20	0.58
32 GTS0AD GT-HRSG-10 HEAT		0.	934.	2056.	947.	600.	176.	0.	-840.	2056.	DISTILLA	1216.	0	0.31	0.29	0.46
33 GTRA08 GT-85RE-08 POWR		0.	475.	929.	312.	332.	97.	747.	0.	1676.	DISTILLA	1676.	0	0.22	0.20	0.57
33 GTRA08 GT-85RE-08 HEAT		0.	1440.	2816.	947.	1005.	295.	0.	-2106.	2816.	DISTILLA	711.	0	0.34	0.36	0.34
34 GTRA12 GT-85RE-12 POWR		0.	487.	926.	321.	332.	97.	737.	0.	1663.	DISTILLA	1663.	0	0.23	0.20	0.57
34 GTRA12 GT-85RE-12 HEAT		0.	1439.	2735.	947.	979.	287.	0.	-2024.	2735.	DISTILLA	712.	0	0.34	0.36	0.35
35 GTRA16 GT-85RE-16 POWR		0.	491.	950.	344.	332.	97.	709.	0.	1659.	DISTILLA	1659.	0	0.23	0.20	0.57
35 GTRA16 GT-85RE-16 HEAT		0.	1351.	2613.	947.	912.	267.	0.	-1814.	2613.	DISTILLA	800.	0	0.34	0.35	0.36
36 GTR208 GT-60RE-08 POWR		0.	490.	1036.	417.	332.	97.	624.	0.	1660.	DISTILLA	1660.	0	0.23	0.20	0.57
36 GTR208 GT-60RE-08 HEAT		0.	1114.	2355.	947.	754.	221.	0.	-1319.	2355.	DISTILLA	1036.	0	0.32	0.32	0.40
37 GTR212 GT-60RE-12 POWR		0.	489.	1005.	389.	332.	97.	657.	0.	1662.	DISTILLA	1662.	0	0.23	0.20	0.57
37 GTR212 GT-60RE-12 HEAT		0.	1191.	2449.	947.	808.	237.	0.	-1490.	2449.	DISTILLA	960.	0	0.33	0.33	0.39
38 GTR216 GT-60RE-16 POWR		0.	498.	984.	379.	332.	97.	668.	0.	1652.	DISTILLA	1652.	0	0.23	0.20	0.57
38 GTR216 GT-60RE-16 HEAT		0.	1245.	2459.	947.	829.	243.	0.	-1554.	2459.	DISTILLA	906.	0	0.34	0.34	0.39
39 GTRW08 GT-85RE-08 POWR		0.	400.	945.	262.	332.	97.	806.	0.	1751.	DISTILLA	1751.	0	0.19	0.19	0.54
39 GTRW08 GT-85RE-08 HEAT		0.	1445.	3414.	947.	1198.	351.	0.	-2709.	3414.	DISTILLA	706.	0	0.30	0.35	0.28
40 GTRW12 GT-85RE-12 POWR		0.	429.	911.	258.	332.	97.	810.	0.	1721.	DISTILLA	1721.	0	0.20	0.19	0.55
40 GTRW12 GT-85RE-12 HEAT		0.	1573.	3340.	947.	1216.	356.	0.	-2763.	3340.	DISTILLA	577.	0	0.32	0.36	0.28

HONEYWELL PAGE PRINTING SYSTEM- P1188-02

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 95

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28003 MW 97.20 PROCESS MILLIONS BTU/HR 947.0 PROCESS TEMP(F) 366. PRODUCT CHEM HOURS PER YEAR 8760.

POWER TO HEAT RATIO 0.350

UTILITY FUEL COAL

WASTE FUEL EQV BTU\*10\*\*6= 0.

HOT WATER BTU\*10\*\*6= 0.

			WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41	GTRW16	GT-85RE-16	0.	436.	929.	279.	332.	97.	786.	0.	1715.	DISTILLA	1715.	0	0.20	0.19	0.55
41	GTRW16	GT-85RE-16	0.	1478.	3150.	947.	1125.	330.	0.	-2478.	3150.	DISTILLA	672.	0	0.32	0.36	0.30
42	GTR308	GT-60RE-08	0.	370.	1070.	343.	332.	97.	710.	0.	1780.	DISTILLA	1780.	0	0.17	0.19	0.53
42	GTR308	GT-60RE-08	0.	1022.	2952.	947.	915.	268.	0.	-1823.	2952.	DISTILLA	1129.	0	0.26	0.31	0.32
43	GTR312	GT-60RE-12	0.	445.	970.	321.	332.	97.	736.	0.	1706.	DISTILLA	1706.	0	0.21	0.19	0.56
43	GTR312	GT-60RE-12	0.	1311.	2857.	947.	977.	286.	0.	-2017.	2857.	DISTILLA	840.	0	0.31	0.34	0.33
44	GTR316	GT-60RE-16	0.	442.	978.	326.	332.	97.	730.	0.	1708.	DISTILLA	1708.	0	0.21	0.19	0.55
44	GTR316	GT-60RE-16	0.	1283.	2838.	947.	962.	282.	0.	-1970.	2838.	DISTILLA	868.	0	0.31	0.34	0.33
45	FCPADS	FUEL-CL-PH	0.	338.	873.	148.	332.	97.	940.	0.	1812.	DISTILLA	1812.	0	0.16	0.18	0.52
45	FCPADS	FUEL-CL-PH	0.	2159.	5571.	947.	2117.	620.	0.	-5579.	5571.	DISTILLA	-8.	0	0.28	0.38	0.17
46	FCMCDS	FUEL-CL-MO	0.	452.	805.	188.	332.	97.	893.	0.	1698.	DISTILLA	1698.	0	0.21	0.20	0.56
46	FCMCDS	FUEL-CL-MO	0.	2283.	4064.	947.	1675.	491.	0.	-4196.	4064.	DISTILLA	-132.	0	0.36	0.41	0.23



DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 96

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28121 MW 120.00 PROCESS MILLIONS BTU/HR 265.0 PROCESS TEMP(F) 338. PRODUCT CHLORINE-CAU HOURS PER YEAR 8500.

POWER TO HEAT RATIO 1.545

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET* TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
0	ONOCGN N O C O O O N	0.	0.	0.	0.	0.	0.	312.	1280.	312.	COAL-FGD	1591.	0	0.	0.26	0.17
1	STM141 STM-TURB-1 POWR	0.	-937.	2528.	1740.	409.	120.	-1735.	0.	2528.	RESIDUAL	2528.	0	-0.59	0.16	0.10
1	STM141 STM-TURB-1 HEAT	0.	122.	385.	265.	62.	18.	0.	1085.	385.	RESIDUAL	1470.	0	0.08	0.04	0.18
1	STM141 STM-TURB-1 POWR	0.	-937.	2528.	1740.	409.	120.	-1735.	0.	2528.	COAL-FGD	2528.	0	-0.59	0.16	0.10
1	STM141 STM-TURB-1 HEAT	0.	122.	385.	265.	62.	18.	0.	1085.	385.	COAL-FGD	1470.	0	0.08	0.04	0.18
1	STM141 STM-TURB-1 POWR	0.	-937.	2528.	1740.	409.	120.	-1735.	0.	2528.	COAL-AFB	2528.	0	-0.59	0.16	0.10
1	STM141 STM-TURB-1 HEAT	0.	122.	385.	265.	62.	18.	0.	1085.	385.	COAL-AFB	1470.	0	0.08	0.04	0.18
2	STM088 STM-TURB-8 POWR	0.	-1614.	3205.	2315.	409.	120.	-2412.	0.	3205.	RESIDUAL	3205.	0	-1.01	0.13	0.08
2	STM088 STM-TURB-8 HEAT	0.	91.	367.	265.	47.	14.	0.	1133.	367.	RESIDUAL	1500.	0	0.06	0.03	0.18
2	STM088 STM-TURB-8 POWR	0.	-1614.	3205.	2315.	409.	120.	-2412.	0.	3205.	COAL-FGD	3205.	0	-1.01	0.13	0.08
2	STM088 STM-TURB-8 HEAT	0.	91.	367.	265.	47.	14.	0.	1133.	367.	COAL-FGD	1500.	0	0.06	0.03	0.18
2	STM088 STM-TURB-8 POWR	0.	-1614.	3205.	2315.	409.	120.	-2412.	0.	3205.	COAL-AFB	3205.	0	-1.01	0.13	0.08
2	STM088 STM-TURB-8 HEAT	0.	91.	367.	265.	47.	14.	0.	1133.	367.	COAL-AFB	1500.	0	0.06	0.03	0.18
3	PFBSTM PFB-STMTB- POWR	0.	-219.	1810.	1118.	409.	120.	-1004.	0.	1810.	COAL-PFB	1810.	0	-0.14	0.23	0.15
3	PFBSTM PFB-STMTB- HEAT	0.	186.	429.	265.	97.	28.	0.	976.	429.	COAL-PFB	1405.	0	0.12	0.07	0.19
4	TISTMT TI-STMTB-1 POWR	0.	99.	1492.	848.	409.	120.	-686.	0.	1492.	RESIDUAL	1492.	0	0.06	0.27	0.18
4	TISTMT TI-STMTB-1 HEAT	0.	245.	466.	265.	128.	37.	0.	880.	466.	RESIDUAL	1346.	0	0.15	0.10	0.20
4	TISTMT TI-STMTB-1 POWR	0.	99.	1492.	848.	409.	120.	-686.	0.	1492.	COAL	1492.	0	0.06	0.27	0.18
4	TISTMT TI-STMTB-1 HEAT	0.	245.	466.	265.	128.	37.	0.	880.	466.	COAL	1346.	0	0.15	0.10	0.20
5	TIHRSG THERMIONIC POWR	0.	-1319.	2910.	1905.	409.	120.	-1930.	0.	2910.	RESIDUAL	2910.	0	-0.83	0.14	0.09
5	TIHRSG THERMIONIC HEAT	0.	85.	405.	265.	57.	17.	0.	1102.	405.	RESIDUAL	1506.	0	0.05	0.04	0.18
5	TIHRSG THERMIONIC POWR	0.	-1319.	2910.	1905.	409.	120.	-1930.	0.	2910.	COAL	2910.	0	-0.83	0.14	0.09
5	TIHRSG THERMIONIC HEAT	0.	85.	405.	265.	57.	17.	0.	1102.	405.	COAL	1506.	0	0.05	0.04	0.18
6	STIRL STIRLING-1 POWR	0.	7.	1584.	746.	409.	120.	-565.	0.	1584.	DISTILLA	1584.	0	0.00	0.26	0.17
6	STIRL STIRLING-1 HEAT	0.	203.	563.	265.	146.	43.	0.	825.	563.	DISTILLA	1388.	0	0.13	0.10	0.19

HONEYWELL PAGE PRINTING SYSTEM- P1188-02

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28121 MW 120.00 PROCESS MILLIONS BTU/HR 265.0 PROCESS TEMP(F) 338. PRODUCT CHLORINE-CAU HOURS PER YEAR 8500.

UTILITY FUEL		COAL		POWER TO HEAT RATIO 1.545										WASTE FUEL EQV BTU*10**6=		0.		HOT WATER BTU*10**6=		0.	
		WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED- NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET+ TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR					
6	STIRL STIRLING-1 POWR	0.	7.	1584.	746.	409.	120.	-565.	0.	1584.	RESIDUAL	1584.	0	0.00	0.26	0.17					
6	STIRL STIRLING-1 HEAT	0.	203.	563.	265.	146.	43.	0.	825.	563.	RESIDUAL	1388.	0	0.13	0.10	0.19					
6	STIRL STIRLING-1 POWR	0.	7.	1584.	746.	409.	120.	-565.	0.	1584.	COAL	1584.	0	0.00	0.26	0.17					
6	STIRL STIRLING-1 HEAT	0.	203.	563.	265.	146.	43.	0.	825.	563.	COAL	1388.	0	0.13	0.10	0.19					
7	HEGT85 HELIUM-GT- POWR	0.	243.	1276.	203.	409.	120.	72.	0.	1348.	COAL-AFB	1348.	0	0.15	0.30	0.20					
7	HEGT85 HELIUM-GT- HEAT	0.	317.	1661.	265.	533.	156.	0.	-387.	1661.	COAL-AFB	1274.	0	0.16	0.32	0.16					
8	HEGT60 HELIUM-GT- POWR	0.	10.	1581.	500.	409.	120.	-276.	0.	1581.	COAL-AFB	1581.	0	0.01	0.26	0.17					
8	HEGT60 HELIUM-GT- HEAT	0.	152.	839.	265.	217.	64.	0.	601.	839.	COAL-AFB	1439.	0	0.10	0.15	0.18					
9	HEGT00 HELIUM-GT- POWR	0.	-735.	2326.	1152.	409.	120.	-1043.	0.	2326.	COAL-AFB	2326.	0	-0.46	0.18	0.11					
9	HEGT00 HELIUM-GT- HEAT	0.	71.	535.	265.	94.	28.	0.	985.	535.	COAL-AFB	1520.	10	0.04	0.08	0.17					
10	FCMCCL FUEL-CL-MO POWR	0.	244.	1347.	638.	409.	120.	-439.	0.	1347.	COAL	1347.	0	0.15	0.30	0.20					
10	FCMCCL FUEL-CL-MO HEAT	0.	284.	559.	265.	170.	50.	0.	748.	559.	COAL	1307.	10	0.18	0.13	0.20					
11	FCSTCL FUEL-CL-ST POWR	0.	552.	1040.	401.	409.	120.	-159.	0.	1040.	COAL	1040.	10	0.35	0.39	0.25					
11	FCSTCL FUEL-CL-ST HEAT	0.	470.	688.	265.	271.	79.	0.	433.	688.	COAL	1121.	10	0.30	0.24	0.24					
12	IGGTST INT-GAS-GT POWR	0.	212.	1380.	570.	409.	120.	-359.	0.	1380.	COAL	1380.	0	0.13	0.30	0.19					
12	IGGTST INT-GAS-GT HEAT	0.	265.	641.	265.	190.	56.	0.	685.	641.	COAL	1326.	10	0.17	0.14	0.20					
13	GTSCAR GT-HRSO-10 POWR	0.	179.	1412.	610.	409.	120.	-406.	0.	1412.	RESIDUAL	1412.	0	0.11	0.29	0.19					
13	GTSCAR GT-HRSO-10 HEAT	0.	254.	613.	265.	178.	52.	0.	724.	613.	RESIDUAL	1337.	0	0.16	0.13	0.20					
14	GTAC08 GT-HRSO-08 POWR	0.	75.	1516.	779.	409.	120.	-604.	0.	1516.	RESIDUAL	1516.	0	0.05	0.27	0.17					
14	GTAC08 GT-HRSO-08 HEAT	0.	231.	516.	265.	139.	41.	0.	844.	516.	RESIDUAL	1360.	0	0.15	0.10	0.19					
15	GTAC12 GT-HRSO-12 POWR	0.	249.	1342.	625.	409.	120.	-423.	0.	1342.	RESIDUAL	1342.	0	0.16	0.31	0.20					
15	GTAC12 GT-HRSO-12 HEAT	0.	285.	569.	265.	174.	51.	0.	737.	569.	RESIDUAL	1306.	0	0.18	0.13	0.20					
16	GTAC16 GT-HRSO-16 POWR	0.	324.	1268.	553.	409.	120.	-338.	0.	1268.	RESIDUAL	1268.	0	0.20	0.32	0.21					
16	GTAC16 GT-HRSO-16 HEAT	0.	317.	608.	265.	196.	58.	0.	666.	608.	RESIDUAL	1274.	0	0.20	0.15	0.21					
17	GTWC16 GT-HRSO-16 POWR	0.	291.	1300.	526.	409.	120.	-307.	0.	1300.	RESIDUAL	1300.	0	0.18	0.32	0.20					
17	GTWC16 GT-HRSO-16 HEAT	0.	302.	655.	265.	206.	61.	0.	634.	655.	RESIDUAL	1290.	0	0.19	0.16	0.21					

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28121 MW 120.00 PROCESS MILLIONS BTU/HR 265.0 PROCESS TEMP(F) 338. PRODUCT CHLORINE-CAU HOURS PER YEAR 8500.

UTILITY FUEL		COAL		POWER TO HEAT RATIO 1.545										WASTE FUEL EQV BTU*10**6= 0.		HOT WATER BTU*10**6= 0.		
WASTE FUEL USED 10**6 BTU/HR	FUEL NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN PROCES 10**6 BTU/HR	COGEN PROCES 10**6 BTU/HR	COGEN MW ELECT	AUX BOILR 10**6 BTU/HR	UTILIT FUEL 10**6 BTU/HR	TOTAL FUEL 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET+ TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR			
18	CC1626	GTST-16/26	POWR	0.	531.	1060.	319.	409.	120.	-64.	0.	1060.	RESIDUAL	1060.	0	0.33	0.39	0.25
16	CC1626	GTST-16/26	HEAT	0.	494.	879.	265.	340.	100.	0.	218.	879.	RESIDUAL	1098.	0	0.31	0.31	0.24
19	CC1622	GTST-16/22	POWR	0.	518.	1073.	355.	409.	120.	-106.	0.	1073.	RESIDUAL	1073.	0	0.33	0.38	0.25
19	CC1622	GTST-16/22	HEAT	0.	466.	801.	265.	306.	90.	0.	324.	801.	RESIDUAL	1125.	0	0.29	0.27	0.24
20	CC1222	GTST-12/22	POWR	0.	523.	1069.	356.	409.	120.	-107.	0.	1069.	RESIDUAL	1069.	0	0.33	0.38	0.25
20	CC1222	GTST-12/22	HEAT	0.	469.	795.	265.	305.	89.	0.	327.	795.	RESIDUAL	1123.	0	0.29	0.27	0.24
21	CC0822	GTST-08/22	POWR	0.	462.	1129.	445.	409.	120.	-212.	0.	1129.	RESIDUAL	1129.	0	0.29	0.36	0.23
21	CC0822	GTST-08/22	HEAT	0.	401.	672.	265.	244.	71.	0.	518.	672.	RESIDUAL	1190.	0	0.25	0.20	0.22
22	ST1015	ST10-15-16	POWR	0.	221.	1075.	14.	409.	120.	295.	0.	1370.	RESIDUAL	1370.	0	0.14	0.30	0.19
22	ST1015	ST10-15-16	HEAT	0.	4198.	20385.	265.	7767.	2276.	0.	-22991.	20385.	RESIDUAL	-2606.	0	0.17	0.38	0.01
23	ST1010	ST10-10-16	POWR	0.	317.	1140.	151.	409.	120.	134.	0.	1274.	RESIDUAL	1274.	0	0.20	0.32	0.21
23	ST1010	ST10-10-16	HEAT	0.	556.	2000.	265.	718.	210.	0.	-965.	2000.	RESIDUAL	1035.	0	0.22	0.36	0.13
24	ST1015	ST10-15-16	POWR	0.	361.	1221.	257.	409.	120.	9.	0.	1230.	RESIDUAL	1230.	0	0.23	0.33	0.22
24	ST1015	ST10-15-16	HEAT	0.	371.	1257.	265.	421.	124.	0.	-37.	1257.	RESIDUAL	1220.	0	0.23	0.34	0.21
25	DEADV3	DIESEL-ADV	POWR	0.	457.	1104.	239.	409.	120.	30.	0.	1134.	RESIDUAL	1134.	0	0.29	0.36	0.23
25	DEADV3	DIESEL-ADV	HEAT	0.	507.	1222.	265.	453.	133.	0.	-137.	1222.	RESIDUAL	1085.	0	0.29	0.37	0.22
26	DEADV2	DIESEL-ADV	POWR	0.	488.	1104.	280.	409.	120.	-18.	0.	1104.	RESIDUAL	1104.	1	0.31	0.37	0.24
26	DEADV2	DIESEL-ADV	HEAT	0.	478.	1043.	265.	387.	113.	0.	70.	1043.	RESIDUAL	1113.	1	0.30	0.35	0.24
27	DEADV1	DIESEL-ADV	POWR	0.	488.	1104.	432.	409.	120.	-196.	0.	1104.	RESIDUAL	1104.	1	0.31	0.37	0.24
27	DEADV1	DIESEL-ADV	HEAT	0.	420.	678.	265.	251.	74.	0.	494.	678.	RESIDUAL	1171.	1	0.26	0.21	0.23
28	DEHTPM	ADV-DIESEL	POWR	0.	378.	1213.	522.	409.	120.	-302.	0.	1213.	RESIDUAL	1213.	0	0.24	0.34	0.22
28	DEHTPM	ADV-DIESEL	HEAT	0.	345.	616.	265.	208.	61.	0.	630.	616.	RESIDUAL	1246.	0	0.22	0.17	0.21
29	DES0A3	DIESEL-S0A	POWR	0.	389.	1134.	207.	409.	120.	68.	0.	1202.	DISTILLA	1202.	0	0.24	0.34	0.22
29	DES0A3	DIESEL-S0A	HEAT	0.	497.	1449.	265.	523.	153.	0.	-356.	1449.	DISTILLA	1094.	0	0.26	0.36	0.18
29	DES0A3	DIESEL-S0A	POWR	0.	389.	1134.	207.	409.	120.	68.	0.	1202.	RESIDUAL	1202.	0	0.24	0.34	0.22
29	DES0A3	DIESEL-S0A	HEAT	0.	497.	1449.	265.	523.	153.	0.	-356.	1449.	RESIDUAL	1094.	0	0.26	0.36	0.18

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 99

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28121 MW 120.00 PROCESS MILLIONS BTU/HR 265.0 PROCESS TEMP(F) 338. PRODUCT CHLORINE-CAU HOURS PER YEAR 8500.

UTILITY FUEL		COAL		POWER TO HEAT RATIO 1.545 WASTE FUEL EQV BTU*10**6= 0. HOT WATER BTU*10**6= 0.										NET=	FAIL	FESR	POWER	HEAT
		WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	TOTAL+ UTILIT 10**6 BTU/HR				FACTR	FACTR	
30	DESOA2 DIESEL-SOA POWR	0.	439.	1134.	250.	409.	120.	18.	0.	1152.	DISTILLA	1152.	1	0.28	0.36	0.23		
30	DESOA2 DIESEL-SOA HEAT	0.	466.	1205.	265.	435.	127.	0.	-79.	1205.	DISTILLA	1125.	1	0.28	0.36	0.22		
30	DESJA2 DIESEL-SOA POWR	0.	439.	1134.	250.	409.	120.	18.	0.	1152.	RESIDUAL	1152.	1	0.28	0.36	0.23		
30	DESOA2 DIESEL-SOA HEAT	0.	466.	1205.	265.	435.	127.	0.	-79.	1205.	RESIDUAL	1125.	1	0.28	0.36	0.22		
31	DESOA1 DIESEL-SOA POWR	0.	457.	1134.	455.	409.	120.	-223.	0.	1134.	DISTILLA	1134.	1	0.29	0.36	0.23		
31	DESOA1 DIESEL-SOA HEAT	0.	396.	661.	265.	239.	70.	0.	534.	661.	DISTILLA	1195.	1	0.25	0.20	0.22		
31	DESOA1 DIESEL-SOA POWR	0.	457.	1134.	455.	409.	120.	-223.	0.	1134.	RESIDUAL	1151.	1	0.29	0.36	0.23		
31	DESOA1 DIESEL-SOA HEAT	0.	396.	661.	265.	239.	70.	0.	534.	661.	RESIDUAL	1195.	1	0.25	0.20	0.22		
32	GTSOAD GT-HRSO-10 POWR	0.	189.	1402.	650.	409.	120.	-453.	0.	1402.	DISTILLA	1402.	0	0.12	0.29	0.19		
32	GTSOAD GT-HRSO-10 HEAT	0.	262.	572.	265.	167.	49.	0.	758.	572.	DISTILLA	1330.	0	0.16	0.13	0.20		
33	GTRA08 GT-85RE-08 POWR	0.	444.	1147.	399.	409.	120.	-157.	0.	1147.	DISTILLA	1147.	0	0.28	0.36	0.23		
33	GTRA08 GT-85RE-08 HEAT	0.	400.	762.	265.	272.	80.	0.	429.	762.	DISTILLA	1191.	0	0.25	0.23	0.22		
34	GTRA12 GT-85RE-12 POWR	0.	448.	1144.	407.	409.	120.	-167.	0.	1144.	DISTILLA	1144.	0	0.28	0.36	0.23		
34	GTRA12 GT-85RE-12 HEAT	0.	400.	745.	265.	267.	78.	0.	446.	745.	DISTILLA	1191.	0	0.25	0.22	0.22		
35	GTRA16 GT-85RE-16 POWR	0.	418.	1173.	435.	409.	120.	-200.	0.	1173.	DISTILLA	1173.	0	0.26	0.35	0.23		
35	GTRA16 GT-85RE-16 HEAT	0.	377.	715.	265.	249.	73.	0.	500.	715.	DISTILLA	1215.	0	0.24	0.21	0.22		
36	GTR208 GT-60RE-08 POWR	0.	312.	1280.	523.	409.	120.	-304.	0.	1280.	DISTILLA	1280.	0	0.20	0.32	0.21		
36	GTR208 GT-60RE-08 HEAT	0.	312.	648.	265.	207.	61.	0.	631.	648.	DISTILLA	1280.	0	0.20	0.16	0.21		
37	GTR212 GT-60RE-12 POWR	0.	351.	1241.	488.	409.	120.	-262.	0.	1241.	DISTILLA	1241.	0	0.22	0.33	0.21		
37	GTR212 GT-60RE-12 HEAT	0.	333.	674.	265.	223.	65.	0.	584.	674.	DISTILLA	1258.	0	0.21	0.18	0.21		
38	GTR216 GT-60RE-16 POWR	0.	376.	1215.	476.	409.	120.	-248.	0.	1215.	DISTILLA	1215.	0	0.24	0.34	0.22		
38	GTR216 GT-60RE-16 HEAT	0.	348.	676.	265.	228.	67.	0.	587.	676.	DISTILLA	1244.	0	0.22	0.18	0.21		
39	GTRW08 GT-85RE-08 POWR	0.	425.	1166.	333.	409.	120.	-80.	0.	1166.	DISTILLA	1166.	0	0.27	0.35	0.23		
39	GTRW08 GT-85RE-08 HEAT	0.	402.	927.	265.	325.	95.	0.	262.	927.	DISTILLA	1190.	0	0.25	0.27	0.22		
40	GTRW12 GT-85RE-12 POWR	0.	466.	1125.	327.	409.	120.	-73.	0.	1125.	DISTILLA	1125.	0	0.29	0.36	0.24		
40	GTRW12 GT-85RE-12 HEAT	0.	437.	912.	265.	332.	97.	0.	242.	912.	DISTILLA	1154.	0	0.27	0.29	0.23		

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 100

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28121 MW 120.00 PROCESS MILLIONS BTU/HR 265.0 PROCESS TEMP(F) 338. PRODUCT CHLORINE-CAU HOURS PER YEAR 8500.

POWER TO HEAT RATIO 1.545

WASTE FUEL EQV BTU\*10\*\*6=

0.

HOT WATER BTU\*10\*\*6=

0.

UTILITY FUEL

COAL

			WASTE FUEL USED 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR		
41	GTRW16	GT-85RE-16	POWR	0.	444.	1147.	351.	409.	120.	-102.	0.	1147.	DISTILLA	1147.	0	0.28	0.36	0.23
41	GTRW16	GT-85RE-16	HEAT	0.	412.	865.	265.	309.	90.	0.	315.	865.	DISTILLA	1180.	0	0.26	0.26	0.22
42	GTR308	GT-60RE-08	POWR	0.	270.	1321.	436.	409.	120.	-202.	0.	1321.	DISTILLA	1321.	0	0.17	0.31	0.20
42	GTR308	GT-60RE-08	HEAT	0.	287.	802.	265.	249.	73.	0.	503.	802.	DISTILLA	1305.	0	0.18	0.19	0.20
43	GTR312	GT-60RE-12	POWR	0.	394.	1197.	401.	409.	120.	-160.	0.	1197.	DISTILLA	1197.	0	0.25	0.34	0.22
43	GTR312	GT-60RE-12	HEAT	0.	366.	791.	265.	270.	79.	0.	434.	791.	DISTILLA	1225.	0	0.23	0.22	0.22
44	GTR316	GT-60RE-16	POWR	0.	383.	1208.	407.	409.	120.	-168.	0.	1208.	DISTILLA	1208.	0	0.24	0.34	0.22
44	GTR316	GT-60RE-16	HEAT	0.	358.	786.	265.	266.	78.	0.	447.	786.	DISTILLA	1233.	0	0.23	0.22	0.21
45	FCPADS	FUEL-CL-PH	POWR	0.	418.	1077.	183.	409.	120.	96.	0.	1174.	DISTILLA	1174.	0	0.26	0.35	0.23
45	FCPADS	FUEL-CL-PH	HEAT	0.	604.	1559.	265.	592.	174.	0.	-572.	1559.	DISTILLA	987.	0	0.28	0.38	0.17
46	FCMCDS	FUEL-CL-MO	POWR	0.	558.	994.	232.	409.	120.	39.	0.	1033.	DISTILLA	1033.	0	0.35	0.40	0.26
46	FCMCDS	FUEL-CL-MO	HEAT	0.	639.	1137.	265.	469.	137.	0.	-185.	1137.	DISTILLA	953.	0	0.36	0.41	0.23

HONEYWELL PAGE PRINTING SYSTEM- P1188-02

ORIGINAL PAGE IS  
OF POOR QUALITY

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 101

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28131 MW 34.00 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT CRYOGENIC-0- HOURS PER YEAR -1.

POWER TO HEAT RATIO \*\*\*\*\*

UTILITY FUEL COAL WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
------------------------------	---------------------------------	------------------------------	-------------------------	---------------------------------	----------------	-------------------------------	-------------------------------	------------------------------	-----------------------------	---------------------------------	------	------	-------------	------------

0	0	0	0	0	0	0	0	363.	0.	363.	0	0.	0.32	0.
1	15.	347.	179.	116.	34.	-211.	0.	347.	0.	347.	1	0.04	0.33	0.
1	0.	0.	0.	0.	0.	0.	0.	363.	0.	363.	111	0.	0.	0.
1	15.	347.	179.	116.	34.	-211.	0.	347.	0.	347.	1	0.04	0.33	0.
1	0.	0.	0.	0.	0.	0.	0.	363.	0.	363.	111	0.	0.	0.
1	15.	347.	179.	116.	34.	-211.	0.	347.	0.	347.	1	0.04	0.33	0.
1	0.	0.	0.	0.	0.	0.	0.	363.	0.	363.	111	0.	0.	0.
2	-20.	383.	209.	116.	34.	-246.	0.	383.	0.	383.	1	-0.06	0.30	0.
2	0.	0.	0.	0.	0.	0.	0.	363.	0.	363.	111	0.	0.	0.
2	-20.	383.	209.	116.	34.	-246.	0.	383.	0.	383.	1	-0.06	0.30	0.
2	0.	0.	0.	0.	0.	0.	0.	363.	0.	363.	111	0.	0.	0.
2	-20.	383.	209.	116.	34.	-246.	0.	383.	0.	383.	1	-0.06	0.30	0.
2	0.	0.	0.	0.	0.	0.	0.	363.	0.	363.	111	0.	0.	0.
3	60.	303.	143.	116.	34.	-169.	0.	303.	0.	303.	1	0.17	0.38	0.
3	0.	0.	0.	0.	0.	0.	0.	363.	0.	363.	111	0.	0.	0.
4	83.	280.	120.	116.	34.	-141.	0.	280.	0.	280.	1	0.23	0.41	0.
4	0.	0.	0.	0.	0.	0.	0.	363.	0.	363.	111	0.	0.	0.
4	83.	280.	120.	116.	34.	-141.	0.	280.	0.	280.	1	0.23	0.41	0.
4	0.	0.	0.	0.	0.	0.	0.	363.	0.	363.	111	0.	0.	0.
5	-462.	825.	583.	116.	34.	-686.	0.	825.	0.	825.	1	-1.27	0.14	0.
5	0.	0.	0.	0.	0.	0.	0.	363.	0.	363.	111	0.	0.	0.
5	-462.	825.	583.	116.	34.	-686.	0.	825.	0.	825.	1	-1.27	0.14	0.
5	0.	0.	0.	0.	0.	0.	0.	363.	0.	363.	111	0.	0.	0.
6	-14.	377.	157.	116.	34.	-185.	0.	377.	0.	377.	1	-0.04	0.31	0.
6	0.	0.	0.	0.	0.	0.	0.	363.	0.	363.	111	0.	0.	0.

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28131 MW 34.00 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT CRYOGENIC-0- HOURS PER YEAR -1.

UTILITY FUEL		COAL	POWER TO HEAT RATIO *****										WASTE FUEL EQV BTU*10**6= 0. HOT WATER BTU*10**6= 0.			
WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET* TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR		
6 STIRL	STIRLING-1 POWR	0.	-14.	377.	157.	116.	34.	-185.	0.	377.	RESIDUAL	377.	1	-0.04	0.31	0.
6 STIRL	STIRLING-1 HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	RESIDUAL	363.	111	0.	0.	0.
6 STIRL	STIRLING-1 POWR	0.	-14.	377.	157.	116.	34.	-185.	0.	377.	COAL	377.	1	-0.04	0.31	0.
6 STIRL	STIRLING-1 HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	COAL	363.	111	0.	0.	0.
7 HEGT85	HELIUM-GT- POWR	0.	1.	361.	161.	116.	34.	-190.	0.	361.	COAL-AFB	361.	11	0.00	0.32	0.
7 HEGT85	HELIUM-GT- HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	COAL-AFB	363.	111	0.	0.	0.
8 HEGT60	HELIUM-GT- POWR	0.	-85.	448.	192.	116.	34.	-226.	0.	448.	COAL-AFB	448.	11	-0.24	0.26	0.
8 HEGT60	HELIUM-GT- HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	COAL-AFB	363.	111	0.	0.	0.
9 HEGT00	HELIUM-GT- POWR	0.	-297.	659.	398.	116.	34.	-469.	0.	659.	COAL-AFB	659.	11	-0.82	0.18	0.
9 HEGT00	HELIUM-GT- HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	COAL-AFB	363.	111	0.	0.	0.
10 FCMCCL	FUEL-CL-MO POWR	0.	-19.	382.	173.	116.	34.	-215.	0.	382.	COAL	382.	11	-0.05	0.30	0.
10 FCMCCL	FUEL-CL-MO HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	COAL	363.	111	0.	0.	0.
11 FCSTCL	FUEL-CL-ST POWR	0.	127.	236.	68.	116.	34.	-80.	0.	236.	COAL	236.	11	0.35	0.49	0.
11 FCSTCL	FUEL-CL-ST HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	COAL	363.	111	0.	0.	0.
12 IGGTST	INT-GAS-GT POWR	0.	73.	290.	90.	116.	34.	-106.	0.	290.	COAL	290.	11	0.20	0.40	0.
12 IGGTST	INT-GAS-GT HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	COAL	363.	111	0.	0.	0.
13 GTSOAR	GT-HRSG-10 POWR	0.	-38.	400.	198.	116.	34.	-233.	0.	400.	RESIDUAL	400.	1	-0.10	0.29	0.
13 GTSOAR	GT-HRSG-10 HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	RESIDUAL	363.	111	0.	0.	0.
14 GTAC08	GT-HRSG-08 POWR	0.	-67.	430.	206.	116.	34.	-243.	0.	430.	RESIDUAL	430.	1	-0.19	0.27	0.
14 GTAC08	GT-HRSG-08 HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	RESIDUAL	363.	111	0.	0.	0.
15 GTAC12	GT-HRSG-12 POWR	0.	-18.	380.	196.	116.	34.	-231.	0.	380.	RESIDUAL	380.	1	-0.05	0.31	0.
15 GTAC12	GT-HRSG-12 HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	RESIDUAL	363.	111	0.	0.	0.
16 GTAC16	GT-HRSG-16 POWR	0.	3.	359.	180.	116.	34.	-212.	0.	359.	RESIDUAL	359.	1	0.01	0.32	0.
16 GTAC16	GT-HRSG-16 HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	RESIDUAL	363.	111	0.	0.	0.
17 GTWC16	GT-HRSG-16 POWR	0.	-6.	368.	147.	116.	34.	-173.	0.	368.	RESIDUAL	368.	1	-0.02	0.32	0.
17 GTWC16	GT-HRSG-16 HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	RESIDUAL	363.	111	0.	0.	0.

HONEYWELL PAGE PRINTING SYSTEM - P1188-02

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28131 MW 34.00 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT CRYOGENIC-0- HOURS PER YEAR -1.

UTILITY FUEL		COAL		POWER TO HEAT RATIO *****										WASTE FUEL EQV BTU*10**6=		0.		HOT WATER BTU*10**6=		0.	
		WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	PROCES BOILR 10**6 BTU/HR	AUX 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR				
18	CC1626 GTST-16/26 POWR	0.	111.	251.	57.	116.	34.	-67.	0.	251.	RESIDUAL	251.	1	0.31	0.46	0.					
18	CC1626 GTST-16/26 HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	RESIDUAL	363.	111	0.	0.	0.					
19	CC1622 GTST-16/22 POWR	0.	111.	251.	63.	116.	34.	-74.	0.	251.	RESIDUAL	251.	1	0.31	0.46	0.					
19	CC1622 GTST-16/22 HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	RESIDUAL	363.	111	0.	0.	0.					
20	CC1222 GTST-12/22 POWR	0.	114.	249.	62.	116.	34.	-73.	0.	249.	RESIDUAL	249.	1	0.31	0.47	0.					
20	CC1222 GTST-12/22 HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	RESIDUAL	363.	111	0.	0.	0.					
21	CC0822 GTST-08/22 POWR	0.	111.	251.	74.	116.	34.	-87.	0.	251.	RESIDUAL	251.	1	0.31	0.46	0.					
21	CC0822 GTST-08/22 HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	RESIDUAL	363.	111	0.	0.	0.					
22	STIG15 STIG-15-16 POWR	0.	58.	304.	4.	116.	34.	-5.	0.	304.	RESIDUAL	304.	1	0.16	0.38	0.					
22	STIG15 STIG-15-16 HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	RESIDUAL	363.	111	0.	0.	0.					
23	STIG10 STIG-10-16 POWR	0.	39.	323.	43.	116.	34.	-30.	0.	323.	RESIDUAL	323.	1	0.11	0.36	0.					
23	STIG10 STIG-10-16 HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	RESIDUAL	363.	111	0.	0.	0.					
24	STIG1S STIG-1S-16 POWR	0.	16.	346.	73.	116.	34.	-86.	0.	346.	RESIDUAL	346.	1	0.05	0.34	0.					
24	STIG1S STIG-1S-16 HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	RESIDUAL	363.	111	0.	0.	0.					
25	DEADV3 DIESEL-ADV POWR	0.	50.	313.	113.	116.	34.	-132.	0.	313.	RESIDUAL	313.	1	0.14	0.37	0.					
25	DEADV3 DIESEL-ADV HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	RESIDUAL	363.	111	0.	0.	0.					
26	DEADV2 DIESEL-ADV POWR	0.	50.	313.	79.	116.	34.	-93.	0.	313.	RESIDUAL	313.	1	0.14	0.37	0.					
26	DEADV2 DIESEL-ADV HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	RESIDUAL	363.	111	0.	0.	0.					
27	DEADV1 DIESEL-ADV POWR	0.	50.	313.	122.	116.	34.	-144.	0.	313.	RESIDUAL	313.	1	0.14	0.37	0.					
27	DEADV1 DIESEL-ADV HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	RESIDUAL	363.	111	0.	0.	0.					
28	DEHTPM ADV-DIESEL POWR	0.	73.	289.	147.	116.	34.	-173.	0.	289.	RESIDUAL	289.	1	0.20	0.40	0.					
28	DEHTPM ADV-DIESEL HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	RESIDUAL	363.	111	0.	0.	0.					
29	DES0A3 DIESEL-S0A POWR	0.	41.	321.	105.	116.	34.	-123.	0.	321.	DISTILLA	321.	1	0.11	0.36	0.					
29	DES0A3 DIESEL-S0A HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	DISTILLA	363.	111	0.	0.	0.					
29	DES0A3 DIESEL-S0A POWR	0.	41.	321.	105.	116.	34.	-123.	0.	321.	RESIDUAL	321.	1	0.11	0.36	0.					
29	DES0A3 DIESEL-S0A HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	RESIDUAL	363.	111	0.	0.	0.					

HONJYWELL PAGE PRINTING SYSTEM - P1185-02



I&amp;SE PEO AD/ DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28131 MW 34.00 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT CRYCOGENIC-0- HOURS PER YEAR -1.

		POWER TO HEAT RATIO *****															
UTILITY FUEL		COAL		WASTE FUEL EQV BTU*10**6=										HOT WATER BTU*10**6=			
		WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED-NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET+ TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
30	DESOA2 DIESEL-SOA POWR	0.	41.	321.	71.	116.	34.	-83.	0.	321.	DISTILLA	321.	1	0.11	0.36	0.	
30	DESOA2 DIESEL-SOA HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	DISTILLA	363.	111	0.	0.	0.	
30	DESOA2 DIESEL-SOA POWR	0.	41.	321.	71.	116.	34.	-83.	0.	321.	RESIDUAL	321.	1	0.11	0.36	0.	
30	DESOA2 DIESEL-SOA HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	RESIDUAL	363.	111	0.	0.	0.	
31	DESOA1 DIESEL-SOA POWR	0.	41.	321.	129.	116.	34.	-152.	0.	321.	DISTILLA	321.	1	0.11	0.36	0.	
31	DESOA1 DIESEL-SOA HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	DISTILLA	363.	111	0.	0.	0.	
31	DESOA1 DIESEL-SOA POWR	0.	41.	321.	129.	116.	34.	-152.	0.	321.	RESIDUAL	321.	1	0.11	0.36	0.	
31	DESOA1 DIESEL-SOA HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	RESIDUAL	363.	111	0.	0.	0.	
32	GTSOAD GT-HRS6-10 POWR	0.	-35.	397.	214.	116.	34.	-252.	0.	397.	DISTILLA	397.	1	-0.10	0.29	0.	
32	GTSOAD GT-HRS6-10 HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	DISTILLA	363.	111	0.	0.	0.	
33	GTRA08 GT-85RE-08 POWR	0.	38.	325.	131.	116.	34.	-154.	0.	325.	DISTILLA	325.	1	0.10	0.36	0.	
33	GTRA08 GT-85RE-08 HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	DISTILLA	363.	111	0.	0.	0.	
34	GTRA12 GT-85RE-12 POWR	0.	38.	324.	133.	116.	34.	-156.	0.	324.	DISTILLA	324.	1	0.11	0.36	0.	
34	GTRA12 GT-85RE-12 HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	DISTILLA	363.	111	0.	0.	0.	
35	GTRA16 GT-85RE-16 POWR	0.	30.	332.	141.	116.	34.	-166.	0.	332.	DISTILLA	332.	1	0.08	0.35	0.	
35	GTRA16 GT-85RE-16 HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	DISTILLA	363.	111	0.	0.	0.	
36	GTR208 GT-60RE-08 POWR	0.	0.	363.	171.	116.	34.	-201.	0.	363.	DISTILLA	363.	1	0.	0.32	0.	
36	GTR208 GT-60RE-08 HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	DISTILLA	363.	111	0.	0.	0.	
37	GTR212 GT-60RE-12 POWR	0.	11.	352.	157.	116.	34.	-185.	0.	352.	DISTILLA	352.	1	0.03	0.33	0.	
37	GTR212 GT-60RE-12 HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	DISTILLA	363.	111	0.	0.	0.	
38	GTR216 GT-60RE-16 POWR	0.	18.	344.	154.	116.	34.	-181.	0.	344.	DISTILLA	344.	1	0.05	0.34	0.	
38	GTR216 GT-60RE-16 HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	DISTILLA	363.	111	0.	0.	0.	
39	GTRW08 GT-85RE-08 POWR	0.	32.	331.	109.	116.	34.	-128.	0.	331.	DISTILLA	331.	1	0.09	0.35	0.	
39	GTRW08 GT-85RE-08 HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	DISTILLA	363.	111	0.	0.	0.	
40	GTRW12 GT-85RE-12 POWR	0.	44.	319.	106.	116.	34.	-125.	0.	319.	DISTILLA	319.	1	0.12	0.36	0.	
40	GTRW12 GT-85RE-12 HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	DISTILLA	363.	111	0.	0.	0.	

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 105

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28131 MW 34.00 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT CRYOGENIC-0- HOURS PER YEAR -1.

POWER TO HEAT RATIO \*\*\*\*\*

UTILITY FUEL COAL

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED- NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET* TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41 GTRW16 GT-85RE-16 POWR	0.	38.	325.	114.	116.	34.	-134.	0.	325.	DISTILLA	325.	1	0.10	0.36	0.
41 GTRW16 GT-85RE-16 HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	DISTILLA	363.	111	0.	0.	0.
42 GTR308 GT-60RE-08 POWR	0.	-12.	374.	168.	116.	34.	-198.	0.	374.	DISTILLA	374.	1	-0.03	0.31	0.
42 GTR308 GT-60RE-08 HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	DISTILLA	363.	111	0.	0.	0.
43 GTR312 GT-60RE-12 POWR	0.	23.	339.	129.	116.	34.	-152.	0.	339.	DISTILLA	339.	1	0.06	0.34	0.
43 GTR312 GT-60RE-12 HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	DISTILLA	363.	111	0.	0.	0.
44 GTR316 GT-60RE-16 POWR	0.	20.	342.	132.	116.	34.	-155.	0.	342.	DISTILLA	342.	1	0.06	0.34	0.
44 GTR316 GT-60RE-16 HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	DISTILLA	363.	111	0.	0.	0.
45 FCPADS FUEL-CL-PH POWR	0.	57.	305.	52.	116.	34.	-61.	0.	305.	DISTILLA	305.	1	0.16	0.38	0.
45 FCPADS FUEL-CL-PH HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	DISTILLA	363.	111	0.	0.	0.
46 FCMCDS FUEL-CL-MO POWR	0.	81.	282.	66.	116.	34.	-77.	0.	282.	DISTILLA	282.	1	0.22	0.41	0.
46 FCMCDS FUEL-CL-MO HEAT	0.	0.	0.	0.	0.	0.	0.	363.	0.	DISTILLA	363.	111	0.	0.	0.

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28191 MW 30.29 PROCESS MILLIONS BTU/HR 980.0 PROCESS TEMP(F) 495. PRODUCT ALUMINA HOURS PER YEAR 8136.

UTILITY FUEL		COAL		POWER TO HEAT RATIO 0.105										WASTE FUEL EQV BTU*10**6= 0. HOT WATER BTU*10**6= 0.			
WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED-NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILER 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR		
0	0	0	0	0	0	0	1153.	323.	1153.	COAL-FGD	1476.	0	0.	0.07	0.66		
1	201.	1133.	860.	103.	30.	141.	0.	1275.	RESIDUAL	1275.	0	0.14	0.08	0.77			
1	229.	1291.	980.	118.	35.	0.	-45.	1291.	RESIDUAL	1246.	0	0.15	0.09	0.76			
1	201.	1133.	860.	103.	30.	141.	0.	1275.	COAL-FGD	1275.	0	0.14	0.08	0.77			
1	229.	1291.	980.	118.	35.	0.	-45.	1291.	COAL-FGD	1246.	0	0.15	0.09	0.76			
1	201.	1133.	860.	103.	30.	141.	0.	1275.	COAL-AFB	1275.	0	0.14	0.08	0.77			
1	229.	1291.	980.	118.	35.	0.	-45.	1291.	COAL-AFB	1246.	0	0.15	0.09	0.76			
2	-397.	1873.	1489.	103.	30.	-598.	0.	1873.	RESIDUAL	1873.	0	-0.27	0.06	0.52			
2	133.	1233.	980.	68.	20.	0.	110.	1233.	RESIDUAL	1343.	0	0.09	0.05	0.73			
2	-397.	1873.	1489.	103.	30.	-598.	0.	1873.	COAL-FGD	1873.	0	-0.27	0.06	0.52			
2	133.	1233.	980.	68.	20.	0.	110.	1233.	COAL-FGD	1343.	0	0.09	0.05	0.73			
2	-397.	1873.	1489.	103.	30.	-598.	0.	1873.	COAL-AFB	1873.	0	-0.27	0.06	0.52			
2	133.	1233.	980.	68.	20.	0.	110.	1233.	COAL-AFB	1343.	0	0.09	0.05	0.73			
3	193.	630.	425.	103.	30.	653.	0.	1283.	COAL-PFB	1283.	0	0.13	0.08	0.76			
3	445.	1452.	980.	238.	70.	0.	-422.	1452.	COAL-PFB	1030.	0	0.23	0.16	0.67			
4	197.	480.	301.	103.	30.	799.	0.	1278.	RESIDUAL	1278.	0	0.12	0.08	0.77			
4	642.	1561.	980.	336.	99.	0.	-728.	1561.	RESIDUAL	834.	0	0.29	0.22	0.63			
4	197.	480.	301.	103.	30.	799.	0.	1278.	COAL	1278.	0	0.13	0.08	0.77			
4	642.	1561.	980.	336.	99.	0.	-728.	1561.	COAL	834.	0	0.29	0.22	0.63			
5	103.	735.	437.	103.	30.	639.	0.	1373.	RESIDUAL	1373.	0	0.07	0.08	0.71			
5	230.	1647.	980.	232.	68.	0.	-401.	1647.	RESIDUAL	1246.	0	0.12	0.14	0.69			
5	103.	735.	437.	103.	30.	639.	0.	1373.	COAL	1373.	0	0.07	0.08	0.71			
5	230.	1647.	980.	232.	68.	0.	-401.	1647.	COAL	1246.	0	0.12	0.14	0.69			
6	133.	476.	243.	103.	30.	867.	0.	1343.	DISTILLA	1343.	0	0.09	0.08	0.73			
6	537.	1917.	980.	416.	122.	0.	-979.	1917.	DISTILLA	938.	0	0.22	0.22	0.51			

HONEYWELL PAGE PRINTING SYSTEM - P1188-C2

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28191 MW 30.29 PROCESS MILLIONS BTU/HR 980.0 PROCESS TEMP(F) 495. PRODUCT ALUMINA HOURS PER YEAR 8136.

POWER TO HEAT RATIO 0.105

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
6 STIRL STIRLING-1 POWR		0.	133.	476.	243.	103.	30.	867.	0.	1343.	RESIDUAL	1343.	0	0.09	0.08	0.73
6 STIRL STIRLING-1 HEAT		0.	537.	1917.	980.	416.	122.	0.	-979.	1917.	RESIDUAL	938.	0	0.22	0.22	0.51
6 STIRL STIRLING-1 POWR		0.	133.	476.	243.	103.	30.	867.	0.	1343.	COAL	1343.	0	0.09	0.08	0.73
6 STIRL STIRLING-1 HEAT		0.	537.	1917.	980.	416.	122.	0.	-979.	1917.	COAL	938.	0	0.22	0.22	0.51
7 HEGT85 HELIUM-GT- POWR		0.	-39.	322.	-34.	103.	30.	1193.	0.	1515.	COAL-AFB	1515.	11	-0.03	0.07	0.65
7 HEGT85 HELIUM-GT- HEAT		-9206.	1124.	-9206.	980.	-2955.	-866.	0.	9558.	-9206.	COAL-AFB	352.	11	-5.48	-8.40	2.79
8 HEGT60 HELIUM-GT- POWR		0.	-9.	399.	57.	103.	30.	1086.	0.	1485.	COAL-AFB	1485.	10	-0.01	0.07	0.66
8 HEGT60 HELIUM-GT- HEAT		0.	-163.	6901.	980.	1787.	524.	0.	-5283.	6901.	COAL-AFB	1638.	0	-0.02	0.26	0.14
9 HEGT00 HELIUM-GT- POWR		0.	55.	587.	271.	103.	30.	834.	0.	1421.	COAL-AFB	1421.	10	0.04	0.07	0.69
9 HEGT00 HELIUM-GT- HEAT		0.	198.	2121.	980.	373.	109.	0.	-844.	2121.	COAL-AFB	1277.	0	0.09	0.18	0.46
10 FCMCCL FUEL-CL-MO POWR		0.	171.	340.	160.	103.	30.	965.	0.	1305.	COAL	1305.	10	0.12	0.08	0.75
10 FCMCCL FUEL-CL-MO HEAT		0.	1049.	2085.	980.	634.	186.	0.	-1658.	2085.	COAL	427.	0	0.32	0.30	0.47
11 FCSTCL FUEL-CL-ST POWR		0.	177.	291.	123.	103.	30.	1008.	0.	1299.	COAL	1299.	10	0.12	0.08	0.75
11 FCSTCL FUEL-CL-ST HEAT		0.	1406.	2311.	980.	821.	241.	0.	-2242.	2311.	COAL	70.	0	0.38	0.36	0.42
12 IGGTST INT-GAS-GT POWR		0.	134.	406.	185.	103.	30.	935.	0.	1341.	COAL	1341.	10	0.09	0.08	0.73
12 IGGTST INT-GAS-GT HEAT		0.	712.	2151.	980.	547.	160.	0.	-1387.	2151.	COAL	764.	0	0.25	0.25	0.46
13 GTSOAR GT-HRSG-10 POWR		0.	126.	356.	136.	103.	30.	994.	0.	1350.	RESIDUAL	1350.	0	0.09	0.08	0.73
13 GTSOAR GT-HRSG-10 HEAT		0.	911.	2577.	980.	747.	219.	0.	-2013.	2577.	RESIDUAL	565.	0	0.26	0.29	0.38
14 GTAC08 GT-HRSG-08 POWR		0.	172.	383.	197.	103.	30.	921.	0.	1303.	RESIDUAL	1303.	0	0.12	0.08	0.75
14 GTAC08 GT-HRSG-08 HEAT		0.	856.	1900.	980.	513.	150.	0.	-1280.	1900.	RESIDUAL	620.	0	0.31	0.27	0.52
15 GTAC12 GT-HRSG-12 POWR		0.	169.	339.	157.	103.	30.	968.	0.	1307.	RESIDUAL	1307.	0	0.11	0.08	0.75
15 GTAC12 GT-HRSG-12 HEAT		0.	1054.	2114.	980.	645.	189.	0.	-1692.	2114.	RESIDUAL	422.	0	0.33	0.31	0.46
16 GTAC16 GT-HRSG-16 POWR		0.	161.	320.	134.	103.	30.	995.	0.	1315.	RESIDUAL	1315.	0	0.11	0.08	0.75
16 GTAC16 GT-HRSG-16 HEAT		0.	1175.	2332.	980.	753.	221.	0.	-2031.	2332.	RESIDUAL	301.	0	0.33	0.32	0.42
17 GTWC16 GT-HRSG-16 POWR		0.	151.	328.	133.	103.	30.	996.	0.	1324.	RESIDUAL	1324.	0	0.10	0.08	0.74
17 GTWC16 GT-HRSG-16 HEAT		0.	1115.	2416.	980.	761.	223.	0.	-2055.	2416.	RESIDUAL	361.	0	0.32	0.32	0.41

I&amp;SE PEO ADV DESIGN EN3R

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28191 MW 30.29 PROCESS MILLIONS BTU/HR 980.0 PROCESS TEMP(F) 495. PRODUCT ALUMINA HOURS PER YEAR 8136.

POWER TO HEAT RATIO 0.105

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED-NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	AUX MW ELECT	UTILIT PROCES BOILR 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET+ TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
18 CC1626 GTST-16/26 POWR		0.	145.	291.	97.	103.	30.	1039.	0.	1330.	RESIDUAL 1330.	0	0.10	0.08	0.74
18 CC1626 GTST-16/26 HEAT		0.	1478.	2949.	980.	1047.	307.	0.	-2950.	2949.	RESIDUAL -2.	0	0.33	0.36	0.33
19 CC1622 GTST-16/22 POWR		0.	153.	297.	108.	103.	30.	1026.	0.	1323.	RESIDUAL 1323.	0	0.10	0.08	0.74
19 CC1622 GTST-16/22 HEAT		0.	1392.	2693.	980.	938.	275.	0.	-2609.	2693.	RESIDUAL 84.	0	0.34	0.35	0.36
20 CC1222 GTST-12/22 POWR		0.	155.	296.	109.	103.	30.	1025.	0.	1321.	RESIDUAL 1321.	0	0.10	0.08	0.74
20 CC1222 GTST-12/22 HEAT		0.	1394.	2667.	980.	930.	273.	0.	-2584.	2667.	RESIDUAL 82.	0	0.34	0.35	0.37
21 CC0822 GTST-08/22 POWR		0.	166.	321.	140.	103.	30.	989.	0.	1310.	RESIDUAL 1310.	0	0.11	0.08	0.75
21 CC0822 GTST-08/22 HEAT		0.	1168.	2253.	980.	726.	213.	0.	-1945.	2253.	RESIDUAL 308.	0	0.34	0.32	0.43
22 STIG15 STIG-15-16 POWR		0.	56.	271.	4.	103.	30.	1149.	0.	1420.	RESIDUAL 1420.	1	0.04	0.07	0.69
22 STIG15 STIG-15-16 HEAT		0.	15523.	75395.	980.	28722.	8418.	0.	-89432.	75385.	RESIDUAL -14047.	1	0.17	0.38	0.01
23 STIG10 STIG-10-16 POWR		0.	80.	288.	38.	103.	30.	1108.	0.	1396.	RESIDUAL 1396.	1	0.05	0.07	0.70
23 STIG10 STIG-10-16 HEAT		0.	2057.	7396.	980.	2656.	778.	0.	-7977.	7396.	RESIDUAL -581.	1	0.22	0.36	0.13
24 STIG1S STIG-1S-16 POWR		0.	91.	308.	65.	103.	30.	1076.	0.	1385.	RESIDUAL 1385.	1	0.06	0.07	0.71
24 STIG1S STIG-1S-16 HEAT		0.	1374.	4649.	980.	1558.	457.	0.	-4547.	4649.	RESIDUAL 102.	1	0.23	0.34	0.21
25 DEADV3 DIESEL-ADV POWR		0.	94.	279.	42.	103.	30.	1104.	0.	1382.	RESIDUAL 1382.	1	0.06	0.07	0.71
25 DEADV3 DIESEL-ADV HEAT		0.	2191.	6515.	980.	2417.	708.	0.	-7231.	6515.	RESIDUAL -715.	1	0.25	0.37	0.15
26 DEADV2 DIESEL-ADV POWR		0.	128.	279.	71.	103.	30.	1070.	0.	1348.	RESIDUAL 1348.	1	0.09	0.08	0.73
26 DEADV2 DIESEL-ADV HEAT		0.	1768.	3858.	980.	1431.	420.	0.	-4150.	3858.	RESIDUAL -292.	1	0.31	0.37	0.25
27 DEADV1 DIESEL-ADV POWR		0.	173.	279.	109.	103.	30.	1025.	0.	1303.	RESIDUAL 1303.	1	0.12	0.08	0.75
27 DEADV1 DIESEL-ADV HEAT		0.	1552.	2506.	980.	930.	273.	0.	-2583.	2506.	RESIDUAL -76.	1	0.38	0.37	0.39
28 DEHTPM ADV-DIESEL POWR		0.	134.	384.	166.	103.	30.	958.	0.	1342.	RESIDUAL 1342.	0	0.09	0.08	0.73
28 DEHTPM ADV-DIESEL HEAT		0.	791.	2269.	980.	610.	179.	0.	-1584.	2269.	RESIDUAL 685.	0	0.26	0.27	0.43
29 DES0A3 DIESEL-S0A POWR		0.	76.	286.	33.	103.	30.	1114.	0.	1400.	DISTILLA 1400.	1	0.05	0.07	0.70
29 DES0A3 DIESEL-S0A HEAT		0.	2232.	8418.	980.	3039.	891.	0.	-9174.	8418.	DISTILLA -756.	1	0.21	0.36	0.12
29 DES0A3 DIESEL-S0A POWR		0.	76.	286.	33.	103.	30.	1114.	0.	1400.	RESIDUAL 1400.	1	0.05	0.07	0.70
29 DES0A3 DIESEL-S0A HEAT		0.	2232.	8418.	980.	3039.	891.	0.	-9174.	8418.	RESIDUAL -756.	1	0.21	0.36	0.12

HONEYWELL PAGE PRINTING SYSTEM- P1188-02

ORIGINAL PAGE IS  
OF POOR QUALITY

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 109

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28191 MW 30.29 PROCESS MILLIONS BTU/HR 980.0 PROCESS TEMP(F) 495. PRODUCT ALUMINA HOURS PER YEAR 8136.

POWER TO HEAT RATIO 0.105

WASTE FUEL EQV BTU\*10\*\*6= 0.

HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED-NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
30 DES0A2 DIESEL-S0A	POWR	0.	111.	286.	63.	103.	30.	1079.	0.	1365.	DISTILLA	1365.	1	0.08	0.08	0.72
30 DES0A2 DIESEL-S0A	HEAT	0.	1724.	4455.	980.	1608.	471.	0.	-4702.	4455.	DISTILLA	-248.	1	0.28	0.36	0.22
30 DES0A2 DIESEL-S0A	POWR	0.	111.	286.	63.	103.	30.	1079.	0.	1365.	RESIDUAL	1365.	1	0.08	0.08	0.72
30 DES0A2 DIESEL-S0A	HEAT	0.	1724.	4455.	980.	1608.	471.	0.	-4702.	4455.	RESIDUAL	-248.	1	0.28	0.36	0.22
31 DES0A1 DIESEL-S0A	POWR	0.	172.	286.	115.	103.	30.	1018.	0.	1304.	DISTILLA	1304.	1	0.12	0.08	0.75
31 DES0A1 DIESEL-S0A	HEAT	0.	1466.	2444.	980.	882.	259.	0.	-2434.	2444.	DISTILLA	10.	1	0.37	0.36	0.40
31 DES0A1 DIESEL-S0A	POWR	0.	172.	286.	115.	103.	30.	1018.	0.	1304.	RESIDUAL	1304.	1	0.12	0.08	0.75
31 DES0A1 DIESEL-S0A	HEAT	0.	1466.	2444.	980.	882.	259.	0.	-2434.	2444.	RESIDUAL	10.	1	0.37	0.36	0.40
32 GTS0AD GT-HRS0-10	POWR	0.	158.	354.	160.	103.	30.	964.	0.	1318.	DISTILLA	1318.	0	0.11	0.08	0.74
32 GTS0AD GT-HRS0-10	HEAT	0.	964.	2162.	980.	631.	185.	0.	-1650.	2162.	DISTILLA	512.	0	0.31	0.29	0.45
33 GTRA08 GT-85RE-08	POWR	0.	126.	289.	78.	103.	30.	1061.	0.	1350.	DISTILLA	1350.	0	0.09	0.08	0.73
33 GTRA08 GT-85RE-08	HEAT	0.	1572.	3622.	980.	1293.	379.	0.	-3718.	3622.	DISTILLA	-96.	0	0.30	0.36	0.27
34 GTRA12 GT-85RE-12	POWR	0.	133.	289.	84.	103.	30.	1054.	0.	1343.	DISTILLA	1343.	0	0.09	0.08	0.73
34 GTRA12 GT-85RE-12	HEAT	0.	1552.	3360.	980.	1203.	353.	0.	-3436.	3360.	DISTILLA	-76.	0	0.32	0.36	0.29
35 GTRA16 GT-85RE-16	POWR	0.	137.	296.	94.	103.	30.	1043.	0.	1339.	DISTILLA	1339.	0	0.09	0.08	0.73
35 GTRA16 GT-85RE-16	HEAT	0.	1434.	3103.	980.	1083.	317.	0.	-3001.	3103.	DISTILLA	42.	0	0.32	0.35	0.32
36 GTR208 GT-60RE-08	POWR	0.	140.	323.	119.	103.	30.	1013.	0.	1336.	DISTILLA	1336.	0	0.09	0.08	0.73
36 GTR208 GT-60RE-08	HEAT	0.	1153.	2660.	980.	851.	250.	0.	-2337.	2660.	DISTILLA	323.	0	0.30	0.32	0.37
37 GTR212 GT-60RE-12	POWR	0.	140.	313.	111.	103.	30.	1023.	0.	1336.	DISTILLA	1336.	0	0.09	0.08	0.73
37 GTR212 GT-60RE-12	HEAT	0.	1240.	2772.	980.	915.	268.	0.	-2535.	2772.	DISTILLA	236.	0	0.31	0.33	0.35
38 GTR216 GT-60RE-16	POWR	0.	143.	307.	107.	103.	30.	1027.	0.	1333.	DISTILLA	1333.	0	0.10	0.08	0.73
38 GTR216 GT-60RE-16	HEAT	0.	1302.	2801.	980.	944.	277.	0.	-2627.	2801.	DISTILLA	174.	0	0.32	0.34	0.35
39 GTRW08 GT-85RE-08	POWR	0.	108.	294.	68.	103.	30.	1074.	0.	1368.	DISTILLA	1368.	0	0.07	0.08	0.72
39 GTRW08 GT-85RE-08	HEAT	0.	1567.	4275.	980.	1500.	440.	0.	-4366.	4275.	DISTILLA	-91.	0	0.27	0.35	0.23
40 GTRW12 GT-85RE-12	POWR	0.	121.	284.	69.	103.	30.	1071.	0.	1355.	DISTILLA	1355.	0	0.08	0.08	0.72
40 GTRW12 GT-85RE-12	HEAT	0.	1705.	4012.	980.	1460.	428.	0.	-4240.	4012.	DISTILLA	-229.	0	0.30	0.36	0.24

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28191 MW 30.29 PROCESS MILLIONS BTU/HR 980.0 PROCESS TEMP(F) 495. PRODUCT ALUMINA HOURS PER YEAR 8136.

POWER TO HEAT RATIO 0.105

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL COAL

	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41 GTRW16 GT-85RE-16 POWR	0.	125.	289.	78.	103.	30.	1061.	0.	1351.	DISTILLA	1351.	0	0.08	0.08	0.73
41 GTRW16 GT-85RE-16 HEAT	0.	1574.	3641.	980.	1300.	381.	0.	-3739.	3641.	DISTILLA	-98.	0	0.30	0.36	0.27
42 GTR308 GT-60RE-08 POWR	0.	98.	333.	92.	103.	30.	1044.	0.	1378.	DISTILLA	1378.	0	0.07	0.08	0.71
42 GTR308 GT-60RE-08 HEAT	0.	1042.	3544.	980.	1099.	322.	0.	-3110.	3544.	DISTILLA	434.	0	0.23	0.31	0.28
43 GTR312 GT-60RE-12 POWR	0.	133.	302.	95.	103.	30.	1041.	0.	1343.	DISTILLA	1343.	0	0.09	0.08	0.73
43 GTR312 GT-60RE-12 HEAT	0.	1367.	3115.	980.	1065.	312.	0.	-3006.	3115.	DISTILLA	109.	0	0.31	0.34	0.31
44 GTR316 GT-60RE-16 POWR	0.	132.	305.	97.	103.	30.	1039.	0.	1344.	DISTILLA	1344.	0	0.09	0.08	0.73
44 GTR316 GT-60RE-16 HEAT	0.	1336.	3085.	980.	1046.	307.	0.	-2945.	3085.	DISTILLA	140.	0	0.30	0.34	0.32
45 FCPADS FUEL-CL-PH POWR	0.	105.	272.	46.	103.	30.	1099.	0.	1371.	DISTILLA	1371.	0	0.07	0.08	0.72
45 FCPADS FUEL-CL-PH HEAT	0.	2234.	5765.	980.	2191.	642.	0.	-6523.	5765.	DISTILLA	-758.	0	0.28	0.38	0.17
46 FCMCDS FUEL-CL-MO POWR	0.	141.	251.	58.	103.	30.	1084.	0.	1335.	DISTILLA	1335.	0	0.10	0.08	0.73
46 FCMCDS FUEL-CL-MO HEAT	0.	2362.	4206.	980.	1733.	508.	0.	-5092.	4206.	DISTILLA	-886.	0	0.36	0.41	0.23

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 111

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28192 MW 60.58 PROCESS MILLIONS BTU/HR 1961.0 PROCESS TEMP(F) 495. PRODUCT ALUMINA HOURS PER YEAR 8136.

UTILITY FUEL		COAL		POWER TO HEAT RATIO 0.105										WASTE FUEL EQV BTU*10**6= 0.		HOT WATER BTU*10**6= 0.	
WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR			
0 ONOCGN N C O G O N	0.	0.	0.	0.	0.	0.	2307.	646.	2307.	COAL-FGD	2953.	0	0.	0.07	0.66		
1 STM141 STM-TURB-1 POWR	0.	403.	2267.	1720.	207.	61.	284.	0.	2550.	RESIDUAL	2550.	0	0.14	0.08	0.77		
1 STM141 STM-TURB-1 HEAT	0.	459.	2584.	1961.	236.	69.	0.	-91.	2584.	RESIDUAL	2494.	0	0.15	0.09	0.76		
1 STM141 STM-TURB-1 POWR	0.	403.	2267.	1720.	207.	61.	284.	0.	2550.	COAL-FGD	2550.	0	0.14	0.08	0.77		
1 STM141 STM-TURB-1 HEAT	0.	459.	2584.	1961.	236.	69.	0.	-91.	2584.	COAL-FGD	2494.	0	0.15	0.09	0.76		
1 STM141 STM-TURB-1 POWR	0.	403.	2267.	1720.	207.	61.	284.	0.	2550.	COAL-AFB	2550.	0	0.14	0.08	0.77		
1 STM141 STM-TURB-1 HEAT	0.	459.	2584.	1961.	236.	69.	0.	-91.	2584.	COAL-AFB	2494.	0	0.15	0.09	0.76		
2 STM088 STM-TURB-8 POWR	0.	-793.	3746.	2977.	207.	61.	-1196.	0.	3746.	RESIDUAL	3746.	0	-0.27	0.06	0.52		
2 STM088 STM-TURB-8 HEAT	0.	265.	2467.	1961.	136.	40.	0.	220.	2467.	RESIDUAL	2688.	0	0.09	0.05	0.73		
2 STM088 STM-TURB-8 POWR	0.	-793.	3746.	2977.	207.	61.	-1196.	0.	3746.	COAL-FGD	3746.	0	-0.27	0.06	0.52		
2 STM088 STM-TURB-8 HEAT	0.	265.	2467.	1961.	136.	40.	0.	220.	2467.	COAL-FGD	2688.	0	0.09	0.05	0.73		
2 STM088 STM-TURB-8 POWR	0.	-793.	3746.	2977.	207.	61.	-1196.	0.	3746.	COAL-AFB	3746.	0	-0.27	0.06	0.52		
2 STM088 STM-TURB-8 HEAT	0.	265.	2467.	1961.	136.	40.	0.	220.	2467.	COAL-AFB	2688.	0	0.09	0.05	0.73		
3 PFBSTM PFB-STMTB- POWR	0.	386.	1260.	850.	207.	61.	1307.	0.	2567.	COAL-PFB	2567.	0	0.13	0.08	0.76		
3 PFBSTM PFB-STMTB- HEAT	0.	391.	2906.	1961.	477.	140.	0.	-844.	2906.	COAL-PFB	2062.	0	0.23	0.16	0.67		
4 T1STMT TI-STMTB-1 POWR	0.	395.	960.	602.	207.	61.	1598.	0.	2558.	RESIDUAL	2558.	0	0.13	0.08	0.77		
4 T1STMT TI-STMTB-1 HEAT	0.	1285.	3124.	1961.	673.	197.	0.	-1457.	3124.	RESIDUAL	1668.	0	0.29	0.22	0.63		
4 T1STMT TI-STMTB-1 POWR	0.	395.	960.	602.	207.	61.	1598.	0.	2558.	COAL	2558.	0	0.13	0.08	0.77		
4 T1STMT TI-STMTB-1 HEAT	0.	1285.	3124.	1961.	673.	197.	0.	-1457.	3124.	COAL	1668.	0	0.29	0.22	0.63		
5 TIHRSG THERMIONIC POWR	0.	205.	1469.	874.	207.	61.	1279.	0.	2748.	RESIDUAL	2748.	0	0.07	0.08	0.71		
5 TIHRSG THERMIONIC HEAT	0.	460.	3296.	1961.	464.	136.	0.	-803.	3296.	RESIDUAL	2493.	0	0.12	0.14	0.60		
5 TIHRSG THERMIONIC POWR	0.	205.	1469.	874.	207.	61.	1279.	0.	2748.	COAL	2748.	0	0.07	0.08	0.71		
5 TIHRSG THERMIONIC HEAT	0.	460.	3296.	1961.	464.	136.	0.	-803.	3296.	COAL	2493.	0	0.12	0.14	0.60		
6 STIRL STIRLING-1 POWR	0.	267.	951.	486.	207.	61.	1735.	0.	2686.	DISTILLA	2686.	0	0.09	0.08	0.73		
6 STIRL STIRLING-1 HEAT	0.	1075.	3836.	1961.	833.	244.	0.	-1958.	3836.	DISTILLA	1878.	0	0.22	0.22	0.51		

HONEYWELL PAGE PRINTING SYSTEM- P1185-02



I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28192 MW 60.58 PROCESS MILLIONS BTU/HR 1961.0 PROCESS TEMP(F) 495. PRODUCT ALUMINA HOURS PER YEAR 8136.

POWER TO HEAT RATIO 0.105

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET USED 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET* TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
6 STIRL	STIRLING-1 POWR	0.	267.	951.	486.	207.	61.	1735.	0.	2686.	RESIDUAL	2686.	0	0.09	0.08	0.73
6 STIRL	STIRLING-1 HEAT	0.	1075.	3836.	1961.	833.	244.	0.	-1958.	3836.	RESIDUAL	1878.	0	0.22	0.22	0.51
6 STIRL	STIRLING-1 POWR	0.	267.	951.	486.	207.	61.	1735.	0.	2686.	COAL	2686.	0	0.09	0.08	0.73
6 STIRL	STIRLING-1 HEAT	0.	1075.	3836.	1961.	833.	244.	0.	-1958.	3836.	COAL	1878.	0	0.22	0.22	0.51
7 HEGT85	HELIUM-GT- POWR	0.	-79.	644.	-69.	207.	61.	2388.	0.	3032.	COAL-AFB	3032.	1	-0.03	0.07	0.65
7 HEGT85	HELIUM-GT- HEAT-18422.	2249.	-18422.	1961.	-5913.	-1733.	0.	19125.	-18422.	COAL-AFB	704.	704.	11	-5.48	-8.41	2.79
8 HEGT60	HELIUM-GT- POWR	0.	-19.	798.	113.	207.	61.	2174.	0.	2972.	COAL-AFB	2972.	0	-0.01	0.07	0.66
8 HEGT60	HELIUM-GT- HEAT	0.	-325.	13809.	1961.	3577.	1048.	0.	-10531.	13809.	COAL-AFB	3278.	0	-0.02	0.26	0.14
9 HEGT00	HELIUM-GT- POWR	0.	110.	1174.	543.	207.	61.	1669.	0.	2843.	COAL-AFB	2843.	0	0.04	0.07	0.69
9 HEGT00	HELIUM-GT- HEAT	0.	397.	4244.	1961.	747.	219.	0.	-1688.	4244.	COAL-AFB	2556.	0	0.09	0.18	0.46
10 FCMCCL	FUEL-CL-MO POWR	0.	342.	680.	320.	207.	61.	1931.	0.	2611.	COAL	2611.	10	0.12	0.08	0.75
10 FCMCCL	FUEL-CL-MO HEAT	0.	2098.	4172.	1961.	1268.	372.	0.	-3317.	4172.	COAL	855.	0	0.33	0.30	0.47
11 FCSTCL	FUEL-CL-ST POWR	0.	354.	582.	247.	207.	61.	2017.	0.	2599.	COAL	2599.	10	0.12	0.08	0.75
11 FCSTCL	FUEL-CL-ST HEAT	0.	2814.	4625.	1961.	1642.	481.	0.	-4486.	4625.	COAL	139.	0	0.38	0.36	0.42
12 IGGTST	INT-GAS-GT POWR	0.	269.	813.	370.	207.	61.	1872.	0.	2684.	COAL	2684.	10	0.09	0.08	0.73
12 IGGTST	INT-GAS-GT HEAT	0.	1425.	4304.	1961.	1095.	321.	0.	-2776.	4304.	COAL	1528.	0	0.25	0.25	0.46
13 GTSOAR	GT-HRSO-10 POWR	0.	252.	713.	271.	207.	61.	1988.	0.	2701.	RESIDUAL	2701.	0	0.09	0.08	0.73
13 GTSOAR	GT-HRSO-10 HEAT	0.	1824.	5157.	1961.	1496.	438.	0.	-4028.	5157.	RESIDUAL	1129.	0	0.26	0.29	0.38
14 GTAC08	GT-HRSO-08 POWR	0.	345.	766.	395.	207.	61.	1843.	0.	2608.	RESIDUAL	2608.	0	0.12	0.08	0.75
14 GTAC08	GT-HRSO-08 HEAT	0.	1713.	3803.	1961.	1027.	301.	0.	-2583.	3803.	RESIDUAL	1240.	0	0.31	0.27	0.52
15 GTAC12	GT-HRSO-12 POWR	0.	338.	678.	314.	207.	61.	1937.	0.	2615.	RESIDUAL	2615.	0	0.11	0.08	0.75
15 GTAC12	GT-HRSO-12 HEAT	0.	2109.	4229.	1961.	1290.	378.	0.	-3385.	4229.	RESIDUAL	844.	0	0.33	0.31	0.46
16 GTAC16	GT-HRSO-16 POWR	0.	322.	640.	269.	207.	61.	1991.	0.	2631.	RESIDUAL	2631.	0	0.11	0.08	0.75
16 GTAC16	GT-HRSO-16 HEAT	0.	2351.	4667.	1961.	1507.	442.	0.	-4084.	4667.	RESIDUAL	602.	0	0.33	0.32	0.42
17 GTWC16	GT-HRSO-16 POWR	0.	303.	656.	266.	207.	61.	1994.	0.	2650.	RESIDUAL	2650.	0	0.10	0.08	0.74
17 GTWC16	GT-HRSO-16 HEAT	0.	2232.	4835.	1961.	1523.	446.	0.	-4113.	4835.	RESIDUAL	721.	0	0.32	0.32	0.41

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 113

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28192 MW 60.58 PROCESS MILLIONS BTU/HR 1961.0 PROCESS TEMP(F) 495. PRODUCT ALUMINA HOURS PER YEAR 8136.

POWER TO HEAT RATIO 0.105

WASTE FUEL EQV BTU\*10\*\*6= 0.

HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET USED 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET* TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
18 CC1626	GTST-16/26	POWR	0.	292.	582.	193.	207.	61.	2080.	0.	2661.	RESIDUAL	2661.	0	0.10	0.08	0.74
18 CC1626	GTST-16/26	HEAT	0.	2957.	5900.	1961.	2096.	614.	0.	-5904.	5900.	RESIDUAL	-4.	0	0.33	0.36	0.33
19 CC1622	GTST-16/22	POWR	0.	307.	593.	216.	207.	61.	2053.	0.	2646.	RESIDUAL	2646.	0	0.10	0.08	0.74
19 CC1622	GTST-16/22	HEAT	0.	2785.	5389.	1961.	1877.	550.	0.	-5221.	5389.	RESIDUAL	168.	0	0.34	0.35	0.36
20 CC1222	GTST-12/22	POWR	0.	310.	592.	218.	207.	61.	2051.	0.	2643.	RESIDUAL	2643.	0	0.10	0.08	0.74
20 CC1222	GTST-12/22	HEAT	0.	2789.	5336.	1961.	1862.	546.	0.	-5172.	5336.	RESIDUAL	164.	0	0.34	0.35	0.37
21 CC0822	GTST-08/22	POWR	0.	333.	642.	279.	207.	61.	1979.	0.	2620.	RESIDUAL	2620.	0	0.11	0.08	0.75
21 CC0822	GTST-08/22	HEAT	0.	2337.	4509.	1961.	1452.	426.	0.	-3893.	4509.	RESIDUAL	616.	0	0.34	0.32	0.43
22 ST1015	STIG-15-16	POWR	0.	112.	543.	7.	207.	61.	2299.	0.	2841.	RESIDUAL	2841.	1	0.04	0.07	0.69
22 ST1015	STIG-15-16	HEAT	0.	31062.	150846.	1961.	57472.	16844.	0.	*****150846.	RESIDUAL	-28109.	1	0.17	0.38	0.01	
23 ST1010	STIG-10-16	POWR	0.	160.	576.	76.	207.	61.	2217.	0.	2793.	RESIDUAL	2793.	1	0.05	0.07	0.70
23 ST1010	STIG-10-16	HEAT	0.	4115.	14800.	1961.	5315.	1558.	0.	-15982.	14800.	RESIDUAL	-1162.	1	0.22	0.36	0.13
24 ST101S	STIG-1S-16	POWR	0.	182.	617.	130.	207.	61.	2154.	0.	2771.	RESIDUAL	2771.	1	0.06	0.07	0.71
24 ST101S	STIG-1S-16	HEAT	0.	2749.	9303.	1961.	3118.	914.	0.	-9099.	9303.	RESIDUAL	204.	1	0.23	0.34	0.21
25 DEADV3	DIESEL-ADV	POWR	0.	187.	557.	84.	207.	61.	2208.	0.	2766.	RESIDUAL	2766.	1	0.06	0.07	0.71
25 DEADV3	DIESEL-ADV	HEAT	0.	4385.	13037.	1961.	4837.	1418.	0.	-14469.	13037.	RESIDUAL	-1432.	1	0.25	0.37	0.15
26 DEADV2	DIESEL-ADV	POWR	0.	255.	557.	142.	207.	61.	2141.	0.	2698.	RESIDUAL	2698.	1	0.09	0.08	0.73
26 DEADV2	DIESEL-ADV	HEAT	0.	3538.	7720.	1961.	2864.	839.	0.	-8305.	7720.	RES'DUAL	-585.	1	0.31	0.37	0.25
27 DEADV1	DIESEL-ADV	POWR	0.	345.	557.	218.	207.	61.	2051.	0.	2608.	RESIDUAL	2608.	1	0.12	0.08	0.75
27 DEADV1	DIESEL-ADV	HEAT	0.	3106.	5015.	1961.	1861.	545.	0.	-5169.	5015.	RESIDUAL	-153.	1	0.38	0.37	0.39
28 DEHTPM	ADV-DIESEL	POWR	0.	268.	769.	332.	207.	61.	1917.	0.	2685.	RESIDUAL	2685.	0	0.09	0.08	0.73
28 DEHTPM	ADV-DIESEL	HEAT	0.	1583.	4540.	1961.	1221.	358.	0.	-3170.	4540.	RESIDUAL	1370.	0	0.26	0.27	0.43
29 DESOA3	DIESEL-SOA	POWR	0.	152.	573.	67.	207.	61.	2229.	0.	2801.	DISTILLA	2801.	1	0.05	0.07	0.70
29 DESOA3	DIESEL-SOA	HEAT	0.	4465.	16845.	1961.	6081.	1782.	0.	-18357.	16845.	DISTILLA	-1512.	1	0.21	0.36	0.12
29 DESOA3	DIESEL-SOA	POWR	0.	152.	573.	67.	207.	61.	2229.	0.	2801.	RESIDUAL	2801.	1	0.05	0.07	0.70
29 DESOA3	DIESEL-SOA	HEAT	0.	4465.	16845.	1961.	6081.	1782.	0.	-18357.	16845.	RESIDUAL	-1512.	1	0.21	0.36	0.12

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

L&amp;SE PEG ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28192 MW 60.58 PROCESS MILLIONS BTU/HR 1961.0 PROCESS TEMP(F) 495. PRODUCT ALUMINA HOURS PER YEAR 8106.

		POWER TO HEAT RATIO 0.105														
		WASTE FUEL EQV BTU*10**6= 0.						HOT WATER BTU*10**6= 0.								
UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET* TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
30 DES0A2 DIESEL-S0A	POWR	0.	222.	573.	126.	207.	61.	2159.	0.	2731.	DISTILLA	2731.	1	0.08	0.08	0.72
30 DES0A2 DIESEL-S0A	HEAT	0.	3449.	8914.	1961.	3218.	943.	0.	-9410.	8914.	DISTILLA	-496.	1	0.28	0.36	0.22
30 DES0A2 DIESEL-S0A	POWR	0.	222.	573.	126.	207.	61.	2159.	0.	2731.	RESIDUAL	2731.	1	0.08	0.08	0.72
30 DES0A2 DIESEL-S0A	HEAT	0.	3449.	8914.	1961.	3218.	943.	0.	-9410.	8914.	RESIDUAL	-496.	1	0.28	0.36	0.22
31 DES0A1 DIESEL-S0A	POWR	0.	343.	573.	230.	207.	61.	2037.	0.	2610.	DISTILLA	2610.	1	0.12	0.08	0.75
31 DES0A1 DIESEL-S0A	HEAT	0.	2934.	4890.	1961.	1765.	517.	0.	-4871.	4890.	DISTILLA	19.	1	0.37	0.36	0.40
31 DES0A1 DIESEL-S0A	POWR	0.	343.	573.	230.	207.	61.	2037.	0.	2610.	RESIDUAL	2610.	1	0.12	0.08	0.75
31 DES0A1 DIESEL-S0A	HEAT	0.	2934.	4890.	1961.	1765.	517.	0.	-4871.	4890.	RESIDUAL	19.	1	0.37	0.36	0.40
32 GTS0AD GT-HRSG-10	POWR	0.	316.	708.	321.	207.	61.	1930.	0.	2637.	DISTILLA	2637.	0	0.11	0.08	0.74
32 GTS0AD GT-HRSG-10	HEAT	0.	1928.	4327.	1961.	1263.	370.	0.	-3302.	4327.	DISTILLA	1025.	0	0.31	0.29	0.45
33 GTRA08 GT-85RE-08	POWR	0.	251.	579.	157.	207.	61.	2123.	0.	2702.	DISTILLA	2702.	0	0.09	0.08	0.73
33 GTRA08 GT-85RE-08	HEAT	0.	3145.	7248.	1961.	2587.	758.	0.	-7440.	7248.	DISTILLA	-192.	0	0.30	0.36	0.27
34 GTRA12 GT-85RE-12	POWR	0.	267.	577.	168.	207.	61.	2109.	0.	2686.	DISTILLA	2686.	0	0.09	0.08	0.73
34 GTRA12 GT-85RE-12	HEAT	0.	3105.	6723.	1961.	2407.	705.	0.	-6875.	6723.	DISTILLA	-152.	0	0.32	0.36	0.29
35 GTRA16 GT-85RE-16	POWR	0.	274.	592.	187.	207.	61.	2087.	0.	2679.	DISTILLA	2679.	0	0.09	0.08	0.73
35 GTRA16 GT-85RE-16	HEAT	0.	2870.	6209.	1961.	2167.	635.	0.	-6125.	6209.	DISTILLA	83.	0	0.32	0.35	0.32
36 GTR208 GT-60RE-08	POWR	0.	280.	646.	238.	207.	61.	2027.	0.	2673.	DISTILLA	2673.	0	0.09	0.08	0.73
36 GTR208 GT-60RE-08	HEAT	0.	2307.	5323.	1961.	1703.	499.	0.	-4677.	5323.	DISTILLA	646.	0	0.30	0.32	0.37
37 GTR212 GT-60RE-12	POWR	0.	280.	626.	221.	207.	61.	2047.	0.	2673.	DISTILLA	2673.	0	0.09	0.08	0.73
37 GTR212 GT-60RE-12	HEAT	0.	2480.	5546.	1961.	1830.	536.	0.	-5074.	5546.	DISTILLA	473.	0	0.31	0.33	0.35
38 GTR216 GT-60RE-16	POWR	0.	285.	613.	215.	207.	61.	2055.	0.	2668.	DISTILLA	2668.	0	0.10	0.08	0.74
38 GTR216 GT-60RE-16	HEAT	0.	2605.	5605.	1961.	1889.	554.	0.	-5257.	5605.	DISTILLA	348.	0	0.32	0.34	0.35
39 GTRW08 GT-85RE-08	POWR	0.	216.	589.	135.	207.	61.	2148.	0.	2737.	DISTILLA	2737.	0	0.07	0.08	0.72
39 GTRW08 GT-85RE-08	HEAT	0.	3136.	8554.	1961.	3002.	880.	0.	-8736.	8554.	DISTILLA	-183.	0	0.27	0.35	0.23
40 GTRW12 GT-85RE-12	POWR	0.	241.	568.	139.	207.	61.	2144.	0.	2712.	DISTILLA	2712.	0	0.08	0.08	0.72
40 GTRW12 GT-85RE-12	HEAT	0.	3411.	8027.	1961.	2922.	856.	0.	-8485.	8027.	DISTILLA	-458.	0	0.30	0.36	0.24

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 115

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28192 MW 60.58 PROCESS MILLIONS BTU/HR 1961.0 PROCESS TEMP(F) 495. PRODUCT ALUMINA HOURS PER YEAR 8136.

POWER TO HEAT RATIO 0.105

WASTE FUEL EQV BTU\*10\*\*6= 0.

HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	AUX ELECT MW	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41 GTRW16 GT-85RE-16	POWR	0.	250.	579.	156.	207.	61.	2124.	0.	2703.	DISTILLA 2703.	0	0.08	0.08	0.73
41 GTRW16 GT-85RE-16	HEAT	0.	3150.	7286.	1961.	2601.	762.	0.	-7483.	7286.	DISTILLA -197.	0	0.30	0.36	0.27
42 GTR308 GT-60RE-08	POWR	0.	196.	667.	184.	207.	61.	2090.	0.	2757.	DISTILLA 2757.	0	0.07	0.07	0.71
42 GTR308 GT-60RE-08	HEAT	0.	2085.	7092.	1961.	2199.	644.	0.	-6224.	7092.	DISTILLA 868.	0	0.23	0.31	0.28
43 GTR312 GT-60RE-12	POWR	0.	265.	604.	190.	207.	61.	2083.	0.	2688.	DISTILLA 2688.	0	0.09	0.08	0.73
43 GTR312 GT-60RE-12	HEAT	0.	2736.	6233.	1961.	2132.	625.	0.	-6016.	6233.	DISTILLA 217.	0	0.31	0.34	0.31
44 GTR316 GT-60RE-16	POWR	0.	264.	610.	194.	207.	61.	2079.	0.	2689.	DISTILLA 2689.	0	0.09	0.08	0.73
44 GTR316 GT-60RE-16	HEAT	0.	2674.	6173.	1961.	2093.	613.	0.	-5894.	6173.	DISTILLA 279.	0	0.30	0.34	0.32
45 FCPADS FUEL-CL-PH	POWR	0.	211.	544.	92.	207.	61.	2198.	0.	2742.	DISTILLA 2742.	0	0.07	0.08	0.72
45 FCPADS FUEL-CL-PH	HEAT	0.	4470.	11535.	1961.	4383.	1285.	0.	-13052.	11535.	DISTILLA -1517.	0	0.28	0.38	0.17
46 FCMCDS FUEL-CL-MO	POWR	0.	282.	502.	117.	207.	61.	2170.	0.	2671.	DISTILLA 2671.	0	0.10	0.08	0.73
46 FCMCDS FUEL-CL-MO	HEAT	0.	4727.	8416.	1961.	3468.	1016.	0.	-10190.	8416.	DISTILLA -1774.	0	0.36	0.41	0.23

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28212 MW 4.00 PROCESS MILLIONS BTU/HR 207.0 PROCESS TEMP(F) 422. PRODUCT VINYL-CHLORI HOURS PER YEAR 8300.

UTILITY FUEL COAL

POWER TO HEAT RATIO 0.066

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
------------------------------	---------------------------------	------------------------------	--------------------------------	---------------------------------	----------------	-------------------------------	-------------------------------	------------------------------	----------------	---------------------------------	------	------	-------------	------------

0 ONCOGN N O C O G O N	0.	0.	0.	0.	0.	0.	244.	43.	244.	COAL-FGD	286.	0	0.	0.05	0.72
1 STM141 STM-TURB-1 POWR	0.	27.	108.	78.	14.	4.	152.	0.	260.	RESIDUAL	260.	10	0.09	0.05	0.80
1 STM141 STM-TURB-1 HEAT	0.	71.	286.	207.	36.	11.	0.	-70.	286.	RESIDUAL	216.	0	0.20	0.13	0.72
1 STM141 STM-TURB-1 POWR	0.	27.	108.	78.	14.	4.	152.	0.	260.	COAL-FGD	260.	10	0.09	0.05	0.80
1 STM141 STM-TURB-1 HEAT	0.	71.	286.	207.	36.	11.	0.	-70.	286.	COAL-FGD	216.	0	0.20	0.13	0.72
1 STM141 STM-TURB-1 POWR	0.	27.	108.	78.	14.	4.	152.	0.	260.	COAL-AFB	260.	10	0.09	0.05	0.80
1 STM141 STM-TURB-1 HEAT	0.	71.	286.	207.	36.	11.	0.	-70.	286.	COAL-AFB	216.	0	0.20	0.13	0.72
2 STM088 STM-TURB-8 POWR	0.	27.	149.	113.	14.	4.	110.	0.	260.	RESIDUAL	260.	10	0.09	0.05	0.80
2 STM088 STM-TURB-8 HEAT	0.	49.	273.	207.	25.	7.	0.	-35.	273.	RESIDUAL	238.	0	0.15	0.09	0.76
2 STM088 STM-TURB-8 POWR	0.	27.	149.	113.	14.	4.	110.	0.	260.	COAL-FGD	260.	10	0.09	0.05	0.80
2 STM088 STM-TURB-8 HEAT	0.	49.	273.	207.	25.	7.	0.	-35.	273.	COAL-FGD	238.	0	0.15	0.09	0.76
2 STM088 STM-TURB-8 POWR	0.	27.	149.	113.	14.	4.	110.	0.	260.	COAL-AFB	260.	10	0.09	0.05	0.80
2 STM088 STM-TURB-8 HEAT	0.	49.	273.	207.	25.	7.	0.	-35.	273.	COAL-AFB	238.	0	0.15	0.09	0.76
3 PFBSTM PFB-STMTB- POWR	0.	26.	70.	45.	14.	4.	190.	0.	260.	COAL-PFB	260.	10	0.09	0.05	0.80
3 PFBSTM PFB-STMTB- HEAT	0.	118.	320.	207.	62.	18.	0.	-152.	320.	COAL-PFB	168.	0	0.27	0.19	0.65
4 TISTMT TI-STMTB-1 POWR	0.	26.	56.	33.	14.	4.	204.	0.	260.	RESIDUAL	260.	10	0.09	0.05	0.80
4 TISTMT TI-STMTB-1 HEAT	0.	162.	346.	207.	85.	25.	0.	-222.	346.	RESIDUAL	124.	0	0.32	0.24	0.60
4 TISTMT TI-STMTB-1 POWR	0.	26.	56.	33.	14.	4.	204.	0.	260.	COAL	260.	10	0.09	0.05	0.80
4 TISTMT TI-STMTB-1 HEAT	0.	162.	346.	207.	85.	25.	0.	-222.	346.	COAL	124.	0	0.32	0.24	0.60
5 TIHRSG THERMIONIC POWR	0.	17.	97.	61.	14.	4.	172.	0.	269.	RESIDUAL	269.	0	0.06	0.05	0.77
5 TIHRSG THERMIONIC HEAT	0.	58.	331.	207.	47.	14.	0.	-103.	331.	RESIDUAL	228.	0	0.15	0.14	0.63
5 TIHRSG THERMIONIC POWR	0.	17.	97.	61.	14.	4.	172.	0.	269.	COAL	269.	0	0.06	0.05	0.77
5 TIHRSG THERMIONIC HEAT	0.	58.	331.	207.	47.	14.	0.	-103.	331.	COAL	228.	0	0.15	0.14	0.63
6 STIRL STIRLING-1 POWR	0.	18.	57.	28.	14.	4.	210.	0.	268.	DISTILLA	268.	0	0.06	0.05	0.77
6 STIRL STIRLING-1 HEAT	0.	135.	422.	207.	100.	29.	0.	-271.	422.	DISTILLA	151.	0	0.24	0.24	0.49

ORIGINAL PAGE IS  
OF POOR QUALITY

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 117

I&amp;SE PEG ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28212 MW 4.00 PROCESS MILLIONS BTU/HR 207.0 PROCESS TEMP(F) 422. PRODUCT VINYL-CHLORI HOURS PER YEAR 8300.

POWER TO HEAT RATIO 0.066

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
6 STIRL	STIRLING-1 POWR	0.	18.	57.	28.	14.	4.	210.	0.	268.	RESIDUAL	268.	0	0.06	0.05	0.77
6 STIRL	STIRLING-1 HEAT	0.	135.	422.	207.	100.	29.	0.	-271.	422.	RESIDUAL	151.	0	0.24	0.24	0.49
6 STIRL	STIRLING-1 POWR	0.	18.	57.	28.	14.	4.	210.	0.	268.	COAL	268.	0	0.06	0.05	0.77
6 STIRL	STIRLING-1 HEAT	0.	135.	422.	207.	100.	29.	0.	-271.	422.	COAL	151.	0	0.24	0.24	0.49
7 HEGT85	HELIUM-GT- POWR	0.	2.	43.	1.	14.	4.	242.	0.	285.	COAL-AFB	285.	11	0.01	0.05	0.73
7 HEGT85	HELIUM-GT- HEAT	0.	267.	7482.	207.	2402.	704.	0.	-7483.	7482.	COAL-AFB	19.	1	0.03	0.32	0.03
8 HEGT60	HELIUM-GT- POWR	0.	4.	53.	12.	14.	4.	229.	0.	282.	COAL-AFB	282.	10	0.02	0.05	0.73
8 HEGT60	HELIUM-GT- HEAT	0.	74.	890.	207.	231.	68.	0.	-678.	890.	COAL-AFB	212.	0	0.08	0.26	0.23
9 HEGT00	HELIUM-GT- POWR	0.	9.	78.	37.	14.	4.	200.	0.	278.	COAL-AFB	278.	10	0.03	0.05	0.75
9 HEGT00	HELIUM-GT- HEAT	0.	48.	435.	207.	77.	22.	0.	-197.	435.	COAL-AFB	238.	10	0.10	0.18	0.48
10 FCMCCL	FUEL-CL-MO POWR	0.	23.	45.	21.	14.	4.	219.	0.	263.	COAL	263.	10	0.08	0.05	0.79
10 FCMCCL	FUEL-CL-MO HEAT	0.	222.	439.	207.	133.	39.	0.	-374.	439.	COAL	65.	10	0.34	0.30	0.47
11 FCSTCL	FUEL-CL-ST POWR	0.	24.	36.	15.	14.	4.	226.	0.	263.	COAL	263.	10	0.08	0.05	0.79
11 FCSTCL	FUEL-CL-ST HEAT	0.	330.	511.	207.	191.	56.	0.	-556.	511.	COAL	-44.	10	0.39	0.37	0.40
12 IGGTST	INT-GAS-GT POWR	0.	18.	50.	22.	14.	4.	218.	0.	268.	COAL	268.	10	0.06	0.05	0.77
12 IGGTST	INT-GAS-GT HEAT	0.	177.	476.	207.	131.	38.	0.	-368.	476.	COAL	109.	10	0.27	0.28	0.43
13 GTSOAR	GT-HRSG-10 POWR	0.	18.	47.	19.	14.	4.	221.	0.	268.	RESIDUAL	268.	10	0.06	0.05	0.77
13 GTSOAR	GT-HRSG-10 HEAT	0.	196.	510.	207.	148.	43.	0.	-419.	510.	RESIDUAL	90.	0	0.28	0.29	0.41
14 GTAC08	GT-HRSG-08 POWR	0.	23.	51.	26.	14.	4.	213.	0.	263.	RESIDUAL	263.	10	0.08	0.05	0.79
14 GTAC08	GT-HRSG-08 HEAT	0.	181.	401.	207.	108.	32.	0.	-296.	401.	RESIDUAL	105.	0	0.31	0.27	0.52
15 GTAC12	GT-HRSG-12 POWR	0.	22.	45.	21.	14.	4.	219.	0.	264.	RESIDUAL	264.	10	0.08	0.05	0.78
15 GTAC12	GT-HRSG-12 HEAT	0.	223.	447.	207.	136.	40.	0.	-384.	447.	RESIDUAL	64.	0	0.33	0.31	0.46
16 GTAC16	GT-HRSG-16 POWR	0.	22.	42.	18.	14.	4.	222.	0.	265.	RESIDUAL	265.	10	0.08	0.05	0.78
16 GTAC16	GT-HRSG-16 HEAT	0.	248.	486.	207.	157.	46.	0.	-447.	486.	RESIDUAL	38.	0	0.34	0.32	0.43
17 GTWC16	GT-HRSG-16 POWR	0.	20.	43.	18.	14.	4.	223.	0.	266.	RESIDUAL	266.	10	0.07	0.05	0.78
17 GTWC16	GT-HRSG-16 HEAT	0.	236.	511.	207.	161.	47.	0.	-480.	511.	RESIDUAL	51.	0	0.32	0.32	0.41

HONEYWELL PAGE PRINTING SYSTEM- P1188-02

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28212 MW 4.00 PROCESS MILLIONS BTU/HR 207.0 PROCESS TEMP(F) 422. PRODUCT VINYL-CHLORI HOURS PER YEAR 8300.

		POWER TO HEAT RATIO 0.066														
UTILITY FUEL		WASTE FUEL EQV BTU*10**6= 0.										HOT WATER BTU*10**6= 0.				
	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
18	CC1626 GTST-16/26 POWR	0.	20.	37.	12.	14.	4.	230.	0.	267.	RESIDUAL	267.	10	0.07	0.05	0.78
18	CC1626 GTST-16/26 HEAT	0.	347.	653.	207.	242.	71.	0.	-714.	653.	RESIDUAL	-61.	0	0.35	0.37	0.32
19	CC1622 GTST-16/22 POWR	0.	21.	37.	13.	14.	4.	228.	0.	266.	RESIDUAL	266.	10	0.07	0.05	0.78
19	CC1622 GTST-16/22 HEAT	0.	327.	596.	207.	218.	64.	0.	-637.	596.	RESIDUAL	-41.	0	0.35	0.36	0.35
20	CC1222 GTST-12/22 POWR	0.	21.	37.	13.	14.	4.	228.	0.	265.	RESIDUAL	265.	10	0.07	0.05	0.78
20	CC1222 GTST-12/22 HEAT	0.	328.	591.	207.	216.	63.	0.	-633.	591.	RESIDUAL	-42.	0	0.36	0.37	0.35
21	CC0822 GTST-08/22 POWR	0.	22.	40.	17.	14.	4.	224.	0.	264.	RESIDUAL	264.	10	0.08	0.05	0.78
21	CC0822 GTST-08/22 HEAT	0.	278.	499.	207.	171.	50.	0.	-491.	499.	RESIDUAL	8.	0	0.36	0.34	0.41
22	STIG15 STIG-15-16 POWR	0.	7.	36.	0.	14.	4.	243.	0.	279.	RESIDUAL	279.	10	0.03	0.05	0.74
22	STIG15 STIG-15-16 HEAT	0.	3279.	15923.	207.	6067.	1778.	0.	-18916.	15923.	RESIDUAL	-2993.	0	0.17	0.38	0.01
23	STIG10 STIG-10-16 POWR	0.	11.	38.	5.	14.	4.	238.	0.	276.	RESIDUAL	276.	10	0.04	0.05	0.75
23	STIG10 STIG-10-16 HEAT	0.	434.	1562.	207.	561.	164.	0.	-1711.	1562.	RESIDUAL	-148.	0	0.22	0.36	0.13
24	STIG1S STIG-1S-16 POWR	0.	12.	41.	9.	14.	4.	233.	0.	274.	RESIDUAL	274.	10	0.04	0.05	0.76
24	STIG1S STIG-1S-16 HEAT	0.	290.	982.	207.	329.	96.	0.	-986.	982.	RESIDUAL	-4.	0	0.23	0.34	0.21
25	DEADV3 DIESEL-ADV POWR	0.	14.	37.	7.	14.	4.	236.	0.	272.	RESIDUAL	272.	0	0.05	0.05	0.76
25	DEADV3 DIESEL-ADV HEAT	0.	426.	1142.	207.	424.	124.	0.	-1281.	1142.	RESIDUAL	-139.	0	0.27	0.37	0.18
26	DEADV2 DIESEL-ADV POWR	0.	17.	37.	9.	14.	4.	233.	0.	269.	RESIDUAL	269.	1	0.06	0.05	0.77
26	DEADV2 DIESEL-ADV HEAT	0.	373.	815.	207.	392.	89.	0.	-902.	815.	RESIDUAL	-87.	1	0.31	0.37	0.25
27	DEADV1 DIESEL-ADV POWR	0.	23.	37.	14.	14.	4.	227.	0.	263.	RESIDUAL	263.	1	0.08	0.05	0.79
27	DEADV1 DIESEL-ADV HEAT	0.	328.	529.	207.	196.	58.	0.	-571.	529.	RESIDUAL	-42.	1	0.38	0.37	0.39
28	DEHTPM ADV-DIESEL POWR	0.	20.	45.	19.	14.	4.	221.	0.	266.	RESIDUAL	266.	0	0.07	0.05	0.78
28	DEHTPM ADV-DIESEL HEAT	0.	219.	484.	207.	147.	43.	0.	-417.	484.	RESIDUAL	67.	0	0.31	0.30	0.43
29	DES0A3 DIESEL-S0A POWR	0.	11.	38.	6.	14.	4.	237.	0.	275.	DISTILLA	275.	0	0.04	0.05	0.75
29	DES0A3 DIESEL-S0A HEAT	0.	424.	1405.	207.	507.	149.	0.	-1543.	1405.	DISTILLA	-137.	0	0.23	0.36	0.15
29	DES0A3 DIESEL-S0A POWR	0.	11.	38.	6.	14.	4.	237.	0.	275.	RESIDUAL	275.	0	0.04	0.05	0.75
29	DES0A3 DIESEL-S0A HEAT	0.	424.	1405.	207.	507.	149.	0.	-1543.	1405.	RESIDUAL	-137.	0	0.23	0.36	0.15

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28212 MW 4.00 PROCESS MILLIONS BTU/HR 207.0 PROCESS TEMP(F) 422. PRODUCT VINYL-CHLORI HOURS PER YEAR 8300.

POWER TO HEAT RATIO 0.066

WASTE FUEL EQV BTU\*10\*\*6= 0.

HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	AUX MW ELECT	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
30 DES0A2 DIESEL-S0A POWR		0.	15.	38.	8.	14.	4.	234.	0.	272.	DISTILLA	272.	1	0.05	0.05	0.76
30 DES0A2 DIESEL-S0A HEAT		0.	364.	941.	207.	340.	100.	0.	-1019.	941.	DISTILLA	-78.	1	0.28	0.36	0.22
30 DES0A2 DIESEL-S0A POWR		0.	15.	38.	8.	14.	4.	234.	0.	272.	RESIDUAL	272.	1	0.05	0.05	0.76
30 DES0A2 DIESEL-S0A HEAT		0.	364.	941.	207.	340.	100.	0.	-1019.	941.	RESIDUAL	-78.	1	0.28	0.36	0.22
31 DES0A1 DIESEL-S0A POWR		0.	23.	38.	15.	14.	4.	226.	0.	263.	DISTILLA	263.	1	0.08	0.05	0.79
31 DES0A1 DIESEL-S0A HEAT		0.	310.	516.	207.	186.	55.	0.	-540.	516.	DISTILLA	-23.	1	0.37	0.36	0.40
31 DES0A1 DIESEL-S0A POWR		0.	23.	38.	15.	14.	4.	226.	0.	263.	RESIDUAL	263.	1	0.08	0.05	0.79
31 DES0A1 DIESEL-S0A HEAT		0.	310.	516.	207.	186.	55.	0.	-540.	516.	RESIDUAL	-23.	1	0.37	0.36	0.40
32 GTS0AD GT-HRS0-10 POWR		0.	21.	47.	21.	14.	4.	218.	0.	265.	DISTILLA	265.	10	0.07	0.05	0.78
32 GTS0AD GT-HRS0-10 HEAT		0.	204.	454.	207.	133.	39.	0.	-371.	454.	DISTILLA	82.	0	0.31	0.29	0.46
33 GTRA08 GT-85RE-08 POWR		0.	18.	38.	12.	14.	4.	230.	0.	268.	DISTILLA	268.	10	0.06	0.05	0.77
33 GTRA08 GT-85RE-08 HEAT		0.	321.	667.	207.	238.	70.	0.	-701.	667.	DISTILLA	-34.	0	0.32	0.36	0.31
34 GTRA12 GT-85RE-12 POWR		0.	19.	38.	12.	14.	4.	229.	0.	267.	DISTILLA	267.	10	0.07	0.05	0.78
34 GTRA12 GT-85RE-12 HEAT		0.	319.	638.	207.	228.	67.	0.	-671.	638.	DISTILLA	-33.	0	0.33	0.36	0.32
35 GTRA16 GT-85RE-16 POWR		0.	19.	39.	13.	14.	4.	228.	0.	267.	DISTILLA	267.	10	0.07	0.05	0.78
35 GTRA16 GT-85RE-16 HEAT		0.	298.	602.	207.	210.	62.	0.	-614.	602.	DISTILLA	-12.	0	0.33	0.35	0.34
36 GTR208 GT-60RE-08 POWR		0.	19.	43.	17.	14.	4.	224.	0.	267.	DISTILLA	267.	10	0.07	0.05	0.78
36 GTR208 GT-60RE-08 HEAT		0.	244.	533.	207.	171.	50.	0.	-491.	533.	DISTILLA	43.	0	0.31	0.32	0.39
37 GTR212 GT-60RE-12 POWR		0.	19.	41.	15.	14.	4.	225.	0.	267.	DISTILLA	267.	10	0.07	0.05	0.78
37 GTR212 GT-60RE-12 HEAT		0.	261.	555.	207.	183.	54.	0.	-530.	555.	DISTILLA	25.	0	0.32	0.33	0.37
38 GTR216 GT-60RE-16 POWR		0.	20.	40.	15.	14.	4.	226.	0.	266.	DISTILLA	266.	10	0.07	0.05	0.78
38 GTR216 GT-60RE-16 HEAT		0.	273.	558.	207.	188.	55.	0.	-546.	558.	DISTILLA	13.	0	0.33	0.34	0.37
39 GTRW08 GT-85RE-08 POWR		0.	16.	39.	10.	14.	4.	232.	0.	271.	DISTILLA	271.	10	0.05	0.05	0.76
39 GTRW08 GT-85RE-08 HEAT		0.	321.	801.	207.	281.	82.	0.	-836.	801.	DISTILLA	-35.	0	0.29	0.35	0.26
40 GTRW12 GT-85RE-12 POWR		0.	17.	37.	10.	14.	4.	232.	0.	269.	DISTILLA	269.	10	0.06	0.05	0.77
40 GTRW12 GT-85RE-12 HEAT		0.	350.	773.	207.	231.	82.	0.	-836.	773.	DISTILLA	-64.	0	0.31	0.36	0.27



I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28212 MW 4.00 PROCESS MILLIONS BTU/HR 207.0 PROCESS TEMP(F) 422. PRODUCT VINYL-CHLORI HOURS PER YEAR 8300.

UTILITY FUEL COAL POWER TO HEAT RATIO 0.066  
WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

		WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41	GTRW16 GT-85RE-16 POWR	0.	17.	38.	11.	14.	4.	231.	0.	269.	DISTILLA	269.	10	0.06	0.05	0.77
41	GTRW16 GT-85RE-16 HEAT	0.	327.	719.	207.	257.	75.	0.	-760.	719.	DISTILLA	-41.	0	0.31	0.36	0.29
42	GTR308 GT-60RE-08 POWR	0.	14.	44.	13.	14.	4.	228.	0.	272.	DISTILLA	272.	10	0.05	0.05	0.76
42	GTR308 GT-60RE-08 HEAT	0.	222.	687.	207.	213.	62.	0.	-622.	687.	DISTILLA	64.	0	0.24	0.31	0.30
43	GTR312 GT-60RE-12 POWR	0.	18.	40.	13.	14.	4.	228.	0.	268.	DISTILLA	268.	10	0.06	0.05	0.77
43	GTR312 GT-60RE-12 HEAT	0.	287.	639.	207.	218.	64.	0.	-640.	639.	DISTILLA	-1.	0	0.31	0.34	0.32
44	GTR316 GT-60RE-16 POWR	0.	18.	40.	13.	14.	4.	228.	0.	268.	DISTILLA	268.	10	0.06	0.05	0.77
44	GTR316 GT-60RE-16 HEAT	0.	281.	634.	207.	215.	63.	0.	-629.	634.	DISTILLA	5.	0	0.31	0.34	0.33
45	FCPADS FUEL-CL-PH POWR	0.	14.	36.	6.	14.	4.	236.	0.	272.	DISTILLA	272.	0	0.05	0.05	0.76
45	FCPADS FUEL-CL-PH HEAT	0.	472.	1218.	207.	463.	136.	0.	-1403.	1218.	DISTILLA	-186.	0	0.28	0.38	0.17
46	FCMCDS FUEL-CL-MO POWR	0.	19.	33.	8.	14.	4.	234.	0.	268.	DISTILLA	268.	10	0.07	0.05	0.77
46	FCMCDS FUEL-CL-MO HEAT	0.	499.	888.	207.	366.	107.	0.	-1101.	888.	DISTILLA	-213.	0	0.36	0.41	0.23

HONEYWELL PAGE PRINTING SYSTEM- PL188-01

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 121

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28213 MW 55.00 PROCESS MILLIONS BTU/HR 16.0 PROCESS TEMP(F) 448. PRODUCT LOW-DENSITY- HOURS PER YEAR 7900.

UTILITY FUEL		COAL		POWER TO HEAT RATIO *****										WASTE FUEL EQV BTU*10**6= 0.		HOT WATER BTU*10**6= 0.	
WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED- NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR			
0 ONOCGN	0	0	0	0	0	0	19.	586.	19.	RESIDUAL	605.	0	0.	0.31	0.03		
1 STM141 STM-TURB-1 POWR	0.	-1655.	2260.	1733.	188.	55.	-2020.	0.	2260.	RESIDUAL	2260.	0	-2.73	0.08	0.01		
1 STM141 STM-TURB-1 HEAT	0.	3.	21.	16.	2.	1.	0.	581.	21.	RESIDUAL	602.	10	0.01	0.00	0.03		
1 STM141 STM-TURB-1 POWR	0.	-1655.	2260.	1733.	188.	55.	-2020.	0.	2260.	COAL-FGD	2260.	0	-2.73	0.08	0.01		
1 STM141 STM-TURB-1 HEAT	0.	3.	21.	16.	2.	1.	0.	581.	21.	COAL-FGD	602.	10	0.01	0.00	0.03		
1 STM141 STM-TURB-1 POWR	0.	-1655.	2260.	1733.	188.	55.	-2020.	0.	2260.	COAL-AFB	2260.	0	-2.73	0.08	0.01		
1 STM141 STM-TURB-1 HEAT	0.	3.	21.	16.	2.	1.	0.	581.	21.	COAL-AFB	602.	10	0.01	0.00	0.03		
2 STM088 STM-TURB-8 POWR	0.	-3404.	4009.	3220.	188.	55.	-3770.	0.	4009.	RESIDUAL	4009.	0	-5.62	0.05	0.00		
2 STM088 STM-TURB-8 HEAT	0.	2.	20.	16.	1.	0.	0.	584.	20.	RESIDUAL	603.	10	0.00	0.00	0.03		
2 STM088 STM-TURB-8 POWR	0.	-3404.	4009.	3220.	188.	55.	-3770.	0.	4009.	COAL-FGD	4009.	0	-5.62	0.05	0.00		
2 STM088 STM-TURB-8 HEAT	0.	2.	20.	16.	1.	0.	0.	584.	20.	COAL-FGD	603.	10	0.00	0.00	0.03		
2 STM088 STM-TURB-8 POWR	0.	-3404.	4009.	3220.	188.	55.	-3770.	0.	4009.	COAL-AFB	4009.	0	-5.62	0.05	0.00		
2 STM088 STM-TURB-8 HEAT	0.	2.	20.	16.	1.	0.	0.	584.	20.	COAL-AFB	603.	10	0.00	0.00	0.03		
3 PFBSTM PFB-STMTB- POWR	0.	-590.	1195.	814.	188.	55.	-939.	0.	1195.	COAL-PFB	1195.	0	-0.97	0.16	0.01		
3 PFBSTM PFB-STMTB- HEAT	0.	7.	23.	16.	4.	1.	0.	575.	23.	COAL-PFB	598.	10	0.01	0.01	0.03		
4 TISTMT TI-STMTB-1 POWR	0.	-295.	900.	571.	188.	55.	-653.	0.	900.	RESIDUAL	900.	0	-0.49	0.21	0.02		
4 TISTMT TI-STMTB-1 HEAT	0.	10.	25.	16.	5.	2.	0.	570.	25.	RESIDUAL	595.	10	0.02	0.01	0.03		
4 TISTMT TI-STMTB-1 POWR	0.	-295.	900.	571.	188.	55.	-653.	0.	900.	COAL	900.	0	-0.49	0.21	0.02		
4 TISTMT TI-STMTB-1 HEAT	0.	10.	25.	16.	5.	2.	0.	570.	25.	COAL	595.	10	0.02	0.01	0.03		
5 TIHRSG THERMIONIC POWR	0.	-728.	1334.	821.	188.	55.	-947.	0.	1334.	RESIDUAL	1334.	0	-1.20	0.14	0.01		
5 TIHRSG THERMIONIC HEAT	0.	4.	26.	16.	4.	1.	0.	575.	26.	RESIDUAL	601.	10	0.01	0.01	0.03		
5 TIHRSG THERMIONIC POWR	0.	-728.	1334.	821.	188.	55.	-947.	0.	1334.	COAL	1334.	0	-1.20	0.14	0.01		
5 TIHRSG THERMIONIC HEAT	0.	4.	26.	16.	4.	1.	0.	575.	26.	COAL	601.	10	0.01	0.01	0.03		
6 STIRL STIRLING-1 POWR	0.	-208.	813.	405.	188.	55.	-458.	0.	813.	DISTILLA	813.	0	-0.34	0.23	0.02		
6 STIRL STIRLING-1 HEAT	0.	10.	32.	16.	7.	2.	0.	563.	32.	DISTILLA	595.	0	0.02	0.01	0.03		

HONEYWELL PAGE PRINTING SYSTEM- P118B-02

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 2&amp;213 MW 55.00 PROCESS MILLIONS BTU/HR 16.0 PROCESS TEMP(F) 448. PRODUCT LOW-DENSITY- HOURS PER YEAR 7900.

UTILITY FUEL		COAL		POWER TO HEAT RATIO *****												
				WASTE FUEL EQV BTU*10**6=						0. HOT WATER BTU*10**6=				0.		
		WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET* TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
6	STIRL STIRLING-1 POWR	0.	-208.	813.	405.	188.	55.	-458.	0.	813.	RESIDUAL	813.	0	-0.34	0.23	0.02
6	STIRL STIRLING-1 HEAT	0.	10.	32.	16.	7.	2.	0.	563.	32.	RESIDUAL	595.	0	0.02	0.01	0.03
6	STIRL STIRLING-1 POWR	0.	-208.	813.	405.	188.	55.	-458.	0.	813.	COAL	813.	0	-0.34	0.23	0.02
6	STIRL STIRLING-1 HEAT	0.	10.	32.	16.	7.	2.	0.	563.	32.	COAL	595.	0	0.02	0.01	0.03
7	HEGT85 HELIUM-GT- POWR	0.	-11.	585.	-1.	188.	55.	31.	0.	616.	COAL-AFB	616.	1	-0.02	0.30	0.03
7	HEGT85 HELIUM-GT- HEAT	-888.	16.	-888.	16.	-285.	-84.	0.	1477.	-888.	COAL-AFB	589.	11	-1.44	-0.48	0.03
8	HEGT60 HELIUM-GT- POWR	0.	-119.	725.	146.	188.	55.	-154.	0.	725.	COAL-AFB	725.	0	-0.20	0.26	0.02
8	HEGT60 HELIUM-GT- HEAT	0.	4.	79.	16.	20.	6.	0.	522.	79.	COAL-AFB	602.	10	0.01	0.03	0.03
9	HEGT00 HELIUM-GT- POWR	0.	-461.	1066.	502.	188.	55.	-572.	0.	1066.	COAL-AFB	1066.	0	-0.76	0.18	0.02
9	HEGT00 HELIUM-GT- HEAT	0.	4.	34.	16.	6.	2.	0.	568.	34.	COAL-AFB	602.	10	0.01	0.01	0.03
10	FCMCL FUEL-CL-MO POWR	0.	-12.	617.	291.	188.	55.	-323.	0.	617.	COAL	617.	10	-0.02	0.30	0.03
10	FCMCL FUEL-CL-MO HEAT	0.	17.	34.	16.	10.	3.	0.	554.	34.	COAL	598.	10	0.03	0.02	0.03
11	FCSTCL FUEL-CL-ST POWR	0.	70.	535.	229.	188.	55.	-251.	0.	535.	COAL	535.	10	0.12	0.35	0.03
11	FCSTCL FUEL-CL-ST HEAT	0.	22.	37.	16.	13.	4.	0.	546.	37.	COAL	583.	10	0.04	0.02	0.03
12	IGGTST INT-GAS-GT POWR	0.	-147.	752.	346.	188.	55.	-389.	0.	752.	COAL	752.	10	-0.24	0.25	0.02
12	IGGTST INT-GAS-GT HEAT	0.	11.	35.	16.	9.	3.	0.	539.	35.	COAL	594.	10	0.02	0.01	0.03
13	GTSOAR GT-HRSG-10 POWR	0.	-42.	647.	257.	188.	55.	-284.	0.	647.	RESIDUAL	647.	0	-0.07	0.29	0.02
13	GTSOAR GT-HRSG-10 HEAT	0.	15.	40.	16.	12.	3.	0.	550.	40.	RESIDUAL	590.	10	0.02	0.02	0.03
14	GTAC08 GT-HRSG-08 POWR	0.	-90.	695.	359.	188.	55.	-403.	0.	695.	RESIDUAL	695.	0	-0.15	0.27	0.02
14	GTAC08 GT-HRSG-08 HEAT	0.	14.	31.	16.	8.	2.	0.	560.	31.	RESIDUAL	591.	10	0.02	0.01	0.03
15	GTAC12 GT-HRSG-12 POWR	0.	-10.	615.	285.	188.	55.	-316.	0.	615.	RESIDUAL	615.	0	-0.02	0.31	0.03
15	GTAC12 GT-HRSG-12 HEAT	0.	17.	35.	16.	11.	3.	0.	553.	35.	RESIDUAL	588.	10	0.03	0.02	0.03
16	GTAC16 GT-HRSG-16 POWR	0.	24.	581.	246.	188.	55.	-271.	0.	581.	RESIDUAL	581.	0	0.04	0.32	0.03
16	GTAC16 GT-HRSG-16 HEAT	0.	19.	38.	16.	12.	4.	0.	548.	38.	RESIDUAL	586.	10	0.03	0.02	0.03
17	GTWC16 GT-HRSG-16 POWR	0.	10.	596.	241.	188.	55.	-265.	0.	596.	RESIDUAL	596.	0	0.02	0.32	0.03
17	GTWC16 GT-HRSG-16 HEAT	0.	18.	39.	16.	12.	4.	0.	548.	39.	RESIDUAL	587.	10	0.03	0.02	0.03

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 26213 MW 55.00 PROCESS MILLIONS BTU/HR 16.0 PROCESS TEMP(F) 448. PRODUCT LOW-DENSITY- HOURS PER YEAR 7900.

POWER TO HEAT RATIO \*\*\*\*\*

WASTE FUEL EQV BTU\*10\*\*6= 0.

HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
18 CC1626	GTST-16/26	POWR	0.	72.	534.	179.	188.	55.	-192.	0.	534.	RESIDUAL	534.	0	0.12	0.35	0.03
18 CC1626	GTST-16/26	HEAT	0.	24.	48.	16.	17.	5.	0.	534.	48.	RESIDUAL	582.	10	0.04	0.03	0.03
19 CC1622	GTST-16/22	POWR	0.	61.	545.	200.	188.	55.	-217.	0.	545.	RESIDUAL	545.	0	0.10	0.34	0.03
19 CC1622	GTST-16/22	HEAT	0.	22.	44.	16.	15.	4.	0.	540.	44.	RESIDUAL	583.	10	0.04	0.03	0.03
20 CC1222	GTST-12/22	POWR	0.	61.	544.	202.	188.	55.	-219.	0.	544.	RESIDUAL	544.	0	0.10	0.34	0.03
20 CC1222	GTST-12/22	HEAT	0.	22.	43.	16.	15.	4.	0.	540.	43.	RESIDUAL	583.	10	0.04	0.03	0.03
21 CC0822	GTST-08/22	POWR	0.	14.	591.	260.	188.	55.	-287.	0.	591.	RESIDUAL	591.	0	0.02	0.32	0.03
21 CC0822	GTST-08/22	HEAT	0.	19.	36.	16.	12.	3.	0.	550.	36.	RESIDUAL	587.	10	0.03	0.02	0.03
22 STIG15	STIG-15-16	POWR	0.	101.	493.	6.	188.	55.	11.	0.	504.	RESIDUAL	504.	1	0.17	0.37	0.03
22 STIG15	STIG-15-16	HEAT	0.	253.	1231.	16.	469.	137.	0.	-879.	1231.	RESIDUAL	352.	1	0.17	0.38	0.01
23 STIG10	STIG-10-16	POWR	0.	83.	523.	69.	188.	55.	13.	0.	523.	RESIDUAL	523.	1	0.14	0.36	0.03
23 STIG10	STIG-10-16	HEAT	0.	34.	121.	16.	43.	13.	0.	451.	121.	RESIDUAL	572.	11	0.06	0.08	0.03
24 STIG1S	STIG-1S-16	POWR	0.	45.	560.	118.	188.	55.	-120.	0.	560.	RESIDUAL	560.	1	0.08	0.34	0.03
24 STIG1S	STIG-1S-16	HEAT	0.	22.	76.	16.	25.	7.	0.	507.	76.	RESIDUAL	583.	11	0.04	0.04	0.03
25 DEADV3	DIESEL-ADV	POWR	0.	99.	506.	86.	188.	55.	-83.	0.	506.	RESIDUAL	506.	0	0.16	0.37	0.03
25 DEADV3	DIESEL-ADV	HEAT	0.	34.	94.	16.	35.	10.	0.	478.	94.	RESIDUAL	571.	0	0.06	0.06	0.03
26 DEADV2	DIESEL-ADV	POWR	0.	99.	506.	128.	188.	55.	-132.	0.	506.	RESIDUAL	506.	1	0.16	0.37	0.03
26 DEADV2	DIESEL-ADV	HEAT	0.	29.	63.	16.	23.	7.	0.	513.	63.	RESIDUAL	576.	1	0.05	0.04	0.03
27 DEADV1	DIESEL-ADV	POWR	0.	99.	506.	198.	188.	55.	-214.	0.	506.	RESIDUAL	506.	1	0.16	0.37	0.03
27 DEADV1	DIESEL-ADV	HEAT	0.	25.	41.	16.	15.	4.	0.	539.	41.	RESIDUAL	580.	1	0.04	0.03	0.03
28 DEHTPM	ADV-DIESEL	POWR	0.	-37.	643.	276.	188.	55.	-305.	0.	643.	RESIDUAL	643.	0	-0.06	0.29	0.02
28 DEHTPM	ADV-DIESEL	HEAT	0.	16.	37.	16.	11.	3.	0.	552.	37.	RESIDUAL	590.	0	0.03	0.02	0.03
29 DESOA3	DIESEL-SOA	POWR	0.	85.	520.	71.	188.	55.	-65.	0.	520.	DISTILLA	520.	0	0.14	0.36	0.03
29 DESOA3	DIESEL-SOA	HEAT	0.	34.	117.	16.	42.	12.	0.	454.	117.	DISTILLA	571.	0	0.06	0.07	0.03
29 DESOA3	DIESEL-SOA	POWR	0.	85.	520.	71.	188.	55.	-65.	0.	520.	RESIDUAL	520.	0	0.14	0.36	0.03
29 DESOA3	DIESEL-SOA	HEAT	0.	34.	117.	16.	42.	12.	0.	454.	117.	RESIDUAL	571.	0	0.06	0.07	0.03

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28213 MW 55.00 PROCESS MILLIONS BTU/HR 16.0 PROCESS TEMP(F) 448, PRODUCT LOW-DENSITY- HOURS PER YEAR 7900.

UTILITY FUEL	COAL	POWER TO HEAT RATIO *****										WASTE FUEL EQV BTU*10**6=	0.	HOT WATER BTU*10**6=		0.
		WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED- NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED			NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	
30 DES0A2 DIESEL-S0A POWR		0.	85.	520.	114.	188.	55.	-116.	0.	520.	DISTILLA	520.	1	0.14	0.36	0.03
30 DES0A2 DIESEL-S0A HEAT		0.	28.	73.	16.	26.	8.	0.	504.	73.	DISTILLA	577.	1	0.05	0.05	0.03
30 DES0A2 DIESEL-S0A POWR		0.	85.	520.	114.	188.	55.	-116.	0.	520.	RESIDUAL	520.	1	0.14	0.36	0.03
30 DES0A2 DIESEL-S0A HEAT		0.	28.	73.	16.	26.	8.	0.	504.	73.	RESIDUAL	577.	1	0.05	0.05	0.03
31 DES0A1 DIESEL-S0A POWR		0.	85.	520.	208.	188.	55.	-226.	0.	520.	DISTILLA	520.	1	0.14	0.36	0.03
31 DES0A1 DIESEL-S0A HEAT		0.	24.	40.	16.	14.	4.	0.	541.	40.	DISTILLA	581.	1	0.04	0.02	0.03
31 DES0A1 DIESEL-S0A POWR		0.	85.	520.	208.	188.	55.	-226.	0.	520.	RESIDUAL	520.	1	0.14	0.36	0.03
31 DES0A1 DIESEL-S0A HEAT		0.	24.	40.	16.	14.	4.	0.	541.	40.	RESIDUAL	581.	1	0.04	0.02	0.03
32 GTS0AD GT-HRS0-10 POWR		0.	-37.	643.	292.	188.	55.	-325.	0.	643.	DISTILLA	643.	0	-0.06	0.29	0.02
32 GTS0AD GT-HRS0-10 HEAT		0.	16.	35.	16.	10.	3.	0.	554.	35.	DISTILLA	590.	10	0.03	0.02	0.03
33 GTRA08 GT-85RE-08 POWR		0.	80.	526.	156.	188.	55.	-165.	0.	526.	DISTILLA	526.	0	0.13	0.36	0.03
33 GTRA08 GT-85RE-08 HEAT		0.	25.	54.	16.	19.	6.	0.	526.	54.	DISTILLA	580.	10	0.04	0.03	0.03
34 GTRA12 GT-85RE-12 POWR		0.	81.	524.	164.	188.	55.	-175.	0.	524.	DISTILLA	524.	0	0.13	0.36	0.03
34 GTRA12 GT-85RE-12 HEAT		0.	25.	51.	16.	18.	5.	0.	529.	51.	DISTILLA	580.	10	0.04	0.03	0.03
35 GTRA16 GT-85RE-16 POWR		0.	68.	538.	180.	188.	55.	-193.	0.	538.	DISTILLA	538.	0	0.11	0.35	0.03
35 GTRA16 GT-85RE-16 HEAT		0.	23.	48.	16.	17.	5.	0.	534.	48.	DISTILLA	582.	10	0.04	0.03	0.03
36 GTR208 GT-60RE-08 POWR		0.	19.	586.	224.	188.	55.	-244.	0.	586.	DISTILLA	586.	0	0.03	0.32	0.03
36 GTR208 GT-60RE-08 HEAT		0.	19.	42.	16.	13.	4.	0.	544.	42.	DISTILLA	586.	10	0.03	0.02	0.03
37 GTR212 GT-60RE-12 POWR		0.	37.	569.	208.	188.	55.	-226.	0.	569.	DISTILLA	569.	0	0.06	0.33	0.03
37 GTR212 GT-60RE-12 HEAT		0.	20.	44.	16.	14.	4.	0.	541.	44.	DISTILLA	585.	10	0.03	0.02	0.03
38 GTR216 GT-60RE-16 POWR		0.	48.	557.	202.	188.	55.	-219.	0.	557.	DISTILLA	557.	0	0.08	0.34	0.03
38 GTR216 GT-60RE-16 HEAT		0.	21.	44.	16.	15.	4.	0.	540.	44.	DISTILLA	584.	10	0.03	0.03	0.03
39 GTRW08 GT-85RE-08 POWR		0.	71.	535.	133.	188.	55.	-138.	0.	535.	DISTILLA	535.	0	0.12	0.35	0.03
39 GTRW08 GT-85RE-08 HEAT		0.	25.	64.	16.	23.	7.	0.	516.	64.	DISTILLA	580.	10	0.04	0.04	0.03
40 GTRW12 GT-85RE-12 POWR		0.	90.	516.	134.	188.	55.	-139.	0.	516.	DISTILLA	516.	0	0.15	0.36	0.03
40 GTRW12 GT-85RE-12 HEAT		0.	27.	62.	16.	22.	7.	0.	516.	62.	DISTILLA	578.	10	0.05	0.04	0.03

HONEYWELL PAGE PRINTING SYSTEM- P1187

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 125

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28213 MW 55.00 PROCESS MILLIONS BTU/HR 16.0 PROCESS TEMP(F) 448. PRODUCT LOW-DENSITY- HOURS PER YEAR 7900.

UTILITY FUEL		COAL		POWER TO HEAT RATIO *****										WASTE FUEL EQV BTU*10**6=		0.		HOT WATER BTU*10**6=		0.	
WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN ELECT 10**6 BTU/HR	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET* TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR							
41 GTRW16 GT-85RE-16 POWR	0.	80.	526.	148.	188.	55.	-155.	0.	526.	DISTILLA	526.	0	0.13	0.36	0.03						
41 GTRW16 GT-85RE-16 HEAT	0.	25.	57.	16.	20.	6.	0.	523.	57.	DISTILLA	580.	10	0.04	0.04	0.03						
42 GTR308 GT-60RE-08 POWR	0.	-0.	605.	177.	188.	55.	-190.	0.	605.	DISTILLA	605.	0	-0.00	0.31	0.03						
42 GTR308 GT-60RE-08 HEAT	0.	17.	55.	16.	17.	5.	0.	533.	55.	DISTILLA	588.	10	0.03	0.03	0.03						
43 GTR312 GT-60RE-12 POWR	0.	57.	549.	176.	188.	55.	-188.	0.	549.	DISTILLA	549.	0	0.09	0.34	0.03						
43 GTR312 GT-60RE-12 HEAT	0.	22.	50.	16.	17.	5.	0.	533.	50.	DISTILLA	583.	10	0.04	0.03	0.03						
44 GTR316 GT-60RE-16 POWR	0.	52.	554.	179.	188.	55.	-192.	0.	554.	DISTILLA	554.	0	0.09	0.34	0.03						
44 GTR316 GT-60RE-16 HEAT	0.	22.	49.	16.	17.	5.	0.	534.	49.	DISTILLA	583.	10	0.04	0.03	0.03						
45 FCPADS FUEL-CL-PH POWR	0.	111.	494.	84.	188.	55.	-80.	0.	494.	DISTILLA	494.	0	0.18	0.38	0.03						
45 FCPADS FUEL-CL-PH HEAT	0.	36.	94.	16.	36.	10.	0.	475.	94.	DISTILLA	569.	0	0.06	0.06	0.03						
46 FCMCDS FUEL-CL-MO POWR	0.	150.	455.	106.	188.	55.	-106.	0.	455.	DISTILLA	455.	0	0.25	0.41	0.04						
46 FCMCDS FUEL-CL-MO HEAT	0.	39.	69.	16.	28.	8.	0.	498.	69.	DISTILLA	567.	0	0.06	0.05	0.03						

I&amp;SE PEO ADV DESIGN ENGR

## \*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28221 MW 7.50 PROCESS MILLIONS BTU/HR 35.0 PROCESS TEMP(F) 338. PRODUCT STYRENE-BUTA HOURS PER YEAR 7900.

POWER TO HEAT RATIO 0.731

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL COAL

	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
0 ONCOGN N C O G O N	0.	0.	0.	0.	0.	0.	41.	80.	41.	COAL-AFB	121.	0	0.	0.21	0.29
1 STM141 STM-TURB-1 POWR	0.	-53.	175.	123.	26.	8.	-103.	0.	175.	RESIDUAL	175.	0	-0.44	0.15	0.20
1 STM141 STM-TURB-1 HEAT	0.	14.	50.	35.	7.	2.	0.	57.	50.	RESIDUAL	107.	10	0.12	0.07	0.33
1 STM141 STM-TURB-1 POWR	0.	-53.	175.	123.	26.	8.	-103.	0.	175.	COAL-FGD	175.	0	-0.44	0.15	0.20
1 STM141 STM-TURB-1 HEAT	0.	14.	50.	35.	7.	2.	0.	57.	50.	COAL-FGD	107.	10	0.12	0.07	0.33
1 STM141 STM-TURB-1 POWR	0.	-53.	175.	123.	26.	8.	-103.	0.	175.	COAL-AFB	175.	0	-0.44	0.15	0.20
1 STM141 STM-TURB-1 HEAT	0.	14.	50.	35.	7.	2.	0.	57.	50.	COAL-AFB	107.	10	0.12	0.07	0.33
2 STM088 STM-TURB-8 POWR	0.	-107.	229.	169.	26.	8.	-157.	0.	229.	RESIDUAL	229.	0	-0.89	0.11	0.15
2 STM088 STM-TURB-8 HEAT	0.	10.	47.	35.	5.	2.	0.	63.	47.	RESIDUAL	111.	10	0.09	0.05	0.32
2 STM088 STM-TURB-8 POWR	0.	-107.	229.	169.	26.	8.	-157.	0.	229.	COAL-FGD	229.	0	-0.89	0.11	0.15
2 STM088 STM-TURB-8 HEAT	0.	10.	47.	35.	5.	2.	0.	63.	47.	COAL-FGD	111.	10	0.09	0.05	0.32
2 STM088 STM-TURB-8 POWR	0.	-107.	229.	169.	26.	8.	-157.	0.	229.	COAL-AFB	229.	0	-0.89	0.11	0.15
2 STM088 STM-TURB-8 HEAT	0.	10.	47.	35.	5.	2.	0.	63.	47.	COAL-AFB	111.	10	0.09	0.05	0.32
3 PFBSTM PFB-STMTB- POWR	0.	1.	120.	76.	26.	8.	-48.	0.	120.	COAL-PFB	120.	10	0.01	0.21	0.29
3 PFBSTM PFB-STMTB- HEAT	0.	23.	56.	35.	12.	3.	0.	43.	56.	COAL-PFB	99.	10	0.19	0.12	0.35
4 T1STMT T1-STMTB-1 POWR	0.	23.	98.	57.	26.	8.	-26.	0.	98.	RESIDUAL	98.	10	0.19	0.26	0.36
4 T1STMT T1-STMTB-1 HEAT	0.	30.	60.	35.	16.	5.	0.	31.	60.	RESIDUAL	91.	10	0.25	0.17	0.38
4 T1STMT T1-STMTB-1 POWR	0.	23.	98.	57.	26.	8.	-26.	0.	98.	COAL	98.	10	0.19	0.26	0.36
4 T1STMT T1-STMTB-1 HEAT	0.	30.	60.	35.	16.	5.	0.	31.	60.	COAL	91.	10	0.25	0.17	0.38
5 TIHRSG THERMIONIC POWR	0.	-61.	182.	119.	26.	8.	-99.	0.	182.	RESIDUAL	182.	0	-0.50	0.14	0.19
5 TIHRSG THERMIONIC HEAT	0.	11.	53.	35.	8.	2.	0.	56.	53.	RESIDUAL	110.	10	0.09	0.07	0.32
5 TIHRSG THERMIONIC POWR	0.	-61.	182.	119.	26.	8.	-99.	0.	182.	COAL	182.	0	-0.50	0.14	0.19
5 TIHRSG THERMIONIC HEAT	0.	11.	53.	35.	8.	2.	0.	56.	53.	COAL	110.	10	0.09	0.07	0.32
6 STIRL STIRLING-1 POWR	0.	22.	99.	47.	26.	8.	-14.	0.	99.	DISTILLA	99.	0	0.18	0.26	0.35
6 STIRL STIRLING-1 HEAT	0.	27.	74.	35.	19.	6.	0.	20.	74.	DISTILLA	94.	0	0.22	0.20	0.37

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28221 MW 7.50 PROCESS MILLIONS BTU/HR 35.0 PROCESS TEMP(F) 338. PRODUCT STYRENE-BUTA HOURS PER YEAR 7900.

POWER TO HEAT RATIO 0.731

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
6 STIRL STIRLING-1 POWR		0.	22.	99.	47.	26.	8.	-14.	0.	99.	RESIDUAL	99.	0	0.18	0.26	0.35
6 STIRL STIRLING-1 HEAT		0.	27.	74.	35.	19.	6.	0.	20.	74.	RESIDUAL	94.	0	0.22	0.20	0.37
6 STIRL STIRLING-1 POWR		0.	22.	99.	47.	26.	8.	-14.	0.	99.	COAL	99.	0	0.18	0.26	0.35
6 STIRL STIRLING-1 HEAT		0.	27.	74.	35.	19.	6.	0.	20.	74.	COAL	94.	0	0.22	0.20	0.37
7 HEGT85 HELIUM-GT- POWR		0.	15.	80.	13.	26.	8.	26.	0.	106.	COAL-AFB	106.	10	0.13	0.24	0.33
7 HEGT85 HELIUM-GT- HEAT		0.	42.	219.	35.	70.	21.	0.	-140.	219.	COAL-AFB	79.	10	0.16	0.32	0.16
8 HEGT60 HELIUM-GT- POWR		0.	18.	99.	31.	26.	8.	6.	0.	103.	COAL-AFB	103.	10	0.15	0.25	0.34
8 HEGT60 HELIUM-GT- HEAT		0.	20.	111.	35.	29.	8.	0.	-10.	111.	COAL-AFB	101.	10	0.15	0.26	0.32
9 HEGT00 HELIUM-GT- POWR		0.	-24.	145.	72.	26.	8.	-44.	0.	145.	COAL-AFB	145.	10	-0.20	0.18	0.24
9 HEGT00 HELIUM-GT- HEAT		0.	9.	71.	35.	12.	4.	0.	4.	71.	COAL-AFB	112.	10	0.08	0.11	0.31
10 FCMCCL FUEL-CL-MO POWR		0.	37.	84.	40.	26.	8.	-6.	0.	84.	COAL	84.	10	0.31	0.30	0.42
10 FCMCCL FUEL-CL-MO HEAT		0.	37.	74.	35.	22.	7.	0.	10.	74.	COAL	84.	10	0.31	0.27	0.42
11 FCSTCL FUEL-CL-ST POWR		0.	44.	66.	26.	26.	8.	10.	0.	77.	COAL	77.	10	0.37	0.33	0.46
11 FCSTCL FUEL-CL-ST HEAT		0.	59.	89.	35.	34.	10.	0.	-27.	89.	COAL	62.	10	0.40	0.39	0.39
12 IGGTST INT-GAS-GT POWR		0.	32.	89.	38.	26.	8.	-3.	0.	89.	COAL	89.	10	0.27	0.29	0.39
12 IGGTST INT-GAS-GT HEAT		0.	33.	83.	35.	24.	7.	0.	6.	83.	COAL	88.	10	0.27	0.27	0.40
13 GTSOAR GT-HRSG-10 POWR		0.	33.	88.	38.	26.	8.	-4.	0.	88.	RESIDUAL	88.	10	0.27	0.29	0.40
13 GTSOAR GT-HRSG-10 HEAT		0.	34.	81.	35.	23.	7.	0.	7.	81.	RESIDUAL	88.	10	0.28	0.27	0.40
14 GTAC08 GT-HRSG-08 POWR		0.	26.	95.	49.	26.	8.	-16.	0.	95.	RESIDUAL	95.	10	0.22	0.27	0.37
14 GTAC08 GT-HRSG-08 HEAT		0.	31.	68.	35.	18.	5.	0.	22.	68.	RESIDUAL	91.	10	0.25	0.20	0.39
15 GTAC12 GT-HRSG-12 POWR		0.	37.	84.	39.	26.	8.	-5.	0.	84.	RESIDUAL	84.	10	0.31	0.31	0.42
15 GTAC12 GT-HRSG-12 HEAT		0.	38.	75.	35.	23.	7.	0.	8.	75.	RESIDUAL	83.	10	0.31	0.27	0.42
16 GTAC16 GT-HRSG-16 POWR		0.	41.	79.	35.	26.	8.	1.	0.	80.	RESIDUAL	80.	10	0.34	0.32	0.44
16 GTAC16 GT-HRSG-16 HEAT		0.	42.	80.	35.	26.	8.	0.	-1.	80.	RESIDUAL	79.	10	0.34	0.32	0.44
17 GTWC16 GT-HRSG-16 POWR		0.	37.	81.	33.	26.	8.	3.	0.	84.	RESIDUAL	84.	10	0.31	0.31	0.42
17 GTWC16 GT-HRSG-16 HEAT		0.	40.	87.	35.	27.	8.	0.	-5.	87.	RESIDUAL	81.	10	0.32	0.32	0.40



DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 128

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28221 MW 7.50 PROCESS MILLIONS BTU/HR 35.0 PROCESS TEMP(F) 338. PRODUCT STYRENE-BUTA HOURS PER YEAR 7900.

UTILITY FUEL		POWER TO HEAT RATIO 0.731											WASTE FUEL EQV BTU*10**6= 0.			HOT WATER BTU*10**6= 0.		
WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED-NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR				
18 CC1626	GTST-16/26	POWR	0.	37.	67.	21.	26.	8.	17.	0.	84.	RESIDUAL	84.	10	0.31	0.30	0.42	
18 CC1626	GTST-16/26	HEAT	0.	62.	114.	35.	43.	13.	0.	-55.	114.	RESIDUAL	59.	10	0.35	0.38	0.31	
19 CC1622	GTST-16/22	POWR	0.	39.	68.	23.	26.	8.	14.	0.	82.	RESIDUAL	82.	10	0.32	0.31	0.42	
19 CC1622	GTST-16/22	HEAT	0.	59.	104.	35.	39.	11.	0.	-41.	104.	RESIDUAL	62.	10	0.36	0.37	0.34	
20 CC1222	GTST-12/22	POWR	0.	39.	68.	23.	26.	8.	14.	0.	82.	RESIDUAL	82.	10	0.32	0.31	0.43	
20 CC1222	GTST-12/22	HEAT	0.	59.	103.	35.	39.	11.	0.	-41.	103.	RESIDUAL	62.	10	0.37	0.38	0.34	
21 CC0822	GTST-08/22	POWR	0.	42.	72.	29.	26.	8.	7.	0.	79.	RESIDUAL	79.	10	0.35	0.32	0.44	
21 CC0822	GTST-08/22	HEAT	0.	50.	87.	35.	31.	9.	0.	-16.	87.	RESIDUAL	71.	10	0.37	0.35	0.40	
22 ST1015	ST10-15-16	POWR	0.	14.	67.	1.	26.	8.	40.	0.	107.	RESIDUAL	107.	10	0.11	0.24	0.33	
22 ST1015	ST10-15-16	HEAT	0.	554.	2692.	35.	1026.	301.	0.	-3126.	2692.	RESIDUAL	-433.	0	0.17	0.38	0.01	
23 ST1010	ST10-10-16	POWR	0.	20.	71.	9.	26.	8.	30.	0.	101.	RESIDUAL	101.	10	0.16	0.25	0.35	
23 ST1010	ST10-10-16	HEAT	0.	73.	264.	35.	95.	28.	0.	-216.	264.	RESIDUAL	48.	0	0.22	0.36	0.13	
24 ST1015	ST10-15-16	POWR	0.	23.	76.	16.	26.	8.	22.	0.	99.	RESIDUAL	99.	10	0.19	0.26	0.36	
24 ST1015	ST10-15-16	HEAT	0.	49.	166.	35.	56.	16.	0.	-94.	166.	RESIDUAL	72.	10	0.23	0.34	0.21	
25 DEADV3	DIESEL-ADV	POWR	0.	29.	69.	15.	26.	8.	24.	0.	93.	RESIDUAL	93.	0	0.24	0.28	0.38	
25 DEADV3	DIESEL-ADV	HEAT	0.	67.	161.	35.	60.	18.	0.	-107.	161.	RESIDUAL	54.	0	0.29	0.37	0.22	
26 DEADV2	DIESEL-ADV	POWR	0.	32.	69.	18.	26.	8.	21.	0.	90.	RESIDUAL	90.	1	0.26	0.29	0.39	
26 DEADV2	DIESEL-ADV	HEAT	0.	63.	138.	35.	51.	15.	0.	-80.	138.	RESIDUAL	58.	1	0.31	0.37	0.25	
27 DEADV1	DIESEL-ADV	POWR	0.	43.	69.	27.	26.	8.	9.	0.	78.	RESIDUAL	78.	1	0.35	0.33	0.45	
27 DEADV1	DIESEL-ADV	HEAT	0.	55.	90.	35.	33.	10.	0.	-24.	90.	RESIDUAL	66.	1	0.38	0.37	0.39	
28 DEHTPM	ADV-DIESEL	POWR	0.	42.	76.	33.	26.	8.	3.	0.	79.	RESIDUAL	79.	0	0.35	0.33	0.44	
28 DEHTPM	ADV-DIESEL	HEAT	0.	46.	81.	35.	27.	8.	0.	-6.	81.	RESIDUAL	76.	0	0.36	0.34	0.43	
29 DESOA3	DIESEL-SOA	POWR	0.	24.	71.	13.	26.	8.	26.	0.	97.	DISTILLA	97.	0	0.20	0.26	0.36	
29 DESOA3	DIESEL-SOA	HEAT	0.	66.	191.	35.	69.	20.	0.	-136.	191.	DISTILLA	55.	0	0.26	0.36	0.18	
29 DESOA3	DIESEL-SOA	POWR	0.	24.	71.	13.	26.	8.	26.	0.	97.	RESIDUAL	97.	0	0.20	0.26	0.36	
29 DESOA3	DIESEL-SOA	HEAT	0.	66.	191.	35.	69.	20.	0.	-136.	191.	RESIDUAL	55.	0	0.26	0.36	0.18	

HONEYWELL PAGE PRINTING SYSTEM-PL118-02

1&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28221 MW 7.50 PROCESS MILLIONS BTU/HR 35.0 PROCESS TEMP(F) 338. PRODUCT STYRENE-BUTA HOURS PER YEAR 7900.

POWER TO HEAT RATIO 0.731

WASTE FUEL EQV BTU\*10\*\*6= 0.

HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
30 DES0A2 DIESEL-S0A POWR		0.	27.	71.	16.	26.	8.	23.	0.	94.	DISTILLA	94.	1	0.23	0.27	0.37
30 DES0A2 DIESEL-S0A HEAT		0.	62.	159.	35.	57.	17.	0.	-100.	159.	DISTILLA	60.	1	0.28	0.36	0.22
30 DES0A2 DIESEL-S0A POWR		0.	27.	71.	16.	26.	8.	23.	0.	94.	RESIDUAL	94.	1	0.23	0.27	0.37
30 DES0A2 DIESEL-S0A HEAT		0.	62.	159.	35.	57.	17.	0.	-100.	159.	RESIDUAL	60.	1	0.28	0.36	0.22
31 DES0A1 DIESEL-S0A POWR		0.	43.	71.	28.	26.	8.	8.	0.	79.	DISTILLA	79.	1	0.35	0.33	0.45
31 DES0A1 DIESEL-S0A HEAT		0.	52.	87.	35.	32.	9.	0.	-18.	87.	DISTILLA	69.	1	0.37	0.36	0.40
31 DES0A1 DIESEL-S0A POWR		0.	43.	71.	28.	26.	8.	8.	0.	79.	RESIDUAL	79.	1	0.35	0.33	0.45
31 DES0A1 DIESEL-S0A HEAT		0.	52.	87.	35.	32.	9.	0.	-18.	87.	RESIDUAL	69.	1	0.37	0.36	0.40
32 GTS0AD GT-HRS0-10 POWR		0.	34.	88.	41.	26.	8.	-7.	0.	88.	DISTILLA	88.	10	0.28	0.29	0.40
32 GTS0AD GT-HRS0-10 HEAT		0.	35.	75.	35.	22.	6.	0.	11.	75.	DISTILLA	87.	10	0.29	0.25	0.40
33 GTRA08 GT-85RE-08 POWR		0.	38.	72.	25.	26.	8.	12.	0.	84.	DISTILLA	84.	10	0.31	0.31	0.42
33 GTRA08 GT-85RE-08 HEAT		0.	53.	101.	35.	36.	11.	0.	-32.	101.	DISTILLA	68.	10	0.34	0.36	0.35
34 GTRA12 GT-85RE-12 POWR		0.	38.	71.	25.	26.	8.	11.	0.	83.	DISTILLA	83.	10	0.32	0.31	0.42
34 GTRA12 GT-85RE-12 HEAT		0.	53.	98.	35.	35.	10.	0.	-30.	98.	DISTILLA	68.	10	0.35	0.36	0.36
35 GTRA16 GT-85RE-16 POWR		0.	39.	73.	27.	26.	8.	9.	0.	83.	DISTILLA	83.	10	0.32	0.31	0.42
35 GTRA16 GT-85RE-16 HEAT		0.	50.	94.	35.	33.	10.	0.	-23.	94.	DISTILLA	71.	10	0.35	0.35	0.37
36 GTR208 GT-60RE-08 POWR		0.	38.	80.	33.	26.	8.	3.	0.	83.	DISTILLA	83.	10	0.32	0.31	0.42
36 GTR208 GT-60RE-08 HEAT		0.	41.	66.	35.	27.	8.	0.	-6.	86.	DISTILLA	80.	10	0.32	0.32	0.41
37 GTR212 GT-60RE-12 POWR		0.	38.	78.	30.	26.	8.	5.	0.	83.	DISTILLA	83.	10	0.32	0.31	0.42
37 GTR212 GT-60RE-12 HEAT		0.	44.	89.	35.	29.	9.	0.	-12.	89.	DISTILLA	77.	10	0.33	0.33	0.39
38 GTR216 GT-60RE-16 POWR		0.	39.	76.	30.	26.	8.	6.	0.	82.	DISTILLA	82.	10	0.32	0.31	0.43
38 GTR216 GT-60RE-16 HEAT		0.	46.	89.	35.	30.	9.	0.	-14.	89.	DISTILLA	75.	10	0.34	0.34	0.39
39 GTRW08 GT-85RE-08 POWR		0.	32.	73.	21.	26.	8.	17.	0.	90.	DISTILLA	90.	10	0.26	0.29	0.39
39 GTRW08 GT-85RE-08 HEAT		0.	53.	122.	35.	43.	13.	0.	-54.	122.	DISTILLA	68.	10	0.30	0.35	0.29
40 GTRW12 GT-85RE-12 POWR		0.	34.	70.	20.	26.	8.	17.	0.	87.	DISTILLA	87.	10	0.28	0.29	0.40
40 GTRW12 GT-85RE-12 HEAT		0.	58.	120.	35.	44.	13.	0.	-57.	120.	DISTILLA	63.	10	0.32	0.36	0.29

HONEYWELL PAGE PRINTING SYSTEM - P1185-02

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28221 MW 7.50 PROCESS MILLIONS BTU/HR 35.0 PROCESS TEMP(F) 338. PRODUCT STYRENE-BUTA HOURS PER YEAR 7900.

POWER TO HEAT RATIO 0.731

WASTE FUEL EQV BTU\*10\*\*6= 0.

HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41 GTRW16 GT-85RE-16	POWR	0.	34.	72.	22.	26.	8.	15.	0.	87.	DISTILLA	87.	10	0.28	0.29	0.40
41 GTRW16 GT-85RE-16	HEAT	0.	54.	114.	35.	41.	12.	0.	-47.	114.	DISTILLA	67.	10	0.32	0.36	0.31
42 GTR308 GT-60RE-08	POWR	0.	30.	83.	27.	26.	8.	9.	0.	92.	DISTILLA	92.	10	0.24	0.28	0.38
42 GTR308 GT-60RE-08	HEAT	0.	38.	106.	35.	33.	10.	0.	-23.	106.	DISTILLA	83.	10	0.26	0.31	0.33
43 GTR312 GT-60RE-12	POWR	0.	35.	75.	25.	26.	8.	12.	0.	86.	DISTILLA	86.	10	0.29	0.30	0.40
43 GTR312 GT-60RE-12	HEAT	0.	48.	104.	35.	36.	10.	0.	-32.	104.	DISTILLA	73.	10	0.32	0.34	0.34
44 GTR316 GT-60RE-16	POWR	0.	34.	75.	25.	26.	8.	11.	0.	87.	DISTILLA	87.	10	0.28	0.30	0.40
44 GTR316 GT-60RE-16	HEAT	0.	47.	104.	35.	35.	10.	0.	-30.	104.	DISTILLA	74.	10	0.31	0.34	0.34
45 FCPADS FUEL-CL-PH	POWR	0.	26.	67.	11.	26.	8.	28.	0.	95.	DISTILLA	95.	0	0.22	0.27	0.37
45 FCPADS FUEL-CL-PH	HEAT	0.	80.	206.	35.	78.	23.	0.	-165.	206.	DISTILLA	41.	0	0.28	0.38	0.17
46 FCMCDS FUEL-CL-MO	POWR	0.	35.	62.	14.	26.	8.	24.	0.	86.	DISTILLA	86.	0	0.29	0.30	0.41
46 FCMCDS FUEL-CL-MO	HEAT	0.	84.	150.	35.	62.	18.	0.	-113.	150.	DISTILLA	37.	0	0.36	0.41	0.23

ORIGINAL PAGE IS  
OF POOR QUALITY

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28241 MW 32.00 PROCESS MILLIONS BTU/HR 30.0 PROCESS TEMP(F) 406. PRODUCT POLYESTER HOURS PER YEAR 7900.

POWER TO HEAT RATIO 3.639

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
0 ONCOGN NO COGN		0.	0.	0.	0.	0.	0.	35.	341.	35.	RESIDUAL	376.	0	0.	0.29	0.08
1 STM141 STM-TURB-1 POWR		0.	-640.	1016.	755.	109.	32.	-853.	0.	1016.	RESIDUAL	1016.	0	-1.70	0.11	0.03
1 STM141 STM-TURB-1 HEAT		0.	8.	40.	30.	4.	1.	0.	328.	40.	RESIDUAL	368.	10	0.02	0.01	0.08
1 STM141 STM-TURB-1 POWR		0.	-640.	1016.	755.	109.	32.	-853.	0.	1016.	COAL-FGD	1016.	0	-1.70	0.11	0.03
1 STM141 STM-TURB-1 HEAT		0.	8.	40.	30.	4.	1.	0.	328.	40.	COAL-FGD	368.	10	0.02	0.01	0.08
1 STM141 STM-TURB-1 POWR		0.	-640.	1016.	755.	109.	32.	-853.	0.	1016.	COAL-AFB	1016.	0	-1.70	0.11	0.03
1 STM141 STM-TURB-1 HEAT		0.	8.	40.	30.	4.	1.	0.	328.	40.	COAL-AFB	368.	10	0.02	0.01	0.08
2 STM088 STM-TURB-8 POWR		0.	-1143.	1519.	1182.	109.	32.	-1356.	0.	1519.	RESIDUAL	1519.	0	-3.04	0.07	0.02
2 STM088 STM-TURB-8 HEAT		0.	5.	39.	30.	3.	1.	0.	333.	39.	RESIDUAL	371.	10	0.01	0.01	0.08
2 STM088 STM-TURB-8 POWR		0.	-1143.	1519.	1182.	109.	32.	-1356.	0.	1519.	COAL-FGD	1519.	0	-3.04	0.07	0.02
2 STM088 STM-TURB-8 HEAT		0.	5.	39.	30.	3.	1.	0.	333.	39.	COAL-FGD	371.	10	0.01	0.01	0.08
2 STM088 STM-TURB-8 POWR		0.	-1143.	1519.	1182.	109.	32.	-1356.	0.	1519.	COAL-AFB	1519.	0	-3.04	0.07	0.02
2 STM088 STM-TURB-8 HEAT		0.	5.	39.	30.	3.	1.	0.	333.	39.	COAL-AFB	371.	10	0.01	0.01	0.08
3 PFBSTM PFB-STMTB- POWR		0.	-236.	613.	405.	109.	32.	-442.	0.	613.	COAL-PFB	613.	0	-0.63	0.18	0.05
3 PFBSTM PFB-STMTB- HEAT		0.	15.	45.	30.	8.	2.	0.	316.	45.	COAL-PFB	361.	10	0.04	0.02	0.08
4 TISTMT TI-STMTB-1 POWR		0.	-100.	477.	293.	109.	32.	-309.	0.	477.	RESIDUAL	477.	0	-0.27	0.23	0.06
4 TISTMT TI-STMTB-1 HEAT		0.	21.	49.	30.	11.	3.	0.	306.	49.	RESIDUAL	355.	10	0.06	0.03	0.08
4 TISTMT TI-STMTB-1 POWR		0.	-100.	477.	293.	109.	32.	-309.	0.	477.	COAL	477.	0	-0.27	0.23	0.06
4 TISTMT TI-STMTB-1 HEAT		0.	21.	49.	30.	11.	3.	0.	306.	49.	COAL	355.	10	0.06	0.03	0.08
5 TIHRSG THERMIONIC POWR		0.	-400.	776.	490.	109.	32.	-541.	0.	776.	RESIDUAL	776.	0	-1.06	0.14	0.04
5 TIHRSG THERMIONIC HEAT		0.	9.	47.	30.	7.	2.	0.	320.	47.	RESIDUAL	368.	10	0.02	0.02	0.08
5 TIHRSG THERMIONIC POWR		0.	-400.	776.	490.	109.	32.	-541.	0.	776.	COAL	776.	0	-1.06	0.14	0.04
5 TIHRSG THERMIONIC HEAT		0.	9.	47.	30.	7.	2.	0.	320.	47.	COAL	368.	10	0.02	0.02	0.08
6 STIRL STIRLING-1 POWR		0.	-75.	451.	220.	109.	32.	-223.	0.	451.	DISTILLA	451.	0	-0.20	0.24	0.07
6 STIRL STIRLING-1 HEAT		0.	20.	62.	30.	15.	4.	0.	295.	62.	DISTILLA	356.	0	0.05	0.04	0.08

HONEYWELL PAGE PRINTING SYSTEM- P1188-02

ORIGINAL PAGE IS OF POOR QUALITY

18SE PEG ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28241 MW 32.00 PROCESS MILLIONS BTU/HR 30.0 PROCESS TEMP(F) 406. PRODUCT POLYESTER HOURS PER YEAR 7900.

POWER TO HEAT RATIO 3.639

WASTE FUEL EGV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL COAL

	WASTE FUEL USED 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN ELECT 10**6 BTU/HR	AUX PROCES BOILER 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	FUEL SITE USED 10**6 BTU/HR	TOTAL FUEL SITE USED 10**6 BTU/HR	SITE RESIDUAL	NET* TOTAL* UT LIT 10**6 BTU/HR	FAIL	FESR	POWER HEAT FACTR	
6 STIRL STIRLING-1 POWR	0.	-75.	451.	220.	109.	32.	-223.	0.	451.	RESIDUAL	451.	0	-0.20	0.24	0.07
6 STIRL STIRLING-1 HEAT	0.	20.	62.	30.	15.	4.	0.	295.	62.	RESIDUAL	356.	0	0.05	0.04	0.08
6 STIRL STIRLING-1 POWR	0.	-75.	451.	220.	109.	32.	-223.	0.	451.	COAL	451.	0	-0.20	0.24	0.07
6 STIRL STIRLING-1 HEAT	0.	20.	62.	30.	15.	4.	0.	295.	62.	COAL	356.	0	0.05	0.04	0.08
7 HEGT85 HELIUM-GT- POWR	0.	23.	340.	19.	109.	32.	13.	0.	354.	COAL-AFB	354.	11	0.06	0.31	0.08
7 HEGT85 HELIUM-GT- HEAT	0.	37.	549.	30.	175.	52.	0.	-210.	549.	COAL-AFB	339.	1	0.06	0.32	0.05
8 HEGT60 HELIUM-GT- POWR	0.	-45.	422.	105.	109.	32.	-89.	0.	422.	COAL-AFB	422.	10	-0.12	0.26	0.07
8 HEGT60 HELIUM-GT- HEAT	0.	12.	120.	30.	31.	9.	0.	244.	120.	COAL-AFB	364.	10	0.03	0.09	0.08
9 HEGT00 HELIUM-GT- POWR	0.	-244.	620.	297.	109.	32.	-315.	0.	620.	COAL-AFB	620.	10	-0.65	0.18	0.03
9 HEGT00 HELIUM-GT- HEAT	0.	7.	63.	30.	11.	3.	0.	307.	63.	COAL-AFB	369.	10	0.02	0.03	0.08
10 FCMCCL FUEL-CL-MG POWR	0.	17.	359.	170.	109.	32.	-164.	0.	359.	COAL	359.	10	0.05	0.30	0.08
10 FCMCCL FUEL-CL-MG HEAT	0.	32.	64.	30.	19.	6.	0.	281.	64.	COAL	344.	10	0.09	0.06	0.09
11 FCSTCL FUEL-CL-ST POWR	0.	76.	300.	125.	109.	32.	-111.	0.	300.	COAL	300.	10	0.20	0.36	0.10
11 FCSTCL FUEL-CL-ST HEAT	0.	45.	72.	30.	25.	8.	0.	259.	72.	COAL	331.	10	0.12	0.08	0.09
12 IGGTST INT-GAS-GT POWR	0.	-37.	413.	184.	109.	32.	-182.	0.	413.	COAL	413.	10	-0.10	0.26	0.07
12 IGGTST INT-GAS-GT HEAT	0.	24.	67.	30.	18.	5.	0.	286.	67.	COAL	353.	10	0.06	0.05	0.08
13 GTSOAR GT-HRSG-10 POWR	0.	-0.	376.	155.	109.	32.	-147.	0.	376.	RESIDUAL	376.	0	-0.00	0.29	0.06
13 GTSOAR GT-HRSG-10 HEAT	0.	28.	73.	30.	21.	6.	0.	275.	73.	RESIDUAL	348.	10	0.08	0.06	0.09
14 GTAC08 GT-HPSG-08 POWR	0.	-28.	404.	208.	109.	32.	-210.	0.	404.	RESIDUAL	404.	0	-0.07	0.27	0.07
14 GTAC08 GT-HPSG-08 HEAT	0.	26.	58.	30.	15.	5.	0.	292.	58.	RESIDUAL	350.	10	0.07	0.04	0.09
15 GTAC12 GT-HRSG-12 POWR	0.	19.	358.	166.	109.	32.	-160.	0.	358.	RESIDUAL	358.	0	0.05	0.31	0.08
15 GTAC12 GT-HRSG-12 HEAT	0.	32.	65.	30.	20.	6.	0.	279.	65.	RESIDUAL	344.	10	0.09	0.05	0.09
16 GTAC16 GT-HRSG-16 POWR	0.	38.	338.	145.	109.	32.	-135.	0.	338.	RESIDUAL	338.	0	0.10	0.32	0.09
16 GTAC16 GT-HRSG-16 HEAT	0.	35.	70.	30.	23.	7.	0.	270.	70.	RESIDUAL	341.	10	0.10	0.07	0.09
17 GTWC16 GT-HRSG-16 POWR	0.	30.	347.	140.	109.	32.	-130.	0.	347.	RESIDUAL	347.	0	0.08	0.32	0.09
17 GTWC16 GT-HRSG-16 HEAT	0.	34.	74.	30.	23.	7.	0.	268.	74.	RESIDUAL	342.	10	0.09	0.07	0.09

NONRECYCLED PAPER PRINTED AT THE UNIVERSITY OF MICHIGAN LIBRARY

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28241 MW 32.00 PROCESS MILLIONS BTU/HR 30.0 PROCESS TEMP(F) 406. PRODUCT POLYESTER HOURS PER YEAR 7900.

POWER TO HEAT RATIO 3.639

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL COAL

		WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL\$ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
18	CC1626 GTST-16/26 POWR	0.	75.	301.	98.	109.	32.	-80.	0.	301.	RESIDUAL	301.	0	0.20	0.36	0.10
18	CC1626 GTST-16/26 HEAT	0.	48.	92.	30.	33.	10.	0.	237.	92.	RESIDUAL	329.	10	0.13	0.10	0.09
19	CC1622 GTST-16/22 POWR	0.	70.	307.	109.	109.	32.	-93.	0.	307.	RESIDUAL	307.	0	0.19	0.36	0.10
19	CC1622 GTST-16/22 HEAT	0.	45.	84.	30.	30.	9.	0.	248.	84.	RESIDUAL	332.	10	0.12	0.09	0.09
20	CC1222 GTST-12/22 POWR	0.	70.	306.	110.	109.	32.	-94.	0.	306.	RESIDUAL	306.	0	0.19	0.36	0.10
20	CC1222 GTST-12/22 HEAT	0.	45.	83.	30.	30.	9.	0.	248.	83.	RESIDUAL	332.	10	0.12	0.09	0.09
21	CC0822 GTST-08/22 POWR	0.	47.	329.	140.	109.	32.	-130.	0.	329.	RESIDUAL	329.	0	0.12	0.33	0.09
21	CC0822 GTST-08/22 HEAT	0.	38.	70.	30.	23.	7.	0.	268.	70.	RESIDUAL	339.	10	0.10	0.07	0.09
22	STIG15 STIG-15-16 POWR	0.	59.	287.	4.	109.	32.	31.	0.	317.	RESIDUAL	317.	0	0.16	0.34	0.09
22	STIG15 STIG-15-16 HEAT	0.	475.	2308.	30.	879.	258.	0.	-2406.	2308.	RESIDUAL	-99.	0	0.17	0.38	0.01
23	STIG10 STIG-10-16 POWR	0.	72.	304.	40.	109.	32.	-12.	0.	304.	RESIDUAL	304.	0	0.19	0.36	0.10
23	STIG10 STIG-10-16 HEAT	0.	63.	226.	30.	81.	24.	0.	87.	226.	RESIDUAL	314.	0	0.17	0.26	0.10
24	STIG1S STIG-1S-16 POWR	0.	51.	326.	69.	109.	32.	-45.	0.	326.	RESIDUAL	326.	0	0.13	0.34	0.09
24	STIG1S STIG-1S-16 HEAT	0.	42.	142.	30.	48.	14.	0.	192.	142.	RESIDUAL	334.	10	0.11	0.14	0.09
25	DEADV3 DIESEL-ADV POWR	0.	82.	294.	55.	109.	32.	-30.	0.	294.	RESIDUAL	294.	0	0.22	0.37	0.10
25	DEADV3 DIESEL-ADV HEAT	0.	61.	160.	30.	59.	17.	0.	156.	160.	RESIDUAL	316.	0	0.16	0.19	0.10
26	DEADV2 DIESEL-ADV POWR	0.	82.	294.	75.	109.	32.	-53.	0.	294.	RESIDUAL	294.	1	0.22	0.37	0.10
26	DEADV2 DIESEL-ADV HEAT	0.	54.	118.	30.	44.	13.	0.	204.	118.	RESIDUAL	322.	1	0.14	0.14	0.09
27	DEADV1 DIESEL-ADV POWR	0.	82.	294.	115.	109.	32.	-100.	0.	294.	RESIDUAL	294.	1	0.22	0.37	0.10
27	DEADV1 DIESEL-ADV HEAT	0.	48.	77.	30.	28.	8.	0.	252.	77.	RESIDUAL	329.	1	0.13	0.09	0.09
28	DEHTPM ADV-DIESEL POWR	0.	25.	351.	150.	109.	32.	-142.	0.	351.	RESIDUAL	351.	0	0.07	0.31	0.09
28	DEHTPM ADV-DIESEL HEAT	0.	33.	70.	30.	22.	6.	0.	273.	70.	RESIDUAL	343.	0	0.09	0.06	0.09
29	DESCA3 DIESEL-SOA POWR	0.	74.	302.	47.	109.	32.	-20.	0.	302.	DISTILLA	302.	0	0.20	0.36	0.10
29	DESCA3 DIESEL-SOA HEAT	0.	60.	195.	30.	70.	21.	0.	122.	195.	DISTILLA	316.	0	0.16	0.22	0.09
29	DESCA3 DIESEL-SOA POWR	0.	74.	302.	47.	109.	32.	-20.	0.	302.	RESIDUAL	302.	0	0.20	0.36	0.10
29	DESCA3 DIESEL-SOA HEAT	0.	60.	195.	30.	70.	21.	0.	122.	195.	RESIDUAL	316.	0	0.16	0.22	0.09

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28241 MW 32.00 PROCESS MILLIONS BTU/HR 30.0 PROCESS TEMP(F) 406. PRODUCT POLYESTER HOURS PER YEAR 7900.

POWER TO HEAT RATIO 3.639

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
30 DES0A2 DIESEL-S0A POWR		0.	74.	302.	67.	109.	32.	-43.	0.	302.	DISTILLA	302.	1	0.20	0.36	0.10
30 DES0A2 DIESEL-S0A HEAT		0.	53.	136.	30.	49.	14.	0.	187.	136.	DISTILLA	324.	1	0.14	0.15	0.09
30 DES0A2 DIESEL-S0A POWR		0.	74.	302.	67.	109.	32.	-43.	0.	302.	RESIDUAL	302.	1	0.20	0.36	0.10
30 DES0A2 DIESEL-S0A HEAT		0.	53.	136.	30.	49.	14.	0.	187.	136.	RESIDUAL	324.	1	0.14	0.15	0.09
31 DES0A1 DIESEL-S0A POWR		0.	74.	302.	121.	109.	32.	-107.	0.	302.	DISTILLA	302.	1	0.20	0.36	0.10
31 DES0A1 DIESEL-S0A HEAT		0.	45.	75.	30.	27.	8.	0.	257.	75.	DISTILLA	332.	1	0.12	0.08	0.09
31 DES0A1 DIESEL-S0A POWR		0.	74.	302.	121.	109.	32.	-107.	0.	302.	RESIDUAL	302.	1	0.20	0.36	0.10
31 DES0A1 DIESEL-S0A HEAT		0.	45.	75.	30.	27.	8.	0.	257.	75.	RESIDUAL	332.	1	0.12	0.08	0.09
32 GTS0AD GT-HRSG-10 POWR		0.	3.	374.	171.	109.	32.	-166.	0.	374.	DISTILLA	374.	0	0.01	0.29	0.08
32 GTS0AD GT-HRSG-10 HEAT		0.	30.	66.	30.	19.	6.	0.	281.	66.	DISTILLA	347.	10	0.08	0.06	0.09
33 GTRA08 GT-85RE-08 POWR		0.	71.	306.	97.	109.	32.	-79.	0.	306.	DISTILLA	306.	0	0.19	0.36	0.10
33 GTRA08 GT-85RE-08 HEAT		0.	46.	94.	30.	34.	10.	0.	236.	94.	DISTILLA	330.	10	0.12	0.10	0.09
34 GTRA12 GT-85RE-12 POWR		0.	72.	305.	101.	109.	32.	-84.	0.	305.	DISTILLA	305.	0	0.19	0.36	0.10
34 GTRA12 GT-85RE-12 HEAT		0.	46.	91.	30.	32.	10.	0.	240.	91.	DISTILLA	330.	10	0.12	0.10	0.09
35 GTRA16 GT-85RE-16 POWR		0.	64.	313.	109.	109.	32.	-93.	0.	313.	DISTILLA	313.	0	0.17	0.35	0.10
35 GTRA16 GT-85RE-16 HEAT		0.	43.	86.	30.	30.	9.	0.	248.	86.	DISTILLA	333.	10	0.11	0.09	0.09
36 GTR208 GT-60RE-08 POWR		0.	35.	341.	134.	109.	32.	-122.	0.	341.	DISTILLA	341.	0	0.09	0.32	0.09
36 GTR208 GT-60RE-08 HEAT		0.	35.	77.	30.	24.	7.	0.	265.	77.	DISTILLA	341.	10	0.09	0.07	0.09
37 GTR212 GT-60RE-12 POWR		0.	46.	331.	125.	109.	32.	-111.	0.	331.	DISTILLA	331.	0	0.12	0.33	0.09
37 GTR212 GT-60RE-12 HEAT		0.	38.	80.	30.	26.	8.	0.	259.	80.	DISTILLA	339.	10	0.10	0.08	0.09
38 GTR216 GT-60RE-16 POWR		0.	53.	324.	121.	109.	32.	-108.	0.	324.	DISTILLA	324.	0	0.14	0.34	0.09
38 GTR216 GT-60RE-16 HEAT		0.	40.	80.	30.	27.	8.	0.	257.	80.	DISTILLA	337.	10	0.11	0.08	0.09
39 GTRW08 GT-85RE-08 POWR		0.	65.	311.	82.	109.	32.	-61.	0.	311.	DISTILLA	311.	0	0.17	0.35	0.10
39 GTRW08 GT-85RE-08 HEAT		0.	46.	114.	30.	40.	12.	0.	217.	114.	DISTILLA	330.	10	0.12	0.12	0.09
40 GTRW12 GT-85RE-12 POWR		0.	77.	300.	82.	109.	32.	-61.	0.	300.	DISTILLA	300.	0	0.20	0.36	0.10
40 GTRW12 GT-85RE-12 HEAT		0.	50.	110.	30.	40.	12.	0.	216.	110.	DISTILLA	326.	10	0.13	0.12	0.09

HONEYWELL PAGE PRINTING SYSTEM- P1188-02

1&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28241 MW 32.00 PROCESS MILLIONS BTU/HR 30.0 PROCESS TEMP(F) 406. PRODUCT POLYESTER HOURS PER YEAR 7900.

POWER TO HEAT RATIO 3.639

UTILITY FUEL COAL WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41 GTRW16 GT-85RE-16 POWR	0.	71.	306.	89.	109.	32.	-70.	0.	306.	DISTILLA	306.	0	0.19	0.36	0.10
41 GTRW16 GT-85RE-16 HEAT	0.	47.	103.	30.	37.	11.	0.	226.	103.	DISTILLA	329.	10	0.13	0.11	0.09
42 GTR308 GT-60RE-08 POWR	0.	24.	352.	88.	109.	32.	-92.	0.	352.	DISTILLA	352.	0	0.06	0.31	0.09
42 GTR308 GT-60RE-08 HEAT	0.	32.	98.	30.	30.	9.	0.	247.	98.	DISTILLA	344.	10	0.09	0.09	0.09
43 GTR312 GT-60RE-12 POWR	0.	57.	319.	104.	109.	32.	-87.	0.	319.	DISTILLA	319.	0	0.15	0.34	0.09
43 GTR312 GT-60RE-12 HEAT	0.	42.	92.	30.	31.	9.	0.	243.	92.	DISTILLA	335.	10	0.11	0.09	0.09
44 GTR316 GT-60RE-16 POWR	0.	54.	322.	106.	109.	32.	-89.	0.	322.	DISTILLA	322.	0	0.14	0.34	0.09
44 GTR316 GT-60RE-16 HEAT	0.	41.	91.	30.	31.	9.	0.	244.	91.	DISTILLA	336.	10	0.11	0.09	0.09
45 FCPADS FUEL-CL-PH POWR	0.	89.	287.	49.	109.	32.	-22.	0.	287.	DISTILLA	287.	0	0.24	0.38	0.10
45 FCPADS FUEL-CL-PH HEAT	0.	68.	176.	30.	67.	20.	0.	132.	176.	DISTILLA	308.	0	0.18	0.22	0.10
46 FCMCDS FUEL-CL-MO POWR	0.	111.	265.	62.	109.	32.	-37.	0.	265.	DISTILLA	265.	0	0.30	0.41	0.11
46 FCMCDS FUEL-CL-MO HEAT	0.	72.	129.	30.	53.	16.	0.	175.	129.	DISTILLA	304.	0	0.19	0.17	0.10

ATTENTION: THE ENGINEERING DEPARTMENT



I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28242 MW 11.00 PROCESS MILLIONS BTU/HR 23.0 PROCESS TEMP(F) 274. PRODUCT NYLON-66-FIB HOURS PER YEAR 8760.

POWER TO HEAT RATIO 1.632

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
0	ONOCGN N O C O O N	0.	0.	0.	0.	0.	0.	27.	117.	27. RESIDUAL	144.	0	0.	0.26	0.16
1	STM141 STM-TURB-1 POWR	0.	-61.	205.	137.	38.	11.	-134.	0.	205. RESIDUAL	205.	0	-0.42	0.18	0.11
1	STM141 STM-TURB-1 HEAT	0.	12.	34.	23.	6.	2.	0.	98.	34. RESIDUAL	132.	10	0.09	0.05	0.17
1	STM141 STM-TURB-1 POWR	0.	-61.	205.	137.	38.	11.	-134.	0.	205. COAL-FGD	205.	0	-0.42	0.18	0.11
1	STM141 STM-TURB-1 HEAT	0.	12.	34.	23.	6.	2.	0.	98.	34. COAL-FGD	132.	10	0.09	0.05	0.17
1	STM141 STM-TURB-1 POWR	0.	-61.	205.	137.	38.	11.	-134.	0.	205. COAL-AFB	205.	0	-0.42	0.18	0.11
1	STM141 STM-TURB-1 HEAT	0.	12.	34.	23.	6.	2.	0.	98.	34. COAL-AFB	132.	10	0.09	0.05	0.17
2	STM088 STM-TURB-8 POWR	0.	-107.	252.	176.	38.	11.	-180.	0.	252. RESIDUAL	252.	0	-0.74	0.15	0.09
2	STM088 STM-TURB-8 HEAT	0.	10.	33.	23.	5.	1.	0.	102.	33. RESIDUAL	135.	10	0.07	0.04	0.17
2	STM088 STM-TURB-8 POWR	0.	-107.	252.	176.	38.	11.	-180.	0.	252. COAL-FGD	252.	0	-0.74	0.15	0.09
2	STM088 STM-TURB-8 HEAT	0.	10.	33.	23.	5.	1.	0.	102.	33. COAL-FGD	135.	10	0.07	0.04	0.17
2	STM088 STM-TURB-8 POWR	0.	-107.	252.	176.	38.	11.	-180.	0.	252. COAL-AFB	252.	0	-0.74	0.15	0.09
2	STM088 STM-TURB-8 HEAT	0.	10.	33.	23.	5.	1.	0.	102.	33. COAL-AFB	135.	10	0.07	0.04	0.17
3	PFBSTM PFB-STMTB- POWR	0.	-9.	153.	92.	38.	11.	-81.	0.	153. COAL-PFB	153.	10	-0.06	0.24	0.15
3	PFBSTM PFB-STMTB- HEAT	0.	18.	38.	23.	9.	3.	0.	88.	38. COAL-PFB	126.	10	0.13	0.07	0.18
4	TISTMT TI-STMTB-1 POWR	0.	16.	129.	71.	38.	11.	-56.	0.	129. RESIDUAL	129.	10	0.11	0.29	0.18
4	TISTMT TI-STMTB-1 HEAT	0.	23.	42.	23.	12.	4.	0.	79.	42. RESIDUAL	121.	10	0.16	0.10	0.19
4	TISTMT TI-STMTB-1 POWR	0.	16.	129.	71.	38.	11.	-56.	0.	129. COAL	129.	10	0.11	0.29	0.18
4	TISTMT TI-STMTB-1 HEAT	0.	23.	42.	23.	12.	4.	0.	79.	42. COAL	121.	10	0.16	0.10	0.19
5	TIHRSG THERMIONIC POWR	0.	-122.	267.	179.	38.	11.	-184.	0.	267. RESIDUAL	267.	0	-0.85	0.14	0.09
5	TIHRSG THERMIONIC HEAT	0.	8.	34.	23.	5.	1.	0.	102.	34. RESIDUAL	136.	10	0.05	0.04	0.17
5	TIHRSG THERMIONIC POWR	0.	-122.	267.	179.	38.	11.	-184.	0.	267. COAL	267.	0	-0.85	0.14	0.09
5	TIHRSG THERMIONIC HEAT	0.	8.	34.	23.	5.	1.	0.	102.	34. COAL	136.	10	0.05	0.04	0.17
6	STIRL STIRLING-1 POWR	0.	6.	138.	63.	38.	11.	-47.	0.	138. DISTILLA	138.	0	0.04	0.27	0.17
6	STIRL STIRLING-1 HEAT	0.	19.	50.	23.	14.	4.	0.	75.	50. DISTILLA	125.	0	0.14	0.11	0.18

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28242 MW 11.00 PROCESS MILLIONS BTU/HR 23.0 PROCESS TEMP(F) 274. PRODUCT NYLON-66-FIB HOURS PER YEAR 8760.

UTILITY FUEL		COAL	POWER TO HEAT RATIO 1.632										WASTE FUEL EQV BTU*10**6= 0. HOT WATER BTU*10**6= 0.			
WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR		
6 STIRL	STIRLING-1 POWR	0.	6.	138.	63.	38.	11.	-47.	0.	138.	RESIDUAL	138.	0	0.04	0.27	0.17
6 STIRL	STIRLING-1 HEAT	0.	19.	50.	23.	14.	4.	0.	75.	50.	RESIDUAL	125.	0	0.14	0.11	0.18
6 STIRL	STIRLING-1 POWR	0.	6.	138.	63.	38.	11.	-47.	0.	138.	COAL	138.	0	0.04	0.27	0.17
6 STIRL	STIRLING-1 HEAT	0.	19.	50.	23.	14.	4.	0.	75.	50.	COAL	125.	0	0.14	0.11	0.18
7 HEGT85	HELIUM-GT- POWR	0.	27.	117.	29.	38.	11.	-6.	0.	117.	COAL-AFB	117.	10	0.19	0.32	0.20
7 HEGT85	HELIUM-GT- HEAT	0.	27.	94.	23.	30.	9.	0.	23.	94.	COAL-AFB	117.	10	0.19	0.26	0.20
8 HEGT60	HELIUM-GT- POWR	0.	-1.	145.	53.	38.	11.	-35.	0.	145.	COAL-AFB	145.	10	-0.00	0.26	0.16
8 HEGT60	HELIUM-GT- HEAT	0.	15.	63.	23.	16.	5.	0.	66.	63.	COAL-AFB	129.	10	0.10	0.13	0.18
9 HEGT00	HELIUM-GT- POWR	0.	-69.	213.	109.	38.	11.	-101.	0.	213.	COAL-AFB	213.	10	-0.48	0.18	0.11
9 HEGT00	HELIUM-GT- HEAT	0.	7.	45.	23.	8.	2.	0.	93.	45.	COAL-AFB	138.	10	0.05	0.06	0.17
10 FCMCCL	FUEL-CL-MO POWR	0.	21.	123.	59.	38.	11.	-42.	0.	123.	COAL	123.	10	0.14	0.30	0.19
10 FCMCCL	FUEL-CL-MO HEAT	0.	25.	48.	23.	15.	4.	0.	71.	48.	COAL	120.	10	0.17	0.12	0.19
11 FCSTCL	FUEL-CL-ST POWR	0.	52.	93.	35.	38.	11.	-14.	0.	93.	COAL	93.	10	0.36	0.41	0.25
11 FCSTCL	FUEL-CL-ST HEAT	0.	44.	62.	23.	25.	7.	0.	39.	62.	COAL	101.	10	0.30	0.25	0.23
12 IGGTST	INT-GAS-GT POWR	0.	23.	121.	49.	38.	11.	-30.	0.	121.	COAL	121.	10	0.16	0.31	0.19
12 IGGTST	INT-GAS-GT HEAT	0.	25.	57.	23.	18.	5.	0.	62.	57.	COAL	119.	10	0.17	0.15	0.19
13 GTSOAR	GT-HRSG-10 POWR	0.	15.	129.	58.	38.	11.	-41.	0.	129.	RESIDUAL	129.	0	0.10	0.29	0.18
13 GTSOAR	GT-HRSG-10 HEAT	0.	22.	51.	23.	15.	4.	0.	71.	51.	RESIDUAL	122.	10	0.15	0.12	0.19
14 GTAC08	GT-HRSG-08 POWR	0.	5.	139.	71.	38.	11.	-56.	0.	139.	RESIDUAL	139.	10	0.04	0.27	0.17
14 GTAC08	GT-HRSG-08 HEAT	0.	20.	45.	23.	12.	4.	0.	79.	45.	RESIDUAL	124.	10	0.14	0.10	0.18
15 GTAC12	GT-HRSG-12 POWR	0.	21.	123.	58.	38.	11.	-41.	0.	123.	RESIDUAL	123.	10	0.15	0.31	0.19
15 GTAC12	GT-HRSG-12 HEAT	0.	25.	49.	23.	15.	4.	0.	71.	49.	RESIDUAL	120.	10	0.17	0.12	0.19
16 GTAC16	GT-HRSG-16 POWR	0.	28.	116.	52.	38.	11.	-34.	0.	116.	RESIDUAL	116.	10	0.20	0.32	0.20
16 GTAC16	GT-HRSG-16 HEAT	0.	28.	52.	23.	17.	5.	0.	65.	52.	RESIDUAL	117.	10	0.19	0.14	0.20
17 GTWC16	GT-HRSG-16 POWR	0.	25.	119.	48.	38.	11.	-30.	0.	119.	RESIDUAL	119.	10	0.17	0.32	0.19
17 GTWC16	GT-HRSG-16 HEAT	0.	26.	57.	23.	18.	5.	0.	61.	57.	RESIDUAL	118.	10	0.18	0.15	0.19

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28242 MW 11.00 PROCESS MILLIONS BTU/HR 23.0 PROCESS TEMP(F) 274. PRODUCT NYLON-66-FIB HOURS PER YEAR 8760.

POWER TO HEAT RATIO 1.632

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
18 CC1626	GTST-16/26	POWR	0.	49.	95.	28.	38.	11.	-6.	0.	95.	RESIDUAL	95.	10	0.34	0.40	0.24
18 CC1626	GTST-16/26	HEAT	0.	46.	79.	23.	31.	9.	0.	20.	79.	RESIDUAL	99.	10	0.32	0.32	0.23
19 CC1622	GTST-16/22	POWR	0.	48.	96.	31.	38.	11.	-9.	0.	96.	RESIDUAL	96.	10	0.34	0.39	0.24
19 CC1622	GTST-16/22	HEAT	0.	43.	72.	23.	28.	8.	0.	30.	72.	RESIDUAL	101.	10	0.30	0.28	0.23
20 CC1222	GTST-12/22	POWR	0.	49.	95.	31.	38.	11.	-9.	0.	95.	RESIDUAL	95.	10	0.34	0.39	0.24
20 CC1222	GTST-12/22	HEAT	0.	43.	71.	23.	28.	8.	0.	30.	71.	RESIDUAL	101.	10	0.30	0.28	0.23
21 CC0822	GTST-08/22	POWR	0.	44.	100.	38.	38.	11.	-18.	0.	100.	RESIDUAL	100.	10	0.31	0.37	0.23
21 CC0822	GTST-08/22	HEAT	0.	37.	60.	23.	23.	7.	0.	47.	60.	RESIDUAL	107.	10	0.26	0.21	0.21
22 STIG15	STIG-15-16	POWR	0.	20.	99.	1.	38.	11.	26.	0.	124.	RESIDUAL	124.	10	0.14	0.30	0.19
22 STIG15	STIG-15-16	HEAT	0.	364.	1769.	23.	674.	198.	0.	-1989.	1769.	RESIDUAL	-220.	0	0.17	0.38	0.01
23 STIG10	STIG-10-16	POWR	0.	29.	105.	14.	38.	11.	11.	0.	115.	RESIDUAL	115.	10	0.20	0.33	0.20
23 STIG10	STIG-10-16	HEAT	0.	48.	174.	23.	62.	16.	0.	-78.	174.	RESIDUAL	96.	10	0.22	0.36	0.13
24 STIG1S	STIG-1S-16	POWR	0.	32.	112.	24.	38.	11.	-1.	0.	112.	RESIDUAL	112.	10	0.22	0.34	0.21
24 STIG1S	STIG-1S-16	HEAT	0.	32.	109.	23.	37.	11.	0.	3.	109.	RESIDUAL	112.	10	0.22	0.33	0.21
25 DEADV3	DIESEL-ADV	POWR	0.	43.	101.	25.	38.	11.	-2.	0.	101.	RESIDUAL	101.	0	0.30	0.37	0.23
25 DEADV3	DIESEL-ADV	HEAT	0.	42.	94.	23.	35.	10.	0.	8.	94.	RESIDUAL	102.	0	0.29	0.34	0.22
26 DEADV2	DIESEL-ADV	POWR	0.	43.	101.	26.	38.	11.	-3.	0.	101.	RESIDUAL	101.	1	0.30	0.37	0.23
26 DEADV2	DIESEL-ADV	HEAT	0.	41.	91.	23.	34.	10.	0.	12.	91.	RESIDUAL	103.	1	0.29	0.35	0.22
27 DEADV1	DIESEL-ADV	POWR	0.	43.	101.	40.	38.	11.	-19.	0.	101.	RESIDUAL	101.	1	0.30	0.37	0.23
27 DEADV1	DIESEL-ADV	HEAT	0.	36.	59.	23.	22.	6.	0.	49.	59.	RESIDUAL	108.	1	0.25	0.20	0.21
28 DEHTPM	ADV-DIESEL	POWR	0.	40.	105.	46.	38.	11.	-27.	0.	105.	RESIDUAL	105.	0	0.27	0.36	0.22
28 DEHTPM	ADV-DIESEL	HEAT	0.	33.	53.	23.	19.	6.	0.	58.	53.	RESIDUAL	111.	0	0.23	0.17	0.21
29 DESOA3	DIESEL-SOA	POWR	0.	39.	104.	22.	38.	11.	1.	0.	105.	DISTILLA	105.	0	0.27	0.36	0.22
29 DESOA3	DIESEL-SOA	HEAT	0.	41.	110.	23.	40.	12.	0.	-6.	110.	DISTILLA	103.	0	0.27	0.36	0.21
29 DESOA3	DIESEL-SOA	POWR	0.	39.	104.	22.	38.	11.	1.	0.	105.	RESIDUAL	105.	0	0.27	0.36	0.22
29 DESOA3	DIESEL-SOA	HEAT	0.	41.	110.	23.	40.	12.	0.	-6.	110.	RESIDUAL	103.	0	0.27	0.36	0.21

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 139

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28242 MW 11.00 PROCESS MILLIONS BTU/HR 23.0 PROCESS TEMP(F) 274. PRODUCT NYLON-66-FIB HOURS PER YEAR 8760.

		POWER TO HEAT RATIO 1.632														
		WASTE FUEL EQV BTU*10**6= 0.										HOT WATER BTU*10**6= 0.				
UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
30 DES0A2 DIESEL-S0A	POWR	0.	40.	104.	23.	38.	11.	0.	0.	104.	DISTILLA	104.	1	0.28	0.36	0.22
30 DES0A2 DIESEL-S0A	HEAT	0.	40.	105.	23.	38.	11.	0.	-1.	105.	DISTILLA	104.	1	0.28	0.36	0.22
30 DES0A2 DIESEL-S0A	POWR	0.	40.	104.	23.	38.	11.	0.	0.	104.	RESIDUAL	104.	1	0.28	0.36	0.22
30 DES0A2 DIESEL-S0A	HEAT	0.	40.	105.	23.	38.	11.	0.	-1.	105.	RESIDUAL	104.	1	0.28	0.36	0.22
31 DES0A1 DIESEL-S0A	POWR	0.	40.	104.	42.	38.	11.	-22.	0.	104.	DISTILLA	104.	1	0.28	0.36	0.22
31 DES0A1 DIESEL-S0A	HEAT	0.	34.	57.	23.	21.	6.	0.	53.	57.	DISTILLA	110.	1	0.24	0.19	0.21
31 DES0A1 DIESEL-S0A	POWR	0.	40.	104.	42.	38.	11.	-22.	0.	104.	RESIDUAL	104.	1	0.28	0.36	0.22
31 DES0A1 DIESEL-S0A	HEAT	0.	34.	57.	23.	21.	6.	0.	53.	57.	RESIDUAL	110.	1	0.24	0.19	0.21
32 GTS0AD GT-HRSG-10	POWR	0.	16.	129.	61.	38.	11.	-44.	0.	129.	DISTILLA	129.	10	0.11	0.29	0.18
32 GTS0AD GT-HRSG-10	HEAT	0.	23.	49.	23.	14.	4.	0.	73.	49.	DISTILLA	122.	10	0.16	0.12	0.19
33 GTRA08 GT-85RE-08	POWR	0.	39.	105.	39.	38.	11.	-19.	0.	105.	DISTILLA	105.	10	0.27	0.36	0.22
33 GTRA08 GT-85RE-08	HEAT	0.	34.	62.	23.	22.	7.	0.	48.	62.	DISTILLA	110.	10	0.24	0.20	0.21
34 GTRA12 GT-85RE-12	POWR	0.	40.	105.	39.	38.	11.	-19.	0.	105.	DISTILLA	105.	10	0.27	0.36	0.22
34 GTRA12 GT-85RE-12	HEAT	0.	34.	61.	23.	22.	6.	0.	49.	61.	DISTILLA	110.	10	0.24	0.20	0.21
35 GTRA16 GT-85RE-16	POWR	0.	37.	108.	42.	38.	11.	-22.	0.	108.	DISTILLA	108.	10	0.25	0.35	0.21
35 GTRA16 GT-85RE-16	HEAT	0.	32.	59.	23.	21.	6.	0.	53.	59.	DISTILLA	112.	10	0.22	0.18	0.21
36 GTR208 GT-60RE-08	POWR	0.	27.	117.	50.	38.	11.	-31.	0.	117.	DISTILLA	117.	10	0.19	0.32	0.20
36 GTR208 GT-60RE-08	HEAT	0.	27.	54.	23.	17.	5.	0.	63.	54.	DISTILLA	117.	10	0.19	0.15	0.20
37 GTR212 GT-60RE-12	POWR	0.	31.	114.	46.	38.	11.	-27.	0.	114.	DISTILLA	114.	10	0.21	0.33	0.20
37 GTR212 GT-60RE-12	HEAT	0.	29.	57.	23.	19.	5.	0.	59.	57.	DISTILLA	116.	10	0.20	0.16	0.20
38 GTR216 GT-60RE-16	POWR	0.	33.	111.	45.	38.	11.	-26.	0.	111.	DISTILLA	111.	10	0.23	0.34	0.21
38 GTR216 GT-60RE-16	HEAT	0.	30.	57.	23.	19.	6.	0.	58.	57.	DISTILLA	114.	10	0.21	0.17	0.20
39 GTRW08 GT-85RE-08	POWR	0.	37.	107.	32.	38.	11.	-11.	0.	107.	DISTILLA	107.	10	0.26	0.35	0.22
39 GTRW08 GT-85RE-08	HEAT	0.	34.	76.	23.	27.	8.	0.	34.	76.	DISTILLA	110.	10	0.24	0.24	0.21
40 GTRW12 GT-85RE-12	POWR	0.	41.	103.	31.	38.	11.	-10.	0.	103.	DISTILLA	103.	10	0.29	0.36	0.22
40 GTRW12 GT-85RE-12	HEAT	0.	37.	76.	23.	27.	8.	0.	31.	76.	DISTILLA	107.	10	0.26	0.26	0.22

HONEYWELL PAGE PRINTING SYSTEM- B118B-02

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28242 MW 11.00 PROCESS MILLIONS BTU/HR 23.0 PROCESS TEMP(F) 274. PRODUCT NYLON-66-FIB HOURS PER YEAR 8760.

POWER TO HEAT RATIO 1.632

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41 GTRW16 GT-85RE-16	POWR	0.	39.	105.	33.	38.	11.	-12.	0.	105.	DISTILLA	105.	10	0.27	0.36	0.22
41 GTRW16 GT-85RE-16	HEAT	0.	35.	72.	23.	26.	8.	0.	37.	72.	DISTILLA	109.	10	0.25	0.24	0.21
42 GTR308 GT-60RE-08	POWR	0.	23.	121.	43.	38.	11.	-23.	0.	121.	DISTILLA	121.	10	0.16	0.31	0.19
42 GTR308 GT-60RE-08	HEAT	0.	25.	65.	23.	20.	6.	0.	54.	65.	DISTILLA	119.	10	0.17	0.17	0.19
43 GTR312 GT-60RE-12	POWR	0.	35.	110.	38.	38.	11.	-17.	0.	110.	DISTILLA	110.	10	0.24	0.34	0.21
43 GTR312 GT-60RE-12	HEAT	0.	32.	67.	23.	23.	7.	0.	46.	67.	DISTILLA	113.	10	0.22	0.20	0.20
44 GTR316 GT-60RE-16	POWR	0.	34.	111.	38.	38.	11.	-18.	0.	111.	DISTILLA	111.	10	0.23	0.34	0.21
44 GTR316 GT-60RE-16	HEAT	0.	31.	67.	23.	23.	7.	0.	47.	67.	DISTILLA	113.	10	0.21	0.20	0.20
45 FCPADS FUEL-CL-PH	POWR	0.	38.	99.	17.	38.	11.	7.	0.	106.	DISTILLA	106.	0	0.27	0.35	0.22
45 FCPADS FUEL-CL-PH	HEAT	0.	52.	135.	23.	51.	15.	0.	-43.	135.	DISTILLA	92.	0	0.28	0.38	0.17
46 FCMCDS FUEL-CL-MO	POWR	0.	51.	91.	21.	38.	11.	2.	0.	93.	DISTILLA	93.	0	0.35	0.40	0.25
46 FCMCDS FUEL-CL-MO	HEAT	0.	55.	99.	23.	41.	12.	0.	-10.	99.	DISTILLA	89.	0	0.36	0.41	0.23

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28651 MW 4.40 PROCESS MILLIONS BTU/HR 510.0 PROCESS TEMP(F) 320. PRODUCT STYRENE-MONO HOURS PER YEAR 7900.

POWER TO HEAT RATIO 0.029

UTILITY FUEL COAL WASTE FUEL EQV BTU\*10\*\*6= 235. HOT WATER BTU\*10\*\*6= 0.

	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
0 ONOCGN N O C O G O N	235.	0.	0.	0.	0.	0.	600.	47.	600.	COAL-FGD	647.	0	0.	0.02	0.79
1 STM141 STM-TURB-1 POWR	235.	29.	90.	62.	15.	4.	527.	0.	619.	RESIDUAL	618.	10	0.07	0.02	0.83
1 STM141 STM-TURB-1 HEAT	235.	242.	746.	510.	124.	36.	0.	-341.	746.	RESIDUAL	405.	0	0.32	0.17	0.68
1 STM141 STM-TURB-1 POWR	235.	29.	90.	62.	15.	4.	527.	0.	618.	COAL-FGD	618.	10	0.07	0.02	0.83
1 STM141 STM-TURB-1 HEAT	235.	242.	746.	510.	124.	36.	0.	-341.	746.	COAL-FGD	405.	0	0.32	0.17	0.68
1 STM141 STM-TURB-1 POWR	235.	29.	90.	62.	15.	4.	527.	0.	618.	COAL-AFB	618.	10	0.07	0.02	0.83
1 STM141 STM-TURB-1 HEAT	235.	242.	746.	510.	124.	36.	0.	-341.	746.	COAL-AFB	405.	0	0.32	0.17	0.68
2 STM088 STM-TURB-8 POWR	235.	29.	113.	81.	15.	4.	504.	0.	619.	RESIDUAL	618.	10	0.07	0.02	0.83
2 STM088 STM-TURB-8 HEAT	235.	183.	711.	510.	94.	28.	0.	-247.	711.	RESIDUAL	464.	0	0.28	0.13	0.72
2 STM088 STM-TURB-8 POWR	235.	29.	113.	81.	15.	4.	504.	0.	618.	COAL-FGD	618.	10	0.07	0.02	0.83
2 STM088 STM-TURB-8 HEAT	235.	183.	711.	510.	94.	28.	0.	-247.	711.	COAL-FGD	464.	0	0.28	0.13	0.72
2 STM088 STM-TURB-8 POWR	235.	29.	113.	81.	15.	4.	504.	0.	618.	COAL-AFB	618.	10	0.07	0.02	0.83
2 STM088 STM-TURB-8 HEAT	235.	183.	711.	510.	94.	28.	0.	-247.	711.	COAL-AFB	464.	0	0.28	0.13	0.72
3 PFBSTM PFB-STMTB- POWR	235.	29.	65.	40.	15.	4.	553.	0.	618.	COAL-PFB	618.	10	0.07	0.02	0.83
3 PFBSTM PFB-STMTB- HEAT	235.	367.	831.	510.	191.	56.	0.	-531.	831.	COAL-PFB	280.	0	0.38	0.23	0.61
4 TISTMT TI-STMTB-1 POWR	235.	29.	54.	30.	15.	4.	564.	0.	618.	RESIDUAL	618.	10	0.07	0.02	0.83
4 TISTMT TI-STMTB-1 HEAT	235.	293.	549.	310.	153.	45.	235.	-430.	784.	RESIDUAL	354.	0	0.35	0.19	0.65
4 TISTMT TI-STMTB-1 POWR	235.	29.	54.	30.	15.	4.	564.	0.	618.	COAL	618.	10	0.07	0.02	0.83
4 TISTMT TI-STMTB-1 HEAT	235.	482.	903.	510.	251.	74.	0.	-738.	903.	COAL	165.	0	0.42	0.28	0.56
5 TIHRSG THERMIONIC POWR	235.	23.	107.	70.	15.	4.	517.	0.	624.	RESIDUAL	624.	0	0.06	0.02	0.82
5 TIHRSG THERMIONIC HEAT	235.	102.	470.	310.	66.	19.	2.5.	-160.	705.	RESIDUAL	545.	0	0.18	0.09	0.72
5 TIHRSG THERMIONIC POWR	235.	23.	107.	70.	15.	4.	517.	0.	624.	COAL	624.	0	0.06	0.02	0.82
5 TIHRSG THERMIONIC HEAT	235.	167.	772.	510.	109.	32.	0.	-293.	772.	COAL	480.	0	0.24	0.14	0.66
6 STIRL STIRLING-1 POWR	235.	21.	57.	27.	15.	4.	569.	0.	626.	DISTILLA	626.	0	0.05	0.02	0.81
6 STIRL STIRLING-1 HEAT	235.	245.	564.	310.	174.	51.	235.	-498.	900.	DISTILLA	402.	0	0.27	0.19	0.57

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28651 MW 4.40 PROCESS MILLIONS BTU/HR 510.0 PROCESS TEMP(F) 320. PRODUCT STYRENE-MONO HOURS PER YEAR 7900.

UTILITY FUEL COAL POWER TO HEAT RATIO 0.029  
WASTE FUEL EQV BTU\*10\*\*6= 235. HOT WATER BTU\*10\*\*6= 0.

			WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	ESR	POWER FACTR	HEAT FACTR
6 STIRL	STIRLING-1	POWR	235.	21.	57.	27.	15.	4.	569.	0.	626.	RESIDUAL	626.	0	0.05	0.02	0.81
6 STIRL	STIRLING-1	HEAT	235.	245.	664.	310.	174.	51.	235.	-498.	900.	RESIDUAL	402.	0	0.27	0.19	0.57
6 STIRL	STIRLING-1	POWR	235.	21.	57.	27.	15.	4.	569.	0.	626.	COAL	526.	0	0.05	0.02	0.81
6 STIRL	STIRLING-1	HEAT	235.	403.	1093.	510.	287.	84.	0.	-850.	1093.	COAL	244.	0	0.27	0.26	0.47
7 HEGT85	HELIUM-GT-	POWR	235.	10.	47.	9.	15.	4.	590.	0.	637.	COAL-AFB	637.	10	0.03	0.02	0.80
7 HEGT85	HELIUM-GT-	HEAT	235.	609.	2762.	510.	897.	260.	0.	-2724.	2762.	COAL-AFB	38.	0	0.19	0.32	0.18
8 HEGT60	HELIUM-GT-	POWR	235.	12.	58.	19.	15.	4.	577.	0.	635.	COAL-AFB	635.	10	0.03	0.02	0.80
8 HEGT60	HELIUM-GT-	HEAT	235.	306.	1540.	510.	399.	117.	0.	-1200.	1540.	COAL-AFB	341.	0	0.19	0.26	0.33
9 HEGT00	HELIUM-GT-	POWR	235.	12.	85.	43.	15.	4.	550.	0.	635.	COAL-AFB	635.	10	0.03	0.02	0.80
9 HEGT00	HELIUM-GT-	HEAT	235.	141.	1021.	510.	180.	53.	0.	-514.	1021.	COAL-AFB	506.	0	0.15	0.18	0.50
10 FCMCCL	FUEL-CL-MO	POWR	0.	25.	49.	23.	15.	4.	572.	0.	622.	COAL	622.	10	-0.51	0.02	0.82
10 FCMCCL	FUEL-CL-MO	HEAT	0.	546.	1075.	510.	327.	96.	0.	-975.	1075.	COAL	101.	10	0.22	0.30	0.47
11 FCSTCL	FUEL-CL-ST	POWR	0.	26.	38.	14.	15.	4.	583.	0.	621.	COAL	621.	10	-0.51	0.02	0.82
11 FCSTCL	FUEL-CL-ST	HEAT	0.	918.	1332.	510.	528.	155.	0.	-1604.	1332.	COAL	-271.	0	0.34	0.40	0.38
12 IGGTST	INT-GAS-GT	POWR	0.	21.	50.	21.	15.	4.	576.	0.	626.	COAL	626.	10	-0.52	0.02	0.81
12 IGGTST	INT-GAS-GT	HEAT	0.	521.	1242.	510.	372.	109.	0.	-1116.	1242.	COAL	126.	0	0.19	0.30	0.41
13 GTSOAR	GT-HRSG-10	POWR	235.	22.	52.	23.	15.	4.	573.	0.	625.	RESIDUAL	625.	10	0.05	0.02	0.82
13 GTSOAR	GT-HRSG-10	HEAT	235.	298.	709.	310.	206.	60.	235.	-596.	944.	RESIDUAL	349.	0	0.30	0.22	0.54
14 GTAC08	GT-HRSG-08	POWR	235.	25.	56.	29.	15.	4.	566.	0.	622.	RESIDUAL	622.	10	0.06	0.02	0.82
14 GTAC08	GT-HRSG-08	HEAT	235.	270.	605.	310.	163.	45.	235.	-483.	840.	RESIDUAL	377.	0	0.31	0.19	0.61
15 GTAC12	GT-HRSG-12	POWR	235.	25.	49.	23.	15.	4.	573.	0.	622.	RESIDUAL	622.	10	0.06	0.02	0.82
15 GTAC12	GT-HRSG-12	HEAT	235.	334.	664.	310.	203.	59.	235.	-586.	900.	RESIDUAL	313.	0	0.33	0.23	0.57
16 GTAC16	GT-HRSG-16	POWR	235.	24.	46.	20.	15.	4.	576.	0.	623.	RESIDUAL	623.	10	0.06	0.02	0.82
16 GTAC16	GT-HRSG-16	HEAT	235.	371.	707.	310.	228.	67.	235.	-667.	942.	RESIDUAL	276.	0	0.34	0.24	0.54
17 GTWC16	GT-HRSG-16	POWR	235.	22.	48.	19.	15.	4.	577.	0.	625.	RESIDUAL	625.	10	0.05	0.02	0.82
17 GTWC16	GT-HRSG-16	HEAT	235.	353.	767.	310.	242.	71.	235.	-708.	1002.	RESIDUAL	294.	0	0.32	0.24	0.51

HONEYWELL PAGE PRINTING SYSTEM- PI185-02

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28651 MW 4.40 PROCESS MILLIONS BTU/HR 510.0 PROCESS TEMP(F) 320. PRODUCT STYRENE-MONO HOURS PER YEAR 7900.

POWER TO HEAT RATIO 0.029

WASTE FUEL EQV BTU\*10\*\*6= 235. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
18 CC1626	GTST-16/26 POWR	235.	22.	39.	12.	15.	4.	586.	0.	625.	RESIDUAL	625.	10	0.05	0.02	0.82
18 CC1626	GTST-16/26 HEAT	235.	585.	1035.	310.	402.	118.	235.	-1209.	1271.	RESIDUAL	61.	0	0.36	0.32	0.40
19 CC1622	GTST-16/22 POWR	235.	23.	39.	13.	15.	4.	585.	0.	624.	RESIDUAL	624.	10	0.06	0.02	0.82
19 CC1622	GTST-16/22 HEAT	235.	553.	944.	310.	362.	106.	235.	-1085.	1179.	RESIDUAL	94.	0	0.37	0.31	0.43
20 CC1222	GTST-12/22 POWR	235.	23.	39.	13.	15.	4.	585.	0.	624.	RESIDUAL	624.	10	0.06	0.02	0.82
20 CC1222	GTST-12/22 HEAT	235.	556.	936.	310.	361.	106.	235.	-1081.	1172.	RESIDUAL	91.	0	0.37	0.31	0.44
21 CC0822	GTST-08/22 POWR	235.	25.	41.	16.	15.	4.	581.	0.	622.	RESIDUAL	622.	10	0.06	0.02	0.82
21 CC0822	GTST-08/22 HEAT	235.	477.	791.	310.	289.	85.	235.	-856.	1027.	RESIDUAL	170.	0	0.38	0.28	0.50
22 STIG15	STIG-15-16 POWR	235.	8.	39.	1.	15.	4.	599.	0.	639.	RESIDUAL	639.	10	0.02	0.02	0.80
22 STIG15	STIG-15-16 HEAT	235.	4910.	23846.	310.	9085.	2663.	235.	-28345.	24081.	RESIDUAL	-4263.	0	0.17	0.38	0.02
23 STIG10	STIG-10-16 POWR	235.	12.	42.	6.	15.	4.	593.	0.	635.	RESIDUAL	635.	10	0.03	0.02	0.80
23 STIG10	STIG-10-16 HEAT	235.	651.	2340.	310.	840.	246.	235.	-2579.	2575.	RESIDUAL	-4.	0	0.22	0.33	0.20
24 STIG15	STIG-15-16 POWR	235.	13.	45.	9.	15.	4.	589.	0.	634.	RESIDUAL	634.	10	0.03	0.02	0.80
24 STIG15	STIG-15-16 HEAT	235.	435.	1471.	310.	493.	144.	235.	-1494.	1706.	RESIDUAL	212.	0	0.23	0.29	0.30
25 DEADV3	DIESEL-ADV POWR	235.	17.	40.	9.	15.	4.	589.	0.	630.	RESIDUAL	630.	0	0.04	0.02	0.81
25 DEADV3	DIESEL-ADV HEAT	235.	585.	1381.	310.	512.	150.	235.	-1554.	1617.	RESIDUAL	62.	0	0.30	0.32	0.32
26 DEADV2	DIESEL-ADV POWR	235.	19.	40.	10.	15.	4.	588.	0.	628.	RESIDUAL	628.	1	0.05	0.02	0.81
26 DEADV2	DIESEL-ADV HEAT	235.	559.	1220.	310.	453.	133.	235.	-1368.	1456.	RESIDUAL	88.	1	0.31	0.31	0.35
27 DEADV1	DIESEL-ADV POWR	235.	25.	40.	16.	15.	4.	581.	0.	622.	RESIDUAL	622.	1	0.06	0.02	0.82
27 DEADV1	DIESEL-ADV HEAT	235.	491.	793.	310.	294.	86.	235.	-872.	1028.	RESIDUAL	156.	1	0.38	0.29	0.50
28 DEHTPM	ADV-DIESEL POWR	235.	25.	44.	19.	15.	4.	578.	0.	622.	RESIDUAL	622.	0	0.06	0.02	0.82
28 DEHTPM	ADV-DIESEL HEAT	235.	418.	719.	310.	247.	72.	235.	-725.	954.	RESIDUAL	229.	0	0.37	0.26	0.53
29 DESOA3	DIESEL-SOA POWR	235.	15.	42.	8.	15.	4.	591.	0.	632.	DISTILLA	632.	0	0.04	0.02	0.81
29 DESOA3	DIESEL-SOA HEAT	235.	573.	1628.	310.	588.	172.	235.	-1789.	1863.	DISTILLA	74.	0	0.26	0.32	0.27
29 DESOA3	DIESEL-SOA POWR	235.	15.	42.	8.	15.	4.	591.	0.	632.	RESIDUAL	632.	0	0.04	0.02	0.81
29 DESOA3	DIESEL-SOA HEAT	235.	573.	1628.	310.	588.	172.	235.	-1789.	1863.	RESIDUAL	74.	0	0.26	0.32	0.27



I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28651 MW 4.40 PROCESS MILLIONS BTU/HR 510.0 PROCESS TEMP(F) 320. PRODUCT STYRENE-MONO HOURS PER YEAR 7900.

POWER TO HEAT RATIO 0.029

WASTE FUEL EQV BTU\*10\*\*6= 235. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
30 DES0A2 DIESEL-S0A POWR		235.	16.	42.	9.	15.	4.	589.	0.	631.	DISTILLA	631.	1	0.04	0.02	0.81
30 DES0A2 DIESEL-S0A HEAT		235.	545.	1409.	310.	509.	149.	235.	-1543.	1644.	DISTILLA	102.	1	0.28	0.31	0.31
30 DES0A2 DIESEL-S0A POWR		235.	16.	42.	9.	15.	4.	589.	0.	631.	RESIDUAL	631.	1	0.04	0.02	0.81
30 DES0A2 DIESEL-S0A HEAT		235.	545.	1409.	310.	509.	149.	235.	-1543.	1644.	RESIDUAL	102.	1	0.28	0.31	0.31
31 DES0A1 DIESEL-S0A POWR		235.	25.	42.	17.	15.	4.	580.	0.	622.	DISTILLA	622.	1	0.06	0.02	0.82
31 DES0A1 DIESEL-S0A HEAT		235.	464.	773.	310.	279.	82.	235.	-825.	1008.	DISTILLA	183.	1	0.37	0.28	0.51
31 DES0A1 DIESEL-S0A POWR		235.	25.	42.	17.	15.	4.	580.	0.	622.	RESIDUAL	622.	1	0.06	0.02	0.82
31 DES0A1 DIESEL-S0A HEAT		235.	464.	773.	310.	279.	82.	235.	-825.	1008.	RESIDUAL	183.	1	0.37	0.28	0.51
32 GTS0AD GT-HRSG-10 POWR		235.	24.	51.	24.	15.	4.	572.	0.	623.	DISTILLA	623.	10	0.06	0.02	0.82
32 GTS0AD GT-HRSG-10 HEAT		235.	306.	666.	310.	194.	57.	235.	-560.	901.	DISTILLA	340.	0	0.32	0.22	0.57
33 GTRA08 GT-85RE-09 POWR		235.	22.	42.	15.	15.	4.	582.	0.	625.	DISTILLA	625.	10	0.05	0.02	0.82
33 GTRA08 GT-85RE-08 HEAT		235.	466.	875.	310.	312.	92.	235.	-929.	1110.	DISTILLA	181.	0	0.35	0.28	0.46
34 GTRA12 GT-85RE-12 POWR		235.	23.	42.	15.	15.	4.	582.	0.	624.	DISTILLA	624.	10	0.06	0.02	0.82
34 GTRA12 GT-85RE-12 HEAT		235.	467.	857.	310.	307.	90.	235.	-912.	1093.	DISTILLA	180.	0	0.35	0.28	0.47
35 GTRA16 GT-85RE-16 POWR		235.	23.	43.	16.	15.	4.	581.	0.	624.	DISTILLA	624.	10	0.06	0.02	0.82
35 GTRA16 GT-85RE-16 HEAT		235.	439.	825.	310.	288.	84.	235.	-853.	1060.	DISTILLA	207.	0	0.35	0.27	0.48
36 GTR208 GT-60RE-09 POWR		235.	23.	47.	19.	15.	4.	577.	0.	624.	DISTILLA	624.	10	0.06	0.02	0.82
36 GTR208 GT-60RE-08 HEAT		235.	365.	751.	310.	240.	70.	235.	-704.	986.	DISTILLA	282.	0	0.33	0.24	0.52
37 GTR212 GT-60RE-12 POWR		235.	23.	45.	18.	15.	4.	579.	0.	624.	DISTILLA	624.	10	0.06	0.02	0.82
37 GTR212 GT-60RE-12 HEAT		235.	389.	781.	310.	258.	76.	235.	-758.	1016.	DISTILLA	258.	0	0.33	0.25	0.50
38 GTR216 GT-60RE-16 POWR		235.	23.	45.	18.	15.	4.	579.	0.	624.	DISTILLA	624.	10	0.06	0.02	0.82
38 GTR216 GT-60RE-16 HEAT		235.	406.	783.	310.	264.	77.	235.	-778.	1018.	DISTILLA	241.	0	0.34	0.26	0.50
39 GTRW08 GT-85RE-08 POWR		235.	19.	43.	12.	15.	4.	585.	0.	628.	DISTILLA	628.	10	0.05	0.02	0.81
39 GTRW08 GT-85RE-08 HEAT		235.	468.	1066.	310.	374.	110.	235.	-1122.	1301.	DISTILLA	179.	0	0.31	0.29	0.39
40 GTRW12 GT-85RE-12 POWR		235.	20.	41.	12.	15.	4.	586.	0.	627.	DISTILLA	627.	10	0.05	0.02	0.81
40 GTRW12 GT-85RE-12 HEAT		235.	509.	1052.	310.	383.	112.	235.	-1150.	1287.	DISTILLA	138.	0	0.33	0.30	0.40

HONEYWELL PAGE PRINTING SYSTEM- P1185-02

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28651 MW 4.40 PROCESS MILLIONS BTU/HR 510.0 PROCESS TEMP(F) 320. PRODUCT STYRENE-MONO HOURS PER YEAR 7900.

POWER TO HEAT RATIO 0.029

WASTE FUEL EQV BTU\*10\*\*6= 235. HOT WATER BTU\*10\*\*6= 0.

	UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
41	GTRW16	GT-85RE-16	POWR	235.	20.	42.	13.	15.	4.	585.	0.	627.	DISTILLA	627.	10	0.05	0.02	0.81
41	GTRW16	GT-85RE-16	HEAT	235.	480.	1000.	310.	357.	105.	235.	-1069.	1235.	DISTILLA	167.	0	0.32	0.29	0.41
42	GTR308	GT-60RE-08	POWR	235.	18.	48.	16.	15.	4.	581.	0.	629.	DISTILLA	629.	10	0.04	0.02	0.81
42	GTR308	GT-60RE-08	HEAT	235.	336.	921.	310.	285.	84.	235.	-845.	1156.	DISTILLA	311.	0	0.27	0.25	0.44
43	GTR312	GT-60RE-12	POWR	235.	20.	44.	15.	15.	4.	583.	0.	626.	DISTILLA	626.	10	0.05	0.02	0.81
43	GTR312	GT-60RE-12	HEAT	235.	428.	918.	310.	314.	92.	235.	-935.	1154.	DISTILLA	219.	0	0.32	0.27	0.44
44	GTR316	GT-60RE-16	POWR	235.	20.	44.	15.	15.	4.	582.	0.	627.	DISTILLA	627.	10	0.05	0.02	0.81
44	GTR316	GT-60RE-16	HEAT	235.	419.	913.	310.	309.	91.	235.	-920.	1148.	DISTILLA	228.	0	0.31	0.27	0.44
45	FCPADS	FUEL-CL-PH	POWR	235.	15.	40.	7.	15.	4.	592.	0.	632.	DISTILLA	632.	0	0.04	0.02	0.81
45	FCPADS	FUEL-CL-PH	HEAT	235.	707.	1824.	310.	693.	203.	235.	-2119.	2059.	DISTILLA	-60.	0	0.28	0.34	0.25
46	FCMCDS	FUEL-CL-MO	POWR	235.	20.	36.	8.	15.	4.	590.	0.	626.	DISTILLA	626.	0	0.05	0.02	0.81
46	FCMCDS	FUEL-CL-MO	HEAT	235.	747.	1330.	310.	548.	161.	235.	-1666.	1566.	DISTILLA	-100.	0	0.36	0.35	0.33

ORIGINAL PAGE IS  
OF POOR QUALITY

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28652 MW 0.60 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT CUMENE-BENZE HOURS PER YEAR 8400.

UTILITY FUEL		COAL		POWER TO HEAT RATIO *****					WASTE FUEL EQV BTU*10**6=		HOT WATER BTU*10**6=							
				WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
0	ONOCGN	N	O	0.	0.	0.	0.	0.	0.	0.	6.	0.	0.	6.	0	0.	0.32	0.
1	STM141	STM-TURB-1	POWR	0.	0.	6.	3.	2.	1.	-4.	0.	6.	0.	6.	11	0.04	0.33	0.
1	STM141	STM-TURB-1	HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0.	0.	6.	111	0.	0.	0.
1	STM141	STM-TURB-1	POWR	0.	0.	6.	3.	2.	1.	-4.	0.	6.	0.	6.	11	0.04	0.33	0.
1	STM141	STM-TURB-1	HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0.	0.	6.	111	0.	0.	0.
1	STM141	STM-TURB-1	POWR	0.	0.	6.	3.	2.	1.	-4.	0.	6.	0.	6.	11	0.04	0.33	0.
1	STM141	STM-TURB-1	HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0.	0.	6.	111	0.	0.	0.
2	STM088	STM-TURB-8	POWR	0.	-0.	7.	4.	2.	1.	-4.	0.	7.	0.	7.	11	-0.06	0.30	0.
2	STM088	STM-TURB-8	HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0.	0.	6.	111	0.	0.	0.
2	STM088	STM-TURB-8	POWR	0.	-0.	7.	4.	2.	1.	-4.	0.	7.	0.	7.	11	-0.06	0.30	0.
2	STM088	STM-TURB-8	HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0.	0.	6.	111	0.	0.	0.
2	STM088	STM-TURB-8	POWR	0.	-0.	7.	4.	2.	1.	-4.	0.	7.	0.	7.	11	-0.06	0.30	0.
2	STM088	STM-TURB-8	HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0.	0.	6.	111	0.	0.	0.
3	PFBSTM	PFB-STMTB-	POWR	0.	1.	5.	3.	2.	1.	-3.	0.	5.	0.	5.	11	0.17	0.38	0.
3	PFBSTM	PFB-STMTB-	HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0.	0.	6.	111	0.	0.	0.
4	TISTMT	TI-STMTB-1	POWR	0.	1.	5.	2.	2.	1.	-2.	0.	5.	0.	5.	11	0.23	0.41	0.
4	TISTMT	TI-STMTB-1	HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0.	0.	6.	111	0.	0.	0.
4	TISTMT	TI-STMTB-1	POWR	0.	1.	5.	2.	2.	1.	-2.	0.	5.	0.	5.	11	0.23	0.41	0.
4	TISTMT	TI-STMTB-1	HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0.	0.	6.	111	0.	0.	0.
5	TIHRSG	THERMIONIC	POWR	0.	-8.	15.	10.	2.	1.	-12.	0.	15.	0.	15.	11	-1.27	0.14	0.
5	TIHRSG	THERMIONIC	HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0.	0.	6.	111	0.	0.	0.
5	TIHRSG	THERMIONIC	POWR	0.	-8.	15.	10.	2.	1.	-12.	0.	15.	0.	15.	11	-1.27	0.14	0.
5	TIHRSG	THERMIONIC	HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0.	0.	6.	111	0.	0.	0.
6	STIRL	STIRLING-1	POWR	0.	-0.	7.	3.	2.	1.	-3.	0.	7.	0.	7.	1	-0.04	0.31	0.
6	STIRL	STIRLING-1	HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0.	0.	6.	111	0.	0.	0.

HONEYWELL PAGE PRINTING SYSTEM-PL1105-02

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 147

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28652 MW 0.60 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT CUMENE-BENZE HOURS PER YEAR 8400.

UTILITY FUEL		COAL		POWER TO HEAT RATIO *****							WASTE FUEL EQV BTU*10**6=		HOT WATER BTU*10**6=		0.	
		WASTE FUEL USED	FUEL SAVED= NO-NET	COGEN FUEL USED	COGEN HEAT	COGEN POWER	COGEN ELECT	AUX BOILR	UTILIT FUEL USED	TOTAL FUEL SITE	NET= TOTAL+ UTILIT	FAIL	FESR	POWER FACTR	HEAT FACTR	
		10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR	MW	10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR					
6	STIRL STIRLING-1 POWR	0.	-0.	7.	3.	2.	1.	-3.	0.	7. RESIDUAL	7.	1	-0.04	0.31	0.	
6	STIRL STIRLING-1 HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0. RESIDUAL	6.	111	0.	0.	0.	
6	STIRL STIRLING-1 POWR	0.	-0.	7.	3.	2.	1.	-3.	0.	7. COAL	7.	1	-0.04	0.31	0.	
6	STIRL STIRLING-1 HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0. COAL	6.	111	0.	0.	0.	
7	HEGT85 HELIUM-GT- POWR	0.	0.	6.	3.	2.	1.	-3.	0.	6. COAL-AFB	5.	11	0.00	0.32	0.	
7	HEGT85 HELIUM-GT- HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0. COAL-AFB	6.	111	0.	0.	0.	
8	HEGT60 HELIUM-GT- POWR	0.	-2.	8.	3.	2.	1.	-4.	0.	8. COAL-AFB	8.	11	-0.24	0.26	0.	
8	HEGT60 HELIUM-GT- HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0. COAL-AFB	6.	111	0.	0.	0.	
9	HEGT00 HELIUM-GT- POWR	0.	-5.	12.	7.	2.	1.	-8.	0.	12. COAL-AFB	12.	11	-0.02	0.18	0.	
9	HEGT00 HELIUM-GT- HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0. COAL-AFB	5.	111	0.	0.	0.	
10	FCMCL FUEL-CL-MO POWR	0.	-0.	7.	3.	2.	1.	-4.	0.	7. COAL	7.	11	-0.05	0.30	0.	
10	FCMCL FUEL-CL-MO HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0. COAL	6.	111	0.	0.	0.	
11	FCSTCL FUEL-CL-ST POWR	0.	2.	4.	1.	2.	1.	-1.	0.	4. COAL	4.	11	0.35	0.49	0.	
11	FCSTCL FUEL-CL-ST HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0. COAL	6.	111	0.	0.	0.	
12	IGGTST INT-GAS-GT POWR	0.	1.	5.	2.	2.	1.	-2.	0.	5. COAL	5.	11	0.20	0.40	0.	
12	IGGTST INT-GAS-GT HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0. COAL	6.	111	0.	0.	0.	
13	GTS0AR GT-HRSG-10 POWR	0.	-1.	7.	3.	2.	1.	-4.	0.	7. RESIDUAL	7.	11	-0.10	0.29	0.	
13	GTS0AR GT-HRSG-10 HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0. RESIDUAL	6.	111	0.	0.	0.	
14	GTAC08 GT-HRSG-08 POWR	0.	-1.	8.	4.	2.	1.	-4.	0.	8. RESIDUAL	8.	11	-0.19	0.27	0.	
14	GTAC08 GT-HRSG-08 HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0. RESIDUAL	6.	111	0.	0.	0.	
15	GTAC12 GT-HRSG-12 POWR	0.	-0.	7.	3.	2.	1.	-4.	0.	7. RESIDUAL	7.	11	-0.05	0.31	0.	
15	GTAC12 GT-HRSG-12 HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0. RESIDUAL	6.	111	0.	0.	0.	
16	GTAC16 GT-HRSG-16 POWR	0.	0.	6.	3.	2.	1.	-4.	0.	6. RESIDUAL	6.	11	0.01	0.32	0.	
16	GTAC16 GT-HRSG-16 HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0. RESIDUAL	6.	111	0.	0.	0.	
17	GTWC16 GT-HRSG-16 POWR	0.	-0.	6.	3.	2.	1.	-3.	0.	6. RESIDUAL	6.	11	-0.02	0.32	0.	
17	GTWC16 GT-HRSG-16 HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0. RESIDUAL	5.	111	0.	0.	0.	

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28652 MW 0.60 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT CUMENE-BENZE HOURS PER YEAR 8400.

		POWER TO HEAT RATIO *****															
UTILITY FUEL		COAL		WASTE FUEL EQV BTU*10**6= 0.										HOT WATER BTU*10**6= 0.			
		WASTE FUEL USED 10**6 BTU/HR	SAVED= FUEL NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
18	CC1626 GTST-16/26 POWR	0.	2.	4.	1.	2.	1.	-1.	0.	4.	RESIDUAL	4.	11	0.31	0.46	0.	
18	CC1626 GTST-16/26 HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0.	RESIDUAL	6.	111	0.	0.	0.	
19	CC1622 GTST-16/22 POWR	0.	2.	4.	1.	2.	1.	-1.	0.	4.	RESIDUAL	4.	11	0.31	0.46	0.	
19	CC1622 GTST-16/22 HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0.	RESIDUAL	6.	111	0.	0.	0.	
20	CC1222 GTST-12/22 POWR	0.	2.	4.	1.	2.	1.	-1.	0.	4.	RESIDUAL	4.	11	0.31	0.47	0.	
20	CC1222 GTST-12/22 HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0.	RESIDUAL	6.	111	0.	0.	0.	
21	CC0822 GTST-08/22 POWR	0.	2.	4.	1.	2.	1.	-2.	0.	4.	RESIDUAL	4.	11	0.31	0.46	0.	
21	CC0822 GTST-08/22 HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0.	RESIDUAL	6.	111	0.	0.	0.	
22	STIG15 STIG-15-16 POWR	0.	1.	5.	0.	2.	1.	-0.	0.	5.	RESIDUAL	5.	11	0.16	0.38	0.	
22	STIG15 STIG-15-16 HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0.	RESIDUAL	6.	111	0.	0.	0.	
23	STIG10 STIG-10-16 POWR	0.	1.	6.	1.	2.	1.	-1.	0.	6.	RESIDUAL	6.	11	0.11	0.36	0.	
23	STIG10 STIG-10-16 HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0.	RESIDUAL	6.	111	0.	0.	0.	
24	STIG1S STIG-1S-16 POWR	0.	0.	6.	1.	2.	1.	-2.	0.	6.	RESIDUAL	6.	11	0.05	0.34	0.	
24	STIG1S STIG-1S-16 HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0.	RESIDUAL	6.	111	0.	0.	0.	
25	DEADV3 DIESEL-ADV POWR	0.	1.	6.	2.	2.	1.	-2.	0.	6.	RESIDUAL	6.	11	0.14	0.37	0.	
25	DEADV3 DIESEL-ADV HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0.	RESIDUAL	6.	111	0.	0.	0.	
26	DEADV2 DIESEL-ADV POWR	0.	1.	6.	1.	2.	1.	-2.	0.	6.	RESIDUAL	6.	11	0.14	0.37	0.	
26	DEADV2 DIESEL-ADV HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0.	RESIDUAL	6.	111	0.	0.	0.	
27	DEADV1 DIESEL-ADV POWR	0.	1.	6.	2.	2.	1.	-3.	0.	6.	RESIDUAL	6.	11	0.14	0.37	0.	
27	DEADV1 DIESEL-ADV HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0.	RESIDUAL	6.	111	0.	0.	0.	
28	DEHTPM ADV-DIESEL POWR	0.	1.	5.	3.	2.	1.	-3.	0.	5.	RESIDUAL	5.	11	0.20	0.40	0.	
28	DEHTPM ADV-DIESEL HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0.	RESIDUAL	6.	111	0.	0.	0.	
29	DES0A3 DIESEL-S0A POWR	0.	1.	6.	2.	2.	1.	-2.	0.	6.	DISTILLA	6.	1	0.11	0.36	0.	
29	DES0A3 DIESEL-S0A HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0.	DISTILLA	6.	111	0.	0.	0.	
29	DES0A3 DIESEL-S0A POWR	0.	1.	6.	2.	2.	1.	-2.	0.	6.	RESIDUAL	6.	1	0.11	0.36	0.	
29	DES0A3 DIESEL-S0A HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0.	RESIDUAL	6.	111	0.	0.	0.	

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28652 MW 0.60 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT CUMENE-BENZE HOURS PER YEAR 8400.

UTILITY FUEL	COAL	POWER TO HEAT RATIO *****										NET=	FAIL	FESR	POWER FACTR	HEAT FACTR
		WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED					
30 DES0A2 DIESEL-S0A POWR		0.	1.	6.	1.	2.	1.	-1.	0.	6.DISTILLA	6.	1	0.11	0.36	0.	
30 DES0A2 DIESEL-S0A HEAT		0.	0.	0.	0.	0.	0.	0.	6.	0.DISTILLA	6.	111	0.	0.	0.	
30 DES0A2 DIESEL-S0A POWR		0.	1.	6.	1.	2.	1.	-1.	0.	6.RESIDUAL	6.	1	0.11	0.36	0.	
30 DES0A2 DIESEL-S0A HEAT		0.	0.	0.	0.	0.	0.	0.	6.	0.RESIDUAL	6.	111	0.	0.	0.	
31 DES0A1 DIESEL-S0A POWR		0.	1.	6.	2.	2.	1.	-3.	0.	6.DISTILLA	6.	1	0.11	0.36	0.	
31 DES0A1 DIESEL-S0A HEAT		0.	0.	0.	0.	0.	0.	0.	6.	0.DISTILLA	6.	111	0.	0.	0.	
31 DES0A1 DIESEL-S0A POWR		0.	1.	6.	2.	2.	1.	-3.	0.	6.RESIDUAL	6.	1	0.11	0.36	0.	
31 DES0A1 DIESEL-S0A HEAT		0.	0.	0.	0.	0.	0.	0.	6.	0.RESIDUAL	6.	111	0.	0.	0.	
32 GTS0AD GT-HRSG-10 POWR		0.	-1.	7.	4.	2.	1.	-4.	0.	7.DISTILLA	7.	11	-0.10	0.29	0.	
32 GTS0AD GT-HRSG-10 HEAT		0.	0.	0.	0.	0.	0.	0.	6.	0.DISTILLA	6.	111	0.	0.	0.	
33 GTRA08 GT-85RE-08 POWR		0.	1.	6.	2.	2.	1.	-3.	0.	6.DISTILLA	6.	11	0.10	0.36	0.	
33 GTRA08 GT-85RE-08 HEAT		0.	0.	0.	0.	0.	0.	0.	6.	0.DISTILLA	6.	111	0.	0.	0.	
34 GTRA12 GT-85RE-12 POWR		0.	1.	6.	2.	2.	1.	-3.	0.	6.DISTILLA	6.	11	0.11	0.36	0.	
34 GTRA12 GT-85RE-12 HEAT		0.	0.	0.	0.	0.	0.	0.	6.	0.DISTILLA	6.	111	0.	0.	0.	
35 GTRA16 GT-85RE-16 POWR		0.	1.	6.	2.	2.	1.	-3.	0.	6.DISTILLA	6.	11	0.06	0.35	0.	
35 GTRA16 GT-85RE-16 HEAT		0.	0.	0.	0.	0.	0.	0.	6.	0.DISTILLA	6.	111	0.	0.	0.	
36 GTR208 GT-60RE-08 POWR		0.	0.	6.	3.	2.	1.	-4.	0.	6.DISTILLA	6.	11	0.	0.32	0.	
36 GTR208 GT-60RE-08 HEAT		0.	0.	0.	0.	0.	0.	0.	6.	0.DISTILLA	6.	111	0.	0.	0.	
37 GTR212 GT-60RE-12 POWR		0.	0.	6.	3.	2.	1.	-3.	0.	6.DISTILLA	6.	11	0.03	0.33	0.	
37 GTR212 GT-60RE-12 HEAT		0.	0.	0.	0.	0.	0.	0.	6.	0.DISTILLA	6.	111	0.	0.	0.	
38 GTR216 GT-60RE-16 POWR		0.	0.	6.	3.	2.	1.	-3.	0.	6.DISTILLA	6.	11	0.05	0.34	0.	
38 GTR216 GT-60RE-16 HEAT		0.	0.	0.	0.	0.	0.	0.	6.	0.DISTILLA	6.	111	0.	0.	0.	
39 GTRW08 GT-85RE-08 POWR		0.	1.	6.	2.	2.	1.	-2.	0.	6.DISTILLA	6.	11	0.09	0.35	0.	
39 GTRW08 GT-85RE-08 HEAT		0.	0.	0.	0.	0.	0.	0.	6.	0.DISTILLA	6.	111	0.	0.	0.	
40 GTRW12 GT-85RE-12 POWR		0.	1.	6.	2.	2.	1.	-2.	0.	6.DISTILLA	6.	11	0.12	0.36	0.	
40 GTRW12 GT-85RE-12 HEAT		0.	0.	0.	0.	0.	0.	0.	6.	0.DISTILLA	6.	111	0.	0.	0.	

HONEYWELL PAGE PRINTING SYSTEM-PI188-02

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28652 MW 0.60 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT CUMENE-BENZE HOURS PER YEAR 8400.

POWER TO HEAT RATIO \*\*\*\*\*

UTILITY FUEL COAL

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41 GTRW16 GT-85RE-16 POWR	0.	1.	6.	2.	2.	1.	-2.	0.	6.DISTILLA		6.	11	0.10	0.36	0.
41 GTRW16 GT-85RE-16 HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0.DISTILLA		6.	111	0.	0.	0.
42 GTR308 GT-60RE-08 POWR	0.	-0.	7.	3.	2.	1.	-3.	0.	7.DISTILLA		7.	11	-0.03	0.31	0.
42 GTR308 GT-60RE-08 HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0.DISTILLA		6.	111	0.	0.	0.
43 GTR312 GT-60RE-12 POWR	0.	0.	6.	2.	2.	1.	-3.	0.	6.DISTILLA		6.	11	0.06	0.34	0.
43 GTR312 GT-60RE-12 HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0.DISTILLA		6.	111	0.	0.	0.
44 GTR316 GT-60RE-16 POWR	0.	0.	6.	2.	2.	1.	-3.	0.	6.DISTILLA		6.	11	0.06	0.34	0.
44 GTR316 GT-60RE-16 HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0.DISTILLA		6.	111	0.	0.	0.
45 FCPADS FUEL-CL-PH POWR	0.	1.	5.	1.	2.	1.	-1.	0.	5.DISTILLA		5.	11	0.16	0.38	0.
45 FCPADS FUEL-CL-PH HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0.DISTILLA		6.	111	0.	0.	0.
46 FCMCDS FUEL-CL-MO POWR	0.	1.	5.	1.	2.	1.	-1.	0.	5.DISTILLA		5.	11	0.22	0.41	0.
46 FCMCDS FUEL-CL-MO HEAT	0.	0.	0.	0.	0.	0.	0.	6.	0.DISTILLA		6.	111	0.	0.	0.

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28653 MW 6.00 PROCESS MILLIONS BTU/HR 300.0 PROCESS TEMP(F) 489. PRODUCT PHENOL-ACETO HOURS PER YEAR 8200.

POWER TO HEAT RATIO 0.068

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
0 ONOCGN N O C O G O N		0.	0.	0.	0.	0.	0.	353.	64.	353.	COAL-FGD	417.	0	0.	0.05	0.72
1 STM141 STM-TURB-1 POWR		0.	40.	183.	135.	20.	6.	194.	0.	377.	RESIDUAL	377.	10	0.10	0.05	0.80
1 STM141 STM-TURB-1 HEAT		0.	89.	407.	300.	46.	13.	0.	-78.	407.	RESIDUAL	328.	0	0.18	0.11	0.74
1 STM141 STM-TURB-1 POWR		0.	40.	183.	135.	20.	6.	194.	0.	377.	COAL-FGD	377.	10	0.10	0.05	0.80
1 STM141 STM-TURB-1 HEAT		0.	89.	407.	300.	46.	13.	0.	-78.	407.	COAL-FGD	328.	0	0.16	0.11	0.74
1 STM141 STM-TURB-1 POWR		0.	40.	183.	135.	20.	6.	194.	0.	377.	COAL-AFB	377.	10	0.10	0.05	0.80
1 STM141 STM-TURB-1 HEAT		0.	89.	407.	300.	46.	13.	0.	-78.	407.	COAL-AFB	328.	0	0.18	0.11	0.74
2 STM088 STM-TURB-8 POWR		0.	40.	267.	207.	20.	6.	110.	0.	377.	RESIDUAL	377.	0	0.10	0.05	0.80
2 STM088 STM-TURB-8 HEAT		0.	58.	388.	300.	30.	9.	0.	-29.	388.	RESIDUAL	359.	0	0.13	0.08	0.77
2 STM088 STM-TURB-8 POWR		0.	40.	267.	207.	20.	6.	110.	0.	377.	COAL-FGD	377.	0	0.10	0.05	0.80
2 STM088 STM-TURB-8 HEAT		0.	58.	388.	300.	30.	9.	0.	-29.	388.	COAL-FGD	359.	0	0.13	0.08	0.77
2 STM088 STM-TURB-8 POWR		0.	40.	267.	207.	20.	6.	110.	0.	377.	COAL-AFB	377.	0	0.10	0.05	0.80
2 STM088 STM-TURB-8 HEAT		0.	58.	388.	300.	30.	9.	0.	-29.	388.	COAL-AFB	359.	0	0.13	0.08	0.77
3 PFBSTM PFB-STMTB- POWR		0.	39.	112.	74.	20.	6.	266.	0.	378.	COAL-PFB	378.	10	0.09	0.05	0.79
3 PFBSTM PFB-STMTB- HEAT		0.	157.	456.	300.	83.	24.	0.	-196.	456.	COAL-PFB	260.	0	0.26	0.18	0.66
4 TISTMT TI-STMTB-1 POWR		0.	39.	88.	54.	20.	6.	290.	0.	378.	RESIDUAL	378.	10	0.09	0.05	0.79
4 TISTMT TI-STMTB-1 HEAT		0.	219.	492.	300.	114.	34.	0.	-294.	492.	RESIDUAL	198.	0	0.31	0.23	0.61
4 TISTMT TI-STMTB-1 POWR		0.	39.	88.	54.	20.	6.	290.	0.	378.	COAL	378.	10	0.09	0.05	0.79
4 TISTMT TI-STMTB-1 HEAT		0.	219.	492.	300.	114.	34.	0.	-294.	492.	COAL	198.	0	0.31	0.23	0.61
5 TIHRSG THERMIONIC POWR		0.	21.	146.	87.	20.	6.	251.	0.	396.	RESIDUAL	396.	0	0.05	0.05	0.76
5 TIHRSG THERMIONIC HEAT		0.	72.	502.	300.	71.	21.	0.	-137.	502.	RESIDUAL	345.	0	0.13	0.14	0.60
5 TIHRSG THERMIONIC POWR		0.	21.	146.	87.	20.	6.	251.	0.	396.	COAL	396.	0	0.05	0.05	0.76
5 TIHRSG THERMIONIC HEAT		0.	72.	502.	300.	71.	21.	0.	-137.	502.	COAL	345.	0	0.13	0.14	0.60
6 STIRL STIRLING-1 POWR		0.	27.	93.	48.	20.	6.	297.	0.	390.	DISTILLA	390.	0	0.06	0.05	0.77
6 STIRL STIRLING-1 HEAT		0.	167.	589.	300.	129.	38.	0.	-339.	589.	DISTILLA	250.	0	0.22	0.22	0.51

HONEYWELL PAGE PRINTING SYSTEM - P1188-02



I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 20653 MW 6.00 PROCESS MILLIONS BTU/HR 300.0 PROCESS TEMP(F) 489. PRODUCT PHENOL-ACETO HOURS PER YEAR 8200.

		POWER TO HEAT RATIO 0.068														
UTILITY FUEL		WASTE FUEL EQV BTU*10**6= 0.											HOT WATER BTU*10**6= 0.			
	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED-NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET+ TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
6 STIRL	STIRLING-1 POWR	0.	27.	93.	48.	20.	6.	297.	0.	390.	RESIDUAL	390.	0	0.06	0.05	0.77
6 STIRL	STIRLING-1 HEAT	0.	167.	589.	300.	129.	38.	0.	-339.	589.	RESIDUAL	250.	0	0.22	0.22	0.51
6 STIRL	STIRLING-1 POWR	0.	27.	93.	48.	20.	6.	297.	0.	390.	COAL	390.	0	0.06	0.05	0.77
6 STIRL	STIRLING-1 HEAT	0.	167.	589.	300.	129.	38.	0.	-339.	589.	COAL	250.	0	0.22	0.22	0.51
7 HEGT85	HELIUM-GT- POWR	0.	-7.	64.	-6.	20.	6.	360.	0.	424.	COAL-AFB	424.	11	-0.02	0.05	0.71
7 HEGT85	HELIUM-GT- HEAT	-3167.	343.	-3167.	300.	-1016.	-298.	0.	3240.	-3167.	COAL-AFB	74.	11	-6.77	*****	4.06
8 HEGT60	HELIUM-GT- POWR	0.	-1.	79.	12.	20.	6.	339.	0.	418.	COAL-AFB	418.	10	-0.00	0.05	0.72
8 HEGT60	HELIUM-GT- HEAT	0.	-28.	1999.	300.	518.	152.	0.	-1554.	1999.	COAL-AFB	445.	0	-0.01	0.26	0.15
9 HEGT00	HELIUM-GT- POWR	0.	11.	116.	54.	20.	6.	290.	0.	406.	COAL-AFB	406.	10	0.03	0.05	0.74
9 HEGT00	HELIUM-GT- HEAT	0.	61.	648.	300.	114.	33.	0.	-292.	648.	COAL-AFB	356.	10	0.09	0.18	0.46
10 FCMCCL	FUEL-CL-MO POWR	0.	34.	67.	32.	20.	6.	316.	0.	383.	COAL	383.	10	0.08	0.05	0.78
10 FCMCCL	FUEL-CL-MO HEAT	0.	321.	638.	300.	134.	57.	0.	-542.	638.	COAL	96.	10	0.33	0.30	0.47
11 FCSTCL	FUEL-CL-ST POWR	0.	35.	56.	23.	20.	6.	326.	0.	382.	COAL	382.	10	0.08	0.05	0.79
11 FCSTCL	FUEL-CL-ST HEAT	0.	458.	727.	300.	266.	78.	0.	-768.	727.	COAL	-42.	10	0.39	0.27	0.41
12 IGGTST	INT-GAS-GT POWR	0.	27.	77.	34.	20.	6.	313.	0.	390.	COAL	390.	10	0.07	0.05	0.77
12 IGGTST	INT-GAS-GT HEAT	0.	241.	677.	300.	181.	53.	0.	-501.	677.	COAL	176.	10	0.26	0.27	0.44
13 GTSOAR	GT-HRSG-10 POWR	0.	25.	71.	27.	20.	6.	321.	0.	392.	RESIDUAL	392.	10	0.06	0.05	0.77
13 GTSOAR	GT-HRSG-10 HEAT	0.	279.	784.	300.	227.	67.	0.	-647.	784.	RESIDUAL	137.	0	0.26	0.29	0.38
14 GTAC08	GT-HRSG-08 POWR	0.	34.	76.	39.	20.	6.	307.	0.	383.	RESIDUAL	383.	10	0.08	0.05	0.78
14 GTAC08	GT-HRSG-08 HEAT	0.	262.	582.	300.	157.	46.	0.	-427.	582.	RESIDUAL	155.	0	0.31	0.27	0.52
15 GTAC12	GT-HRSG-12 POWR	0.	33.	67.	31.	20.	6.	316.	0.	383.	RESIDUAL	383.	10	0.08	0.05	0.78
15 GTAC12	GT-HRSG-12 HEAT	0.	323.	647.	300.	197.	58.	0.	-553.	647.	RESIDUAL	94.	0	0.33	0.31	0.46
16 GTAC16	GT-HRSG-16 POWR	0.	32.	63.	27.	20.	6.	322.	0.	385.	RESIDUAL	385.	10	0.08	0.05	0.78
16 GTAC16	GT-HRSG-16 HEAT	0.	360.	713.	300.	230.	68.	0.	-656.	713.	RESIDUAL	57.	0	0.34	0.32	0.42
17 GTWC16	GT-HRSG-16 POWR	0.	30.	65.	26.	20.	6.	322.	0.	387.	RESIDUAL	387.	10	0.07	0.05	0.78
17 GTWC16	GT-HRSG-16 HEAT	0.	341.	740.	300.	233.	68.	0.	-664.	740.	RESIDUAL	76.	0	0.32	0.32	0.41

ORIGINAL PAGE IS  
OF POOR QUALITY

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28653 MW 6.00 PROCESS MILLIONS BTU/HR 300.0 PROCESS TEMP(F) 489. PRODUCT PHENOL-ACETO 'OURS PER YEAR 8200.

POWER TO HEAT RATIO 0.068

UTILITY FUEL COAL WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

		WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED- NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
18	CC1626 GTST-16/26 POWR	0.	29.	56.	18.	20.	6.	332.	0.	388.	RESIDUAL	388.	10	0.07	0.05	0.77
18	CC1626 GTST-16/26 HEAT	0.	482.	928.	300.	338.	99.	0.	-993.	928.	RESIDUAL	-65.	0	0.34	0.36	0.32
19	CC1622 GTST-16/22 POWR	0.	31.	57.	20.	20.	6.	329.	0.	386.	RESIDUAL	386.	10	0.07	0.05	0.78
19	CC1622 GTST-16/22 HEAT	0.	454.	847.	300.	303.	89.	0.	-884.	847.	RESIDUAL	-37.	0	0.35	0.36	0.35
20	CC1222 GTST-12/22 POWR	0.	31.	57.	20.	20.	6.	329.	0.	386.	RESIDUAL	386.	10	0.07	0.05	0.78
20	CC1222 GTST-12/22 HEAT	0.	455.	839.	300.	301.	88.	0.	-878.	839.	RESIDUAL	-38.	0	0.35	0.36	0.36
21	CC0822 GTST-08/22 POWR	0.	33.	61.	26.	20.	6.	322.	0.	384.	RESIDUAL	384.	10	0.08	0.05	0.78
21	CC0822 GTST-08/22 HEAT	0.	384.	709.	300.	237.	69.	0.	-677.	709.	RESIDUAL	33.	0	0.35	0.33	0.42
22	STIG15 STIG-15-16 POWR	0.	11.	54.	1.	20.	6.	352.	0.	406.	RESIDUAL	406.	11	0.03	0.05	0.74
22	STIG15 STIG-15-16 HEAT	0.	4752.	23077.	300.	8792.	2577.	0.	-27412.	23077.	RESIDUAL	-4335.	1	0.17	0.38	0.01
23	STIG10 STIG-10-16 POWR	0.	16.	57.	8.	20.	6.	344.	0.	401.	RESIDUAL	401.	11	0.04	0.05	0.75
23	STIG10 STIG-10-16 HEAT	0.	630.	2264.	300.	813.	238.	0.	-2477.	2264.	RESIDUAL	-213.	1	0.22	0.36	0.13
24	STIG1S STIG-1S-16 POWR	0.	18.	61.	13.	20.	6.	338.	0.	399.	RESIDUAL	399.	11	0.04	0.05	0.75
24	STIG1S STIG-1S-16 HEAT	0.	421.	1423.	300.	477.	140.	0.	-1427.	1423.	RESIDUAL	-4.	1	0.23	0.34	0.21
25	DEADV3 DIESEL-ADV POWR	0.	19.	55.	8.	20.	6.	343.	0.	398.	RESIDUAL	398.	1	0.04	0.05	0.75
25	DEADV3 DIESEL-ADV HEAT	0.	666.	1961.	300.	728.	213.	0.	-2210.	1961.	RESIDUAL	-249.	1	0.25	0.37	0.15
26	DEADV2 DIESEL-ADV POWR	0.	25.	55.	14.	20.	6.	336.	0.	392.	RESIDUAL	392.	1	0.06	0.05	0.77
26	DEADV2 DIESEL-ADV HEAT	0.	541.	1181.	300.	438.	128.	0.	-1305.	1181.	RESIDUAL	-124.	1	0.31	0.37	0.25
27	DEADV1 DIESEL-ADV POWR	0.	34.	55.	22.	20.	6.	328.	0.	383.	RESIDUAL	383.	1	0.08	0.05	0.78
27	DEADV1 DIESEL-ADV HEAT	0.	475.	767.	300.	285.	83.	0.	-826.	767.	RESIDUAL	-58.	1	0.38	0.37	0.39
28	DEHTPM ADV-DIESEL POWR	0.	27.	75.	32.	20.	6.	315.	0.	390.	RESIDUAL	390.	0	0.06	0.05	0.77
28	DEHTPM ADV-DIESEL HEAT	0.	249.	695.	300.	189.	55.	0.	-527.	695.	RESIDUAL	168.	0	0.26	0.27	0.43
29	DES0A3 DIESEL-S0A POWR	0.	15.	57.	7.	20.	6.	345.	0.	402.	DISTILLA	402.	1	0.04	0.05	0.75
29	DES0A3 DIESEL-S0A HEAT	0.	676.	2522.	300.	910.	267.	0.	-2781.	2522.	DISTILLA	-259.	1	0.21	0.36	0.12
29	DES0A3 DIESEL-S0A POWR	0.	15.	57.	7.	20.	6.	345.	0.	402.	RESIDUAL	402.	1	0.04	0.05	0.75
29	DES0A3 DIESEL-S0A HEAT	0.	676.	2522.	300.	910.	267.	0.	-2781.	2522.	RESIDUAL	-259.	1	0.21	0.36	0.12

HONEYWELL PAGE PRINTING SYSTEM- P1188-02

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28653 MW 6.00 PROCESS MILLIONS BTU/HR 300.0 PROCESS TEMP(F) 489. PRODUCT PHENOL-ACETO HOURS PER YEAR 8200.

		POWER TO HEAT RATIO 0.068															
UTILITY FUEL		COAL		WASTE FUEL EQV BTU*10**6= 0. HOT WATER BTU*10**6= 0.													
		WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED- NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
30	DESOA2 DIESEL-SOA POWR	0.	22.	57.	12.	20.	6.	338.	0.	395.	DISTILLA	395.	1	0.05	0.05	0.76	
30	DESOA2 DIESEL-SOA HEAT	0.	528.	1364.	300.	492.	144.	0.	-1474.	1364.	DISTILLA	-111.	1	0.26	0.36	0.22	
30	DESOA2 DIESEL-SOA POWR	0.	22.	57.	12.	20.	6.	338.	0.	395.	RESIDUAL	395.	1	0.05	0.05	0.76	
30	DESOA2 DIESEL-SOA HEAT	0.	528.	1364.	300.	492.	144.	0.	-1474.	1364.	RESIDUAL	-111.	1	0.28	0.36	0.22	
31	DESOA1 DIESEL-SOA POWR	0.	34.	57.	23.	20.	6.	326.	0.	383.	DISTILLA	383.	1	0.08	0.05	0.78	
31	DESOA1 DIESEL-SOA HEAT	0.	449.	748.	300.	270.	79.	0.	-780.	748.	DISTILLA	-32.	1	0.37	0.36	0.40	
31	DESOA1 DIESEL-SOA POWR	0.	34.	57.	23.	20.	6.	326.	0.	383.	RESIDUAL	383.	1	0.08	0.05	0.78	
31	DESOA1 DIESEL-SOA HEAT	0.	449.	748.	300.	270.	79.	0.	-780.	748.	RESIDUAL	-32.	1	0.37	0.36	0.40	
32	GTSOAD GT-HRSO-10 POWR	0.	31.	70.	32.	20.	6.	316.	0.	386.	DISTILLA	386.	10	0.07	0.05	0.78	
32	GTSOAD GT-HRSO-10 HEAT	0.	295.	662.	300.	193.	57.	0.	-540.	662.	DISTILLA	122.	0	0.31	0.29	0.45	
33	GTRA08 GT-85RE-08 POWR	0.	25.	57.	16.	20.	6.	334.	0.	392.	DISTILLA	392.	10	0.06	0.05	0.77	
33	GTRA08 GT-85RE-08 HEAT	0.	479.	1094.	300.	391.	115.	0.	-1157.	1094.	DISTILLA	-63.	0	0.30	0.36	0.27	
34	GTRA12 GT-85RE-12 POWR	0.	27.	57.	17.	20.	6.	333.	0.	390.	DISTILLA	390.	10	0.06	0.05	0.77	
34	GTRA12 GT-85RE-12 HEAT	0.	474.	1018.	300.	365.	107.	0.	-1075.	1018.	DISTILLA	-57.	0	0.32	0.36	0.29	
35	GTRA16 GT-85RE-16 POWR	0.	27.	59.	19.	20.	6.	331.	0.	390.	DISTILLA	390.	10	0.07	0.05	0.77	
35	GTRA16 GT-85RE-16 HEAT	0.	438.	943.	300.	329.	96.	0.	-964.	943.	DISTILLA	-21.	0	0.32	0.35	0.32	
36	GTR208 GT-60RE-08 POWR	0.	28.	64.	24.	20.	6.	325.	0.	389.	DISTILLA	389.	10	0.07	0.05	0.77	
36	GTR208 GT-60RE-08 HEAT	0.	353.	811.	300.	259.	76.	0.	-747.	811.	DISTILLA	64.	0	0.30	0.32	0.37	
37	GTR212 GT-60RE-12 POWR	0.	28.	62.	22.	20.	6.	327.	0.	389.	DISTILLA	389.	10	0.07	0.05	0.77	
37	GTR212 GT-60RE-12 HEAT	0.	379.	845.	300.	279.	82.	0.	-807.	845.	DISTILLA	38.	0	0.31	0.33	0.36	
38	GTR216 GT-60RE-16 POWR	0.	28.	61.	21.	20.	6.	328.	0.	389.	DISTILLA	389.	10	0.07	0.05	0.77	
38	GTR216 GT-60RE-16 HEAT	0.	398.	853.	300.	287.	84.	0.	-834.	853.	DISTILLA	19.	0	0.32	0.34	0.35	
39	GTRW08 GT-85RE-08 POWR	0.	22.	58.	14.	20.	6.	337.	0.	395.	DISTILLA	395.	10	0.05	0.05	0.76	
39	GTRW08 GT-85RE-08 HEAT	0.	478.	1294.	300.	454.	133.	0.	-1355.	1294.	DISTILLA	-61.	0	0.27	0.35	0.23	
40	GTRW12 GT-85RE-12 POWR	0.	24.	56.	14.	20.	6.	337.	0.	393.	DISTILLA	393.	10	0.06	0.05	0.76	
40	GTRW12 GT-85RE-12 HEAT	0.	520.	1218.	300.	443.	130.	0.	-1321.	1218.	DISTILLA	-103.	0	0.30	0.36	0.25	

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
 COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
 REPORT 5.1

PAGE 155

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28653 MW 6.00 PROCESS MILLIONS BTU/HR 300.0 PROCESS TEMP(F) 489. PRODUCT PHENOL-ACETO HOURS PER YEAR 8200.

POWER TO HEAT RATIO 0.068

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41 GTRW16 GT-85RE-16	POWR	0.	25.	57.	16.	20.	6.	335.	0.	392.	DISTILLA	392.	10	0.06	0.05	0.77
41 GTRW16 GT-85RE-16	HEAT	0.	481.	1108.	300.	396.	116.	0.	-1172.	1108.	DISTILLA	-54.	0	0.30	0.36	0.27
42 GTR308 GT-60RE-08	POWR	0.	20.	66.	18.	20.	6.	331.	0.	397.	DISTILLA	397.	10	0.05	0.05	0.76
42 GTR308 GT-60RE-08	HEAT	0.	319.	1077.	300.	334.	98.	0.	-979.	1077.	DISTILLA	98.	0	0.23	0.31	0.28
43 GTR312 GT-60RE-12	POWR	0.	26.	60.	19.	20.	6.	331.	0.	391.	DISTILLA	391.	10	0.06	0.05	0.77
43 GTR312 GT-60RE-12	HEAT	0.	418.	951.	300.	325.	95.	0.	-953.	951.	DISTILLA	-1.	0	0.31	0.34	0.32
44 GTR316 GT-60RE-16	POWR	0.	26.	60.	19.	20.	6.	330.	0.	391.	DISTILLA	391.	10	0.06	0.05	0.77
44 GTR316 GT-60RE-16	HEAT	0.	409.	942.	300.	319.	94.	0.	-934.	942.	DISTILLA	8.	0	0.30	0.34	0.32
45 FCPADS FUEL-CL-PH	POWR	0.	21.	54.	9.	20.	6.	342.	0.	396.	DISTILLA	396.	0	0.05	0.05	0.76
45 FCPADS FUEL-CL-PH	HEAT	0.	684.	1765.	300.	671.	197.	0.	-2032.	1765.	DISTILLA	-267.	0	0.28	0.38	0.17
46 FCMCDS FUEL-CL-MO	POWR	0.	28.	50.	12.	20.	6.	339.	0.	389.	DISTILLA	389.	0	0.07	0.05	0.77
46 FCMCDS FUEL-CL-MO	HEAT	0.	723.	1288.	300.	530.	155.	0.	-1594.	1288.	DISTILLA	-306.	0	0.36	0.41	0.23

HONEYWELL PAGE PRINTING SYSTEM- P1185-02

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28654 MW 0.70 PROCESS MILLIONS BTU/HR 220.0 PROCESS TEMP(F) 489. PRODUCT ETHYLBENZENE HOURS PER YEAR 7900.

POWER TO HEAT RATIO 0.011

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	AUX ELECT BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET* TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
0 ONDCGN	N C C G G N	0.	0.	0.	0.	0.	0.	259.	7.	259.	COAL-FGD	266.	0	0.	0.01	0.83
1 STM141	STM-TURB-1 POWR	0.	5.	40.	32.	2.	1.	221.	0.	262.	RESIDUAL	262.	10	0.02	0.01	0.84
1 STM141	STM-TURB-1 HEAT	0.	32.	278.	220.	16.	5.	0.	-44.	278.	RESIDUAL	234.	10	0.10	0.06	0.79
1 STM141	STM-TURB-1 POWR	0.	5.	40.	32.	2.	1.	221.	0.	262.	COAL-FGD	262.	10	0.02	0.01	0.84
1 STM141	STM-TURB-1 HEAT	0.	32.	278.	220.	16.	5.	0.	-44.	278.	COAL-FGD	234.	10	0.10	0.06	0.79
1 STM141	STM-TURB-1 POWR	0.	5.	40.	32.	2.	1.	221.	0.	262.	COAL-AFB	262.	10	0.02	0.01	0.84
1 STM141	STM-TURB-1 HEAT	0.	32.	278.	220.	16.	5.	0.	-44.	278.	COAL-AFB	234.	10	0.10	0.06	0.79
2 STM088	STM-TURB-8 POWR	0.	5.	108.	89.	2.	1.	154.	0.	262.	RESIDUAL	262.	11	0.02	0.01	0.84
2 STM088	STM-TURB-8 HEAT	0.	11.	266.	220.	6.	2.	0.	-11.	266.	RESIDUAL	255.	11	0.04	0.02	0.83
2 STM088	STM-TURB-8 POWR	0.	5.	108.	89.	2.	1.	154.	0.	262.	COAL-FGD	262.	11	0.02	0.01	0.84
2 STM088	STM-TURB-8 HEAT	0.	11.	266.	220.	6.	2.	0.	-11.	266.	COAL-FGD	255.	11	0.04	0.02	0.83
2 STM088	STM-TURB-8 POWR	0.	5.	108.	89.	2.	1.	154.	0.	262.	COAL-AFB	262.	11	0.02	0.01	0.84
2 STM088	STM-TURB-8 HEAT	0.	11.	266.	220.	6.	2.	0.	-11.	266.	COAL-AFB	255.	11	0.04	0.02	0.83
3 PFBSTM	PFB-STMTB- POWR	0.	4.	18.	12.	2.	1.	244.	0.	262.	COAL-PFB	262.	10	0.02	0.01	0.84
3 PFBSTM	PFB-STMTB- HEAT	0.	79.	314.	220.	43.	13.	0.	-126.	314.	COAL-PFB	188.	10	0.20	0.14	0.70
4 T1STMT	TI-STMTB-1 POWR	0.	5.	13.	8.	2.	1.	249.	0.	262.	RESIDUAL	262.	10	0.02	0.01	0.84
4 T1STMT	TI-STMTB-1 HEAT	0.	120.	336.	220.	63.	19.	0.	-190.	336.	RESIDUAL	146.	0	0.26	0.19	0.65
4 T1STMT	TI-STMTB-1 POWR	0.	5.	13.	8.	2.	1.	249.	0.	262.	COAL	262.	10	0.02	0.01	0.84
4 T1STMT	TI-STMTB-1 HEAT	0.	120.	336.	220.	63.	19.	0.	-190.	336.	COAL	146.	0	0.26	0.19	0.65
5 TIHRSG	THERMIONIC POWR	0.	2.	17.	10.	2.	1.	247.	0.	264.	RESIDUAL	264.	10	0.01	0.01	0.83
5 TIHRSG	THERMIONIC HEAT	0.	53.	368.	220.	52.	15.	0.	-154.	368.	RESIDUAL	214.	0	0.13	0.14	0.60
5 TIHRSG	THERMIONIC POWR	0.	2.	17.	10.	2.	1.	247.	0.	264.	COAL	264.	10	0.01	0.01	0.83
5 TIHRSG	THERMIONIC HEAT	0.	53.	368.	220.	52.	15.	0.	-154.	368.	COAL	214.	0	0.13	0.14	0.60
6 STIRL	STIRLING-1 POWR	0.	3.	11.	6.	2.	1.	252.	0.	263.	DISTILLA	263.	0	0.01	0.01	0.84
6 STIRL	STIRLING-1 HEAT	0.	123.	432.	220.	85.	28.	0.	-288.	432.	DISTILLA	144.	0	0.22	0.22	0.51

1235 PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28654 MW 0.70 PROCESS MILLIONS BTU/HR 220.0 PROCESS TEMP(F) 489. PRODUCT ETHYLBENZENE HOURS PER YEAR 7900.

UTILITY FUEL		COAL	POWER TO HEAT RATIO 0.011							WASTE FUEL EQV BTU*10**6=		0.	HOT WATER BTU*10**6=		0.			
			WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN ELECT MW	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET* TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
6	STIRL	STIRLING-1 POWR	0.	3.	11.	6.	2.	1.	252.	0.	263.	RESIDUAL	263.	0	0.01	0.01	0.84	
6	STIRL	STIRLING-1 HEAT	0.	123.	432.	220.	95.	28.	0.	-288.	432.	RESIDUAL	144.	0	0.22	0.22	0.51	
6	STIRL	STIRLING-1 POWR	0.	3.	11.	6.	2.	1.	252.	0.	263.	COAL	263.	0	0.01	0.01	0.84	
6	STIRL	STIRLING-1 HEAT	0.	123.	432.	220.	95.	28.	0.	-288.	432.	COAL	144.	0	0.22	0.22	0.51	
7	HEGT85	HELIUM-GT- POWR	0.	-1.	7.	-1.	2.	1.	260.	0.	267.	COAL-AFB	267.	11	-0.00	0.01	0.82	
7	HEGT85	HELIUM-GT- HEAT	-2322.	252.	-2322.	220.	-745.	-218.	0.	2337.	-2322.	COAL-AFB	15.	11	-7.78	*****	14.95	
8	HEGT60	HELIUM-GT- POWR	0.	-0.	9.	1.	2.	1.	257.	0.	266.	COAL-AFB	266.	10	-0.00	0.01	0.83	
8	HEGT60	HELIUM-GT- HEAT	0.	-21.	1466.	220.	380.	111.	0.	-1179.	1466.	COAL-AFB	287.	0	-0.01	0.26	0.15	
9	HEGT00	HELIUM-GT- POWR	0.	1.	14.	6.	2.	1.	251.	0.	265.	COAL-AFB	265.	10	0.00	0.01	0.83	
9	HEGT00	HELIUM-GT- HEAT	0.	45.	475.	220.	84.	25.	0.	-254.	475.	COAL-AFB	221.	10	0.09	0.18	0.46	
10	FCMCCL	FUEL-CL-MO POWR	0.	4.	8.	4.	2.	1.	254.	0.	262.	COAL	262.	10	0.01	0.01	0.84	
10	FCMCCL	FUEL-CL-MO HEAT	0.	235.	468.	220.	142.	42.	0.	-437.	468.	COAL	31.	10	0.33	0.30	0.47	
11	FCSTCL	FUEL-CL-ST POWR	0.	4.	7.	3.	2.	1.	255.	0.	262.	COAL	262.	10	0.02	0.01	0.84	
11	FCSTCL	FUEL-CL-ST HEAT	0.	286.	498.	220.	168.	49.	0.	-519.	498.	COAL	-20.	10	0.36	0.34	0.44	
12	IGGTST	INT-GAS-GT POWR	0.	3.	10.	5.	2.	1.	253.	0.	263.	COAL	263.	10	0.01	0.01	0.84	
12	IGGTST	INT-GAS-GT HEAT	0.	136.	463.	220.	109.	32.	0.	-333.	463.	COAL	130.	10	0.23	0.24	0.47	
13	GTSOAR	GT-HRSG-10 POWR	0.	3.	8.	3.	2.	1.	255.	0.	263.	RESIDUAL	263.	10	0.01	0.01	0.84	
13	GTSOAR	GT-HRSG-10 HEAT	0.	205.	575.	220.	167.	49.	0.	-514.	575.	RESIDUAL	61.	0	0.26	0.29	0.38	
14	GTAC08	GT-HRSG-08 POWR	0.	4.	9.	5.	2.	1.	253.	0.	262.	RESIDUAL	262.	10	0.01	0.01	0.84	
14	GTAC08	GT-HRSG-08 HEAT	0.	192.	427.	220.	115.	34.	0.	-352.	427.	RESIDUAL	74.	0	0.31	0.27	0.52	
15	GTAC12	GT-HRSG-12 POWR	0.	4.	8.	4.	2.	1.	255.	0.	262.	RESIDUAL	262.	10	0.01	0.01	0.84	
15	GTAC12	GT-HRSG-12 HEAT	0.	237.	475.	220.	145.	42.	0.	-445.	475.	RESIDUAL	30.	0	0.33	0.31	0.46	
16	GTAC16	GT-HRSG-16 POWR	0.	4.	7.	3.	2.	1.	255.	0.	263.	RESIDUAL	263.	10	0.01	0.01	0.84	
16	GTAC16	GT-HRSG-16 HEAT	0.	264.	523.	220.	169.	50.	0.	-520.	523.	RESIDUAL	3.	0	0.34	0.32	0.42	
17	GTWC16	GT-HRSG-16 POWR	0.	3.	8.	3.	2.	1.	255.	0.	263.	RESIDUAL	263.	10	0.01	0.01	0.84	
17	GTWC16	GT-HRSG-16 HEAT	0.	250.	542.	220.	171.	50.	0.	-526.	542.	RESIDUAL	16.	0	0.32	0.32	0.41	

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28654 MW 0.70 PROCESS MILLIONS BTU/HR 220.0 PROCESS TEMP(F) 489. PRODUCT ETHYLBENZENE HOURS PER YEAR 7900.

POWER TO HEAT RATIO 0.011  
WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN ELECT MW	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
18 CC1626	GTST-16/26	POWR	0.	3.	7.	2.	2.	1.	256.	0.	263.	RESIDUAL	263.	11	0.01	0.01	0.84
18 CC1626	GTST-16/26	HEAT	0.	301.	635.	220.	217.	64.	0.	-670.	635.	RESIDUAL	-35.	1	0.32	0.34	0.35
19 CC1622	GTST-16/22	POWR	0.	3.	7.	3.	2.	1.	256.	0.	263.	RESIDUAL	263.	11	0.01	0.01	0.84
19 CC1622	GTST-16/22	HEAT	0.	283.	580.	220.	193.	57.	0.	-597.	580.	RESIDUAL	-17.	1	0.33	0.33	0.38
20 CC1222	GTST-12/22	POWR	0.	4.	7.	3.	2.	1.	256.	0.	263.	RESIDUAL	263.	11	0.01	0.01	0.84
20 CC1222	GTST-12/22	HEAT	0.	283.	574.	220.	191.	56.	0.	-591.	574.	RESIDUAL	-16.	1	0.33	0.33	0.38
21 CC0822	GTST-08/22	POWR	0.	4.	8.	4.	2.	1.	255.	0.	262.	RESIDUAL	262.	11	0.01	0.01	0.84
21 CC0822	GTST-08/22	HEAT	0.	234.	485.	220.	147.	43.	0.	-453.	485.	RESIDUAL	32.	1	0.33	0.30	0.45
22 ST1015	STIG-15-16	POWR	0.	1.	6.	0.	2.	1.	259.	0.	265.	RESIDUAL	265.	11	0.00	0.01	0.83
22 ST1015	STIG-15-16	HEAT	0.	3485.	16923.	220.	6448.	1890.	0.	-20142.	16923.	RESIDUAL	-3218.	1	0.17	0.38	0.01
23 ST1010	STIG-10-16	POWR	0.	2.	7.	1.	2.	1.	258.	0.	264.	RESIDUAL	264.	11	0.01	0.01	0.83
23 ST1010	STIG-10-16	HEAT	0.	462.	1660.	220.	596.	175.	0.	-1856.	1660.	RESIDUAL	-195.	1	0.22	0.38	0.13
24 ST101S	STIG-1S-16	POWR	0.	2.	7.	2.	2.	1.	257.	0.	264.	RESIDUAL	264.	11	0.01	0.01	0.83
24 ST101S	STIG-1S-16	HEAT	0.	308.	1044.	220.	350.	103.	0.	-1086.	1044.	RESIDUAL	-42.	1	0.23	0.34	0.21
25 DEADV3	DIESEL-ADV	POWR	0.	2.	6.	1.	2.	1.	258.	0.	264.	RESIDUAL	264.	11	0.01	0.01	0.83
25 DEADV3	DIESEL-ADV	HEAT	0.	488.	1438.	220.	534.	156.	0.	-1660.	1438.	RESIDUAL	-222.	1	0.25	0.37	0.15
26 DEADV2	DIESEL-ADV	POWR	0.	3.	6.	2.	2.	1.	257.	0.	263.	RESIDUAL	263.	11	0.01	0.01	0.84
26 DEADV2	DIESEL-ADV	HEAT	0.	397.	866.	220.	321.	94.	0.	-997.	866.	RESIDUAL	-131.	1	0.31	0.37	0.25
27 DEADV1	DIESEL-ADV	POWR	0.	4.	6.	3.	2.	1.	256.	0.	262.	RESIDUAL	262.	11	0.01	0.01	0.84
27 DEADV1	DIESEL-ADV	HEAT	0.	348.	563.	220.	209.	61.	0.	-645.	563.	RESIDUAL	-82.	1	0.38	0.37	0.39
28 DEHTPM	ADV-DIESEL	POWR	0.	3.	9.	4.	2.	1.	254.	0.	263.	RESIDUAL	263.	10	0.01	0.01	0.84
28 DEHTPM	ADV-DIESEL	HEAT	0.	182.	510.	220.	139.	41.	0.	-426.	510.	RESIDUAL	84.	0	0.26	0.27	0.43
29 DESOA3	DIESEL-SOA	POWR	0.	2.	7.	1.	2.	1.	258.	0.	265.	DISTILLA	265.	1	0.01	0.01	0.83
29 DESOA3	DIESEL-SOA	HEAT	0.	496.	1849.	220.	668.	196.	0.	-2079.	1849.	DISTILLA	-229.	1	0.21	0.36	0.12
29 DESOA3	DIESEL-SOA	POWR	0.	2.	7.	1.	2.	1.	258.	0.	265.	RESIDUAL	265.	1	0.01	0.01	0.83
29 DESOA3	DIESEL-SOA	HEAT	0.	496.	1849.	220.	668.	196.	0.	-2079.	1849.	RESIDUAL	-229.	1	0.21	0.36	0.12

HONEYWELL PAGE PRINTING SYSTEM-PI185-02

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28654 MW 0.70 PROCESS MILLIONS BTU/HR 220.0 PROCESS TEMP(F) 489. PRODUCT ETHYLBENZENE HOURS PER YEAR 7900.

		POWER TO HEAT RATIO 0.011															
UTILITY FUEL		COAL		WASTE FUEL EQV BTU*10**6= 0.											HOT WATER BTU*10**6= 0.		
		WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED-NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN ELECT MW	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
30	DESOA2 DIESEL-SOA POWR	0.	3.	7.	1.	2.	1.	257.	0.	264.	DISTILLA	264.	1	0.01	0.01	0.83	
30	DESOA2 DIESEL-SOA HEAT	0.	387.	1000.	220.	361.	106.	0.	-1121.	1000.	DISTILLA	-121.	1	0.28	0.36	0.22	
30	DESOA2 DIESEL-SOA POWR	0.	3.	7.	1.	2.	1.	257.	0.	264.	RESIDUAL	264.	1	0.01	0.01	0.83	
30	DESOA2 DIESEL-SOA HEAT	0.	387.	1000.	220.	361.	106.	0.	-1121.	1000.	RESIDUAL	-121.	1	0.28	0.36	0.22	
31	DESOA1 DIESEL-SOA POWR	0.	4.	7.	3.	2.	1.	256.	0.	262.	DISTILLA	262.	1	0.01	0.01	0.84	
31	DESOA1 DIESEL-SOA HEAT	0.	329.	549.	220.	198.	58.	0.	-611.	549.	DISTILLA	-63.	1	0.37	0.36	0.40	
31	DESOA1 DIESEL-SOA POWR	0.	4.	7.	3.	2.	1.	256.	0.	262.	RESIDUAL	262.	1	0.01	0.01	0.84	
31	DESOA1 DIESEL-SOA HEAT	0.	329.	549.	220.	198.	58.	0.	-611.	549.	RESIDUAL	-63.	1	0.37	0.36	0.40	
32	GTSOAD GT-HRSG-10 POWR	0.	4.	8.	4.	2.	1.	254.	0.	263.	DISTILLA	263.	10	0.01	0.01	0.84	
32	GTSOAD GT-HRSG-10 HEAT	0.	216.	485.	220.	142.	42.	0.	-435.	485.	DISTILLA	50.	0	0.31	0.29	0.45	
33	GTRA08 GT-85RE-08 POWR	0.	3.	7.	2.	2.	1.	257.	0.	263.	DISTILLA	263.	10	0.01	0.01	0.84	
33	GTRA08 GT-85RE-08 HEAT	0.	352.	803.	220.	287.	84.	0.	-888.	803.	DISTILLA	-85.	0	0.30	0.36	0.27	
34	GTRA12 GT-85RE-12 POWR	0.	3.	7.	2.	2.	1.	257.	0.	263.	DISTILLA	263.	10	0.01	0.01	0.84	
34	GTRA12 GT-85RE-12 HEAT	0.	348.	747.	220.	267.	78.	0.	-828.	747.	DISTILLA	-81.	0	0.32	0.36	0.29	
35	GTRA16 GT-85RE-16 POWR	0.	3.	7.	2.	2.	1.	256.	0.	263.	DISTILLA	263.	10	0.01	0.01	0.84	
35	GTRA16 GT-85RE-16 HEAT	0.	321.	691.	220.	241.	71.	0.	-746.	691.	DISTILLA	-55.	0	0.32	0.35	0.32	
36	GTR208 GT-60RE-08 POWR	0.	3.	7.	3.	2.	1.	256.	0.	263.	DISTILLA	263.	10	0.01	0.01	0.84	
36	GTR208 GT-60RE-08 HEAT	0.	259.	595.	220.	190.	56.	0.	-587.	595.	DISTILLA	7.	0	0.30	0.32	0.37	
37	GTR212 GT-60RE-12 POWR	0.	3.	7.	3.	2.	1.	256.	0.	263.	DISTILLA	263.	10	0.01	0.01	0.84	
37	GTR212 GT-60RE-12 HEAT	0.	278.	619.	220.	204.	60.	0.	-631.	619.	DISTILLA	-12.	0	0.31	0.33	0.36	
38	GTR216 GT-60RE-16 POWR	0.	3.	7.	2.	2.	1.	256.	0.	263.	DISTILLA	263.	10	0.01	0.01	0.84	
38	GTR216 GT-60RE-16 HEAT	0.	292.	626.	220.	211.	62.	0.	-651.	626.	DISTILLA	-26.	0	0.32	0.34	0.35	
39	GTRW08 GT-85RE-08 POWR	0.	3.	7.	2.	2.	1.	257.	0.	264.	DISTILLA	264.	10	0.01	0.01	0.83	
39	GTRW08 GT-85RE-08 HEAT	0.	351.	949.	220.	333.	98.	0.	-1033.	949.	DISTILLA	-84.	0	0.27	0.35	0.23	
40	GTRW12 GT-85RE-12 POWR	0.	3.	7.	2.	2.	1.	257.	0.	263.	DISTILLA	263.	10	0.01	0.01	0.83	
40	GTRW12 GT-85RE-12 HEAT	0.	382.	893.	220.	325.	95.	0.	-1008.	893.	DISTILLA	-115.	0	0.30	0.36	0.25	

PULPING SYSTEM- F1169-02

APPROVED  
DATE 06/06/79  
BY [Signature]



I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28654 MW 0.70 PROCESS MILLIONS BTU/HR 220.0 PROCESS TEMP(F) 489. PRODUCT ETHYLBENZENE HOURS PER YEAR 7900.

POWER TO HEAT RATIO 0.011

UTILITY FUEL COAL

WASTE FUEL EQV BTU\*10\*\*6= 0.

HOT WATER BTU\*10\*\*6= 0.

		WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET TOTAL UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41	GTRW16 GT-85RE-16 POWR	0.	3.	7.	2.	2.	1.	257.	0.	263.	DISTILLA	263.	10	0.01	0.01	0.84
41	GTRW16 GT-85RE-16 HEAT	0.	353.	813.	220.	290.	85.	0.	-899.	813.	DISTILLA	-86.	0	0.30	0.36	0.27
42	GTR308 GT-60RE-08 POWR	0.	2.	8.	2.	2.	1.	256.	0.	264.	DISTILLA	264.	10	0.01	0.01	0.83
42	GTR308 GT-60RE-08 HEAT	0.	234.	790.	220.	245.	72.	0.	-758.	790.	DISTILLA	32.	0	0.23	0.31	0.28
43	GTR312 GT-60RE-12 POWR	0.	3.	7.	2.	2.	1.	256.	0.	263.	DISTILLA	263.	10	0.01	0.01	0.84
43	GTR312 GT-60RE-12 HEAT	0.	307.	698.	220.	239.	70.	0.	-738.	698.	DISTILLA	-40.	0	0.31	0.34	0.32
44	GTR316 GT-60RE-16 POWR	0.	3.	7.	2.	2.	1.	256.	0.	263.	DISTILLA	263.	10	0.01	0.01	0.84
44	GTR316 GT-60RE-16 HEAT	0.	300.	691.	220.	234.	69.	0.	-725.	691.	DISTILLA	-34.	0	0.30	0.34	0.32
45	FCPADS FUEL-CL-PH POWR	0.	2.	6.	1.	2.	1.	258.	0.	264.	DISTILLA	264.	10	0.01	0.01	0.83
45	FCPADS FUEL-CL-PH HEAT	0.	501.	1294.	220.	492.	144.	0.	-1529.	1294.	DISTILLA	-235.	0	0.28	0.38	0.17
46	FCMDS FUEL-CL-MO POWR	0.	3.	6.	1.	2.	1.	257.	0.	263.	DISTILLA	263.	10	0.01	0.01	0.84
46	FCMDS FUEL-CL-MO HEAT	0.	530.	944.	220.	389.	114.	0.	-1208.	944.	DISTILLA	-264.	0	0.36	0.41	0.23

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28691 MW 1.50 PROCESS MILLIONS BTU/HR 133.0 PROCESS TEMP(F) 574. PRODUCT METHANOL-SYN HOURS PER YEAR 7880.

		POWER TO HEAT RATIO 0.038																
UTILITY FUEL		COAL		WASTE FUEL EQV BTU*10**6= 353.											HOT WATER BTU*10**6= 0.			
		WASTE FUEL USED	FUEL SAVED= NO-NET	COGEN FUEL USED	COGEN PROCES HEAT	COGEN PROCES POWER	COGEN MW ELECT	AUX PROCES BOILR	UTILIT FUEL USED	TOTAL FUEL SITE	SITE FUEL USED	NET= TOTAL+ UTILIT	FAIL	FESR	POWER FACTR	HEAT FACTR		
		BTU/HR	BTU/HR	BTU/HR	BTU/HR	BTU/HR		BTU/HR	BTU/HR	BTU/HR	BTU/HR	BTU/HR						
0	ONOCGN N O C O G O N	156.	0.	0.	0.	0.	0.	156.	16.	156.	COAL-FGD	172.	0	0.	0.03	0.77		
1	STM141 STM-TURB-1 POWR	170.	3.	170.	139.	5.	2.	-7.	0.	170.	RESIDUAL	170.	11	1.00	0.03	0.78		
1	STM141 STM-TURB-1 HEAT	162.	10.	162.	133.	5.	1.	0.	1.	162.	RESIDUAL	163.	11	0.96	0.03	0.82		
1	STM141 STM-TURB-1 POWR	170.	3.	170.	139.	5.	2.	-7.	0.	170.	COAL-FGD	170.	11	1.00	0.03	0.78		
1	STM141 STM-TURB-1 HEAT	162.	10.	162.	133.	5.	1.	0.	1.	162.	COAL-FGD	163.	11	0.96	0.03	0.82		
1	STM141 STM-TURB-1 POWR	170.	3.	170.	139.	5.	2.	-7.	0.	170.	COAL-AFB	170.	11	1.00	0.03	0.78		
1	STM141 STM-TURB-1 HEAT	162.	10.	162.	133.	5.	1.	0.	1.	162.	COAL-AFB	163.	11	0.96	0.03	0.82		
2	STM088 STM-TURB-8 POWR	162.	10.	-675.	-579.	5.	2.	837.	0.	162.	RESIDUAL	162.	11	1.00	0.03	0.82		
2	STM088 STM-TURB-8 HEAT	155.	-2.	155.	133.	-1.	-0.	0.	20.	155.	RESIDUAL	175.	11	-0.23	-0.01	0.76		
2	STM088 STM-TURB-8 POWR	162.	10.	-675.	-579.	5.	2.	837.	0.	162.	COAL-FGD	162.	11	1.00	0.03	0.82		
2	STM088 STM-TURB-8 HEAT	155.	-2.	155.	133.	-1.	-0.	0.	20.	155.	COAL-FGD	175.	11	-0.23	-0.01	0.76		
2	STM088 STM-TURB-8 POWR	162.	10.	-675.	-579.	5.	2.	837.	0.	162.	COAL-AFB	162.	11	1.00	0.03	0.82		
2	STM088 STM-TURB-8 HEAT	155.	-2.	155.	133.	-1.	-0.	0.	20.	155.	COAL-AFB	175.	11	-0.23	-0.01	0.76		
3	PFBSTM PFB-STMTB- POWR	163.	9.	46.	33.	5.	2.	117.	0.	163.	COAL-PFB	163.	10	1.00	0.03	0.81		
3	PFBSTM PFB-STMTB- HEAT	164.	37.	184.	133.	21.	6.	0.	-48.	184.	COAL-PFB	136.	10	1.00	0.11	0.72		
4	TISTMT TI-STMTB-1 POWR	132.	10.	31.	21.	5.	2.	132.	0.	163.	RESIDUAL	163.	11	-0.95	0.03	0.82		
4	TISTMT TI-STMTB-1 HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	RESIDUAL	172.	111	-0.00	0.	0.77		
4	TISTMT TI-STMTB-1 POWR	163.	10.	31.	21.	5.	2.	132.	0.	163.	COAL	163.	11	1.00	0.03	0.82		
4	TISTMT TI-STMTB-1 HEAT	196.	61.	196.	133.	32.	9.	0.	-84.	196.	COAL	112.	11	1.00	0.16	0.68		
5	TIHRSG THERMIONIC POWR	133.	3.	36.	20.	5.	2.	133.	0.	169.	RESIDUAL	169.	10	-1.27	0.03	0.79		
5	TIHRSG THERMIONIC HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	RESIDUAL	172.	110	-0.00	0.	0.77		
5	TIHRSG THERMIONIC POWR	169.	3.	36.	20.	5.	2.	133.	0.	169.	COAL	169.	10	1.00	0.03	0.79		
5	TIHRSG THERMIONIC HEAT	239.	23.	239.	133.	34.	10.	0.	-89.	239.	COAL	150.	0	1.00	0.14	0.56		
6	STIRL STIRLING-1 POWR	140.	6.	27.	14.	5.	2.	140.	0.	166.	DISTILLA	166.	1	-0.67	0.03	0.80		
6	STIRL STIRLING-1 HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	DISTILLA	172.	111	-0.00	0.	0.77		

HONEYWELL PAGE PRINTING SYSTEM - P1188-02

1&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28691 MW 1.50 PROCESS MILLIONS BTU/HR 133.0 PROCESS TEMP(F) 574. PRODUCT METHANCL-SYN HOURS PER YEAR 7880.

UTILITY FUEL COAL POWER TO HEAT RATIO 0.038 WASTE FUEL EQV BTU\*10\*\*6= 353. HOT WATER BTU\*10\*\*6= 0.

	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN ELECT 10**6 BTU/HR	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE USED 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET- TOTAL UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	
6 STIRL STIRLING-1 POWR	140.	6.	27.	14.	5.	2.	140.	0.	166.	RESIDUAL	166.	1	-0.67	0.03	0.80
6 STIRL STIRLING-1 HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	RESIDUAL	172.	111	-0.00	0.	0.77
6 STIRL STIRLING-1 POWR	166.	6.	27.	14.	5.	2.	140.	0.	166.	COAL	166.	1	1.00	0.03	0.80
6 STIRL STIRLING-1 HEAT	248.	57.	248.	133.	48.	14.	0.	-133.	248.	COAL	115.	1	1.00	0.19	0.54
7 HEGT85 HELIUM-GT- POWR	178.	-5.	16.	-4.	5.	2.	162.	0.	178.	COAL-AFB	178.	11	1.00	0.03	0.75
7 HEGT85 HELIUM-GT- HEAT	-489.	155.	-489.	133.	-157.	-46.	0.	506.	-489.	COAL-AFB	18.	11	*****	-8.96	7.59
8 HEGT60 HELIUM-GT- POWR	176.	-3.	20.	1.	5.	2.	156.	0.	176.	COAL-AFB	176.	11	1.00	0.03	0.76
8 HEGT60 HELIUM-GT- HEAT	353.	-844.	5246.	133.	1359.	398.	0.	-4230.	5246.	COAL-AFB	1016.	1	-0.15	0.26	0.03
9 HEGT00 HELIUM-GT- POWR	170.	2.	29.	13.	5.	2.	141.	0.	170.	COAL-AFB	170.	10	1.00	0.03	0.78
9 HEGT00 HELIUM-GT- HEAT	296.	23.	296.	133.	52.	15.	0.	-147.	296.	COAL-AFB	149.	10	1.00	0.18	0.45
10 FCMCCL FUEL-CL-MO POWR	0.	8.	17.	8.	5.	2.	147.	0.	164.	COAL	164.	10	-9.26	0.03	0.81
10 FCMCCL FUEL-CL-MO HEAT	0.	142.	284.	133.	86.	25.	0.	-254.	284.	COAL	30.	10	-0.05	0.30	0.47
11 FCSTCL FUEL-CL-ST POWR	0.	9.	16.	7.	5.	2.	148.	0.	164.	COAL	164.	11	-9.24	0.03	0.81
11 FCSTCL FUEL-CL-ST HEAT	0.	159.	291.	133.	94.	28.	0.	-277.	291.	COAL	14.	11	0.01	0.32	0.46
12 IGGTST INT-GAS-GT POWR	0.	6.	23.	12.	5.	2.	143.	0.	166.	COAL	166.	11	-9.40	0.03	0.80
12 IGGTST INT-GAS-GT HEAT	0.	70.	270.	133.	59.	17.	0.	-168.	270.	COAL	102.	11	-0.47	0.22	0.49
13 GTSGAR GT-HRSG-10 POWR	149.	6.	18.	6.	5.	2.	149.	0.	167.	RESIDUAL	167.	10	-0.10	0.03	0.80
13 GTSGAR GT-HRSG-10 HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	RESIDUAL	172.	110	-0.00	0.	0.77
14 GTAC08 GT-HRSG-08 POWR	145.	8.	19.	10.	5.	2.	145.	0.	164.	RESIDUAL	164.	10	-0.19	0.03	0.81
14 GTAC08 GT-HRSG-08 HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	RESIDUAL	172.	110	-0.00	0.	0.77
15 GTAC12 GT-HRSG-12 POWR	147.	8.	17.	8.	5.	2.	147.	0.	164.	RESIDUAL	164.	10	-0.05	0.03	0.81
15 GTAC12 GT-HRSG-12 HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	RESIDUAL	172.	110	-0.00	0.	0.77
16 GTAC16 GT-HRSG-16 POWR	149.	8.	16.	7.	5.	2.	149.	0.	165.	RESIDUAL	165.	10	0.01	0.03	0.81
16 GTAC16 GT-HRSG-16 HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	RESIDUAL	172.	110	-0.00	0.	0.77
17 GTWC16 GT-HRSG-16 POWR	149.	8.	16.	7.	5.	2.	149.	0.	165.	RESIDUAL	165.	10	-0.02	0.03	0.81
17 GTWC16 GT-HRSG-16 HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	RESIDUAL	172.	110	-0.00	0.	0.77

ORIGINAL PAGE IS  
OF POOR QUALITY

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 163

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28691 MW 1.50 PROCESS MILLIONS BTU/HR 133.0 PROCESS TEMP(F) 574. PRODUCT METHANOL-SYN HOURS PER YEAR 7860.

POWER TO HEAT RATIO 0.038

WASTE FUEL EQV BTU\*10\*\*6= 353. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET USED 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN ELECT MW	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
18 CC1626	GTST-16/26	POWR	150.	7.	16.	6.	5.	2.	150.	0.	165.	RESIDUAL	165.	11	0.03	0.03	0.80
18 CC1626	GTST-16/26	HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	RESIDUAL	172.	111	-0.00	0.	0.77
19 CC1622	GTST-16/22	POWR	149.	7.	16.	6.	5.	2.	149.	0.	165.	RESIDUAL	165.	11	-0.00	0.03	0.81
19 CC1622	GTST-16/22	HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	RESIDUAL	172.	111	-0.00	0.	0.77
20 CC1222	GTST-12/22	POWR	149.	7.	16.	6.	5.	2.	149.	0.	165.	RESIDUAL	165.	11	-0.00	0.03	0.81
20 CC1222	GTST-12/22	HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	RESIDUAL	172.	111	-0.00	0.	0.77
21 CC0822	GTST-08/22	POWR	147.	8.	18.	8.	5.	2.	147.	0.	164.	RESIDUAL	164.	11	-0.11	0.03	0.81
21 CC0822	GTST-08/22	HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	RESIDUAL	172.	111	-0.00	0.	0.77
22 STIG15	STIG-15-16	POWR	156.	3.	13.	0.	5.	2.	156.	0.	170.	RESIDUAL	170.	11	0.16	0.03	0.78
22 STIG15	STIG-15-16	HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	RESIDUAL	172.	111	-0.00	0.	0.77
23 STIG10	STIG-10-16	POWR	154.	4.	14.	2.	5.	2.	154.	0.	169.	RESIDUAL	169.	11	0.11	0.03	0.79
23 STIG10	STIG-10-16	HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	RESIDUAL	172.	111	-0.00	0.	0.77
24 STIG1S	STIG-1S-16	POWR	153.	5.	15.	3.	5.	2.	153.	0.	168.	RESIDUAL	168.	11	0.05	0.03	0.79
24 STIG1S	STIG-1S-16	HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	RESIDUAL	172.	111	-0.00	0.	0.77
25 DEADV3	DIESEL-ADV	POWR	155.	4.	14.	2.	5.	2.	155.	0.	168.	RESIDUAL	168.	11	0.14	0.03	0.79
25 DEADV3	DIESEL-ADV	HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	RESIDUAL	172.	111	-0.00	0.	0.77
26 DEADV2	DIESEL-ADV	POWR	152.	6.	14.	4.	5.	2.	152.	0.	166.	RESIDUAL	166.	11	0.14	0.03	0.80
26 DEADV2	DIESEL-ADV	HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	RESIDUAL	172.	111	-0.00	0.	0.77
27 DEADV1	DIESEL-ADV	POWR	150.	9.	14.	5.	5.	2.	150.	0.	164.	RESIDUAL	164.	11	0.14	0.03	0.81
27 DEADV1	DIESEL-ADV	HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	RESIDUAL	172.	111	-0.00	0.	0.77
28 DEHTPM	ADV-DIESEL	POWR	145.	5.	23.	10.	5.	2.	145.	0.	167.	RESIDUAL	167.	11	-0.42	0.03	0.79
28 DEHTPM	ADV-DIESEL	HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	RESIDUAL	172.	111	-0.00	0.	0.77
29 DESOA3	DIESEL-SOA	POWR	155.	3.	14.	1.	5.	2.	155.	0.	169.	DISTILLA	169.	1	0.11	0.03	0.79
29 DESOA3	DIESEL-SOA	HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	DISTILLA	172.	111	-0.00	0.	0.77
29 DESOA3	DIESEL-SOA	POWR	155.	3.	14.	1.	5.	2.	155.	0.	169.	RESIDUAL	169.	1	0.11	0.03	0.79
29 DESOA3	DIESEL-SOA	HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	RESIDUAL	172.	111	-0.00	0.	0.77

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28691 MW 1.50 PROCESS MILLIONS BTU/HR 133.0 PROCESS TEMP(F) 574. PRODUCT METHANOL-SYN HOURS PER YEAR 7880.

POWER TO HEAT RATIO 0.038

UTILITY FUEL COAL

WASTE FUEL EQV BTU\*10\*\*6= 353. HOT WATER BTU\*10\*\*6= 0.

		WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
30	DESOA2 DIESEL-SOA POWR	153.	5.	14.	3.	5.	2.	153.	0.	167.	DISTILLA	167.	1	0.11	0.03	0.80
30	DESOA2 DIESEL-SOA HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	DISTILLA	172.	111	-0.00	0.	0.77
30	DESOA2 DIESEL-SOA POWR	153.	5.	14.	3.	5.	2.	153.	0.	167.	RESIDUAL	167.	1	0.11	0.03	0.80
30	DESOA2 DIESEL-SOA HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	RESIDUAL	172.	111	-0.00	0.	0.77
31	DESOA1 DIESEL-SOA POWR	150.	9.	14.	6.	5.	2.	150.	0.	164.	DISTILLA	164.	1	0.11	0.03	0.81
31	DESOA1 DIESEL-SOA HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	DISTILLA	172.	111	-0.00	0.	0.77
31	DESOA1 DIESEL-SOA POWR	150.	9.	14.	6.	5.	2.	150.	0.	164.	RESIDUAL	164.	1	0.11	0.03	0.81
31	DESOA1 DIESEL-SOA HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	RESIDUAL	172.	111	-0.00	0.	0.77
32	GTSOAD GT-HRSG-10 POWR	147.	8.	18.	8.	5.	2.	147.	0.	165.	DISTILLA	165.	10	-0.10	0.03	0.81
32	GTSOAD GT-HRSG-10 HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	DISTILLA	172.	110	-0.00	0.	0.77
33	GTRA08 GT-85RE-08 POWR	153.	5.	14.	3.	5.	2.	153.	0.	167.	DISTILLA	167.	10	0.10	0.03	0.80
33	GTRA08 GT-85RE-08 HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	DISTILLA	172.	110	-0.00	0.	0.77
34	GTRA12 GT-85RE-12 POWR	152.	6.	14.	4.	5.	2.	152.	0.	167.	DISTILLA	167.	10	0.11	0.03	0.80
34	GTRA12 GT-85RE-12 HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	DISTILLA	172.	110	-0.00	0.	0.77
35	GTRA16 GT-85RE-16 POWR	152.	6.	15.	4.	5.	2.	152.	0.	166.	DISTILLA	166.	10	0.08	0.03	0.80
35	GTRA16 GT-85RE-16 HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	DISTILLA	172.	110	-0.00	0.	0.77
36	GTR208 GT-60RE-08 POWR	150.	6.	16.	6.	5.	2.	150.	0.	166.	DISTILLA	166.	10	-0.00	0.03	0.80
36	GTR208 GT-60RE-08 HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	DISTILLA	172.	110	-0.00	0.	0.77
37	GTR212 GT-60RE-12 POWR	150.	7.	16.	5.	5.	2.	150.	0.	166.	DISTILLA	166.	10	0.03	0.03	0.80
37	GTR212 GT-60RE-12 HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	DISTILLA	172.	110	-0.00	0.	0.77
38	GTR216 GT-60RE-16 POWR	151.	7.	15.	5.	5.	2.	151.	0.	166.	DISTILLA	166.	10	0.05	0.03	0.80
38	GTR216 GT-60RE-16 HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	DISTILLA	172.	110	-0.00	0.	0.77
39	GTRW08 GT-85RE-08 POWR	153.	5.	15.	3.	5.	2.	153.	0.	168.	DISTILLA	168.	10	0.09	0.03	0.79
39	GTRW08 GT-85RE-08 HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	DISTILLA	172.	110	-0.00	0.	0.77
40	GTRW12 GT-85RE-12 POWR	153.	5.	14.	3.	5.	2.	153.	0.	167.	DISTILLA	167.	10	0.12	0.03	0.80
40	GTRW12 GT-85RE-12 HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	DISTILLA	172.	110	-0.00	0.	0.77

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 165

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28691 MW 1.50 PROCESS MILLIONS BTU/HR 133.0 PROCESS TEMP(F) 574. PRODUCT METHANOL-SYN HOURS PER YEAR 7880.

POWER TO HEAT RATIO 0.038

WASTE FUEL EQV BTU\*10\*\*6= 353. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41	GTRW16 GT-85RE-16 POWR	152.	6.	14.	4.	5.	2.	152.	0.	167.	DISTILLA	167.	10	0.10	0.03	0.80
41	GTRW16 GT-85RE-16 HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	DISTILLA	172.	110	-0.00	0.	0.77
42	GTR308 GT-60RE-08 POWR	152.	4.	17.	4.	5.	2.	152.	0.	168.	DISTILLA	168.	10	-0.03	0.03	0.79
42	GTR308 GT-60RE-08 HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	DISTILLA	172.	110	-0.00	0.	0.77
43	GTR312 GT-60RE-12 POWR	151.	6.	15.	5.	5.	2.	151.	0.	166.	DISTILLA	166.	10	0.06	0.03	0.80
43	GTR312 GT-60RE-12 HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	DISTILLA	172.	110	-0.00	0.	0.77
44	GTR316 GT-60RE-16 POWR	151.	6.	15.	5.	5.	2.	151.	0.	166.	DISTILLA	166.	10	0.06	0.03	0.80
44	GTR316 GT-60RE-16 HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	DISTILLA	172.	110	-0.00	0.	0.77
45	FCPADS FUEL-CL-PH POWR	154.	5.	13.	2.	5.	2.	154.	0.	167.	DISTILLA	167.	0	0.16	0.03	0.80
45	FCPADS FUEL-CL-PH HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	DISTILLA	172.	110	-0.00	0.	0.77
46	FCMCDS FUEL-CL-MO POWR	153.	7.	12.	3.	5.	2.	153.	0.	165.	DISTILLA	165.	10	0.22	0.03	0.80
46	FCMCDS FUEL-CL-MO HEAT	156.	0.	0.	0.	0.	0.	156.	16.	156.	DISTILLA	172.	110	-0.00	0.	0.77

I&SE PEG ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28692 MW 5.70 PROCESS MILLIONS BTU/HR 150.0 PROCESS TEMP(F) 598. PRODUCT ETHYLENE-FRO HOURS PER YEAR 7900.

POWER TO HEAT RATIO 0.130

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR					
0 ON	0 CGN	0 N	0 C	0 G	0 O	0 N	0.	0.	0.	0.	0.	0.	176.	61.	176.	COAL-FGD	237.	0	0.	0.08	0.63
1 STM141	STM-TURB-1	POWR	0.	38.	-3533.	-3023.	19.	6.	3733.	0.	199.	RESIDUAL	199.	11	0.16	0.10	0.75				
1 STM141	STM-TURB-1	HEAT	0.	-2.	175.	150.	-1.	-0.	0.	64.	175.	RESIDUAL	239.	11	-0.01	-0.00	0.63				
1 STM141	STM-TURB-1	POWR	0.	38.	-3533.	-3023.	19.	6.	3733.	0.	199.	COAL-FGD	199.	11	0.16	0.10	0.75				
1 STM141	STM-TURB-1	HEAT	0.	-2.	175.	150.	-1.	-0.	0.	64.	175.	COAL-FGD	239.	11	-0.01	-0.00	0.63				
1 STM141	STM-TURB-1	POWR	0.	38.	-3533.	-3023.	19.	6.	3733.	0.	199.	COAL-AFB	199.	11	0.16	0.10	0.75				
1 STM141	STM-TURB-1	HEAT	0.	-2.	175.	150.	-1.	-0.	0.	64.	175.	COAL-AFB	239.	11	-0.01	-0.00	0.63				
2 STM088	STM-TURB-8	POWR	0.	38.	-438.	-392.	19.	6.	638.	0.	199.	RESIDUAL	199.	1	0.16	0.10	0.75				
2 STM088	STM-TURB-8	HEAT	0.	-15.	168.	150.	-7.	-2.	0.	84.	168.	RESIDUAL	252.	11	-0.06	-0.03	0.60				
2 STM088	STM-TURB-8	POWR	0.	38.	-438.	-392.	19.	6.	638.	0.	199.	COAL-FGD	199.	1	0.16	0.10	0.75				
2 STM088	STM-TURB-8	HEAT	0.	-15.	168.	150.	-7.	-2.	0.	84.	168.	COAL-FGD	252.	11	-0.06	-0.03	0.60				
2 STM088	STM-TURB-8	POWR	0.	38.	-438.	-392.	19.	6.	638.	0.	199.	COAL-AFB	199.	1	0.16	0.10	0.75				
2 STM088	STM-TURB-8	HEAT	0.	-15.	168.	150.	-7.	-2.	0.	84.	168.	COAL-AFB	252.	11	-0.06	-0.03	0.60				
3 PFBSTM	PFB-STMTB-	POWR	0.	-2.	239.	180.	19.	6.	-35.	0.	239.	COAL-PFB	239.	10	-0.01	0.08	0.63				
3 PFBSTM	PFB-STMTB-	HEAT	0.	27.	200.	150.	16.	5.	0.	10.	200.	COAL-PFB	210.	10	0.12	0.08	0.72				
4 TISTMT	TI-STMTB-1	POWR	0.	37.	146.	103.	19.	6.	55.	0.	201.	RESIDUAL	201.	11	0.15	0.10	0.75				
4 TISTMT	TI-STMTB-1	HEAT	0.	53.	211.	150.	28.	8.	0.	-27.	211.	RESIDUAL	184.	11	0.20	0.13	0.71				
4 TISTMT	TI-STMTB-1	POWR	0.	37.	146.	103.	19.	6.	55.	0.	201.	COAL	201.	11	0.15	0.10	0.75				
4 TISTMT	TI-STMTB-1	HEAT	0.	53.	211.	150.	28.	8.	0.	-27.	211.	COAL	184.	11	0.20	0.13	0.71				
5 TIHRSG	THERMIONIC	POWR	0.	11.	138.	75.	19.	6.	88.	0.	226.	RESIDUAL	226.	0	0.05	0.09	0.66				
5 TIHRSG	THERMIONIC	HEAT	0.	22.	276.	150.	39.	11.	0.	-61.	276.	RESIDUAL	215.	0	0.07	0.14	0.54				
5 TIHRSG	THERMIONIC	POWR	0.	11.	138.	75.	19.	6.	88.	0.	226.	COAL	226.	0	0.05	0.09	0.66				
5 TIHRSG	THERMIONIC	HEAT	0.	22.	276.	150.	39.	11.	0.	-61.	276.	COAL	215.	0	0.07	0.14	0.54				
6 STIRL	STIRLING-1	POWR	0.	23.	106.	57.	19.	6.	109.	0.	215.	DISTILLA	215.	1	0.10	0.09	0.70				
6 STIRL	STIRLING-1	HEAT	0.	59.	276.	150.	51.	15.	0.	-98.	276.	DISTILLA	178.	1	0.18	0.18	0.54				

HONEYWELL PAGE PRINTING SYSTEM-PI185-02

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 167

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28692 MW 5.70 PROCESS MILLIONS BTU/HR 150.0 PROCESS TEMP(F) 598. PRODUCT ETHYLENE-FRO HOURS PER YEAR 7900.

POWER TO HEAT RATIO 0.130

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
6 STIRL STIRLING-1 POWR		0.	23.	106.	57.	19.	6.	109.	0.	215.	RESIDUAL	215.	1	0.10	0.09	0.70
6 STIRL STIRLING-1 HEAT		0.	59.	276.	150.	51.	15.	0.	-98.	276.	RESIDUAL	178.	1	0.18	0.18	0.54
6 STIRL STIRLING-1 POWR		0.	23.	106.	57.	19.	6.	109.	0.	215.	COAL	215.	1	0.10	0.09	0.70
6 STIRL STIRLING-1 HEAT		0.	59.	276.	150.	51.	15.	0.	-98.	276.	COAL	178.	1	0.18	0.18	0.54
7 HEGT85 HELIUM-GT- POWR		0.	-23.	61.	-20.	19.	6.	200.	0.	260.	COAL-AFB	260.	11	-0.10	0.07	0.58
7 HEGT85 HELIUM-GT- HEAT		-459.	175.	-459.	150.	-147.	-43.	0.	522.	-459.	COAL-AFB	62.	11	-1.20	-2.37	2.41
8 HEGT60 HELIUM-GT- POWR		0.	-16.	75.	-1.	19.	6.	178.	0.	253.	COAL-AFB	253.	11	-0.07	0.08	0.59
8 HEGT60 HELIUM-GT- HEAT		-10757.	2227.	-10757.	150.	-2786.	-817.	0.	6767.	-10757.	COAL-AFB	-1990.	11	*****	1.40	-0.08
9 HEGT00 HELIUM-GT- POWR		0.	8.	111.	49.	19.	6.	118.	0.	229.	COAL-AFB	229.	10	0.04	0.08	0.66
9 HEGT00 HELIUM-GT- HEAT		0.	25.	336.	150.	59.	17.	0.	-124.	336.	COAL-AFB	212.	10	0.07	0.18	0.45
10 FCMCCL FUEL-CL-MO POWR		0.	32.	64.	30.	19.	6.	141.	0.	205.	COAL	205.	10	0.13	0.09	0.73
10 FCMCCL FUEL-CL-MO HEAT		0.	160.	321.	150.	98.	29.	0.	-244.	321.	COAL	77.	10	0.33	0.30	0.47
11 FCSTCL FUEL-CL-ST POWR		0.	33.	64.	30.	19.	6.	141.	0.	205.	COAL	205.	11	0.14	0.10	0.73
11 FCSTCL FUEL-CL-ST HEAT		0.	160.	315.	150.	96.	28.	0.	-238.	315.	COAL	77.	11	0.34	0.30	0.48
12 IGGTST INT-GAS-GT POWR		0.	22.	99.	51.	19.	6.	117.	0.	216.	COAL	216.	11	0.09	0.09	0.70
12 IGGTST INT-GAS-GT HEAT		0.	64.	292.	150.	57.	17.	0.	-118.	292.	COAL	174.	11	0.18	0.20	0.51
13 GTSOAR GT-HRSG-10 POWR		0.	20.	67.	23.	19.	6.	150.	0.	217.	RESIDUAL	217.	10	0.09	0.09	0.69
13 GTSOAR GT-HRSG-10 HEAT		0.	135.	444.	150.	129.	38.	0.	-341.	444.	RESIDUAL	102.	0	0.23	0.29	0.34
14 GTAC08 GT-HRSG-08 POWR		0.	32.	72.	37.	19.	6.	133.	0.	205.	RESIDUAL	205.	10	0.14	0.09	0.73
14 GTAC08 GT-HRSG-08 HEAT		0.	131.	293.	150.	79.	23.	0.	-186.	293.	RESIDUAL	107.	0	0.31	0.27	0.51
15 GTAC12 GT-HRSG-12 POWR		0.	32.	64.	30.	19.	6.	141.	0.	205.	RESIDUAL	205.	10	0.14	0.09	0.73
15 GTAC12 GT-HRSG-12 HEAT		0.	162.	319.	150.	97.	29.	0.	-243.	319.	RESIDUAL	76.	0	0.34	0.31	0.47
16 GTAC16 GT-HRSG-16 POWR		0.	30.	60.	25.	19.	6.	147.	0.	207.	RESIDUAL	207.	10	0.13	0.09	0.72
16 GTAC16 GT-HRSG-16 HEAT		0.	180.	361.	150.	117.	34.	0.	-304.	361.	RESIDUAL	57.	0	0.33	0.32	0.42
17 GTWC16 GT-HRSG-16 POWR		0.	29.	62.	25.	19.	6.	147.	0.	209.	RESIDUAL	209.	10	0.12	0.09	0.72
17 GTWC16 GT-HRSG-16 HEAT		0.	171.	369.	150.	116.	34.	0.	-303.	369.	RESIDUAL	67.	0	0.32	0.32	0.41



I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28692 MW 5.70 PROCESS MILLIONS BTU/HR 150.0 PROCESS TEMP(F) 598. PRODUCT ETHYLENE-FRO HOURS PER YEAR 7900.

POWER TO HEAT RATIO 0.130

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
18 CC1626 GTST-16/26 POWR		0.	26.	62.	23.	19.	6.	149.	0.	211. RESIDUAL	211.	11	0.11	0.09	0.71
18 CC1626 GTST-16/26 HEAT		0.	168.	400.	150.	125.	37.	0.	-331.	400. RESIDUAL	70.	1	0.30	0.31	0.37
19 CC1622 GTST-16/22 POWR		0.	27.	64.	26.	19.	6.	146.	0.	210. RESIDUAL	210.	11	0.12	0.09	0.72
19 CC1622 GTST-16/22 HEAT		0.	157.	366.	150.	111.	33.	0.	-286.	366. RESIDUAL	80.	1	0.30	0.30	0.41
20 CC1222 GTST-12/22 POWR		0.	28.	64.	27.	19.	6.	145.	0.	209. RESIDUAL	209.	11	0.12	0.09	0.72
20 CC1222 GTST-12/22 HEAT		0.	156.	362.	150.	109.	32.	0.	-281.	362. RESIDUAL	81.	1	0.30	0.30	0.41
21 CC0822 GTST-08/22 POWR		0.	30.	73.	36.	19.	6.	134.	0.	207. RESIDUAL	207.	11	0.13	0.09	0.72
21 CC0822 GTST-08/22 HEAT		0.	126.	306.	150.	82.	24.	0.	-194.	306. RESIDUAL	112.	1	0.29	0.27	0.49
22 STIG15 STIG-15-16 POWR		0.	11.	51.	1.	19.	6.	176.	0.	227. RESIDUAL	227.	11	0.04	0.09	0.66
22 STIG15 STIG-15-16 HEAT		0.	2376.	11538.	150.	4396.	1288.	0.	-13677.	11538. RESIDUAL	-2139.	1	0.17	0.38	0.01
23 STIG10 STIG-10-16 POWR		0.	15.	54.	7.	19.	6.	168.	0.	222. RESIDUAL	222.	11	0.06	0.09	0.68
23 STIG10 STIG-10-16 HEAT		0.	315.	1132.	150.	407.	119.	0.	-1210.	1132. RESIDUAL	-78.	1	0.22	0.36	0.13
24 STIG1S STIG-1S-16 POWR		0.	17.	58.	12.	19.	6.	162.	0.	220. RESIDUAL	220.	11	0.07	0.09	0.68
24 STIG1S STIG-1S-16 HEAT		0.	210.	712.	150.	239.	70.	0.	-685.	712. RESIDUAL	27.	1	0.23	0.34	0.21
25 DEADV3 DIESEL-ADV POWR		0.	15.	52.	6.	19.	6.	170.	0.	222. RESIDUAL	222.	1	0.06	0.09	0.67
25 DEADV3 DIESEL-ADV HEAT		0.	400.	1404.	150.	521.	153.	0.	-1567.	1404. RESIDUAL	-163.	1	0.22	0.37	0.11
26 DEADV2 DIESEL-ADV POWR		0.	24.	52.	13.	19.	6.	161.	0.	213. RESIDUAL	213.	1	0.10	0.09	0.70
26 DEADV2 DIESEL-ADV HEAT		0.	271.	591.	150.	219.	64.	0.	-624.	591. RESIDUAL	-33.	1	0.31	0.37	0.25
27 DEADV1 DIESEL-ADV POWR		0.	32.	52.	20.	19.	6.	152.	0.	205. RESIDUAL	205.	1	0.14	0.09	0.73
27 DEADV1 DIESEL-ADV HEAT		0.	238.	384.	150.	142.	42.	0.	-384.	384. RESIDUAL	-0.	1	0.38	0.37	0.39
28 DEHTPM ADV-DIESEL POWR		0.	17.	92.	41.	19.	6.	128.	0.	220. RESIDUAL	220.	1	0.07	0.09	0.68
28 DEHTPM ADV-DIESEL HEAT		0.	62.	336.	150.	71.	21.	0.	-160.	336. RESIDUAL	176.	1	0.16	0.21	0.45
29 DESOA3 DIESEL-SOA POWR		0.	12.	54.	4.	19.	6.	172.	0.	226. DISTILLA	226.	1	0.05	0.09	0.66
29 DESOA3 DIESEL-SOA HEAT		0.	440.	2059.	150.	743.	218.	0.	-2262.	2059. DISTILLA	-203.	1	0.18	0.36	0.07
29 DESOA3 DIESEL-SOA POWR		0.	12.	54.	4.	19.	6.	172.	0.	226. RESIDUAL	226.	1	0.05	0.09	0.66
29 DESOA3 DIESEL-SOA HEAT		0.	440.	2059.	150.	743.	218.	0.	-2262.	2059. RESIDUAL	-203.	1	0.18	0.36	0.07

ORIGINAL PAGE IS  
OF POOR QUALITY

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 169

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28692 MW 5.70 PROCESS MILLIONS BTU/HR 150.0 PROCESS TEMP(F) 598. PRODUCT ETHYLENE-FRO HOURS PER YEAR 7900.

UTILITY FUEL		COAL		POWER TO HEAT RATIO 0.130										WASTE FUEL EQV BTU*10**6= 0.		HOT WATER BTU*10**6= 0.	
WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN ELECT 10**6 BTU/HR	AUX BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET* TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR			
30 DES0A2 DIESEL-S0A POWR	0.	21.	54.	12.	19.	6.	163.	0.	216.DISTILLA	216.	1	0.09	0.09	0.69			
30 DES0A2 DIESEL-S0A HEAT	0.	264.	682.	150.	246.	72.	0.	-708.	682.DISTILLA	-27.	1	0.28	0.36	0.22			
30 DES0A2 DIESEL-S0A POWR	0.	21.	54.	12.	19.	6.	163.	0.	216.RESIDUAL	216.	1	0.09	0.09	0.69			
30 DES0A2 DIESEL-S0A HEAT	0.	264.	682.	150.	246.	72.	0.	-708.	682.RESIDUAL	-27.	1	0.28	0.36	0.22			
31 DES0A1 DIESEL-S0A POWR	0.	32.	54.	22.	19.	6.	151.	0.	205.DISTILLA	205.	1	0.14	0.09	0.73			
31 DES0A1 DIESEL-S0A HEAT	0.	224.	374.	150.	135.	40.	0.	-361.	374.DISTILLA	13.	1	0.37	0.36	0.40			
31 DES0A1 DIESEL-S0A POWR	0.	32.	54.	22.	19.	6.	151.	0.	205.RESIDUAL	205.	1	0.14	0.09	0.73			
31 DES0A1 DIESEL-S0A HEAT	0.	224.	374.	150.	135.	40.	0.	-361.	374.RESIDUAL	13.	1	0.37	0.36	0.40			
32 GTS0AD GT-HRS0-10 POWR	0.	30.	67.	30.	19.	6.	141.	0.	207.DISTILLA	207.	10	0.13	0.09	0.72			
32 GTS0AD GT-HRS0-10 HEAT	0.	148.	330.	150.	96.	28.	0.	-240.	330.DISTILLA	90.	0	0.31	0.29	0.45			
33 GTRA08 GT-85RE-08 POWR	0.	19.	54.	11.	19.	6.	163.	0.	218.DISTILLA	218.	10	0.08	0.09	0.69			
33 GTRA08 GT-85RE-08 HEAT	0.	262.	741.	150.	264.	78.	0.	-766.	741.DISTILLA	-25.	0	0.26	0.36	0.20			
34 GTRA12 GT-85RE-12 POWR	0.	22.	54.	13.	19.	6.	161.	0.	216.DISTILLA	216.	10	0.09	0.09	0.70			
34 GTRA12 GT-85RE-12 HEAT	0.	252.	635.	150.	227.	67.	0.	-650.	635.DISTILLA	-15.	0	0.28	0.36	0.24			
35 GTRA16 GT-85RE-16 POWR	0.	23.	56.	15.	19.	6.	159.	0.	215.DISTILLA	215.	10	0.10	0.09	0.70			
35 GTRA16 GT-85RE-16 HEAT	0.	227.	556.	150.	194.	57.	0.	-546.	556.DISTILLA	10.	0	0.29	0.35	0.27			
36 GTR208 GT-60RE-08 POWR	0.	24.	61.	21.	19.	6.	152.	0.	213.DISTILLA	213.	10	0.10	0.09	0.70			
36 GTR208 GT-60RE-08 HEAT	0.	176.	444.	150.	142.	42.	0.	-383.	444.DISTILLA	61.	0	0.28	0.32	0.34			
37 GTR212 GT-60RE-12 POWR	0.	24.	59.	19.	19.	6.	154.	0.	213.DISTILLA	213.	10	0.10	0.09	0.70			
37 GTR212 GT-60RE-12 HEAT	0.	191.	465.	150.	153.	45.	0.	-418.	465.DISTILLA	46.	0	0.29	0.33	0.32			
38 GTR216 GT-60RE-16 POWR	0.	25.	58.	18.	19.	6.	155.	0.	213.DISTILLA	213.	10	0.10	0.09	0.71			
38 GTR216 GT-60RE-16 HEAT	0.	202.	474.	150.	160.	47.	0.	-438.	474.DISTILLA	36.	0	0.30	0.34	0.32			
39 GTRW08 GT-85RE-08 POWR	0.	17.	55.	10.	19.	6.	165.	0.	220.DISTILLA	220.	10	0.07	0.09	0.68			
39 GTRW08 GT-85RE-08 HEAT	0.	257.	834.	150.	293.	86.	0.	-854.	834.DISTILLA	-20.	0	0.24	0.35	0.18			
40 GTRW12 GT-85RE-12 POWR	0.	20.	53.	11.	19.	6.	164.	0.	217.DISTILLA	217.	10	0.09	0.09	0.69			
40 GTRW12 GT-85RE-12 HEAT	0.	277.	732.	150.	267.	78.	0.	-772.	732.DISTILLA	-40.	0	0.27	0.36	0.20			

HONEYWELL PAGE PRINTING SYSTEM- P118B-02

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28692 MW 5.70 PROCESS MILLIONS BTU/HR 150.0 PROCESS TEMP(F) 598. PRODUCT ETHYLENE-FRO HOURS PER YEAR 7900.

POWER TO HEAT RATIO 0.130

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41	GTRW16 GT-85RE-16 POWR	0.	22.	54.	13.	19.	6.	161.	0.	216.	DISTILLA	216.	10	0.09	0.09	0.70
41	GTRW16 GT-85RE-16 HEAT	0.	249.	628.	150.	224.	66.	0.	-640.	628.	DISTILLA	-12.	0	0.28	0.36	0.24
42	GTR308 GT-60RE-08 POWR	0.	16.	63.	15.	19.	6.	159.	0.	221.	DISTILLA	221.	10	0.07	0.09	0.68
42	GTR308 GT-60RE-08 HEAT	0.	157.	621.	150.	193.	56.	0.	-541.	621.	DISTILLA	80.	0	0.20	0.31	0.24
43	GTR312 GT-60RE-12 POWR	0.	24.	57.	17.	19.	6.	156.	0.	213.	DISTILLA	213.	10	0.10	0.09	0.70
43	GTR312 GT-60RE-12 HEAT	0.	211.	498.	150.	170.	50.	0.	-471.	498.	DISTILLA	27.	0	0.30	0.34	0.30
44	GTR316 GT-60RE-16 POWR	0.	24.	57.	18.	19.	6.	156.	0.	213.	DISTILLA	213.	10	0.10	0.09	0.70
44	GTR316 GT-60RE-16 HEAT	0.	206.	491.	150.	166.	49.	0.	-459.	491.	DISTILLA	32.	0	0.30	0.34	0.31
45	FCPADS FUEL-CL-PH POWR	0.	20.	51.	9.	19.	6.	166.	0.	217.	DISTILLA	217.	0	0.08	0.09	0.69
45	FCPADS FUEL-CL-PH HEAT	0.	342.	882.	150.	335.	98.	0.	-987.	882.	DISTILLA	-105.	0	0.28	0.38	0.17
46	FCMCDS FUEL-CL-MO POWR	0.	27.	47.	11.	19.	6.	164.	0.	211.	DISTILLA	211.	0	0.11	0.09	0.71
46	FCMCDS FUEL-CL-MO HEAT	0.	362.	644.	150.	265.	78.	0.	-768.	644.	DISTILLA	-124.	0	0.36	0.41	0.23

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

DATE 06/06/79

1&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28693 MW 3.60 PROCESS MILLIONS BTU/HR 350.0 PROCESS TEMP(F) 366. PRODUCT ISOPROPANOL- HOURS PER YEAR 7900.

POWER TO HEAT RATIO 0.035  
WASTE FUEL EQV BTU\*10\*\*6= 41. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WAST. FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN ELECT 10**6 BTU/HR	COGEN MW	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	FUEL TOTAL SITE USED 10**6 BTU/HR	NET- TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT
0 ONCOGN N O C O O N		41.	0.	0.	0.	0.	0.	412.	38.	412. COAL-FGD	450.	0	0.	0.03	0.78
1 STM141 STM-TURB-1 POWR		41.	24.	68.	12.	4.	332.	0.	0.	426. RESIDUAL	426.	10	0.06	0.03	0.82
1 STM141 STM-TURB-1 HEAT		41.	124.	486.	63.	19.	0.	-160.	0.	486. RESIDUAL	326.	0	0.22	0.13	0.72
1 STM141 STM-TURB-1 POWR		41.	24.	68.	12.	4.	332.	0.	0.	426. COAL-FGD	426.	10	0.06	0.03	0.82
1 STM141 STM-TURB-1 HEAT		41.	124.	486.	63.	19.	0.	-160.	0.	486. COAL-FGD	326.	0	0.22	0.13	0.72
1 STM141 STM-TURB-1 POWR		41.	24.	68.	12.	4.	332.	0.	0.	426. COAL-AFB	426.	10	0.06	0.03	0.82
1 STM141 STM-TURB-1 HEAT		41.	124.	486.	63.	19.	0.	-160.	0.	486. COAL-AFB	326.	0	0.22	0.13	0.72
2 STM088 STM-TURB-8 POWR		41.	24.	129.	12.	4.	298.	0.	0.	426. RESIDUAL	426.	10	0.06	0.03	0.82
2 STM088 STM-TURB-8 HEAT		41.	86.	464.	44.	13.	0.	-100.	0.	464. RESIDUAL	364.	0	0.17	0.10	0.75
2 STM088 STM-TURB-8 POWR		41.	24.	129.	12.	4.	298.	0.	0.	426. COAL-FGD	426.	10	0.06	0.03	0.82
2 STM088 STM-TURB-8 HEAT		41.	86.	464.	44.	13.	0.	-100.	0.	464. COAL-FGD	364.	0	0.17	0.10	0.75
2 STM088 STM-TURB-8 POWR		41.	24.	129.	12.	4.	298.	0.	0.	426. COAL-AFB	426.	10	0.06	0.03	0.82
2 STM088 STM-TURB-8 HEAT		41.	86.	464.	44.	13.	0.	-100.	0.	464. COAL-AFB	364.	0	0.17	0.10	0.75
3 PFBSTM PFB-STMTB- POWR		41.	23.	62.	12.	4.	365.	0.	0.	427. COAL-PFB	427.	10	0.06	0.03	0.82
3 PFBSTM PFB-STMTB- HEAT		41.	205.	544.	108.	32.	0.	-299.	0.	544. COAL-PFB	245.	0	0.29	0.20	0.64
4 T1STMT T1-STMTB-1 POWR		41.	24.	49.	12.	4.	377.	0.	0.	427. RESIDUAL	427.	10	0.06	0.03	0.82
4 T1STMT T1-STMTB-1 HEAT		41.	252.	530.	131.	39.	41.	-373.	0.	571. RESIDUAL	198.	0	0.32	0.23	0.61
4 T1STMT T1-STMTB-1 POWR		41.	24.	49.	12.	4.	377.	0.	0.	427. COAL	427.	10	0.06	0.03	0.82
4 T1STMT T1-STMTB-1 HEAT		41.	280.	588.	146.	43.	0.	-418.	0.	588. COAL	170.	0	0.34	0.25	0.59
5 T1HRSG THERMIONIC POWR		41.	17.	87.	12.	4.	345.	0.	0.	433. RESIDUAL	433.	0	0.04	0.03	0.81
5 T1HRSG THERMIONIC HEAT		41.	97.	488.	69.	20.	41.	-176.	0.	529. RESIDUAL	353.	0	0.17	0.13	0.66
5 T1HRSG THERMIONIC POWR		41.	17.	87.	12.	4.	345.	0.	0.	433. COAL	433.	0	0.04	0.03	0.81
5 T1HRSG THERMIONIC HEAT		41.	108.	542.	76.	22.	0.	-200.	0.	542. COAL	342.	0	0.18	0.14	0.65
6 STIRL STIRLING-1 POWR		41.	17.	49.	12.	4.	384.	0.	0.	433. DISTILLA	433.	0	0.04	0.03	0.81
6 STIRL STIRLING-1 HEAT		41.	230.	660.	166.	49.	41.	-481.	0.	701. DISTILLA	220.	0	0.26	0.24	0.50

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 172

I&amp;SE PEG ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28693 MW 3.60 PROCESS MILLIONS BTU/HR 350.0 PROCESS TEMP(F) 366. PRODUCT ISOPROPANOL- HOURS PER YEAR 7900.

		POWER TO HEAT RATIO 0.035														
UTILITY FUEL		WASTE FUEL EQV BTU*10**6= 41.											HOT WATER BTU*10**6= 0.			
	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET USED 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET+ TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
6 STIRL	STIRLING-1 POWR	41.	17.	49.	23.	12.	4.	384.	0.	433.	RESIDUAL	433.	0	0.04	0.03	0.81
6 STIRL	STIRLING-1 HEAT	41.	230.	660.	315.	166.	49.	41.	-481.	701.	RESIDUAL	220.	0	0.26	0.24	0.50
6 STIRL	STIRLING-1 POWR	41.	17.	49.	23.	12.	4.	384.	0.	433.	COAL	433.	0	0.04	0.03	0.81
6 STIRL	STIRLING-1 HEAT	41.	256.	734.	350.	185.	54.	0.	-539.	734.	COAL	194.	0	0.27	0.25	0.46
7 HEGT85	HELIUM-GT- POWR	41.	5.	38.	5.	12.	4.	406.	0.	445.	COAL-AFB	445.	10	0.01	0.03	0.79
7 HEGT85	HELIUM-GT- HEAT	41.	421.	2960.	350.	950.	279.	0.	-2931.	2960.	COAL-AFB	29.	0	0.13	0.32	0.12
8 HEGT60	HELIUM-GT- POWR	41.	7.	47.	14.	12.	4.	396.	0.	443.	COAL-AFB	443.	10	0.02	0.03	0.79
8 HEGT60	HELIUM-GT- HEAT	41.	182.	1204.	350.	312.	91.	0.	-936.	1204.	COAL-AFB	268.	0	0.14	0.26	0.29
9 HEGT00	HELIUM-GT- POWR	41.	9.	70.	34.	12.	4.	372.	0.	441.	COAL-AFB	441.	10	0.02	0.03	0.79
9 HEGT00	HELIUM-GT- HEAT	41.	89.	717.	350.	126.	37.	0.	-356.	717.	COAL-AFB	361.	10	0.12	0.18	0.49
10 FCMCCL	FUEL-CL-MO POWR	0.	20.	40.	19.	12.	4.	389.	0.	430.	COAL	430.	10	-0.05	0.03	0.81
10 FCMCCL	FUEL-CL-MO HEAT	0.	375.	739.	350.	225.	66.	0.	-664.	739.	COAL	75.	10	0.31	0.30	0.47
11 FCSTCL	FUEL-CL-ST POWR	0.	21.	33.	13.	12.	4.	396.	0.	429.	COAL	429.	10	-0.05	0.03	0.82
11 FCSTCL	FUEL-CL-ST HEAT	0.	565.	869.	350.	327.	96.	0.	-985.	869.	COAL	-115.	10	0.38	0.38	0.40
12 IGGTST	INT-GAS-GT POWR	0.	17.	44.	19.	12.	4.	389.	0.	433.	COAL	433.	10	-0.06	0.03	0.81
12 IGGTST	INT-GAS-GT HEAT	0.	305.	810.	350.	225.	66.	0.	-665.	810.	COAL	145.	10	0.25	0.28	0.43
13 GTSOAR	GT-HRSG-10 POWR	41.	17.	42.	18.	12.	4.	391.	0.	433.	RESIDUAL	433.	10	0.04	0.03	0.81
13 GTSOAR	GT-HRSG-10 HEAT	41.	301.	743.	315.	215.	63.	41.	-635.	784.	RESIDUAL	149.	0	0.29	0.27	0.45
14 GTAC08	GT-HRSG-08 POWR	41.	20.	45.	23.	12.	4.	384.	0.	430.	RESIDUAL	430.	10	0.05	0.03	0.81
14 GTAC08	GT-HRSG-08 HEAT	41.	275.	612.	315.	165.	48.	41.	-478.	653.	RESIDUAL	175.	0	0.31	0.25	0.54
15 GTAC12	GT-HRSG-12 POWR	41.	20.	40.	19.	12.	4.	390.	0.	430.	RESIDUAL	430.	10	0.05	0.03	0.81
15 GTAC12	GT-HRSG-12 HEAT	41.	339.	679.	315.	207.	61.	41.	-608.	720.	RESIDUAL	111.	0	0.33	0.29	0.49
16 GTAC16	GT-HRSG-16 POWR	41.	20.	38.	16.	12.	4.	392.	0.	430.	RESIDUAL	430.	10	0.05	0.03	0.81
16 GTAC16	GT-HRSG-16 HEAT	41.	377.	728.	315.	235.	69.	41.	-697.	770.	RESIDUAL	73.	0	0.34	0.31	0.45
17 GTWC16	GT-HRSG-16 POWR	41.	18.	39.	16.	12.	4.	393.	0.	432.	RESIDUAL	432.	10	0.04	0.03	0.81
17 GTWC16	GT-HRSG-16 HEAT	41.	358.	778.	315.	245.	72.	41.	-728.	820.	RESIDUAL	92.	0	0.32	0.30	0.43

FILED-02

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28693 MW 3.60 PROCESS MILLIONS BTU/HR 350.0 PROCESS TEMP(F) 366. PRODUCT ISOPROPANOL- HOURS PER YEAR 7900.

POWER TO HEAT RATIO 0.035

WASTE FUEL EQV BTU\*10\*\*6= 41. HOT WATER BTU\*10\*\*6= 0.

	UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED- NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	NET- TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
18	CC1626	GTST-16/26	POWR	41.	18.	33.	10.	12.	4.	400.	0.	433.RESIDUAL	433.	10	0.04	0.03	0.81
18	CC1626	GTST-16/26	HEAT	41.	534.	1000.	315.	372.	109.	41.	-1125.	1041.RESIDUAL	-84.	0	0.35	0.36	0.34
19	CC1622	GTST-16/22	POWR	41.	19.	33.	12.	12.	4.	398.	0.	432.RESIDUAL	432.	10	0.05	0.03	0.81
19	CC1622	GTST-16/22	HEAT	41.	504.	912.	315.	335.	98.	41.	-1007.	953.RESIDUAL	-54.	0	0.36	0.35	0.37
20	CC1222	GTST-12/22	POWR	41.	19.	33.	12.	12.	4.	398.	0.	431.RESIDUAL	431.	10	0.05	0.03	0.81
20	CC1222	GTST-12/22	HEAT	41.	506.	904.	315.	333.	97.	41.	-1001.	945.RESIDUAL	-56.	0	0.36	0.35	0.37
21	CC0822	GTST-08/22	POWR	41.	20.	36.	15.	12.	4.	394.	0.	430.RESIDUAL	430.	10	0.05	0.03	0.81
21	CC0822	GTST-08/22	HEAT	41.	429.	764.	315.	263.	77.	41.	-784.	805.RESIDUAL	21.	0	0.36	0.33	0.43
22	STIG15	STIG-15-16	POWR	41.	7.	32.	0.	12.	4.	411.	0.	444.RESIDUAL	444.	10	0.02	0.03	0.79
22	STIG15	STIG-15-16	HEAT	41.	4990.	24251.	315.	9232.	2706.	41.	-28811.	24272.RESIDUAL	-4539.	0	0.17	0.38	0.01
23	STIG10	STIG-10-16	POWR	41.	10.	34.	5.	12.	4.	406.	0.	441.RESIDUAL	441.	10	0.02	0.03	0.79
23	STIG10	STIG-10-16	HEAT	41.	661.	2377.	315.	854.	250.	41.	-2629.	2419.RESIDUAL	-211.	0	0.22	0.35	0.14
24	STIG15	STIG-15-16	POWR	41.	11.	37.	8.	12.	4.	403.	0.	439.RESIDUAL	439.	10	0.03	0.03	0.80
24	STIG15	STIG-15-16	HEAT	41.	442.	1494.	315.	501.	147.	41.	-1527.	1535.RESIDUAL	9.	0	0.23	0.33	0.23
25	DEADV3	DIESEL-ADV	POWR	41.	13.	33.	7.	12.	4.	404.	0.	437.RESIDUAL	437.	0	0.03	0.03	0.80
25	DEADV3	DIESEL-ADV	HEAT	41.	616.	1537.	315.	570.	167.	41.	-1743.	1578.RESIDUAL	-165.	0	0.29	0.36	0.22
26	DEADV2	DIESEL-ADV	POWR	41.	15.	33.	8.	12.	4.	402.	0.	435.RESIDUAL	435.	1	0.04	0.03	0.80
26	DEADV2	DIESEL-ADV	HEAT	41.	568.	1240.	315.	460.	135.	41.	-1399.	1281.RESIDUAL	-118.	1	0.31	0.36	0.27
27	DEADV1	DIESEL-ADV	POWR	41.	21.	33.	13.	12.	4.	397.	0.	430.RESIDUAL	430.	1	0.05	0.03	0.81
27	DEADV1	DIESEL-ADV	HEAT	41.	499.	806.	315.	299.	88.	41.	-896.	847.RESIDUAL	-49.	1	0.38	0.35	0.41
28	DEHTPM	ADV-DIESEL	POWR	41.	20.	38.	16.	12.	4.	393.	0.	430.RESIDUAL	430.	0	0.05	0.03	0.81
28	DEHTPM	ADV-DIESEL	HEAT	41.	387.	735.	315.	240.	70.	41.	-713.	776.RESIDUAL	63.	0	0.34	0.31	0.45
29	DES0A3	DIESEL-S0A	POWR	41.	11.	34.	6.	12.	4.	405.	0.	439.DISTILLA	439.	0	0.03	0.03	0.80
29	DES0A3	DIESEL-S0A	HEAT	41.	607.	1842.	315.	665.	195.	41.	-2040.	1883.DISTILLA	-156.	0	0.25	0.35	0.19
29	DES0A3	DIESEL-S0A	POWR	41.	11.	34.	6.	12.	4.	405.	0.	439.RESIDUAL	439.	0	0.03	0.03	0.80
29	DES0A3	DIESEL-S0A	HEAT	41.	607.	1842.	315.	665.	195.	41.	-2040.	1883.RESIDUAL	-156.	0	0.25	0.35	0.19

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28693 MW 3.60 PROCESS MILLIONS BTU/HR 350.0 PROCESS TEMP(F) 366. PRODUCT ISOPROPANOL- HOURS PER YEAR 7900.

POWER TO HEAT RATIO 0.035

WASTE FUEL EQV BTU\*10\*\*6= 41. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
30 DES0A2 DIESEL-S0A POWR		41.	13.	34.	7.	12.	4.	403.	0.	437.	DISTILLA	437.	1	0.03	0.03	0.80
30 DES0A2 DIESEL-S0A HEAT		41.	554.	1432.	315.	517.	151.	41.	-1577.	1473.	DISTILLA	-104.	1	0.28	0.35	0.24
30 DES0A2 DIESEL-S0A POWR		41.	13.	34.	7.	12.	4.	403.	0.	437.	RESIDUAL	437.	1	0.03	0.03	0.80
30 DES0A2 DIESEL-S0A HEAT		41.	554.	1432.	315.	517.	151.	41.	-1577.	1473.	RESIDUAL	-104.	1	0.28	0.35	0.24
31 DES0A1 DIESEL-S0A POWR		41.	20.	34.	14.	12.	4.	396.	0.	430.	DISTILLA	430.	1	0.05	0.03	0.81
31 DES0A1 DIESEL-S0A HEAT		41.	471.	786.	315.	284.	83.	41.	-848.	827.	DISTILLA	-21.	1	0.37	0.34	0.42
31 DES0A1 DIESEL-S0A POWR		41.	20.	34.	14.	12.	4.	396.	0.	430.	RESIDUAL	430.	1	0.05	0.03	0.81
31 DES0A1 DIESEL-S0A HEAT		41.	471.	786.	315.	284.	83.	41.	-848.	827.	RESIDUAL	-21.	1	0.37	0.34	0.42
32 GTS0AD GT-HRSG-10 POWR		41.	19.	42.	19.	12.	4.	389.	0.	431.	DISTILLA	431.	10	0.05	0.03	0.81
32 GTS0AD GT-HRSG-10 HEAT		41.	311.	684.	315.	200.	59.	41.	-586.	725.	DISTILLA	139.	0	0.31	0.28	0.48
33 GTRA08 GT-85RE-08 POWR		41.	18.	34.	12.	12.	4.	398.	0.	433.	DISTILLA	433.	10	0.04	0.03	0.81
33 GTRA08 GT-85RE-08 HEAT		41.	479.	937.	315.	334.	98.	41.	-1007.	978.	DISTILLA	-29.	0	0.34	0.34	0.36
34 GTRA12 GT-85RE-12 POWR		41.	18.	34.	12.	12.	4.	398.	0.	432.	DISTILLA	432.	10	0.04	0.03	0.81
34 GTRA12 GT-85RE-12 HEAT		41.	479.	910.	315.	326.	95.	41.	-980.	951.	DISTILLA	-28.	0	0.34	0.34	0.37
35 GTRA16 GT-85RE-16 POWR		41.	18.	35.	13.	12.	4.	397.	0.	432.	DISTILLA	432.	10	0.04	0.03	0.81
35 GTRA16 GT-85RE-16 HEAT		41.	449.	869.	315.	303.	89.	41.	-910.	310.	DISTILLA	1.	0	0.34	0.33	0.38
36 GTR208 GT-60RE-08 POWR		41.	18.	38.	15.	12.	4.	394.	0.	432.	DISTILLA	432.	10	0.04	0.03	0.81
36 GTR208 GT-60RE-08 HEAT		41.	371.	783.	315.	251.	73.	41.	-745.	825.	DISTILLA	80.	0	0.32	0.30	0.42
37 GTR212 GT-60RE-12 POWR		41.	18.	37.	14.	12.	4.	395.	0.	432.	DISTILLA	432.	10	0.04	0.03	0.81
37 GTR212 GT-60RE-12 HEAT		41.	396.	815.	315.	269.	79.	41.	-802.	856.	DISTILLA	54.	0	0.33	0.31	0.41
38 GTR216 GT-60RE-16 POWR		41.	18.	36.	14.	12.	4.	395.	0.	432.	DISTILLA	432.	10	0.05	0.03	0.81
38 GTR216 GT-60RE-16 HEAT		41.	414.	818.	315.	276.	81.	41.	-823.	859.	DISTILLA	36.	0	0.34	0.32	0.41
39 GTRW08 GT-85RE-08 POWR		41.	15.	35.	10.	12.	4.	400.	0.	435.	DISTILLA	435.	10	0.04	0.03	0.80
39 GTRW08 GT-85RE-08 HEAT		41.	481.	1136.	315.	399.	117.	41.	-1207.	1177.	DISTILLA	-30.	0	0.30	0.34	0.30
40 GTRW12 GT-85RE-12 POWR		41.	16.	34.	10.	12.	4.	401.	0.	434.	DISTILLA	434.	10	0.04	0.03	0.81
40 GTRW12 GT-85RE-12 HEAT		41.	523.	1111.	315.	404.	119.	41.	-1226.	1152.	DISTILLA	-73.	0	0.32	0.35	0.30

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 175

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28693 MW 3.60 PROCESS MILLIONS BTU/HR 350.0 PROCESS TEMP(F) 366. PRODUCT ISOPROPANOL- HOURS PER YEAR 7900.

UTILITY FUEL COAL POWER TO HEAT RATIO 0.035  
WASTE FUEL EQV BTU\*10\*\*6= 41. HOT WATER BTU\*10\*\*6= 0.

			WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR		
41	GTRW16	GT-85RE-16	POWR	41.	16.	34.	10.	12.	4.	400.	0.	434.	DISTILLA	434.	10	0.04	0.03	0.81
41	GTRW16	GT-85RE-16	HEAT	41.	492.	1048.	315.	374.	110.	41.	-1131.	1089.	DISTILLA	-42.	0	0.32	0.34	0.32
42	GTR308	GT-60RE-08	POWR	41.	14.	40.	13.	12.	4.	397.	0.	436.	DISTILLA	436.	10	0.03	0.03	0.80
42	GTR308	GT-60RE-08	HEAT	41.	340.	982.	315.	304.	89.	41.	-913.	1023.	DISTILLA	110.	0	0.26	0.30	0.34
43	GTR312	GT-60RE-12	POWR	41.	16.	36.	12.	12.	4.	398.	0.	434.	DISTILLA	434.	10	0.04	0.03	0.81
43	GTR312	GT-60RE-12	HEAT	41.	436.	950.	315.	325.	95.	41.	-977.	992.	DISTILLA	14.	0	0.31	0.33	0.35
44	GTR316	GT-60RE-16	POWR	41.	16.	36.	12.	12.	4.	398.	0.	434.	DISTILLA	434.	10	0.04	0.03	0.81
44	GTR316	GT-60RE-16	HEAT	41.	427.	944.	315.	320.	94.	41.	-962.	985.	DISTILLA	24.	0	0.31	0.32	0.36
45	FCPADS	FUEL-CL-PH	POWR	41.	13.	32.	5.	12.	4.	405.	0.	438.	DISTILLA	438.	0	0.03	0.03	0.80
45	FCPADS	FUEL-CL-PH	HEAT	41.	718.	1853.	315.	704.	206.	41.	-2162.	1894.	DISTILLA	-268.	0	0.28	0.37	0.18
46	FCMCDS	FUEL-CL-MO	POWR	41.	17.	30.	7.	12.	4.	404.	0.	433.	DISTILLA	433.	10	0.04	0.03	0.81
46	FCMCDS	FUEL-CL-MO	HEAT	41.	759.	1352.	315.	557.	163.	41.	-1702.	1393.	DISTILLA	-309.	0	0.36	0.40	0.25



I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28694 MW 3.30 PROCESS MILLIONS BTU/HR 400.0 PROCESS TEMP(F) 450. PRODUCT ETHANOL HOURS PER YEAR 7900.

POWER TO HEAT RATIO 0.028

WASTE FUEL EQV BTU\*10\*\*6= 71. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
0 ONCGN N C O G O N		71.	0.	0.	0.	0.	0.	471.	35.	471.	COAL-FGD	506.	0	0.	0.02	0.79
1 STM141 STM-TURB-1 POWR		71.	22.	148.	115.	11.	3.	336.	0.	484.	RESIDUAL	484.	10	0.05	0.02	0.83
1 STM141 STM-TURB-1 HEAT		71.	77.	517.	400.	39.	12.	0.	-88.	517.	RESIDUAL	429.	0	0.15	0.08	0.77
1 STM141 STM-TURB-1 POWR		71.	22.	148.	115.	11.	3.	336.	0.	484.	COAL-FGD	484.	10	0.05	0.02	0.83
1 STM141 STM-TURB-1 HEAT		71.	77.	517.	400.	39.	12.	0.	-88.	517.	COAL-FGD	429.	0	0.15	0.08	0.77
1 STM141 STM-TURB-1 POWR		71.	22.	148.	115.	11.	3.	336.	0.	484.	COAL-AFB	484.	10	0.05	0.02	0.83
1 STM141 STM-TURB-1 HEAT		71.	77.	517.	400.	39.	12.	0.	-88.	517.	COAL-AFB	429.	0	0.15	0.08	0.77
2 STM088 STM-TURB-8 POWR		71.	22.	284.	230.	11.	3.	200.	0.	484.	RESIDUAL	484.	11	0.05	0.02	0.83
2 STM088 STM-TURB-8 HEAT		71.	38.	494.	400.	20.	6.	0.	-26.	494.	RESIDUAL	468.	1	0.08	0.04	0.81
2 STM088 STM-TURB-8 POWR		71.	22.	284.	230.	11.	3.	200.	0.	484.	COAL-FGD	484.	11	0.05	0.02	0.83
2 STM088 STM-TURB-8 HEAT		71.	38.	494.	400.	20.	6.	0.	-26.	494.	COAL-FGD	468.	1	0.08	0.04	0.81
2 STM088 STM-TURB-8 POWR		71.	22.	284.	230.	11.	3.	200.	0.	484.	COAL-AFB	484.	11	0.05	0.02	0.83
2 STM088 STM-TURB-8 HEAT		71.	38.	494.	400.	20.	6.	0.	-26.	494.	COAL-AFB	468.	1	0.08	0.04	0.81
3 PFBSTM PFB-STMTB- POWR		71.	21.	75.	51.	11.	3.	410.	0.	485.	COAL-PFB	485.	10	0.05	0.02	0.82
3 PFBSTM PFB-STMTB- HEAT		71.	163.	582.	400.	88.	26.	0.	-239.	582.	COAL-PFB	343.	0	0.24	0.15	0.69
4 TISTMT TI-STMTB-1 POWR		71.	21.	56.	36.	11.	3.	429.	0.	484.	RESIDUAL	484.	10	0.05	0.02	0.83
4 TISTMT TI-STMTB-1 HEAT		71.	205.	531.	340.	108.	32.	71.	-301.	601.	RESIDUAL	301.	0	0.28	0.18	0.67
4 TISTMT TI-STMTB-1 POWR		71.	21.	56.	36.	11.	3.	429.	0.	484.	COAL	484.	10	0.05	0.02	0.83
4 TISTMT TI-STMTB-1 HEAT		71.	241.	625.	400.	127.	37.	0.	-360.	625.	COAL	264.	0	0.30	0.20	0.64
5 TIHRSG THERMIONIC POWR		71.	13.	80.	49.	11.	3.	413.	0.	493.	RESIDUAL	493.	0	0.03	0.02	0.81
5 TIHRSG THERMIONIC HEAT		71.	88.	557.	340.	78.	23.	71.	-210.	628.	RESIDUAL	418.	0	0.14	0.12	0.64
5 TIHRSG THERMIONIC POWR		71.	13.	80.	49.	11.	3.	413.	0.	493.	COAL	493.	0	0.03	0.02	0.81
5 TIHRSG THERMIONIC HEAT		71.	103.	655.	400.	92.	27.	0.	-253.	655.	COAL	402.	0	0.15	0.14	0.61
6 STIRL STIRLING-1 POWR		71.	15.	50.	25.	11.	3.	441.	0.	491.	DISTILLA	491.	0	0.03	0.02	0.81
6 STIRL STIRLING-1 HEAT		71.	204.	678.	340.	154.	45.	71.	-447.	749.	DISTILLA	302.	0	0.23	0.21	0.53

ORIGINAL PAGE IS  
OF POOR QUALITY

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 177

I&amp;SE PEG ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28694 MW 3.30 PROCESS MILLIONS BTU/HR 400.0 PROCESS TEMP(F) 460. PRODUCT ETHANOL HOURS PER YEAR 7900.

POWER TO HEAT RATIO 0.028

WASTE FUEL EGW BTU\*10\*\*6= 71. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED-NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
6 STIRL STIRLING-1 POWR		71.	15.	50.	25.	11.	3.	441.	0.	491. RESIDUAL	491.	0	0.03	0.02	0.81
6 STIRL STIRLING-1 HEAT		71.	204.	678.	340.	154.	45.	71.	-447.	749. RESIDUAL	302.	0	0.23	0.21	0.53
6 STIRL STIRLING-1 POWR		71.	15.	50.	25.	11.	3.	441.	0.	491. COAL	491.	0	0.03	0.02	0.81
6 STIRL STIRLING-1 HEAT		71.	240.	798.	400.	181.	53.	0.	-532.	798. COAL	266.	0	0.25	0.23	0.50
7 HEGT85 HELIUM-GT- POWR		71.	-2.	35.	-1.	11.	3.	472.	0.	507. COAL-AFB	507.	11	-0.00	0.02	0.79
7 HEGT85 HELIUM-GT- HEAT-10030.		71.	439.	-10030.	400.	-3220.	-944.	0.	10097.	-10030. COAL-AFB	67.	11	*****	*****	6.01
8 HEGT60 HELIUM-GT- POWR		71.	1.	43.	8.	11.	3.	461.	0.	504. COAL-AFB	504.	10	0.00	0.02	0.79
8 HEGT60 HELIUM-GT- HEAT		71.	64.	2134.	400.	553.	162.	0.	-1692.	2134. COAL-AFB	442.	0	0.03	0.26	0.19
9 HEGT00 HELIUM-GT- POWR		71.	6.	64.	30.	11.	3.	435.	0.	499. COAL-AFB	499.	10	0.01	0.02	0.80
9 HEGT00 HELIUM-GT- HEAT		71.	86.	854.	400.	150.	44.	0.	-434.	854. COAL-AFB	419.	10	0.10	0.18	0.47
10 FCMCCL FUEL-CL-MO POWR		0.	19.	37.	17.	11.	3.	450.	0.	487. COAL	487.	10	-0.12	0.02	0.82
10 FCMCCL FUEL-CL-MO HEAT		0.	428.	849.	400.	258.	76.	0.	-772.	849. COAL	78.	10	0.30	0.30	0.47
11 FCSTCL FUEL-CL-ST POWR		0.	19.	32.	14.	11.	3.	454.	0.	487. COAL	487.	10	-0.12	0.02	0.82
11 FCSTCL FUEL-CL-ST HEAT		0.	548.	925.	400.	321.	94.	0.	-968.	925. COAL	-43.	10	0.34	0.35	0.43
12 IGGTST INT-GAS-GT POWR		0.	14.	46.	21.	11.	3.	445.	0.	491. COAL	491.	10	-0.13	0.02	0.81
12 IGGTST INT-GAS-GT HEAT		0.	270.	861.	400.	211.	62.	0.	-625.	861. COAL	236.	10	0.19	0.25	0.46
13 GTSOAR GT-HRSG-10 POWR		71.	14.	39.	15.	11.	3.	453.	0.	491. RESIDUAL	491.	10	0.03	0.02	0.81
13 GTSOAR GT-HRSG-10 HEAT		71.	319.	865.	340.	251.	74.	71.	-749.	935. RESIDUAL	187.	0	0.27	0.27	0.43
14 GTAC08 GT-HRSG-08 POWR		71.	19.	42.	22.	11.	3.	445.	0.	487. RESIDUAL	487.	10	0.04	0.02	0.82
14 GTAC08 GT-HRSG-08 HEAT		71.	297.	659.	340.	178.	52.	71.	-521.	730. RESIDUAL	209.	0	0.31	0.24	0.55
15 GTAC12 GT-HRSG-12 POWR		71.	18.	37.	17.	11.	3.	450.	0.	487. RESIDUAL	487.	10	0.04	0.02	0.82
15 GTAC12 GT-HRSG-12 HEAT		71.	366.	735.	340.	224.	66.	71.	-665.	805. RESIDUAL	140.	0	0.33	0.28	0.50
16 GTAC16 GT-HRSG-16 POWR		71.	18.	35.	15.	11.	3.	453.	0.	488. RESIDUAL	488.	10	0.04	0.02	0.82
16 GTAC16 GT-HRSG-16 HEAT		71.	408.	804.	340.	260.	76.	71.	-776.	875. RESIDUAL	98.	0	0.34	0.30	0.46
17 GTWC16 GT-HRSG-16 POWR		71.	16.	36.	14.	11.	3.	454.	0.	489. RESIDUAL	489.	10	0.04	0.02	0.82
17 GTWC16 GT-HRSG-16 HEAT		71.	387.	839.	340.	264.	77.	71.	-790.	909. RESIDUAL	119.	0	0.32	0.29	0.44

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28694 MW 3.30 PROCESS MILLIONS BTU/HR 400.0 PROCESS TEMP(F) 460. PRODUCT ETHANOL HOURS PER YEAR 7900.

POWER TO HEAT RATIO 0.028

WASTE FUEL EQV BTU\*10\*\*6= 71. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	NET* TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
18 CC1626 GTST-16/26 POWR		71.	16.	32.	11.	11.	3.	458.	0.	490.	RESIDUAL 490.	11	0.04	0.02	0.82
18 CC1626 GTST-16/26 HEAT		71.	490.	1003.	340.	350.	102.	71.	-1057.	1074.	RESIDUAL 16.	1	0.33	0.33	0.37
19 CC1622 GTST-16/22 POWR		71.	17.	33.	12.	11.	3.	456.	0.	489.	RESIDUAL 489.	11	0.04	0.02	0.82
19 CC1622 GTST-16/22 HEAT		71.	461.	916.	340.	313.	92.	71.	-942.	987.	RESIDUAL 45.	1	0.33	0.32	0.41
20 CC1222 GTST-12/22 POWR		71.	17.	33.	12.	11.	3.	456.	0.	489.	RESIDUAL 489.	11	0.04	0.02	0.82
20 CC1222 GTST-12/22 HEAT		71.	461.	907.	340.	310.	91.	71.	-933.	978.	RESIDUAL 45.	1	0.34	0.32	0.41
21 CC0822 GTST-08/22 POWR		71.	18.	36.	16.	11.	3.	452.	0.	488.	RESIDUAL 488.	11	0.04	0.02	0.82
21 CC0822 GTST-08/22 HEAT		71.	384.	767.	340.	240.	70.	71.	-716.	837.	RESIDUAL 122.	1	0.33	0.29	0.48
22 STIG15 STIG-15-16 POWR		71.	6.	30.	0.	11.	3.	470.	0.	500.	RESIDUAL 500.	11	0.01	0.02	0.80
22 STIG15 STIG-15-16 HEAT		71.	5386.	26154.	340.	9965.	2920.	71.	-31104.	26224.	RESIDUAL -4860.	1	0.17	0.38	0.02
23 STIG10 STIG-10-16 POWR		71.	9.	31.	4.	11.	3.	466.	0.	497.	RESIDUAL 497.	11	0.02	0.02	0.80
23 STIG10 STIG-10-16 HEAT		71.	714.	2566.	340.	921.	270.	71.	-2844.	2637.	RESIDUAL -208.	1	0.22	0.35	0.15
24 STIG1S STIG-1S-16 POWR		71.	10.	34.	7.	11.	3.	462.	0.	496.	RESIDUAL 496.	11	0.02	0.02	0.81
24 STIG1S STIG-1S-16 HEAT		71.	477.	1613.	340.	541.	158.	71.	-1654.	1683.	RESIDUAL 29.	1	0.23	0.32	0.24
25 DEADV3 DIESEL-ADV POWR		71.	11.	30.	5.	11.	3.	465.	0.	495.	RESIDUAL 495.	1	0.02	0.02	0.81
25 DEADV3 DIESEL-ADV HEAT		71.	728.	2058.	340.	763.	224.	71.	-2351.	2128.	RESIDUAL -222.	1	0.26	0.36	0.19
26 DEADV2 DIESEL-ADV POWR		71.	14.	30.	8.	11.	3.	462.	0.	492.	RESIDUAL 492.	1	0.03	0.02	0.81
26 DEADV2 DIESEL-ADV HEAT		71.	613.	1339.	340.	497.	146.	71.	-1517.	1409.	RESIDUAL -108.	1	0.31	0.35	0.28
27 DEADV1 DIESEL-ADV POWR		71.	19.	30.	12.	11.	3.	457.	0.	487.	RESIDUAL 487.	1	0.04	0.02	0.82
27 DEADV1 DIESEL-ADV HEAT		71.	539.	870.	340.	323.	95.	71.	-973.	940.	RESIDUAL -33.	1	0.38	0.34	0.43
28 DEHTPM ADV-DIESEL POWR		71.	16.	39.	17.	11.	3.	451.	0.	490.	RESIDUAL 490.	0	0.04	0.02	0.82
28 DEHTPM ADV-DIESEL HEAT		71.	317.	792.	340.	227.	66.	71.	-673.	862.	RESIDUAL 189.	0	0.29	0.26	0.46
29 DESOA3 DIESEL-SOA POWR		71.	9.	31.	4.	11.	3.	466.	0.	497.	DISTILLA 497.	1	0.02	0.02	0.80
29 DESOA3 DIESEL-SOA HEAT		71.	732.	2591.	340.	935.	274.	71.	-2888.	2662.	DISTILLA -226.	1	0.22	0.35	0.15
29 DESOA3 DIESEL-SOA POWR		71.	9.	31.	4.	11.	3.	466.	0.	497.	RESIDUAL 497.	1	0.02	0.02	0.80
29 DESOA3 DIESEL-SOA HEAT		71.	732.	2591.	340.	935.	274.	71.	-2888.	2662.	RESIDUAL -226.	1	0.22	0.35	0.15

FUEL CELL CASE PRINTING SYSTEM- P1185-02

1&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28694 MW 3.30 PROCESS MILLIONS BTU/HR 400.0 PROCESS TEMP(F) 460. PRODUCT ETHANOL HOURS PER YEAR 7900.

POWER TO HEAT RATIO 0.028

UTILITY FUEL COAL WASTE FUEL EQV BTU\*10\*\*6= 71. HOT WATER BTU\*10\*\*6= 0.

	WASTE FUEL 10**6 BTU/HR	FUEL SAVED= NO-NET USED 10**6 BTU/HR	COGEN FUEL 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
30 DES0A2 DIESEL-SOA POWR	71.	12.	31.	7.	11.	3.	463.	0.	494.	DISTILLA	494.	1	0.03	0.02	0.81
30 DES0A2 DIESEL-SOA HEAT	71.	598.	1545.	340.	558.	164.	71.	-1708.	1616.	DISTILLA	-92.	1	0.28	0.35	0.25
30 DES0A2 DIESEL-SOA POWR	71.	12.	31.	7.	11.	3.	463.	0.	494.	RESIDUAL	494.	1	0.03	0.02	0.81
30 DES0A2 DIESEL-SOA HEAT	71.	598.	1545.	340.	558.	164.	71.	-1708.	1616.	RESIDUAL	-92.	1	0.28	0.35	0.25
31 DES0A1 DIESEL-SOA POWR	71.	19.	31.	13.	11.	3.	456.	0.	487.	DISTILLA	487.	1	0.04	0.02	0.82
31 DES0A1 DIESEL-SOA HEAT	71.	509.	848.	340.	306.	90.	71.	-921.	918.	DISTILLA	-3.	1	0.37	0.33	0.44
31 DES0A1 DIESEL-SOA POWR	71.	19.	31.	13.	11.	3.	456.	0.	487.	RESIDUAL	487.	1	0.04	0.02	0.82
31 DES0A1 DIESEL-SOA HEAT	71.	509.	848.	340.	306.	90.	71.	-921.	918.	RESIDUAL	-3.	1	0.37	0.33	0.44
32 GTS0AD GT-HRSG-10 POWR	71.	17.	39.	18.	11.	3.	450.	0.	489.	DISTILLA	489.	10	0.04	0.02	0.82
32 GTS0AD GT-HRSG-10 HEAT	71.	334.	749.	340.	219.	64.	71.	-648.	819.	DISTILLA	171.	0	0.31	0.27	0.49
33 GTRA08 GT-85RE-08 POWR	71.	14.	32.	9.	11.	3.	460.	0.	491.	DISTILLA	491.	10	0.03	0.02	0.81
33 GTRA08 GT-85RE-08 HEAT	71.	535.	1170.	340.	418.	122.	71.	-1270.	1241.	DISTILLA	-30.	0	0.31	0.34	0.32
34 GTRA12 GT-85RE-12 POWR	71.	15.	31.	10.	11.	3.	459.	0.	491.	DISTILLA	491.	10	0.03	0.02	0.82
34 GTRA12 GT-85RE-12 HEAT	71.	531.	1103.	340.	395.	116.	71.	-1199.	1174.	DISTILLA	-25.	0	0.32	0.34	0.34
35 GTRA16 GT-85RE-16 POWR	71.	15.	32.	11.	11.	3.	458.	0.	490.	DISTILLA	490.	10	0.04	0.02	0.82
35 GTRA16 GT-85RE-16 HEAT	71.	493.	1031.	340.	360.	105.	71.	-1089.	1102.	DISTILLA	12.	0	0.32	0.33	0.36
36 GTR208 GT-60RE-08 POWR	71.	16.	35.	13.	11.	3.	455.	0.	490.	DISTILLA	490.	10	0.04	0.02	0.82
36 GTR208 GT-60RE-08 HEAT	71.	400.	899.	340.	288.	84.	71.	-864.	970.	DISTILLA	106.	0	0.31	0.30	0.41
37 GTR212 GT-60RE-12 POWR	71.	16.	34.	12.	11.	3.	456.	0.	490.	DISTILLA	490.	10	0.04	0.02	0.82
37 GTR212 GT-60RE-12 HEAT	71.	429.	936.	340.	309.	91.	71.	-930.	1007.	DISTILLA	77.	0	0.31	0.31	0.40
38 GTR216 GT-60RE-16 POWR	71.	16.	33.	12.	11.	3.	456.	0.	490.	DISTILLA	490.	10	0.04	0.02	0.82
38 GTR216 GT-60RE-16 HEAT	71.	450.	944.	340.	318.	93.	71.	-959.	1015.	DISTILLA	56.	0	0.32	0.31	0.39
39 GTRW08 GT-85RE-08 POWR	71.	12.	32.	8.	11.	3.	461.	0.	493.	DISTILLA	493.	10	0.03	0.02	0.81
39 GTRW08 GT-85RE-08 HEAT	71.	535.	1394.	340.	489.	143.	71.	-1494.	1465.	DISTILLA	-29.	0	0.28	0.33	0.27
40 GTRW12 GT-85RE-12 POWR	71.	14.	31.	8.	11.	3.	461.	0.	492.	DISTILLA	492.	10	0.03	0.02	0.81
40 GTRW12 GT-85RE-12 HEAT	71.	583.	1328.	340.	483.	142.	71.	-1475.	1398.	DISTILLA	-77.	0	0.30	0.35	0.29

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28694 MW 3.30 PROCESS MILLIONS BTU/HR 400.0 PROCESS TEMP(F) 460. PRODUCT ETHANOL HOURS PER YEAR 7900.

POWER TO HEAT RATIO 0.028

WASTE FUEL EQV BTU\*10\*\*6= 71. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED- NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41 GTRW16 GT-85RE-16 POWR		71.	14.	32.	9.	11.	3.	460.	0.	492.	DISTILLA	492.	10	0.03	0.02	0.81
41 GTRW16 GT-85RE-16 HEAT		71.	541.	1221.	340.	436.	128.	71.	-1327.	1292.	DISTILLA	-35.	0	0.31	0.34	0.31
42 GTR308 GT-60RE-08 POWR		71.	11.	36.	10.	11.	3.	458.	0.	495.	DISTILLA	495.	10	0.03	0.02	0.81
42 GTR308 GT-60RE-08 HEAT		71.	363.	1179.	340.	365.	107.	71.	-1107.	1249.	DISTILLA	143.	0	0.24	0.29	0.32
43 GTR312 GT-60RE-12 POWR		71.	15.	33.	11.	11.	3.	458.	0.	491.	DISTILLA	491.	10	0.03	0.02	0.81
43 GTR312 GT-60RE-12 HEAT		71.	473.	1065.	340.	364.	107.	71.	-1103.	1136.	DISTILLA	33.	0	0.31	0.32	0.35
44 GTR316 GT-60RE-16 POWR		71.	15.	33.	11.	11.	3.	458.	0.	491.	DISTILLA	491.	10	0.03	0.02	0.81
44 GTR316 GT-60RE-16 HEAT		71.	463.	1056.	340.	358.	105.	71.	-1084.	1127.	DISTILLA	43.	0	0.30	0.32	0.36
45 FCPADS FUEL-CL-PH POWR		71.	11.	30.	5.	11.	3.	465.	0.	494.	DISTILLA	494.	0	0.03	0.02	0.81
45 FCPADS FUEL-CL-PH HEAT		71.	775.	2000.	340.	760.	223.	71.	-2340.	2071.	DISTILLA	-269.	0	0.28	0.37	0.19
46 FCMCDS FUEL-CL-MO POWR		71.	15.	27.	6.	11.	3.	463.	0.	490.	DISTILLA	490.	10	0.04	0.02	0.82
46 FCMCDS FUEL-CL-MO HEAT		71.	820.	1459.	340.	601.	176.	71.	-1844.	1530.	DISTILLA	-314.	0	0.36	0.39	0.26

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 181

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28731 MW 3.50 PROCESS MILLIONS BTU/HR 640.0 PROCESS TEMP(F) 598. PRODUCT AMMONIA-SYNT HOURS PER YEAR 8400.

POWER TO HEAT RATIO 0.019

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
0 ONCOGN N C C S S N		0.	0.	0.	0.	0.	0.	753.	37.	753.	COAL-FGD	790.	0	0.	0.02	0.81
1 STM141 STM-TURB-1 POWR		0.	-3392.	4183.	3543.	12.	4.	-3416.	0.	4183.	RESIDUAL	4183.	11	-4.29	0.00	0.15
1 STM141 STM-TURB-1 HEAT		0.	4.	755.	640.	2.	1.	0.	31.	755.	RESIDUAL	786.	11	0.01	0.00	0.81
1 STM141 STM-TURB-1 POWR		0.	-3392.	4183.	3543.	12.	4.	-3416.	0.	4183.	COAL-FGD	4183.	11	-4.29	0.00	0.15
1 STM141 STM-TURB-1 HEAT		0.	4.	755.	640.	2.	1.	0.	31.	755.	COAL-FGD	786.	11	0.01	0.00	0.81
1 STM141 STM-TURB-1 POWR		0.	-3392.	4183.	3543.	12.	4.	-3416.	0.	4183.	COAL-AFB	4183.	11	-4.29	0.00	0.15
1 STM141 STM-TURB-1 HEAT		0.	4.	755.	640.	2.	1.	0.	31.	755.	COAL-AFB	786.	11	0.01	0.00	0.81
2 STM088 STM-TURB-8 POWR		0.	23.	-334.	-296.	12.	4.	1101.	0.	767.	RESIDUAL	767.	11	0.03	0.02	0.83
2 STM088 STM-TURB-8 HEAT		0.	-50.	723.	640.	-26.	-8.	0.	118.	723.	RESIDUAL	841.	11	-0.06	-0.03	0.76
2 STM088 STM-TURB-8 POWR		0.	23.	-334.	-296.	12.	4.	1101.	0.	767.	COAL-FGD	767.	11	0.03	0.02	0.83
2 STM088 STM-TURB-8 HEAT		0.	-50.	723.	640.	-26.	-8.	0.	118.	723.	COAL-FGD	841.	11	-0.06	-0.03	0.76
2 STM088 STM-TURB-8 POWR		0.	23.	-334.	-296.	12.	4.	1101.	0.	767.	COAL-AFB	767.	11	0.03	0.02	0.83
2 STM088 STM-TURB-8 HEAT		0.	-50.	723.	640.	-26.	-8.	0.	118.	723.	COAL-AFB	841.	11	-0.06	-0.03	0.76
3 PFBSTM PFB-STMTB- POWR		0.	21.	135.	101.	12.	4.	635.	0.	770.	COAL-PFB	770.	10	0.03	0.02	0.83
3 PFBSTM PFB-STMTB- HEAT		0.	131.	860.	640.	76.	22.	0.	-200.	860.	COAL-PFB	660.	0	0.13	0.09	0.74
4 TISTMT TI-STMTB-1 POWR		0.	23.	85.	60.	12.	4.	683.	0.	768.	RESIDUAL	768.	11	0.03	0.02	0.83
4 TISTMT TI-STMTB-1 HEAT		0.	242.	911.	640.	128.	38.	0.	-363.	911.	RESIDUAL	548.	1	0.21	0.14	0.70
4 TISTMT TI-STMTB-1 POWR		0.	23.	85.	60.	12.	4.	683.	0.	768.	COAL	768.	11	0.03	0.02	0.83
4 TISTMT TI-STMTB-1 HEAT		0.	242.	911.	640.	128.	38.	0.	-363.	911.	COAL	548.	1	0.21	0.14	0.70
5 TIHRSG THERMIONIC POWR		0.	7.	85.	46.	12.	4.	699.	0.	784.	RESIDUAL	784.	0	0.01	0.02	0.82
5 TIHRSG THERMIONIC HEAT		0.	93.	1177.	640.	166.	49.	0.	-480.	1177.	RESIDUAL	697.	0	0.07	0.14	0.54
5 TIHRSG THERMIONIC POWR		0.	7.	85.	46.	12.	4.	699.	0.	784.	COAL	784.	0	0.01	0.02	0.82
5 TIHRSG THERMIONIC HEAT		0.	93.	1177.	640.	166.	49.	0.	-480.	1177.	COAL	697.	0	0.07	0.14	0.54
6 STIRL STIRLING-1 POWR		0.	14.	65.	35.	12.	4.	711.	0.	776.	DISTILLA	776.	1	0.02	0.02	0.82
6 STIRL STIRLING-1 HEAT		0.	252.	1178.	640.	217.	63.	0.	-640.	1178.	DISTILLA	538.	1	0.18	0.18	0.54

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28731 MW 3.50 PROCESS MILLIONS BTU/HR 640.0 PROCESS TEMP(F) 598. PRODUCT AMMONIA-SYNT HOURS PER YEAR 8400.

		POWER TO HEAT RATIO 0.019														
		WASTE FUEL EQV BTU*10**6= 0.											HOT WATER BTU*10**6= 0.			
UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
6 STIRL	STIRLING-1 POWR	0.	14.	65.	35.	12.	4.	711.	0.	776.	RESIDUAL	776.	1	0.02	0.02	0.82
6 STIRL	STIRLING-1 HEAT	0.	252.	1178.	640.	217.	63.	0.	-640.	1178.	RESIDUAL	538.	1	0.18	0.18	0.54
6 STIRL	STIRLING-1 POWR	0.	14.	65.	35.	12.	4.	711.	0.	776.	COAL	776.	1	0.02	0.02	0.82
6 STIRL	STIRLING-1 HEAT	0.	252.	1178.	640.	217.	63.	0.	-640.	1178.	COAL	538.	1	0.18	0.18	0.54
7 HEGT85	HELIUM-GT- POWR	0.	-14.	37.	-12.	12.	4.	767.	0.	804.	COAL-AFB	804.	11	-0.02	0.01	0.80
7 HEGT85	HELIUM-GT- HEAT	-1960.	747.	-1960.	640.	-629.	-184.	0.	2003.	-1960.	COAL-AFB	43.	11	-1.53	*****	14.73
8 HEGT60	HELIUM-GT- POWR	0.	-10.	46.	-1.	12.	4.	754.	0.	800.	COAL-AFB	800.	11	-0.01	0.01	0.80
8 HEGT60	HELIUM-GT- HEAT	-45897.	9502.	-45897.	640.	-11887.	-3484.	0.	37185.	-45897.	COAL-AFB	-8712.	11	*****	1.36	-0.07
9 HEGT00	HELIUM-GT- POWR	0.	5.	68.	30.	12.	4.	717.	0.	785.	COAL-AFB	785.	10	0.01	0.02	0.82
9 HEGT00	HELIUM-GT- HEAT	0.	108.	1434.	640.	252.	74.	0.	-751.	1434.	COAL-AFB	683.	0	0.07	0.18	0.45
10 FCMCCL	FUEL-CL-MO POWR	0.	20.	39.	18.	12.	4.	731.	0.	771.	COAL	771.	10	0.02	0.02	0.83
10 FCMCCL	FUEL-CL-MO HEAT	0.	684.	1371.	640.	417.	122.	0.	-1265.	1371.	COAL	106.	0	0.33	0.30	0.47
11 FCSTCL	FUEL-CL-ST POWR	0.	20.	39.	18.	12.	4.	731.	0.	770.	COAL	770.	11	0.03	0.02	0.83
11 FCSTCL	FUEL-CL-ST HEAT	0.	701.	1358.	640.	418.	123.	0.	-1269.	1358.	COAL	89.	11	0.34	0.31	0.47
12 IGGTST	INT-GAS-GT POWR	0.	14.	59.	30.	12.	4.	717.	0.	777.	COAL	777.	11	0.02	0.02	0.82
12 IGGTST	INT-GAS-GT HEAT	0.	287.	1258.	640.	253.	74.	0.	-755.	1258.	COAL	504.	11	0.19	0.20	0.51
13 GTSQAR	GT-HRSG-10 POWR	0.	13.	41.	14.	12.	4.	737.	0.	778.	RESIDUAL	778.	10	0.02	0.02	0.82
13 GTSQAR	GT-HRSG-10 HEAT	0.	576.	1893.	640.	549.	161.	0.	-1678.	1893.	RESIDUAL	215.	0	0.23	0.29	0.34
14 GTAC08	GT-HRSG-08 POWR	0.	20.	44.	23.	12.	4.	726.	0.	771.	RESIDUAL	771.	10	0.03	0.02	0.83
14 GTAC08	GT-HRSG-08 HEAT	0.	558.	1249.	640.	337.	99.	0.	-1016.	1249.	RESIDUAL	232.	0	0.31	0.27	0.51
15 GTAC12	GT-HRSG-12 POWR	0.	20.	39.	18.	12.	4.	731.	0.	770.	RESIDUAL	770.	10	0.03	0.02	0.83
15 GTAC12	GT-HRSG-12 HEAT	0.	689.	1362.	640.	415.	122.	0.	-1281.	1362.	RESIDUAL	101.	0	0.34	0.31	0.47
16 GTAC16	GT-HRSG-16 POWR	0.	18.	37.	15.	12.	4.	735.	0.	772.	RESIDUAL	772.	10	0.02	0.02	0.83
16 GTAC16	GT-HRSG-16 HEAT	0.	767.	1542.	640.	498.	146.	0.	-1519.	1542.	RESIDUAL	23.	0	0.33	0.32	0.42
17 GTWC16	GT-HRSG-16 POWR	0.	19.	38.	15.	12.	4.	735.	0.	773.	RESIDUAL	773.	10	0.02	0.02	0.83
17 GTWC16	GT-HRSG-16 HEAT	0.	728.	1576.	640.	497.	146.	0.	-1514.	1576.	RESIDUAL	62.	0	0.32	0.32	0.41

ORIGINAL PAGE IS OF POOR QUALITY

HONEYWELL PAGE PRINTING SYSTEM- P118B-02

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 183

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28731 MW 3.50 PROCESS MILLIONS BTU/HR 640.0 PROCESS TEMP(F) 598. PRODUCT AMMONIA-SYNT HOURS PER YEAR 8400.

POWER TO HEAT RATIO 0.019

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET USED 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT PROCES 10**6 BTU/HR	COGEN POWER PROCES 10**6 BTU/HR	COGEN MW ELECT	AUX BOILR PROCES 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE USED 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR		
18	CC1626	GTST-16/26	POWR	0.	16.	38.	14.	12.	4.	736.	0.	774.	RESIDUAL	774.	11	0.02	0.02	0.83
18	CC1626	GTST-16/26	HEAT	0.	734.	1725.	640.	546.	160.	0.	-1669.	1725.	RESIDUAL	56.	1	0.30	0.32	0.37
19	CC1622	GTST-16/22	POWR	0.	17.	39.	16.	12.	4.	734.	0.	773.	RESIDUAL	773.	11	0.02	0.02	0.83
19	CC1622	GTST-16/22	HEAT	0.	688.	1578.	640.	484.	142.	0.	-1475.	1578.	RESIDUAL	103.	1	0.30	0.31	0.41
20	CC1222	GTST-12/22	POWR	0.	17.	39.	16.	12.	4.	734.	0.	773.	RESIDUAL	773.	11	0.02	0.02	0.83
20	CC1222	GTST-12/22	HEAT	0.	685.	1560.	640.	477.	140.	0.	-1455.	1560.	RESIDUAL	105.	1	0.31	0.31	0.41
21	CC0822	GTST-08/22	POWR	0.	18.	44.	21.	12.	4.	728.	0.	772.	RESIDUAL	772.	11	0.02	0.02	0.83
21	CC0822	GTST-08/22	HEAT	0.	553.	1318.	640.	358.	105.	0.	-1081.	1318.	RESIDUAL	237.	1	0.30	0.27	0.49
22	STIG15	STIG-15-16	POWR	0.	6.	31.	0.	12.	4.	752.	0.	794.	RESIDUAL	784.	11	0.01	0.02	0.82
22	STIG15	STIG-15-16	HEAT	0.	10138.	49231.	640.	18757.	5497.	0.	-58578.	49231.	RESIDUAL	-9347.	1	0.17	0.38	0.01
23	STIG10	STIG-10-16	POWR	0.	9.	33.	4.	12.	4.	748.	0.	781.	RESIDUAL	781.	11	0.01	0.02	0.82
23	STIG10	STIG-10-16	HEAT	0.	1343.	4830.	640.	1735.	508.	0.	-5383.	4830.	RESIDUAL	-553.	1	0.22	0.36	0.13
24	STIG1S	STIG-1S-16	POWR	0.	11.	36.	8.	12.	4.	744.	0.	780.	RESIDUAL	780.	11	0.01	0.02	0.82
24	STIG1S	STIG-1S-16	HEAT	0.	897.	3036.	640.	1018.	298.	0.	-3143.	3036.	RESIDUAL	-107.	1	0.23	0.34	0.21
25	DEADV3	DIESEL-ADV	POWR	0.	9.	32.	3.	12.	4.	749.	0.	781.	RESIDUAL	781.	1	0.01	0.02	0.82
25	DEADV3	DIESEL-ADV	HEAT	0.	1708.	5990.	640.	2222.	651.	0.	-6907.	5990.	RESIDUAL	-917.	1	0.22	0.37	0.11
26	DEADV2	DIESEL-ADV	POWR	0.	15.	32.	8.	12.	4.	743.	0.	776.	RESIDUAL	776.	1	0.02	0.02	0.83
26	DEADV2	DIESEL-ADV	HEAT	0.	1155.	2520.	640.	935.	274.	0.	-2884.	2520.	RESIDUAL	-364.	1	0.31	0.37	0.25
27	DEADV1	DIESEL-ADV	POWR	0.	20.	32.	13.	12.	4.	738.	0.	770.	RESIDUAL	770.	1	0.03	0.02	0.83
27	DEADV1	DIESEL-ADV	HEAT	0.	1014.	1637.	640.	607.	178.	0.	-1860.	1637.	RESIDUAL	-224.	1	0.38	0.37	0.39
28	DEHTPM	ADV-DIESEL	POWR	0.	10.	57.	25.	12.	4.	723.	0.	780.	RESIDUAL	780.	1	0.01	0.02	0.82
28	DEHTPM	ADV-DIESEL	HEAT	0.	263.	1433.	640.	302.	88.	0.	-906.	1433.	RESIDUAL	527.	1	0.16	0.21	0.45
29	DESOA3	DIESEL-SOA	POWR	0.	7.	33.	2.	12.	4.	750.	0.	783.	DISTILLA	783.	1	0.01	0.02	0.82
29	DESOA3	DIESEL-SOA	HEAT	0.	1879.	8786.	640.	3172.	930.	0.	-9874.	8786.	DISTILLA	-1088.	1	0.18	0.36	0.07
29	DESOA3	DIESEL-SOA	POWR	0.	7.	33.	2.	12.	4.	750.	0.	783.	RESIDUAL	783.	1	0.01	0.02	0.82
29	DESOA3	DIESEL-SOA	HEAT	0.	1879.	8786.	640.	3172.	930.	0.	-9874.	8786.	RESIDUAL	-1088.	1	0.18	0.36	0.07



I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28731 MW 3.50 PROCESS MILLIONS BTU/HR 640.0 PROCESS TEMP(F) 598. PRODUCT AMMONIA-SYNT HGURS PER YEAR 8400.

UTILITY FUEL		COAL		POWER TO HEAT RATIO 0.019 WASTE FUEL EQV BTU*10**6= 0. HOT WATER BTU*10**6= 0.										NET=	FAIL	FESR	POWER	HEAT
USED	NO-NET	SAVED=	FUEL	COGEN	COGEN	COGEN	COGEN	AUX	UTILIT	TOTAL	SITE	TOTAL+				FACTR	FACTR	
10**6	10**6	10**6	10**6	10**6	10**6	10**6	10**6	10**6	10**6	10**6	10**6	10**6	10**6					
BTU/HR	BTU/HR	BTU/HR	BTU/HR	BTU/HR	BTU/HR	BTU/HR	BTU/HR	BTU/HR	BTU/HR	BTU/HR	BTU/HR	BTU/HR	BTU/HR					
30 DESO2 DIESEL-SOA POWR	0.	13.	33.	7.	12.	4.	744.	0.	777.	DISTILLA	777.	777.	1	0.02	0.02	0.82		
30 DESO2 DIESEL-SOA HEAT	0.	1126.	2909.	640.	1050.	308.	0.	-3244.	2909.	DISTILLA	-335.	1	0.28	0.36	0.22			
30 DESO2 DIESEL-SOA POWR	0.	13.	33.	7.	12.	4.	744.	0.	777.	RESIDUAL	777.	777.	1	0.02	0.02	0.82		
30 DESO2 DIESEL-SOA HEAT	0.	1126.	2909.	640.	1050.	308.	0.	-3244.	2909.	RESIDUAL	-335.	1	0.28	0.36	0.22			
31 DESO1 DIESEL-SOA POWR	0.	20.	33.	13.	12.	4.	737.	0.	770.	DISTILLA	770.	770.	1	0.03	0.02	0.83		
31 DESO1 DIESEL-SOA HEAT	0.	957.	1596.	640.	576.	169.	0.	-1783.	1596.	DISTILLA	-167.	1	0.37	0.36	0.40			
31 DESO1 DIESEL-SOA POWR	0.	20.	33.	13.	12.	4.	737.	0.	770.	RESIDUAL	770.	770.	1	0.03	0.02	0.83		
31 DESO1 DIESEL-SOA HEAT	0.	957.	1596.	640.	576.	169.	0.	-1783.	1596.	RESIDUAL	-167.	1	0.37	0.36	0.40			
32 GTSO2 GT-HRSG-10 POWR	0.	18.	41.	19.	12.	4.	731.	0.	772.	DISTILLA	772.	772.	10	0.02	0.02	0.83		
32 GTSO2 GT-HRSG-10 HEAT	0.	630.	1407.	640.	411.	120.	0.	-1246.	1407.	DISTILLA	160.	0	0.31	0.29	0.45			
33 GTRA08 GT-85RE-08 POWR	0.	12.	33.	7.	12.	4.	745.	0.	778.	DISTILLA	778.	778.	10	0.01	0.02	0.82		
33 GTRA08 GT-85RE-08 HEAT	0.	1118.	3161.	640.	1128.	331.	0.	-3489.	3161.	DISTILLA	-328.	0	0.26	0.36	0.20			
34 GTRA12 GT-85RE-12 POWR	0.	13.	33.	8.	12.	4.	744.	0.	777.	DISTILLA	777.	777.	10	0.02	0.02	0.82		
34 GTRA12 GT-85RE-12 HEAT	0.	1075.	2710.	640.	970.	284.	0.	-2994.	2710.	DISTILLA	-284.	0	0.28	0.36	0.24			
35 GTRA16 GT-85RE-16 POWR	0.	14.	34.	9.	12.	4.	742.	0.	776.	DISTILLA	776.	776.	10	0.02	0.02	0.82		
35 GTRA16 GT-85RE-16 HEAT	0.	968.	2374.	640.	829.	243.	0.	-2552.	2374.	DISTILLA	-178.	0	0.29	0.35	0.27			
36 GTR208 GT-60RE-08 POWR	0.	15.	37.	13.	12.	4.	738.	0.	775.	DISTILLA	775.	775.	10	0.02	0.02	0.83		
36 GTR208 GT-60RE-08 HEAT	0.	753.	1893.	640.	606.	178.	0.	-1856.	1893.	DISTILLA	37.	0	0.28	0.32	0.34			
37 GTR212 GT-60RE-12 POWR	0.	15.	36.	12.	12.	4.	739.	0.	775.	DISTILLA	775.	775.	10	0.02	0.02	0.83		
37 GTR212 GT-60RE-12 HEAT	0.	815.	1983.	640.	654.	192.	0.	-2007.	1983.	DISTILLA	-25.	0	0.29	0.33	0.32			
38 GTR216 GT-60RE-16 POWR	0.	15.	35.	11.	12.	4.	740.	0.	775.	DISTILLA	775.	775.	10	0.02	0.02	0.83		
38 GTR216 GT-60RE-16 HEAT	0.	860.	2021.	640.	681.	200.	0.	-2091.	2021.	DISTILLA	-70.	0	0.30	0.34	0.32			
39 GTRW08 GT-85RE-08 POWR	0.	10.	34.	6.	12.	4.	746.	0.	780.	DISTILLA	780.	780.	10	0.01	0.02	0.82		
39 GTRW08 GT-85RE-08 HEAT	0.	1098.	3559.	640.	1249.	366.	0.	-3867.	3559.	DISTILLA	-307.	0	0.24	0.35	0.18			
40 GTRW12 GT-85RE-12 POWR	0.	12.	33.	7.	12.	4.	745.	0.	778.	DISTILLA	778.	778.	10	0.02	0.02	0.82		
40 GTRW12 GT-85RE-12 HEAT	0.	1183.	3124.	640.	1137.	333.	0.	-3516.	3124.	DISTILLA	-392.	0	0.27	0.36	0.20			

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 185

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28731 MW 3.50 PROCESS MILLIONS BTU/HR 640.0 PROCESS TEMP(F) 598. PRODUCT AMMONIA-SYNT HOURS PER YEAR 8400.

UTILITY FUEL		COAL		POWER TO HEAT RATIO 0.019 WASTE FUEL EQV BTU*10**6= 0. HOT WATER BTU*10**6= 0.												
		WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41	GTRW16 GT-85RE-16 POWR	0.	13.	33.	8.	12.	4.	744.	0.	777.	DISTILLA	777.	10	0.02	0.02	0.82
41	GTRW16 GT-85RE-16 HEAT	0.	1063.	2680.	640.	957.	280.	0.	-2953.	2680.	DISTILLA	-273.	0	0.28	0.36	0.24
42	GTR308 GT-60RE-08 POWR	0.	10.	39.	9.	12.	4.	742.	0.	781.	DISTILLA	781.	10	0.01	0.02	0.82
42	GTR308 GT-60RE-08 HEAT	0.	670.	2651.	640.	822.	241.	0.	-2531.	2651.	DISTILLA	120.	0	0.20	0.31	0.24
43	GTR312 GT-60RE-12 POWR	0.	15.	35.	11.	12.	4.	741.	0.	775.	DISTILLA	775.	10	0.02	0.02	0.83
43	GTR312 GT-60RE-12 HEAT	0.	899.	2123.	640.	726.	213.	0.	-2231.	2123.	DISTILLA	-109.	0	0.30	0.34	0.30
44	GTR316 GT-60RE-16 POWR	0.	15.	35.	11.	12.	4.	740.	0.	776.	DISTILLA	776.	10	0.02	0.02	0.83
44	GTR316 GT-60RE-16 HEAT	0.	877.	2095.	640.	710.	208.	0.	-2182.	2095.	DISTILLA	-87.	0	0.30	0.34	0.31
45	FCPADS FUEL-CL-PH POWR	0.	12.	31.	5.	12.	4.	747.	0.	778.	DISTILLA	778.	0	0.02	0.02	0.82
45	FCPADS FUEL-CL-PH HEAT	0.	1459.	3765.	640.	1431.	419.	0.	-4433.	3765.	DISTILLA	-669.	0	0.28	0.38	0.17
46	FCMCDS FUEL-CL-MO POWR	0.	16.	29.	7.	12.	4.	745.	0.	774.	DISTILLA	774.	10	0.02	0.02	0.83
46	FCMCDS FUEL-CL-MO HEAT	0.	1543.	2747.	640.	1132.	332.	0.	-3499.	2747.	DISTILLA	-752.	0	0.36	0.41	0.23

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28741 MW 4.00 PROCESS MILLIONS BTU/HR 92.0 PROCESS TEMP(F) 353. PRODUCT PHOS-ACID+SU HOURS PER YEAR 7900.

POWER TO HEAT RATIO 0.148

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL COAL

	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
0 ONOCGN N O C O G O N	0.	0.	0.	0.	0.	0.	108.	43.	108.	COAL-AFB	151.	0	0.	0.09	0.61
1 STM141 STM-TURB-1 POWR	0.	27.	79.	54.	14.	4.	45.	0.	124.	RESIDUAL	124.	10	0.18	0.11	0.74
1 STM141 STM-TURB-1 HEAT	0.	46.	136.	92.	23.	7.	0.	-31.	136.	RESIDUAL	105.	10	0.25	0.17	0.68
1 STM141 STM-TURB-1 POWR	0.	27.	79.	54.	14.	4.	45.	0.	124.	COAL-FGD	124.	10	0.18	0.11	0.74
1 STM141 STM-TURB-1 HEAT	0.	46.	136.	92.	23.	7.	0.	-31.	136.	COAL-FGD	105.	10	0.25	0.17	0.68
1 STM141 STM-TURB-1 POWR	0.	27.	79.	54.	14.	4.	45.	0.	124.	COAL-AFB	124.	10	0.18	0.11	0.74
1 STM141 STM-TURB-1 HEAT	0.	46.	136.	92.	23.	7.	0.	-31.	136.	COAL-AFB	105.	10	0.25	0.17	0.68
2 STM088 STM-TURB-8 POWR	0.	27.	98.	70.	14.	4.	26.	0.	124.	RESIDUAL	124.	10	0.18	0.11	0.74
2 STM088 STM-TURB-8 HEAT	0.	35.	129.	92.	18.	5.	0.	-13.	129.	RESIDUAL	116.	0	0.21	0.14	0.71
2 STM088 STM-TURB-8 POWR	0.	27.	98.	70.	14.	4.	26.	0.	124.	COAL-FGD	124.	10	0.18	0.11	0.74
2 STM088 STM-TURB-8 HEAT	0.	35.	129.	92.	18.	5.	0.	-13.	129.	COAL-FGD	116.	0	0.21	0.14	0.71
2 STM088 STM-TURB-8 POWR	0.	27.	98.	70.	14.	4.	26.	0.	124.	COAL-AFB	124.	10	0.18	0.11	0.74
2 STM088 STM-TURB-8 HEAT	0.	35.	129.	92.	18.	5.	0.	-13.	129.	COAL-AFB	116.	0	0.21	0.14	0.71
3 PFBSTM PFB-STMTB- POWR	0.	26.	58.	35.	14.	4.	67.	0.	125.	COAL-PFB	125.	10	0.17	0.11	0.74
3 PFBSTM PFB-STMTB- HEAT	0.	68.	151.	92.	36.	10.	0.	-69.	151.	COAL-PFB	82.	10	0.31	0.24	0.61
4 TISTMT TI-STMTB-1 POWR	0.	26.	48.	27.	14.	4.	77.	0.	125.	RESIDUAL	125.	10	0.17	0.11	0.74
4 TISTMT TI-STMTB-1 HEAT	0.	89.	164.	92.	47.	14.	0.	-103.	164.	RESIDUAL	61.	0	0.35	0.28	0.56
4 TISTMT TI-STMTB-1 POWR	0.	26.	48.	27.	14.	4.	77.	0.	125.	COAL	125.	10	0.17	0.11	0.74
4 TISTMT TI-STMTB-1 HEAT	0.	89.	164.	92.	47.	14.	0.	-103.	164.	COAL	61.	0	0.35	0.28	0.56
5 TIHRSG THERMIONIC POWR	0.	20.	97.	63.	14.	4.	34.	0.	131.	RESIDUAL	131.	0	0.13	0.10	0.70
5 TIHRSG THERMIONIC HEAT	0.	29.	142.	92.	20.	6.	0.	-20.	142.	RESIDUAL	122.	0	0.17	0.14	0.65
5 TIHRSG THERMIONIC POWR	0.	20.	97.	63.	14.	4.	34.	0.	131.	COAL	131.	0	0.13	0.10	0.70
5 TIHRSG THERMIONIC HEAT	0.	29.	142.	92.	20.	6.	0.	-20.	142.	COAL	122.	0	0.17	0.14	0.65
6 STIRL STIRLING-1 POWR	0.	19.	54.	25.	14.	4.	78.	0.	132.	DISTILLA	132.	0	0.13	0.10	0.70
6 STIRL STIRLING-1 HEAT	0.	69.	194.	92.	49.	15.	0.	-112.	194.	DISTILLA	82.	0	0.26	0.26	0.47

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28741 MW 4.00 PROCESS MILLIONS BTU/HR 92.0 PROCESS TEMP(F) 353. PRODUCT PHOS-ACID+SU HOURS PER YEAR 7900.

POWER TO HEAT RATIO 0.148

WASTE FUEL EQV BTU\*10\*\*6= 0.

HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	SAVED= FUEL NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
6 STIRL	STIRLING-1 POWR	0.	19.	54.	25.	14.	4.	78.	0.	132.	RESIDUAL	132.	0	0.13	0.10	0.70
6 STIRL	STIRLING-1 HEAT	0.	69.	194.	92.	49.	15.	0.	-112.	194.	RESIDUAL	82.	0	0.26	0.26	0.47
6 STIRL	STIRLING-1 POWR	0.	19.	54.	25.	14.	4.	78.	0.	132.	COAL	132.	0	0.13	0.10	0.70
6 STIRL	STIRLING-1 HEAT	0.	69.	194.	92.	49.	15.	0.	-112.	194.	COAL	82.	0	0.26	0.26	0.47
7 HEGT85	HELIUM-GT- POWR	0.	7.	43.	6.	14.	4.	101.	0.	144.	COAL-AFB	144.	10	0.05	0.09	0.64
7 HEGT85	HELIUM-GT- HEAT	0.	110.	668.	92.	214.	63.	0.	-627.	668.	COAL-AFB	41.	0	0.14	0.32	0.14
8 HEGT60	HELIUM-GT- POWR	0.	9.	53.	16.	14.	4.	89.	0.	142.	COAL-AFB	142.	10	0.06	0.10	0.65
8 HEGT60	HELIUM-GT- HEAT	0.	50.	304.	92.	79.	23.	0.	-203.	304.	COAL-AFB	101.	10	0.14	0.26	0.30
9 HEGT00	HELIUM-GT- POWR	0.	10.	78.	38.	14.	4.	63.	0.	141.	COAL-AFB	141.	10	0.07	0.10	0.65
9 HEGT00	HELIUM-GT- HEAT	0.	24.	187.	92.	33.	10.	0.	-60.	187.	COAL-AFB	127.	10	0.11	0.18	0.49
10 FCMCCL	FUEL-CL-MO POWR	0.	23.	45.	21.	14.	4.	83.	0.	128.	COAL	128.	10	0.15	0.11	0.72
10 FCMCCL	FUEL-CL-MO HEAT	0.	99.	194.	92.	59.	17.	0.	-142.	194.	COAL	52.	10	0.34	0.30	0.47
11 FCSTCL	FUEL-CL-ST POWR	0.	24.	34.	13.	14.	4.	93.	0.	127.	COAL	127.	10	0.16	0.11	0.72
11 FCSTCL	FUEL-CL-ST HEAT	0.	169.	243.	92.	37.	28.	0.	-260.	243.	COAL	-18.	10	0.41	0.40	0.38
12 IGGTST	INT-GAS-GT POWR	0.	19.	45.	18.	14.	4.	87.	0.	132.	COAL	132.	10	0.13	0.10	0.70
12 IGGTST	INT-GAS-GT HEAT	0.	96.	226.	92.	69.	20.	0.	-172.	226.	COAL	54.	10	0.30	0.30	0.41
13 GTSOAR	GT-HRSG-10 POWR	0.	19.	47.	20.	14.	4.	85.	0.	132.	RESIDUAL	132.	10	0.13	0.10	0.70
13 GTSOAR	GT-HRSG-10 HEAT	0.	88.	215.	92.	62.	18.	0.	-152.	215.	RESIDUAL	63.	0	0.29	0.29	0.43
14 GTAC08	GT-HRSG-08 POWR	0.	23.	51.	26.	14.	4.	78.	0.	128.	RESIDUAL	128.	10	0.15	0.11	0.72
14 GTAC08	GT-HRSG-08 HEAT	0.	80.	179.	92.	48.	14.	0.	-108.	179.	RESIDUAL	71.	0	0.31	0.27	0.51
15 GTAC12	GT-HRSG-12 POWR	0.	22.	45.	21.	14.	4.	84.	0.	129.	RESIDUAL	129.	10	0.15	0.11	0.72
15 GTAC12	GT-HRSG-12 HEAT	0.	99.	198.	92.	60.	18.	0.	-146.	198.	RESIDUAL	52.	0	0.33	0.31	0.46
16 GTAC16	GT-HRSG-16 POWR	0.	22.	42.	18.	14.	4.	87.	0.	129.	RESIDUAL	129.	10	0.15	0.11	0.71
16 GTAC16	GT-HRSG-16 HEAT	0.	110.	212.	92.	68.	20.	0.	-171.	212.	RESIDUAL	41.	0	0.34	0.32	0.43
17 GTWC16	GT-HRSG-16 POWR	0.	20.	43.	18.	14.	4.	38.	0.	131.	RESIDUAL	131.	10	0.13	0.10	0.70
17 GTWC16	GT-HRSG-16 HEAT	0.	105.	227.	92.	72.	21.	0.	-181.	227.	RESIDUAL	46.	0	0.32	0.32	0.40

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28741 MW 4.00 PROCESS MILLIONS BTU/HR 92.0 PROCESS TEMP(F) 353. PRODUCT PHOS-ACID+SU HOURS PER YEAR 7900.

		POWER TO HEAT RATIO 0.148										WASTE FUEL EQV BTU*10**6= 0.		HOT WATER BTU*10**6= 0.		
UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
18	CC1626 GTST-16/26 POWR	0.	20.	35.	10.	14.	4.	96.	0.	131.	RESIDUAL	131.	10	0.13	0.10	0.70
18	CC1626 GTST-16/26 HEAT	0.	177.	310.	92.	121.	36.	0.	-336.	310.	RESIDUAL	-26.	0	0.36	0.39	0.30
19	CC1622 GTST-16/22 POWR	0.	21.	35.	11.	14.	4.	95.	0.	130.	RESIDUAL	130.	10	0.14	0.10	0.71
19	CC1622 GTST-16/22 HEAT	0.	167.	283.	92.	109.	32.	0.	-299.	283.	RESIDUAL	-16.	0	0.37	0.39	0.33
20	CC1222 GTST-12/22 POWR	0.	21.	35.	12.	14.	4.	95.	0.	130.	RESIDUAL	130.	10	0.14	0.11	0.71
20	CC1222 GTST-12/22 HEAT	0.	168.	280.	92.	109.	32.	0.	-298.	280.	RESIDUAL	-17.	0	0.37	0.39	0.33
21	CC0822 GTST-08/22 POWR	0.	23.	37.	14.	14.	4.	91.	0.	128.	RESIDUAL	128.	10	0.15	0.11	0.72
21	CC0822 GTST-08/22 HEAT	0.	144.	237.	92.	87.	26.	0.	-231.	237.	RESIDUAL	6.	0	0.38	0.37	0.39
22	STIG15 STIG-15-16 POWR	0.	7.	36.	0.	14.	4.	108.	0.	144.	RESIDUAL	144.	10	0.05	0.10	0.64
22	STIG15 STIG-15-16 HEAT	0.	1457.	7077.	92.	2696.	790.	0.	-8383.	7077.	RESIDUAL	-1306.	0	0.17	0.38	0.01
23	STIG10 STIG-10-16 POWR	0.	11.	38.	5.	14.	4.	102.	0.	140.	RESIDUAL	140.	10	0.07	0.10	0.66
23	STIG10 STIG-10-16 HEAT	0.	193.	694.	92.	249.	73.	0.	-737.	694.	RESIDUAL	-42.	0	0.22	0.36	0.13
24	STIG1S STIG-1S-16 POWR	0.	12.	41.	9.	14.	4.	98.	0.	139.	RESIDUAL	139.	10	0.08	0.10	0.66
24	STIG1S STIG-1S-16 HEAT	0.	129.	436.	92.	146.	43.	0.	-415.	436.	RESIDUAL	22.	0	0.23	0.34	0.21
25	DEADV3 DIESEL-ADV POWR	0.	15.	37.	8.	14.	4.	99.	0.	136.	RESIDUAL	136.	0	0.10	0.10	0.68
25	DEADV3 DIESEL-ADV HEAT	0.	178.	437.	92.	162.	48.	0.	-464.	437.	RESIDUAL	-27.	0	0.29	0.37	0.21
26	DEADV2 DIESEL-ADV POWR	0.	17.	37.	9.	14.	4.	97.	0.	134.	RESIDUAL	134.	1	0.11	0.10	0.69
26	DEADV2 DIESEL-ADV HEAT	0.	166.	362.	92.	134.	39.	0.	-377.	362.	RESIDUAL	-15.	1	0.31	0.37	0.25
27	DEADV1 DIESEL-ADV POWR	0.	23.	37.	14.	14.	4.	91.	0.	128.	RESIDUAL	128.	1	0.15	0.11	0.72
27	DEADV1 DIESEL-ADV HEAT	0.	146.	235.	92.	87.	26.	0.	-230.	235.	RESIDUAL	5.	1	0.38	0.37	0.39
28	DEHTPM ADV-DIESEL POWR	0.	22.	41.	18.	14.	4.	87.	0.	129.	RESIDUAL	129.	0	0.15	0.11	0.72
28	DEHTPM ADV-DIESEL HEAT	0.	116.	214.	92.	71.	21.	0.	-180.	214.	RESIDUAL	35.	0	0.35	0.33	0.43
29	DES0A3 DIESEL-S0A POWR	0.	13.	38.	7.	14.	4.	100.	0.	138.	DISTILLA	138.	0	0.08	0.10	0.67
29	DES0A3 DIESEL-S0A HEAT	0.	175.	521.	92.	188.	55.	0.	-545.	521.	DISTILLA	-24.	0	0.25	0.36	0.18
29	DES0A3 DIESEL-S0A POWR	0.	13.	38.	7.	14.	4.	100.	0.	138.	RESIDUAL	138.	0	0.08	0.10	0.67
29	DES0A3 DIESEL-S0A HEAT	0.	175.	521.	92.	188.	55.	0.	-545.	521.	RESIDUAL	-24.	0	0.25	0.36	0.18

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28741 MW 4.00 PROCESS MILLIONS BTU/HR 92.0 PROCESS TEMP(F) 353. PRODUCT PHOS-ACID+SU HOURS PER YEAR 7900.

POWER TO HEAT RATIO 0.148

WASTE FUEL EQV BTU\*10\*\*6= 0.

HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
30 DES0A2 DIESEL-S0A POWR		0.	15.	38.	8.	14.	4.	98.	0.	136.	DISTILLA	136.	1	0.10	0.10	0.68
30 DES0A2 DIESEL-S0A HEAT		0.	162.	418.	92.	151.	44.	0.	-429.	418.	DISTILLA	-11.	1	0.28	0.36	0.22
30 DES0A2 DIESEL-S0A POWR		0.	15.	38.	8.	14.	4.	98.	0.	136.	RESIDUAL	136.	1	0.10	0.10	0.68
30 DES0A2 DIESEL-S0A HEAT		0.	162.	418.	92.	151.	44.	0.	-429.	418.	RESIDUAL	-11.	1	0.28	0.36	0.22
31 DES0A1 DIESEL-S0A POWR		0.	23.	38.	15.	14.	4.	90.	0.	128.	DISTILLA	128.	1	0.15	0.11	0.72
31 DES0A1 DIESEL-S0A HEAT		0.	138.	229.	92.	83.	24.	0.	-216.	229.	DISTILLA	13.	1	0.37	0.36	0.40
31 DES0A1 DIESEL-S0A POWR		0.	23.	38.	15.	14.	4.	90.	0.	128.	RESIDUAL	128.	1	0.15	0.11	0.72
31 DES0A1 DIESEL-S0A HEAT		0.	138.	229.	92.	83.	24.	0.	-216.	229.	RESIDUAL	13.	1	0.37	0.36	0.40
32 GTS0AD GT-HRSG-10 POWR		0.	21.	47.	22.	14.	4.	83.	0.	130.	DISTILLA	130.	10	0.14	0.11	0.71
32 GTS0AD GT-HRSG-10 HEAT		0.	91.	199.	92.	58.	17.	0.	-139.	199.	DISTILLA	60.	0	0.31	0.29	0.46
33 GTRA08 GT-85RE-08 POWR		0.	20.	38.	13.	14.	4.	93.	0.	131.	DISTILLA	131.	10	0.13	0.10	0.70
33 GTRA08 GT-85RE-08 HEAT		0.	139.	269.	92.	96.	28.	0.	-258.	269.	DISTILLA	12.	0	0.34	0.36	0.34
34 GTRA12 GT-85RE-12 POWR		0.	20.	38.	13.	14.	4.	93.	0.	131.	DISTILLA	131.	10	0.13	0.10	0.70
34 GTRA12 GT-85RE-12 HEAT		0.	139.	262.	92.	94.	28.	0.	-251.	262.	DISTILLA	12.	0	0.35	0.36	0.35
35 GTRA16 GT-85RE-16 POWR		0.	20.	39.	14.	14.	4.	91.	0.	130.	DISTILLA	130.	10	0.14	0.10	0.71
35 GTRA16 GT-85RE-16 HEAT		0.	131.	251.	92.	88.	26.	0.	-231.	251.	DISTILLA	20.	0	0.34	0.35	0.37
36 GTR208 GT-60RE-08 POWR		0.	20.	43.	17.	14.	4.	88.	0.	131.	DISTILLA	131.	10	0.13	0.10	0.70
36 GTR208 GT-60RE-08 HEAT		0.	108.	227.	92.	73.	21.	0.	-184.	227.	DISTILLA	43.	0	0.32	0.32	0.41
37 GTR212 GT-60RE-12 POWR		0.	20.	41.	16.	14.	4.	89.	0.	131.	DISTILLA	131.	10	0.13	0.10	0.70
37 GTR212 GT-60RE-12 HEAT		0.	116.	236.	92.	78.	23.	0.	-201.	236.	DISTILLA	35.	0	0.33	0.33	0.39
38 GTR216 GT-60RE-16 POWR		0.	21.	40.	16.	14.	4.	90.	0.	130.	DISTILLA	130.	10	0.14	0.10	0.71
38 GTR216 GT-60RE-16 HEAT		0.	121.	237.	92.	80.	23.	0.	-207.	237.	DISTILLA	30.	0	0.34	0.34	0.39
39 GTRW08 GT-85RE-08 POWR		0.	17.	39.	11.	14.	4.	95.	0.	134.	DISTILLA	134.	10	0.11	0.10	0.69
39 GTRW08 GT-85RE-08 HEAT		0.	140.	327.	92.	115.	34.	0.	-316.	327.	DISTILLA	11.	0	0.30	0.35	0.28
40 GTRW12 GT-85RE-12 POWR		0.	18.	37.	11.	14.	4.	96.	0.	133.	DISTILLA	133.	10	0.12	0.10	0.69
40 GTRW12 GT-85RE-12 HEAT		0.	152.	321.	92.	117.	34.	0.	-322.	321.	DISTILLA	-1.	0	0.32	0.36	0.29

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28741 MW 4.00 PROCESS MILLIONS BTU/HR 92.0 PROCESS TEMP(F) 353. PRODUCT PHOS-ACID+SU HOURS PER YEAR 7900.

POWER TO HEAT RATIO 0.148

UTILITY FUEL COAL

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

			WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
41	GTRW16	GT-85RE-16	POWR	0.	18.	38.	12.	14.	4.	95.	0.	133.	DISTILLA	133.	10	0.12	0.10	0.69
41	GTRW16	GT-85RE-16	HEAT	0.	143.	303.	92.	108.	32.	0.	-296.	303.	DISTILLA	8.	0	0.32	0.36	0.30
42	GTR308	GT-60RE-08	POWR	0.	15.	44.	14.	14.	4.	91.	0.	135.	DISTILLA	135.	10	0.10	0.10	0.68
42	GTR308	GT-60RE-08	HEAT	0.	99.	283.	92.	88.	26.	0.	-231.	283.	DISTILLA	51.	0	0.26	0.31	0.33
43	GTR312	GT-60RE-12	POWR	0.	18.	40.	13.	14.	4.	93.	0.	133.	DISTILLA	133.	10	0.12	0.10	0.69
43	GTR312	GT-60RE-12	HEAT	0.	127.	276.	92.	94.	28.	0.	-252.	276.	DISTILLA	24.	0	0.32	0.34	0.33
44	GTR316	GT-60RE-16	POWR	0.	18.	40.	14.	14.	4.	92.	0.	133.	DISTILLA	133.	10	0.12	0.10	0.69
44	GTR316	GT-60RE-16	HEAT	0.	125.	274.	92.	93.	27.	0.	-248.	274.	DISTILLA	26.	0	0.31	0.34	0.34
45	FCPADS	FUEL-CL-PH	POWR	0.	14.	36.	6.	14.	4.	101.	0.	137.	DISTILLA	137.	0	0.09	0.10	0.67
45	FCPADS	FUEL-CL-PH	HEAT	0.	210.	541.	92.	206.	60.	0.	-600.	541.	DISTILLA	-59.	0	0.28	0.38	0.17
46	FCMCDS	FUEL-CL-MO	POWR	0.	19.	33.	8.	14.	4.	99.	0.	132.	DISTILLA	132.	10	0.12	0.10	0.70
46	FCMCDS	FUEL-CL-MO	HEAT	0.	222.	395.	92.	163.	48.	0.	-466.	395.	DISTILLA	-71.	0	0.36	0.41	0.23

I&SE\_PEO\_ADV\_DESIGN\_ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28951 MW 4.00 PROCESS MILLIONS BTU/HR 20.0 PROCESS TEMP(F) 298. PRODUCT CARBON-BLACK HOURS PER YEAR 7900.

UTILITY FUEL COAL POWER TO HEAT RATIO 0.682 WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

	WASTE FUEL USED 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN ELECT 10**6 BTU/HR	AUX BOILER 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL* UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR
0 ONCOGN N O C O G O N	0.	0.	0.	0.	0.	0.	24.	43.	24. RESIDUAL	66.	0	0.	0.21
1 STM141 STM-TURB-1 POWR	0.	-14.	81.	55.	14.	-41.	0.	0.	81. RESIDUAL	81.	10	-0.22	0.17
1 STM141 STM-TURB-1 HEAT	0.	10.	29.	20.	5.	0.	27.	27.	29. RESIDUAL	56.	10	0.15	0.09
1 STM141 STM-TURB-1 POWR	0.	-14.	81.	55.	14.	-41.	0.	0.	81. COAL-FGD	81.	10	-0.22	0.17
1 STM141 STM-TURB-1 HEAT	0.	10.	29.	20.	5.	0.	27.	27.	29. COAL-FGD	56.	10	0.15	0.09
1 STM141 STM-TURB-1 POWR	0.	-14.	81.	55.	14.	-41.	0.	0.	81. COAL-AFB	81.	10	-0.22	0.17
1 STM141 STM-TURB-1 HEAT	0.	10.	29.	20.	5.	0.	27.	27.	29. COAL-AFB	56.	10	0.15	0.09
2 STM088 STM-TURB-8 POWR	0.	-35.	101.	72.	14.	-61.	0.	0.	101. RESIDUAL	101.	10	-0.52	0.14
2 STM088 STM-TURB-8 HEAT	0.	7.	28.	20.	4.	0.	31.	31.	28. RESIDUAL	59.	10	0.11	0.06
2 STM088 STM-TURB-8 POWR	0.	-35.	101.	72.	14.	-61.	0.	0.	101. COAL-FGD	101.	10	-0.52	0.14
2 STM088 STM-TURB-8 HEAT	0.	7.	28.	20.	4.	0.	31.	31.	28. COAL-FGD	59.	10	0.11	0.06
2 STM088 STM-TURB-8 POWR	0.	-35.	101.	72.	14.	-61.	0.	0.	101. COAL-AFB	101.	10	-0.52	0.14
2 STM088 STM-TURB-8 HEAT	0.	7.	28.	20.	4.	0.	31.	31.	28. COAL-AFB	59.	10	0.11	0.06
3 PFBSTM PFB-STMTB- POWR	0.	8.	59.	36.	14.	-19.	0.	0.	59. COAL-PFB	59.	10	0.11	0.23
3 PFBSTM PFB-STMTB- HEAT	0.	15.	33.	20.	8.	0.	19.	19.	33. COAL-PFB	52.	10	0.22	0.15
4 T1STMT T1-STMTB-1 POWR	0.	18.	49.	27.	14.	-9.	0.	0.	49. RESIDUAL	49.	10	0.26	0.28
4 T1STMT T1-STMTB-1 HEAT	0.	19.	36.	20.	10.	0.	11.	11.	36. RESIDUAL	47.	10	0.29	0.21
4 T1STMT T1-STMTB-1 POWR	0.	18.	49.	27.	14.	-9.	0.	0.	49. COAL	49.	10	0.26	0.28
4 T1STMT T1-STMTB-1 HEAT	0.	19.	36.	20.	10.	0.	11.	11.	36. COAL	47.	10	0.29	0.21
5 T1HRSG THERMIONIC POWR	0.	-31.	97.	65.	14.	-53.	0.	0.	97. RESIDUAL	97.	0	-0.47	0.14
5 T1HRSG THERMIONIC HEAT	0.	7.	30.	20.	4.	0.	29.	29.	30. RESIDUAL	59.	10	0.10	0.07
5 T1HRSG THERMIONIC POWR	0.	-31.	97.	65.	14.	-53.	0.	0.	97. COAL	97.	0	-0.47	0.14
5 T1HRSG THERMIONIC HEAT	0.	7.	30.	20.	4.	0.	29.	29.	30. COAL	59.	10	0.10	0.07
6 STIRL STIRLING-1 POWR	0.	15.	51.	24.	14.	-4.	0.	0.	51. DISTILLA	51.	0	0.23	0.27
6 STIRL STIRLING-1 HEAT	0.	16.	43.	20.	12.	0.	7.	7.	43. DISTILLA	50.	0	0.25	0.23



I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28951 MW 4.00 PROCESS MILLIONS BTU/HR 20.0 PROCESS TEMP(F) 298. PRODUCT CARBON-BLACK HOURS PER YEAR 7900.

UTILITY FUEL		COAL	POWER TO HEAT RATIO 0.682										WASTE FUEL EQV BTU*10**6= 0. HOT WATER BTU*10**6= 0.					
			WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
6	STIRL	STIRLING-1	POWR	0.	15.	51.	24.	14.	4.	-4.	0.	51.	RESIDUAL	51.	0	0.23	0.27	0.39
6	STIRL	STIRLING-1	HEAT	0.	16.	43.	20.	12.	3.	0.	7.	43.	RESIDUAL	50.	0	0.25	0.23	0.40
6	STIRL	STIRLING-1	POWR	0.	15.	51.	24.	14.	4.	-4.	0.	51.	COAL	51.	0	0.23	0.27	0.39
6	STIRL	STIRLING-1	HEAT	0.	16.	43.	20.	12.	3.	0.	7.	43.	COAL	50.	0	0.25	0.23	0.40
7	HEGT85	HELIUM-GT-	POWR	0.	11.	43.	9.	14.	4.	13.	0.	55.	COAL-AFB	55.	10	0.16	0.25	0.36
7	HEGT85	HELIUM-GT-	HEAT	0.	24.	94.	20.	30.	9.	0.	-51.	94.	COAL-AFB	42.	10	0.20	0.32	0.21
8	HEGT60	HELIUM-GT-	POWR	0.	12.	53.	18.	14.	4.	2.	0.	55.	COAL-AFB	55.	10	0.17	0.25	0.37
8	HEGT60	HELIUM-GT-	HEAT	0.	13.	57.	20.	15.	4.	0.	-4.	57.	COAL-AFB	54.	10	0.18	0.26	0.35
9	HEGT00	HELIUM-GT-	POWR	0.	-11.	73.	39.	14.	4.	-23.	0.	78.	COAL-AFB	78.	10	-0.17	0.18	0.26
9	HEGT00	HELIUM-GT-	HEAT	0.	6.	40.	20.	7.	2.	0.	21.	40.	COAL-AFB	60.	10	0.09	0.12	0.33
10	FCMCCL	FUEL-CL-MO	POWR	0.	21.	45.	21.	14.	4.	-2.	0.	45.	COAL	45.	10	0.32	0.30	0.45
10	FCMCCL	FUEL-CL-MO	HEAT	0.	21.	42.	20.	13.	4.	0.	3.	42.	COAL	45.	10	0.32	0.29	0.45
11	FCSTCL	FUEL-CL-ST	POWR	0.	24.	34.	13.	14.	4.	8.	0.	42.	COAL	42.	10	0.36	0.32	0.47
11	FCSTCL	FUEL-CL-ST	HEAT	0.	36.	52.	20.	21.	6.	0.	-23.	52.	COAL	30.	10	0.41	0.40	0.38
12	IGGTST	INT-GAS-GT	POWR	0.	19.	45.	19.	14.	4.	2.	0.	47.	COAL	47.	10	0.29	0.29	0.43
12	IGGTST	INT-GAS-GT	HEAT	0.	21.	49.	20.	15.	4.	0.	-3.	49.	COAL	46.	10	0.30	0.30	0.41
13	GTSOAR	GT-HRSG-10	POWR	0.	19.	47.	21.	14.	4.	-1.	0.	47.	RESIDUAL	47.	10	0.29	0.29	0.42
13	GTSOAR	GT-HRSG-10	HEAT	0.	19.	45.	20.	13.	4.	0.	2.	45.	RESIDUAL	47.	10	0.29	0.28	0.43
14	GTAC08	GT-HRSG-08	POWR	0.	16.	51.	26.	14.	4.	-7.	0.	51.	RESIDUAL	51.	10	0.24	0.27	0.40
14	GTAC08	GT-HRSG-08	HEAT	0.	17.	39.	20.	11.	3.	0.	10.	39.	RESIDUAL	49.	10	0.26	0.22	0.41
15	GTAC12	GT-HRSG-12	POWR	0.	21.	45.	21.	14.	4.	-1.	0.	45.	RESIDUAL	45.	10	0.32	0.31	0.45
15	GTAC12	GT-HRSG-12	HEAT	0.	22.	43.	20.	13.	4.	0.	2.	43.	RESIDUAL	45.	10	0.33	0.29	0.45
16	GTAC16	GT-HRSG-16	POWR	0.	22.	42.	19.	14.	4.	2.	0.	44.	RESIDUAL	44.	10	0.34	0.31	0.46
16	GTAC16	GT-HRSG-16	HEAT	0.	24.	45.	20.	15.	4.	0.	-3.	45.	RESIDUAL	42.	10	0.35	0.32	0.44
17	GTWC16	GT-HRSG-16	POWR	0.	20.	43.	18.	14.	4.	3.	0.	46.	RESIDUAL	46.	10	0.30	0.29	0.43
17	GTWC16	GT-HRSG-16	HEAT	0.	23.	50.	20.	16.	5.	0.	-6.	50.	RESIDUAL	43.	10	0.31	0.32	0.40

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 193

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28951 MW 4.00 PROCESS MILLIONS BTU/HR 20.0 PROCESS TEMP(F) 298. PRODUCT CARBON-BLACK HOURS PER YEAR 7900.

POWER TO HEAT RATIO 0.682

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

		UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
18	CC1626	GTST-16/26	POWR	0.	20.	35.	10.	14.	4.	11.	0.	46.	RESIDUAL	46.	10	0.30	0.29	0.43
18	CC1626	GTST-16/26	HEAT	0.	38.	67.	20.	26.	8.	0.	-39.	67.	RESIDUAL	28.	10	0.36	0.39	0.30
19	CC1622	GTST-16/22	POWR	0.	21.	35.	12.	14.	4.	10.	0.	45.	RESIDUAL	45.	10	0.32	0.30	0.44
19	CC1622	GTST-16/22	HEAT	0.	36.	61.	20.	24.	7.	0.	-31.	61.	RESIDUAL	30.	10	0.37	0.39	0.33
20	CC1222	GTST-12/22	POWR	0.	21.	35.	12.	14.	4.	10.	0.	45.	RESIDUAL	45.	10	0.32	0.30	0.44
20	CC1222	GTST-12/22	HEAT	0.	36.	61.	20.	23.	7.	0.	-31.	61.	RESIDUAL	30.	10	0.37	0.39	0.33
21	CC0822	GTST-08/22	POWR	0.	23.	37.	15.	14.	4.	6.	0.	44.	RESIDUAL	44.	10	0.34	0.31	0.46
21	CC0822	GTST-08/22	HEAT	0.	31.	51.	20.	19.	6.	0.	-16.	51.	RESIDUAL	35.	10	0.38	0.37	0.39
22	STIG15	STIG-15-16	POWR	0.	7.	36.	0.	14.	4.	23.	0.	59.	RESIDUAL	59.	10	0.11	0.23	0.34
22	STIG15	STIG-15-16	HEAT	0.	317.	1538.	20.	586.	172.	0.	-1789.	1538.	RESIDUAL	-251.	0	0.17	0.38	0.01
23	STIG10	STIG-10-16	POWR	0.	11.	38.	5.	14.	4.	18.	0.	56.	RESIDUAL	56.	10	0.16	0.25	0.36
23	STIG10	STIG-10-16	HEAT	0.	42.	151.	20.	54.	16.	0.	-127.	151.	RESIDUAL	24.	10	0.22	0.36	0.13
24	STIG1S	STIG-1S-16	POWR	0.	12.	41.	9.	14.	4.	13.	0.	54.	RESIDUAL	54.	10	0.18	0.25	0.37
24	STIG1S	STIG-1S-16	HEAT	0.	28.	95.	20.	32.	9.	0.	-57.	95.	RESIDUAL	38.	10	0.23	0.34	0.21
25	DEADV3	DIESEL-ADV	POWR	0.	16.	37.	9.	14.	4.	13.	0.	50.	RESIDUAL	50.	0	0.24	0.27	0.40
25	DEADV3	DIESEL-ADV	HEAT	0.	37.	86.	20.	32.	9.	0.	-57.	86.	RESIDUAL	29.	0	0.30	0.37	0.23
26	DEADV2	DIESEL-ADV	POWR	0.	17.	37.	9.	14.	4.	13.	0.	49.	RESIDUAL	49.	1	0.25	0.28	0.41
26	DEADV2	DIESEL-ADV	HEAT	0.	36.	79.	20.	29.	9.	0.	-49.	79.	RESIDUAL	30.	1	0.31	0.37	0.25
27	DEADV1	DIESEL-ADV	POWR	0.	23.	37.	14.	14.	4.	7.	0.	43.	RESIDUAL	43.	1	0.34	0.31	0.46
27	DEADV1	DIESEL-ADV	HEAT	0.	32.	51.	20.	19.	6.	0.	-17.	51.	RESIDUAL	34.	1	0.38	0.37	0.39
28	DEHTPM	ADV-DIESEL	POWR	0.	24.	39.	17.	14.	4.	4.	0.	43.	RESIDUAL	43.	0	0.36	0.32	0.47
28	DEHTPM	ADV-DIESEL	HEAT	0.	28.	46.	20.	16.	5.	0.	-8.	46.	RESIDUAL	38.	0	0.38	0.35	0.43
29	DES0A3	DIESEL-S0A	POWR	0.	14.	38.	8.	14.	4.	15.	0.	52.	DISTILLA	52.	0	0.21	0.26	0.38
29	DES0A3	DIESEL-S0A	HEAT	0.	36.	100.	20.	36.	11.	0.	-70.	100.	DISTILLA	30.	0	0.27	0.36	0.20
29	DES0A3	DIESEL-S0A	POWR	0.	14.	38.	8.	14.	4.	15.	0.	52.	RESIDUAL	52.	0	0.21	0.26	0.38
29	DES0A3	DIESEL-S0A	HEAT	0.	36.	100.	20.	36.	11.	0.	-70.	100.	RESIDUAL	30.	0	0.27	0.36	0.20

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28951 MW 4.00 PROCESS MILLIONS BTU/HR 20.0 PROCESS TEMP(F) 298. PRODUCT CARBON-BLACK HOURS PER YEAR 7900.

POWER TO HEAT RATIO 0.682

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
30 DES0A2 DIESEL-SOA POWR		0.	15.	38.	8.	14.	4.	14.	0.	52.DISTILLA		52.	1	0.22	0.26	0.39
30 DES0A2 DIESEL-SOA HEAT		0.	35.	91.	20.	33.	10.	0.	-60.	91.DISTILLA		31.	1	0.28	0.36	0.22
30 DES0A2 DIESEL-SOA POWR		0.	15.	38.	8.	14.	4.	14.	0.	52.RESIDUAL		52.	1	0.22	0.26	0.39
30 DES0A2 DIESEL-SOA HEAT		0.	35.	91.	20.	33.	10.	0.	-60.	91.RESIDUAL		31.	1	0.28	0.36	0.22
31 DES0A1 DIESEL-SOA POWR		0.	23.	38.	15.	14.	4.	6.	0.	43.DISTILLA		43.	1	0.34	0.31	0.46
31 DES0A1 DIESEL-SOA HEAT		0.	30.	50.	20.	18.	5.	0.	-14.	50.DISTILLA		36.	1	0.37	0.36	0.40
31 DES0A1 DIESEL-SOA POWR		0.	23.	38.	15.	14.	4.	6.	0.	43.RESIDUAL		43.	1	0.34	0.31	0.46
31 DES0A1 DIESEL-SOA HEAT		0.	30.	50.	20.	18.	5.	0.	-14.	50.RESIDUAL		36.	1	0.37	0.36	0.40
32 GTS0AD GT-HRSG-10 POWR		0.	19.	47.	22.	14.	4.	-2.	0.	47.DISTILLA		47.	10	0.29	0.29	0.43
32 GTS0AD GT-HRSG-10 HEAT		0.	20.	43.	20.	12.	4.	0.	4.	43.DISTILLA		46.	10	0.30	0.27	0.43
33 GTRA08 GT-85RE-08 POWR		0.	21.	38.	14.	14.	4.	7.	0.	45.DISTILLA		45.	10	0.31	0.30	0.44
33 GTRA08 GT-85RE-08 HEAT		0.	30.	55.	20.	20.	6.	0.	-19.	55.DISTILLA		36.	10	0.35	0.36	0.36
34 GTRA12 GT-85RE-12 POWR		0.	21.	38.	14.	14.	4.	7.	0.	45.DISTILLA		45.	10	0.32	0.30	0.44
34 GTRA12 GT-85RE-12 HEAT		0.	30.	54.	20.	19.	6.	0.	-18.	54.DISTILLA		36.	10	0.36	0.36	0.37
35 GTRA16 GT-85RE-16 POWR		0.	21.	39.	15.	14.	4.	6.	0.	45.DISTILLA		45.	10	0.32	0.30	0.44
35 GTRA16 GT-85RE-16 HEAT		0.	28.	52.	20.	18.	5.	0.	-14.	52.DISTILLA		38.	10	0.35	0.35	0.38
36 GTR208 GT-60RE-08 POWR		0.	21.	43.	18.	14.	4.	3.	0.	45.DISTILLA		45.	10	0.32	0.30	0.44
36 GTR208 GT-60RE-08 HEAT		0.	24.	48.	20.	15.	4.	0.	-5.	48.DISTILLA		43.	10	0.33	0.32	0.42
37 GTR212 GT-60RE-12 POWR		0.	21.	41.	17.	14.	4.	4.	0.	45.DISTILLA		45.	10	0.31	0.30	0.44
37 GTR212 GT-60RE-12 HEAT		0.	25.	50.	20.	16.	5.	0.	-9.	50.DISTILLA		41.	10	0.33	0.33	0.40
38 GTR216 GT-60RE-16 POWR		0.	21.	40.	16.	14.	4.	4.	0.	45.DISTILLA		45.	10	0.32	0.30	0.45
38 GTR216 GT-60RE-16 HEAT		0.	26.	50.	20.	17.	5.	0.	-10.	50.DISTILLA		40.	10	0.34	0.34	0.40
39 GTRW08 GT-85RE-08 POWR		0.	17.	39.	12.	14.	4.	10.	0.	49.DISTILLA		49.	10	0.26	0.28	0.41
39 GTRW08 GT-85RE-08 HEAT		0.	30.	67.	20.	24.	7.	0.	-31.	67.DISTILLA		36.	10	0.31	0.35	0.30
40 GTRW12 GT-85RE-12 POWR		0.	18.	37.	11.	14.	4.	10.	0.	48.DISTILLA		48.	10	0.28	0.29	0.42
40 GTRW12 GT-85RE-12 HEAT		0.	33.	67.	20.	24.	7.	0.	-33.	67.DISTILLA		33.	10	0.33	0.38	0.30

HONEYWELL PAGE PRINTING SYSTEM- P1189-02

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 28951 MW 4.00 PROCESS MILLIONS BTU/HR 20.0 PROCESS TEMP(F) 298. PRODUCT CARBON-BLACK HOURS PER YEAR 7900.

POWER TO HEAT RATIO 0.682

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAY FACTR
41 GTRW16 GT-85RE-16 POWR		0.	19.	38.	12.	14.	4.	9.	0.	48.	DISTILLA	48.	10	0.28	0.29	0.42
41 GTRW16 GT-85RE-16 HEAT		0.	31.	64.	20.	23.	7.	0.	-28.	64.	DISTILLA	35.	10	0.33	0.36	0.31
42 GTR308 GT-60RE-08 POWR		0.	16.	44.	15.	14.	4.	6.	0.	50.	DISTILLA	50.	10	0.25	0.27	0.40
42 GTR308 GT-60RE-08 HEAT		0.	22.	58.	20.	18.	5.	0.	-14.	58.	DISTILLA	44.	10	0.27	0.31	0.34
43 GTR312 GT-60RE-12 POWR		0.	19.	40.	14.	14.	4.	8.	0.	47.	DISTILLA	47.	10	0.28	0.29	0.42
43 GTR312 GT-60RE-12 HEAT		0.	28.	59.	20.	20.	6.	0.	-20.	59.	DISTILLA	39.	10	0.32	0.34	0.34
44 GTR316 GT-60RE-16 POWR		0.	19.	40.	14.	14.	4.	7.	0.	48.	DISTILLA	48.	10	0.28	0.29	0.42
44 GTR316 GT-60RE-16 HEAT		0.	27.	58.	20.	20.	6.	0.	-19.	58.	DISTILLA	39.	10	0.32	0.34	0.34
45 FCPADS FUEL-CL-PH POWR		0.	14.	36.	6.	14.	4.	16.	0.	52.	DISTILLA	52.	0	0.21	0.26	0.38
45 FCPADS FUEL-CL-PH HEAT		0.	46.	118.	20.	45.	13.	0.	-97.	118.	DISTILLA	21.	0	0.28	0.38	0.17
46 FCMCDS FUEL-CL-MO POWR		0.	19.	33.	8.	14.	4.	14.	0.	48.	DISTILLA	48.	10	0.28	0.29	0.42
46 FCMCDS FUEL-CL-MO HEAT		0.	48.	86.	20.	35.	10.	0.	-68.	86.	DISTILLA	18.	0	0.36	0.41	0.23

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 29111 MW 14.00 PROCESS MILLIONS BTU/HR 375.0 PROCESS TEMP(F) 470. PRODUCT SMALL-REFINE HOURS PER YEAR 8760.

POWER TO HEAT RATIO 0.127

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET* TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
0 ONOCGN N O C O G O N		0.	0.	0.	0.	0.	0.	441.	149.	441.	COAL-FGD	590.	0	0.	0.08	0.64
1 STM141 STM-TURB-1 POWR		0.	93.	407.	299.	48.	14.	90.	0.	497.	RESIDUAL	497.	0	0.16	0.10	0.75
1 STM141 STM-TURB-1 HEAT		0.	117.	512.	375.	60.	18.	0.	-38.	512.	RESIDUAL	474.	0	0.19	0.12	0.73
1 STM141 STM-TURB-1 POWR		0.	93.	407.	299.	48.	14.	90.	0.	497.	COAL-FGD	497.	0	0.16	0.10	0.75
1 STM141 STM-TURB-1 HEAT		0.	117.	512.	375.	60.	18.	0.	-38.	512.	COAL-FGD	474.	0	0.19	0.12	0.73
1 STM141 STM-TURB-1 POWR		0.	93.	407.	299.	48.	14.	90.	0.	497.	COAL-AFB	497.	0	0.16	0.10	0.75
1 STM141 STM-TURB-1 HEAT		0.	117.	512.	375.	60.	18.	0.	-38.	512.	COAL-AFB	474.	0	0.19	0.12	0.73
2 STM088 STM-TURB-8 POWR		0.	7.	583.	448.	48.	14.	-86.	0.	583.	RESIDUAL	583.	0	0.01	0.08	0.64
2 STM088 STM-TURB-8 HEAT		0.	78.	488.	375.	40.	12.	0.	24.	488.	RESIDUAL	512.	0	0.13	0.08	0.73
2 STM088 STM-TURB-8 POWR		0.	7.	583.	448.	48.	14.	-86.	0.	583.	COAL-FGD	583.	0	0.01	0.08	0.64
2 STM088 STM-TURB-8 HEAT		0.	78.	488.	375.	40.	12.	0.	24.	488.	COAL-FGD	512.	0	0.13	0.08	0.73
2 STM088 STM-TURB-8 POWR		0.	7.	583.	448.	48.	14.	-86.	0.	583.	COAL-AFB	583.	0	0.01	0.08	0.64
2 STM088 STM-TURB-8 HEAT		0.	78.	488.	375.	40.	12.	0.	24.	488.	COAL-AFB	512.	0	0.13	0.08	0.73
3 PFBSTM PFB-STMTB- POWR		0.	90.	256.	167.	48.	14.	244.	0.	500.	COAL-PFB	500.	0	0.15	0.10	0.75
3 PFBSTM PFB-STMTB- HEAT		0.	203.	573.	375.	107.	31.	0.	-185.	573.	COAL-PFB	388.	0	0.26	0.19	0.65
4 TISTMT TI-STMTB-1 POWR		0.	91.	201.	122.	48.	14.	298.	0.	499.	RESIDUAL	499.	0	0.15	0.10	0.75
4 TISTMT TI-STMTB-1 HEAT		0.	281.	619.	375.	147.	43.	0.	-310.	619.	RESIDUAL	309.	0	0.31	0.24	0.61
4 TISTMT TI-STMTB-1 POWR		0.	91.	201.	122.	48.	14.	298.	0.	499.	COAL	499.	0	0.15	0.10	0.75
4 TISTMT TI-STMTB-1 HEAT		0.	281.	619.	375.	147.	43.	0.	-310.	619.	COAL	309.	0	0.31	0.24	0.61
5 TIHRSG THERMIONIC POWR		0.	52.	340.	206.	48.	14.	199.	0.	539.	RESIDUAL	539.	0	0.09	0.09	0.70
5 TIHRSG THERMIONIC HEAT		0.	94.	619.	375.	87.	26.	0.	-123.	619.	RESIDUAL	496.	0	0.13	0.14	0.61
5 TIHRSG THERMIONIC POWR		0.	52.	340.	206.	48.	14.	199.	0.	539.	COAL	539.	0	0.09	0.09	0.70
5 TIHRSG THERMIONIC HEAT		0.	94.	619.	375.	87.	26.	0.	-123.	619.	COAL	496.	0	0.13	0.14	0.61
6 STIRL STIRLING-1 POWR		0.	63.	213.	107.	48.	14.	315.	0.	528.	DISTILLA	528.	0	0.11	0.09	0.71
6 STIRL STIRLING-1 HEAT		0.	219.	744.	375.	167.	49.	0.	-373.	744.	DISTILLA	371.	0	0.23	0.22	0.50

I&amp;SE PED ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 29111 MW 14.00 PROCESS MILLIONS BTU/HR 375.0 PROCESS TEMP(F) 470. PRODUCT SMALL-REFINE HOURS PER YEAR 8760.

POWER TO HEAT RATIO 0.127

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
6 STIRL	STIRLING-1 POWR	0.	63.	213.	107.	48.	14.	315.	0.	528.	RESIDUAL	528.	0	0.11	0.09	0.71
6 STIRL	STIRLING-1 HEAT	0.	219.	744.	375.	167.	49.	0.	-373.	744.	RESIDUAL	371.	0	0.23	0.22	0.50
6 STIRL	STIRLING-1 POWR	0.	63.	213.	107.	48.	14.	315.	0.	528.	COAL	528.	0	0.11	0.09	0.71
6 STIRL	STIRLING-1 HEAT	0.	219.	744.	375.	167.	49.	0.	-373.	744.	COAL	371.	0	0.23	0.22	0.50
7 HEGT85	HELIUM-GT- POWR	0.	-10.	149.	-9.	48.	14.	451.	0.	600.	COAL-AFB	600.	11	-0.02	0.08	0.62
7 HEGT85	HELIUM-GT- HEAT	-6413.	421.	-6413.	375.	-2059.	-603.	0.	6582.	-6413.	COAL-AFB	169.	11	*****	*****	2.21
8 HEGT60	HELIUM-GT- POWR	0.	3.	184.	32.	48.	14.	403.	0.	588.	COAL-AFB	588.	10	0.00	0.08	0.64
8 HEGT60	HELIUM-GT- HEAT	0.	32.	2144.	375.	555.	163.	0.	-1586.	2144.	COAL-AFB	558.	0	0.01	0.26	0.17
9 HEGT00	HELIUM-GT- POWR	0.	27.	271.	127.	48.	14.	292.	0.	564.	COAL-AFB	564.	10	0.05	0.08	0.67
9 HEGT00	HELIUM-GT- HEAT	0.	79.	804.	375.	141.	41.	0.	-293.	804.	COAL-AFB	511.	10	0.09	0.19	0.47
10 FCMCCL	FUEL-CL-MO POWR	0.	79.	157.	74.	48.	14.	354.	0.	511.	COAL	511.	10	0.13	0.09	0.73
10 FCMCCL	FUEL-CL-MO HEAT	0.	401.	797.	375.	242.	71.	0.	-608.	797.	COAL	189.	10	0.34	0.30	0.47
11 FCSTCL	FUEL-CL-ST POWR	0.	82.	129.	53.	48.	14.	379.	0.	508.	COAL	508.	10	0.14	0.09	0.74
11 FCSTCL	FUEL-CL-ST HEAT	0.	582.	915.	375.	338.	99.	0.	-907.	915.	COAL	8.	10	0.39	0.37	0.41
12 IGGTST	INT-GAS-GT POWR	0.	64.	177.	78.	48.	14.	350.	0.	527.	COAL	527.	10	0.11	0.09	0.71
12 IGGTST	INT-GAS-GT HEAT	0.	308.	852.	375.	230.	67.	0.	-570.	852.	COAL	282.	10	0.27	0.27	0.44
13 GTSOAR	GT-HRSG-10 POWR	0.	60.	165.	64.	48.	14.	366.	0.	530.	RESIDUAL	530.	0	0.10	0.09	0.71
13 GTSOAR	GT-HRSG-10 HEAT	0.	351.	963.	375.	279.	82.	0.	-723.	963.	RESIDUAL	240.	0	0.27	0.29	0.39
14 GTAC08	GT-HRSG-08 POWR	0.	80.	177.	91.	48.	14.	334.	0.	511.	RESIDUAL	511.	0	0.14	0.09	0.73
14 GTAC08	GT-HRSG-08 HEAT	0.	328.	727.	375.	196.	59.	0.	-464.	727.	RESIDUAL	263.	0	0.31	0.27	0.52
15 GTAC12	GT-HRSG-12 POWR	0.	78.	157.	73.	48.	14.	350.	0.	512.	RESIDUAL	512.	0	0.13	0.09	0.73
15 GTAC12	GT-HRSG-12 HEAT	0.	403.	810.	375.	247.	72.	0.	-523.	810.	RESIDUAL	187.	0	0.33	0.31	0.46
16 GTAC16	GT-HRSG-16 POWR	0.	75.	148.	62.	48.	14.	368.	0.	516.	RESIDUAL	516.	0	0.13	0.09	0.73
16 GTAC16	GT-HRSG-16 HEAT	0.	450.	888.	375.	287.	84.	0.	-747.	888.	RESIDUAL	141.	0	0.34	0.32	0.42
17 GTWC16	GT-HRSG-16 POWR	0.	70.	152.	61.	48.	14.	369.	0.	520.	RESIDUAL	520.	10	0.12	0.09	0.72
17 GTWC16	GT-HRSG-16 HEAT	0.	427.	925.	375.	291.	85.	0.	-761.	925.	RESIDUAL	164.	0	0.32	0.32	0.41

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 29111 MW 14.00 PROCESS MILLIONS BTU/HR 375.0 PROCESS TEMP(F) 470. PRODUCT SMALL-REFINE HOURS PER YEAR 8760.

		POWER TO HEAT RATIO 0.127														
UTILITY FUEL		WASTE FUEL EQV BTU*10**6= 0.										HOT WATER BTU*10**6= 0.				
	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
18	CC1626 GTST-16/26 POWR	0.	68.	130.	42.	48.	14.	392.	0.	522.	RESIDUAL	522.	10	0.12	0.09	0.72
18	CC1626 GTST-16/26 HEAT	0.	612.	1168.	375.	428.	126.	0.	-1190.	1168.	RESIDUAL	-21.	0	0.34	0.37	0.32
19	CC1622 GTST-16/22 POWR	0.	72.	132.	47.	48.	14.	386.	0.	519.	RESIDUAL	519.	10	0.12	0.09	0.72
19	CC1622 GTST-16/22 HEAT	0.	577.	1066.	375.	385.	113.	0.	-1053.	1066.	RESIDUAL	14.	0	0.35	0.36	0.35
20	CC1222 GTST-12/22 POWR	0.	72.	132.	47.	48.	14.	386.	0.	518.	RESIDUAL	518.	0	0.12	0.09	0.72
20	CC1222 GTST-12/22 HEAT	0.	578.	1057.	375.	382.	112.	0.	-1044.	1057.	RESIDUAL	12.	0	0.35	0.36	0.35
21	CC0822 GTST-08/22 POWR	0.	78.	142.	60.	48.	14.	371.	0.	513.	RESIDUAL	513.	0	0.13	0.09	0.73
21	CC0822 GTST-08/22 HEAT	0.	489.	893.	375.	301.	88.	0.	-791.	893.	RESIDUAL	102.	0	0.35	0.34	0.42
22	STIG15 STIG-15-16 POWR	0.	26.	125.	2.	48.	14.	439.	0.	565.	RESIDUAL	565.	11	0.04	0.08	0.66
22	STIG15 STIG-15-16 HEAT	0.	5940.	28846.	375.	10990.	3221.	0.	-34196.	28846.	RESIDUAL	-5350.	1	0.17	0.38	0.01
23	STIG10 STIG-10-16 POWR	0.	37.	133.	18.	48.	14.	420.	0.	553.	RESIDUAL	553.	11	0.06	0.09	0.68
23	STIG10 STIG-10-16 HEAT	0.	787.	2830.	375.	1016.	298.	0.	-3027.	2830.	RESIDUAL	-197.	1	0.22	0.36	0.13
24	STIG1S STIG-1S-16 POWR	0.	42.	143.	30.	48.	14.	406.	0.	548.	RESIDUAL	548.	11	0.07	0.09	0.68
24	STIG1S STIG-1S-16 HEAT	0.	526.	1779.	375.	596.	175.	0.	-1714.	1779.	RESIDUAL	65.	1	0.23	0.34	0.21
25	DEADV3 DIESEL-ADV POWR	0.	45.	129.	21.	48.	14.	417.	0.	546.	RESIDUAL	546.	1	0.08	0.09	0.69
25	DEADV3 DIESEL-ADV HEAT	0.	812.	2329.	375.	864.	253.	0.	-2551.	2329.	RESIDUAL	-222.	1	0.26	0.37	0.16
26	DEADV2 DIESEL-ADV POWR	0.	59.	129.	33.	48.	14.	403.	0.	531.	RESIDUAL	531.	1	0.10	0.09	0.71
26	DEADV2 DIESEL-ADV HEAT	0.	676.	1476.	375.	548.	161.	0.	-1562.	1476.	RESIDUAL	-86.	1	0.31	0.37	0.25
27	DEADV1 DIESEL-ADV POWR	0.	80.	129.	50.	48.	14.	382.	0.	511.	RESIDUAL	511.	1	0.14	0.09	0.73
27	DEADV1 DIESEL-ADV HEAT	0.	594.	959.	375.	356.	104.	0.	-963.	959.	RESIDUAL	-4.	1	0.38	0.37	0.39
28	DEHTPM ADV-DIESEL POWR	0.	65.	170.	73.	48.	14.	355.	0.	525.	RESIDUAL	525.	0	0.11	0.09	0.71
28	DEHTPM ADV-DIESEL HEAT	0.	336.	872.	375.	246.	72.	0.	-618.	872.	RESIDUAL	254.	0	0.28	0.28	0.43
29	DESOA3 DIESEL-SOA POWR	0.	37.	132.	17.	48.	14.	421.	0.	554.	DISTILLA	554.	1	0.06	0.09	0.68
29	DESOA3 DIESEL-SOA HEAT	0.	820.	2953.	375.	1066.	312.	0.	-3182.	2953.	DISTILLA	-229.	1	0.22	0.36	0.13
29	DESOA3 DIESEL-SOA POWR	0.	37.	132.	17.	48.	14.	421.	0.	554.	RESIDUAL	554.	1	0.06	0.09	0.68
29	DESOA3 DIESEL-SOA HEAT	0.	820.	2953.	375.	1066.	312.	0.	-3182.	2953.	RESIDUAL	-229.	1	0.22	0.36	0.13

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 29111 MW 14.00 PROCESS MILLIONS BTU/HR 375.0 PROCESS TEMP(F) 470. PRODUCT SMALL-REFINE HOURS PER YEAR 8760.

UTILITY FUEL		COAL		POWER TO HEAT RATIO 0.127																			
		WASTE FUEL		COGEN FUEL		COGEN PROCES HEAT		COGEN ELECT		AUX PROCES BOILR		UTILIT FUEL USED		TOTAL FUEL SITE		NET= TOTAL+ UTILIT		FAIL FESR		POWER HEAT			
		USED 10**6 BTU/HR		10**6 BTU/HR		10**6 BTU/HR		10**6 BTU/HR		10**6 BTU/HR		10**6 BTU/HR		10**6 BTU/HR		10**6 BTU/HR		10**6 BTU/HR		FACTR		FACTR	
30	DES0A2 DIESEL-S0A POWR	0.	51.	132.	29.	48.	14.	407.	0.	539.	DISTILLA	539.	1	0.09	0.09	0.70							
30	DES0A2 DIESEL-S0A HEAT	0.	660.	1705.	375.	615.	180.	0.	-1774.	1705.	DISTILLA	-69.	1	0.28	0.36	0.22							
30	DES0A2 DIESEL-S0A POWR	0.	51.	132.	29.	48.	14.	407.	0.	539.	RESIDUAL	539.	1	0.09	0.09	0.70							
30	DES0A2 DIESEL-S0A HEAT	0.	660.	1705.	375.	615.	180.	0.	-1774.	1705.	RESIDUAL	-69.	1	0.28	0.36	0.22							
31	DES0A1 DIESEL-S0A POWR	0.	79.	132.	53.	48.	14.	379.	0.	511.	DISTILLA	511.	1	0.13	0.09	0.73							
31	DES0A1 DIESEL-S0A HEAT	0.	561.	935.	375.	338.	99.	0.	-906.	935.	DISTILLA	29.	1	0.37	0.36	0.40							
31	DES0A1 DIESEL-S0A POWR	0.	79.	132.	53.	48.	14.	379.	0.	511.	RESIDUAL	511.	1	0.13	0.09	0.73							
31	DES0A1 DIESEL-S0A HEAT	0.	561.	935.	375.	338.	99.	0.	-906.	935.	RESIDUAL	29.	1	0.37	0.36	0.40							
32	GTSOAD GT-HRSG-10 POWR	0.	73.	164.	74.	48.	14.	354.	0.	517.	DISTILLA	517.	0	0.12	0.09	0.72							
32	GTSOAD GT-HRSG-10 HEAT	0.	369.	826.	375.	241.	71.	0.	-605.	826.	DISTILLA	222.	0	0.31	0.29	0.45							
33	GTRA08 GT-85RE-08 POWR	0.	60.	134.	38.	48.	14.	396.	0.	530.	DISTILLA	530.	0	0.10	0.09	0.71							
33	GTRA08 GT-85RE-08 HEAT	0.	593.	1316.	375.	470.	138.	0.	-1319.	1316.	DISTILLA	-3.	0	0.31	0.36	0.29							
34	GTRA12 GT-85RE-12 POWR	0.	63.	133.	41.	48.	14.	394.	0.	527.	DISTILLA	527.	0	0.11	0.09	0.71							
34	GTRA12 GT-85RE-12 HEAT	0.	588.	1235.	375.	442.	130.	0.	-1233.	1235.	DISTILLA	3.	0	0.32	0.36	0.30							
35	GTRA16 GT-85RE-16 POWR	0.	65.	137.	45.	48.	14.	389.	0.	526.	DISTILLA	526.	0	0.11	0.09	0.71							
35	GTRA16 GT-85RE-16 HEAT	0.	545.	1151.	375.	402.	118.	0.	-1106.	1151.	DISTILLA	45.	0	0.32	0.35	0.33							
36	GTR208 GT-60RE-08 POWR	0.	66.	149.	56.	48.	14.	375.	0.	525.	DISTILLA	525.	0	0.11	0.09	0.71							
36	GTR208 GT-60RE-08 HEAT	0.	441.	999.	375.	320.	94.	0.	-850.	999.	DISTILLA	149.	0	0.31	0.32	0.38							
37	GTR212 GT-60RE-12 POWR	0.	66.	145.	52.	48.	14.	380.	0.	525.	DISTILLA	525.	0	0.11	0.09	0.71							
37	GTR212 GT-60RE-12 HEAT	0.	474.	1040.	375.	343.	101.	0.	-924.	1040.	DISTILLA	117.	0	0.31	0.33	0.36							
38	GTR216 GT-60RE-16 POWR	0.	67.	142.	51.	48.	14.	382.	0.	523.	DISTILLA	523.	0	0.11	0.09	0.72							
38	GTR216 GT-60RE-16 HEAT	0.	497.	1050.	375.	354.	104.	0.	-956.	1050.	DISTILLA	94.	0	0.32	0.34	0.36							
39	GTRW08 GT-85RE-08 POWR	0.	52.	136.	33.	48.	14.	403.	0.	539.	DISTILLA	539.	10	0.09	0.09	0.70							
39	GTRW08 GT-85RE-08 HEAT	0.	593.	1564.	375.	549.	161.	0.	-1566.	1564.	DISTILLA	-2.	0	0.27	0.35	0.24							
40	GTRW12 GT-85RE-12 POWR	0.	57.	131.	33.	48.	14.	402.	0.	539.	DISTILLA	539.	10	0.10	0.09	0.70							
40	GTRW12 GT-85RE-12 HEAT	0.	645.	1484.	375.	540.	158.	0.	-1538.	1484.	DISTILLA	-55.	0	0.30	0.36	0.25							



GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 29111 MW 14.00 PROCESS MILLIONS BTU/HR 375.0 PROCESS TEMP(F) 470. PRODUCT SMALL-REFINE HOURS PER YEAR 8700.

POWER TO HEAT RATIO 0.127

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL COAL

	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41 GTRW16 GT-85RE-16 POWR	0.	59.	134.	37.	48.	14.	398.	0.	532.	DISTILLA	532.	10	0.10	0.09	0.71
41 GTRW16 GT-85RE-16 HEAT	0.	598.	1360.	375.	485.	142.	0.	-1368.	1360.	DISTILLA	-8.	0	0.31	0.36	0.28
42 GTR308 GT-60RE-08 POWR	0.	47.	154.	44.	48.	14.	389.	0.	544.	DISTILLA	544.	10	0.08	0.09	0.69
42 GTR308 GT-60RE-08 HEAT	0.	400.	1316.	375.	408.	120.	0.	-1125.	1316.	DISTILLA	190.	0	0.23	0.31	0.29
43 GTR312 GT-60RE-12 POWR	0.	62.	140.	44.	48.	14.	389.	0.	529.	DISTILLA	529.	10	0.10	0.09	0.71
43 GTR312 GT-60RE-12 HEAT	0.	522.	1180.	375.	404.	118.	0.	-1112.	1180.	DISTILLA	68.	0	0.31	0.34	0.32
44 GTR316 GT-60RE-16 POWR	0.	62.	141.	45.	48.	14.	388.	0.	529.	DISTILLA	529.	10	0.10	0.09	0.71
44 GTR316 GT-60RE-16 HEAT	0.	511.	1169.	375.	396.	116.	0.	-1089.	1169.	DISTILLA	80.	0	0.30	0.34	0.32
45 FCPADS FUEL-CL-PH POWR	0.	49.	126.	21.	48.	14.	416.	0.	542.	DISTILLA	542.	0	0.08	0.09	0.69
45 FCPADS FUEL-CL-PH HEAT	0.	855.	2206.	375.	838.	246.	0.	-2470.	2206.	DISTILLA	-264.	0	0.28	0.38	0.17
46 FCMCDS FUEL-CL-MO POWR	0.	65.	116.	27.	48.	14.	409.	0.	525.	DISTILLA	525.	0	0.11	0.09	0.71
46 FCMCDS FUEL-CL-MO HEAT	0.	904.	1609.	375.	663.	194.	0.	-1923.	1609.	DISTILLA	-313.	0	0.36	0.41	0.23

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 29112 MW 52.00 PROCESS MILLIONS BTU/HR 1333.0 PROCESS TEMP(F) 470. PRODUCT MEDIUM-REFIN HOURS PER YEAR 8760.

POWER TO HEAT RATIO 0.133

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET USED 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX BOILR PROCES 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
0 ONOCGN N O C O G O N		0.	0.	0.	0.	0.	0.	1568.	55.	1568.	COAL-FGD	2123.	0	0.	0.08	0.63
1 STM141 STM-TURB-1	POWER	0.	346.	1559.	1148.	177.	52.	218.	0.	1777.	RESIDUAL	1777.	0	0.16	0.10	0.75
1 STM141 STM-TURB-1	HEAT	0.	401.	1811.	1333.	206.	60.	0.	-89.	1811.	RESIDUAL	1721.	0	0.18	0.11	0.74
1 STM141 STM-TURB-1	POWER	0.	346.	1559.	1148.	177.	52.	218.	0.	1777.	COAL-FGD	1777.	0	0.16	0.10	0.75
1 STM141 STM-TURB-1	HEAT	0.	401.	1811.	1333.	206.	60.	0.	-89.	1811.	COAL-FGD	1721.	0	0.18	0.11	0.74
1 STM141 STM-TURB-1	POWER	0.	346.	1559.	1148.	177.	52.	218.	0.	1777.	COAL-AFB	1777.	0	0.16	0.10	0.75
1 STM141 STM-TURB-1	HEAT	0.	401.	1811.	1333.	206.	60.	0.	-89.	1811.	COAL-AFB	1721.	0	0.18	0.11	0.74
2 STM088 STM-TURB-8	POWER	0.	-141.	2264.	1747.	177.	52.	-487.	0.	2264.	RESIDUAL	2264.	0	-0.07	0.08	0.59
2 STM088 STM-TURB-8	HEAT	0.	264.	1728.	1333.	135.	40.	0.	131.	1728.	RESIDUAL	1859.	0	0.12	0.07	0.72
2 STM088 STM-TURB-8	POWER	0.	-141.	2264.	1747.	177.	52.	-487.	0.	2264.	COAL-FGD	2264.	0	-0.07	0.08	0.59
2 STM088 STM-TURB-8	HEAT	0.	264.	1728.	1333.	135.	40.	0.	131.	1728.	COAL-FGD	1859.	0	0.12	0.07	0.72
2 STM088 STM-TURB-8	POWER	0.	-141.	2264.	1747.	177.	52.	-487.	0.	2264.	COAL-AFB	2264.	0	-0.07	0.08	0.59
2 STM088 STM-TURB-8	HEAT	0.	264.	1728.	1333.	135.	40.	0.	131.	1728.	COAL-AFB	1859.	0	0.12	0.07	0.72
3 PFBSTM PFB-STMTB-	POWER	0.	335.	965.	634.	177.	52.	822.	0.	1788.	COAL-PFB	1788.	0	0.16	0.10	0.75
3 PFBSTM PFB-STMTB-	HEAT	0.	704.	2030.	1333.	373.	109.	0.	-611.	2030.	COAL-PFB	1418.	0	0.26	0.18	0.66
4 TISTMT TI-STMTB-1	POWER	0.	339.	757.	461.	177.	52.	1026.	0.	1783.	RESIDUAL	1783.	0	0.16	0.10	0.75
4 TISTMT TI-STMTB-1	HEAT	0.	982.	2190.	1333.	513.	150.	0.	-1049.	2190.	RESIDUAL	1141.	0	0.31	0.23	0.61
4 TISTMT TI-STMTB-1	POWER	0.	339.	757.	461.	177.	52.	1026.	0.	1783.	COAL	1783.	0	0.16	0.10	0.75
4 TISTMT TI-STMTB-1	HEAT	0.	982.	2190.	1333.	513.	150.	0.	-1049.	2190.	COAL	1141.	0	0.31	0.23	0.61
5 TIHRSG THERMIONIC	POWER	0.	193.	1261.	764.	177.	52.	669.	0.	1930.	RESIDUAL	1930.	0	0.09	0.09	0.69
5 TIHRSG THERMIONIC	HEAT	0.	336.	2200.	1333.	309.	91.	0.	-413.	2200.	RESIDUAL	1787.	0	0.13	0.14	0.61
5 TIHRSG THERMIONIC	POWER	0.	193.	1261.	764.	177.	52.	669.	0.	1930.	COAL	1930.	0	0.09	0.09	0.69
5 TIHRSG THERMIONIC	HEAT	0.	336.	2200.	1333.	309.	91.	0.	-413.	2200.	COAL	1787.	0	0.13	0.14	0.61
6 STIRL STIRLING-1	POWER	0.	233.	790.	398.	177.	52.	1100.	0.	1890.	DISTILLA	1890.	0	0.11	0.09	0.71
6 STIRL STIRLING-1	HEAT	0.	780.	2644.	1333.	594.	174.	0.	-1302.	2644.	DISTILLA	1343.	0	0.23	0.22	0.50

ORIGINAL PAGE IS  
OF POOR QUALITY

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 29112 MW 52.00 PROCESS MILLIONS BTU/HR 1333.0 PROCESS TEMP(F) 470. PRODUCT MEDIUM-REFIN HOURS PER YEAR 8760.

		POWER TO HEAT RATIO 0.133										WASTE FUEL EQV BTU*10**6= 0.		HOT WATER BTU*10**6= 0.		
UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
6 STIRL	STIRLING-1 POWR	0.	233.	790.	398.	177.	52.	1100.	0.	1890.	RESIDUAL	1890.	0	0.11	0.09	0.71
6 STIRL	STIRLING-1 HEAT	0.	780.	2644.	1333.	594.	174.	0.	-1302.	2644.	RESIDUAL	1343.	0	0.23	0.22	0.50
6 STIRL	STIRLING-1 POWR	0.	233.	790.	398.	177.	52.	1100.	0.	1890.	COAL	1890.	0	0.11	0.09	0.71
6 STIRL	STIRLING-1 HEAT	0.	780.	2644.	1333.	594.	174.	0.	-1302.	2644.	COAL	1343.	0	0.23	0.22	0.50
7 HEGT85	HELIUM-GT- POWR	0.	-36.	553.	-32.	177.	52.	1606.	0.	2159.	COAL-AFB	2159.	1	-0.02	0.08	0.62
7 HEGT85	HELIUM-GT- HEAT	-22797.	1497.	-22797.	1333.	-7318.	-2145.	0.	23422.	-22797.	COAL-AFB	626.	11	*****	*****	2.13
8 HEGT60	HELIUM-GT- POWR	0.	10.	685.	120.	177.	52.	1427.	0.	2112.	COAL-AFB	2112.	0	0.00	0.08	0.63
8 HEGT60	HELIUM-GT- HEAT	0.	115.	7623.	1333.	1974.	579.	0.	-5615.	7623.	COAL-AFB	2008.	0	0.01	0.26	0.17
9 HEGT00	HELIUM-GT- POWR	0.	100.	1008.	470.	177.	52.	1015.	0.	2023.	COAL-AFB	2023.	0	0.05	0.09	0.66
9 HEGT00	HELIUM-GT- HEAT	0.	283.	2857.	1333.	503.	147.	0.	-1017.	2857.	COAL-AFB	1840.	0	0.09	0.18	0.47
10 FCMCCL	FUEL-CL-MO POWR	0.	294.	584.	275.	177.	52.	1245.	0.	1829.	COAL	1829.	10	0.14	0.10	0.73
10 FCMCCL	FUEL-CL-MO HEAT	0.	1427.	2832.	1333.	861.	252.	0.	-2136.	2832.	COAL	696.	0	0.34	0.30	0.47
11 FCSTCL	FUEL-CL-ST POWR	0.	305.	483.	199.	177.	52.	1334.	0.	1817.	COAL	1817.	10	0.14	0.10	0.73
11 FCSTCL	FUEL-CL-ST HEAT	0.	2048.	3238.	1333.	1189.	349.	0.	-3162.	3238.	COAL	75.	0	0.39	0.37	0.41
12 IGGTST	INT-GAS-GT POWR	0.	237.	662.	293.	177.	52.	1224.	0.	1886.	COAL	1886.	10	0.11	0.09	0.71
12 IGGTST	INT-GAS-GT HEAT	0.	1078.	3015.	1333.	808.	237.	0.	-1970.	3015.	COAL	1045.	0	0.26	0.27	0.44
13 GTSOAR	GT-HRSG-10 POWR	0.	223.	612.	238.	177.	52.	1288.	0.	1900.	RESIDUAL	1900.	0	0.11	0.09	0.70
13 GTSOAR	GT-HRSG-10 HEAT	0.	1247.	3422.	1333.	992.	291.	0.	-2547.	3422.	RESIDUAL	875.	0	0.27	0.29	0.39
14 GTAC08	GT-HRSG-08 POWR	0.	296.	657.	339.	177.	52.	1169.	0.	1827.	RESIDUAL	1827.	0	0.14	0.10	0.73
14 GTAC08	GT-HRSG-08 HEAT	0.	1165.	2584.	1333.	698.	204.	0.	-1626.	2584.	RESIDUAL	958.	0	0.31	0.27	0.52
15 GTAC12	GT-HRSG-12 POWR	0.	290.	582.	269.	177.	52.	1251.	0.	1833.	RESIDUAL	1833.	0	0.14	0.10	0.73
15 GTAC12	GT-HRSG-12 HEAT	0.	1433.	2879.	1333.	878.	257.	0.	-2189.	2879.	RESIDUAL	689.	0	0.33	0.31	0.46
16 GTAC16	GT-HRSG-16 POWR	0.	278.	549.	232.	177.	52.	1295.	0.	1845.	RESIDUAL	1845.	0	0.13	0.10	0.72
16 GTAC16	GT-HRSG-16 HEAT	0.	1598.	3158.	1333.	1020.	299.	0.	-2633.	3158.	RESIDUAL	525.	0	0.34	0.32	0.42
17 GTWC16	GT-HRSG-16 POWR	0.	260.	563.	228.	177.	52.	1300.	0.	1863.	RESIDUAL	1863.	0	0.12	0.10	0.72
17 GTWC16	GT-HRSG-16 HEAT	0.	1517.	3287.	1333.	1036.	304.	0.	-2682.	3287.	RESIDUAL	606.	0	0.32	0.32	0.41

HONEYWELL PAGE PRINTING SYSTEM- P1189-02

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 29112 MW 52.00 PROCESS MILLIONS BTU/HR 1333.0 PROCESS TEMP(F) 470. PRODUCT MEDIUM-REFIN HOURS PER YEAR 8760.

UTILITY FUEL	COAL	POWER TO HEAT RATIO 0.133										HOT WATER BTU*10**6=			O..			
		WASTE FUEL SAVED=	COGEN FUEL USED	COGEN HEAT	COGEN PROCES	COGEN MW	COGEN ELECT	AUX PROCES	FUEL UTILIT	TOTAL FUEL	SITE FUEL	NET=	FAIL	FESR		POWER FACTR		
		10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR
18 CC1626	GTST-16/26 POWR	0.	253.	486.	157.	177.	52.	1384.	0.	1870.	RESIDUAL	1870.	0	0.12	0.09	0.71		
18 CC1626	GTST-16/26 HEAT	0.	2151.	4134.	1333.	1509.	442.	0.	-4163.	4134.	RESIDUAL	-29.	0	0.34	0.37	0.32		
19 CC1622	GTST-16/22 POWR	0.	266.	494.	175.	177.	52.	1363.	0.	1857.	RESIDUAL	1857.	0	0.13	0.10	0.72		
19 CC1622	GTST-16/22 HEAT	0.	2028.	3773.	1333.	1355.	397.	0.	-3679.	3773.	RESIDUAL	94.	0	0.35	0.36	0.35		
20 CC1222	GTST-12/22 POWR	0.	268.	493.	176.	177.	52.	1361.	0.	1854.	RESIDUAL	1854.	0	0.13	0.10	0.72		
20 CC1222	GTST-12/22 HEAT	0.	2034.	3738.	1333.	1345.	394.	0.	-3649.	3738.	RESIDUAL	89.	0	0.35	0.36	0.36		
21 CC0822	GTST-08/22 POWR	0.	288.	530.	223.	177.	52.	1305.	0.	1835.	RESIDUAL	1835.	0	0.14	0.10	0.73		
21 CC0822	GTST-08/22 HEAT	0.	1717.	3159.	1333.	1059.	310.	0.	-2754.	3159.	RESIDUAL	406.	0	0.35	0.34	0.42		
22 ST1615	STIG-15-16 POWR	0.	96.	466.	6.	177.	52.	1561.	0.	2027.	RESIDUAL	2027.	1	0.05	0.09	0.66		
22 ST1615	STIG-15-16 HEAT	0.	21115.	102538.	1333.	39067.	11450.	0.	*****102538.	RESIDUAL	-18992.	1	1	0.17	0.38	0.01		
23 ST1610	STIG-10-16 POWR	0.	137.	494.	65.	177.	52.	1491.	0.	1985.	RESIDUAL	1985.	1	0.06	0.09	0.67		
23 ST1610	STIG-10-16 HEAT	0.	2797.	10060.	1333.	3613.	1059.	0.	-10735.	10060.	RESIDUAL	-675.	1	0.22	0.36	0.13		
24 ST1615	STIG-1S-16 POWR	0.	156.	529.	112.	177.	52.	1437.	0.	1966.	RESIDUAL	1966.	1	0.07	0.09	0.68		
24 ST1615	STIG-1S-16 HEAT	0.	1869.	6324.	1333.	2120.	621.	0.	-6069.	6324.	RESIDUAL	254.	1	0.23	0.34	0.21		
25 DEADV3	DIESEL-ADV POWR	0.	157.	478.	77.	177.	52.	1478.	0.	1956.	RESIDUAL	1956.	1	0.08	0.09	0.68		
25 DEADV3	DIESEL-ADV HEAT	0.	2880.	8280.	1333.	3072.	900.	0.	-9045.	8280.	RESIDUAL	-765.	1	0.25	0.37	0.16		
26 DEADV2	DIESEL-ADV POWR	0.	219.	478.	121.	177.	52.	1425.	0.	1904.	RESIDUAL	1904.	1	0.10	0.09	0.70		
26 DEADV2	DIESEL-ADV HEAT	0.	2405.	5248.	1333.	1947.	571.	0.	-5530.	5248.	RESIDUAL	-262.	1	0.31	0.37	0.25		
27 DEADV1	DIESEL-ADV POWR	0.	296.	478.	187.	177.	52.	1348.	0.	1826.	RESIDUAL	1826.	1	0.14	0.10	0.73		
27 DEADV1	DIESEL-ADV HEAT	0.	2112.	3409.	1333.	1265.	371.	0.	-3398.	3409.	RESIDUAL	11.	1	0.38	0.37	0.39		
28 DEHTPM	ADV-DIESEL POWR	0.	243.	630.	271.	177.	52.	1249.	0.	1980.	RESIDUAL	1880.	0	0.11	0.09	0.71		
28 DEHTPM	ADV-DIESEL HEAT	0.	1195.	3100.	1333.	873.	256.	0.	-2173.	3100.	RESIDUAL	928.	0	0.28	0.28	0.43		
29 DES0A3	DIESEL-S0A POWR	0.	136.	491.	62.	177.	52.	1495.	0.	1986.	DISTILLA	1986.	1	0.06	0.09	0.67		
29 DES0A3	DIESEL-S0A HEAT	0.	2913.	10497.	1333.	3789.	1111.	0.	-11287.	10497.	DISTILLA	-790.	1	0.22	0.36	0.13		
29 DES0A3	DIESEL-S0A POWR	0.	136.	491.	62.	177.	52.	1495.	0.	1986.	RESIDUAL	1986.	1	0.06	0.09	0.67		
29 DES0A3	DIESEL-S0A HEAT	0.	2913.	10497.	1333.	3789.	1111.	0.	-11287.	10497.	RESIDUAL	-790.	1	0.22	0.36	0.13		

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 29112 MW 52.00 PROCESS MILLIONS BTU/HR 1333.0 PROCESS TEMP(F) 470. PRODUCT MEDIUM-REFIN HOURS PER YEAR 8760.

POWER TO HEAT RATIO 0.133

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
30 DES0A2 DIESEL-S0A POWR		0.	190.	491.	108.	177.	52.	1441.	0.	1933.DISTILLA		1933.	1	0.09	0.09	0.69
30 DES0A2 DIESEL-S0A HEAT		0.	2345.	6059.	1333.	2187.	641.	0.	-6281.	6059.DISTILLA		-222.	1	0.28	0.36	0.22
30 DES0A2 DIESEL-S0A POWR		0.	190.	491.	108.	177.	52.	1441.	0.	1933.RESIDUAL		1933.	1	0.09	0.09	0.69
30 DES0A2 DIESEL-S0A HEAT		0.	2345.	6059.	1333.	2187.	641.	0.	-6281.	6059.RESIDUAL		-222.	1	0.28	0.36	0.22
31 DES0A1 DIESEL-S0A POWR		0.	295.	491.	197.	177.	52.	1336.	0.	1828.DISTILLA		1828.	1	0.14	0.10	0.73
31 DES0A1 DIESEL-S0A HEAT		0.	1994.	3324.	1333.	1200.	352.	0.	-3196.	3324.DISTILLA		129.	1	0.37	0.36	0.40
31 DES0A1 DIESEL-S0A POWR		0.	295.	491.	197.	177.	52.	1336.	0.	1828.RESIDUAL		1828.	1	0.14	0.10	0.73
31 DES0A1 DIESEL-S0A HEAT		0.	1994.	3324.	1333.	1200.	352.	0.	-3196.	3324.RESIDUAL		129.	1	0.37	0.36	0.40
32 GTS0AD GT-HRSG-10 POWR		0.	271.	608.	276.	177.	52.	1244.	0.	1851.DISTILLA		1851.	0	0.13	0.10	0.72
32 GTS0AD GT-HRSG-10 HEAT		0.	1311.	2937.	1333.	858.	251.	0.	-2126.	2937.DISTILLA		811.	0	0.31	0.29	0.45
33 GTRA08 GT-85RE-08 POWR		0.	224.	497.	142.	177.	52.	1402.	0.	1899.DISTILLA		1899.	0	0.11	0.09	0.70
33 GTRA08 GT-85RE-08 HEAT		0.	2109.	4677.	1333.	1670.	489.	0.	-4663.	4677.DISTILLA		14.	0	0.31	0.36	0.29
34 GTRA12 GT-85RE-12 POWR		0.	236.	496.	150.	177.	52.	1391.	0.	1887.DISTILLA		1887.	0	0.11	0.09	0.71
34 GTRA12 GT-85RE-12 HEAT		0.	2090.	4391.	1333.	1572.	461.	0.	-4358.	4391.DISTILLA		33.	0	0.32	0.36	0.30
35 GTRA16 GT-85RE-16 POWR		0.	241.	508.	166.	177.	52.	1373.	0.	1882.DISTILLA		1882.	0	0.11	0.09	0.71
35 GTRA16 GT-85RE-16 HEAT		0.	1939.	4091.	1333.	1428.	418.	0.	-3907.	4091.DISTILLA		184.	0	0.32	0.35	0.33
36 GTR208 GT-60RE-08 POWR		0.	245.	554.	208.	177.	52.	1323.	0.	1878.DISTILLA		1878.	0	0.12	0.09	0.71
36 GTR208 GT-60RE-08 HEAT		0.	1568.	3552.	1333.	1137.	333.	0.	-2998.	3552.DISTILLA		554.	0	0.31	0.32	0.38
37 GTR212 GT-60RE-12 POWR		0.	245.	538.	194.	177.	52.	1340.	0.	1878.DISTILLA		1878.	0	0.12	0.09	0.71
37 GTR212 GT-60RE-12 HEAT		0.	1684.	3698.	1333.	1220.	358.	0.	-3259.	3698.DISTILLA		439.	0	0.31	0.33	0.36
38 GTR216 GT-60RE-16 POWR		0.	249.	526.	188.	177.	52.	1347.	0.	1873.DISTILLA		1873.	0	0.12	0.09	0.71
38 GTR216 GT-60RE-16 HEAT		0.	1766.	3731.	1333.	1257.	369.	0.	-3375.	3731.DISTILLA		356.	0	0.32	0.34	0.36
39 GTRW08 GT-85RE-08 POWR		0.	192.	505.	121.	177.	52.	1426.	0.	1931.DISTILLA		1931.	0	0.09	0.09	0.69
39 GTRW08 GT-85RE-08 HEAT		0.	2107.	5559.	1333.	1951.	572.	0.	-5543.	5559.DISTILLA		16.	0	0.27	0.35	0.24
40 GTRW12 GT-85RE-12 POWR		0.	212.	487.	123.	177.	52.	1423.	0.	1911.DISTILLA		1911.	0	0.10	0.09	0.70
40 GTRW12 GT-85RE-12 HEAT		0.	2293.	5273.	1333.	1920.	563.	0.	-5444.	5273.DISTILLA		-171.	0	0.30	0.36	0.25

HONEYWELL PAGE PRINTING SYSTEM- PL185-02

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 205

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 29112 MW 52.00 PROCESS MILLIONS BTU/HR 1333.0 PROCESS TEMP(F) 470. PRODUCT MEDIUM-REFIN HOURS PER YEAR 8760.

UTILITY FUEL		COAL		POWER TO HEAT RATIO 0.133										WASTE FUEL EQV BTU*10**6=		0.		HOT WATER BTU*10**6=		0.	
WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR							
41 GTRW16 GT-85RE-16 POWR	0.	219.	497.	137.	177.	52.	1407.	0.	1904.	DISTILLA	1904.	0	0.10	0.09	0.70						
41 GTRW16 GT-85RE-16 HEAT	0.	2127.	4833.	1333.	1725.	506.	0.	-4838.	4833.	DISTILLA	-4.	0	0.31	0.36	0.28						
42 GTR308 GT-60RE-08 POWR	0.	174.	572.	163.	177.	52.	1376.	0.	1949.	DISTILLA	1949.	0	0.08	0.09	0.68						
42 GTR308 GT-60RE-08 HEAT	0.	1422.	4676.	1333.	1450.	425.	0.	-3976.	4676.	DISTILLA	701.	0	0.23	0.31	0.29						
43 GTR312 GT-60RE-12 POWR	0.	230.	519.	165.	177.	52.	1374.	0.	1893.	DISTILLA	1893.	0	0.11	0.09	0.70						
43 GTR312 GT-60RE-12 HEAT	0.	1857.	4194.	1333.	1434.	420.	0.	-3928.	4194.	DISTILLA	266.	0	0.31	0.34	0.32						
44 GTR316 GT-60RE-16 POWR	0.	229.	523.	168.	177.	52.	1371.	0.	1894.	DISTILLA	1894.	0	0.11	0.09	0.70						
44 GTR316 GT-60RE-16 HEAT	0.	1815.	4157.	1333.	1409.	413.	0.	-3849.	4157.	DISTILLA	308.	0	0.30	0.34	0.32						
45 FCPADS FUEL-CL-PH POWR	0.	181.	467.	79.	177.	52.	1475.	0.	1942.	DISTILLA	1942.	0	0.09	0.09	0.69						
45 FCPADS FUEL-CL-PH HEAT	0.	3038.	7841.	1333.	2980.	873.	0.	-8757.	7841.	DISTILLA	-916.	0	0.28	0.38	0.17						
46 FCMCDS FUEL-CL-MO POWR	0.	242.	431.	100.	177.	52.	1450.	0.	1881.	DISTILLA	1881.	0	0.11	0.09	0.71						
46 FCMCDS FUEL-CL-MO HEAT	0.	3213.	5721.	1333.	2357.	691.	0.	-6811.	5721.	DISTILLA	-1090.	0	0.36	0.41	0.23						

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 29113 MW 126.00 PROCESS MILLIONS BTU/HR 3042.0 PROCESS TEMP(F) 470. PRODUCT LARGE-REFINE HOURS PER YEAR 8760.

POWER TO HEAT RATIO 0.141

UTILITY FUEL COAL WASTE FUEL EGW BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED 10**6 BTU/HR	COGEN USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN ELECT 10**6 BTU/HR	AUX BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL USED 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR
0 ONOCGN N 0 C 0 0 0 N	0.	0.	0.	0.	0.	0.	3579.	1343.	3579.	4922.	0	0.	0.09
1 STM141 STM-TURB-1 POWR	0.	838.	3596.	2627.	430.	126.	489.	0.	4085.	4085.	0	0.17	0.11
1 STM141 STM-TURB-1 HEAT	0.	370.	4165.	3042.	498.	146.	0.	-213.	4165.	3952.	0	0.19	0.12
1 STM141 STM-TURB-1 POWR	0.	838.	3596.	2627.	430.	126.	489.	0.	4085.	4085.	0	0.17	0.11
1 STM141 STM-TURB-1 HEAT	0.	370.	4165.	3042.	498.	146.	0.	-213.	4165.	3952.	0	0.19	0.12
1 STM141 STM-TURB-1 POWR	0.	838.	3596.	2627.	430.	126.	489.	0.	4085.	4085.	0	0.17	0.11
1 STM141 STM-TURB-1 HEAT	0.	370.	4165.	3042.	498.	146.	0.	-213.	4165.	3952.	0	0.19	0.12
2 STM088 STM-TURB-8 POWR	0.	-177.	5100.	3905.	430.	126.	-1015.	0.	5100.	5100.	0	-0.04	0.08
2 STM088 STM-TURB-8 HEAT	0.	653.	3973.	3042.	335.	98.	0.	297.	3973.	4270.	0	0.13	0.03
2 STM088 STM-TURB-8 POWR	0.	-177.	5100.	3905.	430.	126.	-1015.	0.	5100.	5100.	0	-0.04	0.08
2 STM088 STM-TURB-8 HEAT	0.	653.	3973.	3042.	335.	98.	0.	297.	3973.	4270.	0	0.13	0.08
2 STM088 STM-TURB-8 POWR	0.	-177.	5100.	3905.	430.	126.	-1015.	0.	5100.	5100.	0	-0.04	0.08
2 STM088 STM-TURB-8 HEAT	0.	653.	3973.	3042.	335.	98.	0.	297.	3973.	4270.	0	0.13	0.08
3 PFBSTM PFB-STMTB- POWR	0.	814.	2277.	1485.	430.	126.	1832.	0.	4109.	4109.	0	0.17	0.10
3 PFBSTM PFB-STMTB- HEAT	0.	1667.	4665.	3042.	881.	258.	0.	-1409.	4665.	3255.	0	0.26	0.19
4 T1STMT T1-STMTB-1 POWR	0.	823.	1798.	1086.	430.	126.	2302.	0.	4099.	4099.	0	0.17	0.10
4 T1STMT T1-STMTB-1 HEAT	0.	2306.	5037.	3042.	1205.	353.	0.	-2421.	5037.	2617.	0	0.31	0.24
4 T1STMT T1-STMTB-1 POWR	0.	823.	1798.	1086.	430.	126.	2302.	0.	4099.	4099.	0	0.17	0.10
4 T1STMT T1-STMTB-1 HEAT	0.	2306.	5037.	3042.	1205.	353.	0.	-2421.	5037.	2617.	0	0.31	0.24
5 T1HRSG THERMIONIC POWR	0.	466.	3056.	1852.	430.	126.	1400.	0.	4456.	4456.	0	0.09	0.10
5 T1HRSG THERMIONIC HEAT	0.	766.	5020.	3042.	706.	207.	0.	-864.	5020.	4156.	0	0.13	0.14
5 T1HRSG THERMIONIC POWR	0.	466.	3056.	1852.	430.	126.	1400.	0.	4456.	4456.	0	0.09	0.10
5 T1HRSG THERMIONIC HEAT	0.	766.	5020.	3042.	706.	207.	0.	-864.	5020.	4156.	0	0.13	0.14
6 STIRL STIRLING-1 POWR	0.	564.	1914.	965.	430.	126.	2444.	0.	4358.	4358.	0	0.11	0.10
6 STIRL STIRLING-1 HEAT	0.	1780.	6035.	3042.	1355.	397.	0.	-2892.	6035.	3143.	0	0.23	0.22

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 207

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 29113 MW 126.00 PROCESS MILLIONS BTU/HR 3042.0 PROCESS TEMP(F) 470. PRODUCT LARGE-REFINE HOURS PER YEAR 8760.

POWER TO HEAT RATIO 0.141

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED- NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET- TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
6 STIRL	STIRLING-1 POWR	0.	564.	1914.	965.	430.	126.	2444.	0.	4358.	RESIDUAL	4358.	0	0.11	0.10	0.70
6 STIRL	STIRLING-1 HEAT	0.	1780.	6035.	3042.	1355.	397.	0.	-2892.	6035.	RESIDUAL	3143.	0	0.23	0.22	0.50
6 STIRL	STIRLING-1 POWR	0.	564.	1914.	965.	430.	126.	2444.	0.	4358.	COAL	4358.	0	0.11	0.10	0.70
6 STIRL	STIRLING-1 HEAT	0.	1780.	6035.	3042.	1355.	397.	0.	-2892.	6035.	COAL	3143.	0	0.23	0.22	0.50
7 HEGT85	HELIUM-GT- POWR	0.	-98.	1339.	-78.	430.	126.	3671.	0.	5010.	COAL-AFB	5010.	1	-0.02	0.09	0.61
7 HEGT85	HELIUM-GT- HEAT-52024.	0.	3416.	-52024.	3042.	-16700.	-4894.	0.	53530.	-52024.	COAL-AFB	1506.	11	-9.87	*****	2.02
8 HEGT60	HELIUM-GT- POWR	0.	25.	1660.	290.	430.	126.	3237.	0.	4897.	COAL-AFB	4897.	0	0.0	0.09	0.62
8 HEGT60	HELIUM-GT- HEAT	0.	263.	17396.	3042.	4506.	1321.	0.	-12737.	17396.	COAL-AFB	4660.	0	0.01	0.26	0.17
9 HEGT00	HELIUM-GT- POWR	0.	242.	2443.	1140.	430.	126.	2238.	0.	4681.	COAL-AFB	4681.	0	0.05	0.09	0.63
9 HEGT00	HELIUM-GT- HEAT	0.	645.	6520.	3042.	1148.	336.	0.	-2243.	6520.	COAL-AFB	4278.	0	0.09	0.18	0.47
10 FCMCCL	FUEL-CL-MO POWR	0.	712.	1414.	666.	430.	126.	2796.	0.	4210.	COAL	4210.	0	0.14	0.10	0.72
10 FCMCCL	FUEL-CL-MO HEAT	0.	3256.	6462.	3042.	1964.	576.	0.	-4796.	6462.	COAL	1667.	0	0.34	0.30	0.47
11 FCSTCL	FUEL-CL-ST POWR	0.	741.	1160.	474.	430.	126.	3021.	0.	4181.	COAL	4181.	0	0.15	0.10	0.73
11 FCSTCL	FUEL-CL-ST HEAT	0.	4754.	7445.	3042.	2759.	809.	0.	-7277.	7445.	COAL	168.	0	0.39	0.37	0.41
12 IGGTST	INT-GAS-GT POWR	0.	577.	1584.	695.	430.	126.	2761.	0.	4346.	COAL	4346.	0	0.12	0.10	0.70
12 IGGTST	INT-GAS-GT HEAT	0.	2525.	6936.	3042.	1882.	552.	0.	-4539.	6936.	COAL	2397.	0	0.27	0.27	0.44
13 GTSOAR	GT-HRSG-10 POWR	0.	540.	1482.	577.	430.	126.	2899.	0.	4382.	RESIDUAL	4382.	0	0.11	0.10	0.69
13 GTSOAR	GT-HRSG-10 HEAT	0.	2847.	7809.	3042.	2265.	664.	0.	-5734.	7809.	RESIDUAL	2076.	0	0.27	0.29	0.39
14 GTAC08	GT-HRSG-08 POWR	0.	718.	1592.	821.	430.	126.	2612.	0.	4205.	RESIDUAL	4205.	0	0.15	0.10	0.72
14 GTAC08	GT-HRSG-08 HEAT	0.	2658.	5896.	3042.	1592.	467.	0.	-3631.	5896.	RESIDUAL	2265.	0	0.31	0.27	0.52
15 GTAC12	GT-HRSG-12 POWR	0.	702.	1410.	653.	430.	126.	2811.	0.	4221.	RESIDUAL	4221.	0	0.14	0.10	0.72
15 GTAC12	GT-HRSG-12 HEAT	0.	3271.	6570.	3042.	2004.	587.	0.	-4918.	6570.	RESIDUAL	1651.	0	0.33	0.31	0.46
16 GTAC16	GT-HRSG-16 POWR	0.	673.	1331.	562.	430.	126.	2918.	0.	4249.	RESIDUAL	4249.	0	0.14	0.10	0.72
16 GTAC16	GT-HRSG-16 HEAT	0.	3646.	7207.	3042.	2328.	682.	0.	-5931.	7207.	RESIDUAL	1276.	0	0.34	0.32	0.42
17 GTWC16	GT-HRSG-16 POWR	0.	630.	1365.	553.	430.	126.	2928.	0.	4293.	RESIDUAL	4293.	0	0.13	0.10	0.71
17 GTWC16	GT-HRSG-16 HEAT	0.	3462.	7502.	3042.	2363.	693.	0.	-6042.	7502.	RESIDUAL	1461.	0	0.32	0.32	0.41

HONEYWELL PAGE PRINTING SYSTEM - P1185-02



DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 208

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 29113 MW 126.00 PROCESS MILLIONS BTU/HR 3042.0 PROCESS TEMP(F) 470. PRODUCT LARGE-REFINE HOURS PER YEAR 8760.

POWER TO HEAT RATIO 0.141

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED-NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
18	CC1626 GTST-16/26 POWR	0.	614.	1169.	374.	430.	126.	3139.	0.	4308.	RESIDUAL	4308.	0	0.12	0.10	0.71
18	CC1626 GTST-16/26 HEAT	0.	4995.	9508.	3042.	3496.	1025.	0.	-9581.	9508.	RESIDUAL	-73.	0	0.34	0.37	0.32
19	CC1622 GTST-16/22 POWR	0.	645.	1189.	417.	430.	126.	3089.	0.	4277.	RESIDUAL	4277.	0	0.13	0.10	0.71
19	CC1622 GTST-16/22 HEAT	0.	4710.	8677.	3042.	3139.	920.	0.	-8465.	8677.	RESIDUAL	212.	0	0.35	0.36	0.35
20	CC1222 GTST-12/22 POWR	0.	651.	1186.	419.	430.	126.	3085.	0.	4271.	RESIDUAL	4271.	0	0.13	0.10	0.71
20	CC1222 GTST-12/22 HEAT	0.	4724.	8599.	3042.	3118.	914.	0.	-8401.	8599.	RESIDUAL	198.	0	0.35	0.36	0.35
21	CC0822 GTST-08/22 POWR	0.	699.	1271.	532.	430.	126.	2953.	0.	4224.	RESIDUAL	4224.	0	0.14	0.10	0.72
21	CC0822 GTST-08/22 HEAT	0.	3996.	7267.	3042.	2459.	721.	0.	-6340.	7267.	RESIDUAL	926.	0	0.35	0.34	0.42
22	STIG15 STIG-15-16 POWR	0.	232.	1128.	15.	430.	126.	3562.	0.	4690.	RESIDUAL	4690.	1	0.05	0.09	0.65
22	STIG15 STIG-15-16 HEAT	0.	48185.	234000.	3042.	89154.	26130.	0.	*****234000.	RESIDUAL	-43263.	1	0.17	0.38	0.01	
23	STIG10 STIG-10-16 POWR	0.	333.	1197.	159.	430.	126.	3392.	0.	4589.	RESIDUAL	4589.	1	0.07	0.09	0.66
23	STIG10 STIG-10-16 HEAT	0.	6384.	22958.	3042.	8244.	2416.	0.	-24420.	22958.	RESIDUAL	-1462.	1	0.22	0.36	0.13
24	STIG1S STIG-1S-16 POWR	0.	379.	1283.	270.	430.	126.	3261.	0.	4543.	RESIDUAL	4543.	1	0.08	0.09	0.67
24	STIG1S STIG-1S-16 HEAT	0.	4264.	14431.	3042.	4837.	1418.	0.	-13773.	14431.	RESIDUAL	658.	1	0.23	0.34	0.21
25	DEADV3 DIESEL-ADV POWR	0.	404.	1159.	187.	430.	126.	3359.	0.	4518.	RESIDUAL	4518.	1	0.08	0.10	0.67
25	DEADV3 DIESEL-ADV HEAT	0.	6590.	18896.	3042.	7010.	2055.	0.	-20564.	18896.	RESIDUAL	-1668.	1	0.26	0.37	0.16
26	DEADV2 DIESEL-ADV POWR	0.	531.	1159.	294.	430.	126.	3233.	0.	4391.	RESIDUAL	4391.	1	0.11	0.10	0.69
26	DEADV2 DIESEL-ADV HEAT	0.	5488.	11976.	3042.	4443.	1302.	0.	-12542.	11976.	RESIDUAL	-565.	1	0.31	0.37	0.25
27	DEADV1 DIESEL-ADV POWR	0.	718.	1159.	453.	430.	126.	3046.	0.	4205.	RESIDUAL	4205.	1	0.15	0.10	0.72
27	DEADV1 DIESEL-ADV HEAT	0.	4819.	7780.	3042.	2886.	846.	0.	-7677.	7780.	RESIDUAL	104.	1	0.38	0.37	0.39
28	DEHTPM ADV-DIESEL POWR	0.	589.	1527.	657.	430.	126.	2806.	0.	4334.	RESIDUAL	4334.	0	0.12	0.10	0.70
28	DEHTPM ADV-DIESEL HEAT	0.	2727.	7075.	3042.	1992.	584.	C.	-4880.	7075.	RESIDUAL	2195.	0	0.28	0.28	0.43
29	DESQA3 DIESEL-SQA POWR	0.	331.	1191.	151.	430.	126.	3401.	0.	4592.	DISTILLA	4592.	1	0.07	0.09	0.66
29	DESQA3 DIESEL-SQA HEAT	0.	6648.	23955.	3042.	8648.	2534.	0.	-23680.	23955.	DISTILLA	-1726.	1	0.22	0.36	0.13
29	DESQA3 DIESEL-SQA POWR	0.	331.	1191.	151.	430.	126.	3401.	0.	4592.	RESIDUAL	4592.	1	0.07	0.09	0.66
29	DESQA3 DIESEL-SQA HEAT	0.	6648.	23955.	3042.	8648.	2534.	0.	-25680.	23955.	RESIDUAL	-1726.	1	0.22	0.36	0.13

HONEYWELL PAGE PRINTING SYSTEM- P1195-02

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 29113 MW 126.00 PROCESS MILLIONS BTU/HR 3042.0 PROCESS TEMP(F) 470. PRODUCT LARGE-REFINE HOURS PER YEAR 8760.

POWER TO HEAT RATIO 0.141

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
30 DES0A2 DIESEL-S0A	POWR	0.	461.	1191.	262.	430.	126.	3271.	0.	4461.	DISTILLA	4461.	1	0.09	0.10	0.68
30 DES0A2 DIESEL-S0A	HEAT	0.	5350.	13827.	3042.	4992.	1463.	0.	-14255.	13827.	DISTILLA	-428.	1	0.28	0.36	0.22
30 DES0A2 DIESEL-S0A	POWR	0.	461.	1191.	262.	430.	126.	3271.	0.	4461.	RESIDUAL	4461.	1	0.09	0.10	0.68
30 DES0A2 DIESEL-S0A	HEAT	0.	5350.	13827.	3042.	4992.	1463.	0.	-14255.	13827.	RESIDUAL	-428.	1	0.28	0.36	0.22
31 DES0A1 DIESEL-S0A	POWR	0.	714.	1191.	478.	430.	126.	3017.	0.	4208.	DISTILLA	4208.	1	0.15	0.10	0.72
31 DES0A1 DIESEL-S0A	HEAT	0.	4551.	7586.	3042.	2739.	803.	0.	-7215.	7586.	DISTILLA	372.	1	0.37	0.36	0.40
31 DES0A1 DIESEL-S0A	POWR	0.	714.	1191.	478.	430.	126.	3017.	0.	4208.	RESIDUAL	4208.	1	0.15	0.10	0.72
31 DES0A1 DIESEL-S0A	HEAT	0.	4551.	7586.	3042.	2739.	803.	0.	-7215.	7586.	RESIDUAL	372.	1	0.37	0.36	0.40
32 GTS0AD GT-HRSG-10	POWR	0.	657.	1472.	668.	430.	126.	2793.	0.	4265.	DISTILLA	4265.	0	0.13	0.10	0.71
32 GTS0AD GT-HRSG-10	HEAT	0.	2992.	6703.	3042.	1957.	574.	0.	-4773.	6703.	DISTILLA	1930.	0	0.31	0.29	0.45
33 GTRA08 GT-85RE-08	POWR	0.	543.	1204.	343.	430.	126.	3175.	0.	4379.	DISTILLA	4379.	0	0.11	0.10	0.69
33 GTRA08 GT-85RE-08	HEAT	0.	4813.	10673.	3042.	3810.	1117.	0.	-10564.	10673.	DISTILLA	109.	0	0.31	0.36	0.29
34 GTRA12 GT-85RE-12	POWR	0.	571.	1201.	365.	430.	126.	3150.	0.	4351.	DISTILLA	4351.	0	0.12	0.10	0.70
34 GTRA12 GT-85RE-12	HEAT	0.	4769.	10021.	3042.	3587.	1051.	0.	-9867.	10021.	DISTILLA	154.	0	0.32	0.36	0.30
35 GTRA16 GT-85RE-16	POWR	0.	584.	1232.	401.	430.	126.	3107.	0.	4338.	DISTILLA	4338.	0	0.12	0.10	0.70
35 GTRA16 GT-85RE-16	HEAT	0.	4425.	9335.	3042.	3253.	955.	0.	-8838.	9335.	DISTILLA	497.	0	0.32	0.35	0.33
36 GTR208 GT-60RE-08	POWR	0.	593.	1343.	504.	430.	126.	2986.	0.	4329.	DISTILLA	4329.	0	0.12	0.10	0.70
36 GTR208 GT-60RE-08	HEAT	0.	3579.	8106.	3042.	2594.	760.	0.	-6763.	8106.	DISTILLA	1343.	0	0.31	0.32	0.38
37 GTR212 GT-60RE-12	POWR	0.	593.	1303.	470.	430.	126.	3026.	0.	4329.	DISTILLA	4329.	0	0.12	0.10	0.70
37 GTR212 GT-60RE-12	HEAT	0.	3843.	8440.	3042.	2785.	816.	0.	-7360.	8440.	DISTILLA	1080.	0	0.31	0.33	0.36
38 GTR216 GT-60RE-16	POWR	0.	604.	1276.	456.	430.	126.	3043.	0.	4318.	DISTILLA	4318.	0	0.12	0.10	0.70
38 GTR216 GT-60RE-16	HEAT	0.	4031.	8515.	3042.	2870.	841.	0.	-7624.	8515.	DISTILLA	891.	0	0.32	0.34	0.36
39 GTRW08 GT-85RE-08	POWR	0.	464.	1225.	294.	430.	126.	3233.	0.	4458.	DISTILLA	4458.	0	0.09	0.10	0.68
39 GTRW08 GT-85RE-08	HEAT	0.	4308.	12687.	3042.	4453.	1305.	0.	-12572.	12687.	DISTILLA	114.	0	0.27	0.35	0.24
40 GTRW12 GT-85RE-12	POWR	0.	514.	1181.	299.	430.	126.	3228.	0.	4409.	DISTILLA	4409.	0	0.10	0.10	0.69
40 GTRW12 GT-85RE-12	HEAT	0.	5234.	12034.	3042.	4381.	1284.	0.	-12346.	12034.	DISTILLA	-311.	0	0.30	0.36	0.25

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 29113 MW 126.00 PROCESS MILLIONS BTU/HR 3042.0 PROCESS TEMP(F) 470. PRODUCT LARGE-REFINE HOURS PER YEAR 8760.

POWER TO HEAT RATIO 0.141

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL COAL

	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR.	FAIL	FESR	POWER FACTR	HEAT FACTR
41 GTRW16 GT-85RE-16 PWR	0.	530.	1204.	332.	430.	126.	3188.	0.	4392.	DISTILLA	4392.	0	0.11	0.10	0.69
41 GTRW16 GT-85RE-16 HEAT	0.	4854.	11030.	3042.	3938.	1154.	0.	-10962.	11030.	DISTILLA	68.	0	0.31	0.36	0.28
42 GTR308 GT-60RE-08 PWR	0.	422.	1387.	395.	430.	126.	3114.	0.	4501.	DISTILLA	4501.	0	0.09	0.10	0.68
42 GTR308 GT-60RE-08 HEAT	0.	3245.	10671.	3042.	3308.	970.	0.	-8994.	10671.	DISTILLA	1677.	0	0.23	0.31	0.29
43 GTR312 GT-60RE-12 PWR	0.	556.	1257.	400.	430.	126.	3109.	0.	4366.	DISTILLA	4366.	0	0.11	0.10	0.70
43 GTR312 GT-60RE-12 HEAT	0.	4237.	9571.	3042.	3273.	959.	0.	-8805.	9571.	DISTILLA	685.	0	0.31	0.34	0.32
44 GTR316 GT-60RE-16 PWR	0.	554.	1268.	407.	430.	126.	3100.	0.	4369.	DISTILLA	4369.	0	0.11	0.10	0.70
44 GTR316 GT-60RE-16 HEAT	0.	4142.	9486.	3042.	3216.	942.	0.	-8705.	9486.	DISTILLA	780.	0	0.30	0.34	0.32
45 FCPADS FUEL-CL-PH PWR	0.	438.	1131.	192.	430.	126.	3353.	0.	4484.	DISTILLA	4484.	0	0.09	0.10	0.68
45 FCPADS FUEL-CL-PH HEAT	0.	6934.	17894.	3042.	6800.	1993.	0.	-19906.	17894.	DISTILLA	-2012.	0	0.28	0.38	0.17
46 FCMCDS FUEL-CL-MO PWR	0.	586.	1043.	243.	430.	126.	3293.	0.	4336.	DISTILLA	4336.	0	0.12	0.10	0.70
46 FCMCDS FUEL-CL-MO HEAT	0.	7332.	13056.	3042.	5379.	1576.	0.	-15466.	13056.	DISTILLA	-2410.	0	0.36	0.41	0.23

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 211

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 32111 MW 5.60 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT FLAT-GLASS HOURS PER YEAR 7500.

UTILITY FUEL COAL POWER TO HEAT RATIO \*\*\*\*\* WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

	WASTE FUEL 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
0 ONCOGN N O C O G O N	0.	0.	0.	0.	0.	0.	0.	60.	0.	DISTILLA	60.	0	0.	0.32	0.
1 STM141 STM-TURB-1 POWR	0.	3.	57.	30.	19.	6.	-35.	0.	57.	RESIDUAL	57.	11	0.04	0.33	0.
1 STM141 STM-TURB-1 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	RESIDUAL	60.	111	0.	0.	0.
1 STM141 STM-TURB-1 POWR	0.	3.	57.	30.	19.	6.	-35.	0.	57.	COAL-FGD	57.	11	0.04	0.33	0.
1 STM141 STM-TURB-1 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	COAL-FGD	60.	111	0.	0.	0.
1 STM141 STM-TURB-1 POWR	0.	3.	57.	30.	19.	6.	-35.	0.	57.	COAL-AFB	57.	11	0.04	0.33	0.
1 STM141 STM-TURB-1 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	COAL-AFB	60.	111	0.	0.	0.
2 STM088 STM-TURB-8 POWR	0.	-3.	63.	34.	19.	6.	-41.	0.	63.	RESIDUAL	63.	1	-0.06	0.30	0.
2 STM088 STM-TURB-8 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	RESIDUAL	60.	111	0.	0.	0.
2 STM088 STM-TURB-8 POWR	0.	-3.	63.	34.	19.	6.	-41.	0.	63.	COAL-FGD	63.	1	-0.06	0.30	0.
2 STM088 STM-TURB-8 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	COAL-FGD	60.	111	0.	0.	0.
2 STM088 STM-TURB-8 POWR	0.	-3.	63.	34.	19.	6.	-41.	0.	63.	COAL-AFB	63.	1	-0.06	0.30	0.
2 STM088 STM-TURB-8 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	COAL-AFB	60.	111	0.	0.	0.
3 PFBSTM PFB-STMTB- POWR	0.	10.	50.	24.	19.	6.	-28.	0.	50.	COAL-PFB	50.	11	0.17	0.38	0.
3 PFBSTM PFB-STMTB- HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	COAL-PFB	60.	111	0.	0.	0.
4 TISTMT TI-STMTB-1 POWR	0.	14.	46.	20.	19.	6.	-23.	0.	46.	RESIDUAL	46.	11	0.23	0.41	0.
4 TISTMT TI-STMTB-1 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	RESIDUAL	60.	111	0.	0.	0.
4 TISTMT TI-STMTB-1 POWR	0.	14.	46.	20.	19.	6.	-23.	0.	46.	COAL	46.	11	0.23	0.41	0.
4 TISTMT TI-STMTB-1 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	COAL	60.	111	0.	0.	0.
5 TIHRSG THERMIONIC POWR	0.	-76.	136.	96.	19.	6.	-113.	0.	136.	RESIDUAL	136.	1	-1.27	0.14	0.
5 TIHRSG THERMIONIC HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	RESIDUAL	60.	111	0.	0.	0.
5 TIHRSG THERMIONIC POWR	0.	-76.	136.	96.	19.	6.	-113.	0.	136.	COAL	136.	1	-1.27	0.14	0.
5 TIHRSG THERMIONIC HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	COAL	60.	111	0.	0.	0.
6 STIRL STIRLING-1 POWR	0.	-2.	62.	26.	19.	6.	-30.	0.	62.	DISTILLA	62.	1	-0.04	0.31	0.
6 STIRL STIRLING-1 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	DISTILLA	60.	111	0.	0.	0.

HONEYWELL PAGE PRINTING SYSTEM- P1188-01

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 32111 MW 5.60 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT FLAT-GLASS HOURS PER YEAR 7500.

POWER TO HEAT RATIO \*\*\*\*\*

UTILITY FUEL COAL WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
------------------------------	---------------------------------	------------------------------	--------------------------------	---------------------------------	----------------	-------------------------------	-------------------------------	------------------------------	-----------------------------	---------------------------------	------	------	-------------	------------

6 STIRL STIRLING-1 POWR	0.	-2.	62.	26.	19.	6.	-30.	0.	62.	RESIDUAL	62.	1	-0.04	0.31	0.
6 STIRL STIRLING-1 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	RESIDUAL	60.	111	0.	0.	0.
6 STIRL STIRLING-1 POWR	0.	-2.	62.	26.	19.	6.	-30.	0.	62.	COAL	62.	1	-0.04	0.31	0.
6 STIRL STIRLING-1 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	COAL	60.	111	0.	0.	0.
7 HEGT85 HELIUM-GT- POWR	0.	0.	60.	27.	19.	6.	-31.	0.	60.	COAL-AFB	60.	11	0.00	0.32	0.
7 HEGT85 HELIUM-GT- HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	COAL-AFB	60.	111	0.	0.	0.
8 HEGT60 HELIUM-GT- POWR	0.	-14.	74.	32.	19.	6.	-37.	0.	74.	COAL-AFB	74.	11	-0.24	0.26	0.
8 HEGT60 HELIUM-GT- HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	COAL-AFB	60.	111	0.	0.	0.
9 HEGT00 HELIUM-GT- POWR	0.	-49.	109.	66.	19.	6.	-77.	0.	109.	COAL-AFB	109.	11	-0.82	0.18	0.
9 HEGT00 HELIUM-GT- HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	COAL-AFB	60.	111	0.	0.	0.
10 FCMCCL FUEL-CL-MO POWR	0.	-3.	63.	30.	19.	6.	-35.	0.	63.	COAL	63.	11	-0.05	0.30	0.
10 FCMCCL FUEL-CL-MO HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	COAL	60.	111	0.	0.	0.
11 FCSTCL FUEL-CL-ST POWR	0.	21.	39.	11.	19.	6.	-13.	0.	39.	COAL	39.	11	0.35	0.49	0.
11 FCSTCL FUEL-CL-ST HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	COAL	60.	111	0.	0.	0.
12 IGGTST INT-GAS-GT POWR	0.	12.	48.	15.	19.	6.	-17.	0.	48.	COAL	48.	11	0.20	0.40	0.
12 IGGTST INT-GAS-GT HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	COAL	60.	111	0.	0.	0.
13 GTSOAR GT-HRSG-10 POWR	0.	-6.	66.	33.	19.	6.	-58.	0.	66.	RESIDUAL	66.	11	-0.10	0.29	0.
13 GTSOAR GT-HRSG-10 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	RESIDUAL	60.	111	0.	0.	0.
14 GTAC08 GT-HRSG-08 POWR	0.	-11.	71.	34.	19.	6.	-40.	0.	71.	RESIDUAL	71.	11	-0.19	0.27	0.
14 GTAC08 GT-HRSG-08 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	RESIDUAL	60.	111	0.	0.	0.
15 GTAC12 GT-HRSG-12 POWR	0.	-3.	63.	32.	19.	6.	-38.	0.	63.	RESIDUAL	63.	11	-0.05	0.31	0.
15 GTAC12 GT-HRSG-12 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	RESIDUAL	60.	111	0.	0.	0.
16 GTAC16 GT-HRSG-16 POWR	0.	1.	59.	30.	19.	6.	-35.	0.	59.	RESIDUAL	59.	11	0.01	0.32	0.
16 GTAC16 GT-HRSG-16 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	RESIDUAL	60.	111	0.	0.	0.
17 GTWC16 GT-HRSG-16 POWR	0.	-1.	61.	24.	19.	6.	-28.	0.	61.	RESIDUAL	61.	11	-0.02	0.32	0.
17 GTWC16 GT-HRSG-16 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	RESIDUAL	60.	111	0.	0.	0.

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 213

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 32111 MW 5.60 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT FLAT-GLASS HOURS PER YEAR 7500.

UTILITY FUEL		COAL		POWER TO HEAT RATIO *****										WASTE FUEL EQV BTU*10**6=		0.		HOT WATER BTU*10**6=		0.	
WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED-NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR						
18 CC1626 GTST-16/26 POWR	0.	18.	41.	9.	19.	6.	-11.	0.	41.	RESIDUAL	41.	11	0.31	0.46	0.						
18 CC1626 GTST-16/26 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	RESIDUAL	60.	111	0.	0.	0.						
19 CC1622 GTST-16/22 POWR	0.	18.	41.	10.	19.	6.	-12.	0.	41.	RESIDUAL	41.	11	0.31	0.46	0.						
19 CC1622 GTST-16/22 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	RESIDUAL	60.	111	0.	0.	0.						
20 CC1222 GTST-12/22 POWR	0.	19.	41.	10.	19.	6.	-12.	0.	41.	RESIDUAL	41.	11	0.31	0.47	0.						
20 CC1222 GTST-12/22 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	RESIDUAL	60.	111	0.	0.	0.						
21 CC0822 GTST-08/22 POWR	0.	18.	41.	12.	19.	6.	-14.	0.	41.	RESIDUAL	41.	11	0.31	0.46	0.						
21 CC0822 GTST-08/22 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	RESIDUAL	60.	111	0.	0.	0.						
22 STIG15 STIG-15-16 POWR	0.	10.	50.	1.	19.	6.	-1.	0.	50.	RESIDUAL	50.	11	0.16	0.38	0.						
22 STIG15 STIG-15-16 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	RESIDUAL	60.	111	0.	0.	0.						
23 STIG10 STIG-10-16 POWR	0.	7.	53.	7.	19.	6.	-8.	0.	53.	RESIDUAL	53.	11	0.11	0.36	0.						
23 STIG10 STIG-10-16 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	RESIDUAL	60.	111	0.	0.	0.						
24 STIG1S STIG-1S-16 POWR	0.	3.	57.	12.	19.	6.	-14.	0.	57.	RESIDUAL	57.	11	0.05	0.34	0.						
24 STIG1S STIG-1S-16 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	RESIDUAL	60.	111	0.	0.	0.						
25 DEADV3 DIESEL-ADV POWR	0.	8.	52.	19.	19.	6.	-22.	0.	52.	RESIDUAL	52.	1	0.14	0.37	0.						
25 DEADV3 DIESEL-ADV HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	RESIDUAL	60.	111	0.	0.	0.						
26 DEADV2 DIESEL-ADV POWR	0.	8.	52.	13.	19.	6.	-15.	0.	52.	RESIDUAL	52.	1	0.14	0.37	0.						
26 DEADV2 DIESEL-ADV HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	RESIDUAL	60.	111	0.	0.	0.						
27 DEADV1 DIESEL-ADV POWR	0.	8.	52.	20.	19.	6.	-24.	0.	52.	RESIDUAL	52.	1	0.14	0.37	0.						
27 DEADV1 DIESEL-ADV HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	RESIDUAL	60.	111	0.	0.	0.						
28 DEHTPM ADV-DIESEL POWR	0.	12.	48.	24.	19.	6.	-29.	0.	48.	RESIDUAL	48.	1	0.20	0.40	0.						
28 DEHTPM ADV-DIESEL HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	RESIDUAL	60.	111	0.	0.	0.						
29 DES0A3 DIESEL-S0A POWR	0.	7.	53.	17.	19.	6.	-20.	0.	53.	DISTILLA	53.	1	0.11	0.36	0.						
29 DES0A3 DIESEL-S0A HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	DISTILLA	60.	111	0.	0.	0.						
29 DES0A3 DIESEL-S0A POWR	0.	7.	53.	17.	19.	6.	-20.	0.	53.	RESIDUAL	53.	1	0.11	0.36	0.						
29 DES0A3 DIESEL-S0A HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	RESIDUAL	60.	111	0.	0.	0.						

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 32111 MW 5.60 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT FLAT-GLASS HOURS PER YEAR 7500.

UTILITY FUEL		COAL		POWER TO HEAT RATIO ***** WASTE FUEL EQV BTU*10**6= 0. HOT WATER BTU*10**6= 0.												
		WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
30	DESOA2 DIESEL-SOA POWR	0.	7.	53.	12.	19.	6.	-14.	0.	53.	DISTILLA	53.	1	0.11	0.36	0.
30	DESOA2 DIESEL-SOA HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	DISTILLA	60.	111	0.	0.	0.
30	DESOA2 DIESEL-SOA POWR	0.	7.	53.	12.	19.	6.	-14.	0.	53.	RESIDUAL	53.	1	0.11	0.36	0.
30	DESOA2 DIESEL-SOA HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	RESIDUAL	60.	111	0.	0.	0.
31	DESOA1 DIESEL-SOA POWR	0.	7.	53.	21.	19.	6.	-25.	0.	53.	DISTILLA	53.	1	0.11	0.36	0.
31	DESOA1 DIESEL-SOA HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	DISTILLA	60.	111	0.	0.	0.
31	DESOA1 DIESEL-SOA POWR	0.	7.	53.	21.	19.	6.	-25.	0.	53.	RESIDUAL	53.	1	0.11	0.36	0.
31	DESOA1 DIESEL-SOA HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	RESIDUAL	60.	111	0.	0.	0.
32	GTSCAD GT-HRSO-10 POWR	0.	-6.	65.	35.	19.	6.	-41.	0.	65.	DISTILLA	65.	11	-0.10	0.29	0.
32	GTSCAD GT-HRSO-10 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	DISTILLA	60.	111	0.	0.	0.
33	GTRA08 GT-85RE-08 POWR	0.	6.	54.	22.	19.	6.	-25.	0.	54.	DISTILLA	54.	11	0.10	0.36	0.
33	GTRA08 GT-85RE-08 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	DISTILLA	60.	111	0.	0.	0.
34	GTRA12 GT-85RE-12 POWR	0.	6.	53.	22.	19.	6.	-26.	0.	53.	DISTILLA	53.	11	0.11	0.36	0.
34	GTRA12 GT-85RE-12 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	DISTILLA	60.	111	0.	0.	0.
35	GTRA16 GT-85RE-16 POWR	0.	5.	55.	23.	19.	6.	-27.	0.	55.	DISTILLA	55.	11	0.08	0.35	0.
35	GTRA16 GT-85RE-16 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	DISTILLA	60.	111	0.	0.	0.
36	GTR208 GT-60RE-08 POWR	0.	0.	60.	28.	19.	6.	-33.	0.	60.	DISTILLA	60.	11	0.	0.32	0.
36	GTR208 GT-60RE-08 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	DISTILLA	60.	111	0.	0.	0.
37	GTR212 GT-60RE-12 POWR	0.	2.	58.	26.	19.	6.	-30.	0.	58.	DISTILLA	58.	11	0.03	0.33	0.
37	GTR212 GT-60RE-12 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	DISTILLA	60.	111	0.	0.	0.
38	GTR216 GT-60RE-16 POWR	0.	3.	57.	25.	19.	6.	-30.	0.	57.	DISTILLA	57.	11	0.05	0.34	0.
38	GTR216 GT-60RE-16 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	DISTILLA	60.	111	0.	0.	0.
39	GTRW08 GT-85RE-08 POWR	0.	5.	54.	18.	19.	6.	-21.	0.	54.	DISTILLA	54.	11	0.09	0.35	0.
39	GTRW08 GT-85RE-08 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	DISTILLA	60.	111	0.	0.	0.
40	GTRW12 GT-85RE-12 POWR	0.	7.	52.	17.	19.	6.	-21.	0.	52.	DISTILLA	52.	11	0.12	0.36	0.
40	GTRW12 GT-85RE-12 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	DISTILLA	60.	111	0.	0.	0.

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 215

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 32111 MW 5.60 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT FLAT-GLASS HOURS PER YEAR 7500.

POWER TO HEAT RATIO \*\*\*\*\*

UTILITY FUEL COAL

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES 10**6 BTU/HR	UTILIT FUEL 10**6 BTU/HR	TOTAL FUEL 10**6 BTU/HR	SITE FUEL 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41 GTRW16 GT-85RE-16 POWR	0.	6.	54.	19.	19.	6.	-22.	0.	54.	DISTILLA	54.	11	0.10	0.36	0.
41 GTRW16 GT-85RE-16 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	DISTILLA	60.	111	0.	0.	0.
42 GTR308 GT-60RE-08 POWR	0.	-2.	62.	28.	19.	6.	-33.	0.	62.	DISTILLA	62.	11	-0.03	0.31	0.
42 GTR308 GT-60RE-08 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	DISTILLA	60.	111	0.	0.	0.
43 GTR312 GT-60RE-12 POWR	0.	4.	56.	21.	19.	6.	-25.	0.	56.	DISTILLA	56.	11	0.06	0.34	0.
43 GTR312 GT-60RE-12 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	DISTILLA	60.	111	0.	0.	0.
44 GTR316 GT-60RE-16 POWR	0.	3.	56.	22.	19.	6.	-25.	0.	56.	DISTILLA	56.	11	0.06	0.34	0.
44 GTR316 GT-60RE-16 HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	DISTILLA	60.	111	0.	0.	0.
45 FCPADS FUEL-CL-PH POWR	0.	9.	50.	9.	19.	6.	-10.	0.	50.	DISTILLA	50.	1	0.16	0.38	0.
45 FCPADS FUEL-CL-PH HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	DISTILLA	60.	111	0.	0.	0.
46 FCMCDS FUEL-CL-MO POWR	0.	13.	46.	11.	19.	6.	-13.	0.	46.	DISTILLA	46.	1	0.22	0.41	0.
46 FCMCDS FUEL-CL-MO HEAT	0.	0.	0.	0.	0.	0.	0.	60.	0.	DISTILLA	60.	111	0.	0.	0.

ORIGINAL PAGE IS  
OF POOR QUALITY



I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 32211 MW 5.10 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT GLASS-CONTAINERS HOURS PER YEAR 7500.

UTILITY FUEL		COAL		POWER TO HEAT RATIO ***** WASTE FUEL EQV BTU*10**6= 0. HOT WATER BTU*10**6= 0.												
		WASTE FUEL USED 10**6 BTU/HR	SAVED= FUEL NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
0	ONCOGN N O C O G O N	0.	0.	0.	0.	0.	0.	0.	54.	0.	DISTILLA	54.	0	0.	0.32	0.
1	STM141 STM-TURB-1 POWR	0.	2.	52.	27.	17.	5.	-32.	0.	52.	RESIDUAL	52.	11	0.04	0.33	0.
1	STM141 STM-TURB-1 HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	RESIDUAL	54.	111	0.	0.	0.
1	STM141 STM-TURB-1 POWR	0.	2.	52.	27.	17.	5.	-32.	0.	52.	COAL-FGD	52.	11	0.04	0.33	0.
1	STM141 STM-TURB-1 HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	COAL-FGD	54.	111	0.	0.	0.
1	STM141 STM-TURB-1 POWR	0.	2.	52.	27.	17.	5.	-32.	0.	52.	COAL-AFB	52.	11	0.04	0.33	0.
1	STM141 STM-TURB-1 HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	COAL-AFB	54.	111	0.	0.	0.
2	STMO88 STM-TURB-8 POWR	0.	-3.	57.	31.	17.	5.	-37.	0.	57.	RESIDUAL	57.	1	-0.06	0.30	0.
2	STMO88 STM-TURB-8 HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	RESIDUAL	54.	111	0.	0.	0.
2	STMO88 STM-TURB-8 POWR	0.	-3.	57.	31.	17.	5.	-37.	0.	57.	COAL-FGD	57.	1	-0.06	0.30	0.
2	STMO88 STM-TURB-8 HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	COAL-FGD	54.	111	0.	0.	0.
2	STMO88 STM-TURB-8 POWR	0.	-3.	57.	31.	17.	5.	-37.	0.	57.	COAL-AFB	57.	1	-0.06	0.30	0.
2	STMO88 STM-TURB-8 HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	COAL-AFB	54.	111	0.	0.	0.
3	PFBSTM PFB-STMTB- POWR	0.	9.	45.	21.	17.	5.	-25.	0.	45.	COAL-PFB	45.	11	0.17	0.38	0.
3	PFBSTM PFB-STMTB- HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	COAL-PFB	54.	111	0.	0.	0.
4	TISTMT TI-STMTB-1 POWR	0.	12.	42.	18.	17.	5.	-21.	0.	42.	RESIDUAL	42.	11	0.23	0.41	0.
4	TISTMT TI-STMTB-1 HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	RESIDUAL	54.	111	0.	0.	0.
4	TISTMT TI-STMTB-1 POWR	0.	12.	42.	18.	17.	5.	-21.	0.	42.	COAL	42.	11	0.23	0.41	0.
4	TISTMT TI-STMTB-1 HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	COAL	54.	111	0.	0.	0.
5	TIHRSG THERMIONIC POWR	0.	-69.	124.	87.	17.	5.	-103.	0.	124.	RESIDUAL	124.	1	-1.27	0.14	0.
5	TIHRSG THERMIONIC HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	RESIDUAL	54.	111	0.	0.	0.
5	TIHRSG THERMIONIC POWR	0.	-69.	124.	87.	17.	5.	-103.	0.	124.	COAL	124.	1	-1.27	0.14	0.
5	TIHRSG THERMIONIC HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	COAL	54.	111	0.	0.	0.
6	STIRL STIRLING-1 POWR	0.	-2.	57.	24.	17.	5.	-28.	0.	57.	DISTILLA	57.	1	-0.04	0.31	0.
6	STIRL STIRLING-1 HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	DISTILLA	54.	111	0.	0.	0.

GENERAL ELECTRIC COMPANY  
 COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
 REPORT 5.1  
 \*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

DATE 06/06/79  
 I&SE PEO ADV DESIGN ENGR

INDUSTRY 32211 MW 5.10 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT GLASS-CONTAIN HOURS PER YEAR 7500.  
 WASTE FUEL COAL

UTILITY FUEL	COAL	POWER TO HEAT RATIO *****										NET- TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FEES	POWER HEAT FACTR	
		WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= 10-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN ELECT 10**6 BTU/HR	AUX PROCES BOILER 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR					HOT WATER BTU=10**6=
6 STIRL	STIRLING-1 POWR	0.	-2.	57.	24.	17.	5.	-28.	0.	57.	RESIDUAL	57.	1	-0.04	0.31	0.
6 STIRL	STIRLING-1 HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	RESIDUAL	54.	111	0.	0.	0.
6 STIRL	STIRLING-1 POWR	0.	-2.	57.	24.	17.	5.	-28.	0.	57.	COAL	57.	1	-0.04	0.31	0.
6 STIRL	STIRLING-1 HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	COAL	54.	111	0.	0.	0.
7 HEGT85	HELIUM-GT- POWR	0.	0.	54.	24.	17.	5.	-28.	0.	54.	COAL-AFB	54.	11	0.00	0.32	0.
7 HEGT85	HELIUM-GT- HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	COAL-AFB	54.	111	0.	0.	0.
8 HEGT60	HELIUM-GT- POWR	0.	-13.	67.	29.	17.	5.	-34.	0.	67.	COAL-AFB	67.	11	-0.24	0.26	0.
8 HEGT60	HELIUM-GT- HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	COAL-AFB	54.	111	0.	0.	0.
9 HEGT00	HELIUM-GT- POWR	0.	-44.	99.	60.	17.	5.	-70.	0.	99.	COAL-AFB	99.	11	-0.62	0.18	0.
9 HEGT00	HELIUM-GT- HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	COAL-AFB	54.	111	0.	0.	0.
10 FCMCCL	FUEL-CL-MO POWR	0.	-3.	57.	27.	17.	5.	-32.	0.	57.	COAL	57.	11	-0.05	0.30	0.
10 FCMCCL	FUEL-CL-MO HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	COAL	54.	111	0.	0.	0.
11 FCSTCL	FUEL-CL-ST POWR	0.	19.	35.	10.	17.	5.	-12.	0.	35.	COAL	35.	11	0.35	0.49	0.
11 FCSTCL	FUEL-CL-ST HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	COAL	54.	111	0.	0.	0.
12 IGGTST	INT-GAS-GT POWR	0.	11.	44.	13.	17.	5.	-16.	0.	44.	COAL	44.	11	0.20	0.40	0.
12 IGGTST	INT-GAS-GT HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	COAL	54.	111	0.	0.	0.
13 GTSOAR	GT-HRSG-10 POWR	0.	-6.	60.	30.	17.	5.	-35.	0.	60.	RESIDUAL	60.	11	-0.10	0.29	0.
13 GTSOAR	GT-HRSG-10 HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	RESIDUAL	54.	111	0.	0.	0.
14 GTAC08	GT-HRSG-08 POWR	0.	-10.	64.	31.	17.	5.	-36.	0.	64.	RESIDUAL	64.	11	-0.19	0.27	0.
14 GTAC08	GT-HRSG-08 HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	RESIDUAL	54.	111	0.	0.	0.
15 GTAC12	GT-HRSG-12 POWR	0.	-3.	57.	29.	17.	5.	-35.	0.	57.	RESIDUAL	57.	11	-0.05	0.31	0.
15 GTAC12	GT-HRSG-12 HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	RESIDUAL	54.	111	0.	0.	0.
16 GTAC16	GT-HRSG-16 POWR	0.	1.	54.	27.	17.	5.	-32.	0.	54.	RESIDUAL	54.	11	0.01	0.32	0.
16 GTAC16	GT-HRSG-16 HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	RESIDUAL	54.	111	0.	0.	0.
17 GTVC16	GT-HRSG-16 POWR	0.	-1.	55.	22.	17.	5.	-26.	0.	55.	RESIDUAL	55.	11	-0.02	0.32	0.
17 GTVC16	GT-HRSG-16 HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	RESIDUAL	54.	111	0.	0.	0.

I&amp;SE PEOP ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 32211 MW 5.10 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT GLASS-CONTAINERS HOURS PER YEAR 7500.

UTILITY FUEL COAL POWER TO HEAT RATIO \*\*\*\*\*  
WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

			WASTE FUEL USED 10**6 BTU/HR	SAVED= FUEL NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN ELECT 10**6 BTU/HR	AUX BOILER 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
16	CC1626	GTST-16/26	POWR	0.	17.	38.	9.	17.	5.	-10.	0.	38.	RESIDUAL	38.	11	0.31	0.46	0.
18	CC1626	GTST-16/26	HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	RESIDUAL	54.	111	0.	0.	0.
19	CC1622	GTST-16/22	POWR	0.	17.	38.	9.	17.	5.	-11.	0.	38.	RESIDUAL	38.	11	0.31	0.46	0.
19	CC1622	GTST-16/22	HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	RESIDUAL	54.	111	0.	0.	0.
20	CC1222	GTST-12/22	POWR	0.	17.	37.	9.	17.	5.	-11.	0.	37.	RESIDUAL	37.	11	0.31	0.47	0.
20	CC1222	GTST-12/22	HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	RESIDUAL	54.	111	0.	0.	0.
21	CC0822	GTST-08/22	POWR	0.	17.	38.	11.	17.	5.	-13.	0.	38.	RESIDUAL	38.	11	0.31	0.46	0.
21	CC0822	GTST-08/22	HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	RESIDUAL	54.	111	0.	0.	0.
22	STIG15	STIG-15-16	POWR	0.	9.	46.	1.	17.	5.	-1.	0.	46.	RESIDUAL	46.	11	0.16	0.38	0.
22	STIG15	STIG-15-16	HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	RESIDUAL	54.	111	0.	0.	0.
23	STIG10	STIG-10-16	POWR	0.	6.	48.	6.	17.	5.	-8.	0.	48.	RESIDUAL	48.	11	0.11	0.36	0.
23	STIG10	STIG-10-16	HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	RESIDUAL	54.	111	0.	0.	0.
24	STIG1S	STIG-1S-16	POWR	0.	2.	52.	11.	17.	5.	-13.	0.	52.	RESIDUAL	52.	11	0.05	0.34	0.
24	STIG1S	STIG-1S-16	HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	RESIDUAL	54.	111	0.	0.	0.
25	DEADV3	DIESEL-ADV	POWR	0.	7.	47.	17.	17.	5.	-20.	0.	47.	RESIDUAL	47.	1	0.14	0.37	0.
25	DEADV3	DIESEL-ADV	HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	RESIDUAL	54.	111	0.	0.	0.
26	DEADV2	DIESEL-ADV	POWR	0.	7.	47.	12.	17.	5.	-14.	0.	47.	RESIDUAL	47.	1	0.14	0.37	0.
26	DEADV2	DIESEL-ADV	HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	RESIDUAL	54.	111	0.	0.	0.
27	DEADV1	DIESEL-ADV	POWR	0.	7.	47.	18.	17.	5.	-22.	0.	47.	RESIDUAL	47.	1	0.14	0.37	0.
27	DEADV1	DIESEL-ADV	HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	RESIDUAL	54.	111	0.	0.	0.
28	DEHTPM	ADV-DIESEL	POWR	0.	11.	43.	22.	17.	5.	-26.	0.	43.	RESIDUAL	43.	1	0.20	0.40	0.
28	DEHTPM	ADV-DIESEL	HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	RESIDUAL	54.	111	0.	0.	0.
29	DES0A3	DIESEL-S0A	POWR	0.	6.	48.	16.	17.	5.	-18.	0.	48.	DISTILLA	48.	1	0.11	0.36	0.
29	DES0A3	DIESEL-S0A	HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	DISTILLA	54.	111	0.	0.	0.
29	DES0A3	DIESEL-S0A	POWR	0.	6.	48.	16.	17.	5.	-18.	0.	48.	RESIDUAL	48.	1	0.11	0.36	0.
29	DES0A3	DIESEL-S0A	HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	RESIDUAL	54.	111	0.	0.	0.

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

DATE 06/06/79

1&SE PEQ ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS:\*\*

INDUSTRY 322.1 MW 5.10 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT GLASS-CONTAIN HOURS PER YEAR 7500.

UTILITY FUEL COAL POWER TO HEAT RATIO \*\*\*\*\* HOT WATER BTU\*10\*\*6= 0.

	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES ELECT 10**6 BTU/HR	AUX BOILER 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	FUEL SITE USED 10**6 BTU/HR	NET+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR
30 DES0A2 DIESEL-S0A POWR	0.	6.	48.	11.	17.	5.	-12.	0.	48.	111	0.	0.36
30 DES0A2 DIESEL-S0A HEAT	0.	0.	0.	0.	0.	0.	0.	54.	54.	0.	0.	0.
30 DES0A2 DIESEL-S0A POWR	0.	6.	48.	11.	17.	5.	-12.	0.	48.	111	0.	0.36
30 DES0A2 DIESEL-S0A HEAT	0.	0.	0.	0.	0.	0.	0.	54.	54.	0.	0.	0.
31 DES0A1 DIESEL-S0A POWR	0.	6.	48.	11.	17.	5.	-23.	0.	48.	111	0.	0.36
31 DES0A1 DIESEL-S0A HEAT	0.	0.	0.	0.	0.	0.	0.	54.	54.	0.	0.	0.
31 DES0A1 DIESEL-S0A POWR	0.	6.	48.	19.	17.	5.	-23.	0.	48.	111	0.	0.36
31 DES0A1 DIESEL-S0A HEAT	0.	0.	0.	0.	0.	0.	0.	54.	54.	0.	0.	0.
32 GTS0A0 GT-HRSG-10 POWR	0.	5.	60.	32.	17.	5.	-38.	0.	60.	111	0.	0.29
32 GTS0A0 GT-HRSG-10 HEAT	0.	0.	0.	0.	0.	0.	0.	54.	54.	0.	0.	0.
33 GTRA05 GT-85RE-08 POWR	0.	6.	49.	20.	17.	5.	-23.	0.	49.	111	0.	0.36
33 GTRA05 GT-85RE-08 HEAT	0.	0.	0.	0.	0.	0.	0.	54.	54.	0.	0.	0.
34 GTRA12 GT-85RE-12 POWR	0.	6.	49.	20.	17.	5.	-23.	0.	49.	111	0.	0.36
34 GTRA12 GT-85RE-12 HEAT	0.	0.	0.	0.	0.	0.	0.	54.	54.	0.	0.	0.
35 GTRA16 GT-85RE-16 POWR	0.	5.	50.	21.	17.	5.	-25.	0.	50.	111	0.	0.35
35 GTRA16 GT-85RE-16 HEAT	0.	0.	0.	0.	0.	0.	0.	54.	54.	0.	0.	0.
36 GTR208 GT-60RE-08 POWR	0.	0.	54.	26.	17.	5.	-30.	0.	54.	111	0.	0.32
36 GTR208 GT-60RE-08 HEAT	0.	0.	0.	0.	0.	0.	0.	54.	54.	0.	0.	0.
37 GTR212 GT-60RE-12 POWR	0.	2.	53.	24.	17.	5.	-28.	0.	53.	111	0.	0.33
37 GTR212 GT-60RE-12 HEAT	0.	0.	0.	0.	0.	0.	0.	54.	54.	0.	0.	0.
38 GTR216 GT-60RE-16 POWR	0.	3.	52.	23.	17.	5.	-27.	0.	52.	111	0.	0.34
38 GTR216 GT-60RE-16 HEAT	0.	0.	0.	0.	0.	0.	0.	54.	54.	0.	0.	0.
39 GTR108 GT-85RE-08 POWR	0.	5.	50.	16.	17.	5.	-19.	0.	50.	111	0.	0.35
39 GTR108 GT-85RE-08 HEAT	0.	0.	0.	0.	0.	0.	0.	54.	54.	0.	0.	0.
40 GTR112 GT-85RE-12 POWR	0.	7.	48.	16.	17.	5.	-19.	0.	48.	111	0.	0.36
40 GTR112 GT-85RE-12 HEAT	0.	0.	0.	0.	0.	0.	0.	54.	54.	0.	0.	0.

I&SE PEG ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 32211 MW 5.10 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT GLASS-CONTAI HOURS PER YEAR 7500.

UTILITY FUEL		COAL		POWER TO HEAT RATIO *****										WASTE FUEL EQV BTU*10**6=		HOT WATER BTU*10**6=	
WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED-NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR			
41 GTRW16	GT-85RE-16	POWR	0.	6.	49.	17.	17.	5.	-20.	0.	49.	DISTILLA	49.	11	0.10	0.36	0.
41 GTRW16	GT-85RE-16	HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	DISTILLA	54.	111	0.	0.	0.
42 GTR308	GT-60RE-08	POWR	0.	-2.	56.	25.	17.	5.	-30.	0.	56.	DISTILLA	56.	11	-0.03	0.31	0.
42 GTR308	GT-60RE-08	HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	DISTILLA	54.	111	0.	0.	0.
43 GTR312	GT-60RE-12	POWR	0.	3.	51.	19.	17.	5.	-23.	0.	51.	DISTILLA	51.	11	0.06	0.34	0.
43 GTR312	GT-60RE-12	HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	DISTILLA	54.	111	0.	0.	0.
44 GTR316	GT-60RE-16	POWR	0.	3.	51.	20.	17.	5.	-23.	0.	51.	DISTILLA	51.	11	0.06	0.34	0.
44 GTR316	GT-60RE-16	HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	DISTILLA	54.	111	0.	0.	0.
45 FCPADS	FUEL-CL-PH	POWR	0.	9.	46.	8.	17.	5.	-9.	0.	46.	DISTILLA	46.	1	0.16	0.38	0.
45 FCPADS	FUEL-CL-PH	HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	DISTILLA	54.	111	0.	0.	0.
46 FCMCDS	FUEL-CL-MO	POWR	0.	12.	42.	10.	17.	5.	-12.	0.	42.	DISTILLA	42.	1	0.22	0.41	0.
46 FCMCDS	FUEL-CL-MO	HEAT	0.	0.	0.	0.	0.	0.	0.	54.	0.	DISTILLA	54.	111	0.	0.	0.

ORIGINAL PAGE IS OF POOR QUALITY

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 321

1&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 32291 MW 1.10 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT PRESS-BLOW-G HOURS PER YEAR 7500.

POWER TO HEAT RATIO \*\*\*\*\*

WASTE FUEL EQV BTU\*10\*\*6= 0.

HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESF	POWER FACTR	HEAT FACTR
0 ONOCGN N O C O G O N		0.	0.	0.	0.	0.	0.	0.	12.	0.	DISTILLA	12.	0	0.	0.32	0.
1 STM141 STM-TURB-1 POWR		0.	0.	11.	6.	4.	1.	-7.	0.	11.	RESIDUAL	11.	11	0.04	0.33	0.
1 STM141 STM-TURB-1 HEAT		0.	0.	0.	0.	0.	0.	0.	12.	0.	RESIDUAL	12.	111	0.	0.	0.
1 STM141 STM-TURB-1 POWR		0.	0.	11.	6.	4.	1.	-7.	0.	11.	COAL-FGD	11.	11	0.04	0.33	0.
1 STM141 STM-TURB-1 HEAT		0.	0.	0.	0.	0.	0.	0.	12.	0.	COAL-FGD	12.	111	0.	0.	0.
1 STM141 STM-TURB-1 POWR		0.	0.	11.	6.	4.	1.	-7.	0.	11.	COAL-AFB	11.	11	0.04	0.33	0.
1 STM141 STM-TURB-1 HEAT		0.	0.	0.	0.	0.	0.	0.	12.	0.	COAL-AFB	12.	111	0.	0.	0.
2 STM088 STM-TURB-8 POWR		0.	-1.	12.	7.	4.	1.	-8.	0.	12.	RESIDUAL	12.	11	-0.06	0.30	0.
2 STM088 STM-TURB-8 HEAT		0.	0.	0.	0.	0.	0.	0.	12.	0.	RESIDUAL	12.	111	0.	0.	0.
2 STM088 STM-TURB-8 POWR		0.	-1.	12.	7.	4.	1.	-8.	0.	12.	COAL-FGD	12.	11	-0.06	0.30	0.
2 STM088 STM-TURB-8 HEAT		0.	0.	0.	0.	0.	0.	0.	12.	0.	COAL-FGD	12.	111	0.	0.	0.
2 STM088 STM-TURB-8 POWR		0.	-1.	12.	7.	4.	1.	-8.	0.	12.	COAL-AFB	12.	11	-0.06	0.30	0.
2 STM088 STM-TURB-8 HEAT		0.	0.	0.	0.	0.	0.	0.	12.	0.	COAL-AFB	12.	111	0.	0.	0.
3 PFBSTM PFB-STMTB- POWR		0.	2.	12.	5.	4.	1.	-5.	0.	10.	COAL-PFB	10.	11	0.17	0.30	0.
3 PFBSTM PFB-STMTB- HEAT		0.	0.	0.	0.	0.	0.	0.	12.	0.	COAL-PFB	12.	111	0.	0.	0.
4 T1STMT TI-STMTB-1 POWR		0.	3.	9.	4.	4.	1.	-5.	0.	9.	RESIDUAL	9.	11	0.23	0.41	0.
4 T1STMT TI-STMTB-1 HEAT		0.	0.	0.	0.	0.	0.	0.	12.	0.	RESIDUAL	12.	111	0.	0.	0.
4 T1STMT TI-STMTB-1 POWR		0.	3.	9.	4.	4.	1.	-5.	0.	9.	COAL	9.	11	0.23	0.41	0.
4 T1STMT TI-STMTB-1 HEAT		0.	0.	0.	0.	0.	0.	0.	12.	0.	COAL	12.	111	0.	0.	0.
5 TIHRSG THERMIONIC POWR		0.	-15.	27.	19.	4.	1.	-22.	0.	27.	RESIDUAL	27.	11	-1.27	0.14	0.
5 TIHRSG THERMIONIC HEAT		0.	0.	0.	0.	0.	0.	0.	12.	0.	RESIDUAL	12.	111	0.	0.	0.
5 TIHRSG THERMIONIC POWR		0.	-15.	27.	19.	4.	1.	-22.	0.	27.	COAL	27.	11	-1.27	0.14	0.
5 TIHRSG THERMIONIC HEAT		0.	0.	0.	0.	0.	0.	0.	12.	0.	COAL	12.	111	0.	0.	0.
6 STIRL STIRLING-1 POWR		0.	-0.	12.	5.	4.	1.	-6.	0.	12.	DISTILLA	12.	1	-0.04	0.31	0.
6 STIRL STIRLING-1 HEAT		0.	0.	0.	0.	0.	0.	0.	12.	0.	DISTILLA	12.	111	0.	0.	0.

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 32291 MW 1.10 PROCESS MILLIONS BTU/HR. 0. PROCESS TEMP(F) 0. PRODUCT PRESS-BLOW-G HOURS PER YEAR 7500.

UTILITY FUEL		COAL		POWER TO HEAT RATIO *****										WASTE FUEL EQV BTU*10**6=		HOT WATER BTU*10**6=	
WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILER 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	.NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR			
6 STIRL STIRLING-1 POWR	0.	-0.	12.	5.	4.	1.	-6.	0.	12.	RESIDUAL	12.	1	-0.04	0.31	0.		
6 STIRL STIRLING-1 HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	RESIDUAL	12.	111	0.	0.	0.		
6 STIRL STIRLING-1 POWR	0.	-0.	12.	5.	4.	1.	-6.	0.	12.	COAL	12.	1	-0.04	0.31	0.		
6 STIRL STIRLING-1 HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	COAL	12.	111	0.	0.	0.		
7 HEGT85 HELIUM-GT- POWR	0.	0.	12.	5.	4.	1.	-6.	0.	12.	COAL-AFB	12.	11	0.00	0.32	0.		
7 HEGT85 HELIUM-GT- HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	COAL-AFB	12.	111	0.	0.	0.		
8 HEGT60 HELIUM-GT- POWR	0.	-3.	14.	6.	4.	1.	-7.	0.	14.	COAL-AFB	14.	11	-0.24	0.26	0.		
8 HEGT60 HELIUM-GT- HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	COAL-AFB	12.	111	0.	0.	0.		
9 HEGT00 HELIUM-GT- POWR	0.	-10.	21.	13.	4.	1.	-15.	0.	21.	COAL-AFB	21.	11	-0.82	0.18	0.		
9 HEGT00 HELIUM-GT- HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	COAL-AFB	12.	111	0.	0.	0.		
10 FCMCCL FUEL-CL-MO POWR	0.	-1.	12.	6.	4.	1.	-7.	0.	12.	COAL	12.	11	-0.05	0.30	0.		
10 FCMCCL FUEL-CL-MO HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	COAL	12.	111	0.	0.	0.		
11 FCSTCL FUEL-CL-ST POWR	0.	4.	8.	2.	4.	1.	-3.	0.	8.	COAL	8.	11	0.35	0.49	0.		
11 FCSTCL FUEL-CL-ST HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	COAL	12.	111	0.	0.	0.		
12 IGGTST INT-GAS-GT POWR	0.	2.	9.	3.	4.	1.	-3.	0.	9.	COAL	9.	11	0.20	0.40	0.		
12 IGGTST INT-GAS-GT HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	COAL	12.	111	0.	0.	0.		
13 GTSCAR GT-HRSG-10 POWR	0.	-1.	13.	6.	4.	1.	-8.	0.	13.	RESIDUAL	13.	11	-0.10	0.29	0.		
13 GTSCAR GT-HRSG-10 HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	RESIDUAL	12.	111	0.	0.	0.		
14 GTAC08 GT-HRSG-08 POWR	0.	-2.	14.	7.	4.	1.	-8.	0.	14.	RESIDUAL	14.	11	-0.19	0.27	0.		
14 GTAC08 GT-HRSG-08 HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	RESIDUAL	12.	111	0.	0.	0.		
15 GTAC12 GT-HRSG-12 POWR	0.	-1.	12.	6.	4.	1.	-7.	0.	12.	RESIDUAL	12.	11	-0.05	0.31	0.		
15 GTAC12 GT-HRSG-12 HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	RESIDUAL	12.	111	0.	0.	0.		
16 GTAC16 GT-HRSG-16 POWR	0.	0.	12.	6.	4.	1.	-7.	0.	12.	RESIDUAL	12.	11	0.01	0.32	0.		
16 GTAC16 GT-HRSG-16 HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	RESIDUAL	12.	111	0.	0.	0.		
17 GTWC16 GT-HRSG-16 POWR	0.	-0.	12.	5.	4.	1.	-6.	0.	12.	RESIDUAL	12.	11	-0.02	0.32	0.		
17 GTWC16 GT-HRSG-16 HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	RESIDUAL	12.	111	0.	0.	0.		

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 32291 MW 1.10 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT PRESS-BLOW-13 HOURS PER YEAR 7500.

		POWER TO HEAT RATIO *****														
		WASTE FUEL EQV BTU*10**6=										0. HOT WATER BTU*10**6= 0.				
UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	SAVED= FUEL NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
18	CC1626 GTST-16/26 POWR	0.	4.	8.	2.	4.	1.	-2.	0.	8.	RESIDUAL	8.	11	0.31	0.46	0.
18	CC1626 GTST-16/26 HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	RESIDUAL	12.	111	0.	0.	0.
19	CC1622 GTST-16/22 POWR	0.	4.	8.	2.	4.	1.	-2.	0.	8.	RESIDUAL	8.	11	0.31	0.46	0.
19	CC1622 GTST-16/22 HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	RESIDUAL	12.	111	0.	0.	0.
20	CC1222 GTST-12/22 POWR	0.	4.	8.	2.	4.	1.	-2.	0.	8.	RESIDUAL	8.	11	0.31	0.47	0.
20	CC1222 GTST-12/22 HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	RESIDUAL	12.	111	0.	0.	0.
21	CC0822 GTST-08/22 POWR	0.	4.	8.	2.	4.	1.	-3.	0.	8.	RESIDUAL	8.	11	0.31	0.46	0.
21	CC0822 GTST-08/22 HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	RESIDUAL	12.	111	0.	0.	0.
22	STIG15 STIG-15-16 POWR	0.	2.	10.	0.	4.	1.	-0.	0.	10.	RESIDUAL	10.	11	0.16	0.38	0.
22	STIG15 STIG-15-16 HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	RESIDUAL	12.	111	0.	0.	0.
23	STIG10 STIG-10-16 POWR	0.	1.	10.	1.	4.	1.	-2.	0.	10.	RESIDUAL	10.	11	0.11	0.36	0.
23	STIG10 STIG-10-16 HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	RESIDUAL	12.	111	0.	0.	0.
24	STIG1S STIG-1S-16 POWR	0.	1.	11.	2.	4.	1.	-3.	0.	11.	RESIDUAL	11.	11	0.05	0.34	0.
24	STIG1S STIG-1S-16 HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	RESIDUAL	12.	111	0.	0.	0.
25	DEADV3 DIESEL-ADV POWR	0.	2.	10.	4.	4.	1.	-4.	0.	10.	RESIDUAL	10.	11	0.14	0.37	0.
25	DEADV3 DIESEL-ADV HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	RESIDUAL	12.	111	0.	0.	0.
26	DEADV2 DIESEL-ADV POWR	0.	2.	10.	3.	4.	1.	-3.	0.	10.	RESIDUAL	10.	11	0.14	0.37	0.
26	DEADV2 DIESEL-ADV HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	RESIDUAL	12.	111	0.	0.	0.
27	DEADV1 DIESEL-ADV POWR	0.	2.	10.	4.	4.	1.	-5.	0.	10.	RESIDUAL	10.	11	0.14	0.37	0.
27	DEADV1 DIESEL-ADV HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	RESIDUAL	12.	111	0.	0.	0.
28	DEHTPM ADV-DIESEL POWR	0.	2.	9.	5.	4.	1.	-6.	0.	9.	RESIDUAL	9.	11	0.20	0.40	0.
28	DEHTPM ADV-DIESEL HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	RESIDUAL	12.	111	0.	0.	0.
29	DESCA3 DIESEL-SOA POWR	0.	1.	10.	3.	4.	1.	-4.	0.	10.	DISTILLA	10.	1	0.11	0.36	0.
29	DESCA3 DIESEL-SOA HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	DISTILLA	12.	111	0.	0.	0.
29	DESCA3 DIESEL-SOA POWR	0.	1.	10.	3.	4.	1.	-4.	0.	10.	RESIDUAL	10.	1	0.11	0.36	0.
29	DESCA3 DIESEL-SOA HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	RESIDUAL	12.	111	0.	0.	0.

MONEYWELL PAGE PRINTING SYSTEM- P1185-02



DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 224

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 32291 MW 1.10 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT PRESS-BLOW-G HOURS PER YEAR 7500.

UTILITY FUEL		COAL		POWER TO HEAT RATIO *****										WASTE FUEL EQV BTU*10**6=		HOT WATER BTU*10**6=	
WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN PROCES ELECT 10**6 BTU/HR	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR			
30 DES0A2 DIESEL-S0A POWR	0.	1.	10.	2.	4.	1.	-3.	0.	10.	DISTILLA	10.	1	0.11	0.36	0.		
30 DES0A2 DIESEL-S0A HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	DISTILLA	12.	111	0.	0.	0.		
30 DES0A2 DIESEL-S0A POWR	0.	1.	10.	2.	4.	1.	-3.	0.	10.	RESIDUAL	10.	1	0.11	0.36	0.		
30 DES0A2 DIESEL-S0A HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	RESIDUAL	12.	111	0.	0.	0.		
31 DES0A1 DIESEL-S0A POWR	0.	1.	10.	4.	4.	1.	-5.	0.	10.	DISTILLA	10.	1	0.11	0.36	0.		
31 DES0A1 DIESEL-S0A HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	DISTILLA	12.	111	0.	0.	0.		
31 DES0A1 DIESEL-S0A POWR	0.	1.	10.	4.	4.	1.	-5.	0.	10.	RESIDUAL	10.	1	0.11	0.36	0.		
31 DES0A1 DIESEL-S0A HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	RESIDUAL	12.	111	0.	0.	0.		
32 GTS0AD GT-HRSG-10 POWR	0.	-1.	13.	7.	4.	1.	-8.	0.	13.	DISTILLA	13.	11	-0.10	0.29	0.		
32 GTS0AD GT-HRSG-10 HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	DISTILLA	12.	111	0.	0.	0.		
33 GTRA08 GT-85RE-08 POWR	0.	1.	11.	4.	4.	1.	-5.	0.	11.	DISTILLA	11.	11	0.10	0.36	0.		
33 GTRA08 GT-85RE-08 HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	DISTILLA	12.	111	0.	0.	0.		
34 GTRA12 GT-85RE-12 POWR	0.	1.	10.	4.	4.	1.	-5.	0.	10.	DISTILLA	10.	11	0.11	0.36	0.		
34 GTRA12 GT-85RE-12 HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	DISTILLA	12.	111	0.	0.	0.		
35 GTRA16 GT-85RE-16 POWR	0.	1.	11.	5.	4.	1.	-5.	0.	11.	DISTILLA	11.	11	0.08	0.35	0.		
35 GTRA16 GT-85RE-16 HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	DISTILLA	12.	111	0.	0.	0.		
36 GTR208 GT-60RE-08 POWR	0.	0.	12.	6.	4.	1.	-7.	0.	12.	DISTILLA	12.	11	0.00	0.32	0.		
36 GTR208 GT-60RE-08 HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	DISTILLA	12.	111	0.	0.	0.		
37 GTR212 GT-60RE-12 POWR	0.	0.	11.	5.	4.	1.	-6.	0.	11.	DISTILLA	11.	11	0.03	0.33	0.		
37 GTR212 GT-60RE-12 HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	DISTILLA	12.	111	0.	0.	0.		
38 GTR216 GT-60RE-16 POWR	0.	1.	11.	5.	4.	1.	-6.	0.	11.	DISTILLA	11.	11	0.05	0.34	0.		
38 GTR216 GT-60RE-16 HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	DISTILLA	12.	111	0.	0.	0.		
39 GTRW08 GT-85RE-08 POWR	0.	1.	11.	4.	4.	1.	-4.	0.	11.	DISTILLA	11.	11	0.09	0.35	0.		
39 GTRW08 GT-85RE-08 HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	DISTILLA	12.	111	0.	0.	0.		
40 GTRW12 GT-85RE-12 POWR	0.	1.	10.	3.	4.	1.	-4.	0.	10.	DISTILLA	10.	11	0.12	0.36	0.		
40 GTRW12 GT-85RE-12 HEAT	0.	0.	0.	0.	0.	0.	0.	12.	0.	DISTILLA	12.	111	0.	0.	0.		

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 225

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 32291 MW 1.10 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT PRESS-BLOW-0 HOURS PER YEAR 7500.

POWER TO HEAT RATIO \*\*\*\*\*

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	COGEN FUEL NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41 GTRW16 GT-85RE-16 POWR		0.	1.	11.	4.	4.	1.	-4.	0.	11.DISTILLA		11.	11	0.10	0.36	0.
41 GTRW16 GT-85RE-16 HEAT		0.	0.	0.	0.	0.	0.	0.	12.	0.DISTILLA		12.	111	0.	0.	0.
42 GTR308 GT-60RE-08 POWR		0.	-0.	12.	5.	4.	1.	-6.	0.	12.DISTILLA		12.	11	-0.03	0.31	0.
42 GTR308 GT-60RE-08 HEAT		0.	0.	0.	0.	0.	0.	0.	12.	0.DISTILLA		12.	111	0.	0.	0.
43 GTR312 GT-60RE-12 POWR		0.	1.	11.	4.	4.	1.	-5.	0.	11.DISTILLA		11.	11	0.06	0.34	0.
43 GTR312 GT-60RE-12 HEAT		0.	0.	0.	0.	0.	0.	0.	12.	0.DISTILLA		12.	111	0.	0.	0.
44 GTR316 GT-60RE-16 POWR		0.	1.	11.	4.	4.	1.	-5.	0.	11.DISTILLA		11.	11	0.06	0.34	0.
44 GTR316 GT-60RE-16 HEAT		0.	0.	0.	0.	0.	0.	0.	12.	0.DISTILLA		12.	111	0.	0.	0.
45 FCPADS FUEL-CL-PH POWR		0.	2.	10.	2.	4.	1.	-2.	0.	10.DISTILLA		10.	1	0.16	0.38	0.
45 FCPADS FUEL-CL-PH HEAT		0.	0.	0.	0.	0.	0.	0.	12.	0.DISTILLA		12.	111	0.	0.	0.
46 FCMCDS FUEL-CL-MO POWR		0.	3.	9.	2.	4.	1.	-2.	0.	9.DISTILLA		9.	11	0.22	0.41	0.
46 FCMCDS FUEL-CL-MO HEAT		0.	0.	0.	0.	0.	0.	0.	12.	0.DISTILLA		12.	111	0.	0.	0.

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 227

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 32411 MW 20.32 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT CEMENT HOURS PER YEAR 7920.

POWER TO HEAT RATIO \*\*\*\*\*

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL COAL

WASTE FUEL 10**6 BTU/HR	FUEL NO-NET USED 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
-------------------------------	---	--	----------------------------------	-----------------------------------	----------------------	---------------------------------	---	----------------------------------	---	---	------	------	----------------	---------------

6 STIRL	STIRLING-1	POWR	0.	-9.	225.	94.	69.	20.	-111.	0.	225.	RESIDUAL	225.	1	-0.04	0.31	0.
6 STIRL	STIRLING-1	HEAT	0.	0.	0.	0.	0.	0.	0.	217.	0.	RESIDUAL	217.	111	0.	0.	0.
6 STIRL	STIRLING-1	POWR	0.	-9.	225.	94.	69.	20.	-111.	0.	225.	COAL	225.	1	-0.04	0.31	0.
6 STIRL	STIRLING-1	HEAT	0.	0.	0.	0.	0.	0.	0.	217.	0.	COAL	217.	111	0.	0.	0.
7 HEGT85	HELIUM-GT-	POWR	0.	1.	216.	97.	69.	20.	-114.	0.	216.	COAL-AFB	216.	11	0.00	0.32	0.
7 HEGT85	HELIUM-GT-	HEAT	0.	0.	0.	0.	0.	0.	0.	217.	0.	COAL-AFB	217.	111	0.	0.	0.
8 HEGT60	HELIUM-GT-	POWR	0.	-51.	268.	115.	69.	20.	-135.	0.	268.	COAL-AFB	268.	11	-0.24	0.26	0.
8 HEGT60	HELIUM-GT-	HEAT	0.	0.	0.	0.	0.	0.	0.	217.	0.	COAL-AFB	217.	111	0.	0.	0.
9 HEGT00	HELIUM-GT-	POWR	0.	-177.	394.	238.	69.	20.	-280.	0.	394.	COAL-AFB	394.	11	-0.82	0.18	0.
9 HEGT00	HELIUM-GT-	HEAT	0.	0.	0.	0.	0.	0.	0.	217.	0.	COAL-AFB	217.	111	0.	0.	0.
10 FCMCCL	FUEL-CL-MO	POWR	0.	-11.	228.	109.	69.	20.	-128.	0.	228.	COAL	228.	11	-0.05	0.33	0.
10 FCMCCL	FUEL-CL-MO	HEAT	0.	0.	0.	0.	0.	0.	0.	217.	0.	COAL	217.	111	0.	0.	0.
11 FCSTCL	FUEL-CL-ST	POWR	0.	76.	141.	41.	69.	20.	-48.	0.	141.	COAL	141.	11	0.35	0.49	0.
11 FCSTCL	FUEL-CL-ST	HEAT	0.	0.	0.	0.	0.	0.	0.	217.	0.	COAL	217.	111	0.	0.	0.
12 IGGTST	INT-GAS-GT	POWR	0.	43.	173.	54.	69.	20.	-63.	0.	173.	COAL	173.	11	0.20	0.40	0.
12 IGGTST	INT-GAS-GT	HEAT	0.	0.	0.	0.	0.	0.	0.	217.	0.	COAL	217.	111	0.	0.	0.
13 GTSOAR	GT-HRSG-10	POWR	0.	-22.	239.	118.	69.	20.	-139.	0.	239.	RESIDUAL	239.	1	-0.10	0.29	0.
13 GTSOAR	GT-HRSG-10	HEAT	0.	0.	0.	0.	0.	0.	0.	217.	0.	RESIDUAL	217.	111	0.	0.	0.
14 GTAC08	GT-HRSG-08	POWR	0.	-40.	257.	123.	69.	20.	-145.	0.	257.	RESIDUAL	257.	1	-0.19	0.27	0.
14 GTAC08	GT-HRSG-08	HEAT	0.	0.	0.	0.	0.	0.	0.	217.	0.	RESIDUAL	217.	111	0.	0.	0.
15 GTAC12	GT-HRSG-12	POWR	0.	-11.	227.	117.	69.	20.	-138.	0.	227.	RESIDUAL	227.	1	-0.05	0.31	0.
15 GTAC12	GT-HRSG-12	HEAT	0.	0.	0.	0.	0.	0.	0.	217.	0.	RESIDUAL	217.	111	0.	0.	0.
16 GTAC16	GT-HRSG-16	POWR	0.	2.	215.	108.	69.	20.	-127.	0.	215.	RESIDUAL	215.	1	0.01	0.32	0.
16 GTAC16	GT-HRSG-16	HEAT	0.	0.	0.	0.	0.	0.	0.	217.	0.	RESIDUAL	217.	111	0.	0.	0.
17 GTWC16	GT-HRSG-16	POWR	0.	-3.	220.	88.	69.	20.	-103.	0.	220.	RESIDUAL	220.	1	-0.02	0.32	0.
17 GTWC16	GT-HRSG-16	HEAT	0.	0.	0.	0.	0.	0.	0.	217.	0.	RESIDUAL	217.	111	0.	0.	0.

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

I&SE PER ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 32411 MW 20.32 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT CEMENT HOURS PER YEAR 7920.

POWER TO HEAT RATIO \*\*\*\*\*

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL COAL

WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED-NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
------------------------------	--------------------------------	------------------------------	--------------------------------	---------------------------------	----------------	-------------------------------	-------------------------------	------------------------------	-----------------------------	---------------------------------	------	------	-------------	------------

30 DES0A2 DIESEL-S0A POWR	0.	25.	192.	42.	69.	20.	-50.	0.	192.	DISTILLA	192.	1	0.11	0.36	0.
30 DES0A2 DIESEL-S0A HEAT	0.	0.	0.	0.	0.	0.	0.	217.	0.	DISTILLA	217.	111	0.	0.	0.
30 DES0A2 DIESEL-S0A POWR	0.	25.	192.	42.	69.	20.	-50.	0.	192.	RESIDUAL	192.	1	0.11	0.36	0.
30 DES0A2 DIESEL-S0A HEAT	0.	0.	0.	0.	0.	0.	0.	217.	0.	RESIDUAL	217.	111	0.	0.	0.
31 DES0A1 DIESEL-S0A POWR	0.	25.	192.	77.	69.	20.	-91.	0.	192.	DISTILLA	192.	1	0.11	0.36	0.
31 DES0A1 DIESEL-S0A HEAT	0.	0.	0.	0.	0.	0.	0.	217.	0.	DISTILLA	217.	111	0.	0.	0.
31 DES0A1 DIESEL-S0A POWR	0.	25.	192.	77.	69.	20.	-91.	0.	192.	RESIDUAL	192.	1	0.11	0.36	0.
31 DES0A1 DIESEL-S0A HEAT	0.	0.	0.	0.	0.	0.	0.	217.	0.	RESIDUAL	217.	111	0.	0.	0.
32 GTS0AD GT-HRSG-10 POWR	0.	-21.	237.	128.	69.	20.	-151.	0.	237.	DISTILLA	237.	1	-0.10	0.29	0.
32 GTS0AD GT-HRSG-10 HEAT	0.	0.	0.	0.	0.	0.	0.	217.	0.	DISTILLA	217.	111	0.	0.	0.
33 GTRA08 GT-85RE-08 POWR	0.	22.	194.	78.	69.	20.	-92.	0.	194.	DISTILLA	194.	1	0.10	0.36	0.
33 GTRA08 GT-85RE-08 HEAT	0.	0.	0.	0.	0.	0.	0.	217.	0.	DISTILLA	217.	111	0.	0.	0.
34 GTRA12 GT-85RE-12 POWR	0.	23.	194.	79.	69.	20.	-93.	0.	194.	DISTILLA	194.	1	0.11	0.36	0.
34 GTRA12 GT-85RE-12 HEAT	0.	0.	0.	0.	0.	0.	0.	217.	0.	DISTILLA	217.	111	0.	0.	0.
35 GTRA16 GT-85RE-16 POWR	0.	18.	199.	81.	69.	20.	-99.	0.	199.	DISTILLA	199.	1	0.08	0.35	0.
35 GTRA16 GT-85RE-16 HEAT	0.	0.	0.	0.	0.	0.	0.	217.	0.	DISTILLA	217.	111	0.	0.	0.
36 GTR208 GT-60RE-08 POWR	0.	0.	217.	102.	69.	20.	-120.	0.	217.	DISTILLA	217.	1	0.	0.32	0.
36 GTR208 GT-60RE-08 HEAT	0.	0.	0.	0.	0.	0.	0.	217.	0.	DISTILLA	217.	111	0.	0.	0.
37 GTR212 GT-60RE-12 POWR	0.	7.	210.	94.	69.	20.	-111.	0.	210.	DISTILLA	210.	1	0.03	0.33	0.
37 GTR212 GT-60RE-12 HEAT	0.	0.	0.	0.	0.	0.	0.	217.	0.	DISTILLA	217.	111	0.	0.	0.
38 GTR216 GT-60RE-16 POWR	0.	11.	206.	92.	69.	20.	-108.	0.	206.	DISTILLA	206.	1	0.05	0.34	0.
38 GTR216 GT-60RE-16 HEAT	0.	0.	0.	0.	0.	0.	0.	217.	0.	DISTILLA	217.	111	0.	0.	0.
39 GTRW08 GT-85RE-08 POWR	0.	19.	198.	65.	69.	20.	-77.	0.	198.	DISTILLA	198.	1	0.09	0.35	0.
39 GTRW08 GT-85RE-08 HEAT	0.	0.	0.	0.	0.	0.	0.	217.	0.	DISTILLA	217.	111	0.	0.	0.
40 GTRW12 GT-85RE-12 POWR	0.	26.	190.	63.	69.	20.	-75.	0.	190.	DISTILLA	190.	1	0.12	0.36	0.
40 GTRW12 GT-85RE-12 HEAT	0.	0.	0.	0.	0.	0.	0.	217.	0.	DISTILLA	217.	111	0.	0.	0.

PRECEDING PAGE BLANK FOR FUTURE

HONEYWELL PAGE PRINTING SYSTEM - P11151-02

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 231

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 32412 MW 27.09 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT CEMENT HOURS PER YEAR 7920.

POWER TO HEAT RATIO \*\*\*\*\*

UTILITY FUEL COAL WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED-NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
------------------------------	--------------------------------	------------------------------	--------------------------------	---------------------------------	----------------	-------------------------------	-------------------------------	------------------------------	-----------------------------	---------------------------------	------	------	-------------	------------

0 ONOCGN N O C O G O N	0.	0.	0.	0.	0.	0.	0.	289.	0.	289.	0	0.	0.32	0.
1 STM141 STM-TURB-1 POWR	0.	12.	277.	143.	92.	27.	-168.	0.	277.	277.	1	0.04	0.33	0.
1 STM141 STM-TURB-1 HEAT	0.	0.	0.	0.	0.	0.	0.	289.	0.	289.	111	0.	0.	0.
1 STM141 STM-TURB-1 POWR	0.	12.	277.	143.	92.	27.	-168.	0.	277.	277.	1	0.04	0.33	0.
1 STM141 STM-TURB-1 HEAT	0.	0.	0.	0.	0.	0.	0.	289.	0.	289.	111	0.	0.	0.
1 STM141 STM-TURB-1 POWR	0.	12.	277.	143.	92.	27.	-168.	0.	277.	277.	1	0.04	0.33	0.
1 STM141 STM-TURB-1 HEAT	0.	0.	0.	0.	0.	0.	0.	289.	0.	289.	111	0.	0.	0.
2 STM088 STM-TURB-8 POWR	0.	-16.	305.	167.	92.	27.	-196.	0.	305.	305.	1	-0.06	0.30	0.
2 STM068 STM-TURB-8 HEAT	0.	0.	0.	0.	0.	0.	0.	289.	0.	289.	111	0.	0.	0.
2 STM088 STM-TURB-8 POWR	0.	-16.	305.	167.	92.	27.	-196.	0.	305.	305.	1	-0.06	0.30	0.
2 STM068 STM-TURB-8 HEAT	0.	0.	0.	0.	0.	0.	0.	289.	0.	289.	111	0.	0.	0.
2 STM088 STM-TURB-8 POWR	0.	-16.	305.	167.	92.	27.	-196.	0.	305.	305.	1	-0.06	0.30	0.
2 STM088 STM-TURB-8 HEAT	0.	0.	0.	0.	0.	0.	0.	289.	0.	289.	111	0.	0.	0.
3 PFBSTM PFB-STMTB- POWR	0.	48.	241.	114.	92.	27.	-134.	0.	241.	241.	1	0.17	0.38	0.
3 PFBSTM PFB-STMTB- HEAT	0.	0.	0.	0.	0.	0.	0.	289.	0.	289.	111	0.	0.	0.
4 TISTMT TI-STMTB-1 POWR	0.	66.	223.	95.	92.	27.	-112.	0.	223.	223.	1	0.23	0.41	0.
4 TISTMT TI-STMTB-1 HEAT	0.	0.	0.	0.	0.	0.	0.	289.	0.	289.	111	0.	0.	0.
4 TISTMT TI-STMTB-1 POWR	0.	66.	223.	95.	92.	27.	-112.	0.	223.	223.	1	0.23	0.41	0.
4 TISTMT TI-STMTB-1 HEAT	0.	0.	0.	0.	0.	0.	0.	289.	0.	289.	111	0.	0.	0.
5 TIHRSG THERMIONIC POWR	0.	-368.	657.	464.	92.	27.	-546.	0.	657.	657.	1	-1.27	0.14	0.
5 TIHRSG THERMIONIC HEAT	0.	0.	0.	0.	0.	0.	0.	289.	0.	289.	111	0.	0.	0.
5 TIHRSG THERMIONIC POWR	0.	-368.	657.	464.	92.	27.	-546.	0.	657.	657.	1	-1.27	0.14	0.
5 TIHRSG THERMIONIC HEAT	0.	0.	0.	0.	0.	0.	0.	289.	0.	289.	111	0.	0.	0.
6 STIRL STIRLING-1 POWR	0.	-12.	300.	125.	92.	27.	-147.	0.	300.	300.	1	-0.04	0.31	0.
6 STIRL STIRLING-1 HEAT	0.	0.	0.	0.	0.	0.	0.	289.	0.	289.	111	0.	0.	0.

HONEYWELL PAGE PRINTING SYSTEM- P1185-02

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 233

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 32412 MW 27.09 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT CEMENT HOURS PER YEAR 7920.

UTILITY FUEL COAL POWER TO HEAT RATIO \*\*\*\*\* WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

			WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX BOILR 10**6 BTU/HR	-UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
18	CC1626	GTST-16/26	POWR	0.	89.	200.	45.	92.	27.	-53.	0.	200.	RESIDUAL	200.	1	0.31	0.46	0.
18	CC1626	GTST-16/26	HEAT	0.	0.	0.	0.	0.	0.	0.	289.	0.	RESIDUAL	289.	111	0.	0.	0.
19	CC1622	GTST-16/22	POWR	0.	89.	200.	50.	92.	27.	-59.	0.	200.	RESIDUAL	200.	1	0.31	0.46	0.
19	CC1622	GTST-16/22	HEAT	0.	0.	0.	0.	0.	0.	0.	289.	0.	RESIDUAL	289.	111	0.	0.	0.
20	CC1222	GTST-12/22	POWR	0.	91.	198.	50.	92.	27.	-58.	0.	198.	RESIDUAL	198.	1	0.31	0.47	0.
20	CC1222	GTST-12/22	HEAT	0.	0.	0.	0.	0.	0.	0.	289.	0.	RESIDUAL	289.	111	0.	0.	0.
21	CC0822	GTST-08/22	POWR	0.	88.	200.	59.	92.	27.	-70.	0.	200.	RESIDUAL	200.	1	0.31	0.46	0.
21	CC0822	GTST-08/22	HEAT	0.	0.	0.	0.	0.	0.	0.	289.	0.	RESIDUAL	289.	111	0.	0.	0.
22	STIG15	STIG-15-16	POWR	0.	46.	243.	3.	92.	27.	-4.	0.	243.	RESIDUAL	243.	1	0.16	0.38	0.
22	STIG15	STIG-15-16	HEAT	0.	0.	0.	0.	0.	0.	0.	289.	0.	RESIDUAL	289.	111	0.	0.	0.
23	STIG10	STIG-10-16	POWR	0.	31.	257.	34.	92.	27.	-40.	0.	257.	RESIDUAL	257.	1	0.11	0.36	0.
23	STIG10	STIG-10-16	HEAT	0.	0.	0.	0.	0.	0.	0.	289.	0.	RESIDUAL	289.	111	0.	0.	0.
24	STIG1S	STIG-1S-16	POWR	0.	13.	276.	58.	92.	27.	-68.	0.	276.	RESIDUAL	276.	1	0.05	0.34	0.
24	STIG1S	STIG-1S-16	HEAT	0.	0.	0.	0.	0.	0.	0.	289.	0.	RESIDUAL	289.	111	0.	0.	0.
25	DEADV3	DIESEL-ADV	POWR	0.	40.	249.	90.	92.	27.	-105.	0.	249.	RESIDUAL	249.	1	0.14	0.37	0.
25	DEADV3	DIESEL-ADV	HEAT	0.	0.	0.	0.	0.	0.	0.	289.	0.	RESIDUAL	289.	111	0.	0.	0.
26	DEADV2	DIESEL-ADV	POWR	0.	40.	249.	63.	92.	27.	-74.	0.	249.	RESIDUAL	249.	1	0.14	0.37	0.
26	DEADV2	DIESEL-ADV	HEAT	0.	0.	0.	0.	0.	0.	0.	289.	0.	RESIDUAL	289.	111	0.	0.	0.
27	DEADV1	DIESEL-ADV	POWR	0.	40.	249.	97.	92.	27.	-115.	0.	249.	RESIDUAL	249.	1	0.14	0.37	0.
27	DEADV1	DIESEL-ADV	HEAT	0.	0.	0.	0.	0.	0.	0.	289.	0.	RESIDUAL	289.	111	0.	0.	0.
28	DEHTPM	ADV-DIESEL	POWR	0.	58.	230.	117.	92.	27.	-138.	0.	230.	RESIDUAL	230.	1	0.20	0.40	0.
28	DEHTPM	ADV-DIESEL	HEAT	0.	0.	0.	0.	0.	0.	0.	289.	0.	RESIDUAL	289.	111	0.	0.	0.
29	DES0A3	DIESEL-S0A	POWR	0.	33.	256.	83.	92.	27.	-98.	0.	256.	DISTILLA	256.	1	0.11	0.36	0.
29	DES0A3	DIESEL-S0A	HEAT	0.	0.	0.	0.	0.	0.	0.	289.	0.	DISTILLA	289.	111	0.	0.	0.
29	DES0A3	DIESEL-S0A	POWR	0.	33.	256.	83.	92.	27.	-98.	0.	256.	RESIDUAL	256.	1	0.11	0.36	0.
29	DES0A3	DIESEL-S0A	HEAT	0.	0.	0.	0.	0.	0.	0.	289.	0.	RESIDUAL	289.	111	0.	0.	0.

PRECEDING PAGE BLANK NOT PRINTED

HONEYWELL PAGE PRINTING SYSTEM - P11815-09

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 235

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 32412 MW 27.09 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT CEMENT HOURS PER YEAR 7920.

		POWER TO HEAT RATIO *****														
		WASTE FUEL					EQU BTU*10**6=					0. HOT WATER BTU*10**6= 0.				
UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	FUEL TOTAL SITE 10**6 BTU/HR	FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41	GTRW16 GT-85RE-16 POWR	0.	30.	259.	91.	92.	27.	-107.	0.	259.	DISTILLA	259.	1	0.10	0.36	0.
41	GTRW16 GT-85RE-16 HEAT	0.	0.	0.	0.	0.	0.	0.	289.	0.	DISTILLA	289.	111	0.	0.	0.
42	GTR308 GT-60RE-08 POWR	0.	-9.	298.	134.	92.	27.	-157.	0.	298.	DISTILLA	298.	1	-0.03	0.31	0.
42	GTR308 GT-60RE-08 HEAT	0.	0.	0.	0.	0.	0.	0.	289.	0.	DISTILLA	289.	111	0.	0.	0.
43	GTR312 GT-60RE-12 POWR	0.	19.	270.	103.	92.	27.	-121.	0.	270.	DISTILLA	270.	1	0.06	0.34	0.
43	GTR312 GT-60RE-12 HEAT	0.	0.	0.	0.	0.	0.	0.	289.	0.	DISTILLA	289.	111	0.	0.	0.
44	GTR316 GT-60RE-16 POWR	0.	16.	273.	105.	92.	27.	-123.	0.	273.	DISTILLA	273.	1	0.06	0.34	0.
44	GTR316 GT-60RE-16 HEAT	0.	0.	0.	0.	0.	0.	0.	289.	0.	DISTILLA	289.	111	0.	0.	0.
45	FCPADS FUEL-CL-PH POWR	0.	46.	243.	41.	92.	27.	-49.	0.	243.	DISTILLA	243.	1	0.16	0.38	0.
45	FCPADS FUEL-CL-PH HEAT	0.	0.	0.	0.	0.	0.	0.	289.	0.	DISTILLA	289.	111	0.	0.	0.
46	FCMDS FUEL-CL-MO POWR	0.	64.	224.	52.	92.	27.	-61.	0.	224.	DISTILLA	224.	1	0.22	0.41	0.
46	FCMDS FUEL-CL-MO HEAT	0.	0.	0.	0.	0.	0.	0.	289.	0.	DISTILLA	289.	111	0.	0.	0.

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 237

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 32413 MW 13.54 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT CEMENT HOURS PER YEAR 7920.

UTILITY FUEL		COAL		POWER TO HEAT RATIO *****										WASTE FUEL EQV BTU*10**6=		HOT WATER BTU*10**6=		
				WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
6	STIRL	STIRLING-1	POWR	0.	-6.	150.	63.	46.	14.	-74.	0.	150.	RESIDUAL	150.	1	-0.04	0.31	0.
6	STIRL	STIRLING-1	HEAT	0.	0.	0.	0.	0.	0.	0.	144.	0.	RESIDUAL	144.	111	0.	0.	0.
6	STIRL	STIRLING-1	POWR	0.	-6.	150.	63.	46.	14.	-74.	0.	150.	COAL	150.	1	-0.04	0.31	0.
6	STIRL	STIRLING-1	HEAT	0.	0.	0.	0.	0.	0.	0.	144.	0.	COAL	144.	111	0.	0.	0.
7	HEGT85	HELIUM-GT-	POWR	0.	0.	144.	64.	46.	14.	-76.	0.	144.	COAL-AFB	144.	11	0.00	0.32	0.
7	HEGT85	HELIUM-GT-	HEAT	0.	0.	0.	0.	0.	0.	0.	144.	0.	COAL-AFB	144.	111	0.	0.	0.
8	HEGT60	HELIUM-GT-	POWR	0.	-34.	178.	77.	46.	14.	-90.	0.	178.	COAL-AFB	178.	11	-0.24	0.26	0.
8	HEGT60	HELIUM-GT-	HEAT	0.	0.	0.	0.	0.	0.	0.	144.	0.	COAL-AFB	144.	111	0.	0.	0.
9	HEGT00	HELIUM-GT-	POWR	0.	-118.	263.	159.	46.	14.	-187.	0.	263.	COAL-AFB	263.	11	-0.82	0.18	0.
9	HEGT00	HELIUM-GT-	HEAT	0.	0.	0.	0.	0.	0.	0.	144.	0.	COAL-AFB	144.	111	0.	0.	0.
10	FCMCL	FUEL-CL-MO	POWR	0.	-8.	152.	73.	46.	14.	-86.	0.	152.	COAL	152.	11	-0.05	0.30	0.
10	FCMCL	FUEL-CL-MO	HEAT	0.	0.	0.	0.	0.	0.	0.	144.	0.	COAL	144.	111	0.	0.	0.
11	FCSTCL	FUEL-CL-ST	POWR	0.	50.	94.	27.	46.	14.	-32.	0.	94.	COAL	94.	11	0.35	0.49	0.
11	FCSTCL	FUEL-CL-ST	HEAT	0.	0.	0.	0.	0.	0.	0.	144.	0.	COAL	144.	111	0.	0.	0.
12	IGGTST	INT-GAS-GT	POWR	0.	29.	116.	36.	46.	14.	-42.	0.	116.	COAL	116.	11	0.20	0.40	0.
12	IGGTST	INT-GAS-GT	HEAT	0.	0.	0.	0.	0.	0.	0.	144.	0.	COAL	144.	111	0.	0.	0.
13	GTSOAR	GT-HRSG-10	POWR	0.	-15.	159.	79.	46.	14.	-93.	0.	159.	RESIDUAL	159.	1	-0.10	0.29	0.
13	GTSOAR	GT-HRSG-10	HEAT	0.	0.	0.	0.	0.	0.	0.	144.	0.	RESIDUAL	144.	111	0.	0.	0.
14	GTAC08	GT-HRSG-08	POWR	0.	-27.	171.	82.	46.	14.	-97.	0.	171.	RESIDUAL	171.	11	-0.19	0.27	0.
14	GTAC08	GT-HRSG-08	HEAT	0.	0.	0.	0.	0.	0.	0.	144.	0.	RESIDUAL	144.	111	0.	0.	0.
15	GTAC12	GT-HRSG-12	POWR	0.	-7.	152.	78.	46.	14.	-92.	0.	152.	RESIDUAL	152.	11	-0.05	0.31	0.
15	GTAC12	GT-HRSG-12	HEAT	0.	0.	0.	0.	0.	0.	0.	144.	0.	RESIDUAL	144.	111	0.	0.	0.
16	GTAC16	GT-HRSG-16	POWR	0.	1.	143.	72.	46.	14.	-85.	0.	143.	RESIDUAL	143.	11	0.01	0.32	0.
16	GTAC16	GT-HRSG-16	HEAT	0.	0.	0.	0.	0.	0.	0.	144.	0.	RESIDUAL	144.	111	0.	0.	0.
17	GTWC16	GT-HRSG-16	POWR	0.	-2.	147.	59.	46.	14.	-69.	0.	147.	RESIDUAL	147.	11	-0.02	0.32	0.
17	GTWC16	GT-HRSG-16	HEAT	0.	0.	0.	0.	0.	0.	0.	144.	0.	RESIDUAL	144.	111	0.	0.	0.

PRECEDING PAGE BLANK NOT TO BE REPRODUCED

HONEYWELL PAGE PRINTING SYSTEM - P1188-02



DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 239

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 32413 MW 13.54 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT CEMENT HOURS PER YEAR 7920.

POWER TO HEAT RATIO \*\*\*\*\*  
WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 B J/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
30 DES0A2 DIESEL-S0A POWR		0.	16.	128.	28.	46.	14.	-33.	0.	128.	DISTILLA	128.	1	0.11	0.36	0.
30 DES0A2 DIESEL-S0A HEAT		0.	0.	0.	0.	0.	0.	0.	144.	0.	DISTILLA	144.	111	0.	0.	0.
30 DES0A2 DIESEL-S0A POWR		0.	16.	128.	28.	46.	14.	-33.	0.	128.	RESIDUAL	128.	1	0.11	0.36	0.
30 DES0A2 DIESEL-S0A HEAT		0.	0.	0.	0.	0.	0.	0.	144.	0.	RES: DUAL	144.	111	0.	0.	0.
31 DES0A1 DIESEL-S0A POWR		0.	16.	128.	51.	46.	14.	-60.	0.	128.	DISTILLA	128.	1	0.11	0.36	0.
31 DES0A1 DIESEL-S0A HEAT		0.	0.	0.	0.	0.	0.	0.	144.	0.	DISTILLA	144.	111	0.	0.	0.
31 DES0A1 DIESEL-S0A POWR		0.	16.	128.	51.	46.	14.	-60.	0.	128.	RESIDUAL	128.	1	0.11	0.36	0.
31 DES0A1 DIESEL-S0A HEAT		0.	0.	0.	0.	0.	0.	0.	144.	0.	RESIDUAL	144.	111	0.	0.	0.
32 GTS0AD GT-HRSG-10 POWR		0.	-14.	158.	85.	46.	14.	-100.	0.	158.	DISTILLA	158.	1	-0.10	0.29	0.
32 GTS0AD GT-HRSG-10 HEAT		0.	0.	0.	0.	0.	0.	0.	144.	0.	DISTILLA	144.	111	0.	0.	0.
33 GTRA08 GT-85RE-08 POWR		0.	15.	129.	52.	46.	14.	-61.	0.	129.	DISTILLA	129.	1	0.10	0.36	0.
33 GTRA08 GT-85RE-08 HEAT		0.	0.	0.	0.	0.	0.	0.	144.	0.	DISTILLA	144.	111	0.	0.	0.
34 GTRA12 GT-85RE-12 POWR		0.	15.	129.	53.	46.	14.	-62.	0.	129.	DISTILLA	129.	11	0.11	0.36	0.
34 GTRA12 GT-85RE-12 HEAT		0.	0.	0.	0.	0.	0.	0.	144.	0.	DISTILLA	144.	111	0.	0.	0.
35 GTRA16 GT-85RE-16 POWR		0.	12.	132.	56.	46.	14.	-66.	0.	132.	DISTILLA	132.	11	0.08	0.35	0.
35 GTRA16 GT-85RE-16 HEAT		0.	0.	0.	0.	0.	0.	0.	144.	0.	DISTILLA	144.	111	0.	0.	0.
36 GTR208 GT-60RE-08 POWR		0.	0.	144.	68.	46.	14.	-80.	0.	144.	DISTILLA	144.	1	0.	0.32	0.
36 GTR208 GT-60RE-08 HEAT		0.	0.	0.	0.	0.	0.	0.	144.	0.	DISTILLA	144.	111	0.	0.	0.
37 GTR212 GT-60RE-12 POWR		0.	4.	140.	63.	46.	14.	-74.	0.	140.	DISTILLA	140.	11	0.03	0.33	0.
37 GTR212 GT-60RE-12 HEAT		0.	0.	0.	0.	0.	0.	0.	144.	0.	DISTILLA	144.	111	0.	0.	0.
38 GTR216 GT-60RE-16 POWR		0.	7.	137.	61.	46.	14.	-72.	0.	137.	DISTILLA	137.	11	0.05	0.34	0.
38 GTR216 GT-60RE-16 HEAT		0.	0.	0.	0.	0.	0.	0.	144.	0.	DISTILLA	144.	111	0.	0.	0.
39 GTRW08 GT-85RE-08 POWR		0.	13.	132.	43.	46.	14.	-51.	0.	132.	DISTILLA	132.	11	0.09	0.35	0.
39 GTRW08 GT-85RE-08 HEAT		0.	0.	0.	0.	0.	0.	0.	144.	0.	DISTILLA	144.	111	0.	0.	0.
40 GTRW12 GT-85RE-12 POWR		0.	17.	127.	42.	46.	14.	-50.	0.	127.	DISTILLA	127.	11	0.12	0.36	0.
40 GTRW12 GT-85RE-12 HEAT		0.	0.	0.	0.	0.	0.	0.	144.	0.	DISTILLA	144.	111	0.	0.	0.

THIS PAGE IS  
OF POOR QUALITY

PRECEDING PAGE BLANK NOT REPRODUCED HONEYWELL PAGE PRINTING SYSTEM - P1185-02

PRECEDING PAGE BLANK NOT REPRODUCED

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 241

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 32414 MW 6.77 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT CEMENT HOURS PER YEAR 7920.

POWER TO HEAT RATIO \*\*\*\*\*

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
0 0N0CGN N 0 C 0 0 0 N		0.	0.	0.	0.	0.	0.	0.	72.	0.	DISTILLA	72.	0	0.	0.32	0.
1 STM141 STM-TURB-1 POWR		0.	3.	69.	36.	23.	7.	-42.	0.	69.	RESIDUAL	69.	11	0.04	0.33	0.
1 STM141 STM-TURB-1 HEAT		0.	0.	0.	0.	0.	0.	0.	72.	0.	RESIDUAL	72.	111	0.	0.	0.
1 STM141 STM-TURB-1 POWR		0.	3.	69.	36.	23.	7.	-42.	0.	69.	COAL-FGD	69.	11	0.04	0.33	0.
1 STM141 STM-TURB-1 HEAT		0.	0.	0.	0.	0.	0.	0.	72.	0.	COAL-FGD	72.	111	0.	0.	0.
1 STM141 STM-TURB-1 POWR		0.	3.	69.	36.	23.	7.	-42.	0.	69.	COAL-AFB	69.	11	0.04	0.33	0.
1 STM141 STM-TURB-1 HEAT		0.	0.	0.	0.	0.	0.	0.	72.	0.	COAL-AFB	72.	111	0.	0.	0.
2 STM088 STM-TURB-8 POWR		0.	-4.	76.	42.	23.	7.	-49.	0.	76.	RESIDUAL	76.	1	-0.06	0.30	0.
2 STM088 STM-TURB-8 HEAT		0.	0.	0.	0.	0.	0.	0.	72.	0.	RESIDUAL	72.	111	0.	0.	0.
2 STM088 STM-TURB-8 POWR		0.	-4.	76.	42.	23.	7.	-49.	0.	76.	COAL-FGD	76.	1	-0.06	0.30	0.
2 STM088 STM-TURB-8 HEAT		0.	0.	0.	0.	0.	0.	0.	72.	0.	COAL-FGD	72.	111	0.	0.	0.
2 STM088 STM-TURB-8 POWR		0.	-4.	76.	42.	23.	7.	-49.	0.	76.	COAL-AFB	76.	1	-0.06	0.30	0.
2 STM088 STM-TURB-8 HEAT		0.	0.	0.	0.	0.	0.	0.	72.	0.	COAL-AFB	72.	111	0.	0.	0.
3 PFBSTM PFB-STMTB- POWR		0.	12.	60.	29.	23.	7.	-34.	0.	60.	COAL-PFB	60.	11	0.17	0.38	0.
3 PFBSTM PFB-STMTB- HEAT		0.	0.	0.	0.	0.	0.	0.	72.	0.	COAL-PFB	72.	111	0.	0.	0.
4 TISTMT TI-STMTB-1 POWR		0.	17.	56.	24.	23.	7.	-28.	0.	56.	RESIDUAL	56.	11	0.23	0.41	0.
4 TISTMT TI-STMTB-1 HEAT		0.	0.	0.	0.	0.	0.	0.	72.	0.	RESIDUAL	72.	111	0.	0.	0.
4 TISTMT TI-STMTB-1 POWR		0.	17.	56.	24.	23.	7.	-28.	0.	56.	COAL	56.	11	0.23	0.41	0.
4 TISTMT TI-STMTB-1 HEAT		0.	0.	0.	0.	0.	0.	0.	72.	0.	COAL	72.	111	0.	0.	0.
5 TIHRSG THERMIONIC POWR		0.	-92.	164.	116.	23.	7.	-137.	0.	164.	RESIDUAL	164.	1	-1.27	0.14	0.
5 TIHRSG THERMIONIC HEAT		0.	0.	0.	0.	0.	0.	0.	72.	0.	RESIDUAL	72.	111	0.	0.	0.
5 TIHRSG THERMIONIC POWR		0.	-92.	164.	116.	23.	7.	-137.	0.	164.	COAL	164.	1	-1.27	0.14	0.
5 TIHRSG THERMIONIC HEAT		0.	0.	0.	0.	0.	0.	0.	72.	0.	COAL	72.	111	0.	0.	0.
6 STIRL STIRLING-1 POWR		0.	-3.	75.	31.	23.	7.	-37.	0.	75.	DISTILLA	75.	1	-0.04	0.31	0.
6 STIRL STIRLING-1 HEAT		0.	0.	0.	0.	0.	0.	0.	72.	0.	DISTILLA	72.	111	0.	0.	0.

HONEYWELL PAGE PRINTING SYSTEM - P11811-02

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 243

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 32414 MW 6.77 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT CEMENT HOURS PER YEAR 7920.

POWER TO HEAT RATIO \*\*\*\*\*

WASTE FUEL EQV BTU\*10\*\*6= 0.

HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL

COAL

WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
------------------------------	---------------------------------	------------------------------	--------------------------------	---------------------------------	----------------	-------------------------------	-------------------------------	------------------------------	----------------	---------------------------------	------	------	-------------	------------

18	CC1626	GTST-16/26	POWR	0.	22.	50.	11.	23.	7.	-13.	0.	50.	RESIDUAL	50.	11	0.31	0.46	0.
18	CC1626	GTST-16/26	HEAT	0.	0.	0.	0.	0.	0.	0.	72.	0.	RESIDUAL	72.	111	0.	0.	0.
19	CC1622	GTST-16/22	POWR	0.	22.	50.	12.	23.	7.	-15.	0.	50.	RESIDUAL	50.	11	0.31	0.46	0.
19	CC1622	GTST-16/22	HEAT	0.	0.	0.	0.	0.	0.	0.	72.	0.	RESIDUAL	72.	111	0.	0.	0.
20	CC1222	GTST-12/22	POWR	0.	23.	50.	12.	23.	7.	-15.	0.	50.	RESIDUAL	50.	11	0.31	0.47	0.
20	CC1222	GTST-12/22	HEAT	0.	0.	0.	0.	0.	0.	0.	72.	0.	RESIDUAL	72.	111	0.	0.	0.
21	CC0822	GTST-08/22	POWR	0.	22.	50.	15.	23.	7.	-17.	0.	50.	RESIDUAL	50.	11	0.31	0.46	0.
21	CC0822	GTST-08/22	HEAT	0.	0.	0.	0.	0.	0.	0.	72.	0.	RESIDUAL	72.	111	0.	0.	0.
22	STIG15	STIG-15-16	POWR	0.	12.	61.	1.	23.	7.	-1.	0.	61.	RESIDUAL	61.	11	0.16	0.38	0.
22	STIG15	STIG-15-16	HEAT	0.	0.	0.	0.	0.	0.	0.	72.	0.	RESIDUAL	72.	111	0.	0.	0.
23	STIG10	STIG-10-16	POWR	0.	8.	64.	9.	23.	7.	-10.	0.	64.	RESIDUAL	64.	11	0.11	0.36	0.
23	STIG10	STIG-10-16	HEAT	0.	0.	0.	0.	0.	0.	0.	72.	0.	RESIDUAL	72.	111	0.	0.	0.
24	STIG1S	STIG-1S-16	POWR	0.	3.	69.	15.	23.	7.	-17.	0.	69.	RESIDUAL	69.	11	0.05	0.34	0.
24	STIG1S	STIG-1S-16	HEAT	0.	0.	0.	0.	0.	0.	0.	72.	0.	RESIDUAL	72.	111	0.	0.	0.
25	DEADV3	DIESEL-ADV	POWR	0.	10.	62.	22.	23.	7.	-26.	0.	62.	RESIDUAL	62.	1	0.14	0.37	0.
25	DEADV3	DIESEL-ADV	HEAT	0.	0.	0.	0.	0.	0.	0.	72.	0.	RESIDUAL	72.	111	0.	0.	0.
26	DEADV2	DIESEL-ADV	POWR	0.	10.	62.	16.	23.	7.	-19.	0.	62.	RESIDUAL	62.	1	0.14	0.37	0.
26	DEADV2	DIESEL-ADV	HEAT	0.	0.	0.	0.	0.	0.	0.	72.	0.	RESIDUAL	72.	111	0.	0.	0.
27	DEADV1	DIESEL-ADV	POWR	0.	10.	62.	24.	23.	7.	-29.	0.	62.	RESIDUAL	62.	1	0.14	0.37	0.
27	DEADV1	DIESEL-ADV	HEAT	0.	0.	0.	0.	0.	0.	0.	72.	0.	RESIDUAL	72.	111	0.	0.	0.
28	DEHTPM	ADV-DIESEL	POWR	0.	15.	58.	29.	23.	7.	-35.	0.	58.	RESIDUAL	58.	1	0.20	0.40	0.
28	DEHTPII	ADV-DIESEL	HEAT	0.	0.	0.	0.	0.	0.	0.	72.	0.	RESIDUAL	72.	111	0.	0.	0.
29	DES0A3	DIESEL-S0A	POWR	0.	8.	64.	21.	23.	7.	-25.	0.	64.	DISTILLA	64.	1	0.11	0.36	0.
29	DES0A3	DIESEL-S0A	HEAT	0.	0.	0.	0.	0.	0.	0.	72.	0.	DISTILLA	72.	111	0.	0.	0.
29	DES0A3	DIESEL-S0A	POWR	0.	8.	64.	21.	23.	7.	-25.	0.	64.	RESIDUAL	64.	1	0.11	0.36	0.
29	DES0A3	DIESEL-S0A	HEAT	0.	0.	0.	0.	0.	0.	0.	72.	0.	RESIDUAL	72.	111	0.	0.	0.

HONEYWELL PAGE PRINTING SYSTEM- P1185-02

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
 COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
 REPORT 5.1

PAGE 245

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 32414 MW 6.77 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT CEMENT HOURS PER YEAR 7920.

		POWER TO HEAT RATIO *****														
UTILITY FUEL		WASTE FUEL EQV BTU*10**6=										HOT WATER BTU*10**6=				
COAL		WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41	GTRW16 GT-85RE-16 POWR	0.	7.	65.	23.	23.	7.	-27.	0.	65.	DISTILLA	65.	11	0.10	0.36	0.
41	GTRW16 GT-85RE-16 HEAT	0.	0.	0.	0.	0.	0.	0.	72.	0.	DISTILLA	72.	111	0.	0.	0.
42	GTR308 GT-60RE-08 POWR	0.	-2.	75.	33.	23.	7.	-39.	0.	75.	DISTILLA	75.	11	-0.03	0.31	0.
42	GTR308 GT-60RE-08 HEAT	0.	0.	0.	0.	0.	0.	0.	72.	0.	DISTILLA	72.	111	0.	0.	0.
43	GTR312 GT-60RE-12 POWR	0.	5.	68.	26.	23.	7.	-30.	0.	68.	DISTILLA	68.	11	0.06	0.34	0.
43	GTR312 GT-60RE-12 HEAT	0.	0.	0.	0.	0.	0.	0.	72.	0.	DISTILLA	72.	111	0.	0.	0.
44	GTR316 GT-60RE-16 POWR	0.	4.	68.	26.	23.	7.	-31.	0.	68.	DISTILLA	68.	11	0.06	0.34	0.
44	GTR316 GT-60RE-16 HEAT	0.	0.	0.	0.	0.	0.	0.	72.	0.	DISTILLA	72.	111	0.	0.	0.
45	FCPADS FUEL-CL-PH POWR	0.	11.	61.	10.	23.	7.	-12.	0.	61.	DISTILLA	61.	1	0.16	0.38	0.
45	FCPADS FUEL-CL-PH HEAT	0.	0.	0.	0.	0.	0.	0.	72.	0.	DISTILLA	72.	111	0.	0.	0.
46	FCMCDS FUEL-CL-MO POWR	0.	16.	56.	13.	23.	7.	-15.	0.	56.	DISTILLA	56.	1	0.22	0.41	0.
46	FCMCDS FUEL-CL-MO HEAT	0.	0.	0.	0.	0.	0.	0.	72.	0.	DISTILLA	72.	111	0.	0.	0.

PRECEDING PAGE BLANK NOT FILLED

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 247

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 33121 MW 60.00 PROCESS MILLIONS BTU/HR 93.0 PROCESS TEMP(F) 448. PRODUCT SPECIAL-STEEL HOURS PER YEAR 6700.

		POWER TO HEAT RATIO 2.201														
		WASTE FUEL EQV BTU*10**6= 0.										HOT WATER BTU*10**6= 0.				
UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED-NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
6 STIRL	STIRLING-1 POWR	0.	-138.	887.	442.	205.	60.	-410.	0.	887.	RESIDUAL	887.	0	-0.18	0.23	0.10
6 STIRL	STIRLING-1 HEAT	0.	57.	187.	93.	43.	13.	0.	505.	187.	RESIDUAL	692.	0	0.08	0.06	0.13
6 STIRL	STIRLING-1 POWR	0.	-138.	887.	442.	205.	60.	-410.	0.	887.	COAL	887.	0	-0.18	0.23	0.10
6 STIRL	STIRLING-1 HEAT	0.	57.	187.	93.	43.	13.	0.	505.	187.	COAL	692.	0	0.08	0.06	0.13
7 HEGT85	HELIUM-GT- POWR	0.	-12.	638.	-11.	205.	60.	123.	0.	761.	COAL-AFB	761.	1	-0.02	0.27	0.12
7 HEGT85	HELIUM-GT- HEAT	-5162.	93.	-5162.	93.	-1657.	-486.	0.	5817.	-5162.	COAL-AFB	656.	11	-6.77	-2.53	0.14
8 HEGT60	HELIUM-GT- POWR	0.	-41.	790.	160.	205.	60.	-79.	0.	790.	COAL-AFB	790.	0	-0.06	0.26	0.12
8 HEGT60	HELIUM-GT- HEAT	0.	22.	460.	93.	119.	35.	0.	267.	460.	COAL-AFB	727.	10	0.03	0.16	0.13
9 HEGT00	HELIUM-GT- POWR	0.	-414.	1163.	548.	205.	60.	-535.	0.	1163.	COAL-AFB	1163.	0	-0.55	0.18	0.08
9 HEGT00	HELIUM-GT- HEAT	0.	21.	198.	93.	35.	10.	0.	531.	198.	COAL-AFB	729.	10	0.03	0.05	0.13
10 FCMCCL	FUEL-CL-MO POWR	0.	76.	673.	317.	205.	60.	-264.	0.	673.	COAL	673.	10	0.10	0.30	0.14
10 FCMCCL	FUEL-CL-MO HEAT	0.	100.	197.	93.	60.	18.	0.	452.	197.	COAL	650.	10	0.13	0.09	0.14
11 FCSTCL	FUEL-CL-ST POWR	0.	166.	583.	249.	205.	60.	-184.	0.	583.	COAL	583.	10	0.22	0.35	0.16
11 FCSTCL	FUEL-CL-ST HEAT	0.	131.	217.	93.	76.	22.	0.	401.	217.	COAL	618.	10	0.17	0.12	0.15
12 IGGTST	INT-GAS-GT POWR	0.	-69.	818.	376.	205.	60.	-333.	0.	818.	COAL	818.	10	-0.09	0.25	0.11
12 IGGTST	INT-GAS-GT HEAT	0.	65.	202.	93.	51.	15.	0.	482.	202.	COAL	684.	10	0.09	0.07	0.14
13 GTSOAR	GT-HRSG-10 POWR	0.	43.	706.	281.	205.	60.	-221.	0.	706.	RESIDUAL	706.	0	0.06	0.29	0.13
13 GTSOAR	GT-HRSG-10 HEAT	0.	87.	234.	93.	68.	20.	0.	428.	234.	RESIDUAL	662.	0	0.12	0.10	0.14
14 GTAC08	GT-HRSG-08 POWR	0.	-9.	758.	391.	205.	60.	-351.	0.	758.	RESIDUAL	758.	0	-0.01	0.27	0.12
14 GTAC08	GT-HRSG-08 HEAT	0.	81.	180.	93.	49.	14.	0.	488.	180.	RESIDUAL	669.	0	0.11	0.07	0.14
15 GTAC12	GT-HRSG-12 POWR	0.	78.	671.	311.	205.	60.	-256.	0.	671.	RESIDUAL	671.	0	0.10	0.31	0.14
15 GTAC12	GT-HRSG-12 HEAT	0.	100.	201.	93.	61.	18.	0.	448.	201.	RESIDUAL	649.	0	0.13	0.09	0.14
16 GTAC16	GT-HRSG-16 POWR	0.	115.	634.	269.	205.	60.	-207.	0.	634.	RESIDUAL	634.	0	0.15	0.32	0.15
16 GTAC16	GT-HRSG-16 HEAT	0.	111.	219.	93.	71.	21.	0.	418.	219.	RESIDUAL	638.	0	0.15	0.11	0.15
17 GTWC16	GT-HRSG-16 POWR	0.	99.	650.	263.	205.	60.	-201.	0.	650.	RESIDUAL	650.	0	0.13	0.32	0.14
17 GTWC16	GT-HRSG-16 HEAT	0.	106.	229.	93.	72.	21.	0.	414.	229.	RESIDUAL	643.	0	0.14	0.11	0.14

HONEYWELL PAGE PRINTING SYSTEM - P1189-02

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 249

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 33121 MW 60.00 PROCESS MILLIONS BTU/HR 93.0 PROCESS TEMP(F) 448. PRODUCT SPECIAL-STEEL HOURS PER YEAR 6700.

UTILITY FUEL		COAL	POWER TO HEAT RATIO 2.201										WASTE FUEL EQV BTU*10**6= 0. HOT WATER BTU*10**6= 0.			
WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET USED 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR		
30 DES0A2 DIESEL-S0A POWR	0.	182.	567.	125.	205.	60.	-37.	0.	567.	DISTILLA	567.	1	0.24	0.36	0.16	
30 DES0A2 DIESEL-S0A HEAT	0.	164.	423.	93.	153.	45.	0.	163.	423.	DISTILLA	586.	1	0.22	0.26	0.16	
30 DES0A2 DIESEL-S0A POWR	0.	182.	567.	125.	205.	60.	-37.	0.	567.	RESIDUAL	567.	1	0.24	0.36	0.16	
30 DES0A2 DIESEL-S0A HEAT	0.	164.	423.	93.	153.	45.	0.	163.	423.	RESIDUAL	586.	1	0.22	0.26	0.16	
31 DES0A1 DIESEL-S0A POWR	0.	182.	567.	227.	205.	60.	-158.	0.	567.	DISTILLA	567.	1	0.24	0.36	0.16	
31 DES0A1 DIESEL-S0A HEAT	0.	139.	232.	93.	84.	25.	0.	378.	232.	DISTILLA	610.	1	0.19	0.14	0.15	
31 DES0A1 DIESEL-S0A POWR	0.	182.	567.	227.	205.	60.	-158.	0.	567.	RESIDUAL	567.	1	0.24	0.36	0.16	
31 DES0A1 DIESEL-S0A HEAT	0.	139.	232.	93.	84.	25.	0.	378.	232.	RESIDUAL	610.	1	0.19	0.14	0.15	
32 GTS0AD GT-HRSG-10 POWR	0.	48.	701.	319.	205.	60.	-266.	0.	701.	DISTILLA	701.	0	0.06	0.29	0.13	
32 GTS0AD GT-HRSG-10 HEAT	0.	92.	205.	93.	60.	18.	0.	453.	205.	DISTILLA	658.	0	0.12	0.09	0.14	
33 GTRA08 GT-85RE-08 POWR	0.	176.	573.	170.	205.	60.	-91.	0.	573.	DISTILLA	573.	0	0.23	0.36	0.16	
33 GTRA08 GT-85RE-08 HEAT	0.	146.	313.	93.	112.	33.	0.	290.	313.	DISTILLA	604.	0	0.19	0.19	0.15	
34 GTRA12 GT-85RE-12 POWR	0.	177.	572.	179.	205.	60.	-101.	0.	572.	DISTILLA	572.	0	0.24	0.36	0.16	
34 GTRA12 GT-85RE-12 HEAT	0.	145.	297.	93.	106.	31.	0.	308.	297.	DISTILLA	605.	0	0.19	0.18	0.15	
35 GTRA16 GT-85RE-16 POWR	0.	163.	587.	196.	205.	60.	-121.	0.	587.	DISTILLA	587.	0	0.22	0.35	0.16	
35 GTRA16 GT-85RE-16 HEAT	0.	135.	278.	93.	97.	28.	0.	336.	278.	DISTILLA	615.	0	0.18	0.16	0.15	
36 GTR208 GT-60RE-08 POWR	0.	109.	640.	244.	205.	60.	-178.	0.	640.	DISTILLA	640.	0	0.15	0.32	0.15	
36 GTR208 GT-60RE-08 HEAT	0.	109.	244.	93.	78.	23.	0.	396.	244.	DISTILLA	640.	0	0.15	0.12	0.15	
37 GTR212 GT-60RE-12 POWR	0.	129.	620.	227.	205.	60.	-158.	0.	620.	DISTILLA	620.	0	0.17	0.33	0.15	
37 GTR212 GT-60RE-12 HEAT	0.	117.	254.	93.	84.	25.	0.	378.	254.	DISTILLA	632.	0	0.16	0.13	0.15	
38 GTR216 GT-60RE-16 POWR	0.	142.	607.	221.	205.	60.	-150.	0.	607.	DISTILLA	607.	0	0.19	0.34	0.15	
38 GTR216 GT-60RE-16 HEAT	0.	123.	256.	93.	86.	25.	0.	370.	256.	DISTILLA	626.	0	0.16	0.14	0.15	
39 GTRW08 GT-85RE-08 POWR	0.	166.	583.	145.	205.	60.	-61.	0.	583.	DISTILLA	583.	0	0.22	0.35	0.16	
39 GTRW08 GT-85RE-08 HEAT	0.	146.	374.	93.	131.	38.	0.	229.	374.	DISTILLA	604.	0	0.19	0.22	0.15	
40 GTRW12 GT-85RE-12 POWR	0.	187.	562.	146.	205.	60.	-63.	0.	562.	DISTILLA	562.	0	0.25	0.36	0.17	
40 GTRW12 GT-85RE-12 HEAT	0.	159.	358.	93.	130.	38.	0.	233.	358.	DISTILLA	591.	0	0.21	0.22	0.16	

PRINTING PAGE BLANK NOT FILMED

HONEYWELL PAGE PRINTING SYSTEM - P118B-02

PRECEDING PAGE BLANK NOT TO BE REPRODUCED

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 251

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 33251 MW 280.00 PROCESS MILLIONS BTU/HR 912.0 PROCESS TEMP(F) 448. PRODUCT INTGR-STEEL HOURS PER YEAR 6700.

POWER TO HEAT RATIO 1.048

WASTE FUEL EQV BTU\*10\*\*6= 529. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FFSR	POWER FACTR	HEAT FACTR
0 ONOCGN N O C O O O N		529.	0.	0.	0.	0.	0.	1073.	2986.	1073.	COAL-FGD	4058.	0	0.	0.24	0.22
1 STM141 STM-TURB-1 POWR		529.	-7209.	11268.	8622.	955.	280.	-9073.	0.	11268.	RESIDUAL	11268.	0	-2.04	0.08	0.08
1 STM141 STM-TURB-1 HEAT		529.	197.	1192.	912.	101.	30.	0.	2670.	1192.	RESIDUAL	3862.	0	0.06	0.03	0.24
1 STM141 STM-TURB-1 POWR		529.	-7209.	11268.	8622.	955.	280.	-9071.	0.	11268.	COAL-FGD	11268.	0	-2.04	0.08	0.08
1 STM141 STM-TURB-1 HEAT		529.	197.	1192.	912.	101.	30.	0.	2670.	1192.	COAL-FGD	3862.	0	0.06	0.03	0.24
1 STM141 STM-TURB-1 POWR		529.	-7209.	11268.	8622.	955.	280.	-9071.	0.	11268.	COAL-AFE	11268.	0	-2.04	0.08	0.08
1 STM141 STM-TURB-1 HEAT		529.	197.	1192.	912.	101.	30.	0.	2670.	1192.	COAL-AFE	3862.	0	0.06	0.03	0.24
2 STM088 STM-TURB-8 POWR		529.	-15597.	19656.	15752.	955.	280.	-17459.	0.	19656.	RESIDUAL	19656.	0	-4.42	0.05	0.05
2 STM088 STM-TURB-8 HEAT		529.	108.	1138.	912.	55.	16.	0.	2813.	1138.	RESIDUAL	3951.	0	0.03	0.01	0.23
2 STM088 STM-TURB-8 POWR		529.	-15597.	19656.	15752.	955.	280.	-17459.	0.	19656.	COAL-FGD	19656.	0	-4.42	0.05	0.05
2 STM088 STM-TURB-8 HEAT		529.	108.	1138.	912.	55.	16.	0.	2813.	1138.	COAL-FGD	3951.	0	0.03	0.01	0.23
2 STM088 STM-TURB-8 POWR		529.	-15597.	19656.	15752.	955.	280.	-17459.	0.	19656.	COAL-AFB	19656.	0	-4.42	0.05	0.05
2 STM088 STM-TURB-8 HEAT		529.	108.	1138.	912.	55.	16.	0.	2813.	1138.	COAL-AFB	3951.	0	0.03	0.01	0.23
3 PFBSTM PFB-STMTB- POWR		529.	-1968.	6026.	4098.	955.	280.	-3748.	0.	6026.	COAL-PFB	6026.	0	-0.56	0.16	0.15
3 PFBSTM PFB-STMTB- HEAT		529.	396.	1341.	912.	213.	62.	0.	2321.	1341.	COAL-PFB	3662.	0	0.11	0.06	0.25
4 TISTMT TI-STMTB-1 POWR		0.	-492.	4550.	2881.	955.	280.	-2316.	0.	4550.	RESIDUAL	4550.	0	-0.29	0.21	0.20
4 TISTMT TI-STMTB-1 HEAT		529.	293.	730.	462.	153.	45.	529.	2507.	1259.	RESIDUAL	3766.	0	0.08	0.04	0.24
4 TISTMT TI-STMTB-1 POWR		529.	-492.	4550.	2881.	955.	280.	-2316.	0.	4550.	COAL	4550.	0	-0.14	0.21	0.20
4 TISTMT TI-STMTB-1 HEAT		529.	573.	1441.	912.	302.	89.	0.	2040.	1441.	COAL	3481.	0	0.16	0.09	0.26
5 TIHRSG THERMIONIC POWR		0.	-2732.	6790.	4178.	955.	280.	-3842.	0.	6790.	RESIDUAL	6790.	0	-0.92	0.14	0.13
5 TIHRSG THERMIONIC HEAT		529.	123.	751.	462.	106.	31.	529.	2655.	1280.	RESIDUAL	3936.	0	0.03	0.03	0.23
5 TIHRSG THERMIONIC POWR		529.	-2732.	6790.	4178.	955.	280.	-3842.	0.	6790.	COAL	6790.	0	-0.77	0.14	0.13
5 TIHRSG THERMIONIC HEAT		529.	242.	1482.	912.	209.	61.	0.	2334.	1482.	COAL	3816.	0	0.07	0.05	0.24
6 STIRL STIRLING-1 POWR		0.	-81.	4139.	2061.	955.	280.	-1352.	0.	4139.	DISTILLA	4139.	0	-0.17	0.23	0.22
6 STIRL STIRLING-1 HEAT		529.	285.	928.	462.	214.	63.	529.	2316.	1457.	DISTILLA	3773.	0	0.08	0.06	0.24

HONEYWELL PAGE PRINTING SYSTEM- P1185-02

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 33251 MW 280.00 PROCESS MILLIONS BTU/HR 912.0 PROCESS TEMP(F) 448. PRODUCT INTGR-STEEL HOURS PER YEAR 6700.

POWER TO HEAT RATIO 1.046

WASTE FUEL EQV BTU\*10\*\*6= 529. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
18 CC1626 GTST-16/26 POWR		4.	1344.	2711.	909.	955.	280.	4.	0.	2715.	RESIDUAL	2715.	0	0.23	0.35	0.34
18 CC1626 GTST-16/26 HEAT		529.	683.	1378.	462.	486.	142.	529.	1467.	1908.	RESIDUAL	3375.	0	0.19	0.14	0.27
19 CC1622 GTST-16/22 POWR		0.	1292.	2766.	1015.	955.	200.	-121.	0.	2766.	RESIDUAL	2766.	0	0.22	0.35	0.33
19 CC1622 GTST-16/22 HEAT		529.	643.	1259.	462.	435.	127.	529.	1627.	1789.	RESIDUAL	3415.	0	0.18	0.13	0.27
20 CC1222 GTST-12/22 POWR		0.	1296.	2763.	1024.	955.	280.	-132.	0.	2763.	RESIDUAL	2763.	0	0.22	0.35	0.33
20 CC1222 GTST-12/22 HEAT		529.	644.	1247.	462.	431.	126.	529.	1638.	1776.	RESIDUAL	3414.	0	0.18	0.13	0.27
21 CC0822 GTST-08/22 POWR		0.	1058.	3000.	1316.	955.	280.	-475.	0.	3000.	RESIDUAL	3000.	0	0.15	0.32	0.30
21 CC0822 GTST-08/22 HEAT		529.	538.	1053.	462.	335.	98.	529.	1937.	1583.	RESIDUAL	3520.	0	0.15	0.10	0.26
22 STIG15 STIG-15-16 POWR		529.	516.	2508.	33.	955.	280.	1035.	0.	3542.	RESIDUAL	3542.	1	0.15	0.27	0.26
22 STIG15 STIG-15-16 HEAT		529.	7318.	35538.	462.	13540.	3968.	529.	-39327.	36068.	RESIDUAL	-3260.	1	0.17	0.38	0.03
23 STIG10 STIG-10-16 POWR		529.	740.	2660.	353.	955.	280.	658.	0.	3319.	RESIDUAL	3319.	1	0.21	0.29	0.27
23 STIG10 STIG-10-16 HEAT		529.	970.	3487.	462.	1252.	367.	529.	-927.	4016.	RESIDUAL	3089.	1	0.22	0.31	0.23
24 STIG15 STIG-15-16 POWR		366.	842.	2850.	601.	955.	280.	366.	0.	3216.	RESIDUAL	3216.	1	0.19	0.30	0.28
24 STIG15 STIG-15-16 HEAT		529.	648.	2192.	462.	735.	215.	529.	690.	2721.	RESIDUAL	3411.	1	0.18	0.22	0.27
25 DEADV3 DIESEL-ADV POWR		529.	926.	2575.	439.	955.	280.	557.	0.	3132.	RESIDUAL	3132.	0	0.26	0.31	0.29
25 DEADV3 DIESEL-ADV HEAT		529.	976.	2713.	462.	1006.	295.	529.	-160.	3242.	RESIDUAL	3083.	0	0.26	0.31	0.28
26 DEADV2 DIESEL-ADV POWR		303.	1180.	2575.	654.	955.	280.	303.	0.	2879.	RESIDUAL	2879.	1	0.27	0.33	0.32
26 DEADV2 DIESEL-ADV HEAT		529.	833.	1819.	462.	675.	198.	529.	877.	2348.	RESIDUAL	3225.	1	0.24	0.21	0.28
27 DEADV1 DIESEL-ADV POWR		0.	1483.	2575.	1007.	955.	280.	-112.	0.	2575.	RESIDUAL	2575.	1	0.27	0.37	0.35
27 DEADV1 DIESEL-ADV HEAT		529.	732.	1182.	462.	438.	128.	529.	1616.	1711.	RESIDUAL	3327.	1	0.21	0.13	0.27
28 DEHTPM ADV-DIESEL POWR		0.	787.	3272.	1403.	955.	280.	-577.	0.	3272.	RESIDUAL	3272.	0	0.07	0.29	0.28
28 DEHTPM ADV-DIESEL HEAT		529.	449.	1078.	462.	315.	92.	529.	2002.	1607.	RESIDUAL	3609.	0	0.13	0.09	0.25
29 DESQA3 DIESEL-SQA POWR		529.	763.	2646.	361.	955.	280.	649.	0.	3295.	DISTILLA	3295.	0	0.22	0.29	0.28
29 DESQA3 DIESEL-SQA HEAT		529.	978.	3390.	462.	1224.	359.	529.	-838.	3919.	DISTILLA	3081.	0	0.22	0.31	0.23
29 DESQA3 DIESEL-SQA POWR		529.	763.	2646.	361.	955.	280.	649.	0.	3295.	RESIDUAL	3295.	0	0.22	0.29	0.28
29 DESQA3 DIESEL-SQA HEAT		529.	978.	3390.	462.	1224.	359.	529.	-838.	3919.	RESIDUAL	3081.	0	0.22	0.31	0.23

PRECEDING PAGE BLANK-NOT PRINTED

HONEYWELL PAGE PRINTING SYSTEM - P1189-02



I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 33251 MW 280.00 PROCESS MILLIONS BTU/HR 912.0 PROCESS TEMP(F) 448. PRODUCT INTGR-STEEL HOURS PER YEAR 6700.

POWER TO HEAT RATIO 1.048

UTILITY FUEL COAL

WASTE FUEL EQV BTU\*10\*\*6= 529. HOT WATER BTU\*10\*\*6= 0.

	WASTE FUEL USED 10**6 BTU/HR	FUEL NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41 GTRW16 GT-85RE-16 POWR	187.	1195.	2676.	753.	955.	280.	187.	0.	2863.	DISTILLA	2863.	0	0.24	0.33	0.32
41 GTRW16 GT-85RE-16 HEAT	529.	733.	1642.	462.	586.	172.	529.	1154.	2171.	DISTILLA	3325.	0	0.21	0.18	0.27
42 GTR308 GT-GORE-08 POWR	12.	965.	3082.	902.	955.	280.	12.	0.	3094.	DISTILLA	3094.	0	0.13	0.31	0.29
42 GTR308 GT-GORE-08 HEAT	529.	494.	1579.	462.	489.	143.	529.	1456.	2108.	DISTILLA	3564.	0	0.14	0.14	0.26
43 GTR312 GT-GORE-12 POWR	19.	1246.	2793.	896.	955.	280.	19.	0.	2812.	DISTILLA	2812.	0	0.21	0.34	0.32
43 GTR312 GT-GORE-12 HEAT	529.	643.	1441.	462.	493.	144.	529.	1446.	1970.	DISTILLA	3416.	0	0.18	0.14	0.27
44 GTR316 GT-GORE-16 POWR	1.	1240.	2818.	911.	955.	280.	1.	0.	2819.	DISTILLA	2819.	0	0.20	0.34	0.32
44 GTR316 GT-GORE-16 HEAT	529.	628.	1429.	462.	484.	142.	529.	1472.	1958.	DISTILLA	3430.	0	0.18	0.14	0.27
45 FCPADS FUEL-CL-PH POWR	529.	974.	2514.	427.	955.	280.	570.	0.	3084.	DISTILLA	3084.	0	0.28	0.31	0.30
45 FCPADS FUEL-CL-PH HEAT	529.	1053.	2718.	462.	1033.	303.	529.	-242.	3247.	DISTILLA	3005.	0	0.28	0.32	0.28
46 FCMCDS FUEL-CL-MO POWR	437.	1302.	2319.	540.	955.	280.	437.	0.	2756.	DISTILLA	2756.	0	0.34	0.35	0.33
46 FCMCDS FUEL-CL-MO HEAT	529.	1114.	1983.	462.	817.	239.	529.	433.	2512.	DISTILLA	2945.	0	0.32	0.28	0.31

PRECEDING PAGE BLANK NOT FILLED

HONEYWELL PAGE PRINTING SYSTEM - P1185-02

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 3.1

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 33254 MW 40.00 PROCESS MILLIONS BTU/HR 91.0 PROCESS TEMP(F) 448. PRODUCT MINI-STEEL HOURS PER YEAR 6700.

POWER TO HEAT RATIO 1.50  
WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
6 STIRL	STIRLING-1 POWR	0.	-58.	591.	294.	136.	40.	-239.	0.	591.	RESIDUAL	591.	0	-0.11	0.23	0.15
6 STIRL	STIRLING-1 HEAT	0.	56.	183.	91.	42.	12.	0.	295.	183.	RESIDUAL	477.	0	0.11	0.09	0.19
6 STIRL	STIRLING-1 POWR	0.	-58.	591.	294.	136.	40.	-239.	0.	591.	COAL	591.	0	-0.11	0.23	0.15
6 STIRL	STIRLING-1 HEAT	0.	56.	183.	91.	42.	12.	0.	295.	183.	COAL	477.	0	0.11	0.09	0.19
7 HEGT85	HELIUM-GT- POWR	0.	-8.	425.	-8.	136.	40.	116.	0.	541.	COAL-AFB	541.	11	-0.01	0.25	0.17
7 HEGT85	HELIUM-GT- HEAT	-5051.	91.	-5051.	91.	-1621.	-475.	0.	5493.	-5051.	COAL-AFB	442.	11	-9.29	-3.67	0.21
8 HEGT60	HELIUM-GT- POWR	0.	7.	527.	107.	136.	40.	-18.	0.	527.	COAL-AFB	527.	10	0.01	0.26	0.17
8 HEGT60	HELIUM-GT- HEAT	0.	21.	450.	91.	117.	34.	0.	62.	450.	COAL-AFB	512.	10	0.04	0.23	0.18
9 HEGT00	HELIUM-GT- POWR	0.	-242.	775.	365.	136.	40.	-322.	0.	775.	COAL-AFB	775.	10	-0.45	0.18	0.12
9 HEGT00	HELIUM-GT- HEAT	0.	20.	193.	91.	34.	10.	0.	320.	193.	COAL-AFB	513.	10	0.04	0.07	0.18
10 FCMCCL	FUEL-CL-MO POWR	0.	85.	449.	212.	136.	40.	-142.	0.	449.	COAL	449.	10	0.16	0.30	0.20
10 FCMCCL	FUEL-CL-MO HEAT	0.	97.	193.	91.	59.	17.	0.	243.	193.	COAL	436.	10	0.18	0.13	0.21
11 FCSTCL	FUEL-CL-ST POWR	0.	145.	388.	166.	136.	40.	-88.	0.	388.	COAL	388.	10	0.27	0.35	0.23
11 FCSTCL	FUEL-CL-ST HEAT	0.	128.	213.	91.	75.	22.	0.	193.	213.	COAL	406.	10	0.24	0.18	0.22
12 IGGTST	INT-GAS-GT POWR	0.	-12.	545.	251.	136.	40.	-188.	0.	545.	COAL	545.	10	-0.02	0.25	0.17
12 IGGTST	INT-GAS-GT HEAT	0.	64.	198.	91.	50.	15.	0.	272.	198.	COAL	470.	10	0.12	0.11	0.19
13 GTSOAR	GT-HRSG-10 POWR	0.	63.	471.	167.	136.	40.	-113.	0.	471.	RESIDUAL	471.	0	0.12	0.29	0.19
13 GTSOAR	GT-HRSG-10 HEAT	0.	86.	229.	91.	66.	19.	0.	219.	229.	RESIDUAL	448.	0	0.16	0.15	0.20
14 GTAC08	GT-HRSG-08 POWR	0.	28.	505.	261.	136.	40.	-200.	0.	505.	RESIDUAL	505.	0	0.05	0.27	0.18
14 GTAC08	GT-HRSG-08 HEAT	0.	80.	176.	91.	48.	14.	0.	278.	176.	RESIDUAL	454.	10	0.15	0.10	0.20
15 GTAC12	GT-HRSG-12 POWR	0.	86.	447.	207.	136.	40.	-137.	0.	447.	RESIDUAL	447.	0	0.16	0.31	0.20
15 GTAC12	GT-HRSG-12 HEAT	0.	98.	197.	91.	60.	18.	0.	239.	197.	RESIDUAL	436.	0	0.18	0.14	0.21
16 GTAC16	GT-HRSG-16 POWR	0.	111.	423.	179.	136.	40.	-104.	0.	423.	RESIDUAL	423.	0	0.21	0.32	0.22
16 GTAC16	GT-HRSG-16 HEAT	0.	109.	215.	91.	69.	20.	0.	210.	215.	RESIDUAL	424.	0	0.20	0.16	0.21
17 GTWC16	GT-HRSG-16 POWR	0.	100.	433.	176.	136.	40.	-100.	0.	433.	RESIDUAL	433.	0	0.19	0.32	0.21
17 GTWC16	GT-HRSG-16 HEAT	0.	104.	225.	91.	71.	21.	0.	205.	225.	RESIDUAL	430.	0	0.19	0.16	0.21

HONEYWELL PAGE PRINTING SYSTEM- P1188-02

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 259

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 33254 MW 40.00 PROCESS MILLIONS BTU/HR 91.0 PROCESS TEMP(F) 448. PRODUCT MINI-STEEL HOURS PER YEAR 6700.

POWER TO HEAT RATIO 1.500

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED- NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
30 DES0A2 DIESEL-S0A POWR		0.	146.	378.	83.	136.	40.	9.	0.	387.	DISTILLA	387.	1	0.27	0.35	0.23
30 DES0A2 DIESEL-S0A HEAT		0.	160.	414.	91.	149.	44.	0.	-40.	414.	DISTILLA	374.	1	0.28	0.36	0.22
30 DES0A2 DIESEL-S0A POWR		0.	146.	378.	83.	136.	40.	9.	0.	387.	RESIDUAL	387.	1	0.27	0.35	0.23
30 DES0A2 DIESEL-S0A HEAT		0.	160.	414.	91.	149.	44.	0.	-40.	414.	RESIDUAL	374.	1	0.28	0.36	0.22
31 DES0A1 DIESEL-S0A POWR		0.	155.	378.	152.	136.	40.	-71.	0.	378.	DISTILLA	378.	1	0.29	0.36	0.24
31 DES0A1 DIESEL-S0A HEAT		0.	136.	227.	91.	82.	24.	0.	170.	227.	DISTILLA	397.	1	0.26	0.21	0.23
31 DES0A1 DIESEL-S0A POWR		0.	155.	378.	152.	136.	40.	-71.	0.	378.	RESIDUAL	378.	1	0.29	0.36	0.24
31 DES0A1 DIESEL-S0A HEAT		0.	136.	227.	91.	82.	24.	0.	170.	227.	RESIDUAL	397.	1	0.26	0.21	0.23
32 GTS0AD GT-HRSG-10 POWR		0.	66.	467.	213.	136.	40.	-143.	0.	467.	DISTILLA	467.	0	0.12	0.29	0.19
32 GTS0AD GT-HRSG-10 HEAT		0.	90.	200.	91.	58.	17.	0.	244.	200.	DISTILLA	444.	0	0.17	0.13	0.20
33 GTRA08 GT-85RE-08 POWR		0.	151.	382.	114.	136.	40.	-27.	0.	382.	DISTILLA	382.	0	0.28	0.36	0.24
33 GTRA08 GT-85RE-08 HEAT		0.	142.	306.	91.	109.	32.	0.	85.	306.	DISTILLA	391.	0	0.27	0.28	0.23
34 GTRA12 GT-85RE-12 POWR		0.	152.	381.	120.	136.	40.	-34.	0.	381.	DISTILLA	381.	0	0.29	0.36	0.24
34 GTRA12 GT-85RE-12 HEAT		0.	142.	290.	91.	104.	30.	0.	102.	290.	DISTILLA	392.	0	0.27	0.27	0.23
35 GTRA16 GT-85RE-16 POWR		0.	142.	391.	131.	136.	40.	-47.	0.	391.	DISTILLA	391.	0	0.27	0.35	0.23
35 GTRA16 GT-85RE-16 HEAT		0.	132.	272.	91.	95.	28.	0.	130.	272.	DISTILLA	402.	0	0.25	0.24	0.23
36 GTR208 GT-60RE-08 POWR		0.	107.	427.	163.	136.	40.	-84.	0.	427.	DISTILLA	427.	0	0.20	0.32	0.21
36 GTR208 GT-60RE-08 HEAT		0.	107.	239.	91.	76.	22.	0.	188.	239.	DISTILLA	427.	0	0.20	0.18	0.21
37 GTR212 GT-60RE-12 POWR		0.	120.	414.	151.	136.	40.	-71.	0.	414.	DISTILLA	414.	0	0.22	0.33	0.22
37 GTR212 GT-60RE-12 HEAT		0.	115.	248.	91.	82.	24.	0.	170.	248.	DISTILLA	419.	0	0.22	0.20	0.22
38 GTR216 GT-60RE-16 POWR		0.	129.	405.	147.	136.	40.	-66.	0.	405.	DISTILLA	405.	0	0.24	0.34	0.22
38 GTR216 GT-60RE-16 HEAT		0.	120.	250.	91.	84.	25.	0.	163.	250.	DISTILLA	413.	0	0.23	0.20	0.22
39 GTRW08 GT-85RE-08 POWR		0.	145.	389.	97.	136.	40.		0.	389.	DISTILLA	389.	0	0.27	0.35	0.23
39 GTRW08 GT-85RE-08 HEAT		0.	143.	366.	91.	129.	38.		25.	366.	DISTILLA	391.	0	0.27	0.33	0.23
40 GTRW12 GT-85RE-12 POWR		0.	159.	375.	97.	136.	40.	-8.	0.	375.	DISTILLA	375.	0	0.30	0.36	0.24
40 GTRW12 GT-85RE-12 HEAT		0.	155.	350.	91.	127.	37.	0.	28.	350.	DISTILLA	378.	0	0.29	0.34	0.24

HONEYWELL PAGE PRINTING SYSTEM- P118-02

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

DATE 06/06/79

1&SE PEG ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 33311 MW 24.80 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT COPPER-SMELT HOURS PER YEAR 8400.

POWER TO HEAT RATIO \*\*\*\*\* WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	FUEL SITE USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER HEAT FACTR
0 ONOCGN N O C O G O N		0.	0.	0.	0.	0.	264.	0.	264.	0	0.	0.32
1 STM141 STM-TURB-1 POWR		0.	11.	253.	131.	85.	0.	253.	253.	1	0.04	0.33
1 STM141 STM-TURB-1 HEAT		0.	0.	0.	0.	0.	264.	0.	264.	111	0.	0.
1 STM141 STM-TURB-1 POWR		0.	11.	253.	131.	85.	0.	253.	253.	1	0.04	0.33
1 STM141 STM-TURB-1 HEAT		0.	0.	0.	0.	0.	264.	0.	264.	111	0.	0.
1 STM141 STM-TURB-1 POWR		0.	11.	253.	131.	85.	0.	253.	253.	1	0.04	0.33
1 STM141 STM-TURB-1 HEAT		0.	0.	0.	0.	0.	264.	0.	264.	111	0.	0.
2 STM088 STM-TURB-8 POWR		0.	-15.	279.	153.	85.	0.	279.	279.	1	-0.06	0.30
2 STM088 STM-TURB-8 HEAT		0.	0.	0.	0.	0.	264.	0.	264.	111	0.	0.
2 STM088 STM-TURB-8 POWR		0.	-15.	279.	153.	85.	0.	279.	279.	1	-0.06	0.30
2 STM088 STM-TURB-8 HEAT		0.	0.	0.	0.	0.	264.	0.	264.	111	0.	0.
3 PFBSTM PFB-STMTB- POWR		0.	44.	221.	104.	85.	0.	221.	221.	1	0.17	0.38
3 PFBSTM PFB-STMTB- HEAT		0.	0.	0.	0.	0.	264.	0.	264.	111	0.	0.
4 T1STMT T1-STMTB-1 POWR		0.	60.	204.	87.	85.	0.	204.	204.	1	0.23	0.41
4 T1STMT T1-STMTB-1 HEAT		0.	0.	0.	0.	0.	264.	0.	264.	111	0.	0.
4 T1STMT T1-STMTB-1 POWR		0.	60.	204.	87.	85.	0.	204.	204.	1	0.23	0.41
4 T1STMT T1-STMTB-1 HEAT		0.	0.	0.	0.	0.	264.	0.	264.	111	0.	0.
5 T1HRSG THERMIONIC POWR		0.	-337.	601.	425.	85.	0.	601.	601.	1	-1.27	0.14
5 T1HRSG THERMIONIC HEAT		0.	0.	0.	0.	0.	264.	0.	264.	111	0.	0.
5 T1HRSG THERMIONIC POWR		0.	-337.	601.	425.	85.	0.	601.	601.	1	-1.27	0.14
5 T1HRSG THERMIONIC HEAT		0.	0.	0.	0.	0.	264.	0.	264.	111	0.	0.
6 STIRL STIRLING-1 POWR		0.	-11.	275.	115.	85.	0.	275.	275.	1	-0.04	0.31
6 STIRL STIRLING-1 HEAT		0.	0.	0.	0.	0.	264.	0.	264.	111	0.	0.

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 263

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 33311 MW 24.80 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT COPPER-SMELT HOURS PER YEAR 8400.

		POWER TO HEAT RATIO *****														
UTILITY FUEL		WASTE FUEL EQV BTU=10**6=										HOT WATER BTU=10**6=				
COAL		WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
18	CC1626 GTST-16/26 POWR	0.	81.	183.	41.	85.	25.	-49.	0.	183.	RESIDUAL	163.	1	0.31	0.46	0.
18	CC1626 GTST-16/26 HEAT	0.	0.	0.	0.	0.	0.	0.	264.	0.	RESIDUAL	264.	111	0.	0.	0.
19	CC1622 GTST-16/22 POWR	0.	81.	183.	46.	85.	25.	-54.	0.	183.	RESIDUAL	183.	11	0.31	0.46	0.
19	CC1622 GTST-16/22 HEAT	0.	0.	0.	0.	0.	0.	0.	264.	0.	RESIDUAL	264.	111	0.	0.	0.
20	CC1222 GTST-12/22 POWR	0.	83.	181.	45.	85.	25.	-53.	0.	181.	RESIDUAL	181.	1	0.31	0.47	0.
20	CC1222 GTST-12/22 HEAT	0.	0.	0.	0.	0.	0.	0.	264.	0.	RESIDUAL	264.	111	0.	0.	0.
21	CC0822 GTST-08/22 POWR	0.	81.	183.	54.	85.	25.	-64.	0.	183.	RESIDUAL	183.	1	0.31	0.46	0.
21	CC0822 GTST-08/22 HEAT	0.	0.	0.	0.	0.	0.	0.	264.	0.	RESIDUAL	264.	111	0.	0.	0.
22	STIG15 STIG-15-16 POWR	0.	42.	222.	3.	85.	25.	-3.	0.	222.	RESIDUAL	222.	1	0.16	0.38	0.
22	STIG15 STIG-15-16 HEAT	0.	0.	0.	0.	0.	0.	0.	264.	0.	RESIDUAL	264.	111	0.	0.	0.
23	STIG10 STIG-10-16 POWR	0.	29.	236.	31.	85.	25.	-37.	0.	236.	RESIDUAL	236.	1	0.11	0.36	0.
23	STIG10 STIG-10-16 HEAT	0.	0.	0.	0.	0.	0.	0.	264.	0.	RESIDUAL	264.	111	0.	0.	0.
24	STIG1S STIG-1S-16 POWR	0.	12.	252.	53.	85.	25.	-63.	0.	252.	RESIDUAL	252.	1	0.05	0.34	0.
24	STIG1S STIG-1S-16 HEAT	0.	0.	0.	0.	0.	0.	0.	264.	0.	RESIDUAL	264.	111	0.	0.	0.
25	DEADV3 DIESEL-ADV POWR	0.	36.	228.	82.	85.	25.	-97.	0.	228.	RESIDUAL	228.	1	0.14	0.37	0.
25	DEADV3 DIESEL-ADV HEAT	0.	0.	0.	0.	0.	0.	0.	264.	0.	RESIDUAL	264.	111	0.	0.	0.
26	DEADV2 DIESEL-ADV POWR	0.	36.	228.	58.	85.	25.	-68.	0.	228.	RESIDUAL	228.	1	0.14	0.37	0.
26	DEADV2 DIESEL-ADV HEAT	0.	0.	0.	0.	0.	0.	0.	264.	0.	RESIDUAL	264.	111	0.	0.	0.
27	DEADV1 DIESEL-ADV POWR	0.	36.	228.	89.	85.	25.	-105.	0.	228.	RESIDUAL	228.	1	0.14	0.37	0.
27	DEADV1 DIESEL-ADV HEAT	0.	0.	0.	0.	0.	0.	0.	264.	0.	RESIDUAL	264.	111	0.	0.	0.
28	DEHTPM ADV-DIESEL POWR	0.	54.	211.	107.	85.	25.	-126.	0.	211.	RESIDUAL	211.	1	0.20	0.40	0.
28	DEHTPM ADV-DIESEL HEAT	0.	0.	0.	0.	0.	0.	0.	264.	0.	RESIDUAL	264.	111	0.	0.	0.
29	DESOA3 DIESEL-SOA POWR	0.	30.	234.	76.	85.	25.	-90.	0.	234.	DISTILLA	234.	1	0.11	0.36	0.
29	DESOA3 DIESEL-SOA HEAT	0.	0.	0.	0.	0.	0.	0.	264.	0.	DISTILLA	264.	111	0.	0.	0.
29	DESOA3 DIESEL-SOA POWR	0.	30.	234.	76.	85.	25.	-90.	0.	234.	RESIDUAL	234.	1	0.11	0.36	0.
29	DESOA3 DIESEL-SOA HEAT	0.	0.	0.	0.	0.	0.	0.	264.	0.	RESIDUAL	264.	111	0.	0.	0.

PART B AND NOT FILMED

HONEYWELL PAGE PRINTING SYSTEM- P1103-02

L&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 33311 MW 24.80 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT COPPER-SMELT HOURS PER YEAR 8400.

UTILITY FUEL COAL POWER TO HEAT RATIO \*\*\*\*\*  
 WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41 GTRW16 GT-85RE-16 POWR	0.	27.	237.	83.	85.	25.	-98.	0.	237.	DISTILLA	237.	1	0.10	0.36	0.
41 GTRW16 GT-85RE-16 HEAT	0.	0.	0.	0.	0.	0.	0.	264.	0.	DISTILLA	264.	111	0.	0.	0.
42 GTR308 GT-60RE-08 POWR	0.	-9.	273.	122.	85.	25.	-144.	0.	273.	DISTILLA	273.	1	-0.03	0.31	0.
42 GTR308 GT-60RE-08 HEAT	0.	0.	0.	0.	0.	0.	0.	264.	0.	DISTILLA	264.	111	0.	0.	0.
43 GTR312 GT-60RE-12 POWR	0.	17.	247.	94.	85.	25.	-111.	0.	247.	DISTILLA	247.	1	0.06	0.34	0.
43 GTR312 GT-60RE-12 HEAT	0.	0.	0.	0.	0.	0.	0.	264.	0.	DISTILLA	264.	111	0.	0.	0.
44 GTR316 GT-60RE-16 POWR	0.	15.	250.	96.	85.	25.	-113.	0.	250.	DISTILLA	250.	1	0.06	0.34	0.
44 GTR316 GT-60RE-16 HEAT	0.	0.	0.	0.	0.	0.	0.	264.	0.	DISTILLA	264.	111	0.	0.	0.
45 FCPADS FUEL-CL-PH POWR	0.	42.	223.	38.	85.	25.	-45.	0.	223.	DISTILLA	223.	1	0.16	0.38	0.
45 FCPADS FUEL-CL-PH HEAT	0.	0.	0.	0.	0.	0.	0.	264.	0.	DISTILLA	264.	111	0.	0.	0.
46 FMCDS FUEL-CL-HO POWR	0.	59.	205.	48.	85.	25.	-56.	0.	205.	DISTILLA	205.	1	0.22	0.41	0.
46 FMCDS FUEL-CL-HO HEAT	0.	0.	0.	0.	0.	0.	0.	264.	0.	DISTILLA	264.	111	0.	0.	0.

PRECEDING PAGE BLANK NOT FINISHED

HONEYWELL PAGE PRINTING SYSTEM P110-02

PRECEDING PAGE CONTAINS INFORMATION FROM OTHER SHEETS  
 HONEYWELL PAGE PRINTING SYSTEM - P1185-02

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
 COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
 REPORT 5.1

PAGE 267

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 33312 MW 25.80 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT COPPER-SMELT HOURS PER YEAR 8400.

		POWER TO HEAT RATIO *****														
		WASTE FUEL EQV BTU*10**6=										0. HOT WATER BTU*10**6=				
UTILITY FUEL	COAL	WASTE FUEL USED	SAVED= NO-NET	COGEN FUEL USED	COGEN PROCES HEAT	COGEN PROCES POWER	COGEN MW ELECT	AUX PROCES BOILR	UTILIT FUEL USED	TOTAL FUEL SITE	SITE FUEL USED	NET= TOTAL+ UTILIT	FAIL	FESR	POWER FACTR	HEAT FACTR
		10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR		10**6 BTU/HR	10**6 BTU/HR	10**6 BTU/HR		10**6 BTU/HR				
6 STIRL	STIRLING-1 POWR	0.	-11.	286.	119.	88.	26.	-140.	0.	286.	RESIDUAL	286.	1	-0.04	0.31	0.
6 STIRL	STIRLING-1 HEAT	0.	0.	0.	0.	0.	0.	0.	275.	0.	RESIDUAL	275.	111	0.	0.	0.
6 STIRL	STIRLING-1 POWR	0.	-11.	286.	119.	88.	26.	-140.	0.	286.	COAL	286.	1	-0.04	0.31	0.
6 STIRL	STIRLING-1 HEAT	0.	0.	0.	0.	0.	0.	0.	275.	0.	COAL	275.	111	0.	0.	0.
7 HEGT85	HELIUM-GT- POWR	0.	1.	274.	123.	88.	26.	-144.	0.	274.	COAL-AFB	274.	11	0.00	0.32	0.
7 HEGT85	HELIUM-GT- HEAT	0.	0.	0.	0.	0.	0.	0.	275.	0.	COAL-AFB	275.	111	0.	0.	0.
8 HEGT60	HELIUM-GT- POWR	0.	-65.	340.	146.	88.	26.	-172.	0.	340.	COAL-AFB	340.	11	-0.24	0.26	0.
8 HEGT60	HELIUM-GT- HEAT	0.	0.	0.	0.	0.	0.	0.	275.	0.	COAL-AFB	275.	111	0.	0.	0.
9 HEGT00	HELIUM-GT- POWR	0.	-225.	500.	302.	88.	26.	-356.	0.	500.	COAL-AFB	500.	11	-0.82	0.18	0.
9 HEGT00	HELIUM-GT- HEAT	0.	0.	0.	0.	0.	0.	0.	275.	0.	COAL-AFB	275.	111	0.	0.	0.
10 FCMCCL	FUEL-CL-MO POWR	0.	-14.	290.	139.	88.	26.	-163.	0.	290.	COAL	290.	11	-0.05	0.30	0.
10 FCMCCL	FUEL-CL-MO HEAT	0.	0.	0.	0.	0.	0.	0.	275.	0.	COAL	275.	111	0.	0.	0.
11 FCSTCL	FUEL-CL-ST POWR	0.	96.	179.	51.	88.	26.	-61.	0.	179.	COAL	179.	11	0.35	0.49	0.
11 FCSTCL	FUEL-CL-ST HEAT	0.	0.	0.	0.	0.	0.	0.	275.	0.	COAL	275.	111	0.	0.	0.
12 IGGTST	INT-GAS-GT POWR	0.	55.	220.	68.	88.	26.	-80.	0.	220.	COAL	220.	11	0.20	0.40	0.
12 IGGTST	INT-GAS-GT HEAT	0.	0.	0.	0.	0.	0.	0.	275.	0.	COAL	275.	111	0.	0.	0.
13 GTSOAR	GT-HRSG-10 POWR	0.	-28.	304.	150.	88.	26.	-176.	0.	304.	RESIDUAL	304.	1	-0.10	0.29	0.
13 GTSOAR	GT-HRSG-10 HEAT	0.	0.	0.	0.	0.	0.	0.	275.	0.	RESIDUAL	275.	111	0.	0.	0.
14 GTAC08	GT-HRSG-08 POWR	0.	-51.	326.	157.	88.	26.	-184.	0.	326.	RESIDUAL	326.	1	-0.19	0.27	0.
14 GTAC08	GT-HRSG-08 HEAT	0.	0.	0.	0.	0.	0.	0.	275.	0.	RESIDUAL	275.	111	0.	0.	0.
15 GTAC12	GT-HRSG-12 POWR	0.	-14.	289.	149.	88.	26.	-175.	0.	289.	RESIDUAL	289.	1	-0.05	0.31	0.
15 GTAC12	GT-HRSG-12 HEAT	0.	0.	0.	0.	0.	0.	0.	275.	0.	RESIDUAL	275.	111	0.	0.	0.
16 GTAC16	GT-HRSG-16 POWR	0.	3.	273.	137.	88.	26.	-161.	0.	273.	RESIDUAL	273.	1	0.01	0.32	0.
16 GTAC16	GT-HRSG-16 HEAT	0.	0.	0.	0.	0.	0.	0.	275.	0.	RESIDUAL	275.	111	0.	0.	0.
17 GTWC16	GT-HRSG-16 POWR	0.	-4.	279.	112.	88.	26.	-131.	0.	279.	RESIDUAL	279.	1	-0.02	0.32	0.
17 GTWC16	GT-HRSG-16 HEAT	0.	0.	0.	0.	0.	0.	0.	275.	0.	RESIDUAL	275.	111	0.	0.	0.

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 269

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 33312 MW 25.80 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT COPPER-SMELT HOURS PER YEAR 8400.

UTILITY FUEL		COAL	POWER TO HEAT RATIO *****										WASTE FUEL EQV BTU*10**6= 0. HOT WATER BTU*10**6= 0.			
WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR		
30 DES0A2 DIESEL-S0A POWR	0.	31.	244.	54.	88.	26.	-63.	0.	244.	DISTILLA	244.	1	0.11	0.36	0.	
30 DES0A2 DIESEL-S0A HEAT	0.	0.	0.	0.	0.	0.	0.	275.	0.	DISTILLA	275.	111	0.	0.	0.	
30 DES0A2 DIESEL-S0A POWR	0.	31.	244.	54.	88.	26.	-63.	0.	244.	RESIDUAL	244.	1	0.11	0.36	0.	
30 DES0A2 DIESEL-S0A HEAT	0.	0.	0.	0.	0.	0.	0.	275.	0.	RESIDUAL	275.	111	0.	0.	0.	
31 DES0A1 DIESEL-S0A POWR	0.	31.	244.	98.	88.	26.	-115.	0.	244.	DISTILLA	244.	1	0.11	0.36	0.	
31 DES0A1 DIESEL-S0A HEAT	0.	0.	0.	0.	0.	0.	0.	275.	0.	DISTILLA	275.	111	0.	0.	0.	
31 DES0A1 DIESEL-S0A POWR	0.	31.	244.	98.	88.	26.	-115.	0.	244.	RESIDUAL	244.	1	0.11	0.36	0.	
31 DES0A1 DIESEL-S0A HEAT	0.	0.	0.	0.	0.	0.	0.	275.	0.	RESIDUAL	275.	111	0.	0.	0.	
32 GTS0AD GT-HRSG-10 POWR	0.	-26.	301.	162.	88.	26.	-191.	0.	301.	DISTILLA	301.	1	-0.10	0.29	0.	
32 GTS0AD GT-HRSG-10 HEAT	0.	0.	0.	0.	0.	0.	0.	275.	0.	DISTILLA	275.	111	0.	0.	0.	
33 GTRA08 GT-85RE-08 POWR	0.	29.	247.	100.	88.	26.	-117.	0.	247.	DISTILLA	247.	1	0.10	0.36	0.	
33 GTRA08 GT-85RE-08 HEAT	0.	0.	0.	0.	0.	0.	0.	275.	0.	DISTILLA	275.	111	0.	0.	0.	
34 GTRA12 GT-85RE-12 POWR	0.	29.	246.	101.	88.	26.	-119.	0.	246.	DISTILLA	246.	1	0.11	0.36	0.	
34 GTRA12 GT-85RE-12 HEAT	0.	0.	0.	0.	0.	0.	0.	275.	0.	DISTILLA	275.	111	0.	0.	0.	
35 GTRA16 GT-85RE-16 POWR	0.	23.	252.	107.	88.	26.	-126.	0.	252.	DISTILLA	252.	1	0.09	0.35	0.	
35 GTRA16 GT-85RE-16 HEAT	0.	0.	0.	0.	0.	0.	0.	275.	0.	DISTILLA	275.	111	0.	0.	0.	
36 GTR208 GT-60RE-08 POWR	0.	0.	275.	130.	88.	26.	-153.	0.	275.	DISTILLA	275.	1	0.	0.32	0.	
36 GTR208 GT-60RE-08 HEAT	0.	0.	0.	0.	0.	0.	0.	275.	0.	DISTILLA	275.	111	0.	0.	0.	
37 GTR212 GT-60RE-12 POWR	0.	8.	267.	119.	88.	26.	-140.	0.	267.	DISTILLA	267.	1	0.03	0.33	0.	
37 GTR212 GT-60RE-12 HEAT	0.	0.	0.	0.	0.	0.	0.	275.	0.	DISTILLA	275.	111	0.	0.	0.	
38 GTR216 GT-60RE-16 POWR	0.	14.	261.	117.	88.	26.	-137.	0.	261.	DISTILLA	261.	1	0.05	0.34	0.	
38 GTR216 GT-60RE-16 HEAT	0.	0.	0.	0.	0.	0.	0.	275.	0.	DISTILLA	275.	111	0.	0.	0.	
39 GTRW08 GT-85RE-08 POWR	0.	24.	251.	83.	88.	26.	-97.	0.	251.	DISTILLA	251.	1	0.09	0.35	0.	
39 GTRW08 GT-85RE-08 HEAT	0.	0.	0.	0.	0.	0.	0.	275.	0.	DISTILLA	275.	111	0.	0.	0.	
40 GTRW12 GT-85RE-12 POWR	0.	33.	242.	81.	88.	26.	-95.	0.	242.	DISTILLA	242.	1	0.12	0.36	0.	
40 GTRW12 GT-85RE-12 HEAT	0.	0.	0.	0.	0.	0.	0.	275.	0.	DISTILLA	275.	111	0.	0.	0.	

PRECEDING PAGE BLANK NOT FILMED

HONEYWELL PAGE PRINTING SYSTEM - P1189-02



DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 271

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 33313 MW 28.50 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT COPPER-SMELT HOURS PER YEAR 8400.

POWER TO HEAT RATIO \*\*\*\*\*

UTILITY FUEL COAL WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
0 ONOCGN N C C G O N	0.	0.	0.	0.	0.	0.	0.	304.	0.	0.	304.	0	0.	0.32	0.
1 STM141 STM-TURB-1 POWR	0.	13.	291.	150.	97.	29.	-177.	0.	291.	0.	291.	1	0.04	0.33	0.
1 STM141 STM-TURB-1 HEAT	0.	0.	0.	0.	0.	0.	0.	304.	0.	0.	304.	111	0.	0.	0.
1 STM141 STM-TURB-1 POWR	0.	13.	291.	150.	97.	29.	-177.	0.	291.	0.	291.	1	0.04	0.33	0.
1 STM141 STM-TURB-1 HEAT	0.	0.	0.	0.	0.	0.	0.	304.	0.	0.	304.	111	0.	0.	0.
1 STM141 STM-TURB-1 POWR	0.	13.	291.	150.	97.	29.	-177.	0.	291.	0.	291.	1	0.04	0.33	0.
1 STM141 STM-TURB-1 HEAT	0.	0.	0.	0.	0.	0.	0.	304.	0.	0.	304.	111	0.	0.	0.
2 STM088 STM-TURB-8 POWR	0.	-17.	321.	175.	97.	29.	-206.	0.	321.	0.	321.	1	-0.06	0.30	0.
2 STM088 STM-TURB-8 HEAT	0.	0.	0.	0.	0.	0.	0.	304.	0.	0.	304.	111	0.	0.	0.
2 STM088 STM-TURB-8 POWR	0.	-17.	321.	175.	97.	29.	-206.	0.	321.	0.	321.	1	-0.06	0.30	0.
2 STM088 STM-TURB-8 HEAT	0.	0.	0.	0.	0.	0.	0.	304.	0.	0.	304.	111	0.	0.	0.
2 STM088 STM-TURB-8 POWR	0.	-17.	321.	175.	97.	29.	-206.	0.	321.	0.	321.	1	-0.06	0.30	0.
2 STM088 STM-TURB-8 HEAT	0.	0.	0.	0.	0.	0.	0.	304.	0.	0.	304.	111	0.	0.	0.
3 PFBSTM PFB-STMTB- POWR	0.	50.	254.	120.	97.	29.	-141.	0.	254.	0.	254.	1	0.17	0.38	0.
3 PFBSTM PFB-STMTB- HEAT	0.	0.	0.	0.	0.	0.	0.	304.	0.	0.	304.	111	0.	0.	0.
4 TISTMT TI-STMTB-1 POWR	0.	70.	234.	100.	97.	29.	-118.	0.	234.	0.	234.	1	0.23	0.41	0.
4 TISTMT TI-STMTB-1 HEAT	0.	0.	0.	0.	0.	0.	0.	304.	0.	0.	304.	111	0.	0.	0.
4 TISTMT TI-STMTB-1 POWR	0.	70.	234.	100.	97.	29.	-118.	0.	234.	0.	234.	1	0.23	0.41	0.
4 TISTMT TI-STMTB-1 HEAT	0.	0.	0.	0.	0.	0.	0.	304.	0.	0.	304.	111	0.	0.	0.
5 TIHRSG THERMIONIC POWR	0.	-387.	691.	489.	97.	29.	-575.	0.	691.	0.	691.	1	-1.27	0.14	0.
5 TIHRSG THERMIONIC HEAT	0.	0.	0.	0.	0.	0.	0.	304.	0.	0.	304.	111	0.	0.	0.
5 TIHRSG THERMIONIC POWR	0.	-387.	691.	489.	97.	29.	-575.	0.	691.	0.	691.	1	-1.27	0.14	0.
5 TIHRSG THERMIONIC HEAT	0.	0.	0.	0.	0.	0.	0.	304.	0.	0.	304.	111	0.	0.	0.
6 STIRL STIRLING-1 POWR	0.	-12.	316.	132.	97.	29.	-155.	0.	316.	0.	316.	1	-0.04	0.31	0.
6 STIRL STIRLING-1 HEAT	0.	0.	0.	0.	0.	0.	0.	304.	0.	0.	304.	111	0.	0.	0.

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 273

I&SE PEG ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 33313 MW 28.50 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT COPPER-SMELT HOURS PER YEAR 8400.

		POWER TO HEAT RATIO *****															
							WASTE FUEL EQV BTU*10**6= 0.					HOT WATER BTU*10**6= 0.					
UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
18 CC1626	GTST-16/26	POWR	0.	93.	211.	48.	97.	29.	-56.	0.	211.	RESIDUAL	211.	1	0.31	0.46	0.
18 CC1626	GTST-16/26	HEAT	0.	0.	0.	0.	0.	0.	0.	304.	0.	RESIDUAL	304.	111	0.	0.	0.
19 CC1622	GTST-16/22	POWR	0.	93.	211.	53.	97.	29.	-62.	0.	211.	RESIDUAL	211.	1	0.31	0.46	0.
19 CC1622	GTST-16/22	HEAT	0.	0.	0.	0.	0.	0.	0.	304.	0.	RESIDUAL	304.	111	0.	0.	0.
20 CC1222	GTST-12/22	POWR	0.	95.	208.	52.	97.	29.	-61.	0.	208.	RESIDUAL	208.	1	0.31	0.47	0.
20 CC1222	GTST-12/22	HEAT	0.	0.	0.	0.	0.	0.	0.	304.	0.	RESIDUAL	304.	111	0.	0.	0.
21 CC0822	GTST-08/22	POWR	0.	93.	211.	62.	97.	29.	-73.	0.	211.	RESIDUAL	211.	1	0.31	0.46	0.
21 CC0822	GTST-08/22	HEAT	0.	0.	0.	0.	0.	0.	0.	304.	0.	RESIDUAL	304.	111	0.	0.	0.
22 STIG15	STIG-15-16	POWR	0.	49.	255.	3.	97.	29.	-4.	0.	255.	RESIDUAL	255.	1	0.16	0.38	0.
22 STIG15	STIG-15-16	HEAT	0.	0.	0.	0.	0.	0.	0.	304.	0.	RESIDUAL	304.	111	0.	0.	0.
23 STIG10	STIG-10-16	POWR	0.	33.	271.	36.	97.	29.	-42.	0.	271.	RESIDUAL	271.	1	0.11	0.36	0.
23 STIG10	STIG-10-16	HEAT	0.	0.	0.	0.	0.	0.	0.	304.	0.	RESIDUAL	304.	111	0.	0.	0.
24 STIG1S	STIG-1S-16	POWR	0.	14.	290.	61.	97.	29.	-72.	0.	290.	RESIDUAL	290.	1	0.05	0.34	0.
24 STIG1S	STIG-1S-16	HEAT	0.	0.	0.	0.	0.	0.	0.	304.	0.	RESIDUAL	304.	111	0.	0.	0.
25 DEADV3	DIESEL-ADV	POWR	0.	42.	262.	94.	97.	29.	-111.	0.	262.	RESIDUAL	262.	1	0.14	0.37	0.
25 DEADV3	DIESEL-ADV	HEAT	0.	0.	0.	0.	0.	0.	0.	304.	0.	RESIDUAL	304.	111	0.	0.	0.
26 DEADV2	DIESEL-ADV	POWR	0.	42.	262.	67.	97.	29.	-78.	0.	262.	RESIDUAL	262.	1	0.14	0.37	0.
26 DEADV2	DIESEL-ADV	HEAT	0.	0.	0.	0.	0.	0.	0.	304.	0.	RESIDUAL	304.	111	0.	0.	0.
27 DEADV1	DIESEL-ADV	POWR	0.	42.	262.	102.	97.	29.	-121.	0.	262.	RESIDUAL	262.	1	0.14	0.37	0.
27 DEADV1	DIESEL-ADV	HEAT	0.	0.	0.	0.	0.	0.	0.	304.	0.	RESIDUAL	304.	111	0.	0.	0.
28 DEHTPM	ADV-DIESEL	POWR	0.	62.	242.	123.	97.	29.	-145.	0.	242.	RESIDUAL	242.	1	0.20	0.40	0.
28 DEHTPM	ADV-DIESEL	HEAT	0.	0.	0.	0.	0.	0.	0.	304.	0.	RESIDUAL	304.	111	0.	0.	0.
29 DES0A3	DIESEL-S0A	POWR	0.	35.	269.	88.	97.	29.	-103.	0.	269.	DISTILLA	269.	1	0.11	0.36	0.
29 DES0A3	DIESEL-S0A	HEAT	0.	0.	0.	0.	0.	0.	0.	304.	0.	DISTILLA	304.	111	0.	0.	0.
29 DES0A3	DIESEL-S0A	POWR	0.	35.	269.	88.	97.	29.	-103.	0.	269.	RESIDUAL	269.	1	0.11	0.36	0.
29 DES0A3	DIESEL-S0A	HEAT	0.	0.	0.	0.	0.	0.	0.	304.	0.	RESIDUAL	304.	111	0.	0.	0.

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 275

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 33313 MW 28.50 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT COPPER-SMELT HOURS PER YEAR 8400.

		POWER TO HEAT RATIO *****															
UTILITY FUEL		COAL		WASTE FUEL EQV BTU*10**6=										0. HOT WATER BTU*10**6= 0.			
		WASTE FUEL USED 10**6 BTU/HR	COGEN FUEL NET 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN ELECT 10**6 BTU/HR	AUX BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR		
41	GTRW16 GT-85RE-16 POWR	0.	31.	272.	95.	97.	29.	-112.	0.	272.	DISTILLA	272.	1	0.10	0.36	0.	
41	GTRW16 GT-85RE-16 HEAT	0.	0.	0.	0.	0.	0.	0.	304.	0.	DISTILLA	304.	111	0.	0.	0.	
42	GTR308 GT-60RE-08 POWR	0.	-10.	314.	141.	97.	29.	-166.	0.	314.	DISTILLA	314.	1	-0.03	0.31	0.	
42	GTR308 GT-60RE-08 HEAT	0.	0.	0.	0.	0.	0.	0.	304.	0.	DISTILLA	304.	111	0.	0.	0.	
43	GTR312 GT-60RE-12 POWR	0.	20.	284.	109.	97.	29.	-128.	0.	284.	DISTILLA	284.	1	0.06	0.34	0.	
43	GTR312 GT-60RE-12 HEAT	0.	0.	0.	0.	0.	0.	0.	304.	0.	DISTILLA	304.	111	0.	0.	0.	
44	GTR316 GT-60RE-16 POWR	0.	17.	287.	110.	97.	29.	-130.	0.	287.	DISTILLA	287.	1	0.06	0.34	0.	
44	GTR316 GT-60RE-16 HEAT	0.	0.	0.	0.	0.	0.	0.	304.	0.	DISTILLA	304.	111	0.	0.	0.	
45	FCPADS FUEL-CL-PH POWR	0.	48.	256.	44.	97.	29.	-51.	0.	256.	DISTILLA	256.	1	0.16	0.38	0.	
45	FCPADS FUEL-CL-PH HEAT	0.	0.	0.	0.	0.	0.	0.	304.	0.	DISTILLA	304.	111	0.	0.	0.	
46	FCMCDS FUEL-CL-MO POWR	0.	68.	236.	55.	97.	29.	-65.	0.	236.	DISTILLA	236.	1	0.22	0.41	0.	
46	FCMCDS FUEL-CL-MO HEAT	0.	0.	0.	0.	0.	0.	0.	304.	0.	DISTILLA	304.	111	0.	0.	0.	

PRELIMINARY PAGE BLANK NOT FILMED

HONEYWELL PAGE PRINTING SYSTEM-PI1195-02

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 33314 MW 10.10 PROCESS MILLIONS BTU/HR 40.0 PROCESS TEMP(F) 364. PRODUCT COPPER-SMELT HOURS PER YEAR 7620.

UTILITY FUEL		COAL	POWER TO HEAT RATIO 0.862										WASTE FUEL EQV BTU*10**6= 0. HOT WATER BTU*10**6= 0.				
			WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED-NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	ALL PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FA1L	FESR	POWER FACTR	HEAT FACTR
6	STIRL	STIRLING-1 POWR	0.	18.	137.	65.	34.	10.	-29.	0.	137.	RESIDUAL	137.	0	0.12	0.25	0.29
6	STIRL	STIRLING-1 HEAT	0.	29.	84.	40.	21.	6.	0.	41.	84.	RESIDUAL	125.	0	0.19	0.17	0.32
6	STIRL	STIRLING-1 POWR	0.	18.	137.	65.	34.	10.	-29.	0.	137.	COAL	137.	0	0.12	0.25	0.29
6	STIRL	STIRLING-1 HEAT	0.	29.	84.	40.	21.	6.	0.	41.	84.	COAL	125.	0	0.19	0.17	0.32
7	HEGT85	HELIUM-GT- POWR	0.	16.	107.	13.	34.	10.	32.	0.	139.	COAL-AFB	139.	10	0.10	0.25	0.29
7	HEGT85	HELIUM-GT- HEAT	0.	48.	330.	40.	106.	31.	0.	-223.	330.	COAL-AFB	107.	10	0.3	0.32	0.12
8	HEGT60	HELIUM-GT- POWR	0.	20.	133.	39.	34.	10.	1.	0.	134.	COAL-AFB	134.	10	0.13	0.26	0.30
8	HEGT60	HELIUM-GT- HEAT	0.	21.	137.	40.	35.	10.	0.	-3.	137.	COAL-AFB	134.	10	0.13	0.26	0.29
9	HEGT00	HELIUM-GT- POWR	0.	-41.	196.	96.	34.	10.	-66.	0.	196.	COAL-AFB	196.	10	-0.27	0.18	0.20
9	HEGT00	HELIUM-GT- HEAT	0.	10.	82.	40.	14.	4.	0.	63.	82.	COAL-AFB	145.	10	0.07	0.10	0.28
10	FCMCL	FUEL-CL-MO POWR	0.	41.	113.	54.	34.	10.	-16.	0.	113.	COAL	113.	10	0.27	0.30	0.35
10	FCMCL	FUEL-CL-MO HEAT	0.	43.	84.	40.	26.	8.	0.	27.	84.	COAL	112.	10	0.28	0.23	0.36
11	FCSTCL	FUEL-CL-ST POWR	0.	60.	91.	37.	34.	10.	4.	0.	95.	COAL	95.	10	0.38	0.36	0.42
11	FCSTCL	FUEL-CL-ST HEAT	0.	65.	100.	40.	38.	11.	0.	-10.	100.	COAL	90.	10	0.39	0.38	0.40
12	IGGTST	INT-GAS-GT POWR	0.	31.	124.	53.	34.	10.	-16.	0.	124.	COAL	124.	10	0.29	0.28	0.32
12	IGGTST	INT-GAS-GT HEAT	0.	35.	93.	40.	26.	8.	0.	27.	93.	COAL	120.	10	0.23	0.22	0.33
13	GTSOAR	GT-HRSG-10 POWR	0.	36.	119.	50.	34.	10.	-12.	0.	119.	RESIDUAL	119.	0	0.23	0.29	0.34
13	GTSOAR	GT-HRSG-10 HEAT	0.	38.	94.	40.	27.	8.	0.	22.	94.	RESIDUAL	117.	10	0.25	0.23	0.34
14	GTAC08	GT-HRSG-08 POWR	0.	27.	128.	66.	34.	10.	-30.	0.	128.	RESIDUAL	128.	10	0.18	0.27	0.31
14	GTAC08	GT-HRSG-08 HEAT	0.	35.	78.	40.	21.	6.	0.	42.	78.	RESIDUAL	120.	10	0.23	0.18	0.33
15	GTAC12	GT-HRSG-12 POWR	0.	42.	113.	52.	34.	10.	-15.	0.	113.	RESIDUAL	113.	10	0.27	0.31	0.35
15	GTAC12	GT-HRSG-12 HEAT	0.	43.	86.	40.	26.	8.	0.	26.	86.	RESIDUAL	112.	10	0.28	0.24	0.36
16	GTAC16	GT-HRSG-16 POWR	0.	48.	107.	46.	34.	10.	-7.	0.	107.	RESIDUAL	107.	10	0.31	0.32	0.37
16	GTAC16	GT-HRSG-16 HEAT	0.	48.	92.	40.	30.	9.	0.	14.	92.	RESIDUAL	107.	10	0.31	0.28	0.37
17	GTWC16	GT-HRSG-16 POWR	0.	45.	109.	44.	34.	10.	-5.	0.	109.	RESIDUAL	109.	10	0.29	0.32	0.37
17	GTWC16	GT-HRSG-16 HEAT	0.	46.	99.	40.	31.	9.	0.	10.	99.	RESIDUAL	109.	10	0.29	0.29	0.37

PRECEDING PAGE BLANK NOT FILMED

HONEYWELL PAGE PRINTING SYSTEM- P1186-02

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 279

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 33314 MW 10.10 PROCESS MILLIONS BTU/HR 40.0 PROCESS TEMP(F) 364. PRODUCT COPPER-SMELT HOURS PER YEAR 7620.

UTILITY FUEL		COAL		POWER TO HEAT RATIO 0.862							WASTE FUEL EQV BTU*10**6=		HOT WATER BTU*10**6=					
				WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	NET= TCTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
30	DESOA2	DIESEL-SOA	POWR	0.	37.	95.	21.	34.	10.	22.	0.	118.	DISTILLA	118.	1	0.24	0.29	0.34
30	DESOA2	DIESEL-SOA	HEAT	0.	70.	182.	40.	66.	19.	0.	-97.	182.	DISTILLA	84.	1	0.28	0.36	0.22
30	DESOA2	DIESEL-SOA	POWR	0.	37.	95.	21.	34.	10.	22.	0.	118.	RESIDUAL	118.	1	0.24	0.29	0.34
30	DESOA2	DIESEL-SOA	HEAT	0.	70.	182.	40.	66.	19.	0.	-97.	182.	RESIDUAL	84.	1	0.28	0.36	0.22
31	DESOA1	DIESEL-SOA	POWR	0.	57.	95.	38.	34.	10.	2.	0.	97.	DISTILLA	97.	1	0.37	0.35	0.41
31	DESOA1	DIESEL-SOA	HEAT	0.	60.	100.	40.	36.	11.	0.	-5.	100.	DISTILLA	95.	1	0.37	0.36	0.40
31	DESOA1	DIESEL-SOA	POWR	0.	57.	95.	38.	34.	10.	2.	0.	97.	RESIDUAL	97.	1	0.37	0.35	0.41
31	DESOA1	DIESEL-SOA	HEAT	0.	60.	100.	40.	36.	11.	0.	-5.	100.	RESIDUAL	95.	1	0.37	0.36	0.40
32	GTSOAD	GT-HRSG-10	POWR	0.	37.	118.	54.	34.	10.	-17.	0.	118.	DISTILLA	118.	10	0.24	0.29	0.34
32	GTSOAD	GT-HRSG-10	HEAT	0.	39.	87.	40.	25.	7.	0.	28.	87.	DISTILLA	115.	10	0.26	0.22	0.35
33	GTRA08	GT-85RE-08	POWR	0.	49.	97.	33.	34.	10.	9.	0.	105.	DISTILLA	105.	10	0.32	0.33	0.38
33	GTRA08	GT-85RE-08	HEAT	0.	61.	119.	40.	42.	12.	0.	-25.	119.	DISTILLA	94.	10	0.34	0.36	0.34
34	GTRA12	GT-85RE-12	POWR	0.	51.	96.	33.	34.	10.	8.	0.	104.	DISTILLA	104.	10	0.33	0.33	0.38
34	GTRA12	GT-85RE-12	HEAT	0.	61.	115.	40.	41.	12.	0.	-21.	115.	DISTILLA	94.	10	0.35	0.36	0.35
35	GTRA16	GT-85RE-16	POWR	0.	51.	99.	36.	34.	10.	5.	0.	104.	DISTILLA	104.	10	0.33	0.33	0.39
35	GTRA16	GT-85RE-16	HEAT	0.	57.	110.	40.	38.	11.	0.	-12.	110.	DISTILLA	98.	10	0.34	0.35	0.35
36	GTR208	GT-60RE-08	POWR	0.	47.	108.	43.	34.	10.	-4.	0.	108.	DISTILLA	108.	10	0.30	0.32	0.37
36	GTR208	GT-60RE-08	HEAT	0.	47.	99.	40.	32.	9.	0.	8.	99.	DISTILLA	108.	10	0.30	0.30	0.37
37	GTR212	GT-60RE-12	POWR	0.	50.	104.	40.	34.	10.	-0.	0.	104.	DISTILLA	104.	10	0.33	0.33	0.38
37	GTR212	GT-60RE-12	HEAT	0.	50.	103.	40.	34.	10.	0.	1.	103.	DISTILLA	104.	10	0.32	0.33	0.38
38	GTR216	GT-60RE-16	POWR	0.	52.	102.	39.	34.	10.	1.	0.	103.	DISTILLA	103.	10	0.33	0.33	0.39
38	GTR216	GT-60RE-16	HEAT	0.	53.	104.	40.	35.	10.	0.	-2.	104.	DISTILLA	102.	10	0.34	0.34	0.39
39	GTRW08	GT-85RE-08	POWR	0.	42.	98.	27.	34.	10.	15.	0.	113.	DISTILLA	113.	10	0.27	0.30	0.35
39	GTRW08	GT-85RE-08	HEAT	0.	61.	144.	40.	51.	15.	0.	-50.	144.	DISTILLA	94.	10	0.30	0.35	0.28
40	GTRW12	GT-85RE-12	POWR	0.	45.	95.	27.	34.	10.	15.	0.	110.	DISTILLA	110.	10	0.29	0.31	0.36
40	GTRW12	GT-85RE-12	HEAT	0.	66.	141.	40.	51.	15.	0.	-53.	141.	DISTILLA	88.	10	0.32	0.36	0.28

HONEYWELL PAGE PRINTING SYSTEM- P1185-02

PREPARED BY: [REDACTED]

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 281

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 33315 MW 18.50 PROCESS MILLIONS BTU/HR 60.0 PROCESS TEMP(F) 366. PRODUCT COPPER-SMELT HOURS PER YEAR 7620.

UTILITY FUEL		COAL		POWER TO HEAT RATIO 1.052							WASTE FUEL EQV BTU*10**6=		0.		HOT WATER BTU*10**6=		0.	
		WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED-NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR		
0	ONOCGN NO COGN	0.	0.	0.	0.	0.	0.	71.	197.	71.	COAL-AFB	268.	0	0.	0.24	0.22		
1	STM141 STM-TURB-1 POWR	0.	-216.	484.	348.	63.	19.	-339.	0.	484.	RESIDUAL	484.	0	-0.81	0.13	0.12		
1	STM141 STM-TURB-1 HEAT	0.	21.	83.	60.	11.	3.	0.	163.	83.	RESIDUAL	247.	10	0.08	0.04	0.24		
1	STM141 STM-TURB-1 POWR	0.	-216.	484.	348.	63.	19.	-339.	0.	484.	COAL-FGD	484.	0	-0.81	0.13	0.12		
1	STM141 STM-TURB-1 HEAT	0.	21.	83.	60.	11.	3.	0.	163.	83.	COAL-FGD	247.	10	0.08	0.04	0.24		
1	STM141 STM-TURB-1 POWR	0.	-216.	484.	348.	63.	19.	-339.	0.	484.	COAL-AFB	484.	0	-0.81	0.13	0.12		
1	STM141 STM-TURB-1 HEAT	0.	21.	83.	60.	11.	3.	0.	163.	83.	COAL-AFB	247.	10	0.08	0.04	0.24		
2	STM088 STM-TURB-8 POWR	0.	-393.	661.	499.	63.	19.	-516.	0.	661.	RESIDUAL	661.	0	-1.47	0.10	0.09		
2	STM088 STM-TURB-8 HEAT	0.	15.	80.	60.	8.	2.	0.	174.	80.	RESIDUAL	253.	10	0.06	0.03	0.24		
2	STM088 STM-TURB-8 POWR	0.	-393.	661.	499.	63.	19.	-516.	0.	661.	COAL-FGD	661.	0	-1.47	0.10	0.09		
2	STM088 STM-TURB-8 HEAT	0.	15.	80.	60.	8.	2.	0.	174.	80.	COAL-FGD	253.	10	0.06	0.03	0.24		
2	STM088 STM-TURB-8 POWR	0.	-393.	661.	499.	63.	19.	-516.	0.	661.	COAL-AFB	661.	0	-1.47	0.10	0.09		
2	STM088 STM-TURB-8 HEAT	0.	15.	80.	60.	8.	2.	0.	174.	80.	COAL-AFB	253.	10	0.06	0.03	0.24		
3	PFBSTM PFB-STMTB- POWR	0.	-50.	318.	205.	63.	19.	-170.	0.	318.	COAL-PFB	318.	0	-0.19	0.20	0.19		
3	PFBSTM PFB-STMTB- HEAT	0.	35.	93.	60.	19.	5.	0.	139.	93.	COAL-PFB	233.	10	0.13	0.08	0.26		
4	TISTMT TI-STMTB-1 POWR	0.	14.	254.	151.	63.	19.	-107.	0.	254.	RESIDUAL	254.	0	0.15	0.25	0.24		
4	TISTMT TI-STMTB-1 HEAT	0.	48.	101.	60.	25.	7.	0.	119.	101.	RESIDUAL	220.	10	0.18	0.11	0.27		
4	TISTMT TI-STMTB-1 POWR	0.	14.	254.	151.	63.	19.	-107.	0.	254.	COAL	254.	0	0.05	0.25	0.24		
4	TISTMT TI-STMTB-1 HEAT	0.	48.	101.	60.	25.	7.	0.	119.	101.	COAL	220.	10	0.18	0.11	0.27		
5	TIHRSG THERMIONIC POWR	0.	-181.	449.	290.	63.	19.	-270.	0.	449.	RESIDUAL	449.	0	-0.67	0.14	0.13		
5	TIHRSG THERMIONIC HEAT	0.	19.	93.	60.	13.	4.	0.	156.	93.	RESIDUAL	249.	0	0.07	0.05	0.24		
5	TIHRSG THERMIONIC POWR	0.	-181.	449.	290.	63.	19.	-270.	0.	449.	COAL	449.	0	-0.67	0.14	0.13		
5	TIHRSG THERMIONIC HEAT	0.	19.	93.	60.	13.	4.	0.	156.	93.	COAL	249.	0	0.07	0.05	0.24		
6	STIRL STIRLING-1 POWR	0.	17.	251.	120.	63.	19.	-70.	0.	251.	DISTILLA	251.	0	0.06	0.25	0.24		
6	STIRL STIRLING-1 HEAT	0.	44.	126.	60.	32.	9.	0.	98.	126.	DISTILLA	224.	0	0.16	0.14	0.27		

RECORDING PAGE BLANK NOT FILMED

HONEYWELL PAGE PRINTING SYSTEM - P1185-02

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 33315 MW 18.50 PROCESS MILLIONS BTU/HR 60.0 PROCESS TEMP(F) 366. PRODUCT COPPER-SMELT HOURS PER YEAR 7620.

POWER TO HEAT RATIO 1.052

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
18 CC1626	GTST-16/26	POWR	0.	91.	169.	53.	63.	19.	8.	0.	177. RESIDUAL	177.	10	0.34	0.36	0.34
18 CC1626	GTST-16/26	HEAT	0.	102.	190.	60.	71.	21.	0.	-24.	190. RESIDUAL	166.	0	0.35	0.37	0.32
19 CC1622	GTST-16/22	POWR	0.	95.	172.	59.	63.	19.	1.	0.	173. RESIDUAL	173.	10	0.36	0.37	0.35
19 CC1622	GTST-16/22	HEAT	0.	96.	174.	60.	64.	19.	0.	-2.	174. RESIDUAL	172.	10	0.36	0.37	0.35
20 CC1222	GTST-12/22	POWR	0.	98.	172.	60.	63.	19.	0.	0.	172. RESIDUAL	172.	0	0.36	0.37	0.35
20 CC1222	GTST-12/22	HEAT	0.	96.	172.	60.	63.	19.	0.	-1.	172. RESIDUAL	171.	0	0.36	0.37	0.35
21 CC0822	GTST-08/22	POWR	0.	85.	183.	76.	63.	19.	-18.	0.	183. RESIDUAL	183.	0	0.32	0.34	0.33
21 CC0822	GTST-08/22	HEAT	0.	82.	146.	60.	50.	15.	0.	41.	146. RESIDUAL	186.	0	0.31	0.27	0.32
22 STIG15	STIG-15-16	POWR	0.	34.	166.	2.	63.	19.	68.	0.	234. RESIDUAL	234.	10	0.13	0.27	0.26
22 STIG15	STIG-15-16	HEAT	0.	950.	4615.	60.	1758.	515.	0.	-5298.	4615. RESIDUAL	-683.	0	0.17	0.38	0.01
23 STIG10	STIG-10-16	POWR	0.	49.	176.	23.	63.	19.	43.	0.	219. RESIDUAL	219.	10	0.18	0.29	0.27
23 STIG10	STIG-10-16	HEAT	0.	126.	453.	60.	163.	48.	0.	-311.	453. RESIDUAL	142.	0	0.22	0.36	0.13
24 STIG1S	STIG-1S-16	POWR	0.	56.	188.	40.	63.	19.	24.	0.	212. RESIDUAL	212.	10	0.21	0.30	0.28
24 STIG1S	STIG-1S-16	HEAT	0.	84.	285.	60.	95.	28.	0.	-101.	285. RESIDUAL	184.	0	0.23	0.34	0.21
25 DEADV3	DIESEL-ADV	POWR	0.	68.	170.	35.	63.	19.	30.	0.	200. RESIDUAL	200.	0	0.25	0.32	0.30
25 DEADV3	DIESEL-ADV	HEAT	0.	117.	293.	60.	109.	32.	0.	-142.	293. RESIDUAL	151.	0	0.29	0.37	0.20
26 DEADV2	DIESEL-ADV	POWR	0.	78.	170.	43.	63.	19.	20.	0.	190. RESIDUAL	190.	1	0.29	0.33	0.32
26 DEADV2	DIESEL-ADV	HEAT	0.	108.	236.	60.	88.	26.	0.	-77.	236. RESIDUAL	160.	1	0.31	0.37	0.25
27 DEADV1	DIESEL-ADV	POWR	0.	98.	170.	67.	63.	19.	-8.	0.	170. RESIDUAL	170.	1	0.36	0.37	0.35
27 DEADV1	DIESEL-ADV	HEAT	0.	95.	153.	60.	57.	17.	0.	19.	153. RESIDUAL	173.	1	0.35	0.33	0.35
28 DEHTPM	ADV-DIESEL	POWR	0.	75.	193.	83.	63.	19.	-27.	0.	193. RESIDUAL	193.	0	0.28	0.33	0.31
28 DEHTPM	ADV-DIESEL	HEAT	0.	74.	140.	60.	46.	13.	0.	54.	140. RESIDUAL	194.	0	0.27	0.24	0.31
29 DESOA3	DIESEL-SOA	POWR	0.	58.	175.	30.	63.	19.	35.	0.	210. DISTILLA	210.	0	0.21	0.30	0.29
29 DESOA3	DIESEL-SOA	HEAT	0.	116.	351.	60.	127.	37.	0.	-199.	351. DISTILLA	152.	0	0.25	0.36	0.17
29 DESOA3	DIESEL-SOA	POWR	0.	58.	175.	30.	63.	19.	35.	0.	210. RESIDUAL	210.	0	0.21	0.30	0.29
29 DESOA3	DIESEL-SOA	HEAT	0.	116.	351.	60.	127.	37.	0.	-199.	351. RESIDUAL	152.	0	0.25	0.36	0.17

RECORDING PAGE BLANK NOT FILMED

HONEYWELL PAGE PRINTING SYSTEM- P1185-02

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 285

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 33315 MW 18.50 PROCESS MILLIONS BTU/HR 60.0 PROCESS TEMP(F) 366. PRODUCT COPPER-SMELT HOURS PER YEAR 7620.

POWER TO HEAT RATIO 1.052

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER EQV\*10\*\*6= 0.

UTILITY FUEL COAL

	WASTE FUEL 10**6 BTU/HR	FUEL 10**6 BTU/HR	COGEN 10**6 BTU/HR	COGEN 10**6 BTU/HR	COGEN 10**6 BTU/HR	COGEN 10**6 BTU/HR	AUX 10**6 BTU/HR	UTILIT 10**6 BTU/HR	TOTAL 10**6 BTU/HR	SITE FUEL USED	NET+ 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41 GTRW16 GT-85RE-16 POWR	0.	83.	177.	53.	63.	19.	8.	0.	195.	DISTILLA	185.	10	0.31	0.34	0.32
41 GTRW16 GT-85RE-16 HEAT	0.	94.	200.	60.	71.	21.	0.	-25.	200.	DISTILLA	174.	0	0.32	0.36	0.30
42 GTR308 GT-60RE-08 POWR	0.	64.	204.	65.	63.	19.	-6.	0.	204.	DISTILLA	204.	0	0.24	0.31	0.29
42 GTR308 GT-60RE-08 HEAT	0.	65.	187.	60.	58.	17.	0.	16.	187.	DISTILLA	203.	10	0.24	0.29	0.30
43 GTR312 GT-60RE-12 POWR	0.	83.	185.	61.	63.	19.	-1.	0.	185.	DISTILLA	185.	10	0.31	0.34	0.33
43 GTR312 GT-60RE-12 HEAT	0.	83.	181.	60.	62.	18.	0.	4.	181.	DISTILLA	185.	10	0.31	0.33	0.32
44 GTR316 GT-60RE-16 POWR	0.	82.	186.	62.	63.	19.	-3.	0.	186.	DISTILLA	186.	10	0.30	0.34	0.32
44 GTR316 GT-60RE-16 HEAT	0.	81.	180.	60.	61.	18.	0.	7.	180.	DISTILLA	187.	10	0.30	0.33	0.32
45 FCPADS FUEL-CL-PH POWR	0.	64.	166.	28.	63.	19.	37.	0.	203.	DISTILLA	203.	0	0.24	0.31	0.29
45 FCPADS FUEL-CL-PH HEAT	0.	137.	353.	60.	134.	39.	0.	-222.	353.	DISTILLA	131.	0	0.28	0.38	0.17
46 FCMCDS FUEL-CL-MO POWR	0.	86.	153.	36.	63.	19.	29.	0.	182.	DISTILLA	182.	0	0.32	0.35	0.33
46 FCMCDS FUEL-CL-MO HEAT	0.	145.	258.	60.	106.	31.	0.	-134.	258.	DISTILLA	123.	0	0.36	0.41	0.23

PRECEDING PAGE BLANK NOT FILMED



DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 287

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 33316 MW 16.00 PROCESS MILLIONS BTU/HR 60.0 PROCESS TEMP(F) 366. PRODUCT COPPER-SMELT HOURS PER YEAR 7620.

POWER TO HEAT RATIO 0.910

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET USED 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR USED 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
6 STIRL STIRLING-1 POWR		0.	25.	217.	103.	55.	16.	-51.	0.	217.	RESIDUAL	217.	0	0.10	0.25	0.28
6 STIRL STIRLING-1 HEAT		0.	44.	126.	60.	32.	9.	0.	72.	126.	RESIDUAL	197.	0	0.18	0.16	0.30
6 STIRL STIRLING-1 POWR		0.	25.	217.	103.	55.	16.	-51.	0.	217.	COAL	217.	0	0.10	0.25	0.28
6 STIRL STIRLING-1 HEAT		0.	44.	126.	60.	32.	9.	0.	72.	126.	COAL	197.	0	0.18	0.16	0.30
7 HEGT85 HELIUM-GT- POWR		0.	24.	170.	20.	55.	16.	47.	0.	217.	COAL-AFB	217.	10	0.10	0.25	0.28
7 HEGT85 HELIUM-GT- HEAT		0.	72.	507.	60.	163.	48.	0.	-338.	507.	COAL-AFB	169.	10	0.12	0.32	0.12
8 HEGT60 HELIUM-GT- POWR		0.	30.	211.	61.	55.	16.	-1.	0.	211.	COAL-AFB	211.	10	0.13	0.26	0.28
8 HEGT60 HELIUM-GT- HEAT		0.	31.	206.	60.	53.	16.	0.	4.	206.	COAL-AFB	210.	10	0.13	0.25	0.29
9 HEGT00 HELIUM-GT- POWR		0.	-69.	310.	151.	55.	16.	-108.	0.	310.	COAL-AFB	310.	10	-0.29	0.18	0.19
9 HEGT00 HELIUM-GT- HEAT		0.	15.	123.	60.	22.	6.	0.	103.	123.	COAL-AFB	226.	10	0.06	0.10	0.27
10 FCMCCL FUEL-CL-MO POWR		0.	62.	180.	85.	55.	16.	-29.	0.	180.	COAL	180.	10	0.26	0.30	0.33
10 FCMCCL FUEL-CL-MO HEAT		0.	64.	127.	60.	39.	11.	0.	50.	127.	COAL	177.	10	0.27	0.22	0.34
11 FCSTCL FUEL-CL-ST POWR		0.	94.	145.	58.	55.	16.	2.	0.	147.	COAL	147.	10	0.39	0.37	0.41
11 FCSTCL FUEL-CL-ST HEAT		0.	97.	149.	60.	56.	16.	0.	-5.	149.	COAL	144.	10	0.39	0.38	0.40
12 IGGTST INT-GAS-GT POWR		0.	45.	196.	85.	55.	16.	-29.	0.	196.	COAL	196.	10	0.19	0.28	0.31
12 IGGTST INT-GAS-GT HEAT		0.	52.	139.	60.	39.	11.	0.	50.	139.	COAL	189.	10	0.22	0.20	0.32
13 GTSOAR GT-HRSG-10 POWR		0.	53.	188.	80.	55.	16.	-23.	0.	188.	RESIDUAL	188.	0	0.22	0.29	0.32
13 GTSOAR GT-HRSG-10 HEAT		0.	57.	141.	60.	41.	12.	0.	42.	141.	RESIDUAL	184.	0	0.24	0.22	0.33
14 GTAC08 GT-HRSG-08 POWR		0.	39.	202.	104.	55.	16.	-52.	0.	202.	RESIDUAL	202.	0	0.16	0.27	0.30
14 GTAC08 GT-HRSG-08 HEAT		0.	52.	117.	60.	31.	9.	0.	72.	117.	RESIDUAL	189.	10	0.22	0.17	0.32
15 GTAC12 GT-HRSG-12 POWR		0.	62.	179.	83.	55.	16.	-27.	0.	179.	RESIDUAL	179.	0	0.26	0.31	0.34
15 GTAC12 GT-HRSG-12 HEAT		0.	65.	129.	60.	39.	12.	0.	47.	129.	RESIDUAL	177.	10	0.27	0.22	0.34
16 GTAC16 GT-HRSG-16 POWR		0.	72.	169.	73.	55.	16.	-15.	0.	169.	RESIDUAL	169.	0	0.30	0.32	0.35
16 GTAC16 GT-HRSG-16 HEAT		0.	72.	139.	60.	45.	13.	0.	31.	139.	RESIDUAL	169.	10	0.30	0.26	0.35
17 GTWC16 GT-HRSG-16 POWR		0.	68.	173.	70.	55.	16.	-12.	0.	173.	RESIDUAL	173.	10	0.28	0.32	0.35
17 GTWC16 GT-HRSG-16 HEAT		0.	68.	148.	60.	47.	14.	0.	25.	148.	RESIDUAL	173.	10	0.28	0.27	0.35

HONEYWELL PAGE PRINTING SYSTEM- P1185-02

1&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 33316 MW 16.00 PROCESS MILLIONS BTU/HR 60.0 PROCESS TEMP(F) 366. PRODUCT COPPER-SMELT HOURS PER YEAR 7620.

POWER TO HEAT RATIO 0.910

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
30 DES0A2 DIESEL-S0A POWR		0.	59.	151.	33.	55.	16.	31.	0.	183.	DISTILLA	183.	1	0.24	0.30	0.33
30 DES0A2 DIESEL-S0A HEAT		0.	106.	273.	60.	98.	29.	0.	-137.	273.	DISTILLA	136.	1	0.28	0.36	0.22
30 DES0A2 DIESEL-S0A POWR		0.	59.	151.	33.	55.	16.	31.	0.	183.	RESIDUAL	183.	1	0.24	0.30	0.33
30 DES0A2 DIESEL-S0A HEAT		0.	106.	273.	60.	98.	29.	0.	-137.	273.	RESIDUAL	136.	1	0.28	0.36	0.22
31 DES0A1 DIESEL-S0A POWR		0.	90.	151.	61.	55.	16.	-1.	0.	151.	DISTILLA	151.	1	0.37	0.36	0.40
31 DES0A1 DIESEL-S0A HEAT		0.	90.	150.	60.	54.	16.	0.	2.	150.	DISTILLA	151.	1	0.37	0.36	0.40
31 DES0A1 DIESEL-S0A POWR		0.	90.	151.	61.	55.	16.	-1.	0.	151.	RESIDUAL	151.	1	0.37	0.36	0.40
31 DES0A1 DIESEL-S0A HEAT		0.	90.	150.	60.	54.	16.	0.	2.	150.	RESIDUAL	151.	1	0.37	0.36	0.40
32 GTS0AD GT-HRSG-10 POWR		0.	54.	187.	86.	55.	16.	-31.	0.	187.	DISTILLA	187.	0	0.22	0.29	0.32
32 GTS0AD GT-HRSG-10 HEAT		0.	59.	130.	60.	38.	11.	0.	52.	130.	DISTILLA	182.	10	0.25	0.21	0.33
33 GTRA08 GT-85RE-08 POWR		0.	78.	153.	51.	55.	16.	10.	0.	163.	DISTILLA	163.	0	0.32	0.33	0.37
33 GTRA08 GT-85RE-08 HEAT		0.	91.	178.	60.	64.	19.	0.	-28.	178.	DISTILLA	150.	0	0.34	0.36	0.34
34 GTRA12 GT-85RE-12 POWR		0.	80.	152.	53.	55.	16.	8.	0.	161.	DISTILLA	161.	0	0.33	0.34	0.37
34 GTRA12 GT-85RE-12 HEAT		0.	91.	173.	60.	62.	18.	0.	-23.	173.	DISTILLA	150.	0	0.34	0.36	0.35
35 GTRA16 GT-85RE-16 POWR		0.	81.	156.	57.	55.	16.	4.	0.	160.	DISTILLA	160.	0	0.34	0.34	0.37
35 GTRA16 GT-85RE-16 HEAT		0.	86.	166.	60.	53.	17.	0.	-10.	166.	DISTILLA	156.	0	0.34	0.35	0.36
36 GTR208 GT-60RE-08 POWR		0.	71.	171.	69.	55.	16.	-10.	0.	171.	DISTILLA	171.	0	0.29	0.32	0.35
36 GTR208 GT-60RE-08 HEAT		0.	71.	149.	60.	48.	14.	0.	21.	149.	DISTILLA	171.	0	0.29	0.28	0.35
37 GTR212 GT-60RE-12 POWR		0.	76.	165.	64.	55.	16.	-5.	0.	165.	DISTILLA	165.	0	0.31	0.33	0.36
37 GTR212 GT-60RE-12 HEAT		0.	75.	155.	60.	51.	15.	0.	11.	155.	DISTILLA	166.	0	0.31	0.31	0.36
38 GTR216 GT-60RE-16 POWR		0.	79.	162.	62.	55.	16.	-3.	0.	162.	DISTILLA	162.	0	0.33	0.34	0.37
38 GTR216 GT-60RE-16 HEAT		0.	79.	156.	60.	53.	15.	0.	6.	156.	DISTILLA	162.	0	0.33	0.32	0.37
39 GTRW08 GT-85RE-08 POWR		0.	66.	156.	43.	55.	16.	20.	0.	175.	DISTILLA	175.	10	0.27	0.31	0.34
39 GTRW08 GT-85RE-08 HEAT		0.	92.	216.	60.	76.	22.	0.	-67.	216.	DISTILLA	150.	0	0.30	0.35	0.28
40 GTRW12 GT-85RE-12 POWR		0.	71.	150.	43.	55.	16.	21.	0.	171.	DISTILLA	171.	10	0.29	0.32	0.35
40 GTRW12 GT-85RE-12 HEAT		0.	100.	212.	60.	77.	23.	0.	-70.	212.	DISTILLA	141.	0	0.32	0.36	0.28

PRECEDING PAGE BLANK NOT FILMED

HONEYWELL PAGE PRINTING SYSTEM - P1188-02

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 291

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 33341 MW 756.00 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT ALUMINUM HOURS PER YEAR 8760.

UTILITY FUEL		COAL		POWER TO HEAT RATIO *****										WASTE FUEL EQV BTU*10**6=		HOT WATER BTU*10**6=	
WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NG-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR			
0 ONOCGN N 0 C 0 G 0 N	0.	0.	0.	0.	0.	0.	0.	8061.	0.	8061.	0	0.	0.32	0.			
1 STM141 STM-TURB-1 POWR	0.	340.	7721.	3983.	2579.	756.	-4686.	0.	7721.	7721.	1	0.04	0.33	0.			
1 STM141 STM-TURB-1 HEAT	0.	0.	0.	0.	0.	0.	0.	8061.	0.	8061.	111	0.	0.	0.			
1 STM141 STM-TURB-1 POWR	0.	340.	7721.	3983.	2579.	756.	-4686.	0.	7721.	7721.	1	0.04	0.33	0.			
1 STM141 STM-TURB-1 HEAT	0.	0.	0.	0.	0.	0.	0.	8061.	0.	8061.	111	0.	0.	0.			
1 STM141 STM-TURB-1 POWR	0.	340.	7721.	3983.	2579.	756.	-4686.	0.	7721.	7721.	1	0.04	0.33	0.			
1 STM141 STM-TURB-1 HEAT	0.	0.	0.	0.	0.	0.	0.	8061.	0.	8061.	111	0.	0.	0.			
2 STM088 STM-TURB-8 POWR	0.	-449.	8510.	4654.	2579.	756.	-5476.	0.	8510.	8510.	1	-0.06	0.30	0.			
2 STM088 STM-TURB-8 HEAT	0.	0.	0.	0.	0.	0.	0.	8061.	0.	8061.	111	0.	0.	0.			
2 STM088 STM-TURB-8 POWR	0.	-449.	8510.	4654.	2579.	756.	-5476.	0.	8510.	8510.	1	-0.06	0.30	0.			
2 STM088 STM-TURB-8 HEAT	0.	0.	0.	0.	0.	0.	0.	8061.	0.	8061.	111	0.	0.	0.			
2 STM088 STM-TURB-8 POWR	0.	-449.	8510.	4654.	2579.	756.	-5476.	0.	8510.	8510.	1	-0.06	0.30	0.			
2 STM088 STM-TURB-8 HEAT	0.	0.	0.	0.	0.	0.	0.	8061.	0.	8061.	111	0.	0.	0.			
3 PFBSTM PFB-STMTB- POWR	0.	1331.	6730.	3185.	2579.	756.	-3747.	0.	6730.	6730.	1	0.17	0.38	0.			
3 PFBSTM PFB-STMTB- HEAT	0.	0.	0.	0.	0.	0.	0.	8061.	0.	8061.	111	0.	0.	0.			
4 T1STMT TI-STMTB-1 POWR	0.	1844.	6217.	2662.	2579.	756.	-3131.	0.	6217.	6217.	1	0.23	0.41	0.			
4 T1STMT TI-STMTB-1 HEAT	0.	0.	0.	0.	0.	0.	0.	8061.	0.	8061.	111	0.	0.	0.			
4 T1STMT TI-STMTB-1 POWR	0.	1844.	6217.	2662.	2579.	756.	-3131.	0.	6217.	6217.	1	0.23	0.41	0.			
4 T1STMT TI-STMTB-1 HEAT	0.	0.	0.	0.	0.	0.	0.	8061.	0.	8061.	111	0.	0.	0.			
5 TIHRSG THERMIONIC POWR	0.	-10272.	18333.	12963.	2579.	756.	-15251.	0.	18333.	18333.	1	-1.27	0.14	0.			
5 TIHRSG THERMIONIC HEAT	0.	0.	0.	0.	0.	0.	0.	8061.	0.	8061.	111	0.	0.	0.			
5 TIHRSG THERMIONIC POWR	0.	-10272.	18333.	12963.	2579.	756.	-15251.	0.	18333.	18333.	1	-1.27	0.14	0.			
5 TIHRSG THERMIONIC HEAT	0.	0.	0.	0.	0.	0.	0.	8061.	0.	8061.	111	0.	0.	0.			
6 STIRL STIRLING-1 POWR	0.	-322.	8383.	3497.	2579.	756.	-4115.	0.	8383.	8383.	1	-0.04	0.31	0.			
6 STIRL STIRLING-1 HEAT	0.	0.	0.	0.	0.	0.	0.	8061.	0.	8061.	111	0.	0.	0.			

PRECEDING PAGE BLANK NOT FILLED

HONEYWELL PAGE PRINTING SYSTEM - P11185-02

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 293

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 33341 MW 756.00 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT ALUMINUM HOURS PER YEAR 8760.

UTILITY FUEL COAL

POWER TO HEAT RATIO \*\*\*\*\*

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

			WASTE FUEL 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	AUX MW ELECT	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER HEAT FACTR	HEAT FACTR		
18	CC1626	GTST-16/26	POWR	0.	2473.	5588.	1263.	2579.	756.	-1486.	0.	5588.	RESIDUAL	5588.	1	0.31	0.46	0.
18	CC1626	GTST-16/26	HEAT	0.	0.	0.	0.	0.	0.	0.	8061.	0.	RESIDUAL	8061.	111	0.	0.	0.
19	CC1622	GTST-16/22	POWR	0.	2476.	5584.	1398.	2579.	756.	-1645.	0.	5584.	RESIDUAL	5584.	1	0.31	0.46	0.
19	CC1622	GTST-16/22	HEAT	0.	0.	0.	0.	0.	0.	0.	8061.	0.	RESIDUAL	8061.	111	0.	0.	0.
20	CC1222	GTST-12/22	POWR	0.	2531.	5529.	1382.	2579.	756.	-1626.	0.	5529.	RESIDUAL	5529.	1	0.31	0.47	0.
20	CC1222	GTST-12/22	HEAT	0.	0.	0.	0.	0.	0.	0.	8061.	0.	RESIDUAL	8061.	111	0.	0.	0.
21	CC0822	GTST-08/22	POWR	0.	2469.	5592.	1653.	2579.	756.	-1945.	0.	5592.	RESIDUAL	5592.	1	0.31	0.46	0.
21	CC0822	GTST-08/22	HEAT	0.	0.	0.	0.	0.	0.	0.	8061.	0.	RESIDUAL	8061.	111	0.	0.	0.
22	STIG15	STIG-15-16	POWR	0.	1291.	6770.	88.	2579.	756.	-104.	0.	6770.	RESIDUAL	6770.	1	0.16	0.38	0.
22	STIG15	STIG-15-16	HEAT	0.	0.	0.	0.	0.	0.	0.	8061.	0.	RESIDUAL	8061.	111	0.	0.	0.
23	STIG10	STIG-10-16	POWR	0.	878.	7183.	952.	2579.	756.	-1120.	0.	7183.	RESIDUAL	7183.	1	0.11	0.36	0.
23	STIG10	STIG-10-16	HEAT	0.	0.	0.	0.	0.	0.	0.	8061.	0.	RESIDUAL	8061.	111	0.	0.	0.
24	STIG1S	STIG-1S-16	POWR	0.	366.	7695.	1622.	2579.	756.	-1908.	0.	7695.	RESIDUAL	7695.	1	0.05	0.34	0.
24	STIG1S	STIG-1S-16	HEAT	0.	0.	0.	0.	0.	0.	0.	8061.	0.	RESIDUAL	8061.	111	0.	0.	0.
25	DEADV3	DIESEL-ADV	POWR	0.	1108.	6953.	2502.	2579.	756.	-2943.	0.	6953.	RESIDUAL	6953.	1	0.14	0.37	0.
25	DEADV3	DIESEL-ADV	HEAT	0.	0.	0.	0.	0.	0.	0.	8061.	0.	RESIDUAL	8061.	111	0.	0.	0.
26	DEADV2	DIESEL-ADV	POWR	0.	1108.	6953.	1766.	2579.	756.	-2078.	0.	6953.	RESIDUAL	6953.	1	0.14	0.37	0.
26	DEADV2	DIESEL-ADV	HEAT	0.	0.	0.	0.	0.	0.	0.	8061.	0.	RESIDUAL	8061.	111	0.	0.	0.
27	DEADV1	DIESEL-ADV	POWR	0.	1108.	6953.	2719.	2579.	756.	-3198.	0.	6953.	RESIDUAL	6953.	1	0.14	0.37	0.
27	DEADV1	DIESEL-ADV	HEAT	0.	0.	0.	0.	0.	0.	0.	8061.	0.	RESIDUAL	8061.	111	0.	0.	0.
28	DEHTPM	ADV-DIESEL	POWR	0.	1631.	6429.	3274.	2579.	756.	-3852.	0.	6429.	RESIDUAL	6429.	1	0.20	0.40	0.
28	DEHTPM	ADV-DIESEL	HEAT	0.	0.	0.	0.	0.	0.	0.	8061.	0.	RESIDUAL	8061.	111	0.	0.	0.
29	DES0A3	DIESEL-S0A	POWR	0.	915.	7145.	2328.	2579.	756.	-2739.	0.	7145.	DISTILLA	7145.	1	0.11	0.36	0.
29	DES0A3	DIESEL-S0A	HEAT	0.	0.	0.	0.	0.	0.	0.	8061.	0.	DISTILLA	8061.	111	0.	0.	0.
29	DES0A3	DIESEL-S0A	POWR	0.	915.	7145.	2328.	2579.	756.	-2739.	0.	7145.	RESIDUAL	7145.	1	0.11	0.36	0.
29	DES0A3	DIESEL-S0A	HEAT	0.	0.	0.	0.	0.	0.	0.	8061.	0.	RESIDUAL	8061.	111	0.	0.	0.

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 295

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 33341 MW 756.00 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT ALUMINUM HOURS PER YEAR 8760.

POWER TO HEAT RATIO \*\*\*\*\*

UTILITY FUEL COAL

WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL± UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41 GTRW16 GT-85RE-16 POWR	0.	835.	7225.	2531.	2579.	756.	-2978.	0.	7225.	DISTILLA	7225.	1	0.10	0.36	0.
41 GTRW16 GT-85RE-16 HEAT	0.	0.	0.	0.	0.	0.	0.	8061.	0.	DISTILLA	8061.	111	0.	0.	0.
42 GTR308 GT-60RE-08 POWR	0.	-260.	8321.	3734.	2579.	756.	-4392.	0.	8321.	DISTILLA	8321.	1	-0.03	0.31	0.
42 GTR308 GT-60RE-08 HEAT	0.	0.	0.	0.	0.	0.	0.	8061.	0.	DISTILLA	8061.	111	0.	0.	0.
43 GTR312 GT-60RE-12 POWR	0.	519.	7542.	2878.	2579.	756.	-3386.	0.	7542.	DISTILLA	7542.	1	0.06	0.34	0.
43 GTR312 GT-60RE-12 HEAT	0.	0.	0.	0.	0.	0.	0.	8061.	0.	DISTILLA	8061.	111	0.	0.	0.
44 GTR316 GT-60RE-16 POWR	0.	452.	7609.	2925.	2579.	756.	-3441.	0.	7609.	DISTILLA	7609.	1	0.06	0.34	0.
44 GTR316 GT-60RE-16 HEAT	0.	0.	0.	0.	0.	0.	0.	8061.	0.	DISTILLA	8061.	111	0.	0.	0.
45 FCPADS FUEL-CL-PH POWR	0.	1273.	6788.	1154.	2579.	756.	-1358.	0.	6788.	DISTILLA	6788.	1	0.15	0.38	0.
45 FCPADS FUEL-CL-PH HEAT	0.	0.	0.	0.	0.	0.	0.	8061.	0.	DISTILLA	8061.	111	0.	0.	0.
46 FCMCDS FUEL-CL-MO POWR	0.	1800.	6261.	1459.	2579.	756.	-1716.	0.	6261.	DISTILLA	6261.	1	0.22	0.41	0.
46 FCMCDS FUEL-CL-MO HEAT	0.	0.	0.	0.	0.	0.	0.	8061.	0.	DISTILLA	8061.	111	0.	0.	0.

PRECEDING PAGE BLANK NOT REPRODUCED

HONEYWELL PAGE PRINTING SYSTEM- P1185-02

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 297

I&amp;SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 33342 MW 378.00 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT ALUMINUM HOURS PER YEAR 8760.

POWER TO HEAT RATIO \*\*\*\*\*

UTILITY FUEL COAL WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED- NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	AUX MW ELECT	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL 10**6 BTU/HR	SITE FUEL USED 10**6 BTU/HR	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR	
6 STIRL STIRLING-1 POWR		0.	-161.	4192.	1749.	1290.	378.	-2057.	0.	4192.	RESIDUAL	4192.	1	-0.04	0.31	0.
6 STIRL STIRLING-1 HEAT		0.	0.	0.	0.	0.	0.	0.	4030.	0.	RESIDUAL	4030.	111	0.	0.	0.
6 STIRL STIRLING-1 POWR		0.	-161.	4192.	1749.	1290.	378.	-2057.	0.	4192.	COAL	4192.	1	-0.04	0.31	0.
6 STIRL STIRLING-1 HEAT		0.	0.	0.	0.	0.	0.	0.	4030.	0.	COAL	4030.	111	0.	0.	0.
7 HEGT65 HELIUM-GT- POWR		0.	13.	4018.	1795.	1290.	378.	-2112.	0.	4018.	COAL-AFB	4018.	1	0.00	0.32	0.
7 HEGT65 HELIUM-GT- HEAT		0.	0.	0.	0.	0.	0.	0.	4030.	0.	COAL-AFB	4030.	111	0.	0.	0.
8 HEGT60 HELIUM-GT- POWR		0.	-949.	4980.	2140.	1290.	378.	-2517.	0.	4980.	COAL-AFB	4980.	1	-0.24	0.26	0.
8 HEGT60 HELIUM-GT- HEAT		0.	0.	0.	0.	0.	0.	0.	4030.	0.	COAL-AFB	4030.	111	0.	0.	0.
9 HEGT00 HELIUM-GT- POWR		0.	-3298.	7328.	4429.	1290.	378.	-5211.	0.	7328.	COAL-AFB	7328.	1	-0.82	0.18	0.
9 HEGT00 HELIUM-GT- HEAT		0.	0.	0.	0.	0.	0.	0.	4030.	0.	COAL-AFB	4030.	111	0.	0.	0.
10 FCMCCL FUEL-CL-MO POWR		0.	-212.	4243.	2029.	1290.	378.	-2387.	0.	4243.	COAL	4243.	1	-0.05	0.30	0.
10 FCMCCL FUEL-CL-MO HEAT		0.	0.	0.	0.	0.	0.	0.	4030.	0.	COAL	4030.	111	0.	0.	0.
11 FCSTCL FUEL-CL-ST POWR		0.	1408.	2622.	753.	1290.	378.	-886.	0.	2622.	COAL	2622.	1	0.35	0.49	0.
11 FCSTCL FUEL-CL-ST HEAT		0.	0.	0.	0.	0.	0.	0.	4030.	0.	COAL	4030.	111	0.	0.	0.
12 IGGTST INT-GAS-GT POWR		0.	806.	3224.	1000.	1290.	378.	-1176.	0.	3224.	COAL	3224.	1	0.20	0.40	0.
12 IGGTST INT-GAS-GT HEAT		0.	0.	0.	0.	0.	0.	0.	4030.	0.	COAL	4030.	111	0.	0.	0.
13 GTSOAR GT-HRSG-10 POWR		0.	-417.	4447.	2197.	1290.	378.	-2585.	0.	4447.	RESIDUAL	4447.	1	-0.10	0.29	0.
13 GTSOAR GT-HRSG-10 HEAT		0.	0.	0.	0.	0.	0.	0.	4030.	0.	RESIDUAL	4030.	111	0.	0.	0.
14 GTAC08 GT-HRSG-08 POWR		0.	-746.	4777.	2294.	1290.	378.	-2699.	0.	4777.	RESIDUAL	4777.	1	-0.19	0.27	0.
14 GTAC08 GT-HRSG-08 HEAT		0.	0.	0.	0.	0.	0.	0.	4030.	0.	RESIDUAL	4030.	111	0.	0.	0.
15 GTAC12 GT-HRSG-12 POWR		0.	-198.	4229.	2182.	1290.	378.	-2568.	0.	4229.	RESIDUAL	4229.	1	-0.05	0.31	0.
15 GTAC12 GT-HRSG-12 HEAT		0.	0.	0.	0.	0.	0.	0.	4030.	0.	RESIDUAL	4030.	111	0.	0.	0.
16 GTAC16 GT-HRSG-16 POWR		0.	37.	3993.	2005.	1290.	378.	-2359.	0.	3993.	RESIDUAL	3993.	1	0.01	0.32	0.
16 GTAC16 GT-HRSG-16 HEAT		0.	0.	0.	0.	0.	0.	0.	4030.	0.	RESIDUAL	4030.	111	0.	0.	0.
17 GTWC16 GT-HRSG-16 POWR		0.	-64.	4094.	1634.	1290.	378.	-1922.	0.	4094.	RESIDUAL	4094.	1	-0.02	0.32	0.
17 GTWC16 GT-HRSG-16 HEAT		0.	0.	0.	0.	0.	0.	0.	4030.	0.	RESIDUAL	4030.	111	0.	0.	0.

PRECEDING PAGE BLANK NOT FILMED

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 299

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 33342 MW 378.00 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT ALUMINUM HOURS PER YEAR 8760.

		POWER TO HEAT RATIO *****																	
UTILITY FUEL		COAL		WASTE FUEL EQV BTU*10**6=										0.		HOT WATER BTU*10**6=		0.	
		WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR			
30	DESOA2 DIESEL-SOA POWR	0.	458.	3573.	786.	1290.	378.	-925.	0.	3573.	DISTILLA	3573.	1	0.11	0.36	0.			
30	DESOA2 DIESEL-SOA HEAT	0.	0.	0.	0.	0.	0.	0.	4030.	0.	DISTILLA	4030.	111	0.	0.	0.			
30	DESOA2 DIESEL-SOA POWR	0.	458.	3573.	786.	1290.	378.	-925.	0.	3573.	RESIDUAL	3573.	1	0.11	0.36	0.			
30	DESOA2 DIESEL-SOA HEAT	0.	0.	0.	0.	0.	0.	0.	4030.	0.	RESIDUAL	4030.	111	0.	0.	0.			
31	DESOA1 DIESEL-SOA POWR	0.	458.	3573.	1433.	1290.	378.	-1685.	0.	3573.	DISTILLA	3573.	1	0.11	0.36	0.			
31	DESOA1 DIESEL-SOA HEAT	0.	0.	0.	0.	0.	0.	0.	4030.	0.	DISTILLA	4030.	111	0.	0.	0.			
31	DESOA1 DIESEL-SOA POWR	0.	458.	3573.	1433.	1290.	378.	-1685.	0.	3573.	RESIDUAL	3573.	1	0.11	0.36	0.			
31	DESOA1 DIESEL-SOA HEAT	0.	0.	0.	0.	0.	0.	0.	4030.	0.	RESIDUAL	4030.	111	0.	0.	0.			
32	GTSOAD GT-HRSG-10 POWR	0.	-386.	4417.	2380.	1290.	378.	-2800.	0.	4417.	DISTILLA	4417.	1	-0.10	0.29	0.			
32	GTSOAD GT-HRSG-10 HEAT	0.	0.	0.	0.	0.	0.	0.	4030.	0.	DISTILLA	4030.	111	0.	0.	0.			
33	GTRA08 GT-85RE-08 POWR	0.	418.	3613.	1459.	1290.	378.	-1716.	0.	3613.	DISTILLA	3613.	1	0.10	0.36	0.			
33	GTRA08 GT-85RE-08 HEAT	0.	0.	0.	0.	0.	0.	0.	4030.	0.	DISTILLA	4030.	111	0.	0.	0.			
34	GTRA12 GT-85RE-12 POWR	0.	428.	3603.	1477.	1290.	378.	-1737.	0.	3603.	DISTILLA	3603.	1	0.11	0.36	0.			
34	GTRA12 GT-85RE-12 HEAT	0.	0.	0.	0.	0.	0.	0.	4030.	0.	DISTILLA	4030.	111	0.	0.	0.			
35	GTRA16 GT-85RE-16 POWR	0.	335.	3696.	1571.	1290.	378.	-1848.	0.	3696.	DISTILLA	3696.	1	0.08	0.35	0.			
35	GTRA16 GT-85RE-16 HEAT	0.	0.	0.	0.	0.	0.	0.	4030.	0.	DISTILLA	4030.	111	0.	0.	0.			
36	GTR208 GT-60RE-08 POWR	0.	0.	4030.	1903.	1290.	378.	-2239.	0.	4030.	DISTILLA	4030.	1	0.	0.32	0.			
36	GTR208 GT-60RE-08 HEAT	0.	0.	0.	0.	0.	0.	0.	4030.	0.	DISTILLA	4030.	111	0.	0.	0.			
37	GTR212 GT-60RE-12 POWR	0.	122.	3908.	1749.	1290.	378.	-2058.	0.	3908.	DISTILLA	3908.	1	0.03	0.33	0.			
37	GTR212 GT-60RE-12 HEAT	0.	0.	0.	0.	0.	0.	0.	4030.	0.	DISTILLA	4030.	111	0.	0.	0.			
38	GTR216 GT-60RE-16 POWR	0.	203.	3827.	1709.	1290.	378.	-2010.	0.	3827.	DISTILLA	3827.	1	0.05	0.34	0.			
38	GTR216 GT-60RE-16 HEAT	0.	0.	0.	0.	0.	0.	0.	4030.	0.	DISTILLA	4030.	111	0.	0.	0.			
39	GTRW08 GT-85RE-08 POWR	0.	356.	3674.	1213.	1290.	378.	-1427.	0.	3674.	DISTILLA	3674.	1	0.09	0.35	0.			
39	GTRW08 GT-85RE-08 HEAT	0.	0.	0.	0.	0.	0.	0.	4030.	0.	DISTILLA	4030.	111	0.	0.	0.			
40	GTRW12 GT-85RE-12 POWR	0.	487.	3543.	1180.	1290.	378.	-1388.	0.	3543.	DISTILLA	3543.	1	0.12	0.36	0.			
40	GTRW12 GT-85RE-12 HEAT	0.	0.	0.	0.	0.	0.	0.	4030.	0.	DISTILLA	4030.	111	0.	0.	0.			

HONEYWELL PAGE PRINTING SYSTEM - P1185-02

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 301

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 33343 MW 153.00 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT ALUMINUM HOURS PER YEAR 8760.

POWER TO HEAT RATIO \*\*\*\*\*

WASTE FUEL EQV BTU\*10\*\*6= 0.

HOT WATER BTU\*10\*\*6= 0.

UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN USED 10**6 BTU/HR	COGEN HEAT 10**6 BTU/HR	COGEN POWER 10**6 BTU/HR	AUX ELECT BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
0 ONOCGN N O C O G O N		0.	0.	0.	0.	0.	0.	1631.	0.	DISTILLA	1631.	0	0.	0.32	0.
1 STM141 STM-TURB-1 POWR		0.	69.	1563.	806.	522.	153.	-948.	0.	1563. RESIDUAL	1563.	1	0.04	0.33	0.
1 STM141 STM-TURB-1 HEAT		0.	0.	0.	0.	0.	0.	0.	1631.	0. RESIDUAL	1631.	111	0.	0.	0.
1 STM141 STM-TURB-1 POWR		0.	69.	1563.	806.	522.	153.	-948.	0.	1563. COAL-FGD	1563.	1	0.04	0.33	0.
1 STM141 STM-TURB-1 HEAT		0.	0.	0.	0.	0.	0.	0.	1631.	0. COAL-FGD	1631.	111	0.	0.	0.
1 STM141 STM-TURB-1 POWR		0.	69.	1563.	806.	522.	153.	-948.	0.	1563. COAL-AFB	1563.	1	0.04	0.33	0.
1 STM141 STM-TURB-1 HEAT		0.	0.	0.	0.	0.	0.	0.	1631.	0. COAL-AFB	1631.	111	0.	0.	0.
2 STM088 STM-TURB-8 POWR		0.	-91.	1722.	942.	522.	153.	-1108.	0.	1722. RESIDUAL	1722.	1	-0.06	0.30	0.
2 STM088 STM-TURB-8 HEAT		0.	0.	0.	0.	0.	0.	0.	1631.	0. RESIDUAL	1631.	111	0.	0.	0.
2 STM088 STM-TURB-8 POWR		0.	-91.	1722.	942.	522.	153.	-1108.	0.	1722. COAL-FGD	1722.	1	-0.06	0.30	0.
2 STM088 STM-TURB-8 HEAT		0.	0.	0.	0.	0.	0.	0.	1631.	0. COAL-FGD	1631.	111	0.	0.	0.
2 STM088 STM-TURB-8 POWR		0.	-91.	1722.	942.	522.	153.	-1108.	0.	1722. COAL-AFB	1722.	1	-0.06	0.30	0.
2 STM088 STM-TURB-8 HEAT		0.	0.	0.	0.	0.	0.	0.	1631.	0. COAL-AFB	1631.	111	0.	0.	0.
3 PFBSTM PFB-STMTB- POWR		0.	269.	1362.	645.	522.	153.	-758.	0.	1362. COAL-PFB	1362.	1	0.17	0.38	0.
3 PFBSTM PFB-STMTB- HEAT		0.	0.	0.	0.	0.	0.	0.	1631.	0. COAL-PFB	1631.	111	0.	0.	0.
4 TISTMT TI-STMTB-1 POWR		0.	373.	1258.	539.	522.	153.	-634.	0.	1258. RESIDUAL	1258.	1	0.23	0.41	0.
4 TISTMT TI-STMTB-1 HEAT		0.	0.	0.	0.	0.	0.	0.	1631.	0. RESIDUAL	1631.	111	0.	0.	0.
4 TISTMT TI-STMTB-1 POWR		0.	373.	1258.	539.	522.	153.	-634.	0.	1258. COAL	1258.	1	0.23	0.41	0.
4 TISTMT TI-STMTB-1 HEAT		0.	0.	0.	0.	0.	0.	0.	1631.	0. COAL	1631.	111	0.	0.	0.
5 TIHRSG THERMIONIC POWR		0.	-2079.	3710.	2624.	522.	153.	-3087.	0.	3710. RESIDUAL	3710.	1	-1.27	0.14	0.
5 TIHRSG THERMIONIC HEAT		0.	0.	0.	0.	0.	0.	0.	1631.	0. RESIDUAL	1631.	111	0.	0.	0.
5 TIHRSG THERMIONIC POWR		0.	-2079.	3710.	2624.	522.	153.	-3087.	0.	3710. COAL	3710.	1	-1.27	0.14	0.
5 TIHRSG THERMIONIC HEAT		0.	0.	0.	0.	0.	0.	0.	1631.	0. COAL	1631.	111	0.	0.	0.
6 STIRL STIRLING-1 POWR		0.	-65.	1697.	708.	522.	153.	-833.	0.	1697. DISTILLA	1697.	1	-0.04	0.31	0.
6 STIRL STIRLING-1 HEAT		0.	0.	0.	0.	0.	0.	0.	1631.	0. DISTILLA	1631.	111	0.	0.	0.

PRECEDING PAGE BLANK NOT REPRODUCED

HONEYWELL PAGE PRINTING SYSTEM- P1185-02



I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 33343 MW 153.00 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT ALUMINUM HOURS PER YEAR 8760.

		POWER TO HEAT RATIO *****																
		WASTE FUEL EQV BTU*10**6=										0. HOT WATER BTU*10**6= 0.						
UTILITY FUEL	COAL	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR		
18	CC1626	GTST-16/26	POWR	0.	500.	1131.	256.	522.	153.	-301.	0.	1131.	RESIDUAL	1131.	1	0.31	0.46	0.
18	CC1626	GTST-16/26	HEAT	0.	0.	0.	0.	0.	0.	1631.	0.	RESIDUAL	1631.	111	0.	0.	0.	
19	CC1622	GTST-16/22	POWR	0.	501.	1130.	283.	522.	153.	-333.	0.	1130.	RESIDUAL	1130.	1	0.31	0.46	0.
19	CC1622	GTST-16/22	HEAT	0.	0.	0.	0.	0.	0.	1631.	0.	RESIDUAL	1631.	111	0.	0.	0.	
20	CC1222	GTST-12/22	POWR	0.	512.	1119.	280.	522.	153.	-329.	0.	1119.	RESIDUAL	1119.	1	0.31	0.47	0.
20	CC1222	GTST-12/22	HEAT	0.	0.	0.	0.	0.	0.	1631.	0.	RESIDUAL	1631.	111	0.	0.	0.	
21	CC0822	GTST-08/22	POWR	0.	500.	1132.	335.	522.	153.	-394.	0.	1132.	RESIDUAL	1132.	1	0.31	0.46	0.
21	CC0822	GTST-08/22	HEAT	0.	0.	0.	0.	0.	0.	1631.	0.	RESIDUAL	1631.	111	0.	0.	0.	
22	STIG15	STIG-15-16	POWR	0.	261.	1370.	18.	522.	153.	-21.	0.	1370.	RESIDUAL	1370.	1	0.16	0.38	0.
22	STIG15	STIG-15-16	HEAT	0.	0.	0.	0.	0.	0.	1631.	0.	RESIDUAL	1631.	111	0.	0.	0.	
23	STIG10	STIG-10-16	POWR	0.	178.	1454.	193.	522.	153.	-227.	0.	1454.	RESIDUAL	1454.	1	0.11	0.36	0.
23	STIG10	STIG-10-16	HEAT	0.	0.	0.	0.	0.	0.	1631.	0.	RESIDUAL	1631.	111	0.	0.	0.	
24	STIG15	STIG-1S-16	POWR	0.	74.	1557.	328.	522.	153.	-386.	0.	1557.	RESIDUAL	1557.	1	0.05	0.34	0.
24	STIG15	STIG-1S-16	HEAT	0.	0.	0.	0.	0.	0.	1631.	0.	RESIDUAL	1631.	111	0.	0.	0.	
25	DEADV3	DIESEL-ADV	POWR	0.	224.	1407.	506.	522.	153.	-596.	0.	1407.	RESIDUAL	1407.	1	0.14	0.37	0.
25	DEADV3	DIESEL-ADV	HEAT	0.	0.	0.	0.	0.	0.	1631.	0.	RESIDUAL	1631.	111	0.	0.	0.	
26	DEADV2	DIESEL-ADV	POWR	0.	224.	1407.	357.	522.	153.	-420.	0.	1407.	RESIDUAL	1407.	1	0.14	0.37	0.
26	DEADV2	DIESEL-ADV	HEAT	0.	0.	0.	0.	0.	0.	1631.	0.	RESIDUAL	1631.	111	0.	0.	0.	
27	DEADV1	DIESEL-ADV	POWR	0.	224.	1407.	550.	522.	153.	-647.	0.	1407.	RESIDUAL	1407.	1	0.14	0.37	0.
27	DEADV1	DIESEL-ADV	HEAT	0.	0.	0.	0.	0.	0.	1631.	0.	RESIDUAL	1631.	111	0.	0.	0.	
28	DEHTPM	ADV-DIESEL	POWR	0.	330.	1301.	663.	522.	153.	-779.	0.	1301.	RESIDUAL	1301.	1	0.20	0.40	0.
28	DEHTPM	ADV-DIESEL	HEAT	0.	0.	0.	0.	0.	0.	1631.	0.	RESIDUAL	1631.	111	0.	0.	0.	
29	DESOA3	DIESEL-SOA	POWR	0.	185.	1446.	471.	522.	153.	-554.	0.	1446.	DISTILLA	1446.	1	0.11	0.36	0.
29	DESOA3	DIESEL-SOA	HEAT	0.	0.	0.	0.	0.	0.	1631.	0.	DISTILLA	1631.	111	0.	0.	0.	
29	DESOA3	DIESEL-SOA	POWR	0.	185.	1446.	471.	522.	153.	-554.	0.	1446.	RESIDUAL	1446.	1	0.11	0.36	0.
29	DESOA3	DIESEL-SOA	HEAT	0.	0.	0.	0.	0.	0.	1631.	0.	RESIDUAL	1631.	111	0.	0.	0.	

PRECEDING PAGE BLANK NOT FILLED

HONEYWELL PAGE PRINTING SYSTEM- P1185-02

DATE 06/06/79

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.1

PAGE 305

I&SE PEO ADV DESIGN ENGR

\*\*FUEL ENERGY SAVED BY PROCESS AND ECS\*\*

INDUSTRY 33343 MW 153.00 PROCESS MILLIONS BTU/HR 0. PROCESS TEMP(F) 0. PRODUCT ALUMINUM HOURS PER YEAR 8760.

UTILITY FUEL COAL POWER TO HEAT RATIO \*\*\*\*\* WASTE FUEL EQV BTU\*10\*\*6= 0. HOT WATER BTU\*10\*\*6= 0.

	WASTE FUEL USED 10**6 BTU/HR	FUEL SAVED= NO-NET 10**6 BTU/HR	COGEN FUEL USED 10**6 BTU/HR	COGEN PROCES HEAT 10**6 BTU/HR	COGEN PROCES POWER 10**6 BTU/HR	COGEN MW ELECT	AUX PROCES BOILR 10**6 BTU/HR	UTILIT FUEL USED 10**6 BTU/HR	TOTAL FUEL SITE 10**6 BTU/HR	SITE FUEL USED	NET= TOTAL+ UTILIT 10**6 BTU/HR	FAIL	FESR	POWER FACTR	HEAT FACTR
41 GTRW16 GT-85RE-16 POWR	0.	169.	1462.	512.	522.	153.	-603.	0.	1462.	DISTILLA	1462.	1	0.10	0.36	0.
41 GTRW16 GT-85RE-16 HEAT	0.	0.	0.	0.	0.	0.	0.	1631.	0.	DISTILLA	1631.	111	0.	0.	0.
42 GTR308 GT-60RE-08 POWR	0.	-53.	1684.	756.	522.	153.	-889.	0.	1684.	DISTILLA	1684.	1	-0.03	0.31	0.
42 GTR308 GT-60RE-08 HEAT	0.	0.	0.	0.	0.	0.	0.	1631.	0.	DISTILLA	1631.	111	0.	0.	0.
43 GTR312 GT-60RE-12 POWR	0.	105.	1526.	582.	522.	153.	-685.	0.	1526.	DISTILLA	1526.	1	0.06	0.34	0.
43 GTR312 GT-60RE-12 HEAT	0.	0.	0.	0.	0.	0.	0.	1631.	0.	DISTILLA	1631.	111	0.	0.	0.
44 GTR316 GT-60RE-16 POWR	0.	91.	1540.	592.	522.	153.	-696.	0.	1540.	DISTILLA	1540.	1	0.06	0.34	0.
44 GTR316 GT-60RE-16 HEAT	0.	0.	0.	0.	0.	0.	0.	1631.	0.	DISTILLA	1631.	111	0.	0.	0.
45 FCPADS FUEL-CL-PH POWR	0.	258.	1374.	234.	522.	153.	-275.	0.	1374.	DISTILLA	1374.	1	0.16	0.38	0.
45 FCPADS FUEL-CL-PH HEAT	0.	0.	0.	0.	0.	0.	0.	1631.	0.	DISTILLA	1631.	111	0.	0.	0.
46 FCMCDS FUEL-CL-MO POWR	0.	364.	1267.	295.	522.	153.	-347.	0.	1267.	DISTILLA	1267.	1	0.22	0.41	0.
46 FCMCDS FUEL-CL-MO HEAT	0.	0.	0.	0.	0.	0.	0.	1631.	0.	DISTILLA	1631.	111	0.	0.	0.

HONEYWELL PAGE PRINTING SYSTEM - P1185-02

HONEYWELL LOW SERVICE BLOW DOWN CONTROLLER

HONEYWELL LOW SERVICE BLOW DOWN CONTROLLER

**COAL-FIRED NOCOGENERATION PROCESS BOILER**

**5.2 - SUMMARY OF FUEL SAVED BY TYPE AND  
ECONOMICS**

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																				
ECS	PROCS	**COGENERATION CASE**			**NO COGEN - COGEN**			POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVEL CHRG	NORM WRTH ENRG		
		DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL													
OHOCGN	10101	0.	25.	126.	0.	0.	0.	F	10.	0.	0.63	0.25	0.	12.3	1.00	260.1	0	6.0	1.00	80
STM141	10101	0.	84.	1.	0.	-53.	125.		10.	10.	0.57	0.25	0.44	8.3	0.68	141.8	999	3.9	0.66	176
STM141	10101	0.	0.	84.	0.	24.	42.	F	10.	10.	1.08	0.25	0.44	16.2	1.32	275.2	28	4.3	0.71	160
STM141	10101	0.	0.	84.	0.	24.	42.	A	10.	10.	0.96	0.25	0.44	12.5	1.01	211.6	999	3.7	0.63	164
STM088	10101	0.	80.	20.	0.	-55.	105.		10.	8.	0.54	0.25	0.33	7.4	0.60	132.5	999	4.3	0.71	166
STM088	10101	0.	6.	94.	0.	18.	32.	F	10.	8.	1.02	0.25	0.33	14.9	1.22	266.6	31	4.6	0.78	150
STM088	10101	0.	6.	94.	0.	18.	32.	A	10.	8.	0.92	0.25	0.33	11.8	-0.96	209.8	999	4.2	0.70	154
PFBSTM	10101	0.	0.	65.	0.	25.	41.		10.	10.	1.59	0.25	0.44	20.8	1.69	351.2	10	5.3	0.88	169
PFBSTM	10101	0.	0.	106.	0.	37.	62.		10.	15.	1.45	0.25	0.48	19.9	1.62	304.3	17	4.4	0.74	160
TISTMT	10101	0.	122.	0.	0.	-97.	126.		10.	10.	1.27	0.25	0.19	29.6	2.41	499.5	0	8.0	1.34	143
TISTMT	10101	0.	77.	38.	0.	-52.	88.		10.	5.	1.01	0.25	0.23	20.5	1.67	381.1	0	6.6	1.10	136
TISTMT	10101	0.	0.	65.	0.	25.	41.		10.	10.	1.96	0.25	0.44	41.4	3.37	698.9	0	7.9	1.32	168
TISTMT	10101	0.	0.	126.	0.	49.	82.		10.	20.	2.15	0.25	0.51	57.1	4.65	800.9	0	8.6	1.44	160
TIHRSG	10101	0.	74.	63.	0.	-50.	62.		10.	2.	0.84	0.25	0.08	17.5	1.43	345.5	0	6.7	1.12	112
TIHRSG	10101	0.	4.	101.	0.	21.	25.		10.	8.	1.76	0.25	0.31	48.1	3.92	798.3	0	8.9	1.49	143
STIRL	10101	128.	0.	0.	-128.	25.	126.		10.	10.	0.77	0.25	0.15	11.1	0.91	173.1	-26	6.5	1.09	153
STIRL	10101	80.	9.	31.	-80.	15.	95.		10.	6.	0.70	0.25	0.20	9.3	0.76	160.7	999	5.7	0.95	149
STIRL	10101	0.	128.	0.	0.	-103.	126.		10.	10.	0.77	0.25	0.15	11.1	0.91	173.3	999	5.7	0.95	150
STIRL	10101	0.	89.	31.	0.	-65.	95.		10.	6.	0.70	0.25	0.20	9.3	0.76	160.8	999	5.2	0.96	147
STIRL	10101	0.	0.	102.	0.	25.	24.		10.	10.	1.44	0.25	0.32	21.9	1.78	340.5	9	5.5	0.92	155
STIRL	10101	0.	0.	179.	0.	57.	55.		10.	23.	1.43	0.25	0.38	28.1	2.29	323.2	9	5.0	0.83	137
HEGT85	10101	0.	0.	123.	0.	25.	2.	A	10.	10.	1.69	0.25	0.18	35.4	2.88	500.5	0	7.6	1.27	137
HEGT85	10101	0.	0.	531.	0.	150.	14.	A	10.	61.	3.34	0.25	0.24	91.7	7.46	482.4	0	12.8	2.14	113
HEGT60	10101	0.	0.	122.	0.	25.	4.	A	10.	10.	1.66	0.25	0.19	34.0	2.76	484.4	0	7.4	1.24	139
HEGT60	10101	0.	0.	278.	0.	74.	12.	A	10.	30.	2.12	0.25	0.24	55.1	4.49	476.1	0	9.1	1.52	120
HEGT00	10101	0.	0.	122.	0.	25.	3.	A	10.	10.	1.56	0.25	0.19	31.2	2.54	444.5	0	7.0	1.17	138
HEGT00	10101	0.	0.	154.	0.	34.	5.	A	10.	14.	1.41	0.25	0.20	33.4	2.72	419.9	0	6.9	1.15	126
FCMCCL	10101	0.	0.	211.	0.	25.	-85.		10.	10.	1.72	0.25	-0.40	29.8	2.43	483.1	0	8.6	1.45	71
FCMCCL	10101	0.	0.	289.	0.	63.	-34.		10.	26.	2.09	0.25	0.09	40.3	3.28	476.4	0	8.5	1.43	107
FCSTCL	10101	0.	0.	208.	0.	25.	-83.		10.	10.	1.73	0.25	-0.39	29.0	2.36	474.6	0	8.5	1.42	73
FCSTCL	10101	0.	0.	359.	0.	102.	28.		10.	42.	2.65	0.25	0.27	50.3	4.09	478.2	0	8.4	1.41	113
IGGTST	10101	0.	0.	220.	0.	25.	-94.		10.	10.	1.61	0.25	-0.47	28.9	2.35	448.2	0	8.5	1.43	64
IGGTST	10101	0.	0.	335.	0.	72.	-49.		10.	29.	1.64	0.25	0.06	40.4	3.29	412.3	0	8.2	1.37	99
GTSOAR	10101	0.	118.	0.	0.	-93.	126.		10.	10.	0.71	0.25	0.22	10.6	0.86	166.2	999	5.3	0.88	158
GTSOAR	10101	0.	91.	24.	0.	-66.	102.		10.	7.	0.67	0.25	0.24	9.6	0.78	162.0	999	5.0	0.84	151
GTAC08	10101	0.	126.	0.	0.	-102.	126.		10.	10.	0.68	0.25	0.16	9.6	0.78	155.0	999	5.4	0.90	154
GTAC08	10101	0.	83.	35.	0.	-58.	90.		10.	6.	0.63	0.25	0.21	8.3	0.68	149.7	999	4.9	0.83	150
GTAC12	10101	0.	112.	0.	0.	-87.	126.		10.	10.	0.68	0.25	0.25	9.8	0.80	157.8	999	5.0	0.83	164
GTAC12	10101	0.	86.	24.	0.	-62.	102.		10.	7.	0.65	0.25	0.27	8.8	0.72	153.2	999	4.8	0.80	155
GTAC16	10101	0.	106.	0.	0.	-81.	126.		10.	10.	0.69	0.25	0.30	10.1	0.32	162.8	999	4.8	0.81	167
GTAC16	10101	0.	89.	17.	0.	-64.	109.		10.	8.	0.66	0.25	0.30	9.4	0.76	159.0	999	4.7	0.79	158
GTWC16	10101	0.	108.	0.	0.	-84.	126.		10.	10.	0.70	0.25	0.28	10.4	0.85	162.9	999	5.0	0.83	165
GTWC16	10101	0.	95.	13.	0.	-71.	113.		10.	8.	0.68	0.25	0.28	9.9	0.80	161.1	999	4.9	0.82	155

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																			
**COGENERATION CASE** **NO COGEN - COGEN**																			
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVEL CHRG	NORM ENRG	WRTH
CC1626	10101	0.	100.	0.	0.	-76.	126.	10.	10.	0.80	0.25	0.33	10.7	0.87	166.8	999	4.9	0.82	171
CC1626	10101	0.	124.	0.	0.	-89.	159.	10.	14.	0.86	0.25	0.36	12.1	0.98	170.9	999	5.0	0.84	160
CC1622	10101	0.	98.	0.	0.	-74.	126.	10.	10.	0.79	0.25	0.35	10.4	0.84	164.0	999	4.8	0.80	173
CC1622	10101	0.	113.	0.	0.	-82.	148.	10.	13.	0.83	0.25	0.37	11.3	0.92	167.9	999	4.8	0.81	162
CC1222	10101	0.	98.	0.	0.	-73.	126.	10.	10.	0.78	0.25	0.35	10.1	0.82	160.2	999	4.7	0.79	174
CC1222	10101	0.	112.	0.	0.	-81.	148.	10.	13.	0.82	0.25	0.37	11.0	0.90	163.3	999	4.8	0.80	163
CC0822	10101	0.	94.	0.	0.	-69.	126.	10.	10.	0.78	0.25	0.37	10.2	0.83	164.9	999	4.6	0.77	176
CC0822	10101	0.	95.	0.	0.	-70.	127.	10.	10.	0.79	0.25	0.38	10.3	0.84	165.1	999	4.6	0.77	165
STIG15	10101	0.	132.	0.	0.	-107.	126.	10.	10.	0.81	0.25	0.12	10.7	0.87	146.1	999	5.8	0.97	148
STIG15	10101	0.	2846.	0.	0.	-2067.	2653.	10.	318.	5.91	0.25	0.17	97.7	7.95	112.4	0	42.2	7.06	220
STIG10	10101	0.	124.	0.	0.	-99.	126.	10.	10.	0.77	0.25	0.18	10.2	0.83	144.5	999	5.4	0.91	155
STIG10	10101	0.	279.	0.	0.	-207.	285.	10.	29.	1.09	0.25	0.22	16.0	1.30	137.8	0	7.3	1.23	132
STIG15	10101	0.	120.	0.	0.	-96.	126.	10.	10.	0.76	0.25	0.20	10.0	0.82	144.0	999	5.3	0.89	158
STIG15	10101	0.	176.	0.	0.	-133.	185.	10.	17.	0.89	0.25	0.23	12.2	1.00	142.6	0	6.0	1.00	145
DEADV3	10101	0.	110.	0.	0.	-86.	126.	10.	10.	0.82	0.25	0.27	13.3	1.08	198.5	46	5.4	0.91	159
DEADV3	10101	0.	159.	0.	0.	-117.	185.	10.	17.	0.94	0.25	0.30	16.6	1.36	205.4	5	6.0	1.00	146
DEHTPM	10101	0.	97.	0.	0.	-73.	126.	10.	10.	0.84	0.25	0.35	13.0	1.06	212.9	101	5.1	0.85	169
DEHTPM	10101	0.	88.	10.	0.	-64.	116.	10.	9.	0.82	0.25	0.34	12.5	1.02	210.6	999	5.0	0.84	158
DES0A3	10101	116.	0.	0.	-116.	25.	126.	10.	10.	0.84	0.25	0.23	13.9	1.13	203.3	0	6.4	1.08	157
DES0A3	10101	186.	0.	0.	-186.	48.	205.	10.	20.	1.08	0.25	0.27	21.3	1.74	239.9	0	8.2	1.37	144
DES0A3	10101	0.	116.	0.	0.	-91.	126.	10.	10.	0.84	0.25	0.23	13.9	1.13	203.3	18	5.7	0.95	154
DES0A3	10101	0.	186.	0.	0.	-138.	205.	10.	20.	1.08	0.25	0.27	21.3	1.74	239.9	0	7.0	1.17	139
GTS0AD	10101	117.	0.	0.	-117.	25.	126.	10.	10.	0.67	0.25	0.22	9.3	0.76	149.0	0	5.8	0.98	164
GTS0AD	10101	79.	8.	27.	-79.	17.	99.	10.	7.	0.64	0.25	0.24	8.4	0.69	146.2	999	5.3	0.89	156
GTRA03	10101	98.	0.	0.	-98.	25.	126.	10.	10.	0.72	0.25	0.34	11.0	0.90	173.8	999	5.4	0.90	174
GTRA08	10101	102.	0.	0.	-102.	26.	131.	10.	11.	0.73	0.25	0.35	11.3	0.92	174.9	999	5.4	0.91	163
GTRA12	10101	98.	0.	0.	-98.	25.	126.	10.	10.	0.72	0.25	0.35	11.0	0.89	174.1	999	5.4	0.90	174
GTRA12	10101	101.	0.	0.	-101.	26.	130.	10.	11.	0.72	0.25	0.36	11.2	0.91	175.1	999	5.4	0.90	164
GTRA16	10101	98.	0.	0.	-98.	25.	126.	10.	10.	0.72	0.25	0.35	11.3	0.92	180.0	999	5.4	0.91	173
GTRA16	10101	97.	0.	1.	-97.	24.	125.	10.	10.	0.72	0.25	0.35	11.2	0.92	179.8	999	5.4	0.91	163
GTR208	10101	107.	0.	0.	-107.	25.	126.	10.	10.	0.70	0.25	0.29	10.4	0.85	165.5	999	5.6	0.94	169
GTR208	10101	89.	4.	14.	-89.	20.	112.	10.	8.	0.68	0.25	0.29	9.8	0.80	163.0	999	5.4	0.90	159
GTR212	10101	103.	0.	0.	-103.	25.	126.	10.	10.	0.71	0.25	0.31	10.7	0.87	169.3	999	5.5	0.93	171
GTR212	10101	92.	3.	9.	-92.	22.	117.	10.	9.	0.69	0.25	0.31	10.3	0.84	167.5	999	5.4	0.91	160
GTR216	10101	101.	0.	0.	-101.	25.	126.	10.	10.	0.71	0.25	0.33	10.9	0.89	173.6	999	5.5	0.92	172
GTR216	10101	92.	2.	7.	-92.	22.	118.	10.	9.	0.70	0.25	0.32	10.6	0.86	171.9	999	5.4	0.90	151
GTRW08	10101	107.	0.	0.	-107.	25.	126.	10.	10.	0.72	0.25	0.29	11.1	0.90	168.8	999	5.7	0.96	168
GTRW08	10101	125.	0.	0.	-125.	32.	149.	10.	13.	0.76	0.25	0.31	12.2	0.99	170.9	-6	6.0	1.00	157
GTRW12	10101	104.	0.	0.	-104.	25.	126.	10.	10.	0.72	0.25	0.31	11.1	0.90	170.7	999	5.6	0.94	169
GTRW12	10101	124.	0.	0.	-124.	32.	152.	10.	13.	0.77	0.25	0.33	12.3	1.00	173.4	999	5.9	0.99	159
GTRW16	10101	104.	0.	0.	-104.	25.	126.	10.	10.	0.73	0.25	0.31	11.4	0.93	175.3	999	5.6	0.94	169
GTRW16	10101	118.	0.	0.	-118.	30.	145.	10.	12.	0.76	0.25	0.33	12.3	1.00	177.8	999	5.8	0.98	159
GTR308	10101	110.	0.	0.	-110.	25.	126.	10.	10.	0.71	0.25	0.27	10.6	0.86	159.1	999	5.8	0.96	166
GTR308	10101	108.	1.	2.	-108.	24.	124.	10.	10.	0.71	0.25	0.27	10.5	0.85	159.0	999	5.7	0.96	156

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----

\*\*COGENERATION CASE\*\* \*\*NOCOGEN - COGEN\*\*

ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVEL CHRG	NORM ENRG	WRTH
GTR312	10101	103.	0.	0.	-103.	25.	126.	10.	10.	0.71	0.25	0.31	10.7	0.87	164.8	999	5.5	0.93	171
GTR312	10101	109.	0.	0.	-109.	27.	133.	10.	11.	0.72	0.25	0.32	11.0	0.89	165.6	999	5.6	0.94	161
GTR316	10101	104.	0.	0.	-104.	25.	126.	10.	10.	0.72	0.25	0.31	11.0	0.89	169.4	999	5.6	0.93	170
GTR316	10101	108.	0.	0.	-108.	26.	132.	10.	11.	0.73	0.25	0.32	11.3	0.92	170.2	999	5.6	0.94	160
FCPADS	10101	115.	0.	0.	-115.	25.	126.	10.	10.	1.53	0.25	0.23	11.7	0.95	171.3	-60	6.9	1.15	164
FCPADS	10101	218.	0.	0.	-218.	59.	243.	10.	24.	3.02	0.25	0.28	19.6	1.60	199.7	0	10.2	1.71	152
FCMCDS	10101	104.	0.	0.	-104.	25.	126.	10.	10.	1.47	0.25	0.31	12.1	0.99	186.9	-62	6.4	1.08	171
FCMCDS	10101	159.	0.	0.	-159.	47.	201.	10.	19.	2.37	0.25	0.36	17.4	1.42	214.9*	0	8.2	1.37	160

ORIGINAL PAGE IS  
OF POOR QUALITY

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																		
**COGENERATION CASE** **NOCOGEN - COGEN**																		
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD	COGEN POWER	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EOVL	ROI (%)	LEVL CHRG	NORM WRTH ENRG
ONOCGN	10102	0.	74.	729.	0.	0.	0.	F 30.	0.	1.52	0.25	0.	25.2	1.00	178.4	0	21.6	1.00 80
STM141	10102	0.	602.	3.	0.	-529.	726.	30.	30.	0.98	0.25	0.25	19.0	0.75	107.7	999	20.6	0.95 156
STM141	10102	0.	1.	604.	0.	73.	124.	F 30.	30.	2.01	0.25	0.25	34.5	1.37	195.9	36	16.0	0.74 136
STM141	10102	0.	1.	604.	0.	73.	124.	A 30.	30.	1.95	0.25	0.25	29.8	1.18	169.1	69	15.4	0.71 139
STM088	10102	0.	591.	61.	0.	-518.	667.	30.	23.	0.93	0.25	0.19	17.2	0.68	102.2	-6	21.8	1.01 152
STM088	10102	0.	18.	634.	0.	55.	94.	F 30.	23.	1.89	0.25	0.19	32.1	1.27	191.5	37	17.3	0.80 131
STM088	10102	0.	18.	634.	0.	55.	94.	A 30.	23.	1.75	0.25	0.19	23.4	0.93	139.2	999	16.3	0.75 138
PFBSTM	10102	0.	0.	606.	0.	74.	123.	30.	30.	3.12	0.25	0.25	42.4	1.68	239.1	17	17.9	0.83 144
PFBSTM	10102	0.	0.	369.	0.	111.	186.	30.	45.	3.13	0.25	0.31	41.0	1.63	209.0	24	16.0	0.74 138
TISTMT	10102	0.	606.	0.	0.	-532.	729.	30.	30.	2.40	0.25	0.24	65.9	2.61	371.3	0	27.2	1.26 147
TISTMT	10102	0.	728.	0.	0.	-581.	972.	30.	60.	3.11	0.25	0.35	101.7	4.03	477.0	0	29.8	1.38 140
TISTMT	10102	0.	0.	606.	0.	74.	123.	30.	30.	3.78	0.25	0.24	91.4	3.63	515.1	2	23.9	1.10 138
TISTMT	10102	0.	0.	728.	0.	146.	244.	30.	60.	4.45	0.25	0.35	128.5	5.09	602.4	2	25.2	1.16 132
TIHRSG	10102	0.	627.	38.	0.	-553.	691.	30.	25.	2.52	0.25	0.17	84.9	3.37	470.5	0	30.8	1.42 127
TIHRSG	10102	0.	11.	654.	0.	62.	75.	30.	25.	3.72	0.25	0.17	108.6	4.31	601.8	0	27.3	1.26 120
STIRL	10102	657.	0.	0.	-657.	74.	729.	30.	30.	1.43	0.25	0.18	28.9	1.14	149.8	0	27.9	1.29 157
STIRL	10102	887.	0.	0.	-887.	170.	1051.	30.	69.	1.71	0.25	0.27	46.9	1.86	180.6	0	31.0	1.43 142
STIRL	10102	0.	657.	0.	0.	-584.	729.	30.	30.	1.43	0.25	0.18	28.9	1.15	149.9	0	23.6	1.09 152
STIRL	10102	0.	887.	0.	0.	-717.	1051.	30.	69.	1.71	0.25	0.27	47.0	1.86	180.8	0	25.2	1.17 135
STIRL	10102	0.	0.	657.	0.	74.	71.	30.	30.	2.85	0.25	0.18	54.2	2.15	281.6	10	19.7	0.91 133
STIRL	10102	0.	0.	887.	0.	170.	165.	30.	69.	3.40	0.25	0.27	82.1	3.26	315.9	7	19.8	0.91 119
HEGT85	10102	0.	0.	722.	0.	74.	7.	A 30.	30.	3.34	0.25	0.10	75.4	2.99	356.6	1	23.7	1.10 122
HEGT85	10102	0.	0.	1941.	0.	448.	41.	A 30.	183.	7.47	0.25	0.20	199.4	7.91	350.7	0	33.6	1.55 94
HEGT60	10102	0.	0.	716.	0.	74.	12.	A 30.	30.	3.27	0.25	0.11	72.4	2.87	344.8	2	23.2	1.07 123
HEGT60	10102	0.	0.	1183.	0.	220.	37.	A 30.	90.	4.65	0.25	0.18	119.5	4.74	344.8	0	26.5	1.23 105
HEGT00	10102	0.	0.	719.	0.	74.	10.	A 30.	30.	3.13	0.25	0.10	67.1	2.66	318.9	3	22.5	1.04 124
HEGT00	10102	0.	0.	812.	0.	103.	14.	A 30.	42.	3.05	0.25	0.13	72.5	2.87	304.6	3	22.4	1.04 113
FCMCCL	10102	0.	0.	631.	0.	74.	98.	30.	30.	3.52	0.25	0.21	64.3	2.55	348.0	5	21.3	0.98 136
FCMCCL	10102	0.	0.	864.	0.	189.	250.	30.	77.	4.87	0.25	0.34	88.8	3.52	351.1	6	20.6	0.95 125
FCSTCL	10102	0.	0.	624.	0.	74.	104.	30.	30.	3.43	0.25	0.22	62.3	2.47	340.6	6	20.9	0.96 138
FCSTCL	10102	0.	0.	1074.	0.	307.	435.	30.	125.	6.12	0.25	0.41	111.0	4.40	352.8	7	19.0	0.88 117
IGGTST	10102	0.	0.	659.	0.	74.	70.	30.	30.	2.85	0.25	0.18	60.0	2.38	310.6	7	20.6	0.95 133
IGGTST	10102	0.	0.	1001.	0.	216.	205.	30.	88.	3.06	0.25	0.30	87.3	3.46	297.5	8	18.9	0.87 115
GTSOAR	10102	0.	652.	0.	0.	-578.	729.	30.	30.	1.21	0.25	0.19	22.9	0.91	119.8	-23	22.6	1.04 157
GTSOAR	10102	0.	926.	0.	0.	-733.	1129.	30.	79.	1.30	0.25	0.30	33.8	1.34	124.6	0	22.8	1.06 140
GTAC08	10102	0.	633.	0.	0.	-560.	729.	30.	30.	1.76	0.25	0.21	21.0	0.83	113.2	-7	21.8	1.01 161
GTAC08	10102	0.	801.	0.	0.	-646.	1003.	30.	63.	1.07	0.25	0.31	25.3	1.00	107.9	999	20.9	0.97 150
GTAC12	10102	0.	633.	0.	0.	-560.	729.	30.	30.	1.18	0.25	0.21	21.7	0.86	116.8	-9	21.9	1.01 161
GTAC12	10102	0.	876.	0.	0.	-684.	1125.	30.	78.	1.20	0.25	0.33	30.1	1.19	117.4	15	21.0	0.97 145
GTAC16	10102	0.	635.	0.	0.	-561.	729.	30.	30.	1.23	0.25	0.21	23.8	0.94	128.0	-21	22.2	1.03 158
GTAC16	10102	0.	929.	0.	0.	-714.	1205.	30.	88.	1.31	0.25	0.35	34.2	1.36	125.8	8	21.3	0.98 141
GTWC16	10102	0.	653.	0.	0.	-579.	729.	30.	30.	1.23	0.25	0.19	23.7	0.94	123.6	-32	22.7	1.05 156
GTWC16	10102	0.	1015.	0.	0.	-785.	1252.	30.	94.	1.30	0.25	0.31	33.0	1.31	111.1	0	22.6	1.04 138

DATE 06/07/77  
I&SE-PEG-ADV-DES-ENGR

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																			
**COGENERATION CASE** **NOCOGEN - COGEN**																			
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER RECD	COGEN POWER	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM WRTH ENRG	
CC1626	10102	0.	653.	0.	0.	-579.	729.	30.	30.	1.43	0.25	0.19	27.1	1.08	141.9	0	23.4	1.08	154
CC1626	10102	0.	1373.	0.	0.	-989.	1767.	30.	157.	1.89	0.25	0.36	48.3	1.91	120.0	0	23.7	1.09	124
CC1622	10102	0.	646.	0.	0.	-572.	729.	30.	30.	1.42	0.25	0.19	27.1	1.07	143.2	0	23.1	1.07	154
CC1622	10102	0.	1251.	0.	0.	-905.	1640.	30.	141.	1.86	0.25	0.37	49.1	1.95	133.9	0	23.1	1.07	126
CC1222	10102	0.	644.	0.	0.	-571.	729.	30.	30.	1.41	0.25	0.20	26.5	1.05	140.1	0	23.0	1.06	155
CC1222	10102	0.	1242.	0.	0.	-897.	1636.	30.	141.	1.82	0.25	0.37	46.3	1.84	127.3	0	22.5	1.04	127
CC0822	10102	0.	633.	0.	0.	-360.	729.	30.	30.	1.40	0.25	0.21	26.2	1.04	141.0	0	22.7	1.05	157
CC0822	10102	0.	1049.	0.	0.	-773.	1407.	30.	113.	1.53	0.25	0.38	36.3	1.44	117.9	11	20.7	0.96	137
STIG15	10102	0.	747.	0.	0.	-673.	729.	30.	30.	1.59	0.25	0.07	27.5	1.09	125.8	0	26.2	1.21	142
STIG15	10102	0.	31538.	0.	0.	-22902.	29396.	30.	3522.	51.42	0.25	0.17	861.5	34.16	93.2	0	415.1	19.18	517
STIG10	10102	0.	723.	0.	0.	-649.	729.	30.	30.	1.49	0.25	0.10	26.5	1.05	125.0	0	25.3	1.17	145
STIG10	10102	0.	3094.	0.	0.	-2296.	3156.	30.	326.	4.83	0.25	0.22	94.6	3.75	104.3	0	50.2	2.32	116
STIG1S	10102	0.	712.	0.	0.	-638.	729.	30.	30.	1.48	0.25	0.11	26.0	1.03	124.5	0	24.9	1.15	147
STIG1S	10102	0.	1945.	0.	0.	-1476.	2051.	30.	191.	3.08	0.25	0.23	55.2	2.19	96.9	0	35.8	1.65	114
DEADV3	10102	0.	683.	0.	0.	-609.	729.	30.	30.	1.60	0.25	0.15	35.9	1.42	179.3	0	25.3	1.17	144
DEADV3	10102	0.	1760.	0.	0.	-1291.	2054.	30.	191.	3.82	0.25	0.30	125.1	4.96	242.5	0	38.4	1.78	115
DEHTPM	10102	0.	626.	0.	0.	-552.	729.	30.	30.	1.57	0.25	0.22	32.8	1.30	178.7	0	23.2	1.07	153
DEHTPM	10102	0.	947.	0.	0.	-708.	1280.	30.	97.	2.38	0.25	0.38	69.4	2.75	250.3	0	24.8	1.15	133
DES0A3	10102	700.	0.	0.	-700.	74.	729.	30.	30.	1.73	0.25	0.13	40.8	1.62	199.0	0	31.0	1.43	146
DES0A3	10102	2061.	0.	0.	-2061.	535.	2273.	30.	218.	5.14	0.25	0.27	176.2	6.99	291.8	0	62.5	2.89	133
DES0A3	10102	0.	700.	0.	0.	-626.	729.	30.	30.	1.73	0.25	0.13	40.8	1.62	199.0	0	26.4	1.22	140
DES0A3	10102	0.	2061.	0.	0.	-1526.	2273.	30.	218.	5.14	0.25	0.27	176.2	6.99	291.8	0	49.0	2.26	117
GTS0AD	10102	640.	0.	0.	-640.	74.	729.	30.	30.	1.15	0.25	0.20	20.4	0.81	108.7	-47	26.1	1.21	166
GTS0AD	10102	875.	0.	0.	-875.	184.	1097.	30.	75.	1.10	0.25	0.32	26.3	1.04	102.5	0	26.8	1.24	154
GTRA08	10102	647.	0.	0.	-647.	74.	729.	30.	30.	1.34	0.25	0.19	28.0	1.11	147.8	0	27.4	1.27	158
GTRA08	10102	1134.	0.	0.	-1134.	291.	1457.	30.	119.	1.62	0.25	0.35	45.0	1.78	135.4	0	30.4	1.41	139
GTRA12	10102	645.	0.	0.	-645.	74.	729.	30.	30.	1.35	0.25	0.20	28.3	1.12	149.6	0	27.3	1.26	158
GTRA12	10102	1115.	0.	0.	-1115.	287.	1443.	30.	117.	1.63	0.25	0.36	45.7	1.81	139.9	0	30.2	1.39	139
GTRA16	10102	644.	0.	0.	-644.	74.	729.	30.	30.	1.29	0.25	0.20	26.1	1.03	138.2	0	27.0	1.25	160
GTRA16	10102	1075.	0.	0.	-1075.	270.	1385.	30.	110.	1.64	0.25	0.35	46.1	1.83	146.4	0	30.1	1.39	140
GTR208	10102	645.	0.	0.	-645.	74.	729.	30.	30.	1.24	0.25	0.20	24.0	0.95	127.0	135	26.8	1.24	162
GTR208	10102	982.	0.	0.	-982.	226.	1238.	30.	92.	1.39	0.25	0.33	36.8	1.46	127.7	0	28.8	1.33	145
GTR212	10102	646.	0.	0.	-646.	74.	729.	30.	30.	1.26	0.25	0.19	24.6	0.97	129.8	193	26.9	1.24	161
GTR212	10102	1022.	0.	0.	-1022.	242.	1294.	30.	99.	1.46	0.25	0.33	39.5	1.57	131.9	0	29.4	1.36	143
GTR216	10102	643.	0.	0.	-643.	74.	729.	30.	30.	1.27	0.25	0.20	25.3	1.00	134.0	999	26.9	1.24	161
GTR216	10102	1024.	0.	0.	-1024.	248.	1313.	30.	101.	1.53	0.25	0.34	42.2	1.67	140.6	0	29.4	1.36	142
GTRW08	10102	672.	0.	0.	-672.	74.	729.	30.	30.	1.35	0.25	0.16	27.9	1.11	141.8	0	28.3	1.31	155
GTRW08	10102	1385.	0.	0.	-1385.	349.	1652.	30.	142.	1.70	0.25	0.31	47.1	1.87	116.0	0	35.3	1.63	133
GTRW12	10102	665.	0.	0.	-665.	74.	729.	30.	30.	1.34	0.25	0.17	27.9	1.11	143.5	0	28.0	1.29	156
GTRW12	10102	1370.	0.	0.	-1370.	359.	1683.	30.	146.	1.72	0.25	0.33	47.7	1.89	118.6	0	34.2	1.58	134
GTRW16	10102	663.	0.	0.	-663.	74.	729.	30.	30.	1.36	0.25	0.17	28.5	1.13	146.5	0	28.0	1.30	156
GTRW16	10102	1306.	0.	0.	-1306.	335.	1604.	30.	137.	1.70	0.25	0.33	47.5	1.88	124.0	0	33.6	1.55	134
GTR308	10102	679.	0.	0.	-679.	74.	729.	30.	30.	1.25	0.25	0.15	24.0	0.95	120.8	166	28.0	1.29	158
GTR308	10102	1193.	0.	0.	-1193.	266.	1372.	30.	108.	1.42	0.25	0.27	36.9	1.46	105.6	0	33.4	1.54	139

HONEYWELL PAGE PRINTING SYSTEM - FILE-02



GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----

\*\*COGENERATION CASE\*\* \*\*NO COGEN - COGEN\*\*

ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM ENRG	WRTH
GTR312	10102	662.	0.	0.	-662.	74.	729.	30.	30.	1.32	0.25	0.17	27.0	1.07	139.4	0	27.8	1.28	157
GTR312	10102	1205.	0.	0.	-1205.	296.	1474.	30.	121.	1.53	0.25	0.32	41.1	1.63	116.4	0	32.1	1.48	138
GTR316	10102	663.	0.	0.	-663.	74.	729.	30.	30.	1.34	0.25	0.17	27.7	1.10	142.5	0	27.9	1.29	157
GTR316	10102	1198.	0.	0.	-1198.	292.	1459.	30.	119.	1.56	0.25	0.32	42.3	1.68	120.5	0	32.3	1.49	138
FCPADS	10102	698.	0.	0.	-698.	74.	729.	30.	30.	4.02	0.25	0.13	34.1	1.35	166.8	0	32.5	1.50	152
FCPADS	10102	2412.	0.	0.	-2412.	659.	2688.	30.	269.	28.02	0.25	0.28	154.0	6.11	217.9	0	86.2	3.99	161
FCMCDS	10102	663.	0.	0.	-663.	74.	729.	30.	30.	3.84	0.25	0.17	35.3	1.40	181.9	0	31.2	1.44	155
FCMCDS	10102	1760.	0.	0.	-1760.	521.	2227.	30.	212.	21.00	0.25	0.36	132.4	5.25	256.7	0	64.0	2.96	150

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																			
**COGENERATION CASE** **NOCOGEN - COGEN**																			
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD	COGEN POWER	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVEL CHRGR	NORM ENRG	WRTH
ONCGN	20111	0.	33.	16.	0.	0.	0.	2.	0.	0.19	0.28	0.	1.6	1.00	139.2	0	0.7	1.00	80
STM141	20111	0.	36.	0.	0.	-3.	16.	2.	2.	0.36	0.28	0.26	3.2	2.02	299.4	0	1.0	1.34	155
STM141	20111	0.	37.	0.	0.	-3.	17.	2.	2.	0.29	0.28	0.28	3.0	1.93	280.5	0	0.9	1.23	145
STM141	20111	0.	0.	36.	0.	33.	-20.	F	2.	0.57	0.28	0.26	5.6	3.59	532.0	0	1.3	1.84	159
STM141	20111	0.	0.	37.	0.	33.	-19.	F	2.	0.46	0.28	0.28	5.2	3.30	480.0	0	1.2	1.61	145
STM141	20111	0.	0.	36.	0.	33.	-20.	A	2.	0.51	0.28	0.26	5.1	3.27	484.9	0	1.2	1.68	156
STM141	20111	0.	0.	37.	0.	33.	-19.	A	2.	0.40	0.28	0.23	4.6	2.94	427.7	0	1.0	1.44	143
STM088	20111	0.	36.	2.	0.	-3.	14.	2.	2.	0.28	0.28	0.23	2.6	1.65	252.9	0	0.8	1.17	140
STM088	20111	0.	1.	37.	0.	32.	-21.	F	2.	0.44	0.28	0.23	4.7	3.01	459.7	0	1.1	1.55	139
STM088	20111	0.	1.	37.	0.	32.	-21.	A	2.	0.38	0.28	0.23	4.3	2.75	420.4	0	1.0	1.41	137
PFBSTM	20111	0.	0.	36.	0.	33.	-20.	2.	2.	0.61	0.28	0.26	7.1	4.51	667.4	0	1.5	2.11	163
PFBSTM	20111	0.	0.	41.	0.	36.	-16.	2.	3.	0.47	0.28	0.33	6.8	4.36	571.9	0	1.3	1.84	152
TISTMT	20111	0.	36.	0.	0.	-3.	16.	2.	2.	0.53	0.28	0.26	8.7	5.54	818.2	0	1.7	2.39	167
TISTMT	20111	0.	44.	0.	0.	-7.	32.	2.	4.	0.56	0.28	0.37	13.0	8.32	999.8	0	2.2	3.03	177
TISTMT	20111	0.	0.	36.	0.	33.	-20.	2.	2.	0.79	0.28	0.26	12.2	7.80	1151.3	0	2.3	3.12	183
TISTMT	20111	0.	0.	44.	0.	38.	-12.	2.	4.	0.77	0.28	0.37	16.5	10.57	1270.2	0	2.7	3.65	191
TIHRSG	20111	0.	37.	4.	0.	-4.	12.	2.	1.	0.40	0.28	0.17	10.2	6.54	987.4	0	1.8	2.46	145
TIHRSG	20111	0.	1.	39.	0.	32.	-23.	2.	1.	0.57	0.28	0.17	13.2	8.44	1275.0	0	2.2	3.02	157
STIRL	20111	38.	0.	0.	-38.	33.	16.	2.	2.	0.34	0.28	0.21	2.7	1.71	236.9	0	1.0	1.34	153
STIRL	20111	53.	0.	0.	-53.	40.	39.	2.	5.	0.28	0.28	0.32	3.3	2.09	210.4	0	1.0	1.35	143
STIRL	20111	0.	38.	0.	0.	-5.	16.	2.	2.	0.34	0.28	0.21	2.7	1.71	237.1	0	0.9	1.25	151
STIRL	20111	0.	53.	0.	0.	-13.	39.	2.	5.	0.28	0.28	0.32	3.3	2.09	210.7	0	0.9	1.23	140
STIRL	20111	0.	0.	38.	0.	33.	-23.	2.	2.	0.57	0.28	0.21	5.7	3.66	508.2	0	1.3	1.85	153
STIRL	20111	0.	0.	53.	0.	40.	-14.	2.	5.	0.45	0.28	0.32	5.8	3.74	376.6	0	1.2	1.61	140
HEGT85	20111	0.	0.	40.	0.	33.	-24.	A	2.	0.62	0.28	0.19	10.8	6.91	929.3	0	2.0	2.71	164
HEGT85	20111	0.	0.	64.	0.	43.	-15.	A	2.	0.65	0.28	0.31	17.8	11.37	950.8	0	2.7	3.66	174
HEGT60	20111	0.	0.	42.	0.	33.	-26.	A	2.	0.62	0.28	0.13	10.6	6.79	856.3	0	2.0	2.69	157
HEGT60	20111	0.	0.	63.	0.	40.	-24.	A	2.	0.59	0.28	0.20	15.2	9.70	820.3	0	2.4	3.26	157
HEGT00	20111	0.	0.	43.	0.	33.	-27.	A	2.	0.55	0.28	0.12	9.5	6.08	757.3	0	1.8	2.43	150
HEGT00	20111	0.	0.	46.	0.	34.	-27.	A	2.	0.42	0.28	0.14	9.6	6.13	707.5	0	1.6	2.26	137
FCMCCL	20111	0.	0.	38.	0.	33.	-22.	2.	2.	0.61	0.28	0.23	9.3	5.94	839.5	0	1.8	2.49	165
FCMCCL	20111	0.	0.	50.	0.	39.	-14.	2.	4.	0.54	0.28	0.34	11.7	7.50	793.8	0	1.9	2.66	162
FCSTCL	20111	0.	0.	37.	0.	33.	-21.	2.	2.	0.67	0.28	0.24	9.1	5.78	827.3	0	1.8	2.52	167
FCSTCL	20111	0.	0.	66.	0.	48.	-0.	2.	8.	0.73	0.28	0.42	15.2	9.70	790.3	0	2.4	3.32	173
IGGTST	20111	0.	0.	39.	0.	33.	-24.	2.	2.	0.73	0.28	0.19	9.5	6.07	822.4	0	2.0	2.69	166
IGGTST	20111	0.	0.	61.	0.	42.	-14.	2.	6.	0.71	0.28	0.31	13.2	8.45	738.0	0	2.3	3.11	164
GTSGAR	20111	0.	39.	0.	0.	-6.	16.	2.	2.	0.33	0.28	0.21	3.3	2.14	294.2	0	1.0	1.35	148
GTSGAR	20111	0.	53.	0.	0.	-14.	37.	2.	4.	0.26	0.28	0.31	4.0	2.56	259.4	0	1.0	1.33	137
GTAC08	20111	0.	38.	0.	0.	-5.	16.	2.	2.	0.32	0.28	0.22	2.9	1.88	264.4	0	0.9	1.26	150
GTAC08	20111	0.	47.	0.	0.	-10.	31.	2.	4.	0.23	0.28	0.31	3.1	2.01	227.1	0	0.8	1.15	141
GTAC12	20111	0.	38.	0.	0.	-5.	16.	2.	2.	0.32	0.28	0.23	3.0	1.89	266.6	0	0.9	1.26	150
GTAC12	20111	0.	51.	0.	0.	-11.	37.	2.	5.	0.25	0.28	0.34	3.5	2.21	232.0	0	0.9	1.20	141
GTAC16	20111	0.	38.	0.	0.	-5.	16.	2.	2.	0.32	0.28	0.23	3.0	1.95	274.5	0	0.9	1.28	150

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																					
ECS	PROCS	**COGENERATION CASE**				**NOCOGEN - COGEN**				POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM ENRG	WRTH
		DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL														
GTAC16	20111	0.	53.	0.	0.	-13.	42.	2.	5.	0.26	0.28	0.35	3.8	2.45	244.5	0	0.9	1.27	140		
GTWC16	20111	0.	39.	0.	0.	-6.	16.	2.	2.	0.33	0.28	0.20	3.3	2.10	285.3	0	1.0	1.34	147		
GTWC16	20111	0.	60.	0.	0.	-18.	45.	2.	5.	0.28	0.28	0.31	4.3	2.75	247.4	0	1.0	1.40	134		
CC1626	20111	0.	39.	0.	0.	-6.	16.	2.	2.	0.40	0.28	0.20	3.4	2.18	297.3	0	1.1	1.47	149		
CC1626	20111	0.	84.	0.	0.	-31.	81.	2.	10.	0.44	0.28	0.37	6.3	4.04	257.1	0	1.4	1.89	134		
CC1622	20111	0.	39.	0.	0.	-6.	16.	2.	2.	0.39	0.28	0.21	3.2	2.06	284.4	0	1.0	1.43	151		
CC1622	20111	0.	76.	0.	0.	-26.	73.	2.	9.	0.41	0.28	0.38	5.6	3.60	252.4	0	1.3	1.74	135		
CC1222	20111	0.	39.	0.	0.	-6.	16.	2.	2.	0.39	0.28	0.21	3.1	2.01	277.8	0	1.0	1.41	151		
CC1222	20111	0.	76.	0.	0.	-26.	73.	2.	9.	0.41	0.28	0.38	5.4	3.45	243.3	0	1.2	1.70	135		
CC0822	20111	0.	38.	0.	0.	-5.	16.	2.	2.	0.39	0.28	0.22	3.3	2.09	294.4	0	1.0	1.42	152		
CC0822	20111	0.	64.	0.	0.	-18.	59.	2.	7.	0.38	0.28	0.39	4.9	3.13	261.3	0	1.1	1.58	139		
STIG15	20111	0.	45.	0.	0.	-12.	16.	2.	2.	0.35	0.28	0.07	3.5	2.23	262.4	0	1.1	1.46	133		
STIG15	20111	0.	1846.	0.	0.	-1312.	1693.	2.	206.	2.64	0.28	0.17	65.0	41.49	120.1	0	13.7	18.83	508		
STIG10	20111	0.	44.	0.	0.	-11.	16.	2.	2.	0.34	0.28	0.10	3.3	2.12	258.3	0	1.0	1.41	137		
STIG10	20111	0.	181.	0.	0.	-106.	157.	2.	19.	0.50	0.28	0.22	8.9	5.70	168.0	0	2.0	2.75	122		
STIG1S	20111	0.	43.	0.	0.	-10.	16.	2.	2.	0.34	0.28	0.12	3.2	2.07	257.1	0	1.0	1.39	138		
STIG1S	20111	0.	114.	0.	0.	-58.	92.	2.	11.	0.39	0.28	0.23	6.1	3.93	184.3	0	1.5	2.00	116		
DEADV3	20111	0.	39.	0.	0.	-6.	16.	2.	2.	0.38	0.28	0.20	4.4	2.82	385.1	0	1.1	1.57	148		
DEADV3	20111	0.	72.	0.	0.	-25.	64.	2.	8.	0.40	0.28	0.36	7.1	4.52	335.1	0	1.4	1.93	137		
DEHTPM	20111	0.	37.	0.	0.	-4.	16.	2.	2.	0.40	0.28	0.24	4.3	2.78	400.9	0	1.1	1.56	153		
DEHTPM	20111	0.	55.	0.	0.	-12.	48.	2.	6.	0.38	0.28	0.40	6.0	3.82	374.1	0	1.2	1.70	146		
DESOA3	20111	40.	0.	0.	-40.	33.	16.	2.	2.	0.35	0.28	0.19	3.3	2.11	284.1	0	1.1	1.48	149		
DESOA3	20111	76.	0.	0.	-76.	48.	66.	2.	8.	0.40	0.28	0.33	7.2	4.57	322.0	0	1.6	2.16	139		
DESOA3	20111	0.	40.	0.	0.	-7.	16.	2.	2.	0.35	0.28	0.19	3.3	2.11	284.1	0	1.0	1.38	147		
DESOA3	20111	0.	76.	0.	0.	-28.	66.	2.	8.	0.40	0.28	0.33	7.2	4.57	322.0	0	1.4	1.98	135		
GTSOAD	20111	38.	0.	0.	-38.	33.	16.	2.	2.	0.32	0.28	0.22	2.9	1.83	256.2	0	1.0	1.34	152		
GTSOAD	20111	50.	0.	0.	-50.	39.	35.	2.	4.	0.24	0.28	0.32	3.2	2.03	214.9	0	0.9	1.28	143		
GTRA08	20111	39.	0.	0.	-39.	33.	16.	2.	2.	0.33	0.28	0.21	3.5	2.25	311.5	0	1.1	1.47	150		
GTRA08	20111	64.	0.	0.	-64.	45.	55.	2.	7.	0.30	0.28	0.36	5.2	3.34	279.7	0	1.2	1.68	139		
GTRA12	20111	38.	0.	0.	-38.	33.	16.	2.	2.	0.33	0.28	0.21	3.4	2.19	304.3	0	1.1	1.45	151		
GTRA12	20111	63.	0.	0.	-63.	44.	54.	2.	7.	0.30	0.28	0.36	5.1	3.28	278.4	0	1.2	1.66	140		
GTRA16	20111	38.	0.	0.	-38.	33.	16.	2.	2.	0.33	0.28	0.21	3.5	2.26	314.1	0	1.1	1.47	151		
GTRA16	20111	61.	0.	0.	-61.	44.	51.	2.	6.	0.30	0.28	0.36	5.2	3.34	292.6	0	1.2	1.67	141		
GTR208	20111	38.	0.	0.	-38.	33.	16.	2.	2.	0.33	0.28	0.21	3.3	2.09	290.4	0	1.0	1.42	151		
GTR208	20111	56.	0.	0.	-56.	41.	43.	2.	5.	0.27	0.28	0.34	4.2	2.69	256.3	0	1.1	1.48	141		
GTR212	20111	39.	0.	0.	-39.	33.	16.	2.	2.	0.33	0.28	0.21	3.4	2.14	296.8	0	1.0	1.44	151		
GTR212	20111	58.	0.	0.	-58.	42.	46.	2.	6.	0.28	0.28	0.34	4.5	2.90	265.2	0	1.1	1.55	140		
GTR216	20111	38.	0.	0.	-38.	33.	16.	2.	2.	0.33	0.28	0.22	3.4	2.17	301.6	0	1.0	1.44	151		
GTR216	20111	58.	0.	0.	-58.	42.	47.	2.	6.	0.29	0.28	0.35	4.7	3.01	275.3	0	1.1	1.57	141		
GTRW08	20111	40.	0.	0.	-40.	33.	16.	2.	2.	0.34	0.28	0.18	3.6	2.30	304.7	0	1.1	1.51	147		
GTRW08	20111	78.	0.	0.	-78.	48.	66.	2.	8.	0.34	0.28	0.31	5.9	3.78	258.9	0	1.4	1.92	133		
GTRW12	20111	40.	0.	0.	-40.	33.	16.	2.	2.	0.34	0.28	0.19	3.6	2.29	308.0	0	1.1	1.50	148		
GTRW12	20111	78.	0.	0.	-78.	49.	68.	2.	8.	0.34	0.28	0.33	6.0	3.84	264.4	0	1.4	1.91	134		
GTRW16	20111	40.	0.	0.	-40.	33.	16.	2.	2.	0.34	0.28	0.19	3.7	2.35	316.5	0	1.1	1.52	148		

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----

\*\*COGENERATION CASE\*\* \*\*NOCOGEN - COGEN\*\*

ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVEL CHRG	NORM ENRG	WRTH
GTRW16	20111	74.	0.	0.	-74.	47.	64.	2.	8.	0.34	0.28	0.33	6.0	3.86	277.2	0	1.4	1.90	136
GTR308	20111	41.	0.	0.	-41.	33.	16.	2.	2.	0.33	0.28	0.17	3.3	2.13	280.6	0	1.1	1.46	146
GTR308	20111	66.	0.	0.	-66.	43.	50.	2.	6.	0.29	0.28	0.28	4.6	2.96	238.1	0	1.2	1.66	134
GTR312	20111	40.	0.	0.	-40.	33.	16.	2.	2.	0.33	0.28	0.19	3.4	2.19	295.2	0	1.1	1.47	148
GTR312	20111	69.	0.	0.	-69.	45.	57.	2.	7.	0.31	0.28	0.32	5.1	3.26	251.9	0	1.3	1.72	135
GTR316	20111	40.	0.	0.	-40.	33.	16.	2.	2.	0.34	0.28	0.19	3.5	2.26	304.3	0	1.1	1.49	148
GTR316	20111	69.	0.	0.	-69.	45.	56.	2.	7.	0.31	0.28	0.32	5.3	3.39	263.7	0	1.3	1.76	136
FCPADS	20111	40.	0.	0.	-40.	33.	16.	2.	2.	0.32	0.28	0.19	3.0	1.92	258.7	0	1.0	1.38	149
FCPADS	20111	81.	0.	0.	-81.	50.	74.	2.	9.	0.46	0.28	0.35	6.0	3.80	249.6	0	1.5	2.06	138
FCMCDS	20111	40.	0.	0.	-40.	33.	16.	2.	2.	0.32	0.28	0.18	3.2	2.03	271.7	0	1.0	1.41	148
FCMCDS	20111	103.	0.	0.	-103.	59.	102.	2.	12.	0.59	0.28	0.26	8.8	5.60	290.4	0	2.0	2.71	144

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

		-----FUEL USE IN BTU*10**6-----																			
		**COGENERATION CASE**				**NOCOGEN - COGEN**				POWER	COGEN	O&M	POWER	FESR	CAPITAL	NORM	\$/KW	ROI	LEVL	NORM	WRTH
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	REQD	POWER			/HEAT	RATIO	*10**6	COST	EQVL	(%)	CHRG	ENRG		
								MW	MW												
ONCOGN	20261	0.	16.	11.	0.	0.	0.	1.	0.	0.14	0.41	0.	1.0	1.00	252.1	0	0.4	1.00	80		
STM141	20261	0.	18.	3.	0.	-2.	8.	1.	1.	0.22	0.41	0.24	1.9	1.96	380.5	0	0.6	1.29	141		
STM141	20261	0.	1.	20.	0.	15.	-9. F	1.	1.	0.34	0.41	0.24	3.0	3.19	617.6	0	0.8	1.72	143		
STM141	20261	0.	1.	20.	0.	15.	-9. A	1.	1.	0.29	0.41	0.24	2.9	3.05	591.4	0	0.7	1.59	140		
STM088	20261	0.	17.	4.	0.	-1.	6.	1.	1.	0.21	0.41	0.19	1.6	1.65	337.1	0	0.5	1.22	134		
STM088	20261	0.	1.	20.	0.	15.	-10. F	1.	1.	0.33	0.41	0.19	2.8	2.89	587.9	0	0.7	1.65	135		
STM088	20261	0.	1.	20.	0.	15.	-10. A	1.	1.	0.28	0.41	0.19	2.7	2.84	579.6	0	0.7	1.55	133		
PFBSTM	20261	0.	0.	18.	0.	16.	-8.	1.	1.	0.42	0.41	0.32	4.4	4.64	828.0	0	1.0	2.19	172		
PFBSTM	20261	0.	0.	19.	0.	16.	-7.	1.	1.	0.34	0.41	0.33	4.2	4.41	771.0	0	0.9	1.95	157		
TISTMT	20261	0.	18.	0.	0.	-2.	11.	1.	1.	0.40	0.41	0.32	6.2	6.53	1162.5	0	1.2	2.72	181		
TISTMT	20261	0.	20.	0.	0.	-3.	15.	1.	2.	0.37	0.41	0.37	7.4	7.74	1239.7	0	1.3	2.91	179		
TISTMT	20261	0.	0.	18.	0.	16.	-8.	1.	1.	0.59	0.41	0.32	8.4	8.78	1563.5	0	1.6	3.52	199		
TISTMT	20261	0.	0.	20.	0.	17.	-6.	1.	2.	0.51	0.41	0.37	9.4	9.82	1573.6	0	1.6	3.56	194		
TIHRSG	20261	0.	18.	5.	0.	-2.	5.	1.	1.	0.25	0.41	0.14	5.8	6.07	1221.6	0	1.0	2.33	136		
TIHRSG	20261	0.	2.	21.	0.	15.	-11.	1.	1.	0.37	0.41	0.14	7.5	7.83	1576.7	0	1.3	2.91	149		
STIRL	20261	20.	0.	0.	-20.	16.	11.	1.	1.	0.25	0.41	0.27	1.6	1.68	278.1	0	0.6	1.35	160		
STIRL	20261	24.	0.	0.	-24.	18.	18.	1.	2.	0.19	0.41	0.33	1.6	1.67	224.0	0	0.5	1.21	151		
STIRL	20261	0.	20.	0.	0.	-4.	11.	1.	1.	0.25	0.41	0.27	1.6	1.68	278.2	0	0.6	1.28	158		
STIRL	20261	0.	24.	0.	0.	-6.	18.	1.	2.	0.19	0.41	0.33	1.6	1.67	224.2	0	0.5	1.11	149		
STIRL	20261	0.	0.	20.	0.	16.	-9.	1.	1.	0.42	0.41	0.27	3.5	3.65	603.8	0	0.9	1.95	162		
STIRL	20261	0.	0.	24.	0.	18.	-6.	1.	2.	0.31	0.41	0.33	3.2	3.32	446.0	0	0.7	1.58	148		
HEGT85	20261	0.	0.	20.	0.	16.	-10. A	1.	1.	0.45	0.41	0.25	7.5	7.80	1256.3	0	1.4	3.02	179		
HEGT85	20261	0.	0.	27.	0.	19.	-6. A	1.	3.	0.39	0.41	0.32	9.8	10.22	1221.1	0	1.5	3.38	179		
HEGT60	20261	0.	0.	22.	0.	16.	-12. A	1.	1.	0.45	0.41	0.16	7.3	7.67	1113.1	0	1.3	3.01	168		
HEGT60	20261	0.	0.	29.	0.	18.	-11. A	1.	2.	0.37	0.41	0.20	8.8	9.19	1035.4	0	1.4	3.15	162		
HEGT00	20261	0.	1.	23.	0.	16.	-12. A	1.	1.	0.27	0.41	0.13	5.5	5.80	891.9	0	1.0	2.20	134		
FCMCCL	20261	0.	0.	19.	0.	16.	-9.	1.	1.	0.44	0.41	0.28	6.2	6.50	1092.1	0	1.2	2.72	176		
FCMCCL	20261	0.	0.	23.	0.	18.	-6.	1.	2.	0.35	0.41	0.34	6.8	7.13	1006.6	0	1.2	2.62	167		
FCSTCL	20261	0.	0.	19.	0.	16.	-8.	1.	1.	0.51	0.41	0.29	6.1	6.42	1096.8	0	1.3	2.84	181		
FCSTCL	20261	0.	0.	30.	0.	22.	-0.	1.	4.	0.48	0.41	0.42	8.8	9.22	1000.7	0	1.5	3.32	183		
IGGTST	20261	0.	0.	21.	0.	16.	-10.	1.	1.	0.56	0.41	0.24	6.6	6.88	1094.1	0	1.4	3.09	180		
IGGTST	20261	0.	0.	28.	0.	19.	-7.	1.	3.	0.50	0.41	0.31	8.0	8.33	970.2	0	1.4	3.23	175		
GTSUAR	20261	0.	20.	0.	0.	-4.	11.	1.	1.	0.24	0.41	0.25	2.2	2.33	377.6	0	0.6	1.42	154		
GTSUAR	20261	0.	24.	0.	0.	-6.	17.	1.	2.	0.18	0.41	0.31	2.3	2.46	331.6	0	0.6	1.29	143		
GTAC08	20261	0.	20.	0.	0.	-3.	11.	1.	1.	0.23	0.41	0.27	1.9	1.96	325.8	0	0.6	1.29	156		
GTAC08	20261	0.	22.	0.	0.	-4.	14.	1.	2.	0.16	0.41	0.31	1.8	1.89	285.6	0	0.5	1.12	145		
GTAC12	20261	0.	19.	0.	0.	-3.	11.	1.	1.	0.24	0.41	0.28	1.9	1.99	333.9	0	0.6	1.31	157		
GTAC12	20261	0.	23.	0.	0.	-5.	17.	1.	2.	0.17	0.41	0.34	2.0	2.05	287.1	0	0.5	1.16	147		
GTAC16	20261	0.	19.	0.	0.	-3.	11.	1.	1.	0.24	0.41	0.28	2.0	2.07	347.1	0	0.6	1.34	157		
GTAC16	20261	0.	25.	0.	0.	-6.	19.	1.	2.	0.18	0.41	0.35	2.2	2.26	300.6	0	0.5	1.22	147		
GTWC16	20261	0.	20.	0.	0.	-4.	11.	1.	1.	0.25	0.41	0.24	2.2	2.29	365.9	0	0.6	1.42	153		
GTWC16	20261	0.	27.	0.	0.	-8.	21.	1.	3.	0.19	0.41	0.31	2.5	2.62	313.5	0	0.6	1.35	142		
CC1626	20261	0.	20.	0.	0.	-4.	11.	1.	1.	0.32	0.41	0.24	2.3	2.43	390.5	0	0.7	1.62	157		

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----

\*\*COGENERATION CASE\*\* \*\*NOCOGEN - COGEN\*\*

ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD MW	COGEN POWER MW	G&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVEL CHRG	NORM ENRG	WRTH
CC1626	20261	0.	38.	0.	0.	-14.	37.	1.	5.	0.31	0.41	0.37	3.7	3.84	325.9	0	0.8	1.90	144
CC1622	20261	0.	20.	0.	0.	-4.	11.	1.	1.	0.31	0.41	0.26	2.2	2.27	369.9	0	0.7	1.56	158
CC1622	20261	0.	35.	0.	0.	-12.	33.	1.	4.	0.30	0.41	0.38	3.2	3.35	312.4	0	0.8	1.73	146
CC1222	20261	0.	20.	0.	0.	-4.	11.	1.	1.	0.31	0.41	0.26	2.1	2.20	359.9	0	0.7	1.54	159
CC1222	20261	0.	35.	0.	0.	-12.	33.	1.	4.	0.29	0.41	0.38	3.1	3.21	301.2	0	0.8	1.69	146
CC0822	20261	0.	19.	0.	0.	-3.	11.	1.	1.	0.31	0.41	0.28	2.2	2.31	386.9	0	0.7	1.56	160
CC0822	20261	0.	29.	0.	0.	-8.	27.	1.	3.	0.28	0.41	0.39	2.9	2.99	332.3	0	0.7	1.60	150
STIG15	20261	0.	24.	0.	0.	-8.	11.	1.	1.	0.28	0.41	0.09	2.4	2.54	338.6	0	0.7	1.61	137
STIG15	20261	0.	846.	0.	0.	-601.	776.	1.	94.	1.38	0.41	0.17	29.4	30.76	118.6	0	6.4	14.38	397
STIG10	20261	0.	23.	0.	0.	-7.	11.	1.	1.	0.27	0.41	0.13	2.3	2.39	332.3	0	0.7	1.54	141
STIG10	20261	0.	83.	0.	0.	-49.	72.	1.	9.	0.33	0.41	0.22	5.1	5.37	211.0	0	1.1	2.57	123
STIG1S	20261	0.	23.	0.	0.	-7.	11.	1.	1.	0.26	0.41	0.15	2.2	2.32	329.8	0	0.7	1.51	143
STIG1S	20261	0.	52.	0.	0.	-27.	42.	1.	5.	0.26	0.41	0.23	3.6	3.74	233.8	0	0.9	1.90	124
DEADV3	20261	0.	20.	0.	0.	-4.	11.	1.	1.	0.29	0.41	0.26	3.1	3.22	525.7	0	0.8	1.72	157
DEADV3	20261	0.	31.	0.	0.	-10.	28.	1.	3.	0.27	0.41	0.37	4.2	4.38	459.0	0	0.8	1.89	149
DEHTPM	20261	0.	19.	0.	0.	-3.	11.	1.	1.	0.31	0.41	0.30	3.0	3.17	548.2	0	0.8	1.72	162
DEHTPM	20261	0.	25.	0.	0.	-6.	22.	1.	3.	0.27	0.41	0.40	3.7	3.85	502.1	0	0.8	1.74	156
DESOA3	20261	20.	0.	0.	-20.	16.	11.	1.	1.	0.27	0.41	0.24	2.0	2.13	341.0	0	0.7	1.50	156
DESOA3	20261	32.	0.	0.	-32.	21.	28.	1.	3.	0.24	0.41	0.35	3.2	3.31	335.3	0	0.8	1.74	146
DESOA3	20261	0.	20.	0.	0.	-4.	11.	1.	1.	0.27	0.41	0.24	2.0	2.13	341.0	0	0.6	1.43	154
DESOA3	20261	0.	32.	0.	0.	-11.	28.	1.	3.	0.24	0.41	0.35	3.2	3.31	335.3	0	0.7	1.61	143
GTSOAD	20261	20.	0.	0.	-20.	16.	11.	1.	1.	0.23	0.41	0.27	1.8	1.92	318.5	0	0.6	1.37	158
GTSOAD	20261	23.	0.	0.	-23.	18.	16.	1.	2.	0.17	0.41	0.32	1.8	1.91	269.7	0	0.5	1.22	148
GTRA08	20261	20.	0.	0.	-20.	16.	11.	1.	1.	0.26	0.41	0.26	2.4	2.51	411.0	0	0.7	1.55	157
GTRA08	20261	29.	0.	0.	-29.	20.	25.	1.	3.	0.21	0.41	0.36	3.1	3.19	356.9	0	0.7	1.61	147
GTRA12	20261	20.	0.	0.	-20.	16.	11.	1.	1.	0.25	0.41	0.26	2.3	2.41	397.0	0	0.7	1.53	157
GTRA12	20261	29.	0.	0.	-29.	20.	25.	1.	3.	0.20	0.41	0.36	3.0	3.09	348.7	0	0.7	1.57	148
GTRA16	20261	20.	0.	0.	-20.	16.	11.	1.	1.	0.25	0.41	0.26	2.4	2.50	410.8	0	0.7	1.55	157
GTRA16	20261	28.	0.	0.	-28.	20.	23.	1.	3.	0.20	0.41	0.36	3.0	3.14	366.8	0	0.7	1.59	148
GTR208	20261	20.	0.	0.	-20.	16.	11.	1.	1.	0.25	0.41	0.26	2.2	2.28	374.5	0	0.7	1.48	157
GTR208	20261	26.	0.	0.	-26.	19.	20.	1.	2.	0.19	0.41	0.34	2.4	2.55	324.5	0	0.6	1.41	147
GTR212	20261	20.	0.	0.	-20.	16.	11.	1.	1.	0.25	0.41	0.26	2.2	2.35	384.6	0	0.7	1.51	157
GTR212	20261	27.	0.	0.	-27.	19.	21.	1.	3.	0.19	0.41	0.34	2.6	2.75	334.9	0	0.7	1.47	147
GTR216	20261	20.	0.	0.	-20.	16.	11.	1.	1.	0.25	0.41	0.26	2.3	2.38	391.5	0	0.7	1.51	157
GTR216	20261	27.	0.	0.	-27.	19.	22.	1.	3.	0.20	0.41	0.35	2.7	2.83	345.0	0	0.7	1.49	148
GTRW08	20261	21.	0.	0.	-21.	16.	11.	1.	1.	0.26	0.41	0.22	2.5	2.58	399.3	0	0.7	1.61	152
GTRW08	20261	36.	0.	0.	-36.	22.	30.	1.	4.	0.23	0.41	0.31	3.5	3.64	332.3	0	0.8	1.83	141
GTRW12	20261	21.	0.	0.	-21.	16.	11.	1.	1.	0.26	0.41	0.23	2.5	2.58	405.1	0	0.7	1.60	154
GTRW12	20261	36.	0.	0.	-36.	22.	31.	1.	4.	0.23	0.41	0.33	3.5	3.70	339.3	0	0.8	1.83	143
GTRW16	20261	21.	0.	0.	-21.	16.	11.	1.	1.	0.26	0.41	0.23	2.5	2.65	417.4	0	0.7	1.62	154
GTRW16	20261	34.	0.	0.	-34.	22.	29.	1.	4.	0.23	0.41	0.33	3.6	3.72	356.1	0	0.8	1.82	144
GTR308	20261	21.	0.	0.	-21.	16.	11.	1.	1.	0.25	0.41	0.21	2.2	2.33	358.5	0	0.7	1.54	151
GTR308	20261	30.	0.	0.	-30.	20.	23.	1.	3.	0.20	0.41	0.28	2.7	2.81	301.2	0	0.7	1.56	141
GTR312	20261	21.	0.	0.	-21.	16.	11.	1.	1.	0.26	0.41	0.23	2.3	2.44	384.7	0	0.7	1.56	154

HONEYWELL PAGE PRINTING SYSTEM - P1185-02

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																				
ECS	PROCS	**COGENERATION CASE**						**NO COGEN - COGEN**		POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM WRTH ENRG
		DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	COAL	COAL											
GTR312	20261	32.	0.	0.	-32.	21.	26.	1.	3.	0.21	0.41	0.32	3.0	3.14	322.7	0	0.7	1.64	143	
GTR316	20261	21.	0.	0.	-21.	16.	11.	1.	1.	0.26	0.41	0.23	2.4	2.53	398.0	0	0.7	1.58	154	
GTR316	20261	32.	0.	0.	-32.	21.	26.	1.	3.	0.21	0.41	0.32	3.1	3.27	338.4	0	0.8	1.68	143	
FCPADS	20261	20.	0.	0.	-20.	16.	11.	1.	1.	0.23	0.41	0.25	1.8	1.93	312.7	0	0.6	1.37	156	
FCPADS	20261	34.	0.	0.	-34.	22.	31.	1.	4.	0.23	0.41	0.36	2.7	2.83	274.8	0	0.7	1.58	145	
FCMCDS	20261	21.	0.	0.	-21.	16.	11.	1.	1.	0.23	0.41	0.23	2.0	2.10	329.3	0	0.6	1.43	153	
FCMCDS	20261	47.	0.	0.	-47.	27.	47.	1.	6.	0.31	0.41	0.36	4.2	4.43	306.0	0	1.0	2.20	143	

HONEYWELL PAGE PRINTING SYSTEM- P1185-02

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----  
\*\*COGENERATION CASE\*\* \*\*NO COGEN. - COGEN\*\*

ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD	COGEN POWER	G&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVEL CHRGR	NORM WRTH ENRG
ONOCGN	20461	0.	70.	1009.	0.	0.	0.	F 29.	0.	2.16	0.15	0.	42.8	1.00	188.6	0	24.8	1.00 80
STM141	20461	0.	890.	0.	0.	-820.	1009.	29.	29.	1.57	0.15	0.18	29.6	0.69	113.3	-11	25.1	1.05 163
STM141	20461	0.	1008.	0.	0.	-866.	1252.	29.	58.	1.29	0.15	0.28	28.1	0.66	95.0	999	24.0	0.97 158
STM141	20461	0.	0.	890.	0.	70.	120.	F 29.	29.	3.04	0.15	0.18	51.9	1.21	199.0	27	21.1	0.85 144
STM141	20461	0.	0.	1008.	0.	142.	244.	F 29.	58.	2.90	0.15	0.28	59.0	1.38	199.7	25	18.8	0.76 134
STM141	20461	0.	0.	890.	0.	70.	120.	A 29.	29.	2.83	0.15	0.18	43.4	1.01	166.6	999	19.9	0.80 147
STM141	20461	0.	0.	1008.	0.	142.	244.	A 29.	58.	2.57	0.15	0.28	41.8	0.98	141.4	999	16.6	0.67 140
STM088	20461	0.	890.	0.	0.	-820.	1009.	29.	29.	1.44	0.15	0.18	24.9	0.58	95.5	-7	25.5	1.03 167
STM088	20461	0.	959.	0.	0.	-847.	1152.	29.	46.	1.23	0.15	0.24	25.8	0.60	91.8	-2	24.4	0.98 160
STM088	20461	0.	0.	890.	0.	70.	120.	F 29.	29.	2.58	0.15	0.18	51.1	1.19	196.0	30	20.9	0.84 144
STM088	20461	0.	0.	959.	0.	112.	192.	F 29.	46.	2.73	0.15	0.24	55.5	1.30	197.4	28	19.5	0.78 135
STM088	20461	0.	0.	890.	0.	70.	120.	A 29.	29.	2.60	0.15	0.18	42.0	0.98	161.1	999	19.8	0.80 147
STM088	20461	0.	0.	959.	0.	112.	192.	A 29.	46.	2.49	0.15	0.24	40.5	0.95	144.1	999	17.6	0.71 141
PFBSTM	20461	0.	0.	891.	0.	70.	118.	29.	29.	3.40	0.15	0.17	52.3	1.22	200.4	24	21.5	0.87 144
PFBSTM	20461	0.	0.	1118.	0.	207.	349.	29.	84.	4.23	0.15	0.33	58.6	1.37	176.7	29	17.7	0.71 132
TISTMT	20461	0.	892.	0.	0.	-822.	1009.	29.	29.	2.56	0.15	0.17	69.3	1.62	265.1	0	31.5	1.27 147
TISTMT	20461	0.	1220.	0.	0.	-955.	1665.	29.	108.	4.45	0.15	0.37	150.9	3.52	422.0	0	37.9	1.53 133
TISTMT	20461	0.	0.	892.	0.	70.	117.	29.	29.	4.09	0.15	0.17	95.5	2.23	365.0	1	26.9	1.08 136
TISTMT	20461	0.	0.	1220.	0.	266.	445.	29.	108.	6.28	0.15	0.37	189.7	4.43	530.4	0	31.6	1.27 124
TIHRSG	20461	0.	915.	0.	0.	-845.	1009.	29.	29.	3.14	0.15	0.15	97.4	2.27	363.2	0	35.4	1.42 142
TIHRSG	20461	0.	971.	0.	0.	-873.	1104.	29.	40.	3.46	0.15	0.19	119.8	2.80	420.7	0	37.7	1.52 134
TIHRSG	20461	0.	0.	915.	0.	70.	95.	29.	29.	4.89	0.15	0.15	132.0	3.08	492.3	0	31.9	1.28 133
TIHRSG	20461	0.	0.	971.	0.	98.	133.	29.	40.	5.05	0.15	0.19	152.7	3.56	536.4	0	33.3	1.34 126
STIRL	20461	940.	0.	0.	-940.	70.	1009.	29.	29.	1.74	0.15	0.13	38.3	0.89	139.2	-79	33.5	1.35 158
STIRL	20461	1457.	0.	0.	-1457.	290.	1745.	29.	118.	2.54	0.15	0.28	75.9	1.77	177.8	0	39.8	1.60 134
STIRL	20461	0.	940.	0.	0.	-870.	1009.	29.	29.	1.74	0.15	0.13	38.4	0.90	139.3	-38	28.4	1.14 153
STIRL	20461	0.	1457.	0.	0.	-1168.	1745.	29.	118.	2.55	0.15	0.28	76.0	1.77	176.1	0	31.9	1.28 126
STIRL	20461	0.	0.	940.	0.	70.	69.	29.	29.	3.30	0.15	0.13	64.4	1.50	233.9	10	23.2	0.93 135
STIRL	20461	0.	0.	1457.	0.	290.	287.	29.	118.	5.05	0.15	0.28	134.1	3.13	314.1	4	25.9	1.04 110
HEGT85	20461	0.	0.	981.	0.	70.	28.	A 29.	29.	3.61	0.15	0.09	81.5	1.90	283.5	2	26.1	1.05 128
HEGT85	20461	0.	0.	2424.	0.	559.	224.	A 29.	228.	8.43	0.15	0.24	233.6	5.45	328.7	0	37.1	1.49 96
HEGT60	20461	0.	0.	983.	0.	70.	26.	A 29.	29.	3.58	0.15	0.09	79.3	1.85	275.2	2	25.9	1.04 128
HEGT60	20461	0.	0.	1734.	0.	323.	122.	A 29.	132.	5.89	0.15	0.20	156.6	3.66	308.2	0	31.3	1.26 101
HEGT00	20461	0.	0.	991.	0.	70.	19.	A 29.	29.	3.55	0.15	0.08	76.3	1.78	262.7	3	25.6	1.03 128
HEGT00	20461	0.	0.	1271.	0.	161.	43.	A 29.	66.	4.03	0.15	0.14	99.5	2.32	267.3	1	26.9	1.08 112
FCMCCL	20461	0.	0.	916.	0.	70.	93.	29.	29.	3.85	0.15	0.15	75.2	1.75	280.0	5	25.0	1.00 136
FCMCCL	20461	0.	0.	1386.	0.	303.	403.	29.	123.	6.56	0.15	0.34	125.4	2.93	308.9	4	25.3	1.02 116
FCSTCL	20461	0.	0.	909.	0.	70.	100.	29.	29.	3.74	0.15	0.16	72.3	1.69	271.1	6	24.4	0.98 137
FCSTCL	20461	0.	0.	1800.	0.	534.	764.	29.	218.	8.55	0.15	0.42	163.2	3.81	309.4	6	22.9	0.92 109
IGGTST	20461	0.	0.	940.	0.	70.	69.	29.	29.	3.31	0.15	0.13	69.0	1.61	250.3	7	24.1	0.97 134
IGGTST	20461	0.	0.	1679.	0.	383.	379.	29.	156.	4.25	0.15	0.31	128.9	3.01	262.1	7	22.5	0.90 104
GTSOAR	20461	0.	931.	0.	0.	-861.	1009.	29.	29.	1.52	0.15	0.14	32.2	0.75	118.0	-18	27.3	1.10 157
GTSOAR	20461	0.	1449.	0.	0.	-1147.	1786.	29.	123.	1.82	0.15	0.31	51.5	1.20	121.3	0	27.6	1.11 132

UNSWELL PAGE PRINTING SYSTEM - P118-08

ORIGINAL FROM QUALITY



GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																			
**COGENERATION CASE** **NOCOGEN - COGEN**																			
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER RECD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EVL	ROI (%)	LEVL CHRG	NORM ENRG	WRTH
GTAC08	20461	0.	920.	0.	0.	-850.	1009.	29.	29.	1.48	0.15	0.15	30.4	0.71	112.9	-14	26.8	1.08	160
GTAC08	20461	0.	1296.	0.	0.	-1044.	1617.	29.	103.	1.50	0.15	0.31	39.2	0.92	103.3	-13	25.5	1.02	142
GTAC12	20461	0.	917.	0.	0.	-847.	1009.	29.	29.	1.49	0.15	0.15	31.0	0.72	115.5	-15	26.8	1.08	159
GTAC12	20461	0.	1395.	0.	0.	-1089.	1799.	29.	125.	1.68	0.15	0.34	46.2	1.08	113.1	0	25.4	1.02	136
GTAC16	20461	0.	917.	0.	0.	-847.	1009.	29.	29.	1.50	0.15	0.15	31.8	0.74	118.4	-16	26.9	1.08	159
GTAC16	20461	0.	1468.	0.	0.	-1127.	1916.	29.	139.	1.93	0.15	0.35	55.7	1.30	129.5	0	26.2	1.06	131
GTWC16	20461	0.	938.	0.	0.	-868.	1009.	29.	29.	1.51	0.15	0.13	31.7	0.74	115.5	-18	27.4	1.10	157
GTWC16	20461	0.	1634.	0.	0.	-1264.	2014.	29.	151.	1.80	0.15	0.31	49.6	1.16	103.6	0	27.6	1.11	129
CC1626	20461	0.	936.	0.	0.	-866.	1009.	29.	29.	1.61	0.15	0.13	32.0	0.75	116.6	-19	27.5	1.11	157
CC1626	20461	0.	2302.	0.	0.	-1638.	2999.	29.	271.	2.76	0.15	0.37	78.3	1.83	116.1	0	29.6	1.19	119
CC1622	20461	0.	929.	0.	0.	-859.	1009.	29.	29.	1.60	0.15	0.14	31.9	0.74	117.2	-18	27.4	1.10	158
CC1622	20461	0.	2095.	0.	0.	-1496.	2781.	29.	244.	2.71	0.15	0.38	79.2	1.85	129.0	0	28.7	1.16	120
CC1222	20461	0.	928.	0.	0.	-858.	1009.	29.	29.	1.59	0.15	0.14	31.3	0.73	115.1	-17	27.3	1.10	158
CC1222	20461	0.	2082.	0.	0.	-1484.	2779.	29.	244.	2.63	0.15	0.38	74.2	1.73	121.7	0	27.8	1.12	121
CC0822	20461	0.	918.	0.	0.	-848.	1009.	29.	29.	1.59	0.15	0.15	31.2	0.73	115.9	-16	27.0	1.09	159
CC0822	20461	0.	1759.	0.	0.	-1276.	2394.	29.	197.	2.26	0.15	0.39	61.2	1.43	118.7	2	25.4	1.02	126
STIG15	20461	0.	1027.	0.	0.	-957.	1009.	29.	29.	1.79	0.15	0.05	35.4	0.83	117.6	-38	30.2	1.22	147
STIG15	20461	0.	50692.	0.	0.	-36811.	47249.	29.	5661.	73.68	0.15	0.17	1371.1	32.00	92.3	0	577.1	23.23	619
STIG10	20461	0.	1004.	0.	0.	-934.	1009.	29.	29.	1.71	0.15	0.07	34.4	0.80	117.0	-31	29.4	1.19	149
STIG10	20461	0.	4974.	0.	0.	-3690.	5073.	29.	523.	6.80	0.15	0.22	145.3	3.39	99.7	0	66.1	2.66	125
STIG1S	20461	0.	993.	0.	0.	-924.	1009.	29.	29.	1.63	0.15	0.08	30.7	0.72	105.6	-22	28.7	1.16	153
STIG1S	20461	0.	3126.	0.	0.	-2373.	3297.	29.	307.	4.45	0.15	0.23	91.2	2.13	99.6	0	46.7	1.88	115
DEADV3	20461	0.	959.	0.	0.	-889.	1009.	29.	29.	1.79	0.15	0.11	41.0	0.96	145.9	-77	29.2	1.17	149
DEADV3	20461	0.	2594.	0.	0.	-1902.	3091.	29.	282.	5.36	0.15	0.31	182.6	4.26	240.2	0	48.3	1.94	117
DEHTPM	20461	0.	904.	0.	0.	-834.	1009.	29.	29.	1.82	0.15	0.16	40.3	0.94	152.0	-46	27.8	1.12	155
DEHTPM	20461	0.	1499.	0.	0.	-1106.	2092.	29.	160.	3.45	0.15	0.40	107.7	2.51	245.1	0	30.7	1.24	125
DES0A3	20461	975.	0.	0.	-975.	70.	1009.	29.	29.	1.91	0.15	0.10	45.7	1.07	159.8	0	35.4	1.43	151
DES0A3	20461	2995.	0.	0.	-2995.	777.	3377.	29.	317.	7.19	0.15	0.28	254.2	5.93	289.6	0	78.2	3.15	139
DES0A3	20461	0.	975.	0.	0.	-905.	1009.	29.	29.	1.91	0.15	0.10	45.7	1.07	159.8	0	30.1	1.21	146
DES0A3	20461	0.	2995.	0.	0.	-2218.	3377.	29.	317.	7.19	0.15	0.28	254.2	5.93	289.6	0	62.0	2.50	123
GTS0AD	20461	922.	0.	0.	-922.	70.	1009.	29.	29.	1.46	0.15	0.15	29.8	0.70	110.3	-31	31.7	1.28	165
GTS0AD	20461	1384.	0.	0.	-1384.	290.	1748.	29.	118.	1.53	0.15	0.32	40.1	0.94	99.0	104	32.8	1.32	146
GTRA08	20461	927.	0.	0.	-927.	70.	1009.	29.	29.	1.53	0.15	0.14	33.1	0.77	121.7	-41	32.3	1.30	162
GTRA08	20461	1750.	0.	0.	-1750.	449.	2278.	29.	183.	2.35	0.15	0.36	71.0	1.66	138.5	0	37.8	1.52	133
GTRA12	20461	925.	0.	0.	-925.	70.	1009.	29.	29.	1.54	0.15	0.14	33.3	0.78	122.7	-41	32.3	1.30	162
GTRA12	20461	1730.	0.	0.	-1730.	445.	2266.	29.	182.	2.33	0.15	0.36	70.3	1.64	138.7	0	37.3	1.50	133
GTRA16	20461	925.	0.	0.	-925.	70.	1009.	29.	29.	1.56	0.15	0.14	34.0	0.79	125.6	-44	32.4	1.30	162
GTRA16	20461	1675.	0.	0.	-1675.	420.	2182.	29.	171.	2.35	0.15	0.36	71.3	1.66	145.2	0	37.4	1.51	133
GTR208	20461	926.	0.	0.	-926.	70.	1009.	29.	29.	1.51	0.15	0.14	32.0	0.75	118.1	-37	32.1	1.29	163
GTR208	20461	1538.	0.	0.	-1538.	354.	1960.	29.	144.	1.95	0.15	0.34	56.1	1.31	124.6	0	35.5	1.43	138
GTR212	20461	927.	0.	0.	-927.	70.	1009.	29.	29.	1.52	0.15	0.14	32.6	0.76	119.9	-39	32.3	1.30	162
GTR212	20461	1603.	0.	0.	-1603.	380.	2048.	29.	155.	2.07	0.15	0.34	60.7	1.42	129.3	0	36.4	1.46	136
GTR216	20461	924.	0.	0.	-924.	70.	1009.	29.	29.	1.54	0.15	0.14	33.2	0.78	122.7	-41	32.3	1.30	162
GTR216	20461	1605.	0.	0.	-1605.	389.	2077.	29.	158.	2.18	0.15	0.35	65.0	1.52	138.2	0	36.5	1.47	135

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----

ECS	PROCS	**COGENERATION CASE**			**NOCOGEN - COGEN**			POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVEL CHRG	NORM ENRG	WRTH
		DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL												
GTRW08	20461	952.	0.	0.	-952.	70.	1009.	29.	29.	1.53	0.15	0.12	32.9	0.77	118.0	-43	33.0	1.33	160
GTRW08	20161	2143.	0.	0.	-2143.	541.	2585.	29.	220.	2.44	0.15	0.31	73.0	1.70	116.3	0	44.0	1.77	130
GTRW12	20461	945.	0.	0.	-945.	70.	1009.	29.	29.	1.53	0.15	0.12	32.9	0.77	118.8	-42	32.8	1.32	161
GTRW12	20461	2132.	0.	0.	-2132.	558.	2643.	29.	227.	2.47	0.15	0.33	74.3	1.73	118.9	0	42.7	1.72	130
GTRW16	20461	944.	0.	0.	-944.	70.	1009.	29.	29.	1.55	0.15	0.12	33.4	0.78	120.9	-44	32.9	1.32	160
GTRW16	20461	2042.	0.	0.	-2042.	524.	2530.	29.	214.	2.46	0.15	0.33	74.2	1.73	124.0	0	42.2	1.70	130
GTR308	20461	956.	0.	0.	-956.	70.	1009.	29.	29.	1.52	0.15	0.11	32.1	0.75	114.5	-41	33.0	1.33	160
GTR308	20461	1826.	0.	0.	-1826.	407.	2137.	29.	166.	2.07	0.15	0.28	59.5	1.39	111.2	0	41.1	1.66	132
GTR312	20461	944.	0.	0.	-944.	70.	1009.	29.	29.	1.51	0.15	0.13	32.1	0.75	116.1	-40	32.7	1.32	161
GTR312	20461	1899.	0.	0.	-1899.	467.	2338.	29.	190.	2.19	0.15	0.32	63.9	1.49	114.8	0	40.2	1.62	132
GTR316	20461	944.	0.	0.	-944.	70.	1009.	29.	29.	1.53	0.15	0.12	32.7	0.76	118.3	-42	32.8	1.32	161
GTR316	20461	1888.	0.	0.	-1888.	460.	2316.	29.	188.	2.24	0.15	0.32	65.9	1.54	119.2	0	40.5	1.63	132
FCPADS	20461	980.	0.	0.	-980.	70.	1009.	29.	29.	3.73	0.15	0.09	42.7	1.00	148.7	999	37.1	1.49	154
FCPADS	20461	3876.	0.	0.	-3876.	1059.	4320.	29.	432.	38.13	0.15	0.28	244.7	5.71	215.4	0	116.6	4.69	177
FCMCDS	20461	947.	0.	0.	-947.	70.	1009.	29.	29.	3.59	0.15	0.12	43.9	1.02	158.2	999	36.1	1.45	156
FCMCDS	20461	2828.	0.	0.	-2828.	838.	3579.	29.	342.	28.67	0.15	0.36	210.2	4.91	253.7	0	86.4	3.48	159

OF POWER GENERATED

PUNETELL PAGE PRINTING SYSTEM- P1189-02

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																				
**COGENERATION CASE** **NOCOGEN - COGEN**																				
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REGD	COGEN POWER	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM ENRG	WRTH	
ONOCGN	20631	0.	12.	316.	0.	0.	0.	F	5.	0.	1.13	0.05	0.	20.6	1.00	198.2	0	5.5	1.00	80
STM141	20631	0.	297.	0.	0.	-285.	316.		5.	5.	0.89	0.05	0.10	11.7	0.57	107.1	-1	5.2	0.94	156
STM141	20631	0.	384.	0.	0.	-319.	495.		5.	27.	0.87	0.05	0.31	16.3	0.79	120.4	999	5.1	0.93	133
STM141	20631	0.	0.	297.	0.	12.	20.	F	5.	5.	1.67	0.05	0.10	26.6	1.29	243.1	0	6.3	1.14	139
STM141	20631	0.	0.	384.	0.	65.	111.	F	5.	27.	1.53	0.05	0.31	29.2	1.42	216.4	4	5.6	1.01	120
STM141	20631	0.	0.	297.	0.	12.	20.	A	5.	5.	1.57	0.05	0.10	25.1	1.22	229.3	0	6.0	1.10	140
STM141	20631	0.	0.	384.	0.	65.	111.	A	5.	27.	1.27	0.05	0.31	21.3	1.03	157.5	79	4.4	0.80	123
STM088	20631	0.	297.	0.	0.	-285.	316.		5.	5.	0.89	0.05	0.10	11.5	0.56	105.3	-1	5.2	0.94	156
STM088	20631	0.	362.	0.	0.	-310.	450.		5.	21.	0.83	0.05	0.28	14.7	0.72	114.7	999	5.1	0.92	136
STM088	20631	0.	0.	297.	0.	12.	20.	F	5.	5.	1.68	0.05	0.10	26.6	1.29	243.0	0	6.3	1.15	139
STM088	20631	0.	0.	362.	0.	51.	88.	F	5.	21.	1.46	0.05	0.28	27.2	1.32	211.9	5	5.5	1.00	123
STM088	20631	0.	0.	297.	0.	12.	20.	A	5.	5.	1.58	0.05	0.10	25.0	1.21	228.5	0	6.0	1.10	140
STM088	20631	0.	0.	362.	0.	51.	88.	A	5.	21.	1.23	0.05	0.28	20.3	0.99	158.0	999	4.5	0.82	125
PFBSTM	20631	0.	0.	297.	0.	12.	19.		5.	5.	1.61	0.05	0.09	26.3	1.28	240.8	0	6.2	1.13	139
PFBSTM	20631	0.	0.	434.	0.	94.	159.		5.	38.	1.86	0.05	0.37	34.8	1.69	232.4	2	6.0	1.09	119
TISTMT	20631	0.	297.	0.	0.	-285.	316.		5.	5.	1.13	0.05	0.09	22.2	1.08	203.3	0	6.6	1.19	145
TISTMT	20631	0.	427.	0.	0.	-342.	596.		5.	39.	2.48	0.05	0.37	72.4	3.52	480.9	0	12.6	2.28	136
TISTMT	20631	0.	0.	297.	0.	12.	19.		5.	5.	1.87	0.05	0.09	36.1	1.75	329.8	0	7.5	1.37	138
TISTMT	20631	0.	0.	481.	0.	121.	203.		5.	50.	3.50	0.05	0.40	105.9	5.15	648.2	0	14.9	2.71	145
TIHRSG	20631	0.	301.	0.	0.	-289.	316.		5.	5.	1.25	0.05	0.08	29.5	1.44	267.4	0	7.4	1.35	141
TIHRSG	20631	0.	348.	0.	0.	-313.	395.		5.	14.	1.97	0.05	0.19	57.8	2.81	464.6	0	11.0	2.00	132
TIHRSG	20631	0.	0.	301.	0.	12.	16.		5.	5.	2.09	0.05	0.08	46.3	2.25	419.3	0	8.9	1.61	138
TIHRSG	20631	0.	0.	367.	0.	45.	61.		5.	18.	2.79	0.05	0.22	85.1	4.14	654.3	0	13.3	2.41	135
STIRL	20631	305.	0.	0.	-305.	12.	316.		5.	5.	0.89	0.05	0.07	14.3	0.70	126.0	-12	6.2	1.13	152
STIRL	20631	522.	0.	0.	-522.	104.	625.		5.	42.	1.44	0.05	0.28	31.4	1.53	178.9	0	8.8	1.60	123
STIRL	20631	0.	305.	0.	0.	-293.	316.		5.	5.	0.89	0.05	0.07	14.3	0.70	128.0	-5	5.5	1.00	148
STIRL	20631	0.	522.	0.	0.	-418.	625.		5.	42.	1.44	0.05	0.28	31.4	1.53	179.2	0	7.6	1.39	117
STIRL	20631	0.	0.	305.	0.	12.	11.		5.	5.	1.59	0.05	0.07	26.9	1.31	241.2	0	6.2	1.13	136
STIRL	20631	0.	0.	569.	0.	132.	131.		5.	54.	2.43	0.05	0.31	62.4	3.03	320.0	0	9.3	1.69	114
HEGT85	20631	0.	0.	312.	0.	12.	5.	A	5.	5.	1.62	0.05	0.05	32.9	1.60	289.1	0	7.0	1.27	132
HEGT85	20631	0.	0.	1031.	0.	255.	102.	A	5.	104.	4.24	0.05	0.26	133.9	6.51	412.8	0	18.4	3.34	139
HEGT60	20631	0.	0.	312.	0.	12.	4.	A	5.	5.	1.62	0.05	0.05	32.5	1.58	285.4	0	7.0	1.27	132
HEGT60	20631	0.	0.	716.	0.	147.	56.	A	5.	60.	2.98	0.05	0.22	90.0	4.38	387.9	0	13.4	2.43	116
HEGT00	20631	0.	0.	313.	0.	12.	3.	A	5.	5.	1.63	0.05	0.04	32.0	1.55	280.0	0	6.9	1.26	132
HEGT00	20631	0.	0.	504.	0.	73.	20.	A	5.	30.	2.04	0.05	0.16	57.2	2.78	336.0	0	9.6	1.74	103
FCMCCL	20631	0.	0.	377.	0.	12.	-51.		5.	5.	1.69	0.05	-0.15	33.4	1.62	302.2	0	7.6	1.38	109
FCMCCL	20631	0.	0.	633.	0.	138.	108.		5.	56.	2.81	0.05	0.28	70.9	3.45	382.3	0	11.1	2.01	116
FCSTCL	20631	0.	0.	376.	0.	12.	-60.		5.	5.	1.72	0.05	-0.15	32.5	1.58	294.4	0	7.5	1.37	110
FCSTCL	20631	0.	0.	822.	0.	244.	273.		5.	100.	3.67	0.05	0.39	92.1	4.48	382.4	0	12.6	2.29	133
IGGTST	20631	0.	0.	381.	0.	12.	-65.		5.	5.	1.75	0.05	-0.16	31.6	1.54	282.8	0	7.5	1.36	109
IGGTST	20631	0.	0.	767.	0.	175.	97.		5.	71.	2.60	0.05	0.26	71.5	3.47	318.0	0	10.7	1.95	112
GTSOAR	20631	0.	303.	0.	0.	-292.	316.		5.	5.	0.84	0.05	0.07	13.7	0.66	122.9	-3	5.4	0.98	150
GTSOAR	20631	0.	519.	0.	0.	-411.	640.		5.	44.	1.16	0.05	0.31	23.5	1.14	134.5	0	6.4	1.16	121

HONEYWELL PAGE PRINTING SYSTEM-PI185-02

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																			
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVEL CHRG	NORM WRTH ENRG	
GTAC08	20631	0.	301.	0.	0.	-290.	316.	5.	5.	0.82	0.05	0.08	13.1	0.64	118.4	-2	5.3	0.96	151
GTAC08	20631	0.	464.	0.	0.	-374.	579.	5.	37.	1.05	0.05	0.31	19.6	0.95	123.9	-17	5.8	1.05	125
GTAC12	20631	0.	301.	0.	0.	-289.	316.	5.	5.	0.82	0.05	0.08	13.1	0.64	118.3	-2	5.3	0.96	151
GTAC12	20631	0.	499.	0.	0.	-390.	644.	5.	45.	1.13	0.05	0.34	22.3	1.08	132.2	0	6.0	1.09	124
GTAC16	20631	0.	301.	0.	0.	-290.	316.	5.	5.	0.82	0.05	0.08	13.2	0.64	119.6	-2	5.3	0.96	151
GTAC16	20631	0.	526.	0.	0.	-404.	686.	5.	50.	1.20	0.05	0.35	24.8	1.20	140.4	0	6.3	1.14	124
GTWC16	20631	0.	304.	0.	0.	-293.	316.	5.	5.	0.83	0.05	0.07	13.5	0.66	121.0	-3	5.4	0.97	149
GTWC16	20631	0.	585.	0.	0.	-453.	721.	5.	54.	1.22	0.05	0.31	24.9	1.21	128.7	0	6.6	1.20	120
CC1626	20631	0.	304.	0.	0.	-293.	316.	5.	5.	0.89	0.05	0.07	13.4	0.65	120.1	-4	5.4	0.99	150
CC1626	20631	0.	824.	0.	0.	-587.	1074.	5.	97.	1.64	0.05	0.37	35.0	1.70	132.5	0	7.9	1.43	125
CC1622	20631	0.	303.	0.	0.	-292.	316.	5.	5.	0.89	0.05	0.08	13.1	0.64	118.2	-3	5.4	0.98	151
CC1622	20631	0.	750.	0.	0.	-536.	996.	5.	87.	1.61	0.05	0.38	34.6	1.68	142.6	0	7.6	1.39	125
CC1222	20631	0.	303.	0.	0.	-291.	316.	5.	5.	0.88	0.05	0.08	13.0	0.63	117.0	-3	5.4	0.98	151
CC1222	20631	0.	746.	0.	0.	-531.	995.	5.	87.	1.58	0.05	0.38	32.9	1.60	136.7	0	7.4	1.34	126
CC0822	20631	0.	301.	0.	0.	-290.	316.	5.	5.	0.89	0.05	0.08	13.2	0.64	119.2	-3	5.4	0.98	151
CC0822	20631	0.	630.	0.	0.	-457.	857.	5.	71.	1.43	0.05	0.39	28.1	1.37	135.8	0	6.6	1.20	126
STIG15	20631	0.	319.	0.	0.	-308.	316.	5.	5.	0.91	0.05	0.03	16.3	0.79	140.2	-10	5.9	1.07	141
STIG15	20631	0.	18154.	0.	0.	-13183.	16921.	5.	2027.	20.00	0.05	0.17	510.6	24.82	95.6	0	128.0	23.25	620
STIG10	20631	0.	315.	0.	0.	-304.	316.	5.	5.	0.83	0.05	0.04	13.1	0.64	113.8	-4	5.4	0.98	146
STIG10	20631	0.	1781.	0.	0.	-1321.	1817.	5.	187.	2.56	0.05	0.22	56.7	2.76	104.2	0	14.9	2.70	129
STIG1S	20631	0.	314.	0.	0.	-302.	316.	5.	5.	0.83	0.05	0.04	13.0	0.63	113.8	-4	5.4	0.98	147
STIG1S	20631	0.	1120.	0.	0.	-850.	1181.	5.	110.	1.90	0.05	0.23	39.1	1.90	111.7	0	10.6	1.93	117
DEADV3	20631	0.	308.	0.	0.	-296.	316.	5.	5.	0.92	0.05	0.06	16.3	0.79	145.0	-9	5.8	1.05	145
DEADV3	20631	0.	929.	0.	0.	-681.	1107.	5.	101.	2.51	0.05	0.31	70.2	3.41	238.3	0	13.2	2.39	130
DEHTPM	20631	0.	299.	0.	0.	-287.	316.	5.	5.	0.95	0.05	0.09	16.2	0.79	147.4	-8	5.7	1.04	148
DEHTPM	20631	0.	537.	0.	0.	-396.	749.	5.	57.	1.80	0.05	0.40	42.8	2.08	238.3	0	8.4	1.52	127
DESOA3	20631	311.	0.	0.	0.	-311.	12.	5.	5.	0.91	0.05	0.05	15.5	0.75	136.8	-15	6.4	1.17	148
DESOA3	20631	1072.	0.	0.	0.	-1072.	278.	5.	113.	3.19	0.05	0.28	96.0	4.67	285.3	0	19.7	3.57	151
DESOA3	20631	0.	311.	0.	0.	-299.	316.	5.	5.	0.91	0.05	0.05	15.5	0.75	136.8	-8	5.7	1.04	145
DESOA3	20631	0.	1072.	0.	0.	-794.	1209.	5.	113.	3.19	0.05	0.28	96.0	4.67	285.3	0	17.2	3.13	140
GTSOAD	20631	302.	0.	0.	0.	-302.	12.	5.	5.	0.82	0.05	0.08	12.9	0.63	116.3	-9	5.9	1.08	154
GTSOAD	20631	496.	0.	0.	0.	-496.	104.	5.	42.	1.07	0.05	0.32	20.0	0.97	119.1	-67	5.9	1.26	130
GTRA08	20631	303.	0.	0.	0.	-303.	12.	5.	5.	0.83	0.05	0.08	13.8	0.67	124.5	-10	6.1	1.10	153
GTRA08	20631	627.	0.	0.	0.	-627.	161.	5.	66.	1.40	0.05	0.36	32.0	1.56	155.5	0	8.7	1.57	129
GTRA12	20631	302.	0.	0.	0.	-302.	12.	5.	5.	0.83	0.05	0.08	13.8	0.67	123.9	-10	6.1	1.10	153
GTRA12	20631	620.	0.	0.	0.	-620.	159.	5.	65.	1.37	0.05	0.36	30.7	1.49	150.5	0	8.4	1.53	129
GTRA16	20631	302.	0.	0.	0.	-302.	12.	5.	5.	0.84	0.05	0.06	14.0	0.68	125.9	-11	6.1	1.11	153
GTRA16	20631	600.	0.	0.	0.	-600.	151.	5.	61.	1.37	0.05	0.36	31.1	1.51	156.8	0	8.5	1.54	129
GTR208	20631	303.	0.	0.	0.	-303.	12.	5.	5.	0.83	0.05	0.08	13.5	0.66	121.7	-10	6.0	1.10	153
GTR208	20631	551.	0.	0.	0.	-551.	127.	5.	52.	1.22	0.05	0.34	25.2	1.22	137.0	0	7.7	1.40	128
GTR212	20631	303.	0.	0.	0.	-303.	12.	5.	5.	0.83	0.05	0.08	13.6	0.66	122.8	-10	6.1	1.10	153
GTR212	20631	574.	0.	0.	0.	-574.	136.	5.	56.	1.27	0.05	0.34	27.0	1.31	141.6	0	8.0	1.45	128
GTR216	20631	302.	0.	0.	0.	-302.	12.	5.	5.	0.83	0.05	0.08	13.7	0.67	123.8	-10	6.1	1.10	153
GTR216	20631	575.	0.	0.	0.	-575.	139.	5.	57.	1.31	0.05	0.35	28.6	1.39	149.7	0	8.1	1.48	128

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																			
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM ENRG	WRTH
GTRW08	20631	307.	0.	0.	-307.	12.	316.	5.	5.	0.84	0.05	0.06	13.9	0.68	123.7	-11	6.1	1.11	151
GTRW03	20631	767.	0.	0.	-767.	194.	926.	5.	79.	1.44	0.05	0.31	32.2	1.57	130.3	0	9.6	1.75	128
GTRW12	20631	306.	0.	0.	-306.	12.	316.	5.	5.	0.83	0.05	0.07	13.9	0.68	124.0	-11	6.1	1.11	152
GTRW12	20631	764.	0.	0.	-764.	200.	946.	5.	81.	1.45	0.05	0.33	32.7	1.59	133.0	0	9.5	1.72	129
GTRW16	20631	306.	0.	0.	-306.	12.	316.	5.	5.	0.84	0.05	0.07	14.1	0.68	125.7	-11	6.1	1.11	151
GTRW16	20631	731.	0.	0.	-731.	188.	906.	5.	77.	1.44	0.05	0.33	32.7	1.59	138.2	0	9.4	1.70	128
GTR308	20631	307.	0.	0.	-307.	12.	316.	5.	5.	0.83	0.05	0.06	13.6	0.66	120.6	-10	6.1	1.11	152
GTR308	20631	654.	0.	0.	-654.	146.	765.	5.	59.	1.28	0.05	0.28	26.7	1.30	124.9	0	8.7	1.58	124
GTR312	20631	305.	0.	0.	-305.	12.	316.	5.	5.	0.83	0.05	0.07	13.6	0.66	122.0	-10	6.1	1.10	152
GTR312	20631	680.	0.	0.	-680.	167.	837.	5.	68.	1.33	0.05	0.32	28.5	1.39	128.6	0	8.7	1.58	127
GTR316	20631	306.	0.	0.	-306.	12.	316.	5.	5.	0.84	0.05	0.07	13.8	0.67	123.7	-11	6.1	1.11	152
GTR316	20631	676.	0.	0.	-676.	165.	829.	5.	67.	1.35	0.05	0.32	29.4	1.43	133.1	0	8.9	1.61	127
FCPADS	20631	311.	0.	0.	-311.	12.	316.	5.	5.	0.92	0.05	0.05	14.6	0.71	128.6	-14	6.4	1.15	149
FCPADS	20631	1388.	0.	0.	-1388.	379.	1547.	5.	155.	7.61	0.05	0.28	93.2	4.53	217.1	0	25.1	4.55	176
FCMCDS	20631	306.	0.	0.	-306.	12.	316.	5.	5.	0.91	0.05	0.07	14.8	0.72	132.3	-13	6.3	1.14	151
FCMCDS	20631	1013.	0.	0.	-1013.	300.	1282.	5.	122.	5.96	0.05	0.36	80.4	3.91	251.9	0	19.5	3.54	162

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	COGEN**	POWER	COGEN**	REQD	POWER	MMW	O&M	POWER	FESR	CAPITAL	NORM	\$/KW	ROI	LEVEL	NORM	ENRG	
-----FUEL USE IN BTU*10**6-----																								
**COGENERATION CASE** *NOCOGEN - COGEN**																								
*****																								
ONOCGN	20821	0.	15.	151.	0.	0.	0.	0.	6.	0.	0.63	0.24	0.	0.24	0.	0.24	0.	7.1	1.00	238.6	0	4.3	1.00	80
STM141	20821	0.	125.	0.	-111.	151.	0.	0.	6.	6.	0.61	0.24	0.24	0.24	0.24	0.24	6.9	0.98	189.7	-19	4.4	1.01	161	
STM141	20821	0.	132.	0.	-113.	163.	0.	0.	6.	8.	0.49	0.24	0.28	0.28	0.28	0.28	6.6	0.94	172.0	999	4.1	0.95	154	
STM141	20821	0.	0.	125.	0.	25.	F	6.	6.	1.07	0.24	0.24	0.24	0.24	0.24	0.24	13.6	1.92	370.1	5	4.3	0.93	145	
STM141	20821	0.	0.	132.	0.	19.	F	6.	8.	0.86	0.24	0.23	0.23	0.23	0.23	0.23	12.3	1.74	319.8	12	3.8	0.87	137	
STM141	20821	0.	0.	125.	0.	15.	A	6.	6.	0.98	0.24	0.24	0.24	0.24	0.24	0.24	11.6	1.64	316.6	10	4.0	0.92	147	
STM141	20821	0.	0.	132.	0.	19.	A	6.	8.	0.75	0.24	0.23	0.23	0.23	0.23	0.23	9.9	1.39	255.6	24	3.4	0.79	140	
STM088	20821	0.	125.	0.	-111.	150.	0.	0.	6.	6.	0.46	0.24	0.24	0.24	0.24	0.24	5.9	0.83	160.0	999	4.1	0.95	153	
STM088	20821	0.	0.	126.	0.	15.	F	6.	6.	0.82	0.24	0.24	0.24	0.24	0.24	0.24	11.4	1.61	309.6	13	3.8	0.88	135	
STM088	20821	0.	0.	126.	0.	15.	A	6.	6.	0.72	0.24	0.24	0.24	0.24	0.24	0.24	9.3	1.31	253.4	26	3.5	0.80	138	
PFBSTM	20821	0.	0.	126.	0.	15.	25.	6.	6.	1.18	0.24	0.24	0.24	0.24	0.24	0.24	15.4	2.18	419.1	2	4.6	1.06	144	
PFBSTM	20821	0.	0.	146.	0.	27.	46.	6.	11.	1.06	0.24	0.33	0.33	0.33	0.33	0.33	15.3	2.17	358.8	8	4.0	0.92	138	
TISTMT	20821	0.	126.	0.	-111.	151.	0.	0.	6.	0.95	0.24	0.24	0.24	0.24	0.24	0.24	19.9	2.81	538.1	0	6.1	1.41	149	
TISTMT	20821	0.	159.	0.	-125.	217.	0.	0.	6.	14.	1.17	0.24	0.37	0.37	0.37	0.37	33.1	4.68	709.5	0	7.3	1.69	146	
TISTMT	20821	0.	0.	126.	0.	15.	25.	6.	6.	1.47	0.24	0.24	0.24	0.24	0.24	0.24	28.3	4.00	785.8	0	6.3	1.45	145	
TISTMT	20821	0.	0.	159.	0.	35.	58.	6.	14.	1.64	0.24	0.37	0.37	0.37	0.37	0.37	42.0	5.94	900.4	0	7.2	1.65	142	
TIHRSG	20821	0.	129.	0.	-114.	144.	0.	0.	6.	5.	0.88	0.24	0.18	0.18	0.18	0.18	26.1	3.69	703.3	0	6.9	1.59	131	
TIHRSG	20821	0.	2.	133.	0.	13.	17.	6.	6.	1.27	0.24	0.18	0.18	0.18	0.18	0.18	33.7	4.76	906.5	0	6.9	1.59	128	
STIRL	20821	132.	0.	0.	-132.	15.	151.	6.	6.	0.58	0.24	0.20	0.20	0.20	0.20	0.20	7.0	1.00	182.4	193	5.2	1.20	161	
STIRL	20821	190.	0.	0.	-190.	43.	245.	6.	18.	0.58	0.24	0.34	0.34	0.34	0.34	0.34	10.9	1.54	195.6	0	5.5	1.28	145	
STIRL	20821	0.	132.	0.	-117.	151.	0.	0.	6.	0.59	0.24	0.24	0.24	0.24	0.24	0.24	7.0	1.00	182.6	-44	4.5	1.04	157	
STIRL	20821	0.	190.	0.	-147.	245.	0.	0.	6.	18.	0.58	0.24	0.34	0.34	0.34	0.34	10.9	1.54	195.8	0	4.5	1.05	140	
STIRL	20821	0.	0.	132.	0.	15.	19.	6.	6.	1.05	0.24	0.20	0.20	0.20	0.20	0.20	13.9	1.97	360.9	5	4	1.00	141	
STIRL	20821	0.	0.	190.	0.	43.	55.	6.	18.	1.02	0.24	0.34	0.34	0.34	0.34	0.34	18.4	2.60	331.2	8	5.9	0.89	126	
HEGT85	20821	0.	0.	133.	0.	15.	18.	6.	6.	1.21	0.24	0.20	0.20	0.20	0.20	0.20	24.2	3.43	622.1	0	5.7	1.31	138	
HEGT85	20821	0.	0.	201.	0.	46.	56.	6.	19.	1.44	0.24	0.34	0.34	0.34	0.34	0.34	40.0	5.65	679.5	0	6.6	1.52	129	
HEGT60	20821	0.	0.	145.	0.	15.	6.	6.	6.	1.22	0.24	0.12	0.12	0.12	0.12	0.12	24.0	3.40	565.3	0	5.8	1.35	130	
HEGT60	20821	0.	0.	226.	0.	42.	16.	6.	17.	1.41	0.24	0.20	0.20	0.20	0.20	0.20	37.2	5.26	561.4	0	6.9	1.59	117	
HEGT00	20821	0.	0.	147.	0.	15.	4.	6.	6.	1.14	0.24	0.11	0.11	0.11	0.11	0.11	22.2	3.13	515.1	0	5.6	1.29	126	
HEGT00	20821	0.	0.	166.	0.	21.	6.	6.	6.	0.99	0.24	0.14	0.14	0.14	0.14	0.14	23.6	3.33	485.3	0	5.5	1.26	118	
FCMCL	20821	0.	0.	131.	0.	15.	20.	6.	6.	1.25	0.24	0.21	0.21	0.21	0.21	0.21	21.3	3.01	555.1	0	5.4	1.25	140	
FCMCL	20821	0.	0.	181.	0.	40.	53.	6.	16.	1.41	0.24	0.34	0.34	0.34	0.34	0.34	28.9	4.08	544.7	0	5.6	1.29	131	
FCSTCL	20821	0.	0.	130.	0.	15.	21.	6.	6.	1.28	0.24	0.22	0.22	0.22	0.22	0.22	20.6	2.92	543.2	0	5.4	1.24	141	
FCSTCL	20821	0.	0.	235.	0.	70.	100.	6.	28.	1.86	0.24	0.42	0.42	0.42	0.42	0.42	37.4	5.29	543.6	0	5.9	1.35	125	
IGGTST	20821	0.	0.	136.	0.	15.	15.	6.	6.	1.27	0.24	0.18	0.18	0.18	0.18	0.18	20.8	2.94	521.9	0	5.5	1.26	137	
IGGTST	20821	0.	0.	219.	0.	50.	49.	6.	20.	1.32	0.24	0.31	0.31	0.31	0.31	0.31	30.7	4.34	478.3	0	5.6	1.29	121	
GTSOAR	20821	0.	134.	0.	-119.	151.	0.	0.	6.	0.57	0.24	0.19	0.19	0.19	0.19	0.19	7.6	1.07	193.1	0	4.6	1.06	153	
GTSOAR	20821	0.	189.	0.	-150.	233.	0.	0.	6.	0.50	0.24	0.31	0.31	0.31	0.31	0.31	9.9	1.40	178.3	0	4.6	1.05	140	
GTAC08	20821	0.	132.	0.	-117.	151.	0.	0.	6.	0.54	0.24	0.20	0.20	0.20	0.20	0.20	6.9	0.97	177.7	-20	4.4	1.02	157	
GTAC08	20821	0.	169.	0.	-136.	211.	0.	0.	6.	0.45	0.24	0.31	0.31	0.31	0.31	0.31	7.9	1.12	159.6	17	4.2	0.97	147	
GTAC12	20821	0.	131.	0.	-116.	151.	0.	0.	6.	0.55	0.24	0.21	0.21	0.21	0.21	0.21	6.9	0.98	180.4	-22	4.4	1.02	157	
GTAC12	20821	0.	182.	0.	-142.	235.	0.	0.	6.	0.48	0.24	0.34	0.34	0.34	0.34	0.34	9.0	1.27	168.0	9	4.2	0.98	144	
GTAC16	20821	0.	131.	0.	-116.	151.	0.	0.	6.	0.55	0.24	0.21	0.21	0.21	0.21	0.21	7.2	1.01	186.0	-67	4.5	1.03	156	

ORIGINAL PAGE IS  
OF POOR QUALITY

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----

ECS	PROCS	**COGENERATION CASE**				**NO COGEN - COGEN**			POWER REOD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVEL CHRG	NORM ENRG	WRTH
		DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL													
GTAC16	20821	0.	192.	0.	0.	-147.	250.	6.	18.	0.51	0.24	0.35	10.0	1.42	178.7	5	4.3	1.00	140	
GTWC16	20821	0.	136.	0.	0.	-121.	151.	6.	6.	0.56	0.24	0.18	7.5	1.06	188.1	0	4.6	1.06	153	
GTWC16	20821	0.	213.	0.	0.	-165.	263.	6.	20.	0.54	0.24	0.31	10.7	1.51	170.5	0	4.7	1.08	135	
CC1626	20821	0.	135.	0.	0.	-120.	151.	6.	6.	0.65	0.24	0.18	7.7	1.08	193.6	0	4.7	1.09	153	
CC1626	20821	0.	300.	0.	0.	-214.	391.	6.	35.	0.81	0.24	0.37	15.6	2.20	176.9	0	5.2	1.21	123	
CC1622	20821	0.	134.	0.	0.	-119.	151.	6.	6.	0.64	0.24	0.19	7.4	1.04	188.4	0	4.7	1.07	155	
CC1622	20821	0.	273.	0.	0.	-195.	363.	6.	32.	0.76	0.24	0.38	14.6	2.07	182.7	0	5.0	1.15	125	
CC1222	20821	0.	134.	0.	0.	-119.	151.	6.	6.	0.64	0.24	0.19	7.2	1.02	184.4	0	4.6	1.07	155	
CC1222	20821	0.	272.	0.	0.	-194.	363.	6.	32.	0.75	0.24	0.38	14.0	1.97	175.4	0	4.9	1.12	126	
CC0822	20821	0.	131.	0.	0.	-117.	151.	6.	6.	0.64	0.24	0.21	7.4	1.04	191.4	0	4.6	1.06	156	
CC0822	20821	0.	230.	0.	0.	-166.	312.	6.	26.	0.69	0.24	0.39	12.1	1.72	180.3	1	4.5	1.04	133	
STIG15	20821	0.	154.	0.	0.	-140.	151.	6.	6.	0.62	0.24	0.07	7.7	1.09	170.0	0	5.1	1.19	141	
STIG15	20821	0.	6615.	0.	0.	-4804.	6166.	6.	739.	10.73	0.24	0.17	196.6	27.78	101.4	0	78.6	18.14	492	
STIG10	20821	0.	150.	0.	0.	-135.	151.	6.	6.	0.60	0.24	0.10	7.4	1.04	167.9	0	5.0	1.15	145	
STIG10	20821	0.	649.	0.	0.	-482.	662.	6.	68.	1.27	0.24	0.22	22.7	3.21	119.4	0	9.8	2.25	116	
STIG1S	20821	0.	147.	0.	0.	-133.	151.	6.	6.	0.60	0.24	0.11	7.2	1.02	167.3	999	4.9	1.13	147	
STIG1S	20821	0.	408.	0.	0.	-310.	430.	6.	40.	0.92	0.24	0.23	15.4	2.18	129.1	0	7.2	1.65	114	
DEADV3	20821	0.	132.	0.	0.	-118.	151.	6.	6.	0.64	0.24	0.20	9.4	1.33	242.6	0	4.8	1.11	151	
DEADV3	20821	0.	231.	0.	0.	-169.	307.	6.	25.	0.77	0.24	0.37	17.5	2.47	258.7	0	5.3	1.21	129	
DEHTPM	20821	0.	128.	0.	0.	-114.	151.	6.	6.	0.67	0.24	0.22	9.4	1.32	248.6	0	4.7	1.09	154	
DEHTPM	20821	0.	196.	0.	0.	-144.	273.	6.	21.	0.74	0.24	0.40	15.0	2.12	262.1	0	4.8	1.10	137	
DESOA3	20821	134.	0.	0.	-134.	15.	151.	6.	6.	0.63	0.24	0.19	8.8	1.25	225.7	0	5.5	1.27	155	
DESOA3	20821	235.	0.	0.	-235.	61.	305.	6.	25.	0.87	0.24	0.36	21.3	3.01	308.6	0	7.2	1.65	135	
DESOA3	20821	0.	134.	0.	0.	-119.	151.	6.	6.	0.63	0.24	0.19	8.8	1.25	225.7	0	4.8	1.10	151	
DESOA3	20821	0.	235.	0.	0.	-174.	305.	6.	25.	0.87	0.24	0.36	21.3	3.01	308.6	0	5.9	1.36	128	
GTSOAD	20821	132.	0.	0.	-132.	15.	151.	6.	6.	0.54	0.24	0.20	6.7	0.94	171.9	-70	5.1	1.18	161	
GTSOAD	20821	181.	0.	0.	-181.	38.	228.	6.	15.	0.45	0.24	0.32	8.0	1.14	151.8	0	5.2	1.20	151	
GTRA08	20821	133.	0.	0.	-133.	15.	151.	6.	6.	0.57	0.24	0.19	7.9	1.12	202.1	0	5.3	1.23	157	
GTRA08	20821	228.	0.	0.	-228.	59.	297.	6.	24.	0.60	0.24	0.36	13.0	1.83	193.8	0	6.0	1.38	138	
GTRA12	20821	133.	0.	0.	-133.	15.	151.	6.	6.	0.57	0.24	0.20	7.8	1.11	201.0	0	5.3	1.22	158	
GTRA12	20821	226.	0.	0.	-226.	58.	296.	6.	24.	0.60	0.24	0.36	13.1	1.85	197.3	0	5.9	1.37	139	
GTRA16	20821	133.	0.	0.	-133.	15.	151.	6.	6.	0.58	0.24	0.20	8.1	1.14	207.5	0	5.3	1.23	157	
GTRA16	20821	219.	0.	0.	-219.	55.	285.	6.	22.	0.60	0.24	0.36	13.3	1.87	207.0	0	6.0	1.37	139	
GTR208	20821	133.	0.	0.	-133.	15.	151.	6.	6.	0.56	0.24	0.20	7.5	1.06	191.4	0	5.3	1.22	159	
GTR208	20821	201.	0.	0.	-201.	46.	256.	6.	19.	0.53	0.24	0.34	10.5	1.49	179.3	0	5.6	1.29	144	
GTR212	20821	133.	0.	0.	-133.	15.	151.	6.	6.	0.57	0.24	0.19	7.6	1.08	195.6	0	5.3	1.22	158	
GTR212	20821	209.	0.	0.	-209.	50.	267.	6.	20.	0.55	0.24	0.34	11.4	1.61	186.0	0	5.7	1.33	142	
GTR216	20821	133.	0.	0.	-133.	15.	151.	6.	6.	0.57	0.24	0.20	7.8	1.10	199.9	0	5.3	1.22	158	
GTR216	20821	209.	0.	0.	-209.	51.	271.	6.	21.	0.57	0.24	0.35	12.0	1.70	195.6	0	5.8	1.33	141	
GTRW08	20821	139.	0.	0.	-139.	15.	151.	6.	6.	0.58	0.24	0.16	8.0	1.13	197.1	0	5.5	1.27	154	
GTRW08	20821	280.	0.	0.	-280.	71.	337.	6.	29.	0.66	0.24	0.31	14.4	2.03	175.2	0	6.9	1.60	132	
GTRW12	20821	137.	0.	0.	-137.	15.	151.	6.	6.	0.58	0.24	0.17	8.0	1.13	199.0	0	5.5	1.26	155	
GTRW12	20821	278.	0.	0.	-278.	73.	345.	6.	30.	0.66	0.24	0.33	14.6	2.06	179.1	0	6.8	1.57	132	
GTRW16	20821	137.	0.	0.	-137.	15.	151.	6.	6.	0.58	0.24	0.17	8.2	1.16	204.2	0	5.5	1.26	155	

GENERAL ELECTRIC COMPANY  
 COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
 REPORT 5.2  
 SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----

\*\*COGENERATION CASE\*\* \*\*NOCOGEN - COGEN\*\*

ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM ENRG	WRTH
GTRW16	20821	267.	0.	0.	-267.	68.	330.	6.	28.	0.66	0.24	0.33	14.6	2.07	187.2	0	6.7	1.55	133
GTR308	20821	139.	0.	0.	-139.	15.	151.	6.	6.	0.57	0.24	0.16	7.6	1.07	185.4	0	5.5	1.26	155
GTR308	20821	238.	0.	0.	-238.	53.	279.	6.	22.	0.57	0.24	0.28	11.5	1.62	164.6	0	6.4	1.48	136
GTR312	20821	137.	0.	0.	-137.	15.	151.	6.	6.	0.57	0.24	0.17	7.7	1.09	191.7	0	5.4	1.25	156
GTR312	20821	248.	0.	0.	-248.	61.	305.	6.	25.	0.60	0.24	0.32	12.5	1.76	171.5	0	6.3	1.46	136
GTR316	20821	137.	0.	0.	-137.	15.	151.	6.	6.	0.58	0.24	0.17	7.9	1.12	197.2	0	5.4	1.26	155
GTR316	20821	246.	0.	0.	-246.	60.	302.	6.	24.	0.61	0.24	0.32	12.9	1.83	178.9	0	6.4	1.48	135
FCPADS	20821	133.	0.	0.	-133.	15.	151.	6.	6.	0.92	0.24	0.20	7.6	1.07	195.4	0	5.6	1.30	161
FCPADS	20821	240.	0.	0.	-240.	66.	321.	6.	27.	2.52	0.24	0.38	16.7	2.36	237.1	0	8.2	1.89	146
FCMCDS	20821	137.	0.	0.	-137.	15.	151.	6.	6.	0.91	0.24	0.17	8.2	1.16	203.4	0	5.8	1.34	156
FCMCDS	20821	369.	0.	0.	-369.	109.	467.	6.	45.	3.91	0.24	0.36	29.3	4.14	270.6	0	12.0	2.77	147

ORIGINAL PAGE IS  
 NOT TO BE REPRODUCED



GENERAL ELECTRIC COMPANY  
 COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
 REPORT 5.2  
 SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

DATE 06/07/78  
 I&SE-PEO-ADV-DES-ENGR

ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	COGEN**	POWER	COGEN	REGD	POWER	Q&M	POWER	FESR	CAPITAL	NORM	\$/KW	ROI	LEVEL	NORM	WRTH
									RESID	RESID	RESID	RESID	RESID	RESID	RATIO	COST	COST	EOVL	(%)	CHRG	ENRG	
ONOCGN	22601	0.	15.	237.	0.	0.	0.	F	6.	0.	0.87	0.13	0.13	0.16	13.5	1.00	247.5	0	6.3	1.00	80	
STM141	22601	0.	211.	0.	-196.	237.	0.	F	6.	0.76	0.13	0.16	0.23	9.1	0.68	148.0	-9	6.5	1.04	162		
STM141	22601	0.	226.	0.	-201.	268.	0.	F	10.	0.60	0.13	0.23	0.16	8.8	0.43	132.6	-2	6.1	0.98	156		
STM141	22601	0.	0.	211.	0.	26.	0.	F	6.	1.40	0.13	0.16	0.16	19.3	1.43	313.2	5	6.3	1.00	142		
STM141	22601	0.	0.	226.	0.	42.	0.	F	10.	1.11	0.13	0.23	0.16	17.4	1.29	262.3	18	5.4	0.87	136		
STM141	22601	0.	0.	211.	0.	26.	0.	A	6.	1.29	0.13	0.16	0.23	16.7	1.24	270.4	13	5.9	0.94	144		
STM141	22601	0.	0.	226.	0.	42.	0.	A	10.	0.97	0.13	0.23	0.16	13.2	0.98	199.1	999	4.8	0.77	140		
STM088	22601	0.	211.	0.	-196.	237.	0.	F	6.	0.72	0.13	0.16	0.16	8.4	0.63	136.7	-7	6.4	1.02	164		
STM088	22601	0.	215.	0.	-197.	246.	0.	F	7.	0.57	0.13	0.16	0.16	7.8	0.58	123.6	-3	6.1	0.98	156		
STM088	22601	0.	0.	211.	0.	26.	0.	F	6.	1.32	0.13	0.16	0.16	18.0	1.34	291.6	8	6.0	0.96	143		
STM088	22601	0.	0.	215.	0.	31.	0.	F	7.	1.05	0.13	0.16	0.16	16.0	1.19	253.7	23	5.5	0.87	135		
STM088	22601	0.	0.	211.	0.	26.	0.	A	6.	1.21	0.13	0.16	0.16	15.0	1.11	242.5	28	5.6	0.89	145		
STM088	22601	0.	0.	215.	0.	31.	0.	A	7.	0.93	0.13	0.16	0.16	12.4	0.92	197.1	999	5.0	0.79	139		
STM088	22601	0.	0.	211.	0.	18.	0.	A	6.	1.48	0.13	0.16	0.16	20.6	1.53	332.6	2	6.5	1.04	141		
PFBSM	22601	0.	0.	212.	0.	25.	0.	F	6.	1.45	0.13	0.29	0.16	21.3	1.58	289.1	10	5.7	0.91	132		
PFBSM	22601	0.	0.	252.	0.	65.	0.	F	16.	1.11	0.13	0.16	0.16	23.2	1.72	375.2	0	8.4	1.34	146		
T1STMT	22601	0.	211.	0.	-196.	237.	0.	F	6.	1.63	0.13	0.16	0.16	48.8	3.62	609.6	0	10.9	1.75	137		
T1STMT	22601	0.	273.	0.	-221.	360.	0.	F	21.	1.78	0.13	0.16	0.16	34.8	2.58	562.3	0	8.3	1.33	138		
T1STMT	22601	0.	0.	211.	0.	25.	0.	F	6.	2.27	0.13	0.16	0.16	62.0	4.60	774.1	0	10.4	1.66	132		
T1STMT	22601	0.	0.	273.	0.	87.	0.	F	21.	1.24	0.13	0.16	0.16	32.0	2.37	495.0	0	9.6	1.54	140		
TIHRSG	22601	0.	221.	0.	-205.	237.	0.	F	6.	1.34	0.13	0.17	0.16	42.2	3.13	595.3	0	10.7	1.71	133		
TIHRSG	22601	0.	242.	0.	-217.	268.	0.	F	10.	1.93	0.13	0.12	0.16	44.6	3.31	690.7	0	9.7	1.54	135		
TIHRSG	22601	0.	0.	221.	0.	16.	0.	F	6.	1.93	0.13	0.12	0.16	54.2	4.02	765.5	0	10.4	1.67	129		
TIHRSG	22601	0.	0.	242.	0.	26.	0.	F	10.	0.73	0.13	0.17	0.16	10.0	0.74	153.7	-30	8.0	1.27	159		
STIRL	22601	222.	0.	0.	-222.	15.	0.	F	6.	0.84	0.13	0.26	0.16	18.4	1.37	187.5	0	9.4	1.49	135		
STIRL	22601	335.	0.	0.	-335.	62.	0.	F	25.	0.73	0.13	0.12	0.16	10.0	0.74	153.8	-15	6.8	1.09	155		
STIRL	22601	0.	222.	0.	-207.	237.	0.	F	6.	1.35	0.13	0.26	0.16	18.4	1.37	187.8	0	7.6	1.22	128		
STIRL	22601	0.	335.	0.	-273.	394.	0.	F	25.	0.84	0.13	0.16	0.16	19.9	1.47	305.0	3	6.4	1.02	136		
STIRL	22601	0.	0.	222.	0.	15.	0.	F	6.	1.54	0.13	0.26	0.16	32.5	2.41	330.6	3	6.6	1.06	113		
STIRL	22601	0.	0.	335.	0.	59.	0.	F	25.	1.50	0.13	0.05	0.16	29.8	2.21	424.5	0	7.9	1.26	125		
HEGT85	22601	0.	0.	240.	0.	-3.	0.	A	6.	4.42	0.13	0.16	0.16	126.2	9.36	423.0	0	18.5	2.96	115		
HEGT85	22601	0.	0.	1018.	0.	-46.	0.	A	96.	1.49	0.13	0.06	0.16	29.0	2.15	417.0	0	7.8	1.24	126		
HEGT60	22601	0.	0.	237.	0.	-1.	0.	A	6.	2.41	0.13	0.15	0.16	65.5	4.86	443.1	0	11.5	1.84	99		
HEGT60	22601	0.	0.	504.	0.	94.	0.	A	38.	1.46	0.13	0.06	0.16	27.7	2.06	400.7	0	7.6	1.21	127		
HEGT00	22601	0.	0.	236.	0.	15.	0.	A	6.	1.51	0.13	0.12	0.16	37.5	2.78	400.2	0	8.3	1.32	109		
HEGT00	22601	0.	0.	320.	0.	40.	0.	A	16.	1.52	0.13	0.14	0.16	27.0	2.00	424.9	0	7.4	1.18	136		
FCMCLL	22601	0.	0.	217.	0.	15.	0.	F	6.	2.15	0.13	0.34	0.16	44.7	3.31	457.3	0	8.1	1.29	118		
FCMCLL	22601	0.	0.	333.	0.	73.	0.	F	30.	1.55	0.13	0.15	0.16	26.3	1.95	416.4	0	7.3	1.17	137		
FCSTCL	22601	0.	0.	215.	0.	15.	0.	F	6.	2.67	0.13	0.40	0.16	54.4	4.04	460.3	0	8.3	1.33	116		
FCSTCL	22601	0.	0.	404.	0.	112.	0.	F	46.	1.54	0.13	0.12	0.16	26.3	1.95	402.6	0	7.4	1.18	134		
IGGTST	22601	0.	0.	223.	0.	15.	0.	F	6.	1.74	0.13	0.29	0.16	43.5	3.23	394.6	0	7.8	1.25	110		
IGGTST	22601	0.	0.	376.	0.	78.	0.	F	32.	0.68	0.13	0.12	0.16	9.8	0.72	150.1	-13	6.7	1.08	156		
GTSUAR	22601	0.	222.	0.	-207.	237.	0.	F	6.	0.72	0.13	0.29	0.16	15.9	1.18	147.7	0	7.1	1.14	128		
GTSUAR	22601	0.	355.	0.	-290.	441.	0.	F	31.	0.72	0.13	0.29	0.16	15.9	1.18	147.7	0	7.1	1.14	128		

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----

\*\*COGENERATION CASE\*\* \*\*NOCOGEN - COGEN\*\*

ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQLV	ROI (%)	LEVEL CHRG	NORM WRTH ENRG
GTAC08	22601	0.	217.	0.	0.	-202.	237.	6.	6.	0.66	0.13	0.14	9.1	0.67	142.6	-9	6.5	1.04 159
GTAC08	22601	0.	308.	0.	0.	-248.	386.	6.	24.	0.62	0.13	0.31	12.3	0.91	136.9	-6	6.3	1.00 129
GTAC12	22601	0.	217.	0.	0.	-202.	237.	6.	6.	0.66	0.13	0.14	9.1	0.67	142.8	-9	6.6	1.05 159
GTAC12	22601	0.	340.	0.	0.	-265.	435.	6.	30.	0.68	0.13	0.33	14.4	1.07	144.7	0	6.4	1.03 133
GTAC16	22601	0.	218.	0.	0.	-203.	237.	6.	6.	0.67	0.13	0.14	9.3	0.69	145.6	-10	6.6	1.05 158
GTAC16	22601	0.	363.	0.	0.	-279.	468.	6.	34.	0.73	0.13	0.34	16.4	1.21	153.8	0	6.6	1.06 129
GTWC16	22601	0.	221.	0.	0.	-206.	237.	6.	6.	0.68	0.13	0.12	9.6	0.71	148.1	-12	6.7	1.07 156
GTWC16	22601	0.	391.	0.	0.	-302.	482.	6.	36.	0.75	0.13	0.32	16.5	1.22	144.0	0	7.1	1.13 126
CC1626	22601	0.	221.	0.	0.	-206.	237.	6.	6.	0.76	0.13	0.12	9.7	0.72	149.0	-14	6.8	1.09 156
CC1626	22601	0.	516.	0.	0.	-374.	659.	6.	58.	1.05	0.13	0.36	22.4	1.66	148.0	0	7.8	1.24 121
CC1622	22601	0.	220.	0.	0.	-205.	237.	6.	6.	0.75	0.13	0.13	9.4	0.70	145.9	-13	6.8	1.08 157
CC1622	22601	0.	470.	0.	0.	-343.	612.	6.	52.	1.01	0.13	0.36	21.6	1.60	156.5	0	7.4	1.19 122
CC1222	22601	0.	220.	0.	0.	-204.	237.	6.	6.	0.74	0.13	0.13	9.2	0.68	143.1	-12	6.7	1.07 158
CC1222	22601	0.	466.	0.	0.	-340.	610.	6.	52.	0.99	0.13	0.37	20.5	1.52	149.8	0	7.2	1.16 123
CC0822	22601	0.	217.	0.	0.	-202.	237.	6.	6.	0.75	0.13	0.14	9.4	0.70	147.3	-12	6.7	1.07 159
CC0822	22601	0.	394.	0.	0.	-293.	524.	6.	41.	0.89	0.13	0.37	17.4	1.29	150.6	0	6.7	1.07 128
ST1G15	22601	0.	241.	0.	0.	-225.	237.	6.	6.	0.72	0.13	0.05	9.6	0.71	136.5	-18	7.2	1.15 148
ST1G15	22601	0.	12154.	0.	0.	-8826.	11328.	6.	1357.	18.28	0.13	0.17	345.3	25.61	96.9	0	135.9	21.70 581
ST1G10	22601	0.	236.	0.	0.	-220.	237.	6.	6.	0.70	0.13	0.07	9.3	0.69	134.9	-16	7.0	1.12 151
ST1G10	22601	0.	1192.	0.	0.	-885.	1216.	6.	126.	2.02	0.13	0.22	39.8	2.95	114.0	0	16.1	2.57 124
ST1G15	22601	0.	233.	0.	0.	-218.	237.	6.	6.	0.70	0.13	0.07	9.2	0.68	134.6	-15	7.0	1.11 152
ST1G15	22601	0.	750.	0.	0.	-569.	790.	6.	74.	1.36	0.13	0.23	24.2	1.80	110.3	0	11.2	1.79 115
DEADV3	22601	0.	228.	0.	0.	-213.	237.	6.	6.	0.77	0.13	0.09	12.1	0.90	180.9	-35	7.2	1.16 148
DEADV3	22601	0.	733.	0.	0.	-538.	840.	6.	80.	1.84	0.13	0.29	53.4	3.96	248.5	0	13.5	2.16 120
DEHTPM	22601	0.	217.	0.	0.	-202.	237.	6.	6.	0.81	0.13	0.14	12.2	0.90	191.7	-30	7.0	1.12 153
DEHTPM	22601	0.	368.	0.	0.	-279.	483.	6.	36.	1.16	0.13	0.36	28.0	2.07	259.6	0	8.1	1.30 124
DES0A3	22601	232.	0.	0.	-232.	15.	237.	6.	6.	0.76	0.13	0.08	11.6	0.86	171.2	-55	8.4	1.35 153
DES0A3	22601	870.	0.	0.	-870.	226.	942.	6.	92.	2.43	0.13	0.25	75.9	5.63	297.4	0	22.3	3.56 146
DES0A3	22601	0.	232.	0.	0.	-217.	237.	6.	6.	0.76	0.13	0.08	11.6	0.86	171.2	-30	7.3	1.16 148
DES0A3	22601	0.	870.	0.	0.	-644.	942.	6.	92.	2.43	0.13	0.25	75.9	5.63	297.4	0	17.8	2.84 128
GTS0AD	22601	219.	0.	0.	-219.	15.	237.	6.	6.	0.66	0.13	0.13	8.8	0.65	137.5	-21	7.7	1.23 163
GTS0AD	22601	341.	0.	0.	-341.	72.	426.	6.	29.	0.64	0.13	0.31	12.8	0.95	128.5	-97	8.2	1.30 142
GTRA08	22601	221.	0.	0.	-221.	15.	237.	6.	6.	0.68	0.13	0.12	10.0	0.74	154.2	-28	7.9	1.26 160
GTRA08	22601	456.	0.	0.	-456.	117.	578.	6.	48.	0.89	0.13	0.34	21.4	1.59	160.1	0	9.9	1.57 130
GTRA12	22601	220.	0.	0.	-220.	15.	237.	6.	6.	0.68	0.13	0.13	9.9	0.74	153.8	-28	7.9	1.25 160
GTRA12	22601	445.	0.	0.	-445.	115.	569.	6.	47.	0.89	0.13	0.35	21.6	1.60	165.2	0	9.7	1.55 131
GTRA16	22601	220.	0.	0.	-220.	15.	237.	6.	6.	0.69	0.13	0.13	10.2	0.76	158.0	-29	7.9	1.26 160
GTRA16	22601	427.	0.	0.	-427.	107.	545.	6.	44.	0.89	0.13	0.34	21.7	1.61	173.7	0	9.7	1.54 131
GTR208	22601	220.	0.	0.	-220.	15.	237.	6.	6.	0.68	0.13	0.13	9.6	0.71	148.7	-26	7.8	1.25 161
GTR208	22601	387.	0.	0.	-387.	89.	484.	6.	36.	0.76	0.13	0.32	17.1	1.26	150.3	0	9.0	1.44 134
GTR212	22601	220.	0.	0.	-220.	15.	237.	6.	6.	0.68	0.13	0.13	9.8	0.72	151.2	-27	7.8	1.25 161
GTR212	22601	403.	0.	0.	-403.	96.	506.	6.	39.	0.80	0.13	0.33	18.4	1.37	156.1	0	9.2	1.47 133
GTR216	22601	220.	0.	0.	-220.	15.	237.	6.	6.	0.68	0.13	0.13	9.9	0.73	153.7	-27	7.8	1.25 160
GTR216	22601	404.	0.	0.	-404.	98.	514.	6.	40.	0.83	0.13	0.34	19.6	1.45	165.3	0	9.3	1.48 132

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----

\*\*COGENERATION CASE\*\* \*\*NOCOGEN - COGEN\*\*

ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVEL CHRG	NORM ENRG	WRTH
GTRW08	22601	226.	0.	0.	-226.	15.	237.	6.	6.	0.69	0.13	0.10	10.1	0.75	152.2	-31	8.0	1.28	158
GTRW08	22601	555.	0.	0.	-555.	140.	654.	6.	57.	0.96	0.13	0.30	23.2	1.72	142.5	0	11.5	1.84	128
GTRW12	22601	224.	0.	0.	-224.	15.	237.	6.	6.	0.69	0.13	0.11	10.1	0.75	153.3	-30	8.0	1.27	158
GTRW12	22601	545.	0.	0.	-545.	143.	663.	6.	58.	0.96	0.13	0.32	23.4	1.73	146.4	0	11.1	1.77	129
GTRW16	22601	224.	0.	0.	-224.	15.	237.	6.	6.	0.69	0.13	0.11	10.3	0.75	156.7	-32	8.0	1.28	158
GTRW16	22601	517.	0.	0.	-517.	133.	630.	6.	54.	0.95	0.13	0.32	23.2	1.72	153.4	0	10.9	1.74	129
GTR308	22601	228.	0.	0.	-228.	15.	237.	6.	6.	0.68	0.13	0.10	9.7	0.72	145.1	-29	8.0	1.28	158
GTR308	22601	480.	0.	0.	-480.	107.	544.	6.	44.	0.83	0.13	0.26	18.9	1.40	134.2	0	10.8	1.72	128
GTR312	22601	223.	0.	0.	-223.	15.	237.	6.	6.	0.68	0.13	0.11	9.8	0.72	149.3	-28	7.9	1.27	159
GTR312	22601	472.	0.	0.	-472.	116.	574.	6.	47.	0.85	0.13	0.32	19.7	1.46	142.1	0	10.1	1.62	130
GTR316	22601	224.	0.	0.	-224.	15.	237.	6.	6.	0.69	0.13	0.11	10.0	0.74	152.8	-29	8.0	1.27	159
GTR316	22601	469.	0.	0.	-469.	114.	568.	6.	47.	0.87	0.13	0.31	20.3	1.51	147.9	0	10.2	1.63	129
FPCADS	22601	230.	0.	0.	-230.	15.	237.	6.	6.	1.04	0.13	0.09	10.3	0.77	153.0	-40	8.5	1.36	157
FPCADS	22601	929.	0.	0.	-929.	254.	1036.	6.	104.	8.93	0.13	0.28	61.2	4.54	224.8	0	27.2	4.35	171
FCCMDS	22601	223.	0.	0.	-223.	15.	237.	6.	6.	1.01	0.13	0.11	10.6	0.79	162.0	-39	8.3	1.33	159
FCCMDS	22601	678.	0.	0.	-678.	201.	858.	6.	82.	6.75	0.13	0.36	52.6	3.90	264.5	0	20.3	3.23	155

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																				
**COGENERATION CASE** **NOCOGEN - COGEN**																				
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD	COGEN POWER	O&M	POWER /HEAT	FESR	CAPITAL COST	NORM COST	\$/KW EQVL	ROI (%)	LEVEL CHRGR	NORM ENRG	WRTH	
								MW	MW				*10**6							
ONOCGN	24211	0.	4.	12.	0.	0.	0.	2.	0.	0.21	0.17	0.	1.8	1.00	174.4	0	0.6	1.00	80	
STM141	24211	0.	0.	0.	0.	4.	12.	2.	2.	0.38	0.17	0.99	3.3	1.81	270.3	0	0.7	1.18	245	
STM141	24211	0.	1.	0.	0.	3.	14.	2.	2.	0.30	0.17	0.95	3.1	1.70	248.5	5	0.6	1.00	225	
STM141	24211	0.	0.	0.	0.	4.	12.	F	2.	2.	0.62	0.17	0.99	6.1	3.38	503.5	0	1.3	2.05	256
STM141	24211	0.	0.	1.	0.	4.	13.	F	2.	2.	0.49	0.17	0.95	5.5	3.02	441.9	0	1.1	1.70	232
STM141	24211	0.	0.	0.	0.	4.	12.	A	2.	2.	0.56	0.17	0.99	5.5	3.06	456.4	0	1.2	1.85	252
STM141	24211	0.	0.	1.	0.	4.	13.	A	2.	2.	0.42	0.17	0.95	4.8	2.65	386.8	0	0.9	1.48	229
STM088	24211	0.	1.	2.	0.	3.	10.		2.	1.	0.29	0.17	0.81	2.6	1.45	222.7	6	0.6	0.98	211
STM088	24211	0.	1.	2.	0.	3.	10.	F	2.	1.	0.47	0.17	0.81	5.0	2.76	422.4	0	1.1	1.68	216
STM088	24211	0.	1.	2.	0.	3.	10.	A	2.	1.	0.41	0.17	0.81	4.5	2.48	379.7	0	0.9	1.49	213
PFBSTM	24211	0.	0.	0.	0.	4.	12.		2.	2.	0.67	0.17	0.98	7.5	4.16	617.2	0	1.5	2.36	259
PFBSTM	24211	0.	0.	6.	0.	7.	17.		2.	3.	0.53	0.17	0.80	7.3	4.02	526.0	0	1.2	1.97	213
TISTMT	24211	0.	20.	0.	0.	-16.	12.		2.	2.	0.53	0.17	-0.26	8.4	4.64	688.3	0	1.7	2.75	113
TISTMT	24211	0.	0.	0.	0.	4.	12.		2.	2.	0.81	0.17	0.98	12.2	6.77	1004.1	0	2.1	3.40	281
TISTMT	24211	0.	0.	10.	0.	9.	21.		2.	4.	0.83	0.17	0.76	18.1	10.01	1209.2	0	2.6	4.22	250
TIHRSG	24211	0.	36.	0.	0.	-33.	12.		2.	2.	0.52	0.17	-1.27	11.0	6.12	859.0	0	2.2	3.52	3
TIHRSG	24211	0.	0.	3.	0.	4.	10.		2.	2.	0.78	0.17	0.83	15.0	8.33	1169.0	0	2.4	3.87	273
TIHRSG	24211	0.	0.	5.	0.	5.	11.		2.	2.	0.67	0.17	0.75	16.0	8.90	1186.8	0	2.4	3.84	250
STIRL	24211	20.	0.	0.	-20.	4.	12.		2.	2.	0.35	0.17	-0.25	2.9	1.62	225.1	0	1.0	1.62	103
STIRL	24211	0.	20.	0.	0.	-16.	12.		2.	2.	0.35	0.17	-0.25	2.9	1.62	225.2	0	1.0	1.52	100
STIRL	24211	0.	0.	3.	0.	4.	9.		2.	2.	0.61	0.17	0.81	6.3	3.51	489.0	0	1.3	2.08	234
STIRL	24211	0.	0.	22.	0.	12.	17.		2.	5.	0.50	0.17	0.56	6.7	3.71	360.7	0	1.1	1.74	167
HEGT85	24211	0.	0.	7.	0.	4.	5.	A	2.	2.	0.66	0.17	0.53	10.7	5.91	747.3	0	1.9	2.98	216
HEGT85	24211	0.	0.	177.	0.	50.	-8.	A	2.	20.	1.46	0.17	0.19	42.3	23.47	663.4	0	5.8	9.19	271
HEGT60	24211	0.	0.	7.	0.	4.	5.	A	2.	2.	0.65	0.17	0.57	10.3	5.73	734.2	0	1.8	2.90	219
HEGT60	24211	0.	0.	58.	0.	18.	4.	A	2.	8.	0.79	0.17	0.28	20.8	11.55	717.4	0	3.0	4.74	185
HEGT00	24211	0.	0.	6.	0.	4.	6.	A	2.	2.	0.62	0.17	0.60	9.7	5.36	693.3	0	1.7	2.73	219
HEGT00	24211	0.	0.	20.	0.	8.	6.	A	2.	3.	0.51	0.17	0.41	11.7	6.46	651.8	0	1.8	2.84	179
FCMCCL	24211	0.	0.	63.	0.	14.	-17.		2.	6.	0.65	0.17	-0.05	13.8	7.63	741.5	0	2.3	3.70	128
FCSTCL	24211	0.	0.	75.	0.	21.	-6.		2.	8.	0.83	0.17	0.16	16.5	9.13	746.3	0	2.7	4.22	156
IGGTST	24211	0.	0.	70.	0.	14.	-22.		2.	6.	0.75	0.17	-0.13	14.2	7.88	691.8	0	2.5	4.01	124
GTSOAR	24211	0.	18.	0.	0.	-14.	12.		2.	2.	0.34	0.17	-0.10	3.4	1.89	264.0	0	1.0	1.53	116
GTAC08	24211	0.	19.	0.	0.	-15.	12.		2.	2.	0.33	0.17	-0.19	3.1	1.71	245.8	0	0.9	1.49	107
GTAC12	24211	0.	17.	0.	0.	-13.	12.		2.	2.	0.33	0.17	-0.05	3.1	1.70	243.8	0	0.9	1.43	122
GTAC16	24211	0.	16.	0.	0.	-12.	12.		2.	2.	0.33	0.17	0.01	3.1	1.73	248.0	0	0.9	1.42	129
GTWC16	24211	0.	16.	0.	0.	-13.	12.		2.	2.	0.34	0.17	-0.02	3.3	1.85	259.6	0	0.9	1.48	126
CC1626	24211	0.	14.	0.	0.	-10.	12.		2.	2.	0.40	0.17	0.15	3.4	1.88	263.9	0	1.0	1.54	148
CC1622	24211	0.	14.	0.	0.	-10.	12.		2.	2.	0.40	0.17	0.14	3.2	1.80	254.0	0	0.9	1.51	146
CC1222	24211	0.	14.	0.	0.	-10.	12.		2.	2.	0.39	0.17	0.14	3.2	1.75	247.9	0	0.9	1.49	147
CC0822	24211	0.	15.	0.	0.	-11.	12.		2.	2.	0.40	0.17	0.08	3.3	1.82	261.4	0	1.0	1.54	140
STIG15	24211	0.	13.	0.	0.	-10.	12.		2.	2.	0.35	0.17	0.16	3.5	1.92	243.1	0	0.9	1.45	147
STIG10	24211	0.	14.	0.	0.	-11.	12.		2.	2.	0.35	0.17	0.11	3.3	1.84	239.5	0	0.9	1.44	141
STIG15	24211	0.	15.	0.	0.	-12.	12.		2.	2.	0.35	0.17	0.05	3.3	1.81	238.8	0	0.9	1.45	133

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																			
**COGENERATION CASE** **NOCOGEN - COGEN**																			
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD	COGEN POWER	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVEL CHRG	NORM WRTH ENRG	
DEADV3	24211	0.	14.	0.	0.	-10.	12.	2.	2.	0.39	0.17	0.14	4.5	2.47	333.3	0	1.1	1.69	145
DEHTPM	24211	0.	15.	0.	0.	-12.	12.	2.	2.	0.41	0.17	0.04	4.5	2.50	358.3	0	1.1	1.76	134
DESOA3	24211	14.	0.	0.	-14.	4.	12.	2.	2.	0.36	0.17	0.11	3.4	1.89	249.8	0	1.0	1.55	144
DESOA3	24211	0.	14.	0.	0.	-10.	12.	2.	2.	0.36	0.17	0.11	3.4	1.89	249.8	0	0.9	1.48	142
GTSOAD	24211	18.	0.	0.	-13.	4.	12.	2.	2.	0.33	0.17	-0.10	3.0	1.66	236.4	0	1.0	1.53	119
GTRA08	24211	14.	0.	0.	-14.	4.	12.	2.	2.	0.34	0.17	0.10	3.5	1.95	274.0	0	1.0	1.54	142
GTRA12	24211	14.	0.	0.	-14.	4.	12.	2.	2.	0.34	0.17	0.11	3.4	1.90	268.3	0	1.0	1.52	142
GTRA16	24211	15.	0.	0.	-15.	4.	12.	2.	2.	0.34	0.17	0.08	3.5	1.96	276.0	0	1.0	1.55	139
GTR208	24211	16.	0.	0.	-16.	4.	12.	2.	2.	0.34	0.17	0.00	3.3	1.85	260.2	0	1.0	1.55	130
GTR212	24211	16.	0.	0.	-16.	4.	12.	2.	2.	0.34	0.17	0.03	3.4	1.88	264.8	0	1.0	1.55	133
GTR216	24211	15.	0.	0.	-15.	4.	12.	2.	2.	0.34	0.17	0.05	3.4	1.89	267.7	0	1.0	1.55	136
GTRW08	24211	15.	0.	0.	-15.	4.	12.	2.	2.	0.35	0.17	0.09	3.6	1.98	271.1	0	1.0	1.57	140
GTRW12	24211	14.	0.	0.	-14.	4.	12.	2.	2.	0.35	0.17	0.12	3.6	1.98	273.6	0	1.0	1.55	144
GTRW16	24211	14.	0.	0.	-14.	4.	12.	2.	2.	0.35	0.17	0.10	3.7	2.03	280.5	0	1.0	1.57	142
GTR308	24211	17.	0.	0.	-17.	4.	12.	2.	2.	0.34	0.17	-0.03	3.4	1.86	252.3	0	1.0	1.58	126
GTR312	24211	15.	0.	0.	-15.	4.	12.	2.	2.	0.34	0.17	0.06	3.5	1.91	265.4	0	1.0	1.55	137
GTR316	24211	15.	0.	0.	-15.	4.	12.	2.	2.	0.34	0.17	0.06	3.5	1.97	272.3	0	1.0	1.57	136
FCPADS	24211	13.	0.	0.	-13.	4.	12.	2.	2.	0.35	0.17	0.16	3.2	1.75	234.5	0	0.9	1.48	149
FCMCDS	24211	12.	0.	0.	-12.	4.	12.	2.	2.	0.35	0.17	0.22	3.2	1.78	247.4	0	0.9	1.45	156

GENERAL ELECTRIC COMPANY  
 COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
 REPORT 5.2  
 SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

		-----FUEL USE IN BTU*10**6-----																		
		**COGENERATION CASE** **NOCOGEN - COGEN**																		
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD	COGEN POWER	O&M	POWER /HEAT	FESR	CAPITAL COST	NORM COST	\$/KW EQVL	ROI (%)	LEVEL CHRQ	NORM ENRG	WRTH	
								MW	MW		RATIO	*10**6								
ONOCGN	24361	0.	7.	25.	0.	0.	0.	A	3.	0.	0.58	0.14	0.	6.5	1.00	252.8	0	2.0	1.00	80
STM141	24361	0.	0.	0.	0.	7.	25.		3.	3.	0.51	0.14	0.99	5.3	0.81	181.0	999	1.1	0.55	248
STM141	24361	0.	1.	0.	0.	7.	26.		3.	3.	0.42	0.14	0.97	5.0	0.77	169.6	999	1.0	0.49	235
STM141	24361	0.	0.	0.	0.	7.	24.	F	3.	3.	0.88	0.14	0.99	10.5	1.61	357.8	4	2.0	1.02	243
STM141	24361	0.	0.	1.	0.	8.	25.	F	3.	3.	0.73	0.14	0.97	9.7	1.48	327.2	10	1.8	0.89	229
STM141	24361	0.	0.	0.	0.	7.	24.	A	3.	3.	0.79	0.14	0.99	8.7	1.34	297.4	12	1.7	0.88	244
STM141	24361	0.	0.	1.	0.	8.	25.	A	3.	3.	0.64	0.14	0.97	7.8	1.19	263.4	27	1.5	0.74	230
STM088	24361	0.	2.	8.	0.	5.	17.		3.	2.	0.40	0.14	0.68	4.3	0.66	153.3	999	1.1	0.55	202
STM088	24361	0.	2.	8.	0.	5.	17.	F	3.	2.	0.70	0.14	0.68	8.8	1.35	313.3	8	1.9	0.95	194
STM088	24361	0.	2.	8.	0.	5.	17.	A	3.	2.	0.61	0.14	0.68	7.3	1.12	258.3	30	1.6	0.82	195
PFBSTM	24361	0.	0.	1.	0.	7.	24.		3.	3.	1.03	0.14	0.97	12.9	1.98	437.1	0	2.4	1.23	242
PFBSTM	24361	0.	0.	13.	0.	15.	35.		3.	6.	0.88	0.14	0.79	12.4	1.90	374.3	5	2.0	1.00	198
TISTMT	24361	0.	45.	0.	0.	-37.	25.		3.	3.	0.79	0.14	-0.40	14.8	2.27	503.2	0	3.4	1.70	80
TISTMT	24361	0.	0.	1.	0.	7.	24.		3.	3.	1.24	0.14	0.98	21.9	3.35	742.4	0	3.6	1.83	249
TISTMT	24361	0.	0.	22.	0.	20.	45.		3.	8.	1.37	0.14	0.75	34.0	5.20	949.4	0	4.6	2.33	204
TIHRSG	24361	0.	0.	7.	0.	7.	18.		3.	3.	1.27	0.14	0.78	26.5	4.05	844.5	0	4.2	2.13	230
TIHRSG	24361	0.	0.	19.	0.	12.	21.		3.	5.	1.21	0.14	0.64	32.1	4.91	922.3	0	4.7	2.35	202
STIRL	24361	42.	0.	0.	-42.	7.	25.		3.	3.	0.52	0.14	-0.32	5.6	0.86	180.8	-20	2.2	1.13	97
STIRL	24361	0.	42.	0.	0.	-35.	25.		3.	3.	0.52	0.14	-0.32	5.6	0.86	180.9	-9	2.0	1.03	94
STIRL	24361	0.	0.	6.	0.	7.	18.		3.	3.	0.93	0.14	0.80	11.7	1.79	376.0	0	2.2	1.13	220
STIRL	24361	0.	0.	54.	0.	27.	36.		3.	11.	0.89	0.14	0.54	15.4	2.35	340.5	4	2.1	1.06	150
HEGT60	24361	0.	0.	16.	0.	7.	9.	A	3.	3.	1.00	0.14	0.50	17.8	2.72	522.5	0	3.1	1.58	186
HEGT60	24361	0.	0.	200.	0.	56.	-13.	A	3.	23.	1.68	0.14	0.18	45.4	6.94	516.6	0	6.4	3.22	130
HEGT00	24361	0.	0.	14.	0.	7.	11.	A	3.	3.	0.97	0.14	0.58	16.8	2.57	505.5	0	3.0	1.50	194
HEGT00	24361	0.	0.	56.	0.	20.	10.	A	3.	8.	0.94	0.14	0.34	22.6	3.46	493.7	0	3.4	1.72	144
FCMCL	24361	0.	0.	159.	0.	35.	-43.		3.	14.	1.26	0.14	-0.05	26.3	4.03	565.6	0	4.6	2.34	94
FCSTCL	24361	0.	0.	181.	0.	47.	-22.		3.	19.	1.51	0.14	0.12	30.3	4.63	571.9	0	4.9	2.47	110
IGGTST	24361	0.	0.	168.	0.	32.	-61.		3.	13.	1.14	0.14	-0.21	25.0	3.83	508.2	0	4.7	2.35	77
GTSOAR	24361	0.	35.	0.	0.	-28.	25.		3.	3.	0.49	0.14	-0.10	6.0	0.92	192.5	999	1.9	0.96	118
GTAC03	24361	0.	38.	0.	0.	-31.	25.		3.	3.	0.48	0.14	-0.19	5.5	0.85	183.6	999	1.9	0.96	110
GTAC12	24361	0.	34.	0.	0.	-26.	25.		3.	3.	0.48	0.14	-0.05	5.5	0.85	182.4	999	1.8	0.91	126
GTAC16	24361	0.	32.	0.	0.	-24.	25.		3.	3.	0.48	0.14	0.01	5.6	0.86	185.1	999	1.8	0.89	132
GTWC16	24361	0.	32.	0.	0.	-25.	25.		3.	3.	0.49	0.14	-0.02	5.9	0.90	191.3	999	1.8	0.92	129
CC1626	24361	0.	28.	0.	0.	-21.	25.		3.	3.	0.56	0.14	0.12	5.9	0.90	189.4	999	1.8	0.91	145
CC1622	24361	0.	29.	0.	0.	-21.	25.		3.	3.	0.55	0.14	0.10	5.7	0.87	184.1	999	1.8	0.90	144
CC1222	24361	0.	29.	0.	0.	-21.	25.		3.	3.	0.55	0.14	0.10	5.5	0.85	180.0	999	1.8	0.90	145
CC0822	24361	0.	31.	0.	0.	-24.	25.		3.	3.	0.55	0.14	0.03	5.7	0.87	187.3	999	1.8	0.93	136
STIG15	24361	0.	27.	0.	0.	-20.	25.		3.	3.	0.51	0.14	0.16	5.9	0.90	175.4	999	1.7	0.87	149
STIG10	24361	0.	29.	0.	0.	-21.	25.		3.	3.	0.50	0.14	0.11	5.7	0.87	173.2	999	1.7	0.87	144
STIG1S	24361	0.	31.	0.	0.	-23.	25.		3.	3.	0.50	0.14	0.05	5.6	0.86	172.8	999	1.8	0.89	137
DEADV3	24361	0.	28.	0.	0.	-20.	25.		3.	3.	0.55	0.14	0.14	7.5	1.15	234.3	7	2.0	0.99	143
DEHTPM	24361	0.	33.	0.	0.	-26.	25.		3.	3.	0.59	0.14	-0.03	7.8	1.19	253.3	0	2.1	1.07	124
DESOA3	24361	28.	0.	0.	-28.	7.	25.		3.	3.	0.53	0.14	0.11	6.5	0.99	198.4	-2	2.0	1.00	144

DATE 06/07/77  
I&SE-PEO-ADV-DES-ENGR

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----

\*\*COGENERATION CASE\*\* \*\*NOCOGEN - COGEN\*\*

ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM ENRG	WRTH
DESOA3	24361	0.	28.	0.	0.	-21.	25.	3.	3.	0.53	0.14	0.11	6.5	0.99	198.4	999	1.8	0.93	143
GTSOAD	24361	35.	0.	0.	-35.	7.	25.	3.	3.	0.48	0.14	-0.10	5.4	0.83	176.5	-5	2.0	1.00	123
GTRA08	24361	29.	0.	0.	-29.	7.	25.	3.	3.	0.49	0.14	0.10	6.1	0.94	197.1	999	1.9	0.96	144
GTRA12	24361	29.	0.	0.	-29.	7.	25.	3.	3.	0.49	0.14	0.11	6.1	0.93	195.7	999	1.9	0.96	144
GTRA16	24361	29.	0.	0.	-29.	7.	25.	3.	3.	0.49	0.14	0.08	6.2	0.95	201.2	999	1.9	0.98	141
GTR208	24361	32.	0.	0.	-32.	7.	25.	3.	3.	0.49	0.14	-0.00	5.9	0.90	190.4	-3	2.0	0.99	133
GTR212	24361	31.	0.	0.	-31.	7.	25.	3.	3.	0.49	0.14	0.03	6.0	0.92	193.6	-1	2.0	0.99	136
GTR216	24361	30.	0.	0.	-30.	7.	25.	3.	3.	0.49	0.14	0.05	6.0	0.92	196.0	999	1.9	0.98	138
GTRW08	24361	29.	0.	0.	-29.	7.	25.	3.	3.	0.50	0.14	0.09	6.2	0.95	195.9	999	1.9	0.98	142
GTRW12	24361	28.	0.	0.	-28.	7.	25.	3.	3.	0.49	0.14	0.12	6.2	0.95	197.7	999	1.9	0.96	146
GTRW16	24361	29.	0.	0.	-29.	7.	25.	3.	3.	0.50	0.14	0.10	6.4	0.97	202.4	999	1.9	0.98	143
GTR308	24361	33.	0.	0.	-33.	7.	25.	3.	3.	0.49	0.14	-0.03	5.9	0.91	185.3	-7	2.0	1.01	129
GTR312	24361	30.	0.	0.	-30.	7.	25.	3.	3.	0.49	0.14	0.06	6.0	0.92	193.1	999	1.9	0.97	140
GTR316	24361	30.	0.	0.	-30.	7.	25.	3.	3.	0.50	0.14	0.06	6.2	0.95	197.7	0	2.0	0.99	138
FCPADS	24361	27.	0.	0.	-27.	7.	25.	3.	3.	0.62	0.14	0.16	5.9	0.90	183.3	-3	2.0	0.99	152
FCMCDS	24361	25.	0.	0.	-25.	7.	25.	3.	3.	0.61	0.14	0.22	6.0	0.92	193.0	999	1.9	0.96	159





GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----

ECS	PROCS	**COGENERATION CASE**				**NOCOGEN - COGEN**				POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVEL CHRG	NORM WRTH ENRG
		DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	DISTIL	RESIDL											
CC0822	24921	0.	51.	0.	0.	-39.	43.	5.	5.	0.50	0.46	0.08	5.1	1.16	249.3	0	2.5	1.02	136	
CC0822	24921	0.	16.	37.	0.	-4.	6.	5.	0.	0.36	0.46	0.05	2.9	0.65	212.2	999	2.2	0.89	113	
STIG15	24921	0.	46.	0.	0.	-34.	43.	5.	5.	0.51	0.46	0.17	5.6	1.29	219.6	7	2.5	0.99	144	
STIG15	24921	0.	154.	0.	0.	-112.	143.	5.	17.	0.81	0.46	0.17	10.4	2.39	182.2	0	4.1	1.66	121	
STIG10	24921	0.	48.	0.	0.	-35.	43.	5.	5.	0.48	0.46	0.15	5.3	1.22	216.3	10	2.4	0.97	143	
STIG10	24921	0.	23.	28.	0.	-11.	15.	5.	2.	0.37	0.46	0.08	3.7	0.84	221.7	999	2.2	0.90	123	
STIG1S	24921	0.	51.	0.	0.	-39.	43.	5.	5.	0.47	0.46	0.09	5.1	1.18	214.6	4	2.5	1.00	137	
STIG1S	24921	0.	19.	33.	0.	-7.	10.	5.	1.	0.34	0.46	0.05	3.2	0.74	216.2	999	2.2	0.89	117	
DEADV3	24921	0.	46.	0.	0.	-34.	43.	5.	5.	0.53	0.46	0.17	7.2	1.66	311.6	0	2.6	1.06	141	
DEADV3	24921	0.	20.	32.	0.	-8.	12.	5.	1.	0.39	0.46	0.07	4.5	1.03	295.0	999	2.4	0.95	115	
DEHTPM	24921	0.	55.	0.	0.	-43.	43.	5.	5.	0.54	0.46	0.01	7.3	1.67	350.9	0	2.9	1.17	124	
DEHTPM	24921	0.	16.	38.	0.	-4.	6.	5.	0.	0.34	0.46	0.04	2.9	0.67	218.2	999	2.2	0.88	111	
DESOA3	24921	47.	0.	0.	-47.	12.	43.	5.	5.	0.51	0.46	0.15	6.5	1.50	270.7	0	2.9	1.16	143	
DESOA3	24921	13.	9.	30.	-13.	3.	14.	5.	1.	0.38	0.46	0.07	3.6	0.84	230.0	999	2.3	0.94	122	
DESOA3	24921	0.	47.	0.	0.	-35.	43.	5.	5.	0.51	0.46	0.15	6.5	1.50	270.7	0	2.6	1.04	140	
DESOA3	24921	0.	22.	30.	0.	-10.	14.	5.	1.	0.38	0.46	0.07	3.6	0.84	230.0	999	2.3	0.91	121	
GTSOAD	24921	58.	0.	0.	-58.	12.	43.	5.	5.	0.40	0.46	-0.05	4.5	1.03	216.7	0	3.0	1.19	128	
GTSOAD	24921	4.	11.	38.	-4.	1.	5.	5.	0.	0.30	0.46	0.04	2.7	0.63	205.2	999	2.2	0.87	111	
GTRA08	24921	48.	0.	0.	-48.	12.	43.	5.	5.	0.45	0.46	0.14	5.7	1.31	265.5	0	2.8	1.11	144	
GTRA03	24921	6.	11.	36.	-6.	2.	8.	5.	1.	0.33	0.46	0.06	3.2	0.74	232.4	999	2.2	0.90	114	
GTRA12	24921	48.	0.	0.	-48.	12.	43.	5.	5.	0.44	0.46	0.14	5.6	1.23	265.4	0	2.7	1.10	144	
GTRA12	24921	6.	11.	36.	-6.	2.	8.	5.	1.	0.32	0.46	0.06	3.1	0.72	226.8	999	2.2	0.89	115	
GTRA16	24921	49.	0.	0.	-49.	12.	43.	5.	5.	0.45	0.46	0.12	5.9	1.34	276.2	0	2.8	1.13	141	
GTRA16	24921	6.	11.	35.	-6.	1.	7.	5.	1.	0.32	0.46	0.05	3.1	0.72	229.1	999	2.2	0.89	113	
GTR208	24921	53.	0.	0.	-53.	12.	43.	5.	5.	0.43	0.46	0.04	5.3	1.21	249.5	0	2.9	1.16	135	
GTR208	24921	5.	11.	37.	-5.	1.	6.	5.	0.	0.31	0.46	0.04	3.0	0.68	219.2	999	2.2	0.89	112	
GTR212	24921	52.	0.	0.	-52.	12.	43.	5.	5.	0.43	0.46	0.07	5.5	1.23	257.4	0	2.9	1.15	137	
GTR212	24921	5.	11.	37.	-5.	1.	7.	5.	1.	0.32	0.46	0.05	3.0	0.69	222.2	999	2.2	0.89	112	
GTR216	24921	51.	0.	0.	-51.	12.	43.	5.	5.	0.44	0.46	0.09	5.6	1.28	264.5	0	2.8	1.14	139	
GTR216	24921	5.	11.	37.	-5.	1.	7.	5.	1.	0.32	0.46	0.05	3.0	0.70	223.3	999	2.2	0.89	113	
GTRW08	24921	49.	0.	0.	-49.	12.	43.	5.	5.	0.46	0.46	0.13	5.9	1.34	259.4	0	2.8	1.13	142	
GTRW08	24921	8.	10.	35.	-8.	2.	9.	5.	1.	0.34	0.46	0.06	3.4	0.77	235.5	999	2.3	0.91	115	
GTRW12	24921	47.	0.	0.	-47.	12.	43.	5.	5.	0.45	0.46	0.16	5.9	1.34	264.9	0	2.7	1.10	145	
GTRW12	24921	7.	10.	35.	-7.	2.	9.	5.	1.	0.33	0.46	0.06	3.4	0.77	236.9	999	2.3	0.90	116	
GTRW16	24921	48.	0.	0.	-48.	12.	43.	5.	5.	0.46	0.46	0.14	6.0	1.38	274.0	0	2.8	1.12	143	
GTRW16	24921	7.	11.	35.	-7.	2.	8.	5.	1.	0.33	0.46	0.06	3.4	0.77	239.0	999	2.3	0.90	114	
GTR308	24921	55.	0.	0.	-55.	12.	43.	5.	5.	0.44	0.46	0.01	5.4	1.25	235.9	0	3.0	1.20	131	
GTR308	24921	7.	11.	36.	-7.	1.	7.	5.	1.	0.32	0.46	0.04	3.1	0.70	218.8	999	2.2	0.90	113	
GTR312	24921	50.	0.	0.	-50.	12.	43.	5.	5.	0.44	0.46	0.10	5.5	1.27	254.6	0	2.8	1.13	140	
GTR312	24921	6.	11.	36.	-6.	2.	7.	5.	1.	0.32	0.46	0.05	3.2	0.72	227.6	999	2.2	0.89	114	
GTR316	24921	50.	0.	0.	-50.	12.	43.	5.	5.	0.45	0.46	0.10	5.7	1.32	263.3	0	2.8	1.14	139	
GTR316	24921	6.	11.	36.	-6.	1.	7.	5.	1.	0.32	0.46	0.05	3.2	0.73	231.0	999	2.2	0.90	113	
FPCPADS	24921	45.	0.	0.	-45.	12.	43.	5.	5.	0.82	0.46	0.19	5.5	1.25	234.3	0	3.0	1.20	154	
FPCPADS	24921	12.	9.	30.	-12.	3.	13.	5.	1.	0.42	0.46	0.08	3.4	0.78	218.1	999	2.3	0.94	124	

HONEYWELL PAGE PRINTING SYSTEM- P1185-02

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----

ECS	PROCS	**COGENERATION CASE**			**NO COGEN - COGEN**			POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVEL CHRG	NORM ENRG	WRTH
		DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL												
FCMCDS	24921	41.	3.	0.	-41.	12.	43.	5.	5.	0.78	0.46	0.26	5.6	1.29	260.9	0	2.9	1.15	160
FCMCDS	24921	9.	10.	33.	-9.	3.	11.	5.	1.	0.38	0.46	0.09	3.3	0.75	223.0	999	2.2	0.90	123

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																				
**COGENERATION CASE** **NOCOGEN - COGEN**																				
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REGD	COGEN POWER	Q&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM WRTH ENRG		
ONOCGN	26212	0.	123.	975.	0.	0.	0.	F	50.	0.	2.51	0.22	0.	47.9	1.00	178.0	0	33.9	1.00	80
STM141	26212	0.	761.	23.	0.	-638.	952.		50.	47.	1.41	0.22	0.29	32.3	0.67	99.5	999	28.9	0.85	162
STM141	26212	0.	7.	777.	0.	116.	198.	F	50.	47.	3.20	0.22	0.29	61.3	1.28	188.9	42	24.1	0.71	142
STM141	26212	0.	7.	777.	0.	116.	198.	A	50.	47.	2.93	0.22	0.29	42.6	0.89	131.4	999	21.8	0.64	149
STM088	26212	0.	741.	129.	0.	-618.	846.		50.	34.	1.24	0.22	0.21	25.6	0.54	82.9	999	30.6	0.90	158
STM088	26212	0.	39.	831.	0.	84.	144.	F	50.	34.	2.99	0.22	0.21	57.3	1.20	185.5	43	26.7	0.79	134
STM088	26212	0.	39.	831.	0.	84.	144.	A	50.	34.	2.83	0.22	0.21	41.0	0.86	132.7	999	24.8	0.73	141
PFBSTM	26212	0.	0.	772.	0.	123.	203.		50.	50.	4.64	0.22	0.30	63.2	1.32	191.5	34	25.4	0.75	154
PFBSTM	26212	0.	0.	803.	0.	188.	311.		50.	77.	5.13	0.22	0.36	60.9	1.27	168.3	49	22.2	0.66	148
TISTMT	26212	0.	771.	0.	0.	-648.	975.		50.	50.	3.57	0.22	0.30	105.8	2.21	321.3	0	38.6	1.14	153
TISTMT	26212	0.	824.	0.	0.	-670.	1082.		50.	63.	3.90	0.22	0.33	118.8	2.48	344.3	0	39.4	1.16	145
TISTMT	26212	0.	0.	771.	0.	123.	204.		50.	50.	5.58	0.22	0.30	140.2	2.93	425.9	4	34.4	1.02	146
TISTMT	26212	0.	0.	987.	0.	251.	418.		50.	102.	6.85	0.22	0.40	202.1	4.22	514.9	4	36.1	1.06	138
TIHRSG	26212	0.	791.	159.	0.	-668.	816.		50.	31.	3.40	0.22	0.14	105.5	2.20	328.3	0	43.5	1.28	124
TIHRSG	26212	0.	0.	856.	0.	122.	119.		50.	50.	6.06	0.22	0.22	179.8	3.75	507.9	0	40.7	1.20	126
STIRL	26212	862.	0.	0.	-862.	123.	975.		50.	50.	2.22	0.22	0.22	53.6	1.12	150.7	0	40.2	1.19	159
STIRL	26212	1006.	0.	0.	-1006.	182.	1175.		50.	74.	2.48	0.22	0.26	63.2	1.32	158.7	0	42.1	1.24	149
STIRL	26212	0.	862.	0.	0.	-739.	975.		50.	50.	2.22	0.22	0.22	53.7	1.12	150.8	0	34.2	1.01	154
STIRL	26212	0.	1006.	0.	0.	-824.	1175.		50.	74.	2.48	0.22	0.26	63.3	1.32	158.9	0	35.2	1.04	144
STIRL	26212	0.	0.	862.	0.	123.	113.		50.	50.	4.41	0.22	0.22	91.5	1.91	256.9	12	29.4	0.87	139
STIRL	26212	0.	0.	1282.	0.	296.	274.		50.	121.	5.79	0.22	0.31	150.0	3.13	313.1	7	30.7	0.90	123
HEGT85	26212	0.	0.	1022.	0.	123.	-47.	A	50.	50.	5.20	0.22	0.07	120.7	2.52	299.4	2	36.4	1.07	121
HEGT85	26212	0.	0.	6244.	0.	1522.	-584.	A	50.	621.	23.37	0.22	0.13	652.2	13.62	337.3	0	94.5	2.79	106
HEGT60	26212	0.	0.	998.	0.	123.	-23.	A	50.	50.	5.08	0.22	0.09	115.1	2.40	290.8	3	35.2	1.04	123
HEGT60	26212	0.	0.	2331.	0.	500.	-94.	A	50.	204.	8.72	0.22	0.15	213.3	4.45	271.2	0	43.3	1.28	95
HEGT00	26212	0.	0.	977.	0.	123.	-2.	A	50.	50.	4.76	0.22	0.11	109.7	2.10	258.3	6	33.0	0.97	127
HEGT00	26212	0.	0.	1244.	0.	202.	-3.	A	50.	82.	5.11	0.22	0.14	117.0	2.44	250.1	5	33.6	0.99	114
FCMCCL	26212	0.	0.	1166.	0.	123.	-191.		50.	50.	5.36	0.22	-0.06	96.8	2.02	283.2	0	36.8	1.09	109
FCMCCL	26212	0.	0.	1648.	0.	360.	122.		50.	147.	8.45	0.22	0.23	142.4	2.98	295.0	4	34.7	1.02	112
FCSTCL	26212	0.	0.	1155.	0.	123.	-150.		50.	50.	5.37	0.22	-0.05	101.8	2.13	300.7	0	37.1	1.10	109
FCSTCL	26212	0.	0.	1978.	0.	547.	418.		50.	223.	10.26	0.22	0.33	172.5	3.60	297.6	7	30.9	0.91	108
IGGTST	26212	0.	0.	1216.	0.	123.	-241.		50.	50.	4.02	0.22	-0.11	89.1	1.86	249.9	1	35.5	1.05	104
IGGTST	26212	0.	0.	1843.	0.	330.	-6.		50.	155.	4.50	0.22	0.17	137.8	2.88	255.1	6	32.1	0.95	102
GTSOAR	26212	0.	860.	0.	0.	-737.	975.		50.	50.	1.79	0.22	0.22	39.9	0.83	112.3	999	32.3	0.95	161
GTSOAR	26212	0.	1132.	0.	0.	-896.	1355.		50.	96.	2.04	0.22	0.29	48.3	1.01	110.9	999	32.8	0.97	149
GTAC08	26212	0.	814.	0.	0.	-691.	975.		50.	50.	1.71	0.22	0.26	37.1	0.77	108.5	999	30.5	0.90	167
GTAC08	26212	0.	933.	0.	0.	-752.	1171.		50.	74.	1.80	0.22	0.31	40.1	0.84	106.5	999	29.9	0.88	158
GTAC12	26212	0.	819.	0.	0.	-696.	975.		50.	50.	1.75	0.22	0.25	38.5	0.80	112.2	999	30.8	0.91	165
GTAC12	26212	0.	1034.	0.	0.	-807.	1324.		50.	92.	1.96	0.22	0.33	45.9	0.96	113.0	999	30.2	0.89	155
GTAC16	26212	0.	824.	0.	0.	-702.	975.		50.	50.	1.78	0.22	0.25	39.9	0.83	115.7	999	31.2	0.92	164
GTAC16	26212	0.	1110.	0.	0.	-852.	1427.		50.	105.	2.10	0.22	0.34	50.9	1.06	118.8	87	30.7	0.91	152
GTWC16	26212	0.	848.	0.	0.	-726.	975.		50.	50.	1.77	0.22	0.23	39.1	0.82	111.0	999	31.8	0.94	162
GTWC16	26212	0.	1186.	0.	0.	-918.	1464.		50.	110.	2.05	0.22	0.32	48.6	1.02	107.8	999	31.9	0.94	150

HONEYWELL PAGE PRINTING SYSTEM - B1185-02

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																		
**COGENERATION CASE** **NOCOGEN - COGEN**																		
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER RECD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVEL CHRG	NORM WRTH ENRG
CC1626	26212	0.	851.	0.	0.	-729.	975.	50.	50.	1.98	0.22	0.22	42.9	0.90	121.5	999	32.6	0.96 160
CC1626	26212	0.	1555.	0.	0.	-1132.	1983.	50.	173.	2.58	0.22	0.35	61.3	1.28	109.6	10	32.9	0.97 139
CC1622	26212	0.	839.	0.	0.	-717.	975.	50.	50.	1.98	0.22	0.24	43.4	0.91	124.1	999	32.3	0.95 161
CC1622	26212	0.	1418.	0.	0.	-1037.	1841.	50.	155.	2.55	0.22	0.36	62.5	1.31	120.4	12	32.2	0.95 142
CC1222	26212	0.	837.	0.	0.	-714.	975.	50.	50.	1.96	0.22	0.24	42.3	0.88	121.5	999	32.1	0.95 162
CC1222	26212	0.	1407.	0.	0.	-1027.	1834.	50.	155.	2.51	0.22	0.36	59.5	1.24	115.4	17	31.6	0.93 143
CC0822	26212	0.	818.	0.	0.	-696.	975.	50.	50.	1.86	0.22	0.25	38.4	0.80	111.9	999	31.0	0.92 166
CC0822	26212	0.	1189.	0.	0.	-887.	1575.	50.	123.	2.26	0.22	0.37	51.0	1.07	112.9	63	29.9	0.88 151
STIG15	26212	0.	1006.	0.	0.	-883.	975.	50.	50.	2.32	0.22	0.08	43.7	0.91	109.8	-42	37.7	1.11 146
STIG15	26212	0.	36923.	0.	0.	-26812.	34415.	50.	4123.	62.10	0.22	0.17	1012.1	21.14	92.7	0	507.1	14.97 413
STIG10	26212	0.	966.	0.	0.	-843.	975.	50.	50.	2.14	0.22	0.12	42.2	0.88	109.2	-24	36.1	1.07 150
STIG10	26212	0.	3623.	0.	0.	-2688.	3695.	50.	381.	6.13	0.22	0.22	115.5	2.41	99.2	0	64.8	1.91 115
STIG15	26212	0.	947.	0.	0.	-825.	975.	50.	50.	2.15	0.22	0.14	41.5	0.87	108.8	-18	35.5	1.05 152
STIG15	26212	0.	2277.	0.	0.	-1728.	2401.	50.	224.	4.21	0.22	0.23	75.4	1.57	97.8	0	48.1	1.42 123
DEADV3	26212	0.	914.	0.	0.	-791.	975.	50.	50.	2.38	0.22	0.17	60.4	1.26	162.7	0	36.7	1.08 147
DEADV3	26212	0.	2342.	0.	0.	-1717.	2655.	50.	255.	5.48	0.22	0.29	175.2	3.66	221.9	0	55.8	1.65 118
DEHTPM	26212	0.	823.	0.	0.	-701.	975.	50.	50.	2.41	0.22	0.25	59.3	1.24	171.9	5	33.8	1.00 156
DEHTPM	26212	0.	1120.	0.	0.	-857.	1446.	50.	107.	3.34	0.22	0.34	92.8	1.94	215.1	0	36.2	1.07 142
DES0A3	26212	942.	0.	0.	-942.	123.	975.	50.	50.	2.59	0.22	0.14	68.6	1.43	180.7	0	45.1	1.33 147
DES0A3	26212	2807.	0.	0.	-2807.	728.	3003.	50.	297.	7.37	0.22	0.25	248.5	5.19	268.3	0	90.8	2.68 132
DES0A3	26212	0.	942.	0.	0.	-820.	975.	50.	50.	2.59	0.22	0.14	68.6	1.43	180.7	0	38.6	1.14 143
DES0A3	26212	0.	2807.	0.	0.	-2079.	3003.	50.	297.	7.37	0.22	0.25	248.5	5.19	268.3	0	71.5	2.11 118
GTS0AD	26212	832.	0.	0.	-832.	123.	975.	50.	50.	1.70	0.22	0.24	36.4	0.76	104.8	-19	36.7	1.08 170
GTS0AD	26212	1042.	0.	0.	-1042.	219.	1297.	50.	89.	1.85	0.22	0.31	41.6	0.87	101.8	-32	37.7	1.11 161
GTRA08	26212	854.	0.	0.	-854.	123.	975.	50.	50.	1.90	0.22	0.22	44.7	0.93	126.3	-58	38.6	1.14 163
GTRA08	26212	1428.	0.	0.	-1428.	366.	1791.	50.	149.	2.61	0.22	0.34	69.7	1.46	133.6	0	44.2	1.30 146
GTRA12	26212	847.	0.	0.	-847.	123.	975.	50.	50.	1.91	0.22	0.23	45.2	0.94	128.4	-62	38.4	1.13 164
GTRA12	26212	1386.	0.	0.	-1386.	357.	1759.	50.	145.	2.57	0.22	0.34	68.2	1.42	133.7	0	43.2	1.27 147
GTRA16	26212	845.	0.	0.	-845.	123.	975.	50.	50.	1.94	0.22	0.23	46.2	0.97	131.7	-83	38.5	1.14 163
GTRA16	26212	1325.	0.	0.	-1325.	332.	1677.	50.	135.	2.57	0.22	0.34	68.5	1.43	139.3	0	42.8	1.26 148
GTR208	26212	846.	0.	0.	-846.	123.	975.	50.	50.	1.79	0.22	0.23	39.9	0.83	113.5	-28	37.7	1.11 166
GTR208	26212	1194.	0.	0.	-1194.	275.	1484.	50.	112.	2.13	0.22	0.32	51.6	1.08	113.9	0	40.3	1.19 155
GTR212	26212	847.	0.	0.	-847.	123.	975.	50.	50.	1.81	0.22	0.23	40.7	0.85	115.8	-30	37.8	1.12 166
GTR212	26212	1242.	0.	0.	-1242.	294.	1551.	50.	120.	2.21	0.22	0.33	54.8	1.14	117.2	0	40.9	1.21 153
GTR216	26212	842.	0.	0.	-842.	123.	975.	50.	50.	1.83	0.22	0.23	41.8	0.87	119.5	-34	37.8	1.11 166
GTR216	26212	1247.	0.	0.	-1247.	302.	1576.	50.	123.	2.30	0.22	0.34	58.1	1.21	123.9	J	40.9	1.21 152
GTRW08	26212	892.	0.	0.	-892.	123.	975.	50.	50.	1.90	0.22	0.19	44.2	0.92	121.2	-56	40.0	1.18 160
GTRW08	26212	1731.	0.	0.	-1731.	437.	2026.	50.	178.	2.69	0.22	0.30	71.3	1.49	116.8	0	50.2	1.48 140
GTRW12	26212	877.	0.	0.	-877.	123.	975.	50.	50.	1.89	0.22	0.20	44.2	0.92	122.6	-61	39.4	1.16 161
GTRW12	26212	1693.	0.	0.	-1693.	443.	2048.	50.	181.	2.70	0.22	0.32	71.7	1.50	119.6	0	48.4	1.43 141
GTRW16	26212	874.	0.	0.	-874.	123.	975.	50.	50.	1.91	0.22	0.20	44.9	0.94	125.0	-69	39.4	1.16 161
GTRW16	26212	1597.	0.	0.	-1597.	410.	1936.	50.	167.	2.49	0.22	0.32	63.7	1.33	111.5	0	46.3	1.37 145
GTR308	26212	907.	0.	0.	-907.	123.	975.	50.	50.	1.88	0.22	0.17	43.0	0.90	116.5	-58	40.4	1.19 159
GTR308	26212	1496.	0.	0.	-1496.	333.	1681.	50.	136.	2.25	0.22	0.26	54.9	1.15	101.3	0	47.4	1.40 146

HONEYWELL PAGE PRINTING SYSTEM - 81185-02

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																		
ECS	PRGS	**COGENERATION CASE**						**COGEN**		O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM WRTH ENRG
		DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	REQD MW	POWER MW									
GTR312	26212	859.	0.	0.	-869.	123.	975.	50.	50.	1.86	0.22	0.21	42.9	0.90	119.9	-47	38.9	1.15 163
GTR312	26212	1448.	0.	0.	-1448.	356.	1756.	50.	145.	2.27	0.22	0.31	56.0	1.17	106.1	0	44.0	1.30 149
GTR316	26212	870.	0.	0.	-870.	123.	975.	50.	50.	1.89	0.22	0.21	43.8	0.91	122.1	-54	39.1	1.15 162
GTR316	26212	1438.	0.	0.	-1438.	350.	1738.	50.	143.	2.31	0.22	0.31	57.3	1.20	109.1	0	44.2	1.30 147
FCPADS	26212	924.	0.	0.	-924.	123.	975.	50.	50.	6.71	0.22	0.16	57.1	1.19	152.6	0	47.3	1.40 156
FCPADS	26212	2824.	0.	0.	-2824.	771.	3146.	50.	314.	34.74	0.22	0.28	189.6	3.96	203.7	0	109.2	3.22 151
FCHCDS	26212	865.	0.	0.	-865.	123.	975.	50.	50.	6.39	0.22	0.21	59.1	1.24	165.6	0	45.0	1.33 160
FCHCDS	26212	2060.	0.	0.	-2060.	610.	2607.	50.	249.	26.14	0.22	0.36	164.2	3.43	232.2	0	82.1	2.42 148

HONEYWELL PAGE PRINTING SYSTEM - P1185-02

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----  
\*\*COGENERATION CASE\*\* \*\*NOCCOGEN - COOEN\*\*

ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EOVL	ROI (%)	LEVEL CHRG	NORM ENRG	WRTH
ONOCGN	26214	0.	71.	697.	0.	0.	0.	F 29.	0.	2.15	0.16	0.	40.7	1.00	193.6	0	24.1	1.00	80
STM141	26214	0.	575.	0.	0.	-504.	637.	29.	29.	1.40	0.16	0.25	24.4	0.60	100.0	999	21.6	0.90	172
STM141	26214	0.	615.	0.	0.	-520.	779.	29.	39.	1.17	0.16	0.30	24.2	0.59	94.4	999	20.7	0.86	166
STM141	26214	0.	0.	575.	0.	71.	122.	F 29.	29.	3.00	0.16	0.25	48.8	1.20	199.5	40	18.5	0.77	151
STM141	26214	0.	0.	615.	0.	96.	164.	F 29.	39.	2.75	0.16	0.30	52.2	1.28	203.9	35	17.4	0.72	142
STM141	26214	0.	0.	575.	0.	71.	122.	A 29.	29.	2.94	0.16	0.25	43.6	1.07	178.3	104	17.9	0.74	153
STM141	26214	0.	0.	615.	0.	96.	164.	A 29.	39.	2.50	0.16	0.30	37.0	0.91	144.6	999	15.5	0.64	149
STM088	26214	0.	575.	2.	0.	-504.	695.	29.	29.	1.10	0.16	0.25	21.9	0.54	89.7	999	21.1	0.88	164
STM088	26214	0.	1.	576.	0.	71.	121.	F 29.	29.	2.58	0.16	0.25	48.8	1.20	200.1	42	18.1	0.75	140
STM088	26214	0.	1.	576.	0.	71.	121.	A 29.	29.	2.42	0.16	0.25	35.6	0.87	145.9	999	16.5	0.69	146
PFBSTM	26214	0.	0.	579.	0.	71.	118.	29.	29.	3.70	0.16	0.25	51.1	1.26	208.2	28	19.5	0.81	151
PFBSTM	26214	0.	0.	716.	0.	153.	253.	29.	62.	4.26	0.16	0.36	52.2	1.28	182.7	39	16.2	0.67	143
TISTMT	26214	0.	578.	0.	0.	-507.	637.	29.	29.	2.67	0.16	0.25	73.7	1.81	300.3	0	28.3	1.18	152
TISTMT	26214	0.	676.	0.	0.	-547.	892.	29.	53.	3.39	0.16	0.34	101.2	2.48	369.2	0	30.4	1.26	145
TISTMT	26214	0.	0.	578.	0.	71.	119.	29.	29.	4.27	0.16	0.25	99.7	2.45	406.6	3	25.3	1.05	143
TISTMT	26214	0.	0.	799.	0.	203.	338.	29.	83.	5.79	0.16	0.40	169.3	4.16	546.1	2	27.9	1.16	134
TIHRSG	26214	0.	703.	0.	0.	-632.	697.	29.	29.	3.14	0.16	0.08	98.0	2.41	377.3	0	35.0	1.45	133
TIHRSG	26214	0.	614.	34.	0.	-543.	663.	29.	25.	2.92	0.16	0.16	88.9	2.18	351.6	0	32.1	1.33	130
TIHRSG	26214	0.	0.	628.	0.	71.	69.	29.	29.	4.97	0.16	0.18	131.9	3.24	507.6	0	30.4	1.26	136
TIHRSG	26214	0.	0.	686.	0.	96.	93.	29.	39.	5.07	0.16	0.22	149.5	3.67	540.1	0	31.5	1.31	128
STIRL	26214	631.	0.	0.	-631.	71.	697.	29.	29.	1.74	0.16	0.18	38.4	0.94	147.3	-82	29.4	1.22	159
STIRL	26214	817.	0.	0.	-817.	148.	954.	29.	60.	2.09	0.16	0.26	50.5	1.24	160.3	0	32.0	1.33	148
STIRL	26214	0.	631.	0.	0.	-560.	697.	29.	29.	1.74	0.16	0.18	38.4	0.94	147.4	-22	25.1	1.04	155
STIRL	26214	0.	617.	0.	0.	-669.	954.	29.	60.	2.09	0.16	0.26	50.6	1.24	160.5	0	26.3	1.09	142
STIRL	26214	0.	0.	631.	0.	71.	66.	29.	29.	3.38	0.16	0.18	64.1	1.57	245.6	13	21.3	0.89	139
STIRL	26214	0.	0.	1020.	0.	232.	214.	29.	94.	4.67	0.16	0.30	117.4	2.88	313.3	6	22.5	0.93	117
HEGT85	26214	0.	0.	724.	0.	71.	-27.	A 29.	29.	3.79	0.16	0.06	82.1	2.02	285.0	2	25.5	1.06	123
HEGT85	26214	0.	0.	4901.	0.	1190.	-457.	A 29.	485.	18.23	0.16	0.13	487.4	11.97	322.3	0	69.4	2.08	108
HEGT60	26214	0.	0.	710.	0.	71.	-13.	A 29.	29.	3.73	0.16	0.08	79.3	1.95	279.4	3	21.9	1.04	125
HEGT60	26214	0.	0.	1840.	0.	391.	-73.	A 29.	159.	7.23	0.16	0.15	179.2	4.40	291.4	0	34.0	1.41	91
HEGT00	26214	0.	0.	638.	0.	71.	-1.	A 29.	29.	3.67	0.16	0.09	75.6	1.86	269.5	4	24.2	1.01	128
HEGT00	26214	0.	0.	990.	0.	158.	-2.	A 29.	64.	4.25	0.16	0.14	98.3	2.41	268.7	2	25.6	1.06	111
FCMCCCL	26214	0.	0.	862.	0.	71.	-165.	29.	29.	4.02	0.16	-0.12	73.4	1.80	290.7	0	27.5	1.14	105
FCMCCCL	26214	0.	0.	1289.	0.	282.	113.	29.	115.	6.09	0.16	0.23	119.0	2.92	315.0	2	26.3	1.09	107
FCSTCL	26214	0.	0.	855.	0.	71.	-158.	29.	29.	3.92	0.16	-0.11	71.2	1.75	284.1	0	27.0	1.12	106
FCSTCL	26214	0.	0.	1562.	0.	436.	357.	29.	178.	8.45	0.16	0.34	145.3	3.57	317.6	5	23.4	0.97	104
IGGTST	26214	0.	0.	890.	0.	71.	-193.	29.	29.	3.32	0.16	-0.16	68.4	1.68	262.1	0	26.7	1.11	101
IGGTST	26214	0.	0.	1456.	0.	304.	22.	29.	124.	3.87	0.16	0.18	115.4	2.83	270.4	5	24.0	1.00	97
GTSOAR	26214	0.	630.	0.	0.	-559.	697.	29.	29.	1.49	0.16	0.18	31.4	0.77	120.7	-5	24.1	1.00	159
GTSOAR	26214	0.	920.	0.	0.	-728.	1101.	29.	78.	1.76	0.16	0.29	40.0	0.98	115.7	-20	24.5	1.02	145
GTAC08	26214	0.	603.	0.	0.	-532.	697.	29.	29.	1.44	0.16	0.21	29.5	0.72	116.8	999	23.0	0.96	164
GTAC08	26214	0.	758.	0.	0.	-611.	951.	29.	60.	1.50	0.16	0.31	30.8	0.76	103.3	999	21.9	0.91	157
GTAC12	26214	0.	606.	0.	0.	-535.	697.	29.	29.	1.46	0.16	0.21	30.2	0.74	119.3	999	23.2	0.96	163

HONEYWELL PAGE PRINTING SYSTEM - P1188-02

ORIGINAL PAGE IS  
OF POOR QUALITY

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																			
**COGENERATION CASE** **NO COGEN - COGEN**																			
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD	COGEN POWER	G&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVEL CHRG	NORM WRTH ENRG	
GTAC12	26214	0.	840.	0.	0.	-656.	1075.	29.	75.	1.64	0.16	0.33	35.6	0.87	110.5	999	22.1	0.92 152	
GTAC16	26214	0.	609.	0.	0.	-538.	697.	29.	29.	1.48	0.16	0.21	31.1	0.76	122.1	999	23.4	0.97 152	
GTAC16	26214	0.	902.	0.	0.	-692.	1160.	29.	85.	1.75	0.16	0.34	39.8	0.98	117.0	999	22.6	0.94 147	
GTWC16	26214	0.	623.	0.	0.	-552.	697.	29.	29.	1.48	0.16	0.19	30.9	0.76	119.6	-2	23.8	0.99 161	
GTWC16	26214	0.	964.	0.	0.	-746.	1189.	29.	89.	1.73	0.16	0.32	38.2	0.94	106.7	999	23.5	0.98 145	
CC1626	26214	0.	625.	0.	0.	-554.	697.	29.	29.	1.58	0.16	0.19	31.1	0.76	120.2	-5	24.0	1.00 160	
CC1626	2C214	0.	1276.	0.	0.	-926.	1632.	29.	143.	2.26	0.16	0.36	51.7	1.27	115.0	0	24.8	1.03 132	
CC1622	26214	0.	618.	0.	0.	-547.	697.	29.	29.	1.58	0.16	0.20	31.1	0.76	121.1	-2	23.8	0.99 161	
CC1622	26214	0.	1163.	0.	0.	-848.	1514.	29.	129.	2.23	0.16	0.36	52.3	1.29	125.6	4	24.1	1.00 134	
CC1222	26214	0.	616.	0.	0.	-545.	697.	29.	29.	1.57	0.16	0.20	30.5	0.75	118.8	-1	23.7	0.98 162	
CC1222	26214	0.	1154.	0.	0.	-840.	1510.	29.	128.	2.19	0.16	0.37	49.7	1.22	120.1	9	23.6	0.98 136	
CC0822	26214	0.	606.	0.	0.	-534.	697.	29.	29.	1.56	0.16	0.21	30.3	0.74	119.6	999	23.3	0.97 164	
CC0822	26214	0.	975.	0.	0.	-725.	1297.	29.	102.	1.92	0.16	0.37	40.3	0.99	111.5	999	21.9	0.91 145	
STIG15	26214	0.	715.	0.	0.	-643.	697.	29.	29.	1.82	0.16	0.07	34.5	0.85	120.9	-29	27.3	1.13 146	
STIG15	26214	0.	3000.	0.	0.	-21785.	27962.	29.	3350.	50.80	0.16	0.17	826.8	20.30	93.2	0	410.6	17.05 465	
STIG10	26214	0.	691.	0.	0.	-620.	697.	29.	29.	1.63	0.16	0.10	30.3	0.75	109.0	-15	26.0	1.08 152	
STIG10	26214	0.	2943.	0.	0.	-2184.	3002.	29.	310.	5.18	0.16	0.22	97.2	2.39	103.6	0	50.9	2.12 117	
STIG1S	26214	0.	681.	0.	0.	-610.	697.	29.	29.	1.64	0.16	0.11	29.9	0.74	108.7	-13	25.6	1.06 154	
STIG1S	26214	0.	1850.	0.	0.	-1404.	1951.	29.	182.	3.48	0.16	0.23	59.4	1.46	96.1	0	36.7	1.52 120	
DEADV3	26214	0.	661.	0.	0.	-590.	697.	29.	29.	1.77	0.16	0.14	40.5	0.99	150.1	-87	26.3	1.09 150	
DEADV3	26214	0.	1903.	0.	0.	-1395.	2157.	29.	207.	4.56	0.16	0.29	141.9	3.49	224.1	0	43.2	1.79 116	
DEHTPM	26214	0.	609.	0.	0.	-538.	697.	29.	29.	1.87	0.16	0.21	41.8	1.03	164.5	0	24.9	1.03 156	
DEHTPM	26214	0.	910.	0.	0.	-696.	1175.	29.	87.	2.81	0.16	0.34	74.7	1.83	218.0	0	27.2	1.13 137	
DESOA3	26214	678.	0.	0.	0.	-678.	71.	697.	29.	29.	1.90	0.16	0.12	45.2	1.11	164.8	0	32.1	1.33 150
DESOA3	26214	2281.	0.	0.	0.	-2281.	592.	2440.	29.	241.	6.10	0.16	0.25	201.6	4.95	270.8	0	71.6	2.98 134
DESOA3	26214	0.	678.	0.	0.	-607.	697.	29.	29.	1.90	0.16	0.12	45.2	1.11	164.8	0	27.4	1.14 146	
DESOA3	26214	0.	2281.	0.	0.	-1689.	2440.	29.	241.	6.10	0.16	0.25	201.6	4.95	270.8	0	55.9	2.32 118	
GTSOAD	26214	614.	0.	0.	0.	-614.	71.	697.	29.	29.	1.43	0.16	0.20	29.0	0.71	113.3	-21	27.5	1.14 168
GTSOAD	26214	847.	0.	0.	0.	-847.	178.	1054.	29.	72.	1.55	0.16	0.31	32.0	0.79	98.9	-29	28.2	1.17 159
GTRA08	26214	626.	0.	0.	0.	-626.	71.	697.	29.	29.	1.51	0.16	0.18	32.3	0.79	124.6	-30	28.4	1.18 164
GTRA08	26214	1160.	0.	0.	0.	-1160.	298.	1455.	29.	121.	2.10	0.16	0.34	51.8	1.27	124.7	0	33.1	1.37 142
GTRA12	26214	623.	0.	0.	0.	-623.	71.	697.	29.	29.	1.51	0.16	0.19	32.5	0.80	126.0	-30	28.3	1.17 164
GTRA12	26214	1127.	0.	0.	0.	-1127.	290.	1429.	29.	118.	2.10	0.16	0.34	52.3	1.28	128.8	0	32.5	1.35 143
GTRA16	26214	621.	0.	0.	0.	-621.	71.	697.	29.	29.	1.53	0.16	0.19	33.3	0.82	129.2	-32	28.3	1.18 164
GTRA16	26214	1076.	0.	0.	0.	-1076.	270.	1363.	29.	110.	2.10	0.16	0.34	52.4	1.29	133.9	0	32.2	1.34 144
GTR208	26214	622.	0.	0.	0.	-622.	71.	697.	29.	29.	1.48	0.16	0.19	31.3	0.77	121.2	-26	28.1	1.17 165
GTR208	26214	970.	0.	0.	0.	-970.	223.	1206.	29.	91.	1.84	0.16	0.32	42.7	1.05	118.7	0	30.7	1.27 150
GTR212	26214	622.	0.	0.	0.	-622.	71.	697.	29.	29.	1.50	0.16	0.19	31.8	0.78	123.3	-28	28.2	1.17 165
GTR212	26214	1009.	0.	0.	0.	-1009.	239.	1260.	29.	98.	1.91	0.16	0.33	45.4	1.12	122.3	0	31.2	1.30 148
GTR216	26214	619.	0.	0.	0.	-619.	71.	697.	29.	29.	1.51	0.16	0.19	32.5	0.80	126.2	-29	28.1	1.17 164
GTR216	26214	1013.	0.	0.	0.	-1013.	245.	1280.	29.	100.	1.98	0.16	0.34	48.2	1.18	129.2	0	31.2	1.30 147
GTRW08	26214	649.	0.	0.	0.	-649.	71.	697.	29.	29.	1.51	0.16	0.16	32.2	0.79	121.0	-34	29.2	1.21 161
GTRW08	26214	1406.	0.	0.	0.	-1406.	355.	1646.	29.	145.	2.18	0.16	0.30	53.7	1.32	110.1	0	38.1	1.58 137
GTRW12	26214	640.	0.	0.	0.	-640.	71.	697.	29.	29.	1.50	0.16	0.17	32.2	0.79	122.1	-32	28.9	1.20 162

DATE 06/07/79  
I&SE-PEG-ADV-DES-ENGR

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

PAGE 37

-----FUEL USE IN BTU*10**6-----																			
ECS	PROCS	**COGENERATION CASE** **NOCOGEN - COGEN**								G&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM ENRG	WRTH
		DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	REOD MW	POWER MW										
GTRW12	26214	1376.	0.	0.	-1376.	360.	1664.	29.	147.	2.18	0.16	0.32	54.0	1.33	112.8	0	36.6	1.52	138
GTRW16	26214	638.	0.	0.	-638.	71.	697.	29.	29.	1.52	0.16	0.17	32.7	0.80	124.4	-33	28.9	1.20	162
GTRW16	26214	1297.	0.	0.	-1297.	333.	1573.	29.	136.	2.16	0.16	0.32	53.5	1.31	117.2	0	35.7	1.48	139
GTR308	26214	658.	0.	0.	-658.	71.	697.	29.	29.	1.50	0.16	0.14	31.4	0.77	116.8	-33	29.4	1.22	160
GTR308	26214	1216.	0.	0.	-1216.	271.	1366.	29.	110.	1.90	0.16	0.26	43.6	1.07	100.9	0	36.2	1.51	142
GTR312	26214	635.	0.	0.	-635.	71.	697.	29.	29.	1.49	0.16	0.17	31.3	0.77	119.6	-29	28.6	1.19	163
GTR312	26214	1177.	0.	0.	-1177.	289.	1427.	29.	118.	1.97	0.16	0.31	46.7	1.15	111.1	0	33.7	1.40	143
GTR316	26214	636.	0.	0.	-636.	71.	697.	29.	29.	1.50	0.16	0.17	32.0	0.78	121.8	-31	28.7	1.19	163
GTR316	26214	1169.	0.	0.	-1169.	285.	1412.	29.	116.	2.00	0.16	0.31	47.9	1.18	114.4	0	33.9	1.41	143
FCPADS	26214	667.	0.	0.	-667.	71.	697.	29.	29.	4.23	0.16	0.13	38.6	0.95	142.2	144	33.3	1.38	157
FCPADS	26214	2294.	0.	0.	-2294.	627.	2557.	29.	255.	28.29	0.16	0.28	153.7	3.78	205.5	0	86.5	3.59	156
FCMCDS	26214	633.	0.	0.	-633.	71.	697.	29.	29.	4.04	0.16	0.18	39.8	0.98	152.3	196	32.0	1.33	161
FCMCDS	26214	1674.	0.	0.	-1674.	496.	2118.	29.	202.	21.30	0.16	0.36	133.2	3.27	235.2	0	64.5	2.68	148



GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

ECS	PROGS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	COGEN**	POWER	COGEN	ORM	POWER	FESR	CAPITAL	NORM	\$/KW	ROI	LEVEL	NORM	WRTH
									MW	MW		RATIO	*10**6	COST	COST	EOVL	(%)	CHRG	ENRG	
ONOCN	26216	0.	49.	525.	0.	0.	0.	F	20.	0.	1.30	0.22	0.	20.8	1.00	196.9	0	16.4	1.00	80
STM141	26216	0.	439.	15.	0.	-389.	510.	F	20.	18.	0.79	0.22	0.21	13.1	0.63	102.9	0	16.1	0.98	157
STM141	26216	0.	5.	449.	0.	44.	76.	F	20.	18.	1.66	0.22	0.21	27.1	1.30	213.0	34	12.9	0.78	134
STM141	26216	0.	5.	449.	0.	44.	76.	A	20.	18.	1.49	0.22	0.21	19.5	0.94	153.7	999	11.9	0.73	140
STM088	26216	0.	431.	57.	0.	-382.	469.	F	20.	13.	0.78	0.22	0.15	13.1	0.63	107.9	-10	17.1	1.04	150
STM088	26216	0.	17.	471.	0.	32.	55.	F	20.	13.	1.56	0.22	0.15	25.1	1.20	206.8	36	13.9	0.84	128
STM088	26216	0.	17.	471.	0.	32.	55.	A	20.	13.	1.44	0.22	0.15	18.5	0.89	152.6	999	13.0	0.79	135
PFBSM	26216	0.	0.	444.	0.	49.	81.		20.	20.	2.59	0.22	0.23	34.3	1.65	263.5	15	14.2	0.86	143
PFBSM	26216	0.	0.	485.	0.	73.	120.		20.	30.	2.51	0.22	0.29	32.6	1.57	229.9	22	12.8	0.78	137
TISTMT	26216	0.	444.	0.	0.	-395.	525.		20.	20.	1.97	0.22	0.23	51.7	2.48	397.9	0	21.1	1.29	146
TISTMT	26216	0.	525.	0.	0.	-428.	688.		20.	40.	2.49	0.22	0.33	79.2	3.80	514.8	0	23.3	1.42	140
TISTMT	26216	0.	0.	444.	0.	49.	82.		20.	20.	3.11	0.22	0.23	72.2	3.46	555.4	0	18.0	1.14	138
TISTMT	26216	0.	0.	525.	0.	97.	162.		20.	40.	3.56	0.22	0.33	100.3	4.81	652.2	0	19.9	1.47	132
TIHRSO	26216	0.	476.	3.	0.	-427.	522.		20.	20.	2.11	0.22	0.17	69.9	3.35	501.7	0	24.1	1.47	128
TIHRSO	26216	0.	1.	479.	0.	48.	47.		20.	20.	3.12	0.22	0.17	89.6	4.30	642.9	0	21.4	1.30	120
STIRL	26216	480.	0.	0.	-480.	49.	525.		20.	20.	1.18	0.22	0.16	21.6	1.03	153.4	0	21.4	1.30	157
STIRL	26216	643.	0.	0.	-643.	117.	751.		20.	48.	1.34	0.22	0.26	34.4	1.65	182.2	0	23.7	1.44	142
STIRL	26216	0.	480.	0.	0.	-431.	525.		20.	20.	1.18	0.22	0.16	21.6	1.04	153.5	0	18.1	1.10	152
STIRL	26216	0.	643.	0.	0.	-527.	751.		20.	48.	1.34	0.22	0.26	34.4	1.65	182.5	0	19.3	1.17	135
STIRL	26216	0.	0.	480.	0.	49.	45.		20.	20.	2.32	0.22	0.16	41.0	1.97	291.7	9	15.2	0.92	133
STIRL	26216	0.	0.	643.	0.	117.	108.		20.	48.	2.64	0.22	0.26	60.5	2.90	320.9	7	15.1	0.92	119
HEGT85	26216	0.	0.	544.	0.	49.	-19.	A	20.	20.	2.73	0.22	0.05	59.3	2.84	371.6	0	18.8	1.14	119
HEGT85	26216	0.	0.	2537.	0.	599.	-230.	A	20.	244.	9.43	0.22	0.12	245.2	11.77	322.3	0	38.5	2.34	94
HEGT60	26216	0.	0.	535.	0.	49.	-9.	A	20.	20.	2.67	0.22	0.07	56.9	2.73	363.2	0	18.3	1.11	121
HEGT60	26216	0.	0.	1056.	0.	197.	-37.	A	20.	80.	4.33	0.22	0.13	110.3	5.29	356.4	0	23.3	1.42	95
HEGT00	26216	0.	0.	526.	0.	49.	-1.	A	20.	20.	2.56	0.22	0.08	53.0	3.54	343.5	1	17.6	1.07	123
HEGT00	26216	0.	0.	629.	0.	80.	-1.	A	20.	32.	2.57	0.22	0.11	60.5	2.90	328.3	1	17.8	1.09	111
FCMCL	26216	0.	0.	461.	0.	49.	65.		20.	20.	2.81	0.22	0.20	50.4	2.42	373.3	4	16.6	1.01	136
FCMCL	26216	0.	0.	649.	0.	142.	187.		20.	58.	3.96	0.22	0.34	72.2	3.46	379.6	5	16.1	0.98	123
FCSTCL	26216	0.	0.	456.	0.	49.	69.		20.	20.	2.78	0.22	0.21	49.1	2.35	367.0	5	16.3	0.99	137
FCSTCL	26216	0.	0.	775.	0.	213.	301.		20.	87.	4.82	0.22	0.16	87.0	4.17	383.0	6	15.2	0.93	116
166TST	26216	0.	0.	481.	0.	49.	45.		20.	20.	2.40	0.22	0.16	47.9	2.30	340.0	5	16.2	0.99	132
166TST	26216	0.	0.	723.	0.	149.	134.		20.	60.	2.48	0.22	0.28	67.5	3.24	318.7	7	14.9	0.91	114
GTSOAR	26216	0.	479.	0.	0.	-430.	525.		20.	20.	1.03	0.22	0.17	18.0	0.86	128.3	-24	17.6	1.07	156
GTSOAR	26216	0.	0.	0.	0.	-573.	866.		20.	62.	1.07	0.22	0.29	26.1	1.25	123.0	0	17.9	1.09	137
GTAC08	26216	0.	461.	0.	0.	-412.	525.		20.	20.	0.99	0.22	0.20	16.6	0.79	122.6	-10	16.8	1.02	161
GTAC08	26216	0.	597.	0.	0.	-481.	749.		20.	47.	0.90	0.22	0.31	20.3	0.97	115.9	999	16.0	0.97	149
GTAC12	26216	0.	463.	0.	0.	-414.	525.		20.	20.	1.00	0.22	0.19	17.0	0.81	125.1	-12	16.9	1.03	161
GTAC12	26216	0.	661.	0.	0.	-516.	847.		20.	59.	1.01	0.22	0.33	24.1	1.16	124.5	11	16.2	0.98	143
GTAC16	26216	0.	465.	0.	0.	-416.	525.		20.	20.	1.01	0.22	0.19	17.6	0.84	123.8	-15	17.1	1.04	159
GTAC16	26216	0.	710.	0.	0.	-545.	913.		20.	67.	1.11	0.22	0.34	27.6	1.32	132.7	3	16.6	1.01	138
GTWC16	26216	0.	475.	0.	0.	-426.	525.		20.	20.	1.02	0.22	0.17	17.7	0.85	126.9	-20	17.4	1.06	158
GTWC16	26216	0.	759.	0.	0.	-587.	936.		20.	70.	1.09	0.22	0.32	26.7	1.28	120.0	0	17.4	1.06	136

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																			
**COGENERATION CASE** **NOCOGEN - COGEN**																			
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD	COGEN POWER	OSM	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM WRTH ENRG	
CC1626	26216	0.	476.	0.	0.	-427.	525.	20.	20.	1.12	0.22	0.17	17.8	0.85	127.7	-26	17.6	1.07	157
CC1626	26216	0.	991.	0.	0.	-722.	1262.	20.	110.	1.50	0.22	0.35	35.7	1.71	123.0	0	18.2	1.11	124
CC1622	26216	0.	471.	0.	0.	-422.	525.	20.	20.	1.11	0.22	0.18	17.7	0.85	127.8	-22	17.4	1.06	158
CC1622	26216	0.	904.	0.	0.	-662.	1171.	20.	99.	1.46	0.22	0.36	35.6	1.71	134.4	0	17.7	1.08	127
CC1222	26216	0.	470.	0.	0.	-421.	525.	20.	20.	1.10	0.22	0.18	17.2	0.82	124.7	-19	17.3	1.05	159
CC1222	26216	0.	896.	0.	0.	-655.	1167.	20.	98.	1.43	0.22	0.36	33.7	1.62	128.3	0	17.3	1.05	128
CC0822	26216	0.	463.	0.	0.	-414.	525.	20.	20.	1.10	0.22	0.19	17.2	0.82	126.7	-16	17.1	1.04	160
CC0822	26216	0.	757.	0.	0.	-566.	1002.	20.	78.	1.26	0.22	0.37	27.9	1.34	126.0	8	16.2	0.98	136
ST1615	26216	0.	538.	0.	0.	-488.	525.	20.	20.	1.31	0.22	0.06	22.1	1.06	140.3	0	20.1	1.22	142
ST1615	26216	0.	23615.	0.	0.	-17148.	22011.	20.	2637.	39.96	0.22	0.17	651.1	31.24	94.1	0	322.7	19.64	529
ST1610	26216	0.	522.	0.	0.	-473.	525.	20.	20.	1.16	0.22	0.09	18.4	0.88	120.6	-50	19.0	1.16	149
ST1610	26216	0.	2317.	0.	0.	-1719.	2363.	20.	244.	3.83	0.22	0.22	72.6	3.48	107.0	0	38.9	2.37	117
ST161S	26216	0.	514.	0.	0.	-465.	525.	20.	20.	1.16	0.22	0.10	18.1	0.87	120.4	-43	18.8	1.14	150
ST161S	26216	0.	1456.	0.	0.	-1105.	1536.	20.	143.	2.51	0.22	0.23	44.3	2.13	103.9	0	27.8	1.69	114
DEADV3	26216	0.	501.	0.	0.	-452.	525.	20.	20.	1.24	0.22	0.13	24.3	1.17	165.9	0	19.1	1.16	146
DEADV3	26216	0.	1498.	0.	0.	-1098.	1698.	20.	163.	3.32	0.22	0.29	106.9	5.13	243.5	0	32.7	1.99	114
DEHTPM	26216	0.	465.	0.	0.	-416.	525.	20.	20.	1.28	0.22	0.19	23.9	1.15	175.4	0	18.0	1.10	153
DEHTPM	26216	0.	717.	0.	0.	-548.	925.	20.	69.	1.92	0.22	0.34	53.4	2.56	254.4	0	20.0	1.22	130
DESOA3	26216	512.	0.	0.	-512.	49.	525.	20.	20.	1.33	0.22	0.11	27.6	1.33	184.0	0	23.4	1.43	147
DESOA3	26216	1796.	0.	0.	-1796.	466.	1921.	20.	190.	4.54	0.22	0.25	154.0	7.39	292.6	0	55.1	3.35	139
DESOA3	26216	0.	512.	0.	0.	-463.	525.	20.	20.	1.33	0.22	0.11	27.6	1.33	184.0	0	19.9	1.21	142
DESOA3	26216	0.	1796.	0.	0.	-1330.	1921.	20.	190.	4.54	0.22	0.25	154.0	7.39	232.6	0	42.7	2.60	120
GTSOAD	26216	468.	0.	0.	-468.	49.	525.	20.	20.	0.98	0.22	0.18	16.1	0.77	117.3	-42	20.2	1.23	166
GTSOAD	26216	667.	0.	0.	-667.	140.	830.	20.	57.	0.94	0.22	0.31	21.3	1.02	109.0	999	21.0	1.28	152
GTRA08	26216	477.	0.	0.	-477.	49.	525.	20.	20.	1.04	0.22	0.17	18.6	0.89	133.3	-82	20.9	1.27	161
GTRA08	26216	913.	0.	0.	-913.	234.	1145.	20.	96.	1.41	0.22	0.34	38.1	1.83	142.2	0	25.0	1.52	135
GTRA12	26216	474.	0.	0.	-474.	49.	525.	20.	20.	1.04	0.22	0.17	18.7	0.90	134.9	-84	20.8	1.27	161
GTRA12	26216	887.	0.	0.	-887.	228.	1125.	20.	93.	1.36	0.22	0.34	36.2	1.74	139.5	0	24.2	1.47	136
GTRA16	26216	473.	0.	0.	-473.	49.	525.	20.	20.	1.06	0.22	0.18	19.3	0.93	139.4	107	20.8	1.27	161
GTRA16	26216	847.	0.	0.	-847.	213.	1073.	20.	87.	1.35	0.22	0.34	36.4	1.75	146.5	0	24.0	1.46	137
GTR208	26216	474.	0.	0.	-474.	49.	525.	20.	20.	1.02	0.22	0.18	17.8	0.86	128.5	-64	20.6	1.26	163
GTR208	26216	764.	0.	0.	-764.	176.	949.	20.	72.	1.13	0.22	0.32	28.3	1.36	126.6	0	22.7	1.38	143
GTR212	26216	474.	0.	0.	-474.	49.	525.	20.	20.	1.03	0.22	0.17	18.2	0.88	131.3	-72	20.7	1.26	162
GTR212	26216	794.	0.	0.	-794.	188.	992.	20.	77.	1.20	0.22	0.33	30.6	1.47	131.4	0	23.2	1.41	141
GTR216	26216	472.	0.	0.	-472.	49.	525.	20.	20.	1.04	0.22	0.18	18.7	0.90	135.2	-82	20.7	1.26	162
GTR216	26216	797.	0.	0.	-797.	193.	1008.	20.	79.	1.25	0.22	0.34	32.8	1.57	140.3	0	23.2	1.41	140
GTRW08	26216	492.	0.	0.	-492.	49.	525.	20.	20.	1.05	0.22	0.14	18.6	0.89	129.0	-92	21.4	1.31	159
GTRW08	26216	1107.	0.	0.	-1107.	279.	1296.	20.	114.	1.43	0.22	0.30	37.9	1.82	116.8	0	28.7	1.75	131
GTRW12	26216	486.	0.	0.	-486.	49.	525.	20.	20.	1.04	0.22	0.15	18.6	0.89	130.5	-87	21.2	1.29	160
GTRW12	26216	1083.	0.	0.	-1083.	283.	1310.	20.	116.	1.44	0.22	0.32	38.1	1.83	120.2	0	27.5	1.67	132
GTRW16	26216	485.	0.	0.	-485.	49.	525.	20.	20.	1.05	0.22	0.16	19.0	0.91	134.0	102	21.2	1.29	159
GTRW16	26216	1021.	0.	0.	-1021.	262.	1239.	20.	107.	1.41	0.22	0.32	37.7	1.81	125.9	0	26.8	1.63	133
GTR308	26216	498.	0.	0.	-498.	49.	525.	20.	20.	1.03	0.22	0.13	17.9	0.86	122.9	-78	21.6	1.31	158
GTR308	26216	957.	0.	0.	-957.	213.	1075.	20.	87.	1.24	0.22	0.26	31.2	1.50	111.2	0	27.4	1.67	135

ORIGINAL PAGE IS  
OF POOR QUALITY

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----

ECS	PROCS	**COGENERATION CASE**			**NOCOGEN - COGEN**			POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM ENRG	WRTH
		DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL												
GTR312	26216	483.	0.	0.	-483.	49.	525.	20.	20.	1.03	0.22	0.16	18.0	0.86	126.9	-70	21.0	1.28	161
GTR312	26216	926.	0.	0.	-926.	228.	1123.	20.	93.	1.25	0.22	0.31	31.9	1.53	117.6	0	35.2	1.53	136
GTR316	26216	483.	0.	0.	-483.	49.	525.	20.	20.	1.04	0.22	0.16	18.4	0.89	130.2	-82	21.1	1.28	160
GTR316	26216	920.	0.	0.	-920.	224.	1112.	20.	91.	1.28	0.22	0.31	32.9	1.58	122.1	0	25.4	1.54	136
FCPADS	26216	505.	0.	0.	-505.	49.	525.	20.	20.	2.90	0.22	0.12	23.0	1.10	155.6	0	24.2	1.48	155
FCPADS	26216	1806.	0.	0.	-1806.	493.	2012.	20.	201.	21.96	0.22	0.28	116.5	5.59	220.1	0	66.8	4.96	163
FCMCDS	26216	481.	0.	0.	-481.	49.	525.	20.	20.	2.77	0.22	0.16	23.8	1.14	168.6	0	23.3	1.42	158
FCMCDS	26216	1318.	0.	0.	-1318.	390.	1667.	20.	159.	16.44	0.22	0.36	99.9	4.79	258.8	0	49.4	3.60	150

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																				
**COGENERATION CASE** **HOCOGEN - COGEN**																				
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REGD	COGEN POWER	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM ENRG	WRTH ENRG	
ONOCGN	26217	0.	77.	472.	0.	0.	0.	F	31.	0.	0.97	0.58	0.	14.8	1.00	235.3	0	16.5	1.00	80
STM141	26217	0.	307.	176.	0.	-231.	296.		31.	10.	0.62	0.58	0.12	9.2	0.62	123.5	-2	16.3	0.99	138
STM141	26217	0.	53.	431.	0.	24.	41.	F	31.	10.	1.22	0.58	0.12	18.6	1.25	249.3	30	14.7	0.89	118
STM141	26217	0.	53.	431.	0.	24.	41.	A	31.	10.	1.09	0.58	0.12	13.9	0.94	186.8	999	14.1	0.85	124
STM088	26217	0.	303.	200.	0.	-226.	272.		31.	7.	0.59	0.58	0.08	8.2	0.55	114.6	-8	16.8	1.02	134
STM088	26217	0.	60.	443.	0.	17.	29.	F	31.	7.	1.16	0.58	0.08	17.1	1.15	240.8	34	15.2	0.92	112
STM088	26217	0.	60.	443.	0.	17.	29.	A	31.	7.	1.05	0.58	0.08	13.1	0.88	184.5	999	14.7	0.89	118
PFBSTM	26217	0.	36.	405.	0.	41.	67.		31.	17.	1.73	0.58	0.20	22.9	1.54	274.1	22	14.0	0.85	127
TISTMT	26217	0.	330.	72.	0.	-253.	400.		31.	23.	1.76	0.58	0.27	53.1	3.58	588.3	0	19.8	1.20	132
TISTMT	26217	0.	22.	380.	0.	55.	92.		31.	23.	2.50	0.58	0.27	67.5	4.55	747.4	2	18.1	1.10	126
TIHRSG	26217	0.	331.	161.	0.	-255.	311.		31.	12.	1.48	0.58	0.10	47.5	3.20	571.6	0	21.5	1.30	110
TIHRSG	26217	0.	48.	444.	0.	29.	28.		31.	12.	2.19	0.58	0.10	61.0	4.11	734.5	0	20.2	1.22	104
STIRL	26217	384.	7.	24.	-384.	69.	448.		31.	28.	0.92	0.58	0.24	20.9	1.41	186.1	0	18.5	1.12	144
STIRL	26217	0.	391.	24.	0.	-314.	448.		31.	28.	0.92	0.58	0.24	21.0	1.41	186.4	13	15.8	0.96	140
STIRL	26217	0.	7.	408.	0.	69.	64.		31.	28.	1.75	0.58	0.24	36.2	2.44	322.2	15	13.3	0.81	126
HEGT85	26217	0.	0.	502.	0.	77.	-29.	A	31.	31.	2.92	0.58	0.09	68.5	4.62	466.0	0	19.2	1.16	117
HEGT85	26217	0.	0.	1548.	0.	357.	-137.	A	31.	146.	6.38	0.58	0.12	169.9	11.44	374.5	0	30.0	1.82	95
HEGT60	26217	0.	0.	487.	0.	77.	-14.	A	31.	31.	2.75	0.58	0.11	63.5	4.28	445.3	1	18.2	1.10	120
HEGT60	26217	0.	0.	630.	0.	117.	-22.	A	31.	48.	2.97	0.58	0.13	76.6	5.16	415.0	0	19.2	1.16	109
HEGT00	26217	0.	29.	473.	0.	47.	-1.	A	31.	19.	1.78	0.58	0.09	41.9	2.83	382.0	4	16.8	1.02	107
FCMCCL	26217	0.	0.	371.	0.	77.	101.		31.	31.	2.77	0.58	0.32	49.4	3.33	454.8	8	14.8	0.90	144
FCMCCL	26217	0.	0.	387.	0.	84.	111.		31.	34.	2.65	0.58	0.34	49.7	3.35	438.6	9	14.4	0.87	134
FCSTCL	26217	0.	0.	365.	0.	77.	108.		31.	31.	2.85	0.58	0.34	50.0	3.37	467.9	8	14.9	0.90	145
FCSTCL	26217	0.	0.	455.	0.	123.	173.		31.	50.	3.20	0.58	0.39	59.0	3.98	442.6	9	14.1	0.86	136
IGGTST	26217	0.	0.	404.	0.	77.	68.		31.	31.	2.06	0.58	0.26	46.9	3.16	395.7	9	14.4	0.87	137
IGGTST	26217	0.	0.	424.	0.	85.	75.		31.	35.	1.85	0.58	0.27	46.9	3.16	377.1	10	13.9	0.84	126
GTSOAR	26217	0.	400.	0.	0.	-323.	472.		31.	31.	0.92	0.58	0.27	17.5	1.18	149.4	40	15.0	0.91	158
GTSOAR	26217	0.	432.	0.	0.	-342.	516.		31.	37.	0.79	0.58	0.29	17.8	1.20	141.1	39	14.8	0.90	148
GTAC08	26217	0.	363.	26.	0.	-287.	446.		31.	28.	0.67	0.58	0.29	13.8	0.93	132.4	999	14.0	0.85	154
GTAC12	26217	0.	374.	0.	0.	-297.	472.		31.	31.	0.87	0.58	0.32	16.1	1.09	147.1	131	14.0	0.85	164
GTAC12	26217	0.	394.	0.	0.	-308.	505.		31.	35.	0.74	0.58	0.33	16.2	1.09	140.2	136	13.7	0.83	154
GTAC16	26217	0.	378.	0.	0.	-301.	472.		31.	31.	0.93	0.58	0.31	17.4	1.17	156.9	56	14.3	0.87	162
GTAC16	26217	0.	423.	0.	0.	-325.	544.		31.	40.	0.81	0.58	0.34	18.3	1.24	148.9	45	14.0	0.85	152
GTWC16	26217	0.	393.	0.	0.	-316.	472.		31.	31.	0.93	0.58	0.28	17.2	1.16	149.7	49	14.8	0.89	159
GTWC16	26217	0.	452.	0.	0.	-350.	558.		31.	42.	0.81	0.58	0.32	18.4	1.24	138.6	38	14.5	0.88	150
CC1626	26217	0.	396.	0.	0.	-319.	472.		31.	31.	1.10	0.58	0.28	18.1	1.22	156.5	27	15.2	0.92	158
CC1626	26217	0.	582.	0.	0.	-426.	737.		31.	64.	1.12	0.58	0.35	24.1	1.63	141.5	14	15.2	0.92	144
CC1622	26217	0.	388.	0.	0.	-311.	472.		31.	31.	1.08	0.58	0.29	18.1	1.22	159.4	31	14.9	0.90	159
CC1622	26217	0.	531.	0.	0.	-390.	684.		31.	57.	1.07	0.58	0.35	23.4	1.58	150.5	17	14.8	0.90	146
CC1222	26217	0.	386.	0.	0.	-310.	472.		31.	31.	1.07	0.58	0.30	17.4	1.17	153.9	39	14.8	0.89	160
CC1222	26217	0.	526.	0.	0.	-387.	682.		31.	57.	1.05	0.58	0.36	22.2	1.49	143.9	20	14.6	0.88	148
CC0822	26217	0.	375.	0.	0.	-298.	472.		31.	31.	1.04	0.58	0.32	16.9	1.14	154.3	56	14.3	0.87	163
CC0822	26217	0.	444.	0.	0.	-334.	585.		31.	45.	0.94	0.58	0.36	18.7	1.26	143.7	40	13.9	0.84	153

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----

ECS	PROCS	**COGENERATION CASE**				**NOCOGEN - COGEN**		POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EOVL	ROI (%)	LEVL CHRG	NORM ENRG	WRTH
		DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL												
STIG15	26217	0.	491.	0.	0.	-415.	472.	31.	31.	1.32	0.58	0.11	18.8	1.26	130.3	0	18.3	1.11	140
STIG15	26217	0.	14077.	0.	0.	-10222.	13121.	31.	1572.	24.36	0.58	0.17	396.0	26.68	96.0	0	197.5	11.95	337
STIG10	26217	0.	466.	0.	0.	-390.	472.	31.	31.	1.19	0.58	0.15	17.7	1.19	129.3	0	17.3	1.05	146
STIG10	26217	0.	1381.	0.	0.	-1025.	1409.	31.	145.	2.46	0.58	0.22	44.5	3.00	109.9	0	27.2	1.65	115
STIG1S	26217	0.	455.	0.	0.	-378.	472.	31.	31.	1.18	0.58	0.17	17.1	1.15	128.3	0	16.9	1.02	149
STIG1S	26217	0.	868.	0.	0.	-659.	915.	31.	85.	1.64	0.58	0.23	27.0	1.82	106.3	0	20.6	1.24	128
DEADV3	26217	0.	434.	0.	0.	-357.	472.	31.	31.	1.28	0.58	0.21	26.7	1.80	209.8	0	17.3	1.05	144
DEADV3	26217	0.	893.	0.	0.	-655.	1012.	31.	97.	2.16	0.56	0.29	64.6	4.35	247.0	0	23.5	1.42	123
DEHTPM	26217	0.	377.	0.	0.	-300.	472.	31.	31.	1.31	0.58	0.31	27.4	1.85	248.1	10	15.7	0.95	154
DEHTPM	26217	0.	427.	0.	0.	-327.	551.	31.	41.	1.29	0.58	0.34	32.4	2.18	258.8	8	15.9	0.96	143
DES0A3	26217	452.	0.	0.	-452.	77.	472.	31.	31.	1.42	0.58	0.18	31.8	2.14	240.5	0	21.7	1.31	143
DES0A3	26217	1070.	0.	0.	-1070.	278.	1145.	31.	113.	2.90	0.58	0.25	92.8	6.25	296.0	0	36.9	2.23	131
DES0A3	26217	0.	452.	0.	0.	-375.	472.	31.	31.	1.42	0.58	0.18	31.8	2.14	240.5	0	18.6	1.12	138
DES0A3	26217	0.	1070.	0.	0.	-793.	1145.	31.	113.	2.90	0.58	0.25	92.8	6.25	296.0	0	29.5	1.79	120
GTSOAD	26217	383.	0.	0.	-383.	77.	472.	31.	31.	0.82	0.58	0.30	14.7	0.99	130.6	-24	16.7	1.01	169
GTSOAD	26217	397.	0.	0.	-397.	83.	494.	31.	34.	0.70	0.58	0.31	14.4	0.97	124.1	-10	16.6	1.00	159
GTRA03	26217	396.	0.	0.	-396.	77.	472.	31.	31.	1.00	0.58	0.28	19.1	1.28	164.3	0	17.9	1.08	161
GTRA08	26217	544.	0.	0.	-544.	140.	683.	31.	57.	0.98	0.58	0.34	24.3	1.64	152.5	0	19.0	1.15	150
GTRA12	26217	392.	0.	0.	-392.	77.	472.	31.	31.	1.01	0.58	0.29	19.3	1.30	168.1	0	17.7	1.07	161
GTRA12	26217	529.	0.	0.	-529.	136.	671.	31.	55.	0.99	0.58	0.34	24.5	1.65	158.2	0	18.7	1.13	150
GTRA16	26217	391.	0.	0.	-391.	77.	472.	31.	31.	1.02	0.58	0.29	20.1	1.35	175.2	0	17.8	1.08	151
GTRA16	26217	505.	0.	0.	-505.	127.	639.	31.	52.	0.98	0.58	0.34	24.6	1.66	166.4	0	18.6	1.12	150
GTR208	26217	391.	0.	0.	-391.	77.	472.	31.	31.	0.95	0.58	0.29	17.7	1.19	154.1	0	17.5	1.06	163
GTR208	26217	455.	0.	0.	-455.	105.	566.	31.	43.	0.83	0.58	0.32	19.2	1.30	144.1	0	17.7	1.07	154
GTR212	26217	392.	0.	0.	-392.	77.	472.	31.	31.	0.97	0.58	0.29	18.3	1.24	159.8	0	17.6	1.06	162
GTR212	26217	473.	0.	0.	-473.	112.	591.	31.	46.	0.88	0.58	0.33	20.8	1.40	149.7	0	18.0	1.09	153
GTR216	26217	389.	0.	0.	-389.	77.	472.	31.	31.	0.99	0.58	0.29	19.1	1.29	167.6	0	17.6	1.06	162
GTR216	26217	475.	0.	0.	-475.	115.	601.	31.	47.	0.91	0.58	0.34	22.1	1.49	158.8	0	18.0	1.09	152
GTRW08	26217	420.	0.	0.	-420.	77.	472.	31.	31.	1.02	0.58	0.23	19.0	1.28	154.4	0	18.8	1.14	157
GTRW08	26217	660.	0.	0.	-660.	166.	773.	31.	68.	1.06	0.58	0.30	26.2	1.76	135.4	0	21.4	1.30	144
GTRW12	26217	411.	0.	0.	-411.	77.	472.	31.	31.	1.01	0.58	0.25	19.0	1.28	157.8	0	18.4	1.11	158
GTRW12	26217	646.	0.	0.	-646.	169.	781.	31.	69.	1.06	0.58	0.32	26.3	1.77	139.3	0	20.7	1.26	145
GTRW16	26217	409.	0.	0.	-409.	77.	472.	31.	31.	1.02	0.58	0.26	19.5	1.32	163.1	0	18.4	1.11	158
GTRW16	26217	609.	0.	0.	-609.	156.	738.	31.	64.	1.04	0.58	0.32	26.1	1.76	146.1	0	20.3	1.23	146
GTR308	26217	430.	0.	0.	-430.	77.	472.	31.	31.	0.98	0.58	0.22	18.0	1.21	142.9	0	19.0	1.15	156
GTR308	26217	570.	0.	0.	-570.	127.	641.	31.	52.	0.92	0.58	0.26	21.4	1.44	128.0	0	20.6	1.24	146
GTR312	26217	406.	0.	0.	-406.	77.	472.	31.	31.	0.98	0.58	0.26	18.0	1.21	151.3	0	18.1	1.09	160
GTR312	26217	552.	0.	0.	-552.	136.	670.	31.	55.	0.93	0.58	0.31	22.0	1.48	135.9	0	19.3	1.17	150
GTR316	26217	407.	0.	0.	-407.	77.	472.	31.	31.	0.99	0.58	0.26	18.6	1.26	156.4	0	18.2	1.10	159
GTR316	26217	548.	0.	0.	-548.	134.	663.	31.	54.	0.95	0.58	0.31	22.7	1.53	141.4	0	19.4	1.17	149
FCPADS	26217	440.	0.	0.	-440.	77.	472.	31.	31.	3.95	0.58	0.20	24.9	1.68	192.9	0	23.1	1.40	153
FCPADS	26217	1076.	0.	0.	-1076.	294.	1200.	31.	120.	13.18	0.58	0.28	70.3	4.74	223.0	0	43.7	2.65	146
FCMCDS	26217	403.	0.	0.	-403.	77.	472.	31.	31.	3.74	0.58	0.27	25.8	1.74	218.4	0	21.6	1.31	158
FCMCDS	26217	785.	0.	0.	-785.	233.	994.	31.	95.	9.88	0.58	0.36	60.4	4.07	262.5	0	33.4	2.02	149

MINING SYSTEM- P1188-02

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																				
**COGENERATION CASE** **NOCOGEN - COGEN**																				
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REGD	COGEN POWER	G&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM ENRG	WRTH	
ONCOGN	26218	0.	37.	410.	0.	0.	0.	F	15.	0.	1.14	0.21	0.	17.9	1.07	213.0	0	13.0	1.00	80
STM141	26218	0.	345.	11.	0.	-308.	400.		15.	14.	0.71	0.21	0.20	11.2	0.62	111.5	-2	12.8	0.98	157
STM141	26218	0.	3.	353.	0.	34.	58.	F	15.	14.	1.44	0.21	0.20	22.9	1.28	228.4	32	10.4	0.80	134
STM141	26218	0.	3.	353.	0.	34.	58.	A	15.	14.	1.29	0.21	0.20	16.8	0.94	167.4	999	9.6	0.74	140
STM088	26218	0.	339.	43.	0.	-302.	367.		15.	10.	0.67	0.21	0.15	10.0	0.56	104.4	-9	13.4	1.03	152
STM088	26218	0.	13.	369.	0.	24.	41.	F	15.	10.	1.36	0.21	0.15	21.1	1.18	221.1	35	11.1	0.85	128
STM088	26218	0.	13.	369.	0.	24.	41.	A	15.	10.	1.25	0.21	0.15	15.8	0.88	165.8	999	10.4	0.80	134
PFBSTM	26218	0.	0.	350.	0.	37.	61.		15.	15.	2.21	0.21	0.22	29.3	1.63	285.8	13	11.6	0.89	143
PFBSTM	26218	0.	0.	382.	0.	56.	92.		15.	23.	2.12	0.21	0.28	27.8	1.55	248.4	20	10.4	0.80	137
TISTMT	26218	0.	349.	0.	0.	-312.	410.		15.	15.	1.69	0.21	0.22	42.6	2.38	416.7	0	17.0	1.30	146
TISTMT	26218	0.	414.	0.	0.	-339.	540.		15.	31.	2.13	0.21	0.33	66.2	3.70	546.1	0	18.9	1.45	140
TISTMT	26218	0.	0.	349.	0.	37.	61.		15.	15.	2.67	0.21	0.22	59.9	3.34	585.5	0	15.3	1.18	138
TISTMT	26218	0.	0.	414.	0.	75.	126.		15.	31.	3.04	0.21	0.33	84.0	4.69	692.8	0	16.4	1.26	132
TIHRSG	26218	0.	374.	0.	0.	-338.	410.		15.	15.	1.88	0.21	0.16	57.9	3.23	527.6	0	19.4	1.49	139
TIHRSG	26218	0.	378.	0.	0.	-340.	415.		15.	16.	1.80	0.21	0.17	58.8	3.28	531.4	0	19.4	1.49	129
TIHRSG	26218	0.	0.	374.	0.	37.	36.		15.	15.	2.83	0.21	0.16	75.3	4.20	686.4	0	17.6	1.35	132
TIHRSG	26218	0.	0.	378.	0.	38.	37.		15.	16.	2.66	0.21	0.17	75.5	4.21	681.9	0	17.4	1.34	121
STIRL	26218	376.	0.	0.	0.	-376.	37.	410.	15.	15.	1.02	0.21	0.16	17.2	0.96	156.1	159	16.9	1.30	158
STIRL	26218	511.	0.	0.	-511.	93.	597.		15.	38.	1.13	0.21	0.26	27.6	1.54	183.9	0	18.8	1.44	142
STIRL	26218	0.	376.	0.	0.	-339.	410.		15.	15.	1.02	0.21	0.16	17.2	0.96	156.2	-61	14.3	1.10	153
STIRL	26218	0.	511.	0.	0.	-419.	597.		15.	38.	1.13	0.21	0.26	27.6	1.54	184.1	0	15.3	1.17	136
STIRL	26218	0.	0.	376.	0.	37.	34.		15.	15.	2.00	0.21	0.16	33.8	1.89	307.0	8	12.2	0.94	134
STIRL	26218	0.	0.	511.	0.	93.	86.		15.	38.	2.21	0.21	0.26	48.9	2.73	326.5	7	12.0	0.92	119
HEGT85	26218	0.	0.	424.	0.	37.	-14.	A	15.	15.	2.32	0.21	0.05	49.2	2.75	395.8	0	15.2	1.16	119
HEGT85	26218	0.	0.	2064.	0.	476.	-183.	A	15.	194.	7.92	0.21	0.12	208.3	11.62	344.5	0	32.3	2.48	98
HEGT60	26218	0.	0.	417.	0.	37.	-7.	A	15.	15.	2.27	0.21	0.07	47.3	2.64	387.3	0	14.8	1.14	121
HEGT60	26218	0.	0.	840.	0.	156.	-29.	A	15.	64.	3.66	0.21	0.13	93.8	5.23	381.3	0	19.2	1.48	95
HEGT00	26218	0.	0.	411.	0.	37.	-1.	A	15.	15.	2.18	0.21	0.08	44.2	2.46	367.0	0	14.2	1.09	123
HEGT00	26218	0.	0.	500.	0.	63.	-1.	A	15.	26.	2.18	0.21	0.11	51.4	2.87	351.1	0	14.5	1.11	111
FCMCCL	26218	0.	0.	362.	0.	37.	49.		15.	15.	2.37	0.21	0.19	42.1	2.35	396.9	3	13.4	1.03	136
FCMCCL	26218	0.	0.	515.	0.	113.	149.		15.	46.	3.31	0.21	0.34	61.1	3.41	404.7	4	13.2	1.02	123
FCSTCL	26218	0.	0.	359.	0.	37.	52.		15.	15.	2.37	0.21	0.20	41.0	2.29	390.6	4	13.3	1.02	137
FCSTCL	26218	0.	0.	611.	0.	167.	235.		15.	68.	4.01	0.21	0.40	73.1	4.08	408.3	5	12.7	0.97	117
IGGTST	26218	0.	0.	377.	0.	37.	33.		15.	15.	2.11	0.21	0.16	40.4	2.26	365.7	4	13.3	1.02	132
IGGTST	26218	0.	0.	570.	0.	115.	104.		15.	47.	2.17	0.21	0.28	57.3	3.20	343.3	6	12.4	0.95	114
GTSQAR	26218	0.	375.	0.	0.	-339.	410.		15.	15.	0.91	0.21	0.16	15.1	0.84	137.0	-22	14.0	1.07	156
GTSQAR	26218	0.	575.	0.	0.	-455.	689.		15.	49.	0.94	0.21	0.29	22.0	1.23	130.7	0	14.3	1.10	136
GTAC08	26218	0.	362.	0.	0.	-325.	410.		15.	15.	0.87	0.21	0.19	13.9	0.77	130.6	-11	13.4	1.03	161
GTAC08	26218	0.	474.	0.	0.	-382.	595.		15.	38.	0.79	0.21	0.31	17.1	0.95	122.9	999	12.7	0.98	149
GTAC12	26218	0.	363.	0.	0.	-326.	410.		15.	15.	0.88	0.21	0.19	14.1	0.79	132.7	-12	13.5	1.03	161
GTAC12	26218	0.	526.	0.	0.	-410.	673.		15.	47.	0.88	0.21	0.33	20.2	1.13	131.2	11	12.9	0.99	142
GTAC16	26218	0.	365.	0.	0.	-328.	410.		15.	15.	0.89	0.21	0.18	14.6	0.81	136.4	-14	13.6	1.04	160
GTAC16	26218	0.	564.	0.	0.	-433.	726.		15.	53.	0.96	0.21	0.34	23.1	1.29	139.6	1	13.2	1.01	137

HONEYWELL PAGE PRINTING SYSTEM - P1185-02

INTRODUCED BY  
ST. LOUIS TRADING

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																			
ECS	PROCS	**COGENERATION CASE**				**NOCOGEN - COGEN**				O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM WRTH ENRG	
		DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	REOD	POWER										
GTWC16	26218	0.	372.	0.	0.	-335.	410.	15.	15.	0.90	0.21	0.17	14.8	0.83	135.6	-19	13.8	1.06	158
GTWC16	26218	0.	603.	0.	0.	-466.	744.	15.	56.	0.96	0.21	0.32	22.6	1.26	127.9	0	13.9	1.07	135
CC1626	26218	0.	373.	0.	0.	-337.	410.	15.	15.	1.00	0.21	0.16	14.9	0.83	136.2	-24	14.0	1.08	157
CC1626	26218	0.	781.	0.	0.	-570.	992.	15.	86.	1.31	0.21	0.35	29.9	1.67	130.8	0	14.7	1.13	124
CC1622	26218	0.	370.	0.	0.	-333.	410.	15.	15.	0.99	0.21	0.17	14.7	0.82	135.4	-20	13.9	1.07	159
CC1622	26218	0.	712.	0.	0.	-523.	921.	15.	77.	1.27	0.21	0.36	29.5	1.64	141.2	0	14.2	1.09	127
CC1222	26218	0.	369.	0.	0.	-332.	410.	15.	15.	0.98	0.21	0.17	14.3	0.80	132.2	-18	13.8	1.06	159
CC1222	26218	0.	706.	0.	0.	-518.	918.	15.	77.	1.25	0.21	0.36	27.9	1.56	134.9	0	13.9	1.06	128
CC0822	26218	0.	363.	0.	0.	-327.	410.	15.	15.	0.98	0.21	0.19	14.4	0.80	134.9	-16	13.6	1.05	160
CC0822	26218	0.	597.	0.	0.	-448.	787.	15.	61.	1.10	0.21	0.36	23.3	1.30	133.5	6	13.0	1.00	136
STIG15	26218	0.	419.	0.	0.	-383.	410.	15.	15.	1.04	0.21	0.06	14.9	0.83	121.2	-41	15.4	1.18	147
STIG15	26218	0.	18769.	0.	0.	-13629.	17494.	15.	2096.	32.03	0.21	0.17	520.8	29.06	94.7	0	256.9	19.73	531
STIG10	26218	0.	407.	0.	0.	-371.	410.	15.	15.	0.98	0.21	0.09	14.3	0.80	120.0	-31	14.9	1.15	151
STIG10	26218	0.	1842.	0.	0.	-1366.	1878.	15.	194.	3.07	0.21	0.22	55.3	3.09	102.5	0	30.5	2.34	118
STIG1S	26218	0.	402.	0.	0.	-365.	410.	15.	15.	0.98	0.21	0.10	14.1	0.79	119.7	-27	14.8	1.13	152
STIG1S	26218	0.	1157.	0.	0.	-879.	1221.	15.	114.	2.12	0.21	0.23	37.3	2.08	109.9	0	22.3	1.71	114
DEADV3	26218	0.	392.	0.	0.	-355.	410.	15.	15.	1.11	0.21	0.12	21.1	1.18	134.1	0	15.3	1.18	146
DEADV3	26218	0.	1190.	0.	0.	-873.	1350.	15.	129.	2.74	0.21	0.29	85.5	4.77	245.0	0	25.9	1.99	115
DEHTPM	26218	0.	365.	0.	0.	-328.	410.	15.	15.	1.10	0.21	0.18	19.0	1.06	177.9	0	14.2	1.09	154
DEHTPM	26218	0.	569.	0.	0.	-436.	735.	15.	55.	1.61	0.21	0.34	42.8	2.39	256.7	0	15.9	1.22	130
DESOA3	26218	400.	0.	0.	-400.	37.	410.	15.	15.	1.11	0.21	0.10	20.9	1.16	177.9	0	18.3	1.41	150
DESOA3	26218	1427.	0.	0.	-1427.	370.	1527.	15.	151.	3.71	0.21	0.25	123.0	6.86	294.1	0	43.8	3.36	140
DESOA3	26218	0.	400.	0.	0.	-364.	410.	15.	15.	1.11	0.21	0.10	20.9	1.16	177.9	0	15.5	1.19	144
DESOA3	26218	0.	1427.	0.	0.	-1057.	1527.	15.	151.	3.71	0.21	0.25	123.0	6.86	294.1	0	33.9	2.51	121
GTSOAD	26218	367.	0.	0.	-367.	37.	410.	15.	15.	0.87	0.21	0.18	13.5	0.75	125.1	-37	16.0	1.23	166
GTSOAD	26218	530.	0.	0.	-530.	111.	659.	15.	45.	0.82	0.21	0.31	17.9	1.00	115.4	999	16.7	1.28	151
GTRA08	26218	374.	0.	0.	-374.	37.	410.	15.	15.	0.92	0.21	0.16	15.5	0.87	142.0	-66	16.6	1.27	161
GTRA08	26218	726.	0.	0.	-726.	186.	910.	15.	76.	1.22	0.21	0.34	32.2	1.79	151.3	0	20.0	1.53	134
GTRA12	26218	372.	0.	0.	-372.	37.	410.	15.	15.	0.92	0.21	0.17	15.6	0.87	143.3	-66	16.5	1.27	161
GTRA12	26218	705.	0.	0.	-705.	181.	894.	15.	74.	1.17	0.21	0.34	30.4	1.70	147.4	0	19.4	1.49	135
GTRA16	26218	371.	0.	0.	-371.	37.	410.	15.	15.	0.93	0.21	0.17	16.1	0.90	148.0	-79	16.5	1.27	161
GTRA16	26218	673.	0.	0.	-673.	169.	853.	15.	69.	1.17	0.21	0.34	30.6	1.71	155.0	0	19.2	1.47	136
GTR208	26218	371.	0.	0.	-371.	37.	410.	15.	15.	0.90	0.21	0.17	14.9	0.83	136.8	-53	16.4	1.26	163
GTR208	26218	607.	0.	0.	-607.	140.	754.	15.	57.	0.99	0.21	0.32	23.8	1.33	134.0	0	18.1	1.39	142
GTR212	26218	372.	0.	0.	-372.	37.	410.	15.	15.	0.91	0.21	0.17	15.2	0.85	139.8	-59	16.4	1.26	162
GTR212	26218	631.	0.	0.	-631.	150.	788.	15.	61.	1.04	0.21	0.33	25.7	1.44	139.2	0	18.5	1.42	140
GTR216	26218	370.	0.	0.	-370.	37.	410.	15.	15.	0.92	0.21	0.17	15.6	0.87	143.4	-64	16.4	1.26	162
GTR216	26218	634.	0.	0.	-634.	153.	801.	15.	63.	1.09	0.21	0.34	27.5	1.53	148.1	0	18.5	1.42	139
GTRW08	26218	385.	0.	0.	-385.	37.	410.	15.	15.	0.92	0.21	0.14	15.6	0.87	138.2	-75	17.0	1.31	159
GTRW08	26218	880.	0.	0.	-880.	222.	1030.	15.	90.	1.25	0.21	0.30	32.1	1.79	124.7	0	23.0	1.76	131
GTRW12	26218	381.	0.	0.	-381.	37.	410.	15.	15.	0.92	0.21	0.15	15.6	0.87	139.7	-72	16.8	1.29	160
GTRW12	26218	861.	0.	0.	-861.	225.	1041.	15.	92.	1.25	0.21	0.32	32.3	1.80	128.2	0	22.0	1.69	131
GTRW16	26218	380.	0.	0.	-380.	37.	410.	15.	15.	0.93	0.21	0.15	16.0	0.89	143.4	-81	16.8	1.29	159
GTRW16	26218	812.	0.	0.	-812.	208.	984.	15.	85.	1.23	0.21	0.32	32.0	1.78	134.4	0	21.5	1.65	132

HONEYWELL PAGE PRINTING SYSTEM- PL185-02

DATE 06/07/79  
I&SE-PEO-ADV-DES-ENGR

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

PAGE 45

-----FUEL USE IN BTU*10**6-----																					
**COGENERATION CASE** **NO COGEN - COGEN**																					
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	REQD	COGEN	O&M	POWER	FESR	CAPITAL	NORM	\$/KW	ROI	LEVL	NORM	WRTH		
								MW	MW		/HEAT		*10**6	COST	EQVL	(%)	CHRG	ENRG			
GTR308	26218	390.	0.	0.	-390.	37.	410.	15.	15.	0.91	0.21	0.13	15.0	0.84	131.4	-65	17.1	1.31	159		
GTR308	26218	761.	0.	0.	-761.	169.	854.	15.	69.	1.08	0.21	0.26	26.4	1.47	118.3	0	21.9	1.68	134		
GTR312	26218	378.	0.	0.	-378.	37.	410.	15.	15.	0.91	0.21	0.15	15.1	0.84	135.8	-59	16.7	1.28	161		
GTR312	26218	736.	0.	0.	-736.	181.	893.	15.	74.	1.10	0.21	0.31	27.0	1.51	125.4	0	20.1	1.55	136		
GTR316	26218	379.	0.	0.	-379.	37.	410.	15.	15.	0.92	0.21	0.15	15.5	0.86	139.4	-68	16.7	1.29	150		
GTR316	26218	731.	0.	0.	-731.	178.	883.	15.	73.	1.12	0.21	0.31	27.9	1.56	130.3	0	20.3	1.56	135		
FCPADS	26218	395.	0.	0.	-395.	37.	410.	15.	15.	2.26	0.21	0.12	17.6	0.98	151.7	999	18.9	1.45	157		
FCPADS	26218	1435.	0.	0.	-1435.	392.	1599.	15.	160.	17.50	0.21	0.28	93.0	5.19	221.0	0	53.0	4.07	163		
FCMCDS	26218	377.	0.	0.	-377.	37.	410.	15.	15.	2.16	0.21	0.16	18.1	1.01	163.9	999	18.2	1.40	159		
FCMCDS	26218	1047.	0.	0.	-1047.	310.	1325.	15.	126.	13.12	0.21	0.36	80.0	4.47	260.8	0	39.2	3.01	150		



GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																		
**COGENERATION CASE** **NO COGEN - COGEN**																		
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER RECD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM WRTH ENRG
ONOCGN	28001	0.	80.	1561.	0.	0.	0.	F 33.	0.	3.18	0.10	0.	60.1	1.00	158.4	0	44.6	1.00 80
STM141	28001	0.	1425.	0.	0.	-1345.	1561.	33.	33.	1.92	0.10	0.13	38.4	0.64	92.0	-23	51.5	1.15 162
STM141	28001	0.	1529.	0.	0.	-1385.	1774.	33.	58.	1.66	0.10	0.20	39.8	0.66	88.9	-19	49.4	1.11 154
STM141	28001	0.	0.	1425.	0.	80.	136.	F 33.	33.	4.40	0.10	0.13	77.7	1.29	186.1	22	39.2	0.88 137
STM141	28001	0.	0.	1529.	0.	143.	245.	F 33.	58.	4.00	0.10	0.20	76.0	1.27	169.7	35	35.3	0.79 130
STM141	28001	0.	0.	1425.	0.	80.	136.	A 33.	33.	4.17	0.10	0.13	62.9	1.05	150.6	122	37.3	0.84 141
STM141	28001	0.	0.	1529.	0.	143.	245.	A 33.	58.	3.88	0.10	0.20	58.1	0.97	129.6	999	33.2	0.74 135
STM088	28001	0.	1425.	0.	0.	-1345.	1561.	33.	33.	1.84	0.10	0.13	36.8	0.61	88.1	-21	51.2	1.15 163
STM088	28001	0.	1458.	0.	0.	-1358.	1629.	33.	41.	1.56	0.10	0.16	36.2	0.60	84.8	-19	50.3	1.13 155
STM088	28001	0.	0.	1425.	0.	80.	136.	F 33.	33.	4.27	0.10	0.13	76.6	1.28	183.6	24	38.9	0.87 137
STM088	28001	0.	0.	1458.	0.	100.	171.	F 33.	41.	3.72	0.10	0.16	71.1	1.18	166.5	41	36.7	0.82 130
STM088	28001	0.	0.	1425.	0.	80.	136.	A 33.	33.	4.12	0.10	0.13	58.9	0.98	141.1	999	38.8	0.83 143
STM088	28001	0.	0.	1458.	0.	100.	171.	A 33.	41.	3.74	0.10	0.16	56.1	0.93	131.2	999	35.1	0.79 135
PFBSTM	28001	0.	0.	1430.	0.	80.	131.	33.	33.	5.20	0.10	0.13	78.2	1.30	186.5	19	40.1	0.90 137
PFBSTM	28001	0.	0.	1710.	0.	244.	401.	33.	99.	6.81	0.10	0.27	75.2	1.25	150.0	43	33.0	0.74 127
TISTMT	28001	0.	1428.	0.	0.	-1349.	1561.	33.	33.	3.26	0.10	0.13	92.1	1.53	219.9	0	58.7	1.32 144
TISTMT	28001	0.	1850.	0.	0.	-1520.	2399.	33.	135.	5.95	0.10	0.32	205.8	3.43	379.8	0	66.5	1.49 125
TISTMT	28001	0.	0.	1428.	0.	80.	133.	33.	33.	5.74	0.10	0.13	134.1	2.23	320.5	2	46.7	1.05 130
TISTMT	28001	0.	0.	1850.	0.	330.	549.	33.	135.	8.74	0.10	0.32	258.9	4.31	477.7	2	50.3	1.13 113
TIHRSG	28001	0.	1483.	0.	0.	-1404.	1561.	33.	33.	3.79	0.10	0.10	117.4	1.95	270.0	0	63.5	1.42 138
TIHRSG	28001	0.	1703.	0.	0.	-1531.	1871.	33.	70.	5.19	0.10	0.17	184.9	3.08	370.4	0	71.4	1.60 125
TIHRSG	28001	0.	0.	1483.	0.	80.	77.	33.	33.	6.52	0.10	0.10	166.7	2.78	383.6	0	52.0	1.17 125
TIHRSG	28001	0.	0.	1703.	0.	172.	167.	33.	70.	7.90	0.10	0.17	234.8	3.91	470.3	0	57.2	1.28 114
STIRL	28001	1487.	0.	0.	-1487.	80.	1561.	33.	33.	2.28	0.10	0.09	55.1	0.92	126.5	158	66.2	1.48 156
STIRL	28001	2306.	0.	0.	-2306.	418.	2692.	33.	170.	3.71	0.10	0.26	117.8	1.96	174.4	0	78.3	1.76 127
STIRL	28001	0.	1487.	0.	0.	-1407.	1561.	33.	33.	2.28	0.10	0.09	55.1	0.92	126.5	-86	55.5	1.24 150
STIRL	28001	0.	2306.	0.	0.	-1888.	2692.	33.	170.	3.71	0.10	0.26	118.0	1.96	174.6	0	61.8	1.39 118
STIRL	28001	0.	0.	1487.	0.	80.	74.	33.	33.	4.82	0.10	0.09	97.7	1.63	224.2	9	42.7	0.96 129
STIRL	28001	0.	0.	2306.	0.	418.	385.	33.	170.	7.92	0.10	0.26	210.4	3.50	311.4	5	44.9	1.01 99
HEGT85	28001	0.	0.	1592.	0.	80.	-31.	A 33.	33.	5.13	0.10	0.03	111.6	1.86	239.4	1	46.7	1.05 121
HEGT85	28001	0.	0.	9304.	0.	2147.	-823.	A 33.	875.	31.64	0.10	0.12	833.7	13.88	305.8	0	123.5	2.77 104
HEGT50	28001	0.	0.	1576.	0.	80.	-15.	A 33.	33.	5.08	0.10	0.04	108.5	1.81	235.0	2	46.0	1.03 122
HEGT60	28001	0.	0.	3785.	0.	705.	-132.	A 33.	287.	11.55	0.10	0.13	272.1	4.53	245.3	0	59.5	1.33 79
HEGT00	28001	0.	0.	1562.	0.	80.	-1.	A 33.	33.	5.05	0.10	0.05	104.3	1.74	227.9	3	45.2	1.01 124
HEGT00	28001	0.	0.	2252.	0.	285.	-4.	A 33.	116.	6.75	0.10	0.11	149.4	2.49	226.3	2	47.6	1.07 97
FCMCCL	28001	0.	0.	1456.	0.	80.	105.	33.	33.	5.55	0.10	0.11	106.7	1.78	250.0	5	44.3	0.99 131
FCMCCL	28001	0.	0.	2324.	0.	508.	670.	33.	207.	11.53	0.10	0.34	183.4	3.05	269.4	8	39.5	0.89 103
FCSTCL	28001	0.	0.	1449.	0.	80.	112.	33.	33.	5.45	0.10	0.12	104.7	1.74	246.5	6	43.9	0.98 131
FCSTCL	28001	0.	0.	2732.	0.	739.	1037.	33.	302.	13.72	0.10	0.39	217.9	3.63	272.2	9	34.0	0.76 100
IGGTST	28001	0.	0.	1490.	0.	80.	71.	33.	33.	4.65	0.10	0.09	99.6	1.66	228.1	7	42.3	0.97 129
IGGTST	28001	0.	0.	2546.	0.	509.	451.	33.	207.	5.63	0.10	0.27	178.8	2.98	239.7	9	37.2	0.83 94
GTSOAR	28001	0.	1486.	0.	0.	-1406.	1561.	33.	33.	2.04	0.10	0.09	48.8	0.81	112.2	-45	54.5	1.22 153
GTSOAR	28001	0.	2594.	0.	0.	-2053.	3104.	33.	220.	2.88	0.10	0.29	88.6	1.48	116.6	0	56.9	1.28 119

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																				
ECS	PROCS	**COGENERATION CASE**				**NOCOGEN - COGEN**				POWER REQD MW	COGEN POWER MW	G&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW ROI EQVL	ROII (%)	LEVEL CHRG	NORM WRTH ENRG
		DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	DISTIL	RESIDL											
GTAC08	28001	0.	1456.	0.	0.	-1376.	1561.	33.	33.	1.91	0.10	0.11	43.5	0.72	101.9	-30	52.9	1.19	157	
GTAC08	28001	0.	2138.	0.	0.	-1723.	2683.	33.	169.	2.22	0.10	0.31	64.0	1.07	102.2	0	49.5	1.11	131	
GTAC12	28001	0.	1459.	0.	0.	-1379.	1561.	33.	33.	2.00	0.10	0.11	47.6	0.79	111.3	-38	53.5	1.20	155	
GTAC12	28001	0.	2370.	0.	0.	-1850.	3033.	33.	212.	2.57	0.10	0.33	77.1	1.28	111.0	0	49.9	1.12	125	
GTAC16	28001	0.	1463.	0.	0.	-1383.	1561.	33.	33.	2.02	0.10	0.11	48.5	0.81	113.2	-41	53.8	1.21	154	
GTAC16	28001	0.	2544.	0.	0.	-1953.	3271.	33.	241.	2.86	0.10	0.34	88.3	1.47	118.4	0	51.1	1.15	122	
GTWC16	28001	0.	1479.	0.	0.	-1399.	1561.	33.	33.	2.02	0.10	0.10	48.3	0.80	111.4	-42	54.2	1.22	154	
GTWC16	28001	0.	2718.	0.	0.	-2103.	3355.	33.	251.	2.73	0.10	0.32	82.4	1.37	103.5	0	53.9	1.21	121	
CC1626	28001	0.	1481.	0.	0.	-1402.	1561.	33.	33.	2.12	0.10	0.10	48.3	0.80	111.2	-47	54.6	1.22	154	
CC1626	28001	0.	3490.	0.	0.	-2556.	4422.	33.	381.	3.66	0.10	0.35	108.3	1.80	105.9	0	56.1	1.26	117	
CC1622	28001	0.	1474.	0.	0.	-1394.	1561.	33.	33.	2.12	0.10	0.10	48.3	0.80	111.9	-46	54.3	1.22	154	
CC1622	28001	0.	3184.	0.	0.	-2345.	4105.	33.	342.	3.68	0.10	0.36	114.1	1.90	122.2	0	54.8	1.23	117	
CC1222	28001	0.	1472.	0.	0.	-1392.	1561.	33.	33.	2.11	0.10	0.10	47.6	0.79	110.4	-44	54.2	1.21	154	
CC1222	28001	0.	3157.	0.	0.	-2322.	4089.	33.	340.	3.57	0.10	0.36	106.4	1.77	115.1	0	53.4	1.20	118	
CC0872	28001	0.	1460.	0.	0.	-1380.	1561.	33.	33.	2.10	0.10	0.11	47.3	0.79	110.7	-41	53.7	1.21	155	
CC0872	28001	0.	2668.	0.	0.	-2007.	3506.	33.	269.	2.95	0.10	0.36	83.6	1.39	107.0	0	49.1	1.10	123	
STIG15	28001	0.	1581.	0.	0.	-1501.	1561.	33.	33.	2.31	0.10	0.04	48.5	0.81	104.7	-55	57.8	1.30	148	
STIG15	28001	0.	84615.	0.	0.	-61444.	78863.	33.	9449.	142.09	0.10	0.17	2270.3	37.79	91.6	0	1173.3	26.32	696	
STIG10	28001	0.	1555.	0.	0.	-1475.	1561.	33.	33.	2.19	0.10	0.05	47.5	0.79	104.2	-49	56.8	1.27	150	
STIG10	28001	0.	8302.	0.	0.	-6159.	8468.	33.	874.	11.72	0.10	0.22	222.1	3.70	91.3	0	129.5	2.91	129	
STIG15	28001	0.	1543.	0.	0.	-1463.	1561.	33.	33.	2.20	0.10	0.06	47.0	0.78	104.0	-46	56.3	1.26	151	
STIG15	28001	0.	5218.	0.	0.	-3961.	5503.	33.	513.	7.50	0.10	0.23	136.2	2.27	89.1	0	91.0	2.04	117	
DEADV3	28001	0.	1521.	0.	0.	-1441.	1561.	33.	33.	2.39	0.10	0.07	60.7	1.01	136.2	999	57.3	1.28	146	
DEADV3	28001	0.	5366.	0.	0.	-3935.	6085.	33.	584.	9.83	0.10	0.29	352.1	5.86	223.9	0	106.5	2.39	120	
DEHTPM	28001	0.	1462.	0.	0.	-1383.	1561.	33.	33.	2.49	0.10	0.11	62.2	1.04	145.2	0	55.7	1.25	149	
DEHTPM	28001	0.	2567.	0.	0.	-1964.	3314.	33.	246.	5.55	0.10	0.34	185.2	3.08	246.1	0	63.7	1.43	115	
DESOA3	28001	1540.	0.	0.	-1540.	80.	1561.	33.	33.	2.52	0.10	0.06	66.0	1.10	146.3	0	69.6	1.56	150	
DESOA3	28001	6433.	0.	0.	-6433.	1669.	6883.	33.	681.	14.00	0.10	0.25	516.0	8.59	273.7	0	188.7	4.23	158	
DESOA3	28001	0.	1540.	0.	0.	-1460.	1561.	33.	33.	2.52	0.10	0.06	66.0	1.10	146.3	0	58.6	1.31	143	
DESOA3	28001	0.	6433.	0.	0.	-4764.	6883.	33.	681.	14.00	0.10	0.25	516.0	8.59	273.7	0	142.4	3.19	132	
GTSOAD	28001	1468.	0.	0.	-1458.	80.	1561.	33.	33.	1.97	0.10	0.11	46.2	0.77	107.4	-67	64.2	1.44	161	
GTSOAD	28001	2388.	0.	0.	-2388.	501.	2972.	33.	204.	2.33	0.10	0.31	67.3	1.12	96.2	0	68.0	1.52	136	
GTRA08	28001	1482.	0.	0.	-1482.	80.	1561.	33.	33.	2.05	0.10	0.10	49.8	0.83	114.8	-89	65.2	1.46	159	
GTRA08	28001	3271.	0.	0.	-3271.	839.	4104.	33.	342.	3.87	0.10	0.34	126.2	2.10	131.7	0	82.3	1.85	128	
GTRA12	28001	1478.	0.	0.	-1478.	80.	1561.	33.	33.	2.06	0.10	0.10	50.1	0.83	115.8	-90	65.1	1.46	159	
GTRA12	28001	3177.	0.	0.	-3177.	818.	4031.	33.	333.	3.79	0.10	0.34	123.2	2.05	132.3	0	80.0	1.80	128	
GTRA16	28001	1476.	0.	0.	-1476.	80.	1561.	33.	33.	2.08	0.10	0.10	51.0	0.85	117.8	-96	65.1	1.46	158	
GTRA16	28001	3036.	0.	0.	-3036.	761.	3843.	33.	310.	3.79	0.10	0.34	123.7	2.06	139.1	0	79.2	1.78	128	
GTR208	28001	1477.	0.	0.	-1477.	80.	1561.	33.	33.	2.03	0.10	0.10	48.7	0.81	112.6	-91	64.9	1.45	159	
GTR208	28001	2736.	0.	0.	-2736.	629.	3401.	33.	257.	3.08	0.10	0.32	96.3	1.60	120.2	0	74.8	1.68	130	
GTR212	28001	1477.	0.	0.	-1477.	80.	1561.	33.	33.	2.04	0.10	0.10	49.3	0.82	113.9	-84	65.0	1.46	159	
GTR212	28001	2845.	0.	0.	-2845.	575.	3553.	33.	275.	3.28	0.10	0.33	104.0	1.73	124.7	0	76.3	1.71	129	
GTR216	28001	1474.	0.	0.	-1474.	80.	1561.	33.	33.	2.06	0.10	0.10	50.1	0.83	115.9	-89	64.9	1.46	159	
GTR216	28001	2957.	0.	0.	-2857.	692.	3611.	33.	282.	3.48	0.10	0.34	111.7	1.86	133.4	0	76.4	1.71	128	

HONEYWELL PAGE PRINTING SYSTEM - P118-D2

ORIGINAL PAGE IS  
OF POOR QUALITY

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS.

-----FUEL USE IN BTU*10**6-----																		
**COGENERATION CASE** **NOCOGEN - COGEN**																		
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVEL CHRG	NORM WRTM ENRG
GTRW08	28001	1507.	0.	0.	-1507.	80.	1561.	33.	33.	2.05	0.10	0.08	49.7	0.83	112.4	-91	66.2	1.48 157
GTRW08	28001	3966.	0.	0.	-3966.	1001.	4644.	33.	408.	3.95	0.10	0.30	127.2	2.12	109.4	0	96.3	2.16 130
GTRW12	28001	1497.	0.	0.	-1497.	80.	1561.	33.	33.	2.05	0.10	0.09	49.6	0.83	113.1	-89	65.3	1.48 158
GTRW12	28001	3880.	0.	0.	-3880.	1015.	4593.	33.	414.	3.97	0.10	0.32	128.0	2.13	112.6	0	91.9	2.06 130
GTRW16	28001	1495.	0.	0.	-1495.	80.	1561.	33.	33.	2.06	0.10	0.09	50.2	0.84	114.6	-93	65.8	1.48 158
GTRW16	28001	3659.	0.	0.	-3659.	939.	4438.	33.	383.	3.91	0.10	0.32	126.6	2.11	118.1	0	89.3	2.00 129
GTR308	28001	1517.	0.	0.	-1517.	80.	1561.	33.	33.	2.04	0.10	0.08	48.8	0.81	109.7	-86	66.4	1.49 157
GTR308	28001	3429.	0.	0.	-3429.	764.	3852.	33.	312.	3.13	0.10	0.26	96.1	1.60	95.6	0	90.8	2.04 129
GTR312	28001	1492.	0.	0.	-1492.	80.	1561.	33.	33.	2.03	0.10	0.09	48.7	0.81	111.5	-83	65.5	1.47 159
GTR312	28001	3319.	0.	0.	-3319.	816.	4025.	33.	333.	3.24	0.10	0.31	100.8	1.68	103.6	0	82.8	1.86 130
GTR316	28001	1493.	0.	0.	-1493.	80.	1561.	33.	33.	2.04	0.10	0.09	49.4	0.82	112.9	-87	65.6	1.47 158
GTR316	28001	3296.	0.	0.	-3296.	803.	3983.	33.	327.	3.31	0.10	0.31	103.5	1.72	107.2	0	83.3	1.87 129
FCPADS	28001	1528.	0.	0.	-1528.	80.	1561.	33.	33.	5.29	0.10	0.07	58.8	0.98	131.3	999	71.2	1.60 154
FCPADS	28001	6471.	0.	0.	-6471.	1767.	7211.	33.	721.	80.02	0.10	0.28	379.9	6.32	200.4	9	233.7	5.24 190
FCMCDS	28001	1489.	0.	0.	-1489.	80.	1561.	33.	33.	5.06	0.10	0.09	59.8	1.00	137.1	999	69.6	1.56 156
FCMCDS	28001	4721.	0.	0.	-4721.	1398.	5974.	33.	570.	60.04	0.10	0.36	340.4	5.66	246.0	0	171.6	3.85 166

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																				
**COGENERATION CASE** **NOCOGEN - COGEN**																				
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD	COGEN POWER	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST	NORM COST	\$/KW EGVL	ROI (%)	LEVL CHRGS	NORM ENRG	WRTH	
								MW	MW											
DNOCGN	28002	0.	189.	1874.	0.	0.	0.	F	77.	0.	3.09	0.25	0.	58.4	1.00	160.7	0	58.4	1.00	80
STM141	28002	0.	1517.	174.	0.	-1327.	1700.		77.	56.	1.63	0.25	0.18	38.7	0.66	90.1	-9	59.6	1.02	152
STM141	28002	0.	52.	1639.	0.	137.	235.	F	77.	56.	3.88	0.25	0.18	73.8	1.26	172.0	45	46.1	0.79	130
STM141	28002	0.	52.	1639.	0.	137.	235.	A	77.	56.	3.76	0.25	0.18	56.6	0.97	131.7	999	44.1	0.76	136
STM088	28002	0.	1490.	313.	0.	-1301.	1561.		77.	39.	1.53	0.25	0.13	35.1	0.60	85.8	-16	62.7	1.07	147
STM038	28002	0.	93.	1710.	0.	96.	164.	F	77.	39.	3.61	0.25	0.13	69.0	1.18	168.6	45	49.8	0.85	124
STM088	28002	0.	93.	1710.	0.	96.	164.	A	77.	39.	3.63	0.25	0.13	54.6	0.93	133.4	999	48.2	0.83	129
PFBSTM	28002	0.	0.	1563.	0.	189.	311.		77.	77.	6.53	0.25	0.24	77.6	1.33	169.4	43	43.8	0.75	147
PFBSTM	28002	0.	0.	1638.	0.	234.	384.		77.	95.	6.58	0.25	0.27	73.0	1.25	152.1	61	41.1	0.70	140
TISTMT	28002	0.	1559.	0.	0.	-1369.	1874.		77.	77.	4.70	0.25	0.24	146.6	2.51	321.0	0	70.2	1.20	146
TISTMT	28002	0.	1772.	0.	0.	-1456.	2299.		77.	129.	5.77	0.25	0.32	199.1	3.41	383.3	0	73.3	1.26	139
TISTMT	28002	0.	0.	1559.	0.	189.	315.		77.	77.	7.32	0.25	0.24	191.8	3.28	420.0	6	56.9	0.97	136
TISTMT	28002	0.	0.	1772.	0.	316.	526.		77.	129.	8.47	0.25	0.32	250.4	4.29	482.3	5	57.9	0.99	129
TIHRSG	28002	0.	1656.	81.	0.	-1467.	1793.		77.	67.	5.03	0.25	0.16	178.8	3.06	373.8	0	79.3	1.36	125
TIHRSG	28002	0.	24.	1713.	0.	165.	160.		77.	67.	7.65	0.25	0.16	227.1	3.89	474.7	0	65.7	1.13	116
STIRL	28002	1699.	0.	0.	-1699.	189.	1874.		77.	77.	2.84	0.25	0.18	74.4	1.27	149.5	0	77.1	1.32	154
STIRL	28002	2209.	0.	0.	-2209.	400.	2579.		77.	163.	3.57	0.25	0.26	113.0	1.94	174.6	0	84.4	1.45	141
STIRL	28002	0.	1699.	0.	0.	-1509.	1874.		77.	77.	2.85	0.25	0.18	74.5	1.28	149.6	0	64.8	1.11	149
STIRL	28002	0.	2209.	0.	0.	-1809.	2579.		77.	163.	3.58	0.25	0.26	113.2	1.94	174.8	0	68.5	1.17	134
STIRL	28002	0.	0.	1699.	0.	189.	175.		77.	77.	5.87	0.25	0.18	129.1	2.21	259.4	12	50.9	0.67	132
STIRL	28002	0.	0.	2209.	0.	400.	370.		77.	163.	7.62	0.25	0.26	201.7	3.45	311.6	8	52.4	0.90	118
HEGT85	28002	0.	0.	1946.	0.	189.	-73.	A	77.	77.	6.80	0.25	0.06	157.8	2.70	276.6	3	59.9	1.03	117
HEGT85	28002	0.	0.	8915.	0.	2057.	-789.	A	77.	839.	30.59	0.25	0.12	808.8	13.85	309.6	0	129.0	2.21	91
HEGT60	28002	0.	0.	1909.	0.	189.	-35.	A	77.	77.	6.63	0.25	0.07	149.9	2.57	267.9	5	58.2	1.00	119
HEGT60	28002	0.	0.	3627.	0.	675.	-126.	A	77.	275.	11.17	0.25	0.13	263.9	4.52	248.4	1	66.7	1.14	93
HEGT00	28002	0.	0.	1877.	0.	189.	-3.	A	77.	77.	6.22	0.25	0.09	130.9	2.24	238.0	8	55.1	0.94	122
HEGT00	28002	0.	0.	2158.	0.	273.	-4.	A	77.	111.	6.53	0.25	0.11	144.9	2.48	229.1	7	55.2	0.95	111
FCMCCL	28002	0.	0.	1624.	0.	189.	250.		77.	77.	7.40	0.25	0.21	134.2	2.30	281.9	10	52.3	0.90	136
FCMCCL	28002	0.	0.	2227.	0.	437.	642.		77.	198.	11.12	0.25	0.34	177.8	3.04	272.4	11	47.5	0.81	123
FCSTCL	28002	0.	0.	1608.	0.	189.	266.		77.	77.	7.14	0.25	0.22	131.8	2.26	279.7	11	51.5	0.88	137
FCSTCL	28002	0.	0.	2618.	0.	708.	994.		77.	289.	13.23	0.25	0.39	211.2	3.62	275.2	12	42.2	0.72	117
IGGTST	28002	0.	0.	1706.	0.	189.	168.		77.	77.	5.19	0.25	0.17	125.3	2.15	250.7	12	50.6	0.87	131
IGGTST	28002	0.	0.	2440.	0.	487.	432.		77.	199.	5.39	0.25	0.27	169.7	2.91	237.4	13	44.7	0.77	115
GTSOAR	28002	0.	1695.	0.	0.	-1506.	1874.		77.	77.	2.30	0.25	0.18	56.5	0.97	113.8	-62	62.3	1.07	155
GTSOAR	28002	0.	2486.	0.	0.	-1967.	2974.		77.	211.	2.80	0.25	0.29	85.9	1.47	117.9	0	64.0	1.10	137
GTAC08	28002	0.	1625.	0.	0.	-1436.	1874.		77.	77.	2.11	0.25	0.21	49.5	0.85	104.0	-10	59.1	1.01	161
GTAC08	28002	0.	2048.	0.	0.	-1651.	2571.		77.	152.	2.16	0.25	0.31	62.0	1.06	103.3	44	56.8	0.97	149
GTAC12	28002	0.	1632.	0.	0.	-1443.	1874.		77.	77.	2.20	0.25	0.21	52.8	0.90	110.3	-17	59.8	1.02	159
GTAC12	28002	0.	2271.	0.	0.	-1773.	2906.		77.	203.	2.49	0.25	0.33	74.6	1.28	112.1	10	57.3	0.98	143
GTAC16	28002	0.	1641.	0.	0.	-1451.	1874.		77.	77.	2.25	0.25	0.20	54.9	0.94	114.1	-26	60.3	1.03	156
GTAC16	28002	0.	2437.	0.	0.	-1871.	3134.		77.	231.	2.78	0.25	0.34	85.4	1.46	119.5	5	58.4	1.00	139
GTWC16	28002	0.	1678.	0.	0.	-1489.	1874.		77.	77.	2.21	0.25	0.19	53.0	0.91	107.8	-28	61.3	1.05	157
GTWC16	28002	0.	2605.	0.	0.	-2015.	3214.		77.	240.	2.66	0.25	0.32	79.9	1.37	104.7	0	61.1	1.05	137

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

ECS	PROCS	DISTILL	RESIDL	COAL	DISTILL	RESIDL	COAL	COGEN**	POWER	COGEN	O&M	POWER	FESR	CAPITAL	NORM	\$/KWH	ROI	LEVEL	NORM	WRTH
								MW	REQD	MW		RATIO		*10**6	COST	EVGL	(%)	CHRG	ENRG	
CC1625	28002	0.	1685.	0.	-1496.	1874.	77.	77.	77.	2.37	0.25	0.18	54.0	0.92	109.3	-44	61.9	1.06	157	
CC1626	28002	0.	3344.	0.	-2449.	4237.	77.	365.	77.	3.50	0.25	0.35	102.7	1.76	104.7	0	62.9	1.08	126	
CC1622	28002	0.	1666.	0.	-1477.	1874.	77.	77.	77.	2.38	0.25	0.19	55.3	0.95	113.2	-52	61.5	1.05	157	
CC1622	28002	0.	3051.	0.	-2247.	3933.	77.	328.	77.	3.58	0.25	0.36	110.3	1.89	123.4	0	62.0	1.06	128	
CC1222	28002	0.	1662.	0.	-1473.	1874.	77.	77.	77.	2.36	0.25	0.19	53.8	0.92	110.5	-36	61.2	1.05	158	
CC1222	28002	0.	3025.	0.	-2225.	3918.	77.	326.	77.	3.38	0.25	0.36	99.2	1.70	112.0	0	60.1	1.03	129	
CC0822	28002	0.	1634.	0.	-1444.	1874.	77.	77.	77.	2.32	0.25	0.21	52.3	0.90	109.3	-20	60.0	1.03	160	
CC0822	28002	0.	2956.	0.	-1923.	3360.	77.	258.	77.	2.87	0.25	0.36	81.0	1.39	108.2	11	56.5	0.97	139	
ST1G15	28002	0.	1921.	0.	-1731.	1874.	77.	77.	77.	3.07	0.25	0.17	59.0	1.01	104.8	999	70.5	1.21	144	
ST1G15	28002	0.	81077.	0.	-58875.	75570.	77.	9053.	77.	136.27	0.25	0.17	2177.7	37.28	91.7	0	1133.9	19.42	523	
ST1G10	28002	0.	1859.	0.	-1670.	1874.	77.	77.	77.	2.79	0.25	0.10	56.8	0.97	104.3	151	68.0	1.17	147	
ST1G10	28002	0.	7955.	0.	-5902.	8114.	77.	837.	77.	11.29	0.25	0.22	214.0	3.66	91.8	0	133.6	2.29	115	
ST1G1S	28002	0.	1831.	0.	-1642.	1874.	77.	77.	77.	2.71	0.25	0.11	52.4	0.90	97.6	-59	66.6	1.14	151	
ST1G1S	28002	0.	5000.	0.	-3795.	5273.	77.	491.	77.	7.39	0.25	0.23	137.7	2.36	24.0	0	97.5	1.67	114	
DEADV3	28002	0.	1779.	0.	-1589.	1874.	77.	77.	77.	3.14	0.25	0.14	86.3	1.48	165.5	0	68.9	1.18	143	
DEADV3	28002	0.	5142.	0.	-3771.	5830.	77.	559.	77.	9.46	0.25	0.29	337.5	5.78	224.1	0	111.5	1.91	119	
DEHTPM	28002	0.	1639.	0.	-1450.	1874.	77.	77.	77.	3.21	0.25	0.21	86.4	1.48	179.8	0	64.6	1.11	143	
DEHTPM	28002	0.	2460.	0.	-1982.	2176.	77.	236.	77.	5.35	0.25	0.34	177.5	3.04	246.2	0	70.4	1.21	130	
DESOA3	28002	1823.	0.	-1823.	189.	1874.	77.	77.	77.	3.46	0.25	0.12	98.9	1.69	185.1	0	85.1	1.46	144	
DESOA3	28002	6164.	0.	-6164.	1599.	6595.	77.	652.	77.	13.45	0.25	0.25	494.7	8.47	273.8	0	145.8	2.50	118	
DESOA3	28002	0.	1823.	0.	-1634.	1874.	77.	77.	77.	2.12	0.25	0.20	49.5	0.85	102.2	-69	71.9	1.23	165	
DESOA3	28002	0.	6164.	0.	-4565.	6595.	77.	652.	77.	13.45	0.25	0.25	494.7	8.47	273.8	0	145.8	2.50	118	
GTSOAD	28002	1653.	0.	-1653.	189.	1874.	77.	77.	77.	2.25	0.25	0.31	65.2	1.12	97.2	0	74.5	1.28	152	
GTSOAD	28002	2288.	0.	-2288.	480.	2848.	77.	196.	77.	2.25	0.25	0.31	65.2	1.12	97.2	0	74.5	1.28	152	
GTRAD8	28002	1626.	0.	-1626.	189.	1874.	77.	77.	77.	2.35	0.25	0.18	58.8	1.01	119.0	999	74.2	1.27	160	
GTRAD8	28002	3135.	0.	-3135.	804.	3933.	77.	328.	77.	3.77	0.25	0.34	122.3	2.09	133.1	0	88.4	1.51	135	
GTRA12	28002	1676.	0.	-1676.	189.	1874.	77.	77.	77.	2.32	0.25	0.19	57.5	0.99	117.1	999	73.9	1.27	161	
GTRA12	28002	3044.	0.	-3044.	783.	3863.	77.	319.	77.	3.68	0.25	0.34	119.3	2.04	133.7	0	86.2	1.48	136	
GTRA16	28002	1673.	0.	-1673.	189.	1874.	77.	77.	77.	2.36	0.25	0.19	59.0	1.01	120.4	999	73.9	1.27	160	
GTRA16	28002	2909.	0.	-2909.	730.	3683.	77.	298.	77.	3.68	0.25	0.34	119.8	2.05	140.5	0	85.4	1.46	137	
GTR208	28002	1674.	0.	-1674.	189.	1874.	77.	77.	77.	2.25	0.25	0.19	54.5	0.93	111.1	134	73.4	1.26	162	
GTR208	28002	2621.	0.	-2621.	603.	3258.	77.	246.	77.	2.88	0.25	0.32	88.8	1.52	115.6	0	80.5	1.38	143	
GTR212	28002	1675.	0.	-1675.	189.	1874.	77.	77.	77.	2.28	0.25	0.19	55.7	0.95	113.4	171	73.6	1.26	161	
GTR212	28002	2726.	0.	-2726.	647.	3405.	77.	264.	77.	3.19	0.25	0.33	100.7	1.72	126.0	0	82.6	1.41	140	
GTR216	28002	1668.	0.	-1668.	189.	1874.	77.	77.	77.	2.32	0.25	0.19	57.4	0.98	117.5	999	73.5	1.26	161	
GTR216	28002	2737.	0.	-2737.	663.	3460.	77.	270.	77.	3.38	0.25	0.34	108.1	1.85	134.8	0	82.6	1.42	139	
GTRH08	28002	1746.	0.	-1746.	189.	1874.	77.	77.	77.	2.29	0.25	0.15	55.7	0.95	108.8	199	76.4	1.31	158	
GTRH08	28002	3800.	0.	-3800.	959.	4450.	77.	391.	77.	3.84	0.25	0.30	123.3	2.11	110.8	0	101.8	1.74	131	
GTRW12	28002	1722.	0.	-1722.	189.	1874.	77.	77.	77.	2.28	0.25	0.17	55.6	0.95	110.2	188	75.4	1.29	159	
GTRW12	28002	3718.	0.	-3718.	973.	4496.	77.	397.	77.	3.86	0.25	0.32	124.2	2.13	114.0	0	97.6	1.67	131	
GTRW16	28002	1717.	0.	-1717.	189.	1874.	77.	77.	77.	2.30	0.25	0.17	56.6	0.97	112.5	999	75.3	1.29	159	
GTRW16	28002	3506.	0.	-3506.	900.	4252.	77.	367.	77.	3.81	0.25	0.32	122.8	2.10	119.5	0	95.1	1.63	132	
GTR308	28002	1769.	0.	-1769.	189.	1874.	77.	77.	77.	2.26	0.25	0.14	54.3	0.93	104.7	158	77.1	1.32	138	
GTR308	28002	3226.	0.	-3226.	732.	3691.	77.	299.	77.	3.05	0.25	0.26	93.1	1.59	96.7	0	96.5	1.65	136	

DATE 06/07/79  
I&SE-PEG-ADV-DES-ENGR

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

PAGE 51

-----FUEL USE IN BTU\*10\*\*6-----

\*\*COGENERATION CASE\*\* \*\*NOCOGEN - COGEN\*\*

ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	REGD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVEL CHRG	NORM ENRG	WRTH
GTR312	28002	1710.	0.	0.	-1710.	189.	1874.	77.	77.	2.24	0.25	0.17	54.0	0.92	107.8	134	74.7	1.28	161
GTR312	28002	3180.	0.	0.	-3180.	782.	3857.	77.	319.	3.15	0.25	0.31	97.7	1.67	104.9	0	88.8	1.52	137
GTR316	28002	1712.	0.	0.	-1712.	189.	1874.	77.	77.	2.27	0.25	0.17	55.1	0.94	109.9	165	75.0	1.28	160
GTR316	28002	3158.	0.	0.	-3158.	770.	3816.	77.	314.	3.22	0.25	0.31	100.4	1.72	108.5	0	89.3	1.53	137
FCPADS	28002	1795.	0.	0.	-1795.	189.	1874.	77.	77.	10.23	0.25	0.13	81.2	1.39	154.4	0	88.9	1.52	152
FCPADS	28002	6200.	0.	0.	-6200.	1693.	6909.	77.	691.	76.70	0.25	0.28	364.3	6.24	200.5	0	233.3	4.00	161
FCMCDS	28002	1704.	0.	0.	-1704.	189.	1874.	77.	77.	9.71	0.25	0.17	84.3	1.44	168.7	0	85.2	1.46	155
FCMCDS	28002	4524.	0.	0.	-4524.	1340.	5725.	77.	546.	57.55	0.25	0.36	326.4	5.59	246.3	0	173.8	2.98	149

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																				
**COGENERATION CASE** **NOCOGEN - COGEN**																				
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM WRTH ENRG		
ONOCGN	28003	0.	238.	1912.	0.	0.	0.	F	97.	0.	2.88	0.35	0.	54.4	1.00	166.7	0	62.2	1.00	80
STM141	28003	0.	1431.	385.	0.	-1193.	1527.		97.	50.	1.54	0.35	0.16	35.9	0.66	93.0	-9	63.2	1.02	147
STM141	28003	0.	115.	1701.	0.	123.	211.	F	97.	50.	3.61	0.35	0.16	68.5	1.26	177.7	44	51.2	0.82	125
STM141	28003	0.	115.	1701.	0.	123.	211.	A	97.	50.	3.49	0.35	0.16	53.0	0.97	137.3	999	49.4	0.79	131
STM088	28003	0.	1407.	510.	0.	-1169.	1403.		97.	35.	1.44	0.35	0.11	32.6	0.60	88.5	-15	65.9	1.06	141
STM088	28003	0.	152.	1765.	0.	86.	147.	F	97.	35.	3.37	0.35	0.11	64.0	1.18	174.1	45	54.4	0.88	119
STM088	28003	0.	152.	1765.	0.	86.	147.	A	97.	35.	3.37	0.35	0.11	51.1	0.94	138.9	999	53.1	0.85	124
PFBSTM	28003	0.	28.	1567.	0.	210.	345.		97.	86.	6.03	0.35	0.26	68.0	1.25	157.5	66	44.5	0.72	139
TISTMT	28003	0.	1515.	0.	0.	-1277.	1912.		97.	97.	5.08	0.35	0.30	163.8	3.01	368.9	0	71.1	1.14	148
TISTMT	28003	0.	1592.	0.	0.	-1308.	2065.		97.	116.	5.34	0.35	0.32	183.1	3.36	392.4	0	72.1	1.16	139
TISTMT	28003	0.	0.	1515.	0.	238.	397.		97.	97.	7.72	0.35	0.30	212.9	3.91	479.6	6	58.8	0.95	139
TISTMT	28003	0.	0.	1592.	0.	284.	473.		97.	116.	7.82	0.35	0.32	230.5	4.24	493.9	6	58.4	0.94	131
TIHRSG	28003	0.	1557.	302.	0.	-1318.	1611.		97.	60.	4.65	0.35	0.14	164.4	3.02	382.5	0	81.1	1.31	119
TIHRSG	28003	0.	90.	1768.	0.	148.	144.		97.	60.	7.05	0.35	0.14	208.9	3.84	486.1	0	69.2	1.11	111
STIRL	28003	1692.	0.	0.	-1692.	238.	1912.		97.	97.	3.02	0.35	0.21	82.2	1.51	165.8	0	77.8	1.25	153
STIRL	28003	1985.	0.	0.	-1985.	359.	2318.		97.	147.	3.27	0.35	0.26	101.9	1.87	175.2	0	81.6	1.31	143
STIRL	28003	0.	1692.	0.	0.	-1453.	1912.		97.	97.	3.02	0.35	0.21	82.3	1.51	166.0	0	65.3	1.06	148
STIRL	28003	0.	1985.	0.	0.	-1625.	2318.		97.	147.	3.27	0.35	0.26	102.0	1.87	175.4	0	67.3	1.08	138
STIRL	28003	0.	0.	1692.	0.	238.	221.		97.	97.	6.19	0.35	0.21	143.5	2.64	289.5	12	52.6	0.85	132
STIRL	28003	0.	0.	1985.	0.	359.	333.		97.	147.	6.91	0.35	0.26	180.6	3.32	310.5	10	52.7	0.85	122
HEGT85	28003	0.	0.	2004.	0.	238.	-91.	A	97.	97.	7.28	0.35	0.07	172.4	3.17	293.6	4	63.0	1.01	116
HEGT85	28003	0.	0.	8010.	0.	1848.	-709.	A	97.	754.	28.13	0.35	0.12	749.6	13.77	319.4	0	124.6	2.01	88
HEGT60	28003	0.	0.	1957.	0.	238.	-45.	A	97.	97.	6.85	0.35	0.09	154.2	2.83	269.0	7	53.7	0.96	119
HEGT60	28003	0.	0.	3258.	0.	607.	-114.	A	97.	247.	10.27	0.35	0.13	244.7	4.50	256.3	3	66.7	1.07	99
HEGT00	28003	0.	0.	1916.	0.	238.	-4.	A	97.	97.	6.25	0.35	0.11	135.4	2.49	241.3	10	56.3	0.91	122
HEGT00	28003	0.	0.	1939.	0.	245.	-4.	A	97.	100.	6.01	0.35	0.11	134.3	2.47	236.4	10	55.8	0.90	111
FCMCCL	28003	0.	0.	1598.	0.	238.	315.		97.	97.	7.76	0.35	0.26	133.0	2.44	284.0	13	52.1	0.84	139
FCMCCL	28003	0.	0.	2001.	0.	437.	577.		97.	178.	10.16	0.35	0.34	164.3	3.02	280.2	12	49.0	0.79	129
FCSTCL	28003	0.	0.	1578.	0.	238.	334.		97.	97.	7.61	0.35	0.27	137.6	2.53	297.6	12	52.1	0.84	140
FCSTCL	28003	0.	0.	2352.	0.	637.	893.		97.	260.	12.09	0.35	0.39	195.1	3.59	283.1	13	44.4	0.71	125
IGGTST	28003	0.	0.	1701.	0.	238.	211.		97.	97.	4.95	0.35	0.21	123.0	2.26	246.8	15	50.0	0.81	133
IGGTST	28003	0.	0.	2192.	0.	438.	388.		97.	179.	5.00	0.35	0.27	155.7	2.86	242.5	14	46.4	0.75	121
GTSQAR	28003	0.	1687.	0.	0.	-1449.	1912.		97.	97.	2.26	0.35	0.22	55.1	1.01	111.4	999	61.8	0.99	157
GTSQAR	28003	0.	2233.	0.	0.	-1768.	2673.		97.	190.	2.45	0.35	0.29	73.1	1.34	111.7	2	62.6	1.01	143
GTAC08	28003	0.	1599.	0.	0.	-1360.	1912.		97.	97.	2.11	0.35	0.26	50.3	0.92	107.4	999	58.4	0.94	163
GTAC08	28003	0.	1340.	0.	0.	-1483.	2310.		97.	146.	2.02	0.35	0.31	57.3	1.05	106.2	167	56.9	0.92	153
GTAC12	28003	0.	1608.	0.	0.	-1369.	1912.		97.	97.	2.20	0.35	0.25	53.5	0.98	113.5	999	59.1	0.95	161
GTAC12	28003	0.	2040.	0.	0.	-1593.	2511.		97.	182.	2.32	0.35	0.33	68.6	1.26	114.8	26	57.4	0.92	149
GTAC16	28003	0.	1619.	0.	0.	-1380.	1912.		97.	97.	2.21	0.35	0.25	53.6	0.99	113.1	999	59.5	0.96	160
GTAC16	28003	0.	2190.	0.	0.	-1681.	2816.		97.	207.	2.58	0.35	0.34	78.5	1.44	122.3	16	58.4	0.94	145
GTWC16	28003	0.	1666.	0.	0.	-1427.	1912.		97.	97.	2.16	0.35	0.23	51.0	0.94	104.4	999	60.6	0.98	159
GTWC16	28003	0.	2340.	0.	0.	-1810.	2888.		97.	216.	2.49	0.35	0.32	74.0	1.36	107.9	10	60.8	0.98	143
CC1626	28003	0.	1674.	0.	0.	-1436.	1912.		97.	97.	2.42	0.35	0.22	55.7	1.02	113.6	22	61.8	0.99	157

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																			
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER RECD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVEL CHRG	NORM ENRG	WRTH
CC1626	28003	0.	3005.	0.	0.	-2201.	3807.	97.	328.	3.27	0.35	0.35	95.0	1.74	107.8	4	62.6	1.01	133
CC1622	28003	0.	1651.	0.	0.	-1412.	1912.	97.	97.	2.44	0.35	0.23	57.6	1.06	119.1	21	61.3	0.99	157
CC1622	28003	0.	2741.	0.	0.	-2019.	3534.	97.	295.	3.23	0.35	0.36	97.5	1.79	121.4	7	61.2	0.98	136
CC1222	28003	0.	1646.	0.	0.	-1408.	1912.	97.	97.	2.42	0.35	0.23	55.8	1.03	115.7	51	60.9	0.98	158
CC1222	28003	0.	2718.	0.	0.	-1999.	3520.	97.	293.	3.15	0.35	0.36	91.3	1.68	114.6	9	60.0	0.97	137
CC0822	28003	0.	1610.	0.	0.	-1371.	1912.	97.	97.	2.28	0.35	0.25	50.5	0.93	107.0	999	59.0	0.95	162
CC0822	28003	0.	2297.	0.	0.	-1728.	3019.	97.	232.	2.61	0.35	0.36	71.9	1.32	106.9	24	56.3	0.91	146
STIG15	28003	0.	1971.	0.	0.	-1733.	1912.	97.	97.	3.32	0.35	0.08	61.5	1.13	106.4	0	72.6	1.17	142
STIG15	28003	0.	72846.	0.	0.	-52898.	67898.	97.	9134.	122.67	0.35	0.17	1960.1	36.02	91.8	0	1025.1	16.49	450
STIG10	28003	0.	1894.	0.	0.	-1655.	1912.	97.	97.	2.89	0.35	0.12	55.5	1.02	100.1	999	69.1	1.11	147
STIG10	28003	0.	7147.	0.	0.	-5292.	7290.	97.	752.	10.23	0.35	0.22	193.4	3.55	92.3	0	125.9	2.03	112
STIG15	28003	0.	1858.	0.	0.	-1620.	1912.	97.	97.	2.89	0.35	0.14	54.1	1.00	99.4	166	67.8	1.09	150
STIG15	28003	0.	4492.	0.	0.	-3410.	4738.	97.	441.	6.71	0.35	0.23	124.6	2.29	94.6	0	93.4	1.50	117
DEADV3	28003	0.	1792.	0.	0.	-1554.	1912.	97.	97.	3.31	0.35	0.17	92.4	1.70	176.0	0	70.2	1.13	142
DEADV3	28003	0.	4620.	0.	0.	-3388.	5238.	97.	502.	8.86	0.35	0.29	315.2	5.79	232.8	0	107.4	1.73	115
DEHTPM	28003	0.	1617.	0.	0.	-1379.	1912.	97.	97.	3.40	0.35	0.25	93.4	1.72	197.2	0	64.8	1.04	150
DEHTPM	28003	0.	2210.	0.	0.	-1691.	2853.	97.	212.	4.87	0.35	0.34	160.0	2.94	247.0	0	69.0	1.11	136
DESOA3	28003	1848.	0.	0.	0.	-1848.	238.	97.	97.	3.71	0.35	0.14	108.3	1.99	199.9	0	87.3	1.41	142
DESOA3	28003	5539.	0.	0.	0.	-5539.	1437.	97.	586.	12.17	0.35	0.25	445.1	8.18	274.2	0	176.6	2.84	132
DESOA3	28003	0.	1848.	0.	0.	-1610.	1912.	97.	97.	3.71	0.35	0.14	108.3	1.99	199.9	0	74.0	1.19	137
DESOA3	28003	0.	5539.	0.	0.	-4102.	5925.	97.	586.	12.17	0.35	0.25	445.1	8.18	274.2	0	136.8	2.20	116
GTSOAD	28003	1634.	0.	0.	0.	-1634.	238.	97.	97.	2.11	0.35	0.24	49.5	0.91	103.3	-74	71.2	1.15	166
GTSOAD	28003	2056.	0.	0.	0.	-2056.	432.	97.	176.	2.11	0.35	0.31	60.1	1.10	99.8	0	72.8	1.17	156
GTRA08	28003	1676.	0.	0.	0.	-1676.	238.	97.	97.	2.42	0.35	0.22	61.2	1.12	124.5	0	74.3	1.20	160
GTRA08	28003	2816.	0.	0.	0.	-2816.	723.	97.	295.	3.46	0.35	0.34	111.0	2.04	134.5	0	85.2	1.37	140
GTRA12	28003	1663.	0.	0.	0.	-1663.	238.	97.	97.	2.38	0.35	0.23	59.9	1.10	122.9	0	73.7	1.19	161
GTRA12	28003	2735.	0.	0.	0.	-2735.	704.	97.	287.	3.37	0.35	0.34	107.7	1.98	134.3	0	83.2	1.34	142
GTRA16	28003	1659.	0.	0.	0.	-1659.	238.	97.	97.	2.48	0.35	0.23	63.8	1.17	131.2	0	74.0	1.19	160
GTRA16	28003	2613.	0.	0.	0.	-2613.	656.	97.	267.	3.37	0.35	0.34	108.2	1.99	141.3	0	82.5	1.33	143
GTR208	28003	1660.	0.	0.	0.	-1660.	238.	97.	97.	2.26	0.35	0.23	55.4	1.02	113.8	999	73.0	1.17	163
GTR208	28003	2355.	0.	0.	0.	-2355.	542.	97.	221.	2.63	0.35	0.32	79.6	1.46	115.4	0	78.0	1.26	149
GTR212	28003	1662.	0.	0.	0.	-1662.	238.	97.	97.	2.30	0.35	0.23	56.7	1.04	116.4	0	73.2	1.18	162
GTR212	28003	2449.	0.	0.	0.	-2449.	581.	97.	237.	2.79	0.35	0.33	85.8	1.58	119.6	0	79.3	1.28	147
GTR216	28003	1652.	0.	0.	0.	-1652.	238.	97.	97.	2.35	0.35	0.23	58.8	1.08	121.5	0	73.1	1.18	162
GTR216	28003	2459.	0.	0.	0.	-2459.	596.	97.	243.	2.96	0.35	0.34	92.3	1.70	128.1	0	79.3	1.28	146
GTRW08	28003	1751.	0.	0.	0.	-1751.	238.	97.	97.	2.34	0.35	0.19	57.5	1.06	112.0	0	76.8	1.24	158
GTRW08	28003	3414.	0.	0.	0.	-3414.	861.	97.	351.	3.53	0.35	0.30	111.9	2.06	111.9	0	97.3	1.57	135
GTRW12	28003	1721.	0.	0.	0.	-1721.	238.	97.	97.	2.33	0.35	0.20	57.4	1.06	113.9	0	75.6	1.22	159
GTRW12	28003	3340.	0.	0.	0.	-3340.	874.	97.	356.	3.54	0.35	0.32	112.7	2.07	115.1	0	93.5	1.50	136
GTRW16	28003	1715.	0.	0.	0.	-1715.	238.	97.	97.	2.36	0.35	0.20	58.5	1.08	116.5	0	75.5	1.21	159
GTRW16	28003	3150.	0.	0.	0.	-3150.	808.	97.	330.	3.29	0.35	0.32	103.3	1.90	111.9	0	90.2	1.45	139
GTR308	28003	1780.	0.	0.	0.	-1780.	238.	97.	97.	2.30	0.35	0.17	55.7	1.02	106.8	999	77.7	1.25	157
GTR308	28003	2952.	0.	0.	0.	-2952.	658.	97.	268.	2.95	0.35	0.26	86.1	1.58	99.6	0	92.7	1.49	141
GTR312	28003	1706.	0.	0.	0.	-1706.	238.	97.	97.	2.28	0.35	0.21	55.4	1.02	110.9	999	74.8	1.20	161



GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																			
ECS	PROCS	**COGENERATION CASE**			**NOCOGEN - COGEN**			POWER	COGEN	O&M	POWER	FESR	CAPITAL	NORM	\$/KW	ROI	LEVEL	NORM	
		DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	REQD	POWER		/HEAT		COST	COST	EQVL	(%)	CHRG	WRTH	
							MW	MW		RATIO		*10**6					ENRG		
GTR312	28003	2857.	0.	0.	-2857.	702.	3465.	97.	286.	2.89	0.35	0.31	88.2	1.62	105.3	0	85.5	1.38	143
GTR316	28003	1708.	0.	0.	-1708.	238.	1912.	97.	97.	2.31	0.35	0.21	56.7	1.04	113.3	0	75.0	1.21	160
GTR316	28003	2838.	0.	0.	-2838.	691.	3429.	97.	282.	2.95	0.35	0.31	90.7	1.67	109.1	0	86.0	1.38	143
FCPADS	28003	1812.	0.	0.	-1812.	238.	1912.	97.	97.	12.29	0.35	0.16	86.0	1.58	162.0	0	92.2	1.48	151
FCPADS	28003	5571.	0.	0.	-5571.	1521.	6208.	97.	620.	68.95	0.35	0.28	327.9	6.03	200.9	0	215.3	3.46	153
FCMCDS	28003	1698.	0.	0.	-1698.	238.	1912.	97.	97.	11.63	0.35	0.21	89.5	1.64	179.8	0	87.4	1.41	155
FCMCDS	28003	4064.	0.	0.	-4064.	1204.	5143.	97.	491.	51.89	0.35	0.36	299.7	5.51	251.6	0	162.7	2.62	147

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----

ECS	PROCS	**COGENERATION CASE**				**NOCOGEN - COGEN**				POWER REQD MW	COGEN POWER MW	G&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVEL CHRG	NORM ENRG	WRTH
		DISTIL	RESIDL	COAL		DISTIL	RESIDL	COAL													
ONOCGN	28121	0.	294.	1297.	0.	0.	G.	F	120.	0.	1.20	1.55	0.	18.9	1.00	207.1	0	48.1	1.00	80	
STM141	28121	0.	635.	835.	0.	-340.	462.		120.	18.	0.75	1.55	0.08	12.5	0.66	110.4	999	47.3	0.98	124	
STM141	28121	0.	249.	1220.	0.	45.	77.	F	120.	18.	1.56	1.55	0.08	25.3	1.34	223.9	35	44.5	0.92	104	
STM141	28121	0.	249.	1220.	0.	45.	77.	A	120.	18.	1.40	1.55	0.08	18.5	0.98	163.7	999	43.6	0.91	111	
STM088	28121	0.	628.	872.	0.	-333.	425.		120.	14.	0.72	1.55	0.06	11.2	0.59	104.6	-4	48.0	1.00	122	
STM088	28121	0.	261.	1239.	0.	34.	58.	F	120.	14.	1.47	1.55	0.06	23.4	1.24	217.8	36	45.4	0.94	101	
STM088	28121	0.	261.	1239.	0.	34.	58.	A	120.	14.	1.35	1.55	0.06	17.5	0.93	163.0	999	44.6	0.93	108	
PFBSTM	28121	0.	225.	1181.	0.	70.	116.		120.	28.	2.32	1.55	0.12	30.4	1.61	242.2	27	43.3	0.90	109	
TI1TMT	28121	0.	668.	677.	0.	-374.	620.		120.	37.	2.31	1.55	0.15	72.8	3.85	533.0	0	51.6	1.07	106	
TI1TMT	28121	0.	202.	1144.	0.	92.	153.		120.	37.	3.30	1.55	0.15	92.2	4.87	674.9	4	48.6	1.01	102	
TI1HRSG	28121	0.	658.	848.	0.	-364.	449.		120.	17.	1.89	1.55	0.05	61.9	3.27	522.3	0	54.7	1.14	89	
TI1HRSG	28121	0.	253.	1253.	0.	41.	44.		120.	17.	2.80	1.55	0.05	79.5	4.20	669.9	0	52.5	1.09	84	
ST1RL	28121	563.	190.	635.	-563.	105.	662.		120.	43.	1.21	1.55	0.13	30.3	1.60	183.5	0	51.1	1.06	119	
ST1RL	28121	0.	753.	635.	0.	-459.	662.		120.	43.	1.22	1.55	0.13	30.3	1.60	183.7	11	47.1	0.98	117	
ST1RL	28121	0.	190.	1198.	0.	105.	99.		120.	43.	2.37	1.55	0.13	53.0	2.80	321.0	14	43.4	0.90	104	
HEGT85	28121	0.	0.	1348.	0.	294.	-51.	A	120.	120.	6.08	1.55	0.15	154.6	8.17	391.5	5	47.0	0.98	115	
HEGT85	28121	0.	0.	1661.	0.	383.	-66.	A	120.	156.	6.74	1.55	0.16	178.6	9.44	366.9	4	48.8	1.01	105	
HEGT60	28121	0.	138.	1301.	0.	156.	-4.	A	120.	64.	3.66	1.55	0.10	93.7	4.95	381.5	6	47.3	0.98	99	
HEGT00	28121	0.	227.	1294.	0.	68.	3.	A	120.	28.	2.29	1.55	0.04	54.0	2.85	344.1	5	48.0	1.00	91	
FCMCL	28121	0.	172.	1135.	0.	122.	162.		120.	50.	3.34	1.55	0.18	64.8	3.43	395.7	11	43.7	0.91	110	
FCSTCL	28121	0.	100.	1021.	0.	195.	276.		120.	79.	4.42	1.55	0.30	80.2	4.24	398.0	14	38.9	0.81	123	
IGGTST	28121	0.	157.	1169.	0.	137.	128.		120.	56.	2.33	1.55	0.17	62.6	3.31	333.2	14	41.8	0.87	109	
GTSCAR	28121	0.	780.	557.	0.	-485.	740.		120.	52.	0.97	1.55	0.16	23.2	1.22	129.0	52	44.6	0.93	128	
GTAC08	28121	0.	710.	650.	0.	-416.	647.		120.	41.	0.82	1.55	0.15	18.2	0.96	120.2	999	44.6	0.93	129	
GTAC12	28121	0.	739.	567.	0.	-444.	730.		120.	51.	0.92	1.55	0.18	21.5	1.14	128.8	110	43.4	0.90	131	
GTAC16	28121	0.	761.	513.	0.	-467.	784.		120.	53.	1.00	1.55	0.20	24.5	1.29	137.4	57	42.8	0.89	131	
GTWC16	28121	0.	801.	488.	0.	-507.	808.		120.	61.	1.00	1.55	0.19	24.0	1.27	125.0	57	43.3	0.90	131	
CC1626	28121	0.	929.	168.	0.	-635.	1129.		120.	100.	1.42	1.55	0.31	33.1	1.75	128.5	38	38.9	0.81	140	
CC1622	28121	0.	876.	249.	0.	-582.	1048.		120.	90.	1.37	1.55	0.29	32.8	1.73	139.6	37	39.6	0.82	138	
CC1222	28121	0.	670.	252.	0.	-576.	1045.		120.	89.	1.35	1.55	0.29	31.1	1.64	133.3	42	39.3	0.82	139	
CC0822	28121	0.	791.	399.	0.	-497.	898.		120.	71.	1.19	1.55	0.25	25.9	1.37	131.7	57	40.7	0.85	137	
ST1G15	28121	0.	1370.	0.	0.	-1076.	1297.		120.	120.	2.97	1.55	0.14	45.9	2.43	114.5	0	50.2	1.04	129	
ST1G15	28121	0.	20385.	0.	0.	-14802.	19000.		120.	2276.	34.93	1.55	0.17	565.4	25.89	94.7	0	301.7	6.27	195	
ST1G10	28121	0.	1274.	0.	0.	-980.	1297.		120.	120.	2.49	1.55	0.20	42.5	2.25	113.9	10	46.4	0.96	136	
ST1G10	28121	0.	2000.	0.	0.	-1484.	2040.		120.	210.	3.38	1.55	0.22	62.8	3.32	107.2	0	54.1	1.12	122	
ST1G1S	28121	0.	1230.	0.	0.	-936.	1297.		120.	120.	2.33	1.55	0.23	39.5	2.09	109.6	16	44.5	0.93	140	
ST1G1S	28121	0.	1257.	0.	0.	-954.	1326.		120.	124.	2.26	1.55	0.23	39.7	2.10	107.7	16	44.6	0.93	130	
DEADV3	28121	0.	1134.	0.	0.	-840.	1297.		120.	120.	2.76	1.55	0.29	81.0	4.28	243.8	7	46.4	0.96	138	
DEADV3	28121	0.	1222.	0.	0.	-896.	1403.		120.	133.	2.80	1.55	0.29	87.7	4.63	244.8	6	47.3	0.98	127	
DEHTPM	28121	0.	761.	485.	0.	-467.	812.		120.	61.	1.70	1.55	0.22	46.1	2.43	255.0	13	44.9	0.93	122	
DES0A3	28121	1202.	0.	0.	-1202.	294.	1297.		120.	120.	3.31	1.55	0.24	101.0	5.34	286.8	0	59.5	1.24	137	
DES0A3	28121	1449.	0.	0.	-1449.	376.	1571.		120.	153.	3.77	1.55	0.26	124.9	6.60	294.0	0	65.3	1.36	128	
DES0A3	28121	0.	1202.	0.	0.	-908.	1297.		120.	120.	3.31	1.55	0.24	101.0	5.34	286.8	1	51.1	1.06	133	

ORIGINAL PAGE IS OF POOR QUALITY

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----

\*\*COGENERATION CASE\*\* \*\*NO COGEN - COGEN\*\*

ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM WRTH ENRG
DESOA3	28121	0.	1449.	0.	0.	-1073.	1571.	120.	153.	3.77	1.55	0.26	124.9	6.60	294.0	0	55.2	1.15 123
GTSOAD	28121	572.	17.	584.	-572.	120.	713.	120.	49.	0.86	1.55	0.16	19.0	1.00	113.3	999	47.8	0.99 134
GTRA08	28121	762.	99.	330.	-762.	196.	967.	120.	80.	1.26	1.55	0.25	33.4	1.77	149.6	11	43.9	0.97 136
GTRA12	28121	745.	103.	344.	-745.	192.	953.	120.	78.	1.22	1.55	0.25	31.9	1.68	146.0	13	46.5	0.97 136
GTRA16	28121	715.	115.	385.	-715.	179.	912.	120.	73.	1.22	1.55	0.24	32.1	1.70	153.2	11	47.0	0.98 134
GTR208	28121	648.	145.	486.	-648.	149.	811.	120.	61.	1.03	1.55	0.20	25.1	1.33	132.3	11	47.6	0.99 133
GTR212	28121	674.	134.	450.	-674.	160.	847.	120.	65.	1.09	1.55	0.21	27.1	1.43	137.3	11	47.4	0.99 134
GTR216	28121	676.	130.	437.	-676.	164.	860.	120.	67.	1.13	1.55	0.22	29.0	1.53	146.3	11	47.2	0.98 133
GTRW08	28121	927.	60.	202.	-927.	234.	1095.	120.	95.	1.29	1.55	0.25	33.5	1.77	123.2	5	48.0	1.00 137
GTRW12	28121	912.	56.	186.	-912.	239.	1111.	120.	97.	1.30	1.55	0.27	33.8	1.79	126.5	11	46.9	0.97 139
GTRW16	28121	865.	72.	242.	-865.	222.	1055.	120.	90.	1.28	1.55	0.26	33.5	1.77	132.4	9	47.3	0.98 137
GTR308	28121	802.	116.	387.	-802.	179.	910.	120.	73.	1.12	1.55	0.18	27.5	1.45	116.9	0	49.3	1.04 132
GTR312	28121	791.	100.	335.	-791.	194.	962.	120.	79.	1.14	1.55	0.23	28.5	1.51	123.2	10	47.5	0.99 137
GTR316	28121	786.	103.	344.	-786.	191.	953.	120.	78.	1.17	1.55	0.23	29.5	1.56	127.9	7	47.8	0.99 135
FCPADS	28121	1174.	0.	0.	-1174.	294.	1297.	120.	120.	13.64	1.55	0.26	74.0	3.91	215.0	0	65.9	1.37 146
FCPADS	28121	1559.	0.	0.	-1559.	426.	1737.	120.	174.	19.18	1.55	0.28	106.9	5.33	220.9	0	78.4	1.63 139
FCMCDS	28121	1033.	0.	0.	-1033.	294.	1297.	120.	120.	12.79	1.55	0.35	78.0	4.12	257.5	0	60.2	1.25 153
FCMCDS	28121	1137.	0.	0.	-1137.	337.	1439.	120.	137.	14.36	1.55	0.36	86.6	4.58	259.8	0	63.2	1.31 144

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																			
**COGENERATION CASE** **NO COGEN - COGEN**																			
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REGD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHR	NORM WRTH ENRG	
ONCOGN	28191	0.	74.	1402.	0.	0.	0.	F 30.	0.	2.89	0.11	0.	55.7	1.00	164.8	0	38.2	1.00	80
STM141	28191	0.	1275.	0.	0.	-1200.	1402.	30.	30.	1.73	0.11	0.14	34.8	0.62	93.1	-19	43.2	1.13	163
STM141	28191	0.	1291.	0.	0.	-1207.	1436.	30.	35.	1.48	0.11	0.15	33.8	0.61	89.2	-17	42.6	1.11	154
STM141	28191	0.	0.	1275.	0.	74.	127.	F 30.	30.	3.93	0.11	0.14	70.8	1.27	189.7	22	33.5	0.88	138
STM141	28191	0.	0.	1291.	0.	85.	145.	F 30.	35.	3.46	0.11	0.15	66.0	1.19	174.4	36	32.0	0.84	130
STM141	28191	0.	0.	1275.	0.	74.	127.	A 30.	30.	3.65	0.11	0.14	51.8	0.93	138.7	999	31.2	0.82	144
STM141	28191	0.	0.	1291.	0.	85.	145.	A 30.	35.	3.31	0.11	0.15	50.7	0.91	134.0	999	30.2	0.79	135
STM088	28191	0.	1258.	85.	0.	-1184.	1317.	30.	20.	1.38	0.11	0.09	30.1	0.54	83.4	-19	44.4	1.16	149
STM088	28191	0.	25.	1318.	0.	49.	84.	F 30.	20.	3.22	0.11	0.09	61.2	1.10	169.5	41	34.3	0.90	124
STM088	28191	0.	25.	1318.	0.	49.	84.	A 30.	20.	3.19	0.11	0.09	48.5	0.87	134.3	999	32.9	0.86	129
PFBSTM	28191	0.	0.	1283.	0.	74.	119.	30.	30.	4.73	0.11	0.13	65.4	1.17	173.9	28	33.8	0.89	140
PFBSTM	28191	0.	0.	1452.	0.	171.	274.	30.	70.	5.68	0.11	0.23	65.7	1.18	154.4	44	30.3	0.79	131
TISTMT	28191	0.	1278.	0.	0.	-1204.	1402.	30.	30.	2.26	0.11	0.13	92.9	1.67	247.9	0	51.1	1.34	143
TISTMT	28191	0.	1561.	0.	0.	-1320.	1962.	30.	99.	5.21	0.11	0.29	178.6	3.21	390.4	0	57.9	1.52	129
TISTMT	28191	0.	0.	1278.	0.	74.	123.	30.	30.	5.50	0.11	0.13	132.5	2.38	353.8	0	41.8	1.09	130
TISTMT	28191	0.	0.	1561.	0.	242.	401.	30.	99.	7.59	0.11	0.29	225.3	4.05	492.5	0	46.0	1.20	118
TIHRSG	28191	0.	1373.	0.	0.	-1299.	1402.	30.	30.	3.61	0.11	0.07	111.4	2.00	276.9	0	56.0	1.47	135
TIHRSG	28191	0.	1647.	0.	0.	-1480.	1711.	30.	68.	5.06	0.11	0.12	180.1	3.23	373.1	0	65.7	1.72	121
TIHRSG	28191	0.	0.	1373.	0.	74.	28.	30.	30.	5.95	0.11	0.07	150.8	2.71	374.6	0	45.9	1.20	126
TIHRSG	28191	0.	0.	1647.	0.	167.	64.	30.	68.	7.62	0.11	0.12	228.7	4.11	473.8	0	53.6	1.40	110
STIRL	28191	1343.	0.	0.	-1343.	74.	1402.	30.	30.	2.21	0.11	0.09	53.2	0.96	135.2	999	56.5	1.48	155
STIRL	28191	1917.	0.	0.	-1917.	299.	2155.	30.	122.	3.16	0.11	0.22	97.8	1.76	174.1	0	65.8	1.72	130
STIRL	28191	0.	1343.	0.	0.	-1268.	1402.	30.	30.	2.21	0.11	0.09	53.2	0.96	135.3	119	47.6	1.24	149
STIRL	28191	0.	1917.	0.	0.	-1618.	2155.	30.	122.	3.16	0.11	0.22	97.9	1.76	174.4	0	53.0	1.39	121
STIRL	28191	0.	0.	1343.	0.	74.	59.	30.	30.	4.53	0.11	0.09	93.4	1.68	237.4	6	37.5	0.98	129
STIRL	28191	0.	0.	1917.	0.	299.	238.	30.	122.	6.61	0.11	0.22	174.8	3.14	311.2	3	40.8	1.07	103
HEGT60	28191	0.	0.	1485.	0.	74.	-84.	A 30.	30.	4.79	0.11	-0.01	103.9	1.87	238.8	0	41.6	1.09	117
HEGT60	28191	0.	0.	6901.	0.	1285.	-1447.	A 30.	524.	20.38	0.11	-0.02	508.6	9.14	251.5	0	101.2	2.65	84
HEGT00	28191	0.	0.	1421.	0.	74.	-19.	A 30.	30.	4.67	0.11	0.04	98.4	1.77	236.2	1	39.7	1.04	123
HEGT00	28191	0.	0.	2121.	0.	268.	-70.	A 30.	109.	6.28	0.11	0.09	142.1	2.57	230.3	0	43.4	1.13	94
FCMCCL	28191	0.	0.	1305.	0.	74.	97.	30.	30.	5.07	0.11	0.12	99.5	1.79	260.3	4	38.5	1.01	131
FCMCCL	28191	0.	0.	2085.	0.	456.	593.	30.	186.	10.12	0.11	0.33	169.3	3.04	277.2	7	35.5	0.93	105
FCSTCL	28191	0.	0.	1299.	0.	74.	103.	30.	30.	5.04	0.11	0.12	98.3	1.77	258.2	5	38.3	1.00	132
FCSTCL	28191	0.	0.	2311.	0.	590.	817.	30.	241.	11.42	0.11	0.38	190.4	3.42	281.1	8	32.7	0.86	103
IGGTST	28191	0.	0.	1341.	0.	74.	60.	30.	30.	2.34	0.11	0.09	94.1	1.69	239.3	6	37.8	0.99	129
IGGTST	28191	0.	0.	2151.	0.	393.	319.	30.	160.	4.89	0.11	0.25	151.4	2.72	240.1	6	34.2	0.89	98
GTSOAR	28191	0.	1350.	0.	0.	-1276.	1402.	30.	30.	1.86	0.11	0.09	42.8	0.77	108.1	-35	46.3	1.21	153
GTSOAR	28191	0.	2577.	0.	0.	-2040.	2951.	30.	219.	2.85	0.11	0.26	87.7	1.53	116.2	0	52.9	1.39	116
GTAC08	28191	0.	1303.	0.	0.	-1229.	1402.	30.	30.	1.81	0.11	0.12	40.8	0.73	106.7	-27	44.7	1.17	157
GTAC08	28191	0.	1900.	0.	0.	-1532.	2388.	30.	150.	2.06	0.11	0.31	58.9	1.06	105.8	0	42.0	1.10	132
GTAC12	28191	0.	1307.	0.	0.	-1233.	1402.	30.	30.	1.82	0.11	0.11	41.5	0.74	108.2	-29	44.9	1.17	157
GTAC12	28191	0.	2114.	0.	0.	-1650.	2704.	30.	189.	2.38	0.11	0.33	70.8	1.27	113.3	0	42.6	1.12	126
GTAC16	28191	0.	1315.	0.	0.	-1240.	1402.	30.	30.	1.84	0.11	0.11	42.3	0.76	109.9	-31	45.2	1.18	156

ORIGINAL PAGE IS  
OF POOR QUALITY

HONEYWELL PAGE PRINTING SYSTEM - P1188-02

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																			
**COGENERATION CASE** **NOCOGEN - COGEN**																			
FCS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD	COGEN POWER	OSM	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRQ	NORM WRTH ENRG	
GTAC16	28191	0.	2332.	0.	0.	-1791.	2966.	30.	221.	2.70	0.11	0.33	82.5	1.48	120.7	0	44.6	1.17	121
GTWC16	28191	0.	1324.	0.	0.	-1250.	1402.	30.	30.	1.84	0.11	0.10	42.1	0.76	108.5	-31	45.5	1.19	155
GTWC16	28191	0.	2416.	0.	0.	-1869.	2984.	30.	223.	2.54	0.11	0.32	76.0	1.36	107.3	0	45.9	1.20	121
CC1626	28191	0.	1330.	0.	0.	-1256.	1402.	30.	30.	1.94	0.11	0.10	41.9	0.75	107.5	-34	45.8	1.20	155
CC1626	28191	0.	2949.	0.	0.	-2196.	3673.	30.	307.	3.18	0.11	0.33	91.8	1.65	106.2	0	48.4	1.27	118
CC1622	28191	0.	1323.	0.	0.	-1248.	1402.	30.	30.	1.93	0.11	0.10	42.0	0.75	108.3	-33	45.6	1.19	155
CC1622	28191	0.	2693.	0.	0.	-2019.	3411.	30.	275.	3.14	0.11	0.34	94.1	1.69	119.2	0	47.1	1.23	118
CC1222	28191	0.	1321.	0.	0.	-1247.	1402.	30.	30.	1.92	0.11	0.10	41.3	0.74	106.7	-32	45.5	1.19	156
CC1222	28191	0.	2667.	0.	0.	-1998.	3392.	30.	273.	3.06	0.11	0.34	88.2	1.58	112.8	0	46.0	1.20	119
CC0822	28191	0.	1310.	0.	0.	-1235.	1402.	30.	30.	1.92	0.11	0.11	41.1	0.74	107.0	-30	45.1	1.18	157
CC0822	28191	0.	2253.	0.	0.	-1732.	2900.	30.	213.	2.53	0.11	0.34	69.1	1.24	104.7	0	42.4	1.11	125
DEHTPM	28191	0.	1342.	0.	0.	-1268.	1402.	30.	30.	2.41	0.11	0.09	59.3	1.07	150.9	0	48.4	1.27	147
DEHTPM	28191	0.	2269.	0.	0.	-1830.	2621.	30.	179.	5.05	0.11	0.26	166.7	3.00	250.8	0	61.9	1.62	114
GTSOAD	28191	1318.	0.	0.	-1318.	74.	1402.	30.	30.	1.79	0.11	0.11	40.2	0.72	104.0	-52	53.9	1.41	162
GTSOAD	28191	2162.	0.	0.	-2162.	454.	2672.	30.	185.	2.18	0.11	0.31	62.6	1.12	98.8	0	58.2	1.52	136
GTRA08	28191	1350.	0.	0.	-1350.	74.	1402.	30.	30.	1.95	0.11	0.09	46.9	0.84	118.5	-88	55.9	1.46	157
GTRA08	28191	3622.	0.	0.	-3622.	929.	4264.	30.	379.	4.18	0.11	0.30	137.3	2.47	129.3	0	84.6	2.21	129
GTRA12	28191	1343.	0.	0.	-1343.	74.	1402.	30.	30.	1.88	0.11	0.09	43.8	0.79	111.4	-68	55.2	1.44	159
GTRA12	28191	3360.	0.	0.	-3360.	864.	4047.	30.	353.	3.91	0.11	0.32	127.5	2.29	129.5	0	78.7	2.06	129
GTRA16	28191	1339.	0.	0.	-1339.	74.	1402.	30.	30.	1.90	0.11	0.09	44.6	0.80	113.7	-71	55.2	1.44	159
GTRA16	28191	3103.	0.	0.	-3103.	778.	3759.	30.	317.	3.83	0.11	0.32	125.1	2.25	137.5	0	75.7	1.98	127
GTR208	28191	1336.	0.	0.	-1336.	74.	1402.	30.	30.	1.85	0.11	0.09	42.6	0.76	108.7	-61	54.8	1.43	160
GTR208	28191	2660.	0.	0.	-2660.	612.	3201.	30.	250.	3.02	0.11	0.30	94.1	1.69	120.7	0	68.3	1.79	128
GTR212	28191	1336.	0.	0.	-1336.	74.	1402.	30.	30.	1.86	0.11	0.09	43.1	0.77	110.1	-64	54.9	1.44	160
GTR212	28191	2772.	0.	0.	-2772.	657.	3354.	30.	268.	3.22	0.11	0.31	101.6	1.83	125.1	0	69.8	1.83	128
GTR216	28191	1333.	0.	0.	-1333.	74.	1402.	30.	30.	1.88	0.11	0.10	43.8	0.79	112.1	-65	54.9	1.44	159
GTR216	28191	2801.	0.	0.	-2801.	678.	3424.	30.	277.	3.42	0.11	0.32	109.7	1.97	133.6	0	70.3	1.84	127
GTRV08	28191	1368.	0.	0.	-1368.	74.	1402.	30.	30.	1.95	0.11	0.07	46.7	0.84	116.5	-89	56.5	1.48	156
GTRV08	28191	4275.	0.	0.	-4275.	1078.	4763.	30.	440.	4.12	0.11	0.27	132.9	2.39	106.1	0	96.3	2.52	133
GTRW12	28191	1355.	0.	0.	-1355.	74.	1402.	30.	30.	1.95	0.11	0.08	46.7	0.84	117.5	-87	56.0	1.47	157
GTRW12	28191	4012.	0.	0.	-4012.	1050.	4667.	30.	428.	4.03	0.11	0.30	130.3	2.34	110.8	0	88.6	2.32	132
GTRW16	28191	1351.	0.	0.	-1351.	74.	1402.	30.	30.	1.96	0.11	0.08	47.2	0.85	119.3	-91	56.0	1.46	157
GTRW16	28191	3641.	0.	0.	-3641.	934.	4281.	30.	381.	3.89	0.11	0.30	125.7	2.26	117.8	0	83.4	2.18	130
GTR308	28191	1378.	0.	0.	-1378.	74.	1402.	30.	30.	1.86	0.11	0.07	42.6	0.77	105.5	-66	56.3	1.47	157
GTR308	28191	3544.	0.	0.	-3544.	790.	3797.	30.	322.	3.34	0.11	0.23	104.0	1.87	100.2	0	88.1	2.31	128
GTR312	28191	1343.	0.	0.	-1343.	74.	1402.	30.	30.	1.85	0.11	0.09	42.5	0.76	108.0	-62	55.1	1.44	159
GTR312	28191	3115.	0.	0.	-3115.	766.	3716.	30.	312.	3.11	0.11	0.31	96.3	1.73	105.5	0	73.3	1.92	130
GTR316	28191	1344.	0.	0.	-1344.	74.	1402.	30.	30.	1.86	0.11	0.09	43.1	0.78	109.5	-65	55.2	1.44	159
GTR316	28191	3085.	0.	0.	-3085.	752.	3670.	30.	307.	3.17	0.11	0.30	98.8	1.78	109.3	0	73.6	1.93	129
FCPADS	28191	1371.	0.	0.	-1371.	74.	1402.	30.	30.	4.74	0.11	0.07	54.8	0.99	136.5	999	60.3	1.58	153
FCPADS	28191	5765.	0.	0.	-5765.	1574.	6424.	30.	642.	66.90	0.11	0.28	339.4	6.10	200.9	0	196.9	5.15	188
FCMCD3	28191	1335.	0.	0.	-1335.	74.	1402.	30.	30.	4.55	0.11	0.10	55.8	1.00	142.7	999	58.9	1.54	156
FCMCD3	28191	4206.	0.	0.	-4206.	1246.	5323.	30.	508.	50.30	0.11	0.36	304.0	5.46	246.7	0	145.2	3.80	165

HONEYWELL PAGE PRINTING SYSTEM- P1188-03

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----

\*\*COGENERATION CASE\*\* \*\*NOCOGEN - COGEN\*\*

ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD	COGEN POWER	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM WRTH ENRG
ONOCGN	28192	0.	149.	2804.	0.	0.	0.	F 61.	0.	5.16	0.11	0.	110.4	1.00	163.3	0	75.7	1.00 80
STM141	28192	0.	2550.	0.	0.	-2402.	2804.	61.	61.	2.59	0.11	0.14	60.9	0.55	81.5	-16	84.7	1.12 166
STM141	28192	0.	2584.	0.	0.	-2415.	2874.	61.	69.	2.23	0.11	0.15	60.0	0.54	79.2	-15	83.7	1.10 157
STM141	28192	0.	0.	2550.	0.	149.	254.	F 61.	61.	6.46	0.11	0.14	125.7	1.14	168.2	44	63.9	0.84 140
STM141	28192	0.	0.	2534.	0.	169.	290.	F 61.	69.	6.10	0.11	0.15	128.5	1.16	169.7	41	62.8	0.83 130
STM141	28192	0.	0.	2550.	0.	149.	254.	A 61.	61.	6.21	0.11	0.14	96.0	0.87	128.4	999	60.4	0.80 146
STM141	28192	0.	0.	2584.	0.	169.	290.	A 61.	69.	5.78	0.11	0.15	92.2	0.84	121.8	999	58.6	0.77 137
STM088	28192	0.	2518.	170.	0.	-2369.	2635.	61.	40.	2.12	0.11	0.09	54.0	0.49	74.8	-17	87.5	1.16 152
STM088	28192	0.	51.	2637.	0.	98.	167.	F 61.	40.	5.66	0.11	0.09	120.1	1.09	166.1	47	67.5	0.89 124
STM088	28192	0.	51.	2637.	0.	98.	167.	A 61.	40.	5.58	0.11	0.09	89.0	0.81	123.1	999	64.1	0.85 131
PFBSTM	28192	0.	0.	2567.	0.	149.	238.	61.	61.	8.09	0.11	0.13	115.6	1.05	153.8	99	54.7	0.85 142
PFBSTM	28192	0.	0.	2906.	0.	343.	549.	61.	140.	10.37	0.11	0.23	117.2	1.06	137.7	119	58.1	0.77 133
TISTMT	28192	0.	2558.	0.	0.	-2410.	2804.	61.	61.	5.15	0.11	0.13	159.1	1.44	212.2	0	98.1	1.30 145
TISTMT	28192	0.	3124.	0.	0.	-2641.	3926.	61.	197.	9.84	0.11	0.29	354.3	3.21	387.0	0	115.0	1.52 129
TISTMT	28192	0.	0.	2558.	0.	149.	246.	61.	61.	8.99	0.11	0.13	227.1	2.06	303.0	4	77.5	1.02 131
TISTMT	28192	0.	0.	3124.	0.	484.	802.	61.	197.	14.34	0.11	0.29	447.9	4.06	489.2	0	90.8	1.20 118
TIHRSG	28192	0.	2748.	0.	0.	-2599.	2804.	61.	61.	5.88	0.11	0.07	193.4	1.75	240.2	0	107.6	1.42 136
TIHRSG	28192	0.	3296.	0.	0.	-2962.	3423.	61.	136.	9.71	0.11	0.12	359.6	3.26	372.3	0	131.1	1.73 122
TIHRSG	28192	0.	0.	2748.	0.	149.	57.	61.	61.	9.94	0.11	0.07	262.8	2.38	326.4	0	85.6	1.13 123
TIHRSG	28192	0.	0.	3296.	0.	333.	127.	61.	136.	14.58	0.11	0.12	457.0	4.14	473.2	0	106.5	1.41 110
STIRL	28192	2686.	0.	0.	-2686.	149.	2804.	61.	61.	3.62	0.11	0.09	100.1	0.91	127.1	132	111.6	1.47 156
STIRL	28192	3836.	0.	0.	-3836.	599.	4312.	61.	244.	5.71	0.11	0.22	191.9	1.74	170.7	0	130.6	1.73 130
STIRL	28192	0.	2686.	0.	0.	-2538.	2804.	61.	61.	3.62	0.11	0.09	100.1	0.91	127.2	-72	93.7	1.24 150
STIRL	28192	0.	3836.	0.	0.	-3237.	4312.	61.	244.	5.72	0.11	0.22	192.1	1.74	170.9	0	105.0	1.39 122
STIRL	28192	0.	0.	2686.	0.	149.	118.	61.	61.	7.78	0.11	0.09	176.1	1.59	223.7	9	72.5	0.96 129
STIRL	28192	0.	0.	3836.	0.	599.	476.	61.	244.	12.33	0.11	0.22	344.6	3.12	306.5	3	80.1	1.06 103
HEGT60	28192	0.	0.	2972.	0.	149.	-167.	A 61.	61.	8.21	0.11	-0.01	187.0	1.69	214.8	0	79.5	1.05 118
HEGT60	28192	0.	0.	13809.	0.	2571.	-2896.	A 61.	1048.	40.06	0.11	-0.02	1017.5	9.22	251.4	0	201.9	2.67 85
HEGT00	28192	0.	0.	2843.	0.	149.	-39.	A 61.	61.	7.77	0.11	0.04	167.6	1.52	201.2	6	74.8	0.99 125
HEGT00	28192	0.	0.	4244.	0.	537.	-140.	A 61.	219.	10.80	0.11	0.09	234.2	2.12	188.3	2	79.3	1.05 95
FCMCL	28192	0.	0.	2611.	0.	149.	193.	61.	61.	8.62	0.11	0.12	172.6	1.56	225.5	8	72.6	0.96 133
FCMCL	28192	0.	0.	4172.	0.	912.	1187.	61.	372.	18.31	0.11	0.33	283.0	2.56	231.5	10	62.9	0.83 105
FCSTCL	28192	0.	0.	2599.	0.	149.	206.	61.	61.	8.49	0.11	0.12	170.7	1.55	224.1	9	72.1	0.95 134
FCSTCL	28192	0.	0.	4625.	0.	1180.	1634.	61.	481.	20.58	0.11	0.38	318.2	2.88	234.8	11	56.3	0.74 162
IGGTST	28192	0.	0.	2684.	0.	149.	120.	61.	61.	6.91	0.11	0.09	160.6	1.45	204.2	11	70.8	0.94 131
IGGTST	28192	0.	0.	4304.	0.	787.	638.	61.	321.	8.34	0.11	0.25	279.1	2.53	221.3	9	64.3	0.85 98
GTSCAR	28192	0.	2701.	0.	0.	-2552.	2804.	61.	61.	2.98	0.11	0.09	79.2	0.72	100.1	-30	91.3	1.21 155
GTSCAR	28192	0.	5157.	0.	0.	-4082.	5906.	61.	438.	4.78	0.11	0.26	157.5	1.43	104.2	0	103.1	1.36 118
GTAC08	28192	0.	2608.	0.	0.	-2460.	2804.	61.	61.	2.89	0.11	0.12	75.6	0.69	99.0	-24	88.1	1.16 159
GTAC08	28192	0.	3803.	0.	0.	-3065.	4778.	61.	301.	3.50	0.11	0.31	109.6	0.99	98.3	-93	82.5	1.09 133
GTAC12	28192	0.	2615.	0.	0.	-2467.	2804.	61.	61.	2.93	0.11	0.11	77.4	0.70	101.0	-25	88.5	1.17 158
GTAC12	28192	0.	4229.	0.	0.	-3302.	5411.	61.	378.	4.10	0.11	0.33	132.6	1.20	107.0	0	83.6	1.10 127
GTAC16	28192	0.	2631.	0.	0.	-2482.	2804.	61.	61.	2.97	0.11	0.11	79.1	0.72	102.6	-27	89.2	1.18 157

-----FUEL USE IN BTU\*10\*\*6-----

ECS	PROCS	**COGENERATION CASE**		**NOCOGEN - COGEN**		POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EOVL	ROI (%)	LEVEL CHRG	NORM ENRG	WRTH			
		DISTIL	RESIDL	COAL	DISTIL													RESIDL	COAL	
GTAC16	28192	0.	4667.	0.	0.	-3583.	5934.	61.	442.	4.80	0.11	0.33	159.4	1.44	116.6	0	88.1	1.16	122	
GTWC16	28192	0.	2650.	0.	0.	-2502.	2804.	61.	61.	2.94	0.11	0.10	77.8	0.70	100.1	-27	89.6	1.18	157	
GTWC16	28192	0.	4835.	0.	0.	-3740.	5971.	61.	446.	4.33	0.11	0.32	140.0	1.27	98.8	0	89.7	1.18	123	
CC1626	28192	0.	2661.	0.	0.	-2513.	2804.	61.	61.	3.05	0.11	0.10	77.6	0.70	99.5	-29	90.2	1.19	157	
CC1626	28192	0.	5900.	0.	0.	-4394.	7351.	61.	614.	5.31	0.11	0.33	166.5	1.51	96.3	0	93.9	1.24	119	
CC1622	28192	0.	2646.	0.	0.	-2498.	2804.	61.	61.	3.06	0.11	0.10	78.5	0.71	101.2	-29	89.9	1.19	157	
CC1622	28192	0.	5389.	0.	0.	-4039.	6824.	61.	550.	5.23	0.11	0.34	170.1	1.54	107.7	0	91.1	1.20	120	
CC1222	28192	0.	2643.	0.	0.	-2495.	2804.	61.	61.	3.04	0.11	0.10	77.3	0.70	99.8	-28	89.6	1.18	157	
CC1222	28192	0.	5336.	0.	0.	-3998.	6787.	61.	546.	5.05	0.11	0.34	157.8	1.43	100.9	0	88.9	1.17	121	
CC0322	28192	0.	2620.	0.	0.	-2472.	2804.	61.	61.	3.02	0.11	0.11	76.2	0.69	99.3	-26	88.8	1.17	158	
CC0822	28192	0.	4509.	0.	0.	-3465.	5302.	61.	426.	4.27	0.11	0.34	129.4	1.17	97.9	0	83.1	1.10	126	
DEHTPM	28192	0.	2685.	0.	0.	-2537.	2804.	61.	61.	4.06	0.11	0.09	115.4	1.05	146.6	0	95.7	1.26	147	
DEHTPM	28192	0.	4540.	0.	0.	-3662.	5245.	61.	358.	9.35	0.11	0.26	328.7	2.98	247.1	0	122.6	1.62	114	
GTSOAD	28192	2637.	0.	0.	0.	-2637.	149.	2804.	61.	61.	2.87	0.11	0.11	74.9	0.68	96.9	-46	106.5	1.41	164
GTSOAD	28192	4327.	0.	0.	0.	-4327.	908.	5347.	61.	370.	3.79	0.11	0.31	119.8	1.09	94.5	0	115.2	1.52	137
GTRA08	28192	2702.	0.	0.	0.	-2702.	149.	2804.	61.	61.	3.09	0.11	0.09	84.3	0.76	106.5	-64	110.0	1.45	159
GTRA08	28192	7248.	0.	0.	0.	-7248.	1860.	8533.	61.	758.	7.19	0.11	0.30	249.4	2.26	117.4	0	165.4	2.18	130
GTRA12	28192	2686.	0.	0.	0.	-2686.	149.	2804.	61.	61.	3.02	0.11	0.09	81.5	0.74	103.6	-57	109.1	1.44	160
GTRA12	28192	6723.	0.	0.	0.	-6723.	1730.	8098.	61.	705.	6.78	0.11	0.32	234.0	2.12	118.8	0	154.2	2.04	129
GTRA16	28192	2679.	0.	0.	0.	-2679.	149.	2804.	61.	61.	3.06	0.11	0.09	82.8	0.75	105.4	-59	109.0	1.44	160
GTRA16	28192	6209.	0.	0.	0.	-6209.	1557.	7521.	61.	635.	6.51	0.11	0.32	224.0	2.03	123.1	0	147.5	1.95	129
GTR208	28192	2673.	0.	0.	0.	-2673.	149.	2804.	61.	61.	2.97	0.11	0.09	79.1	0.72	101.0	-53	108.3	1.43	161
GTR208	28192	5323.	0.	0.	0.	-5323.	1224.	6406.	61.	499.	5.10	0.11	0.30	169.7	1.54	108.8	0	133.7	1.77	130
GTR212	28192	2673.	0.	0.	0.	-2673.	149.	2804.	61.	61.	2.99	0.11	0.09	80.0	0.72	102.2	-54	108.4	1.43	161
GTR212	28192	5546.	0.	0.	0.	-5546.	1316.	6711.	61.	536.	5.39	0.11	0.31	180.7	1.64	111.2	0	136.3	1.80	129
GTR216	28192	2668.	0.	0.	0.	-2668.	149.	2804.	61.	61.	3.02	0.11	0.10	81.4	0.74	104.1	-56	108.4	1.43	161
GTR216	28192	5605.	0.	0.	0.	-5605.	1358.	6852.	61.	554.	5.78	0.11	0.32	196.2	1.78	119.5	0	137.2	1.81	129
GTRW08	28192	2737.	0.	0.	0.	-2737.	149.	2804.	61.	61.	3.08	0.11	0.07	83.5	0.76	104.1	-64	111.2	1.47	158
GTRW08	28192	8554.	0.	0.	0.	-8554.	2158.	9531.	61.	880.	7.06	0.11	0.27	241.9	2.19	96.5	0	189.0	2.50	134
GTRW12	28192	2712.	0.	0.	0.	-2712.	149.	2804.	61.	61.	3.07	0.11	0.08	83.5	0.76	105.0	-62	110.3	1.46	159
GTRW12	28192	8027.	0.	0.	0.	-8027.	2100.	9338.	61.	856.	6.72	0.11	0.30	229.0	2.07	97.3	0	172.6	2.28	133
GTRW16	28192	2703.	0.	0.	0.	-2703.	149.	2804.	61.	61.	3.09	0.11	0.08	84.3	0.76	106.4	-64	110.1	1.45	159
GTRW16	28192	7286.	0.	0.	0.	-7286.	1870.	8566.	61.	762.	6.48	0.11	0.30	220.7	2.00	103.3	0	162.3	2.14	131
GTR308	28192	2757.	0.	0.	0.	-2757.	149.	2804.	61.	61.	2.98	0.11	0.07	78.9	0.71	97.7	-57	111.3	1.47	159
GTR308	28192	7092.	0.	0.	0.	-7092.	1580.	7597.	61.	644.	5.46	0.11	0.23	180.5	1.63	86.8	0	172.1	2.27	130
GTR312	28192	2688.	0.	0.	0.	-2688.	149.	2804.	61.	61.	2.95	0.11	0.09	78.6	0.71	99.8	-53	108.8	1.44	161
GTR312	28192	6233.	0.	0.	0.	-6233.	1532.	7437.	61.	625.	5.23	0.11	0.31	173.0	1.57	94.7	0	143.6	1.90	131
GTR316	28192	2689.	0.	0.	0.	-2689.	149.	2804.	61.	61.	2.98	0.11	0.09	79.6	0.72	101.0	-54	108.9	1.44	161
GTR316	28192	6173.	0.	0.	0.	-6173.	1504.	7343.	61.	613.	5.36	0.11	0.30	178.2	1.61	95.5	0	144.3	1.91	131
FCPADS	28192	2742.	0.	0.	0.	-2742.	149.	2804.	61.	61.	8.84	0.11	0.07	103.0	0.93	128.2	202	119.2	1.57	155
FCPADS	28192	11535.	0.	0.	0.	-11535.	3151.	12855.	61.	1285.	133.06	0.11	0.28	659.3	5.97	195.0	0	391.2	5.17	188
FCMCDS	28192	2671.	0.	0.	0.	-2671.	149.	2804.	61.	61.	8.47	0.11	0.10	105.2	0.95	134.4	999	116.5	1.54	157
FCMCDS	28192	8416.	0.	0.	0.	-8416.	2492.	10651.	61.	1016.	99.62	0.11	0.36	578.8	5.24	234.7	0	286.5	3.78	165

HONEYWELL PAGE PRINTING SYSTEM - PL118-0

ORIGINAL PAGE IS OF POOR QUALITY

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----

\*\*COGENERATION CASE\*\* \*\*NOCOGEN - COGEN\*\*

ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI	LEVEL CHRG	NORM ENRG	WRTH	
ONCOGN	28212	0.	10.	276.	0.	0.	0.	F	4.	0.	1.04	0.07	0.	16.1	1.00	225.5	0	8.3	1.00	80
STM141	28212	0.	260.	0.	0.	-250.	276.		4.	4.	0.80	0.07	0.09	9.7	0.51	128.0	-18	9.7	1.16	159
STM141	28212	0.	286.	0.	0.	-260.	331.		4.	11.	0.65	0.07	0.20	9.8	0.61	117.4	-13	9.1	1.09	148
STM141	28212	0.	0.	260.	0.	10.	17.	F	4.	4.	1.58	0.07	0.09	21.7	1.35	285.0	2	8.5	1.02	135
STM141	28212	0.	0.	286.	0.	26.	44.	F	4.	11.	1.30	0.07	0.20	20.1	1.25	239.6	21	7.2	0.87	124
STM141	28212	0.	0.	260.	0.	10.	17.	A	4.	4.	1.48	0.07	0.09	19.7	1.22	258.4	8	8.2	0.98	136
STM141	28212	0.	0.	286.	0.	26.	44.	A	4.	11.	1.16	0.07	0.20	14.9	0.93	177.6	999	6.5	0.78	129
STM088	28212	0.	260.	0.	0.	-250.	276.		4.	4.	0.80	0.07	0.09	9.4	0.59	123.9	-17	9.7	1.16	160
STM088	28212	0.	273.	0.	0.	-255.	304.		4.	7.	0.62	0.07	0.15	8.7	0.54	109.1	-12	9.2	1.10	153
STM088	28212	0.	0.	260.	0.	10.	17.	F	4.	4.	1.57	0.07	0.09	21.4	1.33	280.8	3	8.4	1.01	135
STM088	28212	0.	0.	273.	0.	18.	31.	F	4.	7.	1.23	0.07	0.15	18.5	1.15	231.4	26	7.4	0.89	128
STM088	28212	0.	0.	260.	0.	10.	17.	A	4.	4.	1.48	0.07	0.09	18.9	1.17	248.2	11	8.1	0.97	137
STM088	28212	0.	0.	273.	0.	18.	31.	A	4.	7.	1.12	0.07	0.15	14.0	0.87	175.4	999	6.8	0.81	133
PFBSTM	28212	0.	0.	260.	0.	10.	16.		4.	4.	1.60	0.07	0.09	21.9	1.36	287.1	2	8.5	1.02	135
PFBSTM	28212	0.	0.	320.	0.	45.	74.		4.	18.	1.86	0.07	0.27	24.6	1.53	262.5	12	7.4	0.89	115
TISTMT	28212	0.	260.	0.	0.	-250.	276.		4.	4.	1.03	0.07	0.09	19.7	1.23	258.8	0	11.0	1.32	145
TISTMT	28212	0.	346.	0.	0.	-285.	447.		4.	25.	1.89	0.07	0.32	57.8	3.59	570.2	0	14.6	1.75	121
TISTMT	28212	0.	0.	260.	0.	10.	16.		4.	4.	1.79	0.07	0.09	32.1	2.00	421.9	0	9.8	1.18	130
TISTMT	28212	0.	0.	346.	0.	61.	101.		4.	25.	2.69	0.07	0.32	73.5	4.57	724.4	0	12.7	1.53	112
TIHRSG	28212	0.	269.	0.	0.	-259.	276.		4.	4.	1.11	0.07	0.06	25.6	1.59	324.5	0	11.9	1.43	137
TIHRSG	28212	0.	331.	0.	0.	-297.	356.		4.	14.	1.65	0.07	0.15	53.3	3.31	549.5	0	13.4	1.85	118
TIHRSG	28212	0.	0.	269.	0.	10.	7.		4.	4.	1.92	0.07	0.06	39.2	2.44	497.1	0	10.9	1.31	126
TIHRSG	28212	0.	0.	331.	0.	33.	25.		4.	14.	2.43	0.07	0.15	68.4	4.25	705.6	0	13.8	1.66	110
STIRL	28212	268.	0.	0.	-268.	10.	276.		4.	4.	0.75	0.07	0.06	10.4	0.65	132.9	-35	11.8	1.41	160
STIRL	28212	422.	0.	0.	-422.	72.	485.		4.	29.	0.98	0.07	0.24	22.8	1.42	184.8	0	14.1	1.70	124
STIRL	28212	0.	268.	0.	0.	-258.	276.		4.	4.	0.75	0.07	0.06	10.4	0.65	132.9	-21	9.9	1.19	154
STIRL	28212	0.	422.	0.	0.	-349.	485.		4.	29.	0.98	0.07	0.24	22.9	1.42	185.0	0	11.3	1.35	113
STIRL	28212	0.	0.	268.	0.	10.	9.		4.	4.	1.47	0.07	0.06	21.6	1.34	275.0	3	8.4	1.01	131
STIRL	28212	0.	0.	422.	0.	72.	63.		4.	29.	1.90	0.07	0.24	40.5	2.52	327.7	4	8.7	1.04	96
HEGT60	28212	0.	0.	282.	0.	10.	-5.	A	4.	4.	1.53	0.07	0.02	27.3	1.70	330.5	0	9.4	1.13	123
HEGT60	28212	0.	0.	890.	0.	166.	-92.	A	4.	68.	3.81	0.07	0.08	97.8	6.08	374.8	0	17.8	2.14	87
HEGT00	28212	0.	0.	278.	0.	10.	-1.	A	4.	4.	1.52	0.07	0.03	26.5	1.65	326.2	0	9.3	1.11	125
HEGT00	28212	0.	0.	435.	0.	55.	-7.	A	4.	22.	1.97	0.07	0.10	46.6	2.90	365.6	0	11.1	1.33	88
FCMCCL	28212	0.	0.	263.	0.	10.	13.		4.	4.	1.60	0.07	0.08	27.1	1.68	350.3	0	9.2	1.11	131
FCMCCL	28212	0.	0.	439.	0.	96.	126.		4.	39.	2.90	0.07	0.34	54.4	3.38	423.4	1	9.9	1.19	104
FCSTCL	28212	0.	0.	263.	0.	10.	14.		4.	4.	1.63	0.07	0.08	26.5	1.65	344.7	0	9.2	1.10	131
FCSTCL	28212	0.	0.	511.	0.	138.	193.		4.	56.	3.48	0.07	0.39	64.1	3.98	427.8	3	9.6	1.15	107
IGGTST	28212	0.	0.	268.	0.	10.	9.		4.	4.	1.62	0.07	0.06	26.3	1.64	335.7	0	9.2	1.11	129
IGGTST	28212	0.	0.	476.	0.	94.	83.		4.	38.	1.97	0.07	0.27	50.6	3.15	362.5	2	9.3	1.12	95
GTSOAR	28212	0.	268.	0.	0.	-258.	276.		4.	4.	0.70	0.07	0.06	10.0	0.62	127.9	-19	9.9	1.18	155
GTSOAR	28212	0.	510.	0.	0.	-403.	599.		4.	43.	0.87	0.07	0.28	20.1	1.25	134.4	0	10.8	1.30	118
GTACOB	28212	0.	263.	0.	0.	-254.	276.		4.	4.	0.69	0.07	0.08	9.6	0.59	123.9	-17	9.6	1.16	158
GTACOB	28212	0.	401.	0.	0.	-323.	504.		4.	32.	0.72	0.07	0.31	15.1	0.94	128.3	-34	9.1	1.09	126



GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																			
**COGENERATION CASE** **NO COGEN - COGEN**																			
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD	COGEN POWER	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM WRTH ENRG	
GTAC12	28212	0.	264.	0.	0.	-254.	276.	4.	4.	0.68	0.07	0.08	9.5	0.59	123.1	-17	9.7	1.16	158
GTAC12	28212	0.	447.	0.	0.	-349.	572.	4.	40.	0.80	0.07	0.33	17.8	1.11	136.1	0	9.3	1.12	123
GTAC16	28212	0.	265.	0.	0.	-255.	276.	4.	4.	0.68	0.07	0.08	9.6	0.60	124.4	-17	9.7	1.16	157
GTAC16	28212	0.	486.	0.	0.	-373.	621.	4.	46.	0.87	0.07	0.34	20.5	1.27	144.2	0	9.7	1.16	121
GTWC16	28212	0.	266.	0.	0.	-256.	276.	4.	4.	0.69	0.07	0.07	9.9	0.62	127.2	-18	9.8	1.17	156
GTWC16	28212	0.	511.	0.	0.	-395.	631.	4.	47.	0.87	0.07	0.32	20.1	1.25	134.0	0	10.1	1.22	120
CC1626	28212	0.	267.	0.	0.	-257.	276.	4.	4.	0.76	0.07	0.07	9.8	0.61	125.1	-19	9.9	1.19	156
CC1626	28212	0.	653.	0.	0.	-479.	826.	4.	71.	1.19	0.07	0.35	26.1	1.62	136.6	0	10.9	1.31	120
CC1622	28212	0.	266.	0.	0.	-256.	276.	4.	4.	0.75	0.07	0.07	9.6	0.59	122.8	-18	9.8	1.18	157
CC1622	28212	0.	596.	0.	0.	-440.	767.	4.	64.	1.14	0.07	0.35	25.5	1.59	146.0	0	10.4	1.25	120
CC1222	28212	0.	265.	0.	0.	-256.	276.	4.	4.	0.75	0.07	0.07	9.4	0.58	120.9	-18	9.8	1.17	158
CC1222	28212	0.	591.	0.	0.	-435.	764.	4.	63.	1.12	0.07	0.36	24.2	1.50	139.7	0	10.2	1.22	121
CC0822	28212	0.	264.	0.	0.	-254.	276.	4.	4.	0.76	0.07	0.08	9.6	0.60	124.0	-18	9.8	1.17	158
CC0822	28212	0.	499.	0.	0.	-376.	655.	4.	50.	1.00	0.07	0.36	20.3	1.26	138.8	0	9.4	1.13	123
STIG15	28212	0.	279.	0.	0.	-269.	276.	4.	4.	0.72	0.07	0.03	9.7	0.60	118.9	-21	10.2	1.22	152
STIG15	28212	0.	15923.	0.	0.	-11563.	14842.	4.	1778.	27.14	0.07	0.17	442.5	27.50	94.8	0	214.6	25.77	683
STIG10	28212	0.	276.	0.	0.	-266.	276.	4.	4.	0.70	0.07	0.04	9.5	0.59	117.7	-19	10.0	1.20	154
STIG10	28212	0.	1562.	0.	0.	-1159.	1593.	4.	164.	2.69	0.07	0.22	48.8	3.04	106.7	0	24.3	2.92	132
STIG1S	28212	0.	274.	0.	0.	-264.	276.	4.	4.	0.70	0.07	0.04	9.4	0.59	117.5	-19	10.0	1.20	154
STIG1S	28212	0.	982.	0.	0.	-745.	1036.	4.	96.	1.79	0.07	0.23	29.7	1.84	103.1	0	16.8	2.02	120
DEADV3	28212	0.	272.	0.	0.	-263.	276.	4.	4.	0.78	0.07	0.05	12.3	0.76	153.7	-30	10.3	1.24	149
DEADV3	28212	0.	1142.	0.	0.	-837.	1263.	4.	124.	2.64	0.07	0.27	82.1	5.10	245.3	0	22.8	2.73	128
DEHTPM	28212	0.	266.	0.	0.	-256.	276.	4.	4.	0.82	0.07	0.07	12.7	0.79	162.8	-31	10.2	1.22	151
DEHTPM	28212	0.	484.	0.	0.	-378.	597.	4.	43.	1.42	0.07	0.31	36.7	2.28	259.1	0	12.4	1.49	114
DES0A3	28212	275.	0.	0.	0.	-275.	10.	4.	4.	0.75	0.07	0.04	11.3	0.70	140.8	-43	12.1	1.46	156
DES0A3	28212	1405.	0.	0.	0.	-1405.	365.	4.	149.	3.66	0.07	0.23	121.1	7.53	294.2	0	40.7	4.89	174
DES0A3	28212	0.	275.	0.	0.	-265.	276.	4.	4.	0.75	0.07	0.04	11.3	0.70	140.8	-26	10.2	1.23	150
DES0A3	28212	0.	1405.	0.	0.	-1041.	1464.	4.	149.	3.66	0.07	0.23	121.1	7.53	294.2	0	31.2	3.74	145
GTS0AD	28212	265.	0.	0.	0.	-265.	10.	4.	4.	0.68	0.07	0.07	9.4	0.58	120.3	-29	11.5	1.38	163
GTS0AD	28212	454.	0.	0.	0.	-454.	95.	4.	39.	0.75	0.07	0.31	15.9	0.99	119.8	999	12.6	1.51	133
GTRA08	28212	268.	0.	0.	0.	-268.	10.	4.	4.	0.69	0.07	0.06	10.2	0.63	129.5	-33	11.7	1.40	160
GTRA03	28212	667.	0.	0.	0.	-667.	171.	4.	70.	1.16	0.07	0.32	30.0	1.87	153.6	0	16.4	1.97	131
GTRA12	28212	267.	0.	0.	0.	-267.	10.	4.	4.	0.69	0.07	0.07	10.1	0.63	129.0	-33	11.6	1.40	161
GTRA12	28212	638.	0.	0.	0.	-638.	164.	4.	67.	1.10	0.07	0.33	28.1	1.75	150.4	0	15.6	1.88	131
GTRA16	28212	267.	0.	0.	0.	-267.	10.	4.	4.	0.70	0.07	0.07	10.3	0.64	131.7	-34	11.7	1.40	160
GTRA16	28212	602.	0.	0.	0.	-602.	151.	4.	62.	1.09	0.07	0.33	28.0	1.74	158.7	0	15.3	1.84	130
GTR208	28212	267.	0.	0.	0.	-267.	10.	4.	4.	0.69	0.07	0.07	9.9	0.62	126.7	-32	11.6	1.39	161
GTR208	28212	533.	0.	0.	0.	-533.	123.	4.	50.	0.91	0.07	0.31	21.6	1.34	138.0	0	14.1	1.70	130
GTR212	28212	267.	0.	0.	0.	-267.	10.	4.	4.	0.69	0.07	0.07	10.0	0.62	126.1	-32	11.6	1.40	161
GTR212	28212	555.	0.	0.	0.	-555.	132.	4.	54.	0.96	0.07	0.32	23.3	1.45	143.3	0	14.4	1.73	130
GTR216	28212	266.	0.	0.	0.	-266.	10.	4.	4.	0.69	0.07	0.07	10.1	0.63	129.3	-33	11.6	1.40	161
GTR216	28212	558.	0.	0.	0.	-558.	135.	4.	55.	1.00	0.07	0.33	24.9	1.55	152.2	0	14.5	1.74	130
GTRW08	28212	271.	0.	0.	0.	-271.	10.	4.	4.	0.70	0.07	0.05	10.2	0.64	129.2	-35	11.8	1.42	159
GTRW08	28212	801.	0.	0.	0.	-801.	202.	4.	82.	1.18	0.07	0.29	29.9	1.86	127.4	0	19.0	2.28	134

HONEYWELL PAGE PRINTING SYSTEM - P1188-03

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																				
ECS	PROCS	**COGENERATION CASE**				**HOCOGEN			COGEN**		O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVEL CHRG	NORM ENRG	WRTH
		DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REOD MW	POWER MW											
GTRW12	28212	269.	0.	0.	-269.	10.	276.	4.	4.	0.70	0.07	0.06	10.2	0.64	129.8	-34	11.7	1.41	160	
GTRW12	28212	773.	0.	0.	-773.	202.	920.	4.	82.	1.17	0.07	0.31	29.8	1.85	131.7	0	17.9	2.15	134	
GTRW16	28212	269.	0.	0.	-269.	10.	276.	4.	4.	0.70	0.07	0.06	10.4	0.65	132.1	-35	11.7	1.41	159	
GTRW16	28212	719.	0.	0.	-719.	185.	861.	4.	75.	1.15	0.07	0.31	29.3	1.82	138.8	0	17.2	2.07	132	
GTR308	28212	272.	0.	0.	-272.	10.	276.	4.	4.	0.69	0.07	0.05	9.9	0.62	124.8	-34	11.8	1.42	160	
GTR308	28212	687.	0.	0.	-687.	153.	756.	4.	62.	1.02	0.07	0.24	24.3	1.51	121.0	0	17.8	2.14	129	
GTR312	28212	268.	0.	0.	-268.	10.	276.	4.	4.	0.69	0.07	0.06	10.0	0.62	127.8	-33	11.7	1.40	161	
GTR312	28212	639.	0.	0.	-639.	157.	769.	4.	64.	1.01	0.07	0.31	24.4	1.51	130.2	0	15.7	1.89	131	
GTR316	28212	268.	0.	0.	-268.	10.	276.	4.	4.	0.70	0.07	0.06	10.2	0.64	130.0	-34	11.7	1.41	160	
GTR316	28212	634.	0.	0.	-634.	154.	760.	4.	63.	1.03	0.07	0.31	25.2	1.56	135.4	0	15.8	1.90	131	
FCPADS	28212	272.	0.	0.	-272.	10.	276.	4.	4.	1.00	0.07	0.05	10.5	0.65	131.8	-39	12.2	1.46	159	
FCPADS	28212	1218.	0.	0.	-1218.	333.	1357.	4.	136.	14.73	0.07	0.28	79.4	4.93	222.5	0	43.0	5.16	190	
FCMCDS	28212	268.	0.	0.	-268.	10.	276.	4.	4.	0.97	0.07	0.07	10.7	0.66	136.3	-38	12.0	1.44	160	
FCMCDS	28212	888.	0.	0.	-888.	263.	1124.	4.	107.	11.05	0.07	0.36	68.2	4.24	261.8	0	31.3	3.76	167	

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																					
ECS	PROCS	**COGENERATION CASE**				**NOCOGEN		- COGEN**		POWER RECD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM ENRG	WRTH
		DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL														
ONOCGM 28213	0.	154.	452.	0.	0.	0.	55.	0.	0.16	11.73	0.	1.2	1.00	219.6	0	17.6	1.00	80			
STM141 28213	0.	154.	447.	0.	-1.	4.	55.	1.	0.23	11.73	0.01	1.9	1.53	304.1	0	17.6	1.00	77			
STM141 28213	0.	134.	468.	0.	20.	-17. F	55.	1.	0.37	11.73	0.01	3.2	2.68	530.4	1	17.6	1.00	66			
STM141 28213	0.	134.	468.	0.	20.	-17. A	55.	1.	0.32	11.73	0.01	3.0	2.50	495.0	4	17.6	1.00	67			
STM088 28213	0.	154.	449.	0.	-0.	2.	55.	0.	0.22	11.73	0.00	1.6	1.28	266.1	0	17.6	1.00	79			
STM088 28213	0.	134.	469.	0.	19.	-18. F	55.	0.	0.36	11.73	0.00	2.9	2.43	503.8	0	17.6	1.01	66			
STM088 28213	0.	134.	469.	0.	19.	-18. A	55.	0.	0.32	11.73	0.00	2.8	2.34	484.6	3	17.6	1.00	67			
PFBSTM 28213	0.	132.	466.	0.	21.	-15.	55.	1.	0.40	11.73	0.01	4.6	3.78	664.5	1	17.7	1.01	65			
TISTMT 28213	0.	156.	439.	0.	-3.	13.	55.	2.	0.41	11.73	0.02	8.4	6.90	1130.4	0	18.3	1.04	62			
TISTMT 28213	0.	131.	464.	0.	23.	-13.	55.	2.	0.57	11.73	0.02	10.7	8.82	1445.6	0	18.4	1.05	60			
TIHRSG 28213	0.	158.	443.	0.	-5.	9.	55.	1.	0.33	11.73	0.01	8.2	6.75	1073.4	0	18.3	1.04	59			
TIHRSG 28213	0.	132.	469.	0.	21.	-17.	55.	1.	0.49	11.73	0.01	10.6	8.72	1386.0	0	18.5	1.05	58			
STIRL 28213	32.	130.	434.	-32.	24.	18.	55.	2.	0.41	11.73	0.02	2.0	1.66	213.2	0	17.6	1.00	83			
STIRL 28213	0.	162.	434.	0.	-8.	18.	55.	2.	0.21	11.73	0.02	2.0	1.66	213.5	16	17.4	0.99	83			
STIRL 28213	0.	130.	466.	0.	24.	-14.	55.	2.	0.36	11.73	0.02	3.9	3.21	413.3	10	17.4	0.99	71			
HEGT60 28213	0.	120.	481.	0.	34.	-30. A	55.	6.	0.73	11.73	0.01	17.8	14.69	767.0	0	18.9	1.07	67			
HEGT00 28213	0.	131.	471.	0.	23.	-20. A	55.	2.	0.38	11.73	0.01	7.7	6.38	775.3	0	18.0	1.02	62			
FCMCL 28213	0.	127.	461.	0.	26.	-9.	55.	3.	0.49	11.73	0.03	8.9	7.35	895.0	1	17.8	1.02	66			
FCSTCL 28213	0.	125.	457.	0.	28.	-6.	55.	4.	0.60	11.73	0.04	9.9	8.19	906.2	1	17.9	1.02	68			
IGGTST 28213	0.	129.	465.	0.	25.	-14.	55.	3.	0.54	11.73	0.02	8.8	7.30	868.7	0	18.1	1.03	64			
GTSGAR 28213	0.	167.	423.	0.	-13.	28.	55.	3.	0.23	11.73	0.02	3.3	2.72	278.7	10	17.4	0.99	78			
GTAC08 28213	0.	160.	431.	0.	-6.	20.	55.	2.	0.19	11.73	0.02	2.4	1.97	262.1	18	17.3	0.99	81			
GTAC12 28213	0.	162.	426.	0.	-8.	25.	55.	3.	0.21	11.73	0.03	2.6	2.18	260.4	17	17.3	0.98	81			
GTAC16 28213	0.	164.	422.	0.	-10.	29.	55.	4.	0.22	11.73	0.03	3.0	2.45	268.8	16	17.3	0.98	80			
GTWC16 28213	0.	165.	422.	0.	-12.	30.	55.	4.	0.23	11.73	0.03	3.3	2.71	283.9	12	17.3	0.99	79			
CC1626 28213	0.	170.	411.	0.	-17.	40.	55.	5.	0.34	11.73	0.04	4.0	3.26	283.2	10	17.4	0.99	79			
CC1622 28213	0.	168.	415.	0.	-14.	36.	55.	4.	0.32	11.73	0.04	3.5	2.88	273.3	11	17.3	0.99	80			
CC1222 28213	0.	167.	416.	0.	-14.	36.	55.	4.	0.31	11.73	0.04	3.3	2.71	260.5	12	17.3	0.99	81			
CC0822 28213	0.	163.	424.	0.	-9.	28.	55.	3.	0.29	11.73	0.03	3.0	2.49	283.2	12	17.4	0.99	80			
DEADV3 28213	0.	204.	368.	0.	-50.	84.	55.	10.	0.45	11.73	0.06	8.4	6.91	304.0	4	17.7	1.01	81			
DEHTPM 28213	0.	164.	425.	0.	-11.	26.	55.	3.	0.32	11.73	0.03	4.8	4.00	443.2	2	17.7	1.01	72			
DESGA3 28213	117.	104.	350.	-117.	49.	102.	55.	12.	0.53	11.73	0.06	10.9	8.98	316.3	0	18.8	1.07	82			
DESGA3 28213	0.	222.	350.	0.	-68.	102.	55.	12.	0.53	11.73	0.06	10.9	8.98	316.3	0	18.0	1.03	81			
GTSGAD 28213	35.	127.	427.	-35.	26.	25.	55.	3.	0.20	11.73	0.03	2.5	2.04	240.0	7	17.5	1.00	82			
GTRA08 28213	54.	121.	405.	-54.	33.	46.	55.	6.	0.28	11.73	0.04	4.6	3.78	289.8	2	17.7	1.01	79			
GTRA12 28213	51.	122.	408.	-51.	32.	44.	55.	5.	0.27	11.73	0.04	4.3	3.59	290.5	3	17.6	1.00	79			
GTRA16 28213	48.	123.	411.	-48.	31.	40.	55.	5.	0.27	11.73	0.04	4.3	3.59	309.6	2	17.6	1.01	78			
GTR208 28213	42.	125.	419.	-42.	28.	32.	55.	4.	0.24	11.73	0.03	3.4	2.81	277.0	3	17.6	1.00	79			
GTR212 28213	44.	125.	417.	-44.	29.	35.	55.	4.	0.24	11.73	0.03	3.7	3.03	286.7	3	17.6	1.00	79			
GTR216 28213	44.	124.	416.	-44.	29.	36.	55.	4.	0.25	11.73	0.03	3.8	3.15	296.0	3	17.6	1.00	79			
GTRW08 28213	64.	119.	397.	-64.	35.	54.	55.	7.	0.30	11.73	0.04	5.1	4.21	270.6	0	17.8	1.02	80			
GTRW12 28213	62.	119.	398.	-62.	35.	54.	55.	7.	0.30	11.73	0.05	5.1	4.19	281.1	0	17.7	1.01	80			
GTRW16 28213	57.	120.	403.	-57.	33.	49.	55.	6.	0.29	11.73	0.04	5.0	4.12	299.5	0	17.7	1.01	79			

HONEYWELL PAGE PRINTING SYSTEM - P1185-02



GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																				
**COGENERATION CASE** **NOCOGEN - COGEN**																				
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER RECD	COGEN POWER	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHR	NORM ENRG	WRTH ENRG	
ONOCGN	28221	0.	18.	103.	0.	0.	0.	A	8.	0.	0.43	0.73	0.	4.2	1.00	350.2	0	3.9	1.00	80
STM141	28221	0.	63.	44.	0.	-45.	59.	8.	2.	0.32	0.73	0.12	3.4	0.81	235.5	999	3.8	0.98	130	
STM141	28221	0.	13.	94.	0.	5.	9.	F	8.	2.	0.54	0.73	0.12	6.1	1.45	421.6	11	3.7	0.95	115
STM141	28221	0.	13.	94.	0.	5.	9.	A	8.	2.	0.48	0.73	0.12	5.3	1.26	363.8	23	3.5	0.91	117
STM088	28221	0.	62.	49.	0.	-44.	54.	8.	2.	0.31	0.73	0.09	2.9	0.70	212.0	-1	3.8	0.99	126	
STM068	28221	0.	15.	96.	0.	4.	7.	F	8.	2.	0.52	0.73	0.09	5.6	1.33	403.5	11	3.7	0.97	110
STM088	28221	0.	15.	96.	0.	4.	7.	A	8.	2.	0.46	0.73	0.09	5.0	1.18	357.3	24	3.6	0.93	112
PFBSTM	28221	0.	10.	89.	0.	8.	14.	8.	3.	0.63	0.73	0.19	8.1	1.91	496.8	9	3.7	0.95	122	
TISTMT	28221	0.	67.	24.	0.	-49.	79.	8.	5.	0.66	0.73	0.25	16.0	3.80	909.0	0	5.0	1.30	130	
TISTMT	28221	0.	7.	84.	0.	11.	19.	8.	5.	0.92	0.73	0.25	20.4	4.83	1158.0	0	5.0	1.30	127	
TIHRSG	28221	0.	66.	43.	0.	-48.	59.	8.	2.	0.51	0.73	0.09	13.8	3.28	883.7	0	5.1	1.33	106	
TIHRSG	28221	0.	13.	97.	0.	5.	6.	8.	2.	0.75	0.73	0.09	17.9	4.23	1140.8	0	5.2	1.35	103	
STIRL	28221	74.	5.	15.	-74.	14.	87.	8.	6.	0.33	0.73	0.22	4.4	1.05	203.2	0	4.0	1.04	146	
STIRL	28221	0.	79.	15.	0.	-61.	87.	8.	6.	0.33	0.73	0.22	4.4	1.05	203.4	161	3.5	0.91	143	
STIRL	28221	0.	5.	90.	0.	14.	13.	8.	6.	0.57	0.73	0.22	7.6	1.80	349.9	17	3.2	0.83	128	
HEGT85	28221	0.	0.	106.	0.	18.	-3.	A	8.	8.	1.14	0.73	0.13	24.2	5.74	780.8	0	5.5	1.44	126
HEGT85	28221	0.	0.	219.	0.	51.	-9.	A	8.	21.	1.57	0.73	0.16	42.6	10.07	662.0	0	7.4	1.93	116
HEGT60	28221	0.	0.	103.	0.	18.	-0.	A	8.	8.	1.00	0.73	0.15	21.9	5.18	723.3	0	5.1	1.32	127
HEGT60	28221	0.	0.	111.	0.	21.	-1.	A	8.	8.	0.90	0.73	0.15	22.5	5.33	694.0	0	5.0	1.30	116
HEGT00	28221	0.	9.	102.	0.	9.	0.	A	8.	4.	0.59	0.73	0.08	12.9	3.06	624.1	0	4.3	1.13	105
FCMCL	28221	0.	2.	81.	0.	16.	21.	8.	7.	0.80	0.73	0.31	15.3	3.63	708.3	4	4.0	1.04	134	
FCSTCL	28221	0.	0.	77.	0.	18.	26.	8.	8.	1.08	0.73	0.37	17.2	4.06	761.9	2	4.3	1.11	152	
FCSTCL	28221	0.	0.	89.	0.	25.	35.	8.	10.	1.02	0.73	0.40	18.5	4.39	712.1	3	4.1	1.06	142	
IGGTST	28221	0.	1.	87.	0.	17.	16.	8.	7.	0.81	0.73	0.27	15.9	3.76	655.0	3	4.1	1.07	129	
GTSGAR	28221	0.	82.	5.	0.	-64.	98.	8.	7.	0.32	0.73	0.28	5.4	1.27	226.1	29	3.4	0.88	145	
GTAC08	28221	0.	73.	17.	0.	-55.	85.	8.	5.	0.28	0.73	0.25	4.1	0.97	204.9	999	3.3	0.86	147	
GTAC12	28221	0.	77.	6.	0.	-59.	96.	8.	7.	0.30	0.73	0.31	4.6	1.09	208.8	122	3.2	0.83	152	
GTAC16	28221	0.	80.	0.	0.	-61.	103.	8.	8.	0.36	0.73	0.34	5.2	1.24	223.9	42	3.2	0.83	163	
GTAC16	28221	0.	80.	0.	0.	-62.	104.	8.	8.	0.32	0.73	0.34	5.2	1.22	219.5	48	3.2	0.82	153	
GTWC16	28221	0.	84.	0.	0.	-65.	103.	8.	8.	0.40	0.73	0.31	5.7	1.35	231.7	24	3.4	0.89	159	
GTWC16	28221	0.	87.	0.	0.	-67.	107.	8.	8.	0.33	0.73	0.32	5.6	1.33	221.4	28	3.3	0.86	148	
CC1626	28221	0.	84.	0.	0.	-66.	103.	8.	8.	0.55	0.73	0.31	6.3	1.50	257.3	11	3.7	0.95	157	
CC1326	28221	0.	114.	0.	0.	-83.	145.	8.	13.	0.50	0.73	0.35	7.6	1.80	228.2	9	3.6	0.95	146	
CC1622	28221	0.	82.	0.	0.	-64.	103.	8.	8.	0.53	0.73	0.32	6.0	1.42	249.2	15	3.6	0.92	160	
CC1622	28221	0.	104.	0.	0.	-76.	134.	8.	11.	0.47	0.73	0.36	6.9	1.62	226.2	14	3.5	0.90	149	
CC1222	28221	0.	82.	0.	0.	-64.	103.	8.	8.	0.53	0.73	0.32	5.8	1.37	240.8	18	3.5	0.91	161	
CC1222	28221	0.	103.	0.	0.	-75.	134.	8.	11.	0.46	0.73	0.37	6.5	1.55	217.3	16	3.4	0.89	150	
CC0822	28221	0.	79.	0.	0.	-61.	103.	8.	8.	0.51	0.73	0.35	5.8	1.36	247.8	21	3.4	0.88	163	
CC0822	28221	0.	87.	0.	0.	-65.	115.	8.	9.	0.43	0.73	0.37	5.9	1.39	230.2	24	3.3	0.85	153	
STIG15	28221	0.	107.	0.	0.	-89.	103.	8.	8.	0.57	0.73	0.11	6.7	1.58	212.5	0	4.4	1.13	137	
STIG15	28221	0.	2692.	0.	0.	-1955.	2509.	8.	301.	5.31	0.73	0.17	90.2	21.34	114.3	0	38.7	10.06	290	
STIG10	28221	0.	101.	0.	0.	-83.	103.	8.	8.	0.53	0.73	0.16	6.2	1.47	208.8	0	4.1	1.06	143	
STIG10	28221	0.	264.	0.	0.	-196.	269.	8.	28.	0.73	0.73	0.22	11.7	2.77	151.3	0	5.9	1.52	119	

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																					
**COGENERATION CASE** **NOCOGEN - COGEN**										POWER	COGEN	O&M	POWER	FESR	CAPITAL	NORM	\$/KW	ROI	LEVEL	NORM	WRTH
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	REQD	POWER	MW	MW	RATIO	COST	COST	EQVL	(%)	CHRG	ENRG			
STIG1S	28221	0.	99.	0.	0.	-80.	103.	8.	8.	0.52	0.73	0.19	5.9	1.41	205.8	0	4.0	1.03	146		
STIG1S	28221	0.	166.	0.	0.	-126.	175.	8.	16.	0.54	0.73	0.23	8.0	1.90	165.2	0	4.6	1.18	131		
DEADV3	28221	0.	93.	0.	0.	-74.	103.	8.	8.	0.57	0.73	0.24	8.4	1.98	308.3	0	4.1	1.07	146		
DEADV3	28221	0.	161.	0.	0.	-118.	185.	8.	18.	0.60	0.73	0.29	12.4	2.94	262.5	0	4.7	1.23	131		
DEHTPM	28221	0.	79.	0.	0.	-60.	103.	8.	8.	0.53	0.73	0.35	7.8	1.85	339.1	10	3.6	0.94	158		
DEHTPM	28221	0.	81.	0.	0.	-62.	107.	8.	8.	0.46	0.73	0.36	7.8	1.85	327.1	11	3.5	0.92	148		
DES0A3	28221	97.	0.	0.	-97.	18.	103.	8.	8.	0.57	0.73	0.20	8.3	1.96	292.0	0	4.9	1.26	147		
DES0A3	28221	191.	0.	0.	-191.	50.	207.	8.	20.	0.75	0.73	0.26	17.4	4.13	310.8	0	7.0	1.82	133		
DES0A3	28221	0.	97.	0.	0.	-78.	103.	8.	8.	0.57	0.73	0.20	8.3	1.96	292.0	0	4.2	1.10	142		
DES0A3	28221	0.	191.	0.	0.	-142.	207.	8.	20.	0.75	0.73	0.26	17.4	4.13	310.8	0	5.8	1.50	125		
GTS0AD	28221	75.	3.	9.	-75.	16.	94.	8.	6.	0.29	0.73	0.29	4.2	1.00	190.9	999	3.7	0.96	154		
GTRA08	28221	84.	0.	0.	-84.	18.	103.	8.	8.	0.46	0.73	0.31	6.5	1.53	264.7	0	4.1	1.06	160		
GTRA08	28221	101.	0.	0.	-101.	26.	128.	8.	11.	0.38	0.73	0.34	7.1	1.69	241.9	0	4.1	1.07	151		
GTRA12	28221	83.	0.	0.	-83.	18.	103.	8.	8.	0.45	0.73	0.32	6.4	1.52	264.7	0	4.0	1.05	161		
GTRA12	28221	98.	0.	0.	-98.	25.	126.	8.	10.	0.38	0.73	0.35	7.0	1.66	244.0	0	4.1	1.06	151		
GTRA16	28221	83.	0.	0.	-83.	18.	103.	8.	8.	0.45	0.73	0.32	6.7	1.58	275.5	0	4.1	1.06	161		
GTRA16	28221	94.	0.	0.	-94.	24.	120.	8.	10.	0.38	0.73	0.35	7.1	1.68	257.3	0	4.1	1.05	151		
GTR208	28221	83.	0.	0.	-83.	18.	103.	8.	8.	0.40	0.73	0.32	5.7	1.35	235.8	0	3.9	1.02	163		
GTR208	28221	86.	0.	0.	-86.	20.	107.	8.	8.	0.33	0.73	0.32	5.7	1.34	225.2	5	3.9	1.00	153		
GTR212	28221	83.	0.	0.	-83.	18.	103.	8.	8.	0.43	0.73	0.32	6.0	1.43	248.4	0	4.0	1.03	162		
GTR212	28221	89.	0.	0.	-89.	21.	112.	8.	9.	0.35	0.73	0.33	6.1	1.44	233.5	0	3.9	1.02	152		
GTR216	28221	82.	0.	0.	-82.	18.	103.	8.	8.	0.43	0.73	0.32	6.2	1.47	258.8	0	4.0	1.03	162		
GTR216	28221	89.	0.	0.	-89.	22.	114.	8.	9.	0.36	0.73	0.34	6.4	1.51	243.4	0	3.9	1.02	152		
GTRW08	28221	90.	0.	0.	-90.	18.	103.	8.	8.	0.48	0.73	0.26	6.7	1.58	254.9	0	4.3	1.13	155		
GTRW08	28221	122.	0.	0.	-122.	31.	145.	8.	13.	0.42	0.73	0.30	8.0	1.90	223.2	0	4.7	1.21	145		
GTRW12	28221	87.	0.	0.	-87.	18.	103.	8.	8.	0.48	0.73	0.28	6.7	1.58	261.0	0	4.3	1.11	157		
GTRW12	28221	120.	0.	0.	-120.	32.	147.	8.	13.	0.42	0.73	0.32	8.1	1.92	229.2	0	4.5	1.18	146		
GTRW16	28221	87.	0.	0.	-87.	18.	103.	8.	8.	0.48	0.73	0.28	6.9	1.63	270.0	0	4.3	1.11	157		
GTRW16	28221	114.	0.	0.	-114.	29.	139.	8.	12.	0.42	0.73	0.32	8.1	1.91	241.0	0	4.5	1.16	147		
GTR308	28221	92.	0.	0.	-92.	18.	103.	8.	8.	0.45	0.73	0.24	6.1	1.44	225.9	0	4.3	1.12	155		
GTR308	28221	106.	0.	0.	-106.	24.	120.	8.	10.	0.37	0.73	0.26	6.4	1.51	205.3	0	4.4	1.14	145		
GTR312	28221	86.	0.	0.	-86.	18.	103.	8.	8.	0.45	0.73	0.29	6.2	1.47	245.6	0	4.2	1.08	159		
GTR312	28221	104.	0.	0.	-104.	26.	127.	8.	10.	0.38	0.73	0.32	6.8	1.60	221.0	0	4.2	1.10	149		
GTR316	28221	87.	0.	0.	-87.	18.	103.	8.	8.	0.46	0.73	0.28	6.5	1.53	255.0	0	4.2	1.09	158		
GTR316	28221	104.	0.	0.	-104.	25.	126.	8.	10.	0.38	0.73	0.31	7.0	1.66	231.2	0	4.3	1.11	148		
FCPADS	28221	95.	0.	0.	-95.	18.	103.	8.	8.	1.06	0.73	0.22	6.7	1.58	239.7	0	5.1	1.33	154		
FCPADS	28221	206.	0.	0.	-206.	56.	229.	8.	23.	2.51	0.73	0.28	14.5	3.44	240.6	0	8.5	2.20	145		
FCMCDS	28221	86.	0.	0.	-86.	18.	103.	8.	8.	1.01	0.73	0.29	6.9	1.64	274.1	0	4.8	1.24	161		
FCMCDS	28221	150.	0.	0.	-150.	44.	190.	8.	18.	1.90	0.73	0.36	12.4	2.92	280.7	0	6.6	1.70	150		

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 3.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----

\*\*COGENERATION CASE\*\* \*\*NOCOGEN - COGEN\*\*

ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD	COGEN POWER	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM ENRG	WRTH
ONOCGN	28241	0.	114.	263.	0.	0.	0.	32.	0.	0.21	3.64	0.	1.8	1.00	174.4	0	11.1	1.00	80
STM141	28241	0.	116.	252.	0.	-2.	10.	32.	1.	0.30	3.64	0.02	2.9	1.59	242.5	7	11.1	1.00	85
STM141	28241	0.	75.	293.	0.	38.	-30.	F 32.	1.	0.49	3.64	0.02	5.2	2.87	437.7	6	11.1	0.99	74
STM141	28241	0.	75.	293.	0.	38.	-30.	A 32.	1.	0.43	3.64	0.02	4.5	2.52	383.4	10	10.9	0.98	75
STM088	28241	0.	115.	256.	0.	-1.	7.	32.	1.	0.28	3.64	0.01	2.4	1.35	215.7	5	11.1	1.00	85
STM088	28241	0.	76.	295.	0.	37.	-32.	F 32.	1.	0.47	3.64	0.01	4.7	2.61	417.4	6	11.1	1.00	72
STM088	28241	0.	76.	295.	0.	37.	-32.	A 32.	1.	0.42	3.64	0.01	4.2	2.35	375.7	9	11.0	0.99	73
PFBSTM	28241	0.	73.	289.	0.	41.	-26.	32.	2.	0.56	3.64	0.04	7.0	3.86	524.4	6	11.1	0.99	76
TISTMT	28241	0.	119.	235.	0.	-6.	27.	32.	3.	0.58	3.64	0.06	13.6	7.55	951.2	0	12.2	1.09	77
TISTMT	28241	0.	70.	285.	0.	43.	-22.	32.	3.	0.82	3.64	0.06	17.4	9.64	1214.7	0	12.2	1.10	75
TIHRSG	28241	0.	121.	247.	0.	-7.	16.	32.	2.	0.47	3.64	0.02	12.7	7.04	912.1	0	12.3	1.11	69
TIHRSG	28241	0.	74.	294.	0.	40.	-31.	32.	2.	0.70	3.64	0.02	16.4	9.08	1177.6	0	12.4	1.11	67
STIRL	28241	62.	68.	227.	-62.	46.	36.	32.	4.	0.30	3.64	0.05	3.7	2.05	204.6	0	11.3	1.01	93
STIRL	28241	0.	129.	227.	0.	-16.	36.	32.	4.	0.30	3.64	0.05	3.7	2.05	204.6	14	10.9	0.97	92
STIRL	28241	0.	68.	288.	0.	46.	-26.	32.	4.	0.51	3.64	0.05	6.5	3.62	361.8	12	10.6	0.95	83
HEGT60	28241	0.	56.	308.	0.	58.	-45.	A 32.	9.	0.95	3.64	0.03	23.8	13.21	677.8	0	12.5	1.12	81
HEGT00	28241	0.	71.	299.	0.	43.	-36.	A 32.	3.	0.55	3.64	0.02	11.9	6.58	647.0	0	11.6	1.04	72
FCMCCL	28241	0.	65.	280.	0.	49.	-17.	32.	6.	0.73	3.64	0.09	13.8	7.64	740.9	4	11.3	1.02	83
FCSTCL	28241	0.	60.	272.	0.	54.	-9.	32.	8.	0.89	3.64	0.12	15.9	8.79	748.7	4	11.2	1.01	90
IGGTST	28241	0.	66.	287.	0.	48.	-25.	32.	5.	0.73	3.64	0.06	13.7	7.60	695.1	2	11.5	1.03	80
GTSOAR	28241	0.	136.	212.	0.	-22.	51.	32.	6.	0.31	3.64	0.08	5.0	2.79	235.4	12	10.8	0.97	93
GTAC08	28241	0.	125.	225.	0.	-12.	38.	32.	5.	0.26	3.64	0.07	3.8	2.08	220.1	20	10.7	0.96	94
GTAC12	28241	0.	129.	215.	0.	-15.	48.	32.	6.	0.28	3.64	0.09	4.2	2.33	221.8	20	10.6	0.95	96
GTAC16	28241	0.	132.	208.	0.	-19.	54.	32.	7.	0.30	3.64	0.10	4.7	2.63	231.1	18	10.5	0.94	97
GTWC16	28241	0.	136.	207.	0.	-22.	56.	32.	7.	0.31	3.64	0.09	5.1	2.84	236.3	15	10.6	0.95	95
CC1626	28241	0.	147.	182.	0.	-33.	80.	32.	10.	0.45	3.64	0.13	6.4	3.54	236.5	13	10.5	0.95	100
CC1622	28241	0.	141.	191.	0.	-27.	72.	32.	9.	0.42	3.64	0.12	5.7	3.18	232.7	15	10.5	0.94	100
CC1222	28241	0.	141.	191.	0.	-27.	72.	32.	9.	0.42	3.64	0.12	5.4	3.02	222.9	16	10.5	0.94	100
CC0822	28241	0.	132.	207.	0.	-18.	56.	32.	7.	0.39	3.64	0.10	4.9	2.71	237.0	16	10.6	0.95	97
STIG15	28241	0.	317.	0.	0.	-204.	263.	32.	32.	1.08	3.64	0.16	14.8	8.22	159.4	0	11.8	1.06	118
STIG15	28241	0.	2308.	0.	0.	-1640.	2116.	32.	258.	4.60	3.64	0.17	76.8	42.56	113.5	0	37.8	3.40	126
STIG10	28241	0.	246.	67.	0.	-133.	196.	32.	24.	0.66	3.64	0.17	10.5	5.80	157.8	8	10.6	0.97	108
STIG1S	28241	0.	187.	148.	0.	-73.	115.	32.	14.	0.49	3.64	0.11	7.2	3.99	172.7	9	10.8	0.97	101
DEADV3	28241	0.	495.	120.	0.	-82.	142.	32.	17.	0.60	3.64	0.16	12.3	6.81	262.6	6	10.9	0.98	104
DEHTPM	28241	0.	133.	210.	0.	-19.	52.	32.	6.	0.42	3.64	0.09	7.2	3.97	348.6	7	11.0	0.99	91
DESOA3	28241	195.	28.	94.	-195.	86.	169.	32.	21.	0.76	3.64	0.16	17.7	9.82	310.6	0	13.0	1.16	107
DESOA3	28241	0.	223.	94.	0.	-109.	169.	32.	21.	0.76	3.64	0.16	17.7	9.82	310.6	1	11.7	1.05	105
GTSOAD	28241	66.	65.	217.	-66.	49.	46.	32.	6.	0.27	3.64	0.08	3.9	2.16	202.9	9	11.0	0.99	97
GTRA08	28241	94.	54.	182.	-94.	59.	61.	32.	10.	0.37	3.64	0.12	6.8	3.77	246.5	5	11.1	1.00	100
GTRA12	28241	91.	55.	185.	-91.	59.	78.	32.	10.	0.36	3.64	0.12	6.7	3.69	250.6	6	11.1	1.00	100
GTRA16	28241	86.	57.	191.	-86.	57.	72.	32.	9.	0.36	3.64	0.11	6.7	3.71	265.6	5	11.2	1.00	98
GTR208	28241	77.	61.	204.	-77.	53.	59.	32.	7.	0.32	3.64	0.09	5.3	2.92	234.9	5	11.1	1.00	97
GTR212	28241	80.	60.	200.	-80.	54.	63.	32.	8.	0.33	3.64	0.10	5.7	3.14	243.3	5	11.1	1.00	97

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																					
ECS	PROCS	**COGENERATION CASE**				**NOCOGEN - COGEN**				POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM ENRG	WRTH
		DISTIL	RESIDL	COAL	COAL	DISTIL	RESIDL	COAL	COAL												
GTR216	28241	80.	59.	198.	-80.	55.	65.	32.	8.	0.34	3.64	0.11	5.9	3.29	252.9	5	11.1	1.00	98		
GTRW08	28241	114.	50.	167.	-114.	64.	96.	32.	12.	0.41	3.64	0.12	7.6	4.23	229.2	0	11.4	1.02	101		
GTRW12	28241	110.	50.	166.	-110.	64.	96.	32.	12.	0.40	3.64	0.13	7.6	4.23	236.7	3	11.2	1.01	103		
GTRW16	28241	103.	52.	174.	-103.	62.	88.	32.	11.	0.40	3.64	0.13	7.6	4.19	250.5	3	11.3	1.01	101		
GTR308	28241	98.	57.	190.	-98.	57.	73.	32.	9.	0.35	3.64	0.09	6.1	3.36	211.5	0	11.5	1.03	97		
GTR312	28241	92.	56.	187.	-92.	58.	76.	32.	9.	0.36	3.64	0.11	6.3	3.47	232.1	4	11.2	1.00	99		
GTR316	28241	91.	56.	188.	-91.	58.	74.	32.	9.	0.36	3.64	0.11	6.5	3.60	242.9	3	11.2	1.01	99		
FCPADS	28241	176.	30.	101.	-176.	83.	161.	32.	20.	2.16	3.64	0.18	12.4	6.85	233.1	0	13.4	1.21	113		
FCMCDS	28241	129.	40.	135.	-129.	73.	128.	32.	16.	1.64	3.64	0.19	10.7	5.95	284.6	0	12.3	1.10	111		



GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

ECS	PROCS	DISTIL	RESIDL	COAL	**COGENERATION CASE**	**NOCOGEN -	COGEN**	POWER	COGEN	O&M	POWER	FESR	CAPITAL	NORM	\$/KW	ROI	LEVEL	NORM	WRTH
					RESIDL	DISTIL	RESIDL	COAL	REGD	POWER	RATIO	COST	COST	EQVL	(%)	CHRG	ENRG		
					COAL	COAL	COAL	COAL	MW	MW		*10**6	*10**6						
ONDCGN	28242	0.	54.	90.	0.	0.	0.	0.	11.	0.	0.19	1.63	1.5	1.00	192.2	0	4.9	1.00	80
STM141	28242	0.	57.	75.	0.	-3.	15.	0.	11.	2.	0.29	1.63	2.9	1.86	283.3	12	4.8	0.97	100
STM141	28242	0.	22.	110.	0.	32.	-19.	F	11.	2.	0.47	1.63	4.9	3.22	485.7	9	4.7	0.96	91
STM141	28242	0.	22.	110.	0.	32.	-19.	A	11.	2.	0.41	1.63	4.4	2.88	434.8	12	4.6	0.94	92
STM088	28242	0.	56.	79.	0.	-2.	12.	0.	11.	1.	0.27	1.63	2.4	1.61	254.6	12	4.8	0.98	99
STM088	28242	0.	23.	111.	0.	31.	-21.	F	11.	1.	0.45	1.63	4.5	2.93	464.6	8	4.8	0.97	87
STM088	28242	0.	23.	111.	0.	31.	-21.	A	11.	1.	0.40	1.63	4.1	2.70	427.1	11	4.7	0.95	88
PFBSTH	28242	0.	20.	106.	0.	34.	-16.		11.	3.	0.53	1.63	6.5	4.28	581.5	8	4.7	0.96	96
TISTMT	28242	0.	60.	61.	0.	-6.	29.		11.	4.	0.54	1.63	12.4	8.13	1013.8	0	5.7	1.16	103
TISTMT	28242	0.	18.	103.	0.	36.	-12.		11.	4.	0.76	1.63	15.8	10.34	1288.8	0	5.7	1.17	101
TIHRSG	28242	0.	58.	79.	0.	-4.	12.		11.	1.	0.39	1.63	10.0	6.55	996.5	0	5.8	1.17	81
TIHRSG	28242	0.	24.	113.	0.	31.	-23.		11.	1.	0.58	1.63	12.9	8.46	1286.8	0	5.8	1.17	81
STIRL	28242	50.	17.	57.	-50.	37.	33.		11.	4.	0.27	1.63	3.1	2.03	209.3	5	4.9	1.00	114
STIRL	28242	0.	67.	57.	0.	-13.	33.		11.	4.	0.27	1.63	3.1	2.03	209.3	19	4.6	0.93	112
STIRL	28242	0.	17.	108.	0.	37.	-17.		11.	4.	0.46	1.63	5.6	3.67	378.6	14	4.3	0.88	101
HEGT85	28242	0.	5.	112.	0.	49.	-21.	A	11.	9.	0.90	1.63	23.4	16.38	847.8	0	5.9	1.20	111
HEGT60	28242	0.	15.	114.	0.	39.	-24.	A	11.	5.	0.64	1.63	15.2	9.95	820.8	0	5.5	1.13	96
HEGT00	28242	0.	21.	116.	0.	33.	-26.	A	11.	2.	0.45	1.63	9.4	6.17	713.7	1	5.2	1.06	83
FCMCL	28242	0.	16.	103.	0.	38.	-13.		11.	4.	0.62	1.63	11.4	7.48	803.8	4	5.0	1.02	103
FCSTCL	28242	0.	9.	92.	0.	45.	-1.		11.	7.	0.83	1.63	14.5	9.50	802.5	5	4.8	0.98	121
IGTST	28242	0.	14.	105.	0.	40.	-15.		11.	5.	0.69	1.63	12.6	8.30	751.5	4	5.1	1.04	105
GTSOAR	28242	0.	68.	55.	0.	-13.	36.		11.	4.	0.26	1.63	3.9	2.57	261.2	15	4.5	0.92	111
GTAC08	28242	0.	63.	61.	0.	-9.	29.		11.	4.	0.23	1.63	3.0	2.00	230.2	21	4.5	0.91	111
GTAC12	28242	0.	65.	54.	0.	-11.	36.		11.	4.	0.24	1.63	3.4	2.20	234.1	22	4.4	0.89	115
GTAC16	28242	0.	67.	50.	0.	-13.	40.		11.	5.	0.25	1.63	3.7	2.45	246.3	20	4.4	0.89	116
GTAC16	28242	0.	71.	47.	0.	-17.	43.		11.	5.	0.27	1.63	4.2	2.75	250.6	16	4.5	0.91	114
CC1626	28242	0.	83.	15.	0.	-29.	75.		11.	9.	0.43	1.63	6.0	3.94	260.1	15	4.2	0.86	129
CC1622	28242	0.	78.	23.	0.	-24.	68.		11.	8.	0.40	1.63	5.3	3.51	254.7	16	4.2	0.85	127
CC1222	28242	0.	78.	23.	0.	-24.	67.		11.	8.	0.40	1.63	5.1	3.36	245.3	17	4.2	0.85	128
CC0822	28242	0.	71.	36.	0.	-17.	54.		11.	7.	0.37	1.63	4.7	3.05	263.9	17	4.3	0.87	123
ST1615	28242	0.	124.	0.	0.	-70.	90.		11.	11.	0.64	1.63	7.5	5.00	209.5	0	5.4	1.10	121
ST1615	28242	0.	1769.	0.	0.	-1258.	1622.		11.	190.	3.79	1.63	59.2	38.84	114.2	0	28.7	5.83	183
ST1610	28242	0.	115.	0.	0.	-61.	90.		11.	11.	0.55	1.63	6.8	4.48	202.2	4	4.9	1.01	128
ST1610	28242	0.	174.	0.	0.	-102.	150.		11.	18.	0.57	1.63	8.6	5.68	170.0	0	5.5	1.13	117
ST1615	28242	0.	110.	2.	0.	-56.	88.		11.	11.	0.43	1.63	6.0	3.92	186.7	10	4.6	0.94	120
DEADV3	28242	0.	96.	6.	0.	-42.	84.		11.	10.	0.45	1.63	8.4	5.50	303.6	8	4.6	0.93	124
DEHTPM	28242	0.	56.	45.	0.	-12.	45.		11.	6.	0.37	1.63	5.9	3.86	380.7	11	4.5	0.92	117
DESQA3	28242	105.	0.	0.	-105.	54.	90.		11.	11.	0.55	1.63	9.9	6.50	320.9	0	5.7	1.16	136
DESQA3	28242	110.	0.	0.	-110.	55.	95.		11.	12.	0.51	1.63	10.2	6.58	317.2	0	5.7	1.16	126
DESQA3	28242	0.	105.	0.	0.	-51.	90.		11.	11.	0.55	1.63	9.9	6.50	320.9	4	5.0	1.01	133
DESQA3	28242	0.	110.	0.	0.	-54.	95.		11.	12.	0.51	1.63	10.2	6.58	317.2	4	5.0	1.01	122
GTSOAR	28242	49.	17.	56.	-49.	37.	34.		11.	4.	0.24	1.63	3.1	2.03	216.6	11	4.8	0.97	116
GTRA08	28242	62.	11.	37.	-62.	43.	53.		11.	7.	0.30	1.63	5.1	3.36	281.1	8	4.8	0.97	122

DATE 06/07/79  
I&SE-PEO-ADV-DES-ENGR

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

PAGE 71

-----FUEL USE IN BTU*10**6-----																					
ECS	PROCS	**COGENERATION CASE** **NOCOGEN - COGEN**								POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (\$)	LEVEL CHRG	NORM ENRG	WRTH
		DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	DISTIL	RESIDL												
GTRA12	28242	61.	11.	37.	-61.	43.	53.	11.	6.	0.30	1.63	0.24	5.0	3.30	279.8	8	4.8	0.97	122		
GTRA16	28242	59.	12.	41.	-59.	42.	50.	11.	6.	0.30	1.63	0.22	5.1	3.36	294.4	7	4.8	0.98	120		
GTR208	28242	54.	14.	48.	-54.	40.	42.	11.	5.	0.27	1.63	0.19	4.1	2.70	258.2	8	4.8	0.98	117		
GTR212	28242	57.	14.	45.	-57.	40.	45.	11.	5.	0.28	1.63	0.20	4.4	2.91	267.2	7	4.8	0.98	118		
GTR216	28242	57.	13.	44.	-57.	41.	46.	11.	6.	0.28	1.63	0.21	4.6	3.02	277.2	8	4.8	0.98	119		
GTRW08	28242	76.	8.	26.	-76.	46.	64.	11.	8.	0.33	1.63	0.24	5.8	3.81	260.4	4	5.0	1.01	123		
GTRW12	28242	76.	7.	24.	-76.	47.	66.	11.	8.	0.33	1.63	0.26	5.9	3.87	266.3	5	4.9	1.00	125		
GTRW16	28242	72.	8.	28.	-72.	46.	62.	11.	8.	0.33	1.63	0.25	5.9	3.88	279.4	5	4.9	1.00	123		
GTR308	28242	65.	12.	42.	-65.	42.	49.	11.	6.	0.29	1.63	0.17	4.6	2.99	238.7	1	5.0	1.02	116		
GTR312	28242	67.	11.	35.	-67.	44.	55.	11.	7.	0.30	1.63	0.22	5.0	3.27	254.2	5	4.9	0.99	121		
GTR316	28242	67.	11.	36.	-67.	43.	54.	11.	7.	0.31	1.63	0.21	5.2	3.40	266.2	4	4.9	1.00	120		
FCPADS	28242	106.	0.	0.	-106.	54.	90.	11.	11.	1.47	1.63	0.27	8.0	5.25	257.2	0	6.5	1.31	142		
FCPADS	28242	135.	0.	0.	-135.	64.	124.	11.	15.	1.82	1.63	0.28	9.7	6.39	245.5	0	7.3	1.49	134		
FCMCDS	28242	93.	0.	0.	-93.	54.	90.	11.	11.	1.36	1.63	0.35	8.1	5.34	297.8	0	5.9	1.19	150		
FCMCDS	28242	99.	0.	0.	-99.	56.	98.	11.	12.	1.38	1.63	0.33	8.4	5.53	291.6	0	5.9	1.21	139		

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----

\*\*COGENERATION CASE\*\* \*\*NOCOGEN - COGEN\*\*

ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD	COGEN POWER	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVEL CHRGR	NORM WRTH ENRG		
ONOCGN	28651	0.	11.	401.	0.	0.	0.	F	4.	0.	1.73	0.03	0.	29.1	1.00	165.7	0	12.3	1.00	80
STM141	28651	0.	382.	0.	0.	-372.	401.		4.	4.	1.17	0.03	0.07	20.1	0.69	111.0	-18	14.3	1.17	153
STM141	28651	0.	511.	0.	0.	-422.	664.		4.	36.	1.09	0.03	0.32	22.0	0.76	100.7	-5	12.3	1.00	131
STM141	28651	0.	0.	382.	0.	11.	18.	F	4.	4.	2.31	0.03	0.07	35.6	1.22	196.7	1	12.5	1.02	135
STM141	28651	0.	0.	511.	0.	89.	153.	F	4.	36.	2.29	0.03	0.32	40.1	1.38	183.2	21	9.3	0.76	109
STM141	28651	0.	0.	382.	0.	11.	18.	A	4.	4.	2.22	0.03	0.07	33.9	1.16	187.5	5	12.3	1.00	135
STM141	28651	0.	0.	511.	0.	89.	153.	A	4.	36.	2.22	0.03	0.32	34.0	1.17	155.3	44	8.6	0.70	112
STM088	28651	0.	382.	0.	0.	-372.	401.		4.	4.	1.18	0.03	0.07	19.9	0.68	109.9	-18	14.3	1.16	153
STM088	28651	0.	475.	0.	0.	-408.	591.		4.	28.	1.03	0.03	0.28	20.0	0.69	95.9	-7	12.6	1.03	133
STM088	28651	0.	0.	382.	0.	11.	18.	F	4.	4.	2.33	0.03	0.07	35.8	1.23	197.8	1	12.6	1.02	134
STM088	28651	0.	0.	475.	0.	68.	116.	F	4.	28.	2.15	0.03	0.28	37.3	1.28	179.3	22	9.9	0.80	111
STM088	28651	0.	0.	382.	0.	11.	18.	A	4.	4.	2.25	0.03	0.07	34.0	1.17	187.6	5	12.3	1.00	135
STM088	28651	0.	0.	475.	0.	68.	116.	A	4.	28.	2.15	0.03	0.28	32.7	1.12	157.0	45	9.4	0.76	113
PFBSTM	28651	0.	0.	383.	0.	11.	18.		4.	4.	2.28	0.03	0.07	34.4	1.18	189.8	3	12.4	1.01	135
PFBSTM	28651	0.	0.	595.	0.	137.	230.		4.	56.	3.66	0.03	0.38	47.3	1.62	194.2	15	9.3	0.75	111
TISTMT	28651	0.	383.	0.	0.	-372.	401.		4.	4.	1.36	0.03	0.07	28.7	0.99	158.5	999	15.5	1.26	146
TISTMT	28651	0.	549.	0.	0.	-439.	732.		4.	45.	3.00	0.03	0.35	37.3	3.00	379.8	0	20.8	1.69	120
TISTMT	28651	0.	0.	383.	0.	11.	18.		4.	4.	2.46	0.03	0.07	43.9	1.51	242.5	0	13.6	1.11	132
TISTMT	28651	0.	0.	668.	0.	181.	302.		4.	74.	5.16	0.03	0.42	150.8	5.18	569.9	0	20.0	1.62	119
TIHRSG	28651	0.	389.	0.	0.	-378.	401.		4.	4.	1.50	0.03	0.06	36.2	1.24	197.8	0	16.5	1.34	140
TIHRSG	28651	0.	470.	0.	0.	-422.	524.		4.	19.	2.51	0.03	0.18	74.2	2.55	359.2	0	21.1	1.72	115
TIHRSG	28651	0.	0.	389.	0.	11.	12.		4.	4.	2.66	0.03	0.06	53.2	1.83	291.2	0	14.9	1.21	129
TIHRSG	28651	0.	0.	537.	0.	78.	89.		4.	32.	4.36	0.03	0.24	128.6	4.42	568.2	0	22.2	1.81	107
STIRL	28651	391.	0.	0.	-391.	11.	401.		4.	4.	1.16	0.03	0.05	22.8	0.78	124.2	-42	17.3	1.41	153
STIRL	28651	664.	0.	0.	-664.	125.	784.		4.	51.	1.84	0.03	0.27	42.4	1.46	160.8	0	21.2	1.72	124
STIRL	28651	0.	391.	0.	0.	-380.	401.		4.	4.	1.16	0.03	0.05	22.8	0.78	124.2	-25	14.8	1.20	148
STIRL	28651	0.	664.	0.	0.	-539.	784.		4.	51.	1.84	0.03	0.27	42.4	1.46	160.9	0	16.9	1.37	115
STIRL	28651	0.	0.	391.	0.	11.	10.		4.	4.	2.23	0.03	0.05	36.7	1.26	200.3	0	12.6	1.03	131
STIRL	28651	0.	0.	858.	0.	206.	197.		4.	84.	4.04	0.03	0.32	100.6	3.45	314.1	2	14.4	1.17	100
HEGT85	28651	0.	0.	401.	0.	11.	-0.	A	4.	4.	2.21	0.03	0.03	40.0	1.37	214.4	0	13.2	1.08	127
HEGT85	28651	0.	0.	2527.	0.	637.	-29.	A	4.	260.	9.72	0.03	0.19	256.2	8.80	316.5	0	33.0	2.68	113
HEGT60	28651	0.	0.	400.	0.	11.	1.	A	4.	4.	2.21	0.03	0.03	39.7	1.36	213.0	0	13.2	1.07	128
HEGT60	28651	0.	0.	1305.	0.	287.	20.	A	4.	117.	5.63	0.03	0.19	144.0	4.94	319.1	0	22.5	1.83	96
HEGT00	28651	0.	0.	400.	0.	11.	1.	A	4.	4.	2.23	0.03	0.03	39.3	1.35	211.2	0	13.2	1.07	128
HEGT00	28651	0.	0.	785.	0.	129.	12.	A	4.	53.	3.60	0.03	0.15	85.2	2.93	284.9	0	17.1	1.39	87
FCMCCL	28651	0.	0.	622.	0.	11.	-221.		4.	4.	2.38	0.03	-0.51	43.2	1.48	237.1	0	17.5	1.43	68
FCMCCL	28651	0.	0.	1075.	0.	235.	76.		4.	96.	5.78	0.03	0.22	104.2	3.58	330.8	0	18.6	1.51	96
FCSTCL	28651	0.	0.	621.	0.	11.	-220.		4.	4.	2.40	0.03	-0.51	42.4	1.45	232.9	0	17.5	1.42	68
FCSTCL	28651	0.	0.	1332.	0.	380.	303.		4.	155.	7.23	0.03	0.34	129.9	4.46	332.7	1	16.4	1.33	103
IGGTST	28651	0.	0.	626.	0.	11.	-225.		4.	4.	2.35	0.03	-0.52	40.6	1.39	221.2	0	17.3	1.41	67
IGGTST	28651	0.	0.	1242.	0.	267.	18.		4.	109.	3.46	0.03	0.19	101.1	3.47	277.7	0	16.3	1.33	87
GTSOAR	28651	0.	390.	0.	0.	-379.	401.		4.	4.	1.09	0.03	0.05	21.3	0.73	116.1	-20	14.5	1.18	150
GTSOAR	28651	0.	709.	0.	0.	-561.	859.		4.	60.	1.51	0.03	0.30	32.0	1.10	115.6	0	15.1	1.22	121

HONEYWELL PAGE PRINTING SYSTEM - P1185-02

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----

ECS	PROCS	**COGENERATION CASE**				**NOCOGEN - COGEN**				POWER RECD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM ENRG	WRTH
		DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	COAL	COAL												
GTAC08	28651	0.	387.	0.	0.	-376.	401.	4.	4.	1.08	0.03	0.05	20.7	0.71	113.8	-19	14.4	1.17	151		
GTAC08	28651	0.	605.	0.	0.	-487.	757.	4.	48.	1.35	0.03	0.31	26.6	0.91	108.2	-27	13.6	1.11	125		
GTAC12	28651	0.	387.	0.	0.	-376.	401.	4.	4.	1.07	0.03	0.06	20.7	0.71	113.5	-18	14.4	1.17	151		
GTAC12	28651	0.	664.	0.	0.	-519.	852.	4.	59.	1.45	0.03	0.33	30.4	1.04	115.3	0	13.7	1.12	124		
GTAC16	28651	0.	387.	0.	0.	-376.	401.	4.	4.	1.07	0.03	0.06	20.8	0.72	114.2	-19	14.4	1.17	151		
GTAC16	28651	0.	707.	0.	0.	-543.	914.	4.	67.	1.55	0.03	0.34	33.7	1.16	122.1	0	14.0	1.14	123		
GTWC16	28651	0.	390.	0.	0.	-379.	401.	4.	4.	1.08	0.03	0.05	21.1	0.72	115.3	-20	14.5	1.18	150		
GTWC16	28651	0.	767.	0.	0.	-593.	946.	4.	71.	1.55	0.03	0.32	33.0	1.13	112.5	0	15.0	1.22	122		
CC1626	28651	0.	390.	0.	0.	-379.	401.	4.	4.	1.14	0.03	0.05	20.9	0.72	113.9	-21	14.6	1.19	150		
CC1626	28651	0.	1035.	0.	0.	-747.	1332.	4.	118.	2.00	0.03	0.36	43.3	1.49	116.3	0	15.7	1.28	123		
CC1622	28651	0.	389.	0.	0.	-378.	401.	4.	4.	1.14	0.03	0.06	20.6	0.71	112.8	-20	14.5	1.18	151		
CC1622	28651	0.	944.	0.	0.	-683.	1236.	4.	106.	1.96	0.03	0.37	43.3	1.49	125.3	0	15.2	1.24	123		
CC1222	28651	0.	388.	0.	0.	-378.	401.	4.	4.	1.13	0.03	0.06	20.5	0.70	112.0	-20	14.5	1.18	151		
CC1222	28651	0.	936.	0.	0.	-677.	1233.	4.	106.	1.93	0.03	0.37	41.3	1.42	120.3	0	14.8	1.20	123		
CC0822	28651	0.	387.	0.	0.	-376.	401.	4.	4.	1.14	0.03	0.06	20.7	0.71	113.3	-20	14.5	1.18	151		
CC0822	28651	0.	791.	0.	0.	-584.	1060.	4.	85.	1.75	0.03	0.38	35.3	1.21	117.5	0	13.7	1.11	125		
STIG15	28651	0.	404.	0.	0.	-393.	401.	4.	4.	1.10	0.03	0.02	20.8	0.71	110.9	-21	14.9	1.21	147		
STIG15	28651	0.	23846.	0.	0.	-17316.	22226.	4.	2663.	39.42	0.03	0.17	662.2	22.73	93.8	0	309.6	25.17	668		
STIG10	28651	0.	400.	0.	0.	-389.	401.	4.	4.	1.09	0.03	0.03	20.6	0.71	110.4	-20	14.8	1.20	148		
STIG10	28651	0.	2340.	0.	0.	-1736.	2386.	4.	246.	4.22	0.03	0.22	79.0	2.71	104.6	0	35.7	2.90	134		
STIG15	28651	0.	398.	0.	0.	-388.	401.	4.	4.	1.09	0.03	0.03	20.5	0.70	110.3	-20	14.7	1.19	148		
STIG15	28651	0.	1471.	0.	0.	-1116.	1551.	4.	144.	2.92	0.03	0.23	50.6	1.74	101.1	0	25.0	2.03	122		
DEADV3	28651	0.	394.	0.	0.	-384.	401.	4.	4.	1.19	0.03	0.04	24.7	0.85	134.1	-34	15.1	1.23	145		
DEADV3	28651	0.	1381.	0.	0.	-1013.	1598.	4.	150.	3.56	0.03	0.30	105.4	3.62	222.5	0	27.8	2.26	124		
DEHTPM	28651	0.	386.	0.	0.	-375.	401.	4.	4.	1.23	0.03	0.06	24.8	0.85	136.3	-33	14.9	1.22	147		
DEHTPM	28651	0.	719.	0.	0.	-541.	959.	4.	72.	2.38	0.03	0.37	60.1	2.06	215.0	0	17.0	1.38	119		
DESQA3	28651	397.	0.	0.	0.	-397.	11.	4.	4.	1.17	0.03	0.04	23.9	0.82	128.8	-50	17.7	1.44	151		
DESQA3	28651	1628.	0.	0.	0.	-1628.	422.	4.	172.	4.63	0.03	0.26	146.5	5.03	268.2	0	46.8	3.80	154		
DESQA3	28651	0.	397.	0.	0.	-386.	401.	4.	4.	1.17	0.03	0.04	23.9	0.82	128.8	-30	15.1	1.23	145		
DESQA3	28651	0.	1628.	0.	0.	-1205.	1779.	4.	172.	4.63	0.03	0.26	146.5	5.03	268.2	0	36.3	2.95	132		
GTSQAD	28651	388.	0.	0.	0.	-388.	11.	4.	4.	1.07	0.03	0.06	20.5	0.70	112.3	-31	16.9	1.37	156		
GTSQAD	28651	666.	0.	0.	0.	-666.	140.	4.	57.	1.39	0.03	0.32	27.5	0.94	104.0	119	18.1	1.47	133		
GTRA08	28651	389.	0.	0.	0.	-389.	11.	4.	4.	1.08	0.03	0.05	21.4	0.74	117.0	-35	17.1	1.39	155		
GTRA08	28651	875.	0.	0.	0.	-875.	224.	4.	92.	1.12	0.03	0.35	43.1	1.48	132.6	0	21.3	1.73	132		
GTRA12	28651	389.	0.	0.	0.	-389.	11.	4.	4.	1.08	0.03	0.06	21.3	0.73	116.7	-34	17.0	1.38	155		
GTRA12	28651	857.	0.	0.	0.	-857.	221.	4.	90.	1.08	0.03	0.35	41.6	1.43	129.9	0	20.8	1.69	133		
GTRA16	28651	389.	0.	0.	0.	-389.	11.	4.	4.	1.09	0.03	0.06	21.5	0.74	117.8	-35	17.1	1.39	155		
GTRA16	28651	825.	0.	0.	0.	-825.	207.	4.	84.	1.78	0.03	0.35	41.9	1.44	134.9	0	20.7	1.68	132		
GTR208	28651	389.	0.	0.	0.	-389.	11.	4.	4.	1.08	0.03	0.06	21.1	0.72	115.4	-34	17.0	1.38	155		
GTR208	28651	751.	0.	0.	0.	-751.	173.	4.	70.	1.58	0.03	0.33	34.2	1.17	118.4	0	19.6	1.59	132		
GTR212	28651	389.	0.	0.	0.	-389.	11.	4.	4.	1.08	0.03	0.06	21.2	0.73	116.1	-34	17.0	1.38	155		
GTR212	28651	781.	0.	0.	0.	-781.	185.	4.	76.	1.64	0.03	0.33	36.5	1.25	122.4	0	20.0	1.63	132		
GTR216	28651	389.	0.	0.	0.	-389.	11.	4.	4.	1.08	0.03	0.06	21.3	0.73	116.6	-34	17.0	1.38	155		
GTR216	28651	783.	0.	0.	0.	-783.	190.	4.	77.	1.69	0.03	0.34	38.6	1.32	129.3	0	20.0	1.63	132		

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																			
**COGENERATION CASE** **NOCOGEN - COGEN**																			
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD MW	COGEN POWER MW	G&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM WRTH ENRG	
GTRW08	28651	393.	0.	0.	-393.	11.	401.	4.	4.	1.09	0.03	0.05	21.5	0.74	116.7	-36	17.2	1.40	154
GTRW08	28651	1066.	0.	0.	-1066.	269.	1265.	4.	110.	1.86	0.03	0.31	43.1	1.48	113.1	0	24.8	2.01	134
GTRW12	28651	392.	0.	0.	-392.	11.	401.	4.	4.	1.08	0.03	0.05	21.5	0.74	116.9	-35	17.1	1.39	154
GTRW12	28651	1052.	0.	0.	-1052.	275.	1286.	4.	112.	1.86	0.03	0.33	43.6	1.50	115.5	0	23.8	1.94	135
GTRW16	28651	391.	0.	0.	-391.	11.	401.	4.	4.	1.09	0.03	0.05	21.6	0.74	117.9	-36	17.2	1.39	154
GTRW16	28651	1000.	0.	0.	-1000.	257.	1224.	4.	105.	1.85	0.03	0.32	43.3	1.49	119.7	0	23.4	1.90	134
GTR308	28651	394.	0.	0.	-394.	11.	401.	4.	4.	1.08	0.03	0.04	21.2	0.73	114.7	-35	17.2	1.40	154
GTR308	28651	921.	0.	0.	-921.	205.	1052.	4.	84.	1.67	0.03	0.27	36.5	1.25	107.9	0	23.5	1.91	131
GTR312	28651	391.	0.	0.	-391.	11.	401.	4.	4.	1.08	0.03	0.05	21.2	0.73	115.7	-35	17.1	1.39	154
GTR312	28651	918.	0.	0.	-918.	226.	1120.	4.	92.	1.70	0.03	0.32	37.9	1.30	112.2	0	22.1	1.79	133
GTR316	28651	391.	0.	0.	-391.	11.	401.	4.	4.	1.09	0.03	0.05	21.4	0.74	116.8	-35	17.1	1.39	154
GTR316	28651	913.	0.	0.	-913.	222.	1109.	4.	91.	1.72	0.03	0.31	38.9	1.34	115.7	0	22.2	1.81	133
FCPADS	28651	396.	0.	0.	-396.	11.	401.	4.	4.	1.43	0.03	0.04	23.0	0.79	124.3	-46	17.8	1.45	152
FCPADS	28651	1824.	0.	0.	-1824.	498.	2032.	4.	203.	21.50	0.03	0.28	124.1	4.26	205.6	0	62.6	5.09	190
FCMCDS	28651	391.	0.	0.	-391.	11.	401.	4.	4.	1.41	0.03	0.05	23.2	0.80	126.4	-46	17.6	1.43	153
FCMCDS	28651	1330.	0.	0.	-1330.	394.	1684.	4.	161.	16.24	0.03	0.36	107.5	3.69	234.2	0	45.9	3.73	168

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	COGEN**	POWER	COGEN	Q&M	POWER	FESR	CAPITAL	NORM	COST	EQVL	\$/KW	ROI	LEVEL	CHRG	WRTH	NORM	ENRNG
								MW	REQD	MW		RATIO	%	*10**6					(%)					
ONGCGN	28653	0.	15.	402.	0.	0.	0.	6.	6.	0.	1.27	0.07	0.	20.5	1.00	198.5	0	198.5	0	11.5	1.00	80		
STM141	28653	0.	377.	0.	0.	-362.	402.	6.	6.	0.	0.94	0.07	0.10	12.4	0.60	112.0	-19	112.0	-19	13.5	13.5	1.18	160	
STM141	28653	0.	407.	0.	0.	-374.	463.	6.	13.	13.	0.75	0.07	0.18	12.0	0.58	100.7	-14	100.7	-14	12.8	12.8	1.11	151	
STM141	28653	0.	0.	377.	0.	0.	25.	6.	6.	6.	1.92	0.07	0.10	28.0	1.36	253.0	5	253.0	5	11.5	11.5	1.00	135	
STM141	28653	0.	0.	407.	0.	33.	56.	6.	13.	13.	1.58	0.07	0.18	25.3	1.23	212.7	23	212.7	23	10.0	10.0	0.87	126	
STM141	28653	0.	0.	377.	0.	15.	25.	6.	6.	6.	1.80	0.07	0.10	24.5	1.20	222.1	13	222.1	13	11.0	11.0	0.96	137	
STM141	28653	0.	0.	407.	0.	33.	56.	6.	13.	13.	1.41	0.07	0.18	18.2	0.89	152.9	999	152.9	999	9.0	9.0	0.79	132	
STM088	28653	0.	377.	0.	0.	-362.	402.	6.	6.	6.	0.92	0.07	0.10	11.6	0.58	107.1	-18	107.1	-18	13.5	13.5	1.17	161	
STM088	28653	0.	388.	0.	0.	-367.	424.	6.	9.	9.	0.71	0.07	0.13	10.7	0.52	95.7	-14	95.7	-14	12.9	12.9	1.12	155	
STM088	28653	0.	0.	377.	0.	15.	25.	6.	6.	6.	1.87	0.07	0.10	27.1	1.32	245.3	7	245.3	7	11.3	11.3	0.99	135	
STM088	28653	0.	0.	388.	0.	21.	37.	6.	9.	9.	1.48	0.07	0.13	23.3	1.14	205.3	29	205.3	29	10.2	10.2	0.89	128	
STM088	28653	0.	0.	377.	0.	15.	25.	6.	6.	6.	1.76	0.07	0.10	22.7	1.11	205.3	24	205.3	24	10.3	10.3	0.93	138	
STM088	28653	0.	0.	388.	0.	21.	37.	6.	9.	9.	1.36	0.07	0.13	17.1	0.83	150.3	399	150.3	399	9.4	9.4	0.82	134	
PFB3TM	28653	0.	0.	378.	0.	15.	24.	6.	6.	6.	1.99	0.07	0.09	28.1	1.37	253.1	4	253.1	4	11.6	11.6	1.01	134	
PFB3TM	28653	0.	0.	456.	0.	60.	97.	6.	24.	24.	2.37	0.07	0.26	30.8	1.50	230.5	13	230.5	13	10.1	10.1	0.88	117	
TI1TSG	28653	0.	378.	0.	0.	-363.	402.	6.	6.	6.	1.27	0.07	0.09	26.7	1.30	241.2	0	241.2	0	15.4	15.4	1.34	144	
TI1TMT	28653	0.	492.	0.	0.	-409.	628.	6.	34.	34.	2.37	0.07	0.31	74.9	3.65	519.6	0	519.6	0	19.9	19.9	1.73	121	
TI1TMT	28653	0.	0.	378.	0.	15.	24.	6.	6.	6.	2.24	0.07	0.09	42.9	2.09	387.8	0	387.8	0	13.4	13.4	1.17	130	
TI1TMT	28653	0.	0.	492.	0.	82.	137.	6.	34.	34.	3.39	0.07	0.31	95.0	4.63	659.4	0	659.4	0	17.0	17.0	1.47	112	
TI1HRSG	28653	0.	396.	0.	0.	-381.	402.	6.	6.	6.	1.39	0.07	0.05	34.1	1.66	294.2	0	294.2	0	16.8	16.8	1.46	136	
TI1HRSG	28653	0.	502.	0.	0.	-451.	523.	6.	21.	21.	2.42	0.07	0.13	72.8	3.55	494.9	0	494.9	0	22.1	22.1	1.92	115	
TI1HRSG	28653	0.	0.	396.	0.	15.	24.	6.	6.	6.	2.42	0.07	0.05	52.0	2.53	447.9	0	447.9	0	14.9	14.9	1.30	124	
TI1HRSG	28653	0.	0.	502.	0.	51.	21.	6.	21.	21.	3.23	0.07	0.13	93.2	4.54	634.0	0	634.0	0	19.2	19.2	1.67	106	
ST1RL	28653	390.	0.	0.	-390.	15.	402.	6.	6.	6.	0.92	0.07	0.06	14.2	0.69	124.4	-44	124.4	-44	16.7	16.7	1.45	159	
ST1RL	28653	589.	0.	0.	-589.	93.	663.	6.	38.	38.	1.25	0.07	0.22	31.3	1.53	181.4	0	181.4	0	20.1	20.1	1.74	123	
ST1RL	28653	0.	390.	0.	0.	-376.	402.	6.	6.	6.	0.92	0.07	0.06	14.2	0.69	124.5	-26	124.5	-26	14.1	14.1	1.22	153	
ST1RL	28653	0.	589.	0.	0.	-496.	663.	6.	38.	38.	1.25	0.07	0.22	31.4	1.53	161.7	0	161.7	0	16.1	16.1	1.40	115	
ST1RL	28653	0.	0.	390.	0.	15.	12.	6.	6.	6.	1.63	0.07	0.06	28.5	1.39	249.5	4	249.5	4	11.6	11.6	1.01	130	
ST1RL	28653	0.	0.	589.	0.	93.	74.	6.	38.	38.	2.43	0.07	0.22	54.7	2.66	316.7	2	316.7	2	12.4	12.4	1.08	96	
HEGT60	28653	0.	0.	418.	0.	15.	-16.	6.	6.	6.	1.92	0.07	-0.00	35.7	1.74	291.5	0	291.5	0	13.0	13.0	1.13	120	
HEGT60	28653	0.	0.	1939.	0.	372.	-400.	6.	152.	152.	6.92	0.07	-0.01	173.2	8.44	295.6	0	295.6	0	32.7	32.7	2.84	91	
HEGT00	28653	0.	0.	406.	0.	15.	-4.	6.	6.	6.	1.90	0.07	0.03	34.5	1.68	290.4	0	290.4	0	12.7	12.7	1.10	124	
HEGT00	28653	0.	0.	648.	0.	82.	-21.	6.	33.	33.	2.61	0.07	0.09	61.8	3.01	325.4	0	325.4	0	15.3	15.3	1.33	86	
FCMCL	28653	0.	0.	383.	0.	15.	19.	6.	6.	6.	2.00	0.07	0.08	35.2	1.72	313.7	0	313.7	0	12.5	12.5	1.09	130	
FCMCL	28653	0.	0.	638.	0.	139.	182.	6.	57.	57.	3.87	0.07	0.33	71.3	3.47	381.5	2	381.5	2	13.2	13.2	1.15	103	
FCSTCL	28653	0.	0.	382.	0.	15.	21.	6.	6.	6.	2.03	0.07	0.08	34.6	1.69	309.3	0	309.3	0	12.5	12.5	1.08	131	
FCSTCL	28653	0.	0.	727.	0.	191.	267.	6.	78.	78.	4.52	0.07	0.39	82.3	4.01	386.3	3	386.3	3	12.6	12.6	1.09	105	
1GGTST	28653	0.	0.	390.	0.	15.	13.	6.	6.	6.	1.98	0.07	0.07	34.1	1.66	298.6	0	298.6	0	12.5	12.5	1.09	129	
1GGTST	28653	0.	0.	677.	0.	130.	111.	6.	53.	53.	2.38	0.07	0.26	63.9	3.11	322.0	3	322.0	3	12.3	12.3	1.07	94	
GTSQAR	28653	0.	392.	0.	0.	-377.	402.	6.	6.	6.	0.87	0.07	0.06	14.3	0.70	124.6	-26	124.6	-26	14.1	14.1	1.22	153	
GTSQAR	28653	0.	784.	0.	0.	-621.	900.	6.	67.	67.	1.12	0.07	0.26	27.6	1.34	120.0	0	120.0	0	15.9	15.9	1.39	116	
GTAC08	28653	0.	383.	0.	0.	-368.	402.	6.	6.	6.	0.85	0.07	0.08	13.7	0.67	122.5	-22	122.5	-22	13.7	13.7	1.19	156	
GTAC08	28653	0.	582.	0.	0.	-469.	731.	6.	46.	46.	0.89	0.07	0.31	20.0	0.97	117.2	-62	117.2	-62	12.6	12.6	1.11	126	

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----  
\*\*COGENERATION CASE\*\* \*\*NO COGEN - COGEN\*\*

ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD MW	COGEN POWER MW	Ø2M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM ENRG	WRTH
GTAC12	28653	0.	383.	0.	0.	-369.	402.	6.	6.	0.85	0.07	0.08	13.7	0.67	122.1	-22	13.7	1.19	156
GTAC12	28653	0.	647.	0.	0.	-505.	828.	6.	58.	1.00	0.07	0.33	23.8	1.16	125.6	0	13.0	1.13	123
GTAC16	28653	0.	385.	0.	0.	-370.	402.	6.	6.	0.85	0.07	0.08	13.9	0.68	123.2	-23	13.8	1.20	155
GTAC16	28653	0.	713.	0.	0.	-548.	907.	6.	68.	1.11	0.07	0.34	27.7	1.35	132.6	0	13.7	1.19	120
GTWC16	28653	0.	387.	0.	0.	-372.	402.	6.	6.	0.86	0.07	0.07	14.2	0.69	125.1	-25	13.9	1.21	154
GTWC16	28653	0.	740.	0.	0.	-572.	914.	6.	68.	1.08	0.07	0.32	26.3	1.28	121.3	0	14.1	1.23	120
CC1626	28653	0.	388.	0.	0.	-373.	402.	6.	6.	0.93	0.07	0.07	14.0	0.68	122.9	-26	14.0	1.22	154
CC1626	28653	0.	928.	0.	0.	-685.	1167.	6.	99.	1.43	0.07	0.34	33.4	1.63	122.9	0	15.1	1.31	119
CC1622	28653	0.	886.	0.	0.	-372.	402.	6.	6.	0.92	0.07	0.07	13.7	0.67	121.2	-25	13.9	1.21	155
CC1622	28653	0.	847.	0.	0.	-629.	1083.	6.	89.	1.39	0.07	0.35	33.2	1.62	133.7	0	14.5	1.26	119
CC1222	28653	0.	386.	0.	0.	-371.	402.	6.	6.	0.92	0.07	0.07	13.5	0.66	119.5	-24	13.9	1.21	156
CC1222	28653	0.	839.	0.	0.	-623.	1078.	6.	88.	1.36	0.07	0.35	31.4	1.53	127.7	0	14.2	1.24	120
CC0822	28653	0.	384.	0.	0.	-369.	402.	6.	6.	0.93	0.07	0.08	13.7	0.67	122.0	-24	13.9	1.20	156
CC0822	28653	0.	709.	0.	0.	-539.	923.	6.	69.	1.20	0.07	0.35	26.0	1.27	125.2	0	13.2	1.14	122
DEHTP1	28653	0.	390.	0.	0.	-375.	402.	6.	6.	1.04	0.07	0.06	18.1	0.88	158.3	-57	14.6	1.27	148
DEHTP1	28653	0.	695.	0.	0.	-559.	838.	6.	55.	1.89	0.07	0.26	52.6	2.56	258.3	0	18.8	1.64	111
GTSOAD	28653	386.	0.	0.	-386.	15.	402.	6.	6.	0.84	0.07	0.07	13.5	0.66	119.1	-39	16.4	1.42	161
GTSOAD	28653	662.	0.	0.	-662.	139.	818.	6.	57.	0.93	0.07	0.31	21.2	1.03	109.4	0	17.8	1.55	133
GTRA08	28653	392.	0.	0.	-392.	15.	402.	6.	6.	0.86	0.07	0.06	14.4	0.70	125.7	-45	16.7	1.45	158
GTRA08	28653	1094.	0.	0.	-1094.	281.	1293.	6.	115.	1.55	0.07	0.30	42.8	2.09	133.5	0	25.5	2.22	132
GTRA12	28653	390.	0.	0.	-390.	15.	402.	6.	6.	0.86	0.07	0.06	14.4	0.70	125.9	-45	16.7	1.45	159
GTRA12	28653	1018.	0.	0.	-1018.	262.	1230.	6.	107.	1.47	0.07	0.32	40.0	1.95	134.1	0	23.8	2.07	132
GTRA16	28653	390.	0.	0.	-390.	15.	402.	6.	6.	0.87	0.07	0.07	14.7	0.71	128.5	-46	16.7	1.45	158
GTRA16	28653	943.	0.	0.	-943.	236.	1144.	6.	96.	1.44	0.07	0.32	39.3	1.91	142.2	0	22.9	1.99	130
GTR208	28653	389.	0.	0.	-389.	15.	402.	6.	6.	0.86	0.07	0.07	14.1	0.69	123.9	-43	16.6	1.44	159
GTR208	28653	811.	0.	0.	-811.	186.	977.	6.	76.	1.17	0.07	0.30	29.6	1.44	124.5	0	20.7	1.80	130
GTR212	28653	389.	0.	0.	-389.	15.	402.	6.	6.	0.86	0.07	0.07	14.3	0.70	125.3	-44	16.6	1.44	159
GTR212	28653	845.	0.	0.	-845.	200.	1024.	6.	82.	1.24	0.07	0.31	32.0	1.56	129.2	0	21.2	1.84	130
GTR216	28653	389.	0.	0.	-389.	15.	402.	6.	6.	0.86	0.07	0.07	14.4	0.70	126.5	-44	16.6	1.44	159
GTR216	28653	853.	0.	0.	-853.	207.	1045.	6.	84.	1.30	0.07	0.32	34.4	1.68	137.8	0	21.3	1.85	129
GTRW08	28653	395.	0.	0.	-395.	15.	402.	6.	6.	0.86	0.07	0.05	14.5	0.71	125.3	-47	16.9	1.47	157
GTRW08	28653	1294.	0.	0.	-1294.	326.	1446.	6.	133.	1.57	0.07	0.27	42.1	2.05	111.0	0	29.3	2.54	136
GTRW12	28653	393.	0.	0.	-393.	15.	402.	6.	6.	0.86	0.07	0.06	14.5	0.71	126.1	-46	16.8	1.46	158
GTRW12	28653	1218.	0.	0.	-1218.	319.	1419.	6.	130.	1.54	0.07	0.30	41.3	2.01	115.7	0	27.0	2.34	135
GTRW16	28653	392.	0.	0.	-392.	15.	402.	6.	6.	0.87	0.07	0.06	14.7	0.72	128.3	-47	16.8	1.46	158
GTRW16	28653	1108.	0.	0.	-1108.	284.	1305.	6.	116.	1.48	0.07	0.30	39.8	1.94	122.7	0	25.4	2.21	133
GTR308	28653	397.	0.	0.	-397.	15.	402.	6.	6.	0.86	0.07	0.05	14.2	0.69	122.0	-45	16.9	1.47	157
GTR308	28653	1077.	0.	0.	-1077.	240.	1156.	6.	98.	1.32	0.07	0.23	33.7	1.64	106.7	0	26.9	2.34	131
GTR312	28653	391.	0.	0.	-391.	15.	402.	6.	6.	0.86	0.07	0.06	14.3	0.70	124.7	-44	16.6	1.45	159
GTR312	28653	951.	0.	0.	-951.	234.	1136.	6.	95.	1.28	0.07	0.31	32.6	1.59	116.9	0	22.6	1.96	132
GTR316	28653	391.	0.	0.	-391.	15.	402.	6.	6.	0.86	0.07	0.06	14.5	0.71	126.7	-45	16.7	1.45	158
GTR316	28653	942.	0.	0.	-942.	230.	1122.	6.	94.	1.30	0.07	0.30	33.5	1.63	121.4	0	22.7	1.97	131
FCPADS	28653	396.	0.	0.	-396.	15.	402.	6.	6.	1.35	0.07	0.05	15.3	0.74	131.7	-57	17.4	1.52	157
FCPADS	28653	1765.	0.	0.	-1765.	482.	1967.	6.	197.	21.02	0.07	0.28	113.7	5.54	219.9	0	61.5	5.34	194

GENERAL ELECTRIC COMPANY  
 COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
 REPORT 5.2  
 SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

DATE 06/07/79  
 I&SE-PEO-ADV-DES-ENGR

	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	COGEN	REGD	POWER	MM	O&M	POWER	FESR	RATIO	/HEAT	CAPITAL	COST	NORM	\$/KW	ROI	LEVEL	NORM	WRTH	
ECs	20653	389.	0.	0.	-389.	15.	402.	6.	6.	155.	155.	1.31	0.07	0.07	0.07	0.07	15.6	0.76	0.76	136.4	-57	17.2	1.49	158	
FCMCDS	20653	1288.	0.	0.	-1288.	381.	1629.	6.	6.	155.	155.	15.76	0.07	0.07	0.07	0.07	97.8	4.77	4.77	259.3	0	44.9	3.90	169	

-----FUEL USE IN BTU\*10\*\*6-----  
 \*\*COGENERATION CASE\*\* \*NO\*COGEN - COGEN\*\*  
 \*\*COGENERATION CASE\*\* \*NO\*COGEN - COGEN\*\*



GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----

ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVEL CHRG	NORM ENRG	WRTH	
ONOCGN	28654	0.	2.	265.	0.	0.	0.	F	1.	0.	1.07	0.01	0.	16.7	1.00	220.8	0	7.4	1.00	80
STM141	28654	0.	262.	0.	0.	-260.	265.		1.	1.	0.72	0.01	0.02	8.4	0.50	109.0	-17	9.1	1.23	157
STM141	28654	0.	278.	0.	0.	-266.	293.		1.	5.	0.62	0.01	0.10	8.6	0.51	105.5	-15	8.8	1.19	121
STM141	28654	0.	0.	262.	0.	2.	3.	F	1.	1.	1.46	0.01	0.02	19.8	1.18	257.9	0	8.0	1.07	130
STM141	28654	0.	0.	278.	0.	12.	20.	F	1.	5.	1.24	0.01	0.10	18.6	1.11	228.6	14	7.1	0.97	95
STM141	28654	0.	0.	262.	0.	2.	3.	A	1.	1.	1.40	0.01	0.02	19.1	1.14	249.5	0	7.8	1.06	130
STM141	28654	0.	0.	278.	0.	12.	20.	A	1.	5.	1.10	0.01	0.10	13.6	0.81	166.4	999	6.5	0.87	101
PFBSTM	28654	0.	0.	262.	0.	2.	3.		1.	1.	1.35	0.01	0.02	18.8	1.12	244.7	0	7.8	1.05	130
PFBSTM	28654	0.	0.	314.	0.	31.	48.		1.	13.	1.77	0.01	0.20	23.2	1.39	252.6	5	7.4	0.99	97
TISTMT	28654	0.	262.	0.	0.	-260.	265.		1.	1.	0.72	0.01	0.02	10.4	0.62	135.1	-22	9.4	1.26	152
TISTMT	28654	0.	336.	0.	0.	-291.	411.		1.	19.	1.83	0.01	0.26	55.5	3.31	563.5	0	14.2	1.92	112
TISTMT	28654	0.	0.	262.	0.	2.	3.		1.	1.	1.41	0.01	0.02	21.2	1.26	276.0	0	8.1	1.09	129
TISTMT	28654	0.	0.	336.	0.	45.	75.		1.	19.	2.60	0.01	0.26	70.8	4.23	718.9	0	12.6	1.70	104
TIHRSG	28654	0.	264.	0.	0.	-262.	265.		1.	1.	0.69	0.01	0.01	11.3	0.67	146.0	-25	9.5	1.28	149
TIHRSG	28654	0.	368.	0.	0.	-331.	383.		1.	15.	1.77	0.01	0.13	57.7	3.45	535.0	0	15.8	2.13	100
TIHRSG	28654	0.	0.	264.	0.	2.	1.		1.	1.	1.38	0.01	0.01	22.4	1.34	289.4	0	8.2	1.11	127
TIHRSG	28654	0.	0.	368.	0.	37.	15.		1.	15.	2.60	0.01	0.13	74.0	4.42	686.5	0	14.1	1.90	91
STIRL	28654	263.	0.	0.	-263.	2.	265.		1.	1.	0.64	0.01	0.01	9.0	0.54	116.8	-28	10.9	1.47	160
STIRL	28654	432.	0.	0.	-432.	68.	486.		1.	28.	1.00	0.01	0.22	23.2	1.39	183.7	0	13.7	1.85	121
STIRL	28654	0.	263.	0.	0.	-261.	265.		1.	1.	0.64	0.01	0.01	9.0	0.54	116.8	-18	9.2	1.24	154
STIRL	28654	0.	432.	0.	0.	-364.	486.		1.	28.	1.00	0.01	0.22	23.3	1.39	184.0	0	10.9	1.48	112
STIRL	28654	0.	0.	263.	0.	2.	1.		1.	1.	1.30	0.01	0.01	19.4	1.16	252.0	0	7.7	1.05	129
STIRL	28654	0.	0.	432.	0.	68.	55.		1.	28.	1.91	0.01	0.22	41.2	2.46	325.4	0	8.5	1.15	92
HEGT60	28654	0.	0.	266.	0.	2.	-2.	A	1.	1.	1.23	0.01	-0.00	19.0	1.13	243.1	0	7.7	1.04	128
HEGT60	28654	0.	0.	1466.	0.	273.	-294.	A	1.	111.	5.43	0.01	-0.01	139.1	8.31	323.7	0	24.8	3.34	104
HEGT00	28654	0.	0.	265.	0.	2.	-0.	A	1.	1.	1.23	0.01	0.00	18.9	1.13	242.9	0	7.7	1.04	129
HEGT00	28654	0.	0.	475.	0.	60.	-15.	A	1.	25.	2.07	0.01	0.09	49.6	2.96	356.3	0	11.0	1.49	81
FCMCCL	28654	0.	0.	262.	0.	2.	2.		1.	1.	1.31	0.01	0.01	21.5	1.28	279.7	0	8.1	1.09	128
FCMCCL	28654	0.	0.	468.	0.	102.	133.		1.	42.	3.00	0.01	0.33	57.0	3.40	415.8	0	9.6	1.30	105
FCSTCL	28654	0.	0.	262.	0.	2.	2.		1.	1.	1.35	0.01	0.02	21.4	1.28	278.7	0	8.1	1.09	128
FCSTCL	28654	0.	0.	493.	0.	121.	165.		1.	49.	3.31	0.01	0.36	61.6	3.68	421.7	0	9.6	1.29	108
IGGTST	28654	0.	0.	263.	0.	2.	1.		1.	1.	1.38	0.01	0.01	20.8	1.24	269.0	0	8.1	1.09	128
IGGTST	28654	0.	0.	463.	0.	78.	58.		1.	32.	1.91	0.01	0.23	48.4	2.89	356.6	0	9.3	1.26	93
GTSCAR	28654	0.	263.	0.	0.	-262.	265.		1.	1.	0.60	0.01	0.01	8.3	0.50	107.6	-16	9.0	1.22	156
GTSCAR	28654	0.	575.	0.	0.	-455.	660.		1.	49.	0.93	0.01	0.26	21.9	1.31	130.1	0	11.0	1.48	118
GTAC08	28654	0.	262.	0.	0.	-261.	265.		1.	1.	0.59	0.01	0.01	8.2	0.49	106.4	-16	9.0	1.21	156
GTAC08	28654	0.	427.	0.	0.	-344.	536.		1.	34.	0.74	0.01	0.31	15.9	0.95	127.0	-52	8.6	1.17	124
GTAC12	28654	0.	262.	0.	0.	-261.	265.		1.	1.	0.59	0.01	0.01	8.1	0.49	105.6	-16	9.0	1.21	157
GTAC12	28654	0.	475.	0.	0.	-371.	607.		1.	42.	0.83	0.01	0.33	18.8	1.12	134.9	0	8.8	1.19	124
GTAC16	28654	0.	263.	0.	0.	-261.	265.		1.	1.	0.59	0.01	0.01	8.1	0.49	105.7	-16	9.0	1.21	156
GTAC16	28654	0.	523.	0.	0.	-402.	665.		1.	50.	0.92	0.01	0.34	21.8	1.30	142.1	0	9.3	1.26	122
GTWC16	28654	0.	263.	0.	0.	-261.	265.		1.	1.	0.59	0.01	0.01	8.3	0.49	107.5	-16	9.0	1.22	156
GTWC16	28654	0.	542.	0.	0.	-420.	670.		1.	50.	0.90	0.01	0.32	21.0	1.26	132.3	0	9.7	1.31	122

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----

ECS	PROCS	**COGENERATION CASE**				**NOCOGEN - COGEN**				POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM WRTH ENRG
		DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL													
DEHTPM	28654	0.	263.	0.	0.	-261.	265.	1.	1.	0.66	0.01	0.01	9.3	0.55	120.4	-19	9.2	1.24	153	
DEHTPM	28654	0.	510.	0.	0.	-410.	593.	1.	41.	1.49	0.01	0.26	38.9	2.32	260.2	0	13.0	1.75	113	
GTSCAD	28654	263.	0.	0.	-263.	2.	265.	1.	1.	0.59	0.01	0.01	8.1	0.48	105.2	-25	10.7	1.44	162	
GTSCAD	28654	485.	0.	0.	-485.	102.	600.	1.	42.	0.78	0.01	0.31	16.8	1.00	118.3	999	12.2	1.65	135	
GTRA08	28654	263.	0.	0.	-263.	2.	265.	1.	1.	0.59	0.01	0.01	8.3	0.50	107.9	-26	10.7	1.45	161	
GTRA08	28654	803.	0.	0.	-803.	206.	948.	1.	84.	1.28	0.01	0.30	34.0	2.03	144.7	0	18.0	2.42	138	
GTRA12	28654	263.	0.	0.	-263.	2.	265.	1.	1.	0.59	0.01	0.01	8.3	0.49	107.1	-26	10.7	1.45	162	
GTRA12	28654	747.	0.	0.	-747.	192.	902.	1.	78.	1.21	0.01	0.32	31.6	1.89	144.3	0	16.7	2.25	137	
GTRA16	28654	263.	0.	0.	-263.	2.	265.	1.	1.	0.59	0.01	0.01	8.3	0.50	108.0	-26	10.7	1.45	161	
GTRA16	28654	691.	0.	0.	-691.	173.	839.	1.	71.	1.19	0.01	0.32	31.0	1.85	153.2	0	16.0	2.17	135	
GTR208	28654	263.	0.	0.	-263.	2.	265.	1.	1.	0.59	0.01	0.01	8.2	0.49	106.9	-26	10.7	1.45	162	
GTR208	28654	595.	0.	0.	-595.	137.	717.	1.	56.	0.97	0.01	0.30	23.4	1.40	134.4	0	14.3	1.94	133	
GTR212	28654	263.	0.	0.	-263.	2.	265.	1.	1.	0.59	0.01	0.01	8.3	0.49	107.2	-26	10.7	1.45	162	
GTR212	28654	619.	0.	0.	-619.	147.	751.	1.	60.	1.03	0.01	0.31	25.3	1.51	139.5	0	14.7	1.99	134	
GTR216	28654	263.	0.	0.	-263.	2.	265.	1.	1.	0.59	0.01	0.01	8.3	0.49	107.3	-26	10.7	1.45	162	
GTR216	28654	626.	0.	0.	-626.	152.	766.	1.	62.	1.08	0.01	0.32	27.2	1.62	148.2	0	14.8	2.00	134	
GTRW08	28654	264.	0.	0.	-264.	2.	265.	1.	1.	0.59	0.01	0.01	8.3	0.50	108.0	-26	10.8	1.45	161	
GTRW08	28654	949.	0.	0.	-949.	239.	1060.	1.	98.	1.30	0.01	0.27	33.7	2.01	121.0	0	20.6	2.78	143	
GTRW12	28654	263.	0.	0.	-263.	2.	265.	1.	1.	0.59	0.01	0.01	8.4	0.50	108.1	-26	10.8	1.45	161	
GTRW12	28654	893.	0.	0.	-893.	234.	1041.	1.	95.	1.28	0.01	0.30	33.0	1.97	126.2	0	19.0	2.56	141	
GTRW16	28654	263.	0.	0.	-263.	2.	265.	1.	1.	0.59	0.01	0.01	8.4	0.50	109.0	-26	10.8	1.45	161	
GTRW16	28654	813.	0.	0.	-813.	208.	957.	1.	85.	1.23	0.01	0.30	31.9	1.90	134.0	0	17.8	2.41	138	
GTR308	28654	264.	0.	0.	-264.	2.	265.	1.	1.	0.59	0.01	0.01	8.2	0.49	106.5	-26	10.8	1.45	161	
GTR308	28654	790.	0.	0.	-790.	176.	848.	1.	72.	1.10	0.01	0.23	26.8	1.60	116.0	0	18.8	2.54	136	
GTR312	28654	263.	0.	0.	-263.	2.	265.	1.	1.	0.59	0.01	0.01	8.3	0.50	107.7	-26	10.7	1.45	161	
GTR312	28654	698.	0.	0.	-698.	171.	833.	1.	70.	1.06	0.01	0.31	26.0	1.55	127.3	0	15.8	2.13	136	
GTR316	28654	263.	0.	0.	-263.	2.	265.	1.	1.	0.59	0.01	0.01	8.4	0.50	108.4	-26	10.7	1.45	161	
GTR316	28654	691.	0.	0.	-691.	168.	822.	1.	69.	1.03	0.01	0.30	26.8	1.60	132.4	0	15.9	2.14	135	
FCPADS	28654	264.	0.	0.	-264.	2.	265.	1.	1.	0.63	0.01	0.01	9.0	0.54	116.1	-28	10.9	1.47	160	
FCPADS	28654	1294.	0.	0.	-1294.	353.	1442.	1.	144.	15.00	0.01	0.28	84.3	5.03	222.2	0	43.3	5.85	207	
FMCDS	28654	263.	0.	0.	-263.	2.	265.	1.	1.	0.62	0.01	0.01	9.0	0.54	116.8	-28	10.8	1.46	160	
FMCDS	28654	944.	0.	0.	-944.	280.	1195.	1.	114.	11.26	0.01	0.36	72.3	4.32	261.4	0	31.5	4.25	179	

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																				
**COGENERATION CASE** **NOCOGEN - COGEN**																				
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REOD	COGEN POWER	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM ENRG	WRTH	
ONOCGN	28691	0.	4.	12.	0.	0.	0.	F	2.	0.	0.81	0.04	0.	12.0	1.00	262.8	0	2.6	1.00	80
PFBSTM	28691	0.	0.	0.	0.	4.	12.		2.	2.	1.24	0.04	1.00	15.9	1.32	332.5	0	3.0	1.15	252
PFBSTM	28691	0.	0.	0.	0.	15.	49.		2.	6.	1.24	0.04	1.00	16.0	1.33	297.1	12	2.1	0.83	212
TIHRSG	28691	0.	0.	0.	0.	4.	12.		2.	2.	1.32	0.04	1.00	23.3	1.93	469.7	0	3.1	1.49	252
TIHRSG	28691	0.	0.	0.	0.	24.	81.		2.	10.	1.94	0.04	1.00	53.8	4.46	767.7	0	6.2	2.43	219
HEGT00	28691	0.	0.	0.	0.	4.	12.	A	2.	2.	1.09	0.04	1.00	17.1	1.42	342.9	0	2.9	1.14	250
HEGT00	28691	0.	0.	0.	0.	37.	125.	A	2.	15.	1.49	0.04	1.00	35.5	2.95	409.4	4	2.8	1.10	187
FCMCCL	28691	0.	0.	284.	0.	62.	-76.		2.	25.	2.06	0.04	-0.05	39.9	3.31	478.4	0	6.9	2.67	91
GTSOAR	28691	0.	18.	0.	0.	-14.	12.		2.	2.	0.54	0.04	-0.10	6.8	0.56	138.9	999	1.8	0.68	125
GTAC08	28691	0.	19.	0.	0.	-15.	12.		2.	2.	0.53	0.04	-0.19	6.5	0.54	135.2	999	1.8	0.68	116
GTAC12	28691	0.	17.	0.	0.	-13.	12.		2.	2.	0.52	0.04	-0.05	6.4	0.53	134.0	999	1.7	0.66	132
GTAC16	28691	0.	16.	0.	0.	-12.	12.		2.	2.	0.52	0.04	0.01	6.5	0.54	134.4	999	1.7	0.65	139
GTWC16	28691	0.	16.	0.	0.	-13.	12.		2.	2.	0.53	0.04	-0.02	6.7	0.55	138.3	999	1.7	0.66	135
GTSOAR	28691	18.	0.	0.	-18.	4.	12.		2.	2.	0.52	0.04	-0.10	6.4	0.53	132.2	999	1.8	0.71	128
GTRA08	28691	14.	0.	0.	-14.	4.	12.		2.	2.	0.53	0.04	0.10	6.8	0.57	139.1	999	1.8	0.68	150
GTRA12	28691	14.	0.	0.	-14.	4.	12.		2.	2.	0.53	0.04	0.11	6.7	0.56	138.3	999	1.7	0.68	151
GTRA16	28691	15.	0.	0.	-15.	4.	12.		2.	2.	0.53	0.04	0.08	6.9	0.57	140.9	999	1.8	0.69	148
GTR208	28691	16.	0.	0.	-16.	4.	12.		2.	2.	0.53	0.04	-0.00	6.7	0.56	137.8	999	1.8	0.70	138
GTR212	28691	16.	0.	0.	-16.	4.	12.		2.	2.	0.53	0.04	0.03	6.8	0.56	138.9	999	1.8	0.70	142
GTR216	28691	15.	0.	0.	-15.	4.	12.		2.	2.	0.53	0.04	0.05	6.8	0.56	139.4	999	1.8	0.69	144
GTRV08	28691	15.	0.	0.	-15.	4.	12.		2.	2.	0.53	0.04	0.09	6.9	0.57	139.7	999	1.8	0.69	148
GTRV12	28691	14.	0.	0.	-14.	4.	12.		2.	2.	0.53	0.04	0.12	6.9	0.57	140.6	999	1.8	0.68	152
GTRV16	28691	14.	0.	0.	-14.	4.	12.		2.	2.	0.53	0.04	0.10	7.0	0.58	143.0	999	1.8	0.69	150
GTR308	28691	17.	0.	0.	-17.	4.	12.		2.	2.	0.53	0.04	-0.03	6.7	0.55	135.0	999	1.8	0.71	135
GTR312	28691	15.	0.	0.	-15.	4.	12.		2.	2.	0.53	0.04	0.06	6.8	0.57	139.9	999	1.8	0.69	146
GTR316	28691	15.	0.	0.	-15.	4.	12.		2.	2.	0.53	0.04	0.06	6.9	0.57	141.9	999	1.8	0.70	144
FCPADS	28691	13.	0.	0.	-13.	4.	12.		2.	2.	0.62	0.04	0.16	7.0	0.58	142.2	999	1.8	0.71	157
FCMCDS	28691	12.	0.	0.	-12.	4.	12.		2.	2.	0.60	0.04	0.22	7.0	0.58	145.0	999	1.8	0.69	165

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

DATE 06/07/79  
I&SE-PEO-ADV-DES-ENGR

ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	COGEN**	REOD	POWER	COGEN	MW	O&M	POWER	FESR	RATIO	CAPITAL	COST	*10**6	NORM	COST	EQVL	\$/KW	ROI	LEVEL	CHRG	NORM	WRTH	ENRGR									
ONOCGN	28692	0.	14.	223.	0.	0.	0.	F	6.	0.	0.	0.	0.87	0.13	0.	13.0	1.00	252.0	0	7.0	1.00	80																
PFBSTM	28692	0.	2.	207.	0.	12.	10.		6.	5.	1.29	0.13	0.12	1.24	276.5	11	6.7	0.96	127																			
TIHRSG	28692	0.	226.	0.	-212.	223.	223.		6.	6.	1.21	0.13	0.05	2.35	461.0	0	10.9	1.57	132																			
TIHRSG	28692	0.	276.	0.	-248.	270.	270.		6.	11.	1.46	0.13	0.07	3.57	575.5	0	13.3	1.91	121																			
TIHRSG	28692	0.	0.	226.	0.	14.	-3.		6.	6.	1.95	0.13	0.05	43.4	654.0	0	10.4	1.50	124																			
TIHRSG	28692	0.	0.	276.	0.	28.	-6.	A	6.	11.	2.14	0.13	0.07	59.8	739.5	0	12.2	1.75	114																			
TIHRSG	28692	0.	0.	229.	0.	14.	-6.	A	6.	6.	1.46	0.13	0.04	26.8	399.1	0	8.2	1.18	123																			
HEGT00	28692	0.	0.	335.	0.	43.	-17.	A	6.	17.	1.63	0.13	0.07	38.8	394.3	0	9.3	1.34	100																			
FCMCL	28692	0.	0.	205.	0.	14.	18.		6.	6.	1.52	0.13	0.13	25.8	429.2	0	7.6	1.12	135																			
FCMCL	28692	0.	0.	321.	0.	70.	90.		6.	29.	2.25	0.13	0.33	43.5	462.1	1	8.3	1.19	114																			
GTSOAR	28692	0.	217.	0.	-203.	223.	223.		6.	6.	0.67	0.13	0.09	9.4	148.3	-19	7.9	1.14	153																			
GTSOAR	28692	0.	444.	0.	-351.	486.	486.		6.	38.	0.80	0.13	0.23	17.9	137.6	0	9.6	1.38	117																			
GTAC08	28692	0.	205.	0.	-191.	223.	223.		6.	6.	0.65	0.13	0.14	8.7	145.0	-12	7.5	1.07	160																			
GTAC08	28692	0.	293.	0.	-236.	367.	367.		6.	23.	0.60	0.13	0.31	11.9	139.3	-11	7.1	1.02	139																			
GTAC12	28692	0.	209.	0.	-191.	223.	223.		6.	6.	0.64	0.13	0.34	8.7	145.3	-12	7.5	1.07	160																			
GTAC12	28692	0.	319.	0.	-249.	411.	411.		6.	29.	0.66	0.13	0.14	13.8	147.7	0	7.1	1.02	133																			
GTAC16	28692	0.	207.	0.	-193.	223.	223.		6.	6.	0.65	0.13	0.13	8.9	145.7	-14	7.5	1.09	158																			
GTAC16	28692	0.	361.	0.	-277.	457.	457.		6.	34.	0.73	0.13	0.33	16.3	153.7	0	7.6	1.10	127																			
GTWC16	28692	0.	209.	0.	-195.	223.	223.		6.	6.	0.66	0.13	0.12	9.2	150.5	-15	7.6	1.10	157																			
GTWC16	28692	0.	369.	0.	-286.	456.	456.		6.	34.	0.73	0.13	0.32	15.9	146.9	0	7.8	1.13	126																			
GTSOAR	28692	0.	207.	0.	-207.	14.	223.		6.	5.	0.64	0.13	0.13	8.5	139.5	-27	8.8	1.27	164																			
GTSOAR	28692	0.	330.	0.	-330.	69.	409.		6.	28.	0.63	0.13	0.31	12.6	130.0	148	9.5	1.36	141																			
GTRA08	28692	0.	218.	0.	-218.	14.	223.		6.	6.	0.67	0.13	0.08	9.5	149.2	-38	9.4	1.34	157																			
GTRA08	28692	0.	741.	0.	-741.	190.	813.		6.	78.	1.16	0.13	0.26	29.7	136.8	0	17.3	2.49	132																			
GTRA12	28692	0.	216.	0.	-216.	14.	223.		6.	6.	0.67	0.13	0.09	9.5	150.5	-37	9.3	1.33	158																			
GTRA12	28692	0.	635.	0.	-635.	163.	724.		6.	67.	1.09	0.13	0.28	27.5	147.8	0	15.2	2.19	129																			
GTRA16	28692	0.	215.	0.	-215.	14.	223.		6.	5.	0.67	0.13	0.10	9.8	155.6	-39	9.3	1.33	158																			
GTRA16	28692	0.	556.	0.	-556.	140.	644.		6.	57.	1.03	0.13	0.29	26.0	159.6	0	14.0	2.02	128																			
GTR208	28692	0.	213.	0.	-213.	14.	223.		6.	6.	0.66	0.13	0.10	9.3	148.3	-34	9.1	1.31	160																			
GTR208	28692	0.	444.	0.	-444.	102.	518.		6.	42.	0.82	0.13	0.28	18.6	143.3	0	11.9	1.71	129																			
GTR212	28692	0.	213.	0.	-213.	14.	223.		6.	6.	0.66	0.13	0.10	9.4	150.8	-35	9.2	1.32	159																			
GTR212	28692	0.	465.	0.	-465.	110.	545.		6.	45.	0.86	0.13	0.29	20.2	148.6	0	12.2	1.76	129																			
GTR216	28692	0.	213.	0.	-213.	14.	223.		6.	6.	0.67	0.13	0.10	9.5	152.9	-36	9.2	1.32	159																			
GTR216	28692	0.	474.	0.	-474.	115.	561.		6.	47.	0.90	0.13	0.30	21.8	157.0	0	12.4	1.78	128																			
GTRW08	28692	0.	220.	0.	-220.	14.	223.		6.	6.	0.67	0.13	0.07	9.6	149.5	-40	9.4	1.36	156																			
GTRW08	28692	0.	834.	0.	-834.	210.	881.		6.	86.	1.19	0.13	0.24	30.2	123.6	0	19.2	2.75	135																			
GTRW12	28692	0.	217.	0.	-217.	14.	223.		6.	6.	0.67	0.13	0.09	9.7	151.9	-39	9.3	1.34	157																			
GTRW12	28692	0.	732.	0.	-732.	192.	818.		6.	78.	1.13	0.13	0.27	28.3	131.9	0	16.7	2.40	133																			
GTRW16	28692	0.	216.	0.	-216.	14.	223.		6.	6.	0.67	0.13	0.09	9.9	156.3	-40	9.3	1.34	157																			
GTRW16	28692	0.	628.	0.	-628.	161.	716.		6.	66.	1.05	0.13	0.28	26.3	143.0	0	15.0	2.16	129																			
GTRW308	28692	0.	221.	0.	-221.	14.	223.		6.	6.	0.67	0.13	0.07	9.2	142.6	-37	9.4	1.36	156																			
GTRW308	28692	0.	621.	0.	-621.	138.	640.		6.	56.	0.95	0.13	0.20	22.2	121.9	0	15.9	2.29	127																			
GTR312	28692	0.	213.	0.	-213.	14.	223.		6.	6.	0.66	0.13	0.10	9.4	150.9	-35	9.2	1.32	159																			

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																			
ECS	PROCS	**COGENERATION CASE**			**NOCOGEN - COGEN**			POWER	COGEN	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM ENRG	WRTH
		DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	REQD MW	POWER MW										
GTR312	28692	498.	0.	0.	-498.	122.	586.	6.	50.	0.87	0.13	0.30	20.3	1.56	139.5	0	12.5	1.80	129
GTR316	28692	213.	0.	0.	-213.	14.	223.	6.	6.	0.67	0.13	0.10	9.7	0.74	154.5	-37	9.2	1.32	159
GTR316	28692	491.	0.	0.	-491.	120.	577.	6.	49.	0.89	0.13	0.30	20.9	1.61	145.5	0	12.5	1.80	129
FCPADS	28692	217.	0.	0.	-217.	14.	223.	6.	6.	1.09	0.13	0.08	9.8	0.75	154.2	-46	9.8	1.41	158
FCPADS	28692	882.	0.	0.	-882.	241.	983.	6.	98.	10.30	0.13	0.28	58.1	4.46	224.6	0	30.6	4.40	172
FCMCDS	28692	211.	0.	0.	-211.	14.	223.	6.	6.	1.06	0.13	0.11	10.1	0.77	163.0	-46	9.5	1.37	160
FCMCDS	28692	644.	0.	0.	-644.	191.	815.	6.	78.	7.74	0.13	0.36	50.1	3.84	265.6	0	22.6	3.25	155

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----  
\*\*COGENERATION CASE\*\* \*\*NO COGEN - COGEN\*\*

ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD	COGEN POWER	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVEL CHR	NORM ENRG	WRTH ENRG	
ONOCGN	28693	0.	9.	400.	0.	0.	0.	F	4.	0.	1.38	0.04	0.	22.7	1.00	188.3	0	11.1	1.00	80
STM141	28693	0.	385.	0.	0.	-376.	400.		4.	4.	0.96	0.04	0.06	13.7	0.60	109.3	-20	13.5	1.21	156
STM141	28693	0.	445.	0.	0.	-400.	523.		4.	19.	0.86	0.04	0.22	15.6	0.69	109.6	-17	12.6	1.13	132
STM141	28693	0.	0.	385.	0.	9.	15.	F	4.	4.	1.94	0.04	0.06	28.6	1.26	229.4	0	11.5	1.03	133
STM141	28693	0.	0.	445.	0.	46.	78.	F	4.	19.	1.75	0.04	0.22	29.1	1.28	204.0	19	9.6	0.86	109
STM141	28693	0.	0.	385.	0.	9.	15.	A	4.	4.	1.85	0.04	0.06	26.9	1.18	215.3	4	11.2	1.01	133
STM141	28693	0.	0.	445.	0.	46.	78.	A	4.	19.	1.57	0.04	0.22	20.7	0.91	145.4	999	8.5	0.76	115
STM088	28693	0.	385.	0.	0.	-376.	400.		4.	4.	0.94	0.04	0.06	12.2	0.54	97.9	-17	13.3	1.20	159
STM088	28693	0.	423.	0.	0.	-391.	477.		4.	13.	0.82	0.04	0.17	13.9	0.61	102.4	-16	12.8	1.15	138
STM088	28693	0.	0.	385.	0.	9.	15.	F	4.	4.	1.96	0.04	0.06	28.9	1.27	231.0	0	11.5	1.04	132
STM088	28693	0.	0.	423.	0.	32.	54.	F	4.	13.	1.64	0.04	0.17	26.9	1.18	197.8	22	9.9	0.89	115
STM088	28693	0.	0.	385.	0.	9.	15.	A	4.	4.	1.88	0.04	0.06	26.7	1.18	214.0	3	11.2	1.01	134
STM088	28693	0.	0.	423.	0.	32.	54.	A	4.	13.	1.57	0.04	0.17	19.6	0.36	144.2	999	9.0	0.81	121
PFBSTM	28693	0.	0.	386.	0.	9.	15.		4.	4.	1.92	0.04	0.08	27.9	1.23	223.2	0	11.4	1.02	133
PFBSTM	28693	0.	0.	503.	0.	78.	127.		4.	32.	2.65	0.04	0.29	35.0	1.54	219.5	12	9.7	0.87	105
TISTMT	28693	0.	385.	0.	0.	-377.	400.		4.	4.	1.21	0.04	0.06	25.0	1.10	200.2	0	15.0	1.35	144
TISTMT	28693	0.	530.	0.	0.	-435.	687.		4.	39.	2.71	0.04	0.32	81.2	3.57	485.3	0	20.3	1.83	117
TISTMT	28693	0.	0.	385.	0.	9.	15.		4.	4.	2.09	0.04	0.08	36.9	1.62	295.0	0	12.5	1.12	129
TISTMT	28693	0.	0.	547.	0.	105.	175.		4.	43.	3.82	0.04	0.34	109.0	4.80	631.8	3	17.6	1.58	109
TIHRSG	28693	0.	392.	0.	0.	-383.	400.		4.	4.	1.22	0.04	0.04	27.6	1.21	217.4	0	15.4	1.38	140
TIHRSG	28693	0.	488.	0.	0.	-438.	536.		4.	20.	2.36	0.04	0.17	72.9	3.21	470.5	0	21.1	1.89	109
TIHRSG	28693	0.	0.	392.	0.	9.	9.		4.	4.	2.21	0.04	0.04	43.7	1.93	345.0	0	13.5	1.21	126
TIHRSG	28693	0.	0.	501.	0.	55.	53.		4.	22.	3.40	0.04	0.18	98.7	4.35	621.7	0	19.0	1.71	100
STIRL	28693	392.	0.	0.	-392.	9.	400.		4.	4.	0.99	0.04	0.04	18.2	0.80	143.0	-59	16.7	1.50	154
STIRL	28693	660.	0.	0.	-660.	120.	771.		4.	49.	1.59	0.04	0.26	37.2	1.64	181.2	0	20.5	1.85	122
STIRL	28693	0.	392.	0.	0.	-383.	400.		4.	4.	0.99	0.04	0.04	18.2	0.80	143.1	-36	14.2	1.27	148
STIRL	28693	0.	660.	0.	0.	-541.	771.		4.	49.	1.59	0.04	0.26	37.3	1.64	181.4	0	16.3	1.46	113
STIRL	28693	0.	0.	392.	0.	9.	8.		4.	4.	1.82	0.04	0.04	28.8	1.27	225.7	0	11.4	1.03	130
STIRL	28693	0.	0.	692.	0.	133.	123.		4.	54.	2.92	0.04	0.27	68.8	3.03	320.3	2	12.5	1.13	94
HEGT85	28693	0.	0.	404.	0.	9.	-3.	A	4.	4.	1.82	0.04	0.01	32.6	1.43	250.1	0	12.1	1.09	125
HEGT85	28693	0.	0.	2919.	0.	683.	-262.	A	4.	279.	10.24	0.04	0.13	269.1	11.85	310.3	0	37.9	3.41	121
HEGT60	28693	0.	0.	402.	0.	9.	-2.	A	4.	4.	1.82	0.04	0.02	32.3	1.42	248.5	0	12.0	1.08	126
HEGT60	28693	0.	0.	1163.	0.	224.	-42.	A	4.	91.	4.69	0.04	0.14	121.0	5.33	343.0	0	21.2	1.90	90
HEGT00	28693	0.	0.	400.	0.	9.	-0.	A	4.	4.	1.83	0.04	0.02	31.9	1.40	246.2	0	12.0	1.08	127
HEGT00	28693	0.	0.	675.	0.	91.	-1.	A	4.	37.	2.78	0.04	0.12	66.3	2.92	315.9	0	15.1	1.36	83
FCMCCL	28693	0.	0.	430.	0.	9.	-30.		4.	4.	1.94	0.04	-0.05	34.3	1.51	272.3	0	12.9	1.16	118
FCMCCL	28693	0.	0.	739.	0.	162.	172.		4.	66.	4.28	0.04	0.31	79.4	3.49	366.3	0	14.1	1.26	101
FCSTCL	28693	0.	0.	429.	0.	9.	-29.		4.	4.	1.97	0.04	-0.05	33.7	1.48	268.3	0	12.9	1.16	119
FCSTCL	28693	0.	0.	869.	0.	235.	289.		4.	96.	5.13	0.04	0.38	94.2	4.15	369.8	2	13.2	1.19	105
IGGTST	28693	0.	0.	433.	0.	9.	-33.		4.	4.	1.96	0.04	-0.06	32.8	1.44	258.0	0	12.8	1.15	118
IGGTST	28693	0.	0.	810.	0.	162.	102.		4.	66.	2.64	0.04	0.25	72.7	3.20	306.1	2	12.8	1.15	91
GTSOAR	28693	0.	392.	0.	0.	-383.	400.		4.	4.	0.93	0.04	0.04	17.3	0.76	136.5	-31	14.0	1.26	149
GTSOAR	28693	0.	743.	0.	0.	-588.	889.		4.	63.	1.30	0.04	0.29	28.5	1.25	123.9	0	14.8	1.33	119

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																		
**COGENERATION CASE** **NOCOGEN - COGEN**																		
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVEL CHRG	NORM WRTH ENRG
GTAC08	28693	0.	389.	0.	0.	-380.	400.	4.	4.	0.92	0.04	0.05	16.8	0.74	133.8	-28	13.9	1.25 150
GTAC08	28693	0.	612.	0.	0.	-493.	768.	4.	48.	1.13	0.04	0.31	22.5	0.99	117.7	118	12.9	1.16 123
GTAC12	28693	0.	389.	0.	0.	-380.	400.	4.	4.	0.92	0.04	0.05	16.8	0.74	133.4	-28	13.9	1.25 150
GTAC12	28693	0.	679.	0.	0.	-530.	869.	4.	61.	1.24	0.04	0.33	26.5	1.17	125.6	0	13.1	1.18 122
GTAC16	28693	0.	389.	0.	0.	-380.	400.	4.	4.	0.92	0.04	0.05	16.9	0.74	134.2	-29	13.9	1.25 150
GTAC16	28693	0.	728.	0.	0.	-559.	937.	4.	69.	1.34	0.04	0.34	30.1	1.32	133.3	0	13.5	1.22 121
GTWC16	28693	0.	391.	0.	0.	-382.	400.	4.	4.	0.93	0.04	0.04	17.2	0.76	135.7	-30	14.0	1.26 149
GTWC16	28693	0.	778.	0.	0.	-602.	961.	4.	72.	1.33	0.04	0.32	29.1	1.28	121.0	0	14.3	1.29 121
CC1626	28693	0.	391.	0.	0.	-383.	400.	4.	4.	0.99	0.04	0.04	16.9	0.75	133.7	-32	14.1	1.27 150
CC1626	28693	0.	1000.	0.	0.	-732.	1266.	4.	109.	1.72	0.04	0.35	37.5	1.65	123.1	0	15.3	1.37 121
CC1622	28693	0.	390.	0.	0.	-382.	400.	4.	4.	0.98	0.04	0.05	16.7	0.74	132.3	-30	14.0	1.26 150
CC1622	28693	0.	912.	0.	0.	-671.	1176.	4.	98.	1.68	0.04	0.36	37.4	1.65	134.0	0	14.7	1.32 121
CC1222	28693	0.	390.	0.	0.	-381.	400.	4.	4.	0.98	0.04	0.05	16.6	0.73	131.2	-30	14.0	1.26 151
CC1222	28693	0.	904.	0.	0.	-665.	1171.	4.	97.	1.65	0.04	0.36	35.5	1.56	128.3	0	14.3	1.29 122
CC0822	28693	0.	389.	0.	0.	-380.	400.	4.	4.	0.99	0.04	0.05	16.8	0.74	133.1	-30	14.0	1.26 151
CC0822	28693	0.	764.	0.	0.	-575.	1004.	4.	77.	1.47	0.04	0.36	29.7	1.31	126.1	0	13.2	1.19 123
STIG15	28693	0.	402.	0.	0.	-394.	400.	4.	4.	0.94	0.04	0.02	16.9	0.74	130.1	-32	14.3	1.29 147
STIG15	28693	0.	24231.	0.	0.	-17595.	22585.	4.	2706.	39.86	0.04	0.17	671.0	29.53	94.3	0	314.1	28.24 744
STIG10	28693	0.	399.	0.	0.	-391.	400.	4.	4.	0.93	0.04	0.02	16.7	0.74	129.4	-30	14.2	1.27 148
STIG10	28693	0.	2377.	0.	0.	-1764.	2425.	4.	250.	4.04	0.04	0.22	75.9	3.34	107.0	0	35.4	3.18 138
STIG1S	28693	0.	398.	0.	0.	-389.	400.	4.	4.	0.93	0.04	0.03	16.6	0.73	129.3	-30	14.1	1.27 148
STIG1S	28693	0.	1494.	0.	0.	-1134.	1576.	4.	147.	2.73	0.04	0.23	47.1	2.07	104.6	0	24.5	2.20 122
DEADV3	28693	0.	396.	0.	0.	-387.	400.	4.	4.	1.02	0.04	0.03	20.1	0.88	156.7	-57	14.5	1.30 145
DEADV3	28693	0.	1537.	0.	0.	-1127.	1742.	4.	167.	3.62	0.04	0.29	111.5	4.91	241.2	0	29.7	2.67 129
DEHTPM	28693	0.	389.	0.	0.	-380.	400.	4.	4.	1.06	0.04	0.05	20.2	0.89	160.5	-58	14.4	1.29 146
DEHTPM	28693	0.	735.	0.	0.	-562.	949.	4.	70.	2.18	0.04	0.34	56.8	2.50	249.5	0	17.1	1.54 117
DES0A3	28693	398.	0.	0.	-398.	9.	400.	4.	4.	1.00	0.04	0.03	19.1	0.84	148.2	-73	17.0	1.53 151
DES0A3	28693	1842.	0.	0.	-1842.	478.	1971.	4.	195.	4.87	0.04	0.25	159.8	7.04	289.6	0	51.7	4.65 170
DES0A3	28693	0.	398.	0.	0.	-389.	400.	4.	4.	1.00	0.04	0.03	19.1	0.84	148.2	-45	14.4	1.30 146
DES0A3	28693	0.	1842.	0.	0.	-1364.	1971.	4.	195.	4.87	0.04	0.25	159.8	7.04	289.6	0	39.8	3.58 143
GTSCAD	28693	390.	0.	0.	-390.	9.	400.	4.	4.	0.92	0.04	0.05	16.7	0.73	131.9	-46	16.4	1.48 156
GTSCAD	28693	684.	0.	0.	-684.	144.	551.	4.	59.	1.17	0.04	0.31	23.6	1.04	111.0	0	17.7	1.59 133
GTRA08	28693	391.	0.	0.	-391.	9.	400.	4.	4.	0.93	0.04	0.04	17.4	0.77	137.6	-52	16.6	1.49 155
GTRA08	28693	937.	0.	0.	-937.	240.	1175.	4.	98.	1.64	0.04	0.34	40.7	1.79	141.8	0	21.7	1.95 133
GTRA12	28693	391.	0.	0.	-391.	9.	400.	4.	4.	0.92	0.04	0.04	17.4	0.76	137.2	-51	16.5	1.49 155
GTRA12	28693	910.	0.	0.	-910.	234.	1154.	4.	95.	1.59	0.04	0.34	38.8	1.71	139.3	0	21.0	1.89 133
GTRA16	28693	391.	0.	0.	-391.	9.	400.	4.	4.	0.93	0.04	0.04	17.6	0.77	138.7	-52	16.6	1.49 155
GTRA16	28693	869.	0.	0.	-869.	218.	1101.	4.	89.	1.59	0.04	0.34	39.0	1.72	146.1	0	20.8	1.87 132
GTR208	28693	391.	0.	0.	-391.	9.	400.	4.	4.	0.92	0.04	0.04	17.2	0.76	135.7	-50	16.5	1.48 155
GTR208	28693	783.	0.	0.	-783.	180.	974.	4.	73.	1.37	0.04	0.32	30.8	1.35	127.3	0	19.5	1.75 132
GTR212	28693	391.	0.	0.	-391.	9.	400.	4.	4.	0.93	0.04	0.04	17.3	0.76	136.5	-50	16.5	1.49 155
GTR212	28693	815.	0.	0.	-815.	193.	1018.	4.	79.	1.43	0.04	0.33	33.1	1.46	131.8	0	19.9	1.79 132
GTR216	28693	391.	0.	0.	-391.	9.	400.	4.	4.	0.93	0.04	0.05	17.4	0.76	137.2	-51	16.5	1.49 155
GTR216	28693	818.	0.	0.	-818.	198.	1034.	4.	81.	1.49	0.04	0.34	35.3	1.55	140.2	0	20.0	1.79 132

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																			
**COGENERATION CASE** **NOCOGEN - COGEN**																			
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST EQVL	\$/KW ROI (%)	LEVEL CHRG	NORM ENRG	WRTH	
GTRW08	28693	394.	0.	0.	-394.	9.	400.	4.	4.	0.93	0.04	0.04	17.5	0.77	137.3	-53	16.7	1.50	154
GTRW08	28693	1136.	0.	0.	-1136.	287.	1330.	4.	117.	1.67	0.04	0.30	40.5	1.78	117.3	0	25.3	2.27	136
GTRW12	28693	393.	0.	0.	-393.	9.	400.	4.	4.	0.93	0.04	0.04	17.5	0.77	137.6	-53	16.6	1.50	154
GTRW12	28693	1111.	0.	0.	-1111.	291.	1344.	4.	119.	1.68	0.04	0.32	40.7	1.79	120.6	0	24.1	2.17	136
GTRW16	28693	393.	0.	0.	-393.	9.	400.	4.	4.	0.93	0.04	0.04	17.7	0.78	138.9	-54	16.6	1.50	154
GTRW16	28693	1048.	0.	0.	-1048.	269.	1271.	4.	110.	1.65	0.04	0.32	40.2	1.77	126.1	0	23.5	2.11	135
GTR308	28693	395.	0.	0.	-395.	9.	400.	4.	4.	0.93	0.04	0.03	17.2	0.76	134.7	-51	16.7	1.50	154
GTR308	28693	982.	0.	0.	-982.	219.	1103.	4.	89.	1.48	0.04	0.26	33.6	1.48	112.2	0	24.0	2.16	132
GTR312	28693	392.	0.	0.	-392.	9.	400.	4.	4.	0.93	0.04	0.04	17.3	0.76	136.3	-51	16.6	1.49	155
GTR312	28693	950.	0.	0.	-950.	234.	1153.	4.	95.	1.49	0.04	0.31	34.4	1.51	118.4	0	21.9	1.97	134
GTR316	28693	393.	0.	0.	-393.	9.	400.	4.	4.	0.93	0.04	0.04	17.5	0.77	137.5	-52	16.6	1.49	154
GTR316	28693	944.	0.	0.	-944.	230.	1141.	4.	94.	1.51	0.04	0.31	35.4	1.56	122.6	0	22.0	1.98	133
FCPADS	28693	396.	0.	0.	-396.	9.	400.	4.	4.	1.20	0.04	0.03	18.4	0.81	143.2	-65	17.1	1.54	153
FCPADS	28693	1853.	0.	0.	-1853.	506.	2065.	4.	206.	21.59	0.04	0.28	121.2	5.33	218.4	0	62.7	5.64	201
FCMCDS	28693	392.	0.	0.	-392.	9.	400.	4.	4.	1.17	0.04	0.04	18.5	0.81	145.8	-65	16.9	1.52	154
FCMCDS	28693	1352.	0.	0.	-1352.	400.	1711.	4.	163.	16.25	0.04	0.36	104.5	4.60	256.0	0	45.8	4.12	175



GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----

\*\*COGENERATION CASE\*\* \*\*NOCOGEN - COGEN\*\*

ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD	COGEN POWER	G&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVEL CHRG	NORM ENRG	WRTH	
ONCOGN	28694	0.	8.	427.	0.	0.	0.	F	3.	0.	1.50	0.03	0.	24.8	1.00	179.9	0	11.9	1.00	80
STM141	28694	0.	413.	0.	0.	-405.	427.		3.	3.	1.03	0.03	0.05	14.7	0.59	103.7	-20	14.5	1.22	156
STM141	28694	0.	446.	0.	0.	-418.	495.		3.	12.	0.86	0.03	0.15	15.0	0.61	99.3	-17	13.8	1.16	137
STM141	28694	0.	0.	413.	0.	8.	14.	F	3.	3.	2.11	0.03	0.05	31.6	1.27	222.6	0	12.4	1.05	132
STM141	28694	0.	0.	446.	0.	28.	48.	F	3.	12.	1.78	0.03	0.15	29.1	1.17	191.9	18	10.9	0.92	114
STM141	28694	0.	0.	413.	0.	8.	14.	A	3.	3.	2.01	0.03	0.05	28.8	1.16	203.0	1	12.0	1.01	133
STM141	28694	0.	0.	446.	0.	28.	48.	A	3.	12.	1.59	0.03	0.15	20.3	0.82	133.8	999	9.7	0.82	120
PFBSTM	28694	0.	0.	414.	0.	8.	13.		3.	3.	2.07	0.03	0.05	30.2	1.22	212.4	0	12.2	1.03	132
PFBSTM	28694	0.	0.	512.	0.	63.	100.		3.	26.	2.76	0.03	0.24	35.3	1.42	207.1	10	11.0	0.93	104
TISTMT	28694	0.	414.	0.	0.	-406.	427.		3.	3.	1.28	0.03	0.05	26.8	1.08	188.6	0	16.1	1.35	143
TISTMT	28694	0.	531.	0.	0.	-454.	659.		3.	32.	2.73	0.03	0.28	80.8	3.26	458.6	0	21.6	1.82	113
TISTMT	28694	0.	0.	414.	0.	8.	13.		3.	3.	2.23	0.03	0.05	39.9	1.61	280.8	0	13.4	1.13	128
TISTMT	28694	0.	0.	554.	0.	91.	150.		3.	37.	3.95	0.03	0.30	112.6	4.54	615.2	0	19.2	1.62	106
TIHRSG	28694	0.	423.	0.	0.	-414.	427.		3.	3.	1.30	0.03	0.03	30.3	1.22	209.8	0	16.6	1.40	139
TIHRSG	28694	0.	557.	0.	0.	-501.	589.		3.	23.	2.61	0.03	0.14	81.1	3.27	440.7	0	23.6	1.99	103
TIHRSG	28694	0.	0.	423.	0.	8.	5.		3.	3.	2.29	0.03	0.03	44.4	1.79	307.3	0	14.1	1.19	125
TIHRSG	28694	0.	0.	585.	0.	66.	37.		3.	27.	3.89	0.03	0.15	113.8	4.59	592.3	0	21.6	1.82	94
STIRL	28694	420.	0.	0.	0.	8.	427.		3.	3.	1.04	0.03	0.03	19.5	0.79	135.8	-56	17.9	1.51	153
STIRL	28694	678.	0.	0.	-678.	111.	771.		3.	45.	1.66	0.03	0.23	38.9	1.57	177.1	0	22.0	1.86	120
STIRL	28694	0.	420.	0.	0.	-412.	427.		3.	3.	1.04	0.03	0.03	19.5	0.79	135.8	-35	15.2	1.28	148
STIRL	28694	0.	678.	0.	0.	-567.	771.		3.	45.	1.36	0.03	0.22	38.9	1.57	177.3	0	17.6	1.49	111
STIRL	28694	0.	0.	420.	0.	8.	7.		3.	3.	1.94	0.03	0.03	31.2	1.26	216.6	0	12.2	1.03	130
STIRL	28694	0.	0.	727.	0.	130.	109.		3.	53.	3.09	0.03	0.25	73.5	2.96	314.4	0	13.9	1.17	93
HEGT60	28694	0.	0.	434.	0.	8.	-7.	A	3.	3.	1.91	0.03	0.00	33.6	1.35	227.3	0	12.8	1.08	125
HEGT60	28694	0.	0.	2063.	0.	397.	-333.	A	3.	162.	7.19	0.03	0.03	181.3	7.31	290.0	0	32.3	2.72	95
HEGT00	28694	0.	0.	429.	0.	8.	-2.	A	3.	3.	1.92	0.03	0.01	33.2	1.34	226.6	0	12.7	1.07	127
HEGT00	28694	0.	0.	783.	0.	108.	-22.	A	3.	44.	3.15	0.03	0.10	75.1	3.03	300.2	0	16.9	1.43	81
FCMCCL	28694	0.	0.	487.	0.	8.	-60.		3.	3.	2.04	0.03	-0.12	36.3	1.46	254.2	0	14.2	1.20	111
FCMCCL	28694	0.	0.	849.	0.	186.	172.		3.	76.	4.78	0.03	0.30	87.8	3.54	352.7	0	15.5	1.30	100
FCMCCL	28694	0.	0.	487.	0.	8.	-59.		3.	3.	2.09	0.03	-0.12	36.0	1.45	252.4	0	14.2	1.20	111
FCMCCL	28694	0.	0.	925.	0.	231.	247.		3.	94.	5.35	0.03	0.34	97.0	3.91	357.5	1	15.0	1.26	103
IGG	28694	0.	0.	491.	0.	8.	-64.		3.	3.	2.07	0.03	-0.13	35.0	1.41	242.9	0	14.1	1.19	111
IGG	28694	0.	0.	861.	0.	152.	47.		3.	62.	2.69	0.03	0.19	74.2	2.99	294.2	0	14.6	1.23	87
GTS	28694	0.	421.	0.	0.	-413.	427.		3.	3.	0.97	0.03	0.03	18.3	0.74	127.1	-29	15.0	1.26	149
GTSOAR	28694	0.	865.	0.	0.	-685.	1004.		3.	74.	1.51	0.03	0.27	34.5	1.39	125.7	0	17.2	1.45	117
GTAC08	28694	0.	416.	0.	0.	-408.	427.		3.	3.	0.96	0.03	0.04	17.9	0.72	125.3	-27	14.8	1.25	150
GTAC08	28694	0.	659.	0.	0.	-531.	828.		3.	52.	1.22	0.03	0.31	24.5	0.99	114.7	106	13.8	1.17	124
GTAC12	28694	0.	417.	0.	0.	-409.	427.		3.	3.	0.95	0.03	0.04	17.8	0.72	124.8	-27	14.8	1.25	150
GTAC12	28694	0.	735.	0.	0.	-574.	939.		3.	66.	1.34	0.03	0.33	28.8	1.16	122.2	0	14.1	1.19	123
GTAC16	28694	0.	418.	0.	0.	-409.	427.		3.	3.	0.95	0.03	0.04	17.9	0.72	125.4	-27	14.8	1.25	150
GTAC16	28694	0.	804.	0.	0.	-617.	1025.		3.	76.	1.46	0.03	0.34	33.0	1.33	128.9	0	14.8	1.25	121
GTWC16	28694	0.	419.	0.	0.	-411.	427.		3.	3.	0.96	0.03	0.04	18.2	0.73	126.9	-28	14.9	1.26	149
GTWC16	28694	0.	839.	0.	0.	-649.	1036.		3.	77.	1.43	0.03	0.32	31.4	1.26	117.7	0	15.3	1.29	121

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	COGEN**	POWER	COGEN	COAL	O&M	POWER	FESR	CAPITAL	NORM	\$/KW	RO1	LEVL	NORM	WRTH
								MW	REQD	MW		MW	RATIO	COST	EQVL	(%)	CHRG	ENRG			
DEHTPM	28694	0	419	0	0	-411	427	3	3	1.12	0.03	0.04	0.03	21.8	0.88	151.8	-54	15.5	1.30	146	
DEHTPM	28694	0	792	0	0	-629	946	3	66	2.35	0.03	0.29	0.03	62.3	2.51	246.6	0	20.2	1.70	114	
GTSOAD	28694	418	0	0	-418	8	427	3	3	0.95	0.03	0.04	0.03	17.7	0.71	123.6	-43	17.5	1.48	156	
GTSOAD	28694	749	0	0	-749	157	926	3	64	1.27	0.03	0.31	0.03	25.9	1.04	107.8	0	19.3	1.63	133	
GTRA08	28694	421	0	0	-421	8	427	3	3	0.96	0.03	0.03	0.03	18.4	0.74	128.0	-48	17.7	1.50	154	
GTRA08	28694	1170	0	0	-1170	300	1405	3	122	1.89	0.03	0.31	0.03	47.9	1.93	131.6	0	26.4	2.23	135	
GTRA12	28694	420	0	0	-420	8	427	3	3	0.96	0.03	0.03	0.03	18.3	0.74	127.5	-47	17.7	1.49	155	
GTRA12	28694	1103	0	0	-1103	284	1351	3	116	1.87	0.03	0.32	0.03	47.4	1.91	137.8	0	-25.2	2.13	134	
GTRA16	28694	420	0	0	-420	8	427	3	3	0.97	0.03	0.04	0.03	18.5	0.75	128.8	-48	17.7	1.49	155	
GTRA16	28694	1031	0	0	-1031	259	1266	3	105	1.85	0.03	0.32	0.03	46.9	1.89	145.2	0	24.5	2.06	133	
GTR208	28694	420	0	0	-420	8	427	3	3	0.96	0.03	0.04	0.03	18.2	0.73	126.5	-46	17.7	1.49	155	
GTR208	28694	899	0	0	-899	207	1093	3	84	1.57	0.03	0.31	0.03	36.8	1.48	129.4	0	22.4	1.89	131	
GTR212	28694	420	0	0	-420	8	427	3	3	0.96	0.03	0.04	0.03	18.3	0.74	127.2	-46	17.7	1.49	155	
GTR212	28694	936	0	0	-936	222	1143	3	91	1.64	0.03	0.31	0.03	39.4	1.59	133.4	0	22.9	1.93	132	
GTR216	28694	419	0	0	-419	8	427	3	3	0.96	0.03	0.04	0.03	18.3	0.74	127.7	-47	17.7	1.49	155	
GTR216	28694	944	0	0	-944	229	1166	3	93	1.71	0.03	0.32	0.03	42.0	1.69	141.3	0	23.0	1.94	132	
GTRW08	28694	423	0	0	-423	8	427	3	3	0.97	0.03	0.03	0.03	18.5	0.74	127.7	-48	17.8	1.50	154	
GTRW08	28694	1394	0	0	-1394	352	1578	3	143	1.96	0.03	0.28	0.03	49.3	1.99	114.8	0	30.7	2.59	139	
GTRW12	28694	422	0	0	-422	8	427	3	3	0.96	0.03	0.03	0.03	18.5	0.74	128.1	-48	17.8	1.50	154	
GTRW12	28694	1328	0	0	-1328	347	1563	3	142	1.94	0.03	0.30	0.03	48.8	1.97	119.0	0	28.6	2.41	138	
GTRW16	28694	421	0	0	-421	8	427	3	3	0.97	0.03	0.03	0.03	18.6	0.75	129.2	-49	17.8	1.50	154	
GTRW16	28694	1221	0	0	-1221	313	1449	3	128	1.89	0.03	0.31	0.03	47.5	1.91	125.5	0	27.2	2.30	136	
GTR308	28694	424	0	0	-424	8	427	3	3	0.96	0.03	0.03	0.03	18.2	0.73	125.6	-47	17.8	1.50	154	
GTR308	28694	1179	0	0	-1179	263	1279	3	107	1.67	0.03	0.24	0.03	38.6	1.56	135.6	0	25.3	2.39	134	
GTR312	28694	421	0	0	-421	8	427	3	3	0.96	0.03	0.03	0.03	18.3	0.74	127.2	-47	17.7	1.49	155	
GTR312	28694	1065	0	0	-1065	262	1277	3	107	1.68	0.03	0.31	0.03	40.1	1.62	120.5	0	24.6	2.07	134	
GTR316	28694	421	0	0	-421	8	427	3	3	0.97	0.03	0.03	0.03	18.5	0.74	128.3	-48	17.7	1.50	154	
GTR316	28694	1056	0	0	-1056	257	1262	3	105	1.71	0.03	0.30	0.03	41.1	1.65	124.6	0	24.7	2.08	133	
FCPADS	28694	424	0	0	-424	8	427	3	3	1.21	0.03	0.03	0.03	19.6	0.79	135.1	-59	18.2	1.54	153	
FCPADS	28694	2000	0	0	-2000	546	2229	3	223	23.32	0.03	0.28	0.03	131.4	5.29	216.5	0	67.6	5.70	203	
FCMCD5	28694	420	0	0	-420	8	427	3	3	1.19	0.03	0.04	0.03	19.7	0.79	137.2	-59	18.1	1.52	154	
FCMCD5	28694	1459	0	0	-1459	432	1847	3	176	17.56	0.03	0.36	0.03	113.4	4.57	252.9	0	49.4	4.16	176	

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																				
**COGENERATION CASE**										**NO COGEN - COGEN**										
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD	COGEN POWER	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST	NORM COST	\$/KW EQVL	ROI (%)	LEVEL CHRGR	NORM ENRG	WRTH	
								MW	MW				*10**6							
ONOCGN	28731	0.	9.	782.	0.	0.	0.	F 4.	0.	2.22	0.02	0.	42.0	1.00	190.5	0	21.3	1.00	80	
PFBSTM	28731	0.	0.	770.	0.	9.	12.	4.	4.	2.77	0.02	0.03	40.2	0.96	178.3	999	20.8	0.98	134	
PFBSTM	28731	0.	0.	860.	0.	55.	76.	4.	22.	3.72	0.02	0.13	42.3	1.01	168.1	178	19.9	0.94	102	
TIHRSG	28731	0.	784.	0.	0.	-775.	782.	4.	4.	1.49	0.02	0.01	34.9	0.83	151.8	-53	29.1	1.37	145	
TIHRSG	28731	0.	1177.	0.	0.	-1058.	1152.	4.	49.	3.96	0.02	0.07	138.6	3.30	401.6	0	45.8	2.16	94	
TIHRSG	28731	0.	0.	784.	0.	9.	-2.	4.	4.	3.03	0.02	0.01	61.6	1.46	268.1	0	23.6	1.11	125	
TIHRSG	28731	0.	0.	1177.	0.	119.	-26.	4.	49.	5.95	0.02	0.07	176.4	4.20	511.1	0	37.2	1.75	81	
HFGT00	28731	0.	0.	785.	0.	9.	-3.	A 4.	4.	2.64	0.02	0.01	49.7	1.18	215.9	0	21.9	1.03	128	
HEGT00	28731	0.	0.	1434.	0.	181.	-74.	A 4.	74.	4.71	0.02	0.07	108.4	2.58	258.1	0	28.2	1.33	77	
FCMCCL	28731	0.	0.	771.	0.	9.	11.	4.	4.	2.83	0.02	0.02	55.5	1.32	245.8	0	22.7	1.07	128	
FCMCCL	28731	0.	0.	1371.	0.	300.	385.	4.	122.	7.25	0.02	0.33	124.5	2.96	309.8	4	22.4	1.05	101	
GTS0AR	28731	0.	778.	0.	0.	-769.	782.	4.	4.	1.25	0.02	0.02	26.8	0.64	117.5	-27	27.8	1.31	152	
GTS0AR	28731	0.	1893.	0.	0.	-1498.	2074.	4.	151.	2.18	0.02	0.23	63.6	1.51	114.7	0	36.2	1.70	117	
GTAC08	28731	0.	771.	0.	0.	-762.	782.	4.	4.	1.24	0.02	0.03	26.3	0.63	116.5	-26	27.6	1.30	153	
GTAC08	28731	0.	1249.	0.	0.	-1006.	1564.	4.	99.	1.47	0.02	0.31	38.4	0.91	104.9	-47	25.2	1.19	126	
GTAC12	28731	0.	770.	0.	0.	-762.	782.	4.	4.	1.23	0.02	0.03	26.3	0.62	116.3	-26	27.5	1.30	153	
GTAC12	28731	0.	1362.	0.	0.	-1063.	1753.	4.	122.	1.66	0.02	0.34	45.5	1.08	114.1	0	25.2	1.18	125	
GTAC16	28731	0.	772.	0.	0.	-763.	782.	4.	4.	1.23	0.02	0.02	26.4	0.63	116.5	-26	27.6	1.30	153	
GTAC16	28731	0.	1542.	0.	0.	-1184.	1951.	4.	146.	1.99	0.02	0.33	57.6	1.37	127.5	0	27.6	1.30	121	
GTWC16	28731	0.	773.	0.	0.	-764.	782.	4.	4.	1.24	0.02	0.02	26.6	0.63	117.6	-27	27.7	1.30	153	
GTWC16	28731	0.	1576.	0.	0.	-1219.	1948.	4.	146.	1.77	0.02	0.32	48.6	1.16	105.1	0	27.5	1.29	123	
GTS0AD	28731	772.	0.	0.	-772.	9.	782.	4.	4.	1.23	0.02	0.02	26.1	0.62	115.4	-41	32.9	1.55	159	
GTS0AD	28731	1407.	0.	0.	-1407.	295.	1741.	4.	120.	1.61	0.02	0.31	43.3	1.03	105.1	0	36.2	1.70	136	
GTRA08	28731	778.	0.	0.	-778.	9.	782.	4.	4.	1.24	0.02	0.01	26.8	0.64	117.5	-43	33.2	1.56	158	
GTRA08	28731	3161.	0.	0.	-3161.	811.	3468.	4.	331.	3.58	0.02	0.26	114.8	2.73	123.9	0	70.6	3.32	150	
GTRA12	28731	777.	0.	0.	-777.	9.	782.	4.	4.	1.24	0.02	0.02	26.8	0.64	117.5	-43	33.2	1.56	158	
GTRA12	28731	2710.	0.	0.	-2710.	697.	3087.	4.	284.	3.29	0.02	0.28	104.7	2.49	131.8	0	61.4	2.89	143	
GTRA16	28731	776.	0.	0.	-776.	9.	782.	4.	4.	1.24	0.02	0.02	27.0	0.64	118.5	-43	33.2	1.56	158	
GTRA16	28731	2374.	0.	0.	-2374.	596.	2747.	4.	243.	2.97	0.02	0.29	93.3	2.22	134.0	0	55.3	2.60	139	
GTR208	28731	775.	0.	0.	-775.	9.	782.	4.	4.	1.24	0.02	0.02	26.6	0.63	117.2	-42	33.1	1.56	158	
GTR208	28731	1893.	0.	0.	-1893.	435.	2211.	4.	178.	2.26	0.02	0.28	66.8	1.59	120.5	0	46.5	2.19	134	
GTR212	28731	775.	0.	0.	-775.	9.	782.	4.	4.	1.24	0.02	0.02	26.7	0.64	117.7	-42	33.1	1.56	158	
GTR212	28731	1983.	0.	0.	-1983.	470.	2327.	4.	192.	2.41	0.02	0.29	72.4	1.72	124.7	0	47.8	2.25	135	
GTR216	28731	775.	0.	0.	-775.	9.	782.	4.	4.	1.24	0.02	0.02	26.8	0.64	118.0	-42	33.1	1.56	158	
GTR216	28731	2021.	0.	0.	-2021.	489.	2392.	4.	200.	2.57	0.02	0.30	78.6	1.87	132.7	0	48.5	2.28	135	
GTRW08	28731	780.	0.	0.	-780.	9.	782.	4.	4.	1.24	0.02	0.01	26.9	0.64	117.7	-43	33.3	1.57	158	
GTRW08	28731	3559.	0.	0.	-3559.	898.	3759.	4.	366.	3.56	0.02	0.24	112.8	2.68	108.1	0	78.4	3.69	156	
GTRW12	28731	778.	0.	0.	-778.	9.	782.	4.	4.	1.24	0.02	0.02	26.9	0.64	118.1	-43	33.2	1.56	158	
GTRW12	28731	3124.	0.	0.	-3124.	817.	3489.	4.	333.	3.16	0.02	0.27	97.9	2.33	107.0	0	66.5	3.13	149	
GTRW16	28731	777.	0.	0.	-777.	9.	782.	4.	4.	1.24	0.02	0.02	27.1	0.64	119.0	-44	33.2	1.56	158	
GTRW16	28731	2680.	0.	0.	-2680.	688.	3055.	4.	280.	2.94	0.02	0.28	91.0	2.16	115.8	0	59.2	2.79	143	
GTR308	28731	781.	0.	0.	-781.	9.	782.	4.	4.	1.24	0.02	0.01	26.6	0.63	116.3	-43	33.3	1.57	158	
GTR308	28731	2651.	0.	0.	-2651.	591.	2730.	4.	241.	2.56	0.02	0.20	75.8	1.80	97.5	0	63.8	3.00	142	

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----

ECS	PROCS	**COGENERATION CASE**			**NOCOGEN - COGEN**			POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVEL CHRG	NORM ENRG	WRTH
		DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL												
GTR312	28731	775.	0.	0.	-775.	9.	782.	4.	4.	1.24	0.02	0.02	26.8	0.64	117.8	-42	33.1	1.56	158
GTR312	28731	2123.	0.	0.	-2123.	522.	2500.	4.	213.	2.39	0.02	0.30	70.9	1.69	114.0	0	48.8	2.30	137
GTR316	28731	776.	0.	0.	-776.	9.	782.	4.	4.	1.24	0.02	0.02	26.9	0.64	118.6	-43	33.1	1.56	158
GTR316	28731	2095.	0.	0.	-2095.	510.	2462.	4.	208.	2.43	0.02	0.30	72.8	1.73	118.6	0	48.9	2.30	137
FCPADS	28731	778.	0.	0.	-778.	9.	782.	4.	4.	1.55	0.02	0.02	28.9	0.69	126.8	-50	33.7	1.59	157
FCPADS	28731	3765.	0.	0.	-3765.	1028.	4195.	4.	419.	45.41	0.02	0.28	237.6	5.65	215.4	0	130.9	6.16	214
FCMCDS	28731	774.	0.	0.	-774.	9.	782.	4.	4.	1.52	0.02	0.02	29.1	0.69	128.1	-50	33.6	1.58	157
FCMCDS	28731	2747.	0.	0.	-2747.	813.	3476.	4.	332.	33.97	0.02	0.36	204.4	4.86	253.9	0	94.8	4.46	183

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																				
**COGENERATION CASE** **NOCOGEN - COGEN**																				
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD	COGEN POWER	G&M	POWER /HEAT RATIO	FESR	CAPITAL COST	NORM COST	\$/KW EGVL	ROI (%)	LEVEL CHRG	NORM WRTH ENRG		
								MW	MW				*10**6							
ONOCGN	28741	0.	10.	141.	0.	0.	0.	A	4.	0.	0.66	0.15	0.	7.4	1.00	232.0	0	4.5	1.00	80
STM141	28741	0.	124.	0.	0.	-114.	141.		4.	4.	0.62	0.15	0.18	6.7	0.91	183.4	-38	4.9	1.10	157
STM141	28741	0.	136.	0.	0.	-119.	165.		4.	7.	0.49	0.15	0.25	6.6	0.89	165.3	-13	4.6	1.02	151
STM141	28741	0.	0.	124.	0.	10.	17.	F	4.	4.	1.11	0.15	0.18	13.7	1.86	376.4	2	4.7	1.04	139
STM141	28741	0.	0.	136.	0.	17.	29.	F	4.	7.	0.88	0.15	0.25	12.4	1.69	312.0	12	4.0	0.89	132
STM141	28741	0.	0.	124.	0.	10.	17.	A	4.	4.	1.03	0.15	0.18	12.3	1.67	336.6	6	4.4	0.99	140
STM141	28741	0.	0.	136.	0.	17.	29.	A	4.	7.	0.78	0.15	0.25	9.9	1.34	247.8	25	3.6	0.80	135
STM088	28741	0.	124.	0.	0.	-114.	141.		4.	4.	0.60	0.15	0.18	6.2	0.85	171.2	-23	4.8	1.08	158
STM088	28741	0.	129.	0.	0.	-116.	151.		4.	5.	0.46	0.15	0.21	5.8	0.79	153.1	-9	4.6	1.02	152
STM088	28741	0.	0.	124.	0.	10.	17.	F	4.	4.	1.07	0.15	0.18	13.0	1.77	356.9	4	4.6	1.02	139
STM088	28741	0.	0.	129.	0.	13.	22.	F	4.	5.	0.84	0.15	0.21	11.4	1.55	301.5	12	4.0	0.89	132
STM088	28741	0.	0.	124.	0.	10.	17.	A	4.	4.	1.00	0.15	0.18	11.4	1.55	313.4	8	4.3	0.96	141
STM088	28741	0.	0.	129.	0.	13.	22.	A	4.	5.	0.75	0.15	0.21	9.3	1.26	245.1	27	3.7	0.82	135
PFBSTM	28741	0.	0.	125.	0.	10.	16.		4.	4.	1.17	0.15	0.17	14.8	2.01	405.7	0	4.8	1.08	138
PFBSTM	28741	0.	0.	151.	0.	26.	43.		4.	10.	1.13	0.15	0.31	15.5	2.11	350.2	8	4.2	0.93	129
TISTMT	28741	0.	125.	0.	0.	-115.	141.		4.	4.	0.85	0.15	0.17	16.2	2.21	444.7	0	6.2	1.38	144
TISTMT	28741	0.	164.	0.	0.	-131.	220.		4.	14.	1.19	0.15	0.35	33.7	4.58	699.8	0	7.8	1.74	136
TISTMT	28741	0.	0.	125.	0.	10.	16.		4.	4.	1.37	0.15	0.17	24.3	3.30	665.2	0	6.1	1.36	137
TISTMT	28741	0.	0.	164.	0.	33.	56.		4.	14.	1.68	0.15	0.35	42.8	5.82	889.0	0	7.3	1.63	131
TIHRSG	28741	0.	131.	0.	0.	-121.	141.		4.	4.	0.94	0.15	0.13	23.0	3.12	597.7	0	7.1	1.59	138
TIHRSG	28741	0.	142.	0.	0.	-127.	156.		4.	6.	0.94	0.15	0.17	28.3	3.85	683.4	0	7.7	1.71	131
TIHRSG	28741	0.	0.	131.	0.	10.	10.		4.	4.	1.46	0.15	0.13	31.7	4.31	825.8	0	7.1	1.58	134
TIHRSG	28741	0.	0.	142.	0.	14.	15.		4.	6.	1.38	0.15	0.17	36.5	4.96	880.6	0	7.4	1.64	126
STIRL	28741	132.	0.	0.	-132.	10.	141.		4.	4.	0.57	0.15	0.13	6.7	0.91	173.8	-89	5.9	1.32	156
STIRL	28741	194.	0.	0.	-194.	36.	227.		4.	15.	0.59	0.15	0.26	10.9	1.49	192.3	0	5.7	1.49	136
STIRL	28741	0.	132.	0.	0.	-122.	141.		4.	4.	0.57	0.15	0.13	6.7	0.91	173.9	-42	5.1	1.13	151
STIRL	28741	0.	194.	0.	0.	-159.	227.		4.	15.	0.59	0.15	0.26	11.0	1.49	192.6	0	5.4	1.21	129
STIRL	28741	0.	0.	132.	0.	10.	9.		4.	4.	1.05	0.15	0.13	13.7	1.86	354.7	1	4.7	1.05	133
STIRL	28741	0.	0.	194.	0.	36.	33.		4.	15.	1.05	0.15	0.26	18.6	2.53	326.8	6	4.3	0.97	112
HEGT85	28741	0.	0.	144.	0.	10.	-3.	A	4.	4.	1.17	0.15	0.05	21.6	2.93	511.6	0	5.9	1.32	122
HEGT85	28741	0.	0.	688.	0.	154.	-44.	A	4.	63.	3.40	0.15	0.14	93.6	12.72	478.2	0	13.9	3.11	115
HEGT60	28741	0.	0.	142.	0.	10.	-1.	A	4.	4.	1.16	0.15	0.06	20.9	2.85	502.7	0	5.8	1.29	123
HEGT60	28741	0.	0.	304.	0.	57.	-6.	A	4.	23.	1.76	0.15	0.14	45.8	6.23	514.6	0	8.3	1.85	97
HEGT00	28741	0.	0.	141.	0.	10.	0.	A	4.	4.	1.13	0.15	0.07	19.9	2.70	480.8	0	5.6	1.26	124
HEGT00	28741	0.	0.	187.	0.	24.	0.	A	4.	10.	1.10	0.15	0.11	25.7	3.49	468.3	0	6.0	1.33	108
FCMCCL	28741	0.	0.	128.	0.	10.	13.		4.	4.	1.18	0.15	0.15	19.2	2.61	510.7	0	5.4	1.22	134
FCMCCL	28741	0.	0.	194.	0.	42.	56.		4.	17.	1.56	0.15	0.34	30.4	4.13	533.6	0	5.7	1.28	118
FCSTCL	28741	0.	0.	127.	0.	10.	14.		4.	4.	1.21	0.15	0.16	18.6	2.53	499.2	0	5.4	1.20	135
FCSTCL	28741	0.	0.	243.	0.	70.	99.		4.	28.	2.00	0.15	0.41	38.0	5.17	535.3	1	5.8	1.30	114
IGGTST	28741	0.	0.	132.	0.	10.	9.		4.	4.	1.22	0.15	0.13	18.8	2.56	488.4	0	5.5	1.23	132
IGGTST	28741	0.	0.	226.	0.	49.	47.		4.	20.	1.34	0.15	0.30	31.2	4.23	470.0	0	5.6	1.26	108
GTSOAR	28741	0.	132.	0.	0.	-122.	141.		4.	4.	0.54	0.15	0.13	6.9	0.94	180.1	-53	5.1	1.13	151
GTSOAR	28741	0.	215.	0.	0.	-170.	258.		4.	18.	0.54	0.15	0.29	10.7	1.46	170.6	0	5.2	1.17	126

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	COGEN**	POWER	COGEN	G&M	POWER	FESR	CAPITAL	NORM	\$/KW	ROI	LEVEL	NORM
								MM	MM	MM		RATIO	%	*10**6	COST	EQVL	(%)	CHRG	ENRG
GTAC08	28741	0.	128.	0.	-118.	141.	4.	4.	0.53	0.15	0.15	0.15	6.4	0.87	170.2	-25	4.9	1.09	155
GTAC08	28741	0.	179.	0.	-144.	224.	4.	14.	0.46	0.15	0.31	0.31	8.3	1.12	157.5	0	4.6	1.03	137
GTAC12	28741	0.	129.	0.	-119.	141.	4.	4.	0.53	0.15	0.15	0.15	6.4	0.87	169.9	-25	4.9	1.09	155
GTAC12	28741	0.	198.	0.	-155.	254.	4.	18.	0.50	0.15	0.33	0.33	9.5	1.29	164.2	0	4.7	1.05	132
GTAC16	28741	0.	129.	0.	-119.	141.	4.	4.	0.53	0.15	0.15	0.15	6.5	0.89	173.1	-29	4.9	1.10	154
GTAC16	28741	0.	212.	0.	-163.	273.	4.	20.	0.54	0.15	0.34	0.34	10.8	1.47	173.7	0	4.8	1.08	128
GTWC16	28741	0.	131.	0.	-121.	141.	4.	4.	0.54	0.15	0.13	0.13	6.8	0.93	177.8	-43	5.0	1.12	152
GTWC16	28741	0.	227.	0.	-176.	281.	4.	21.	0.55	0.15	0.32	0.32	11.2	1.52	167.5	0	5.2	1.15	124
CC1626	28741	0.	131.	0.	-121.	141.	4.	4.	0.61	0.15	0.13	0.13	6.9	0.94	180.1	-73	5.1	1.14	152
CC1626	28741	0.	310.	0.	-223.	400.	4.	36.	0.81	0.15	0.36	0.36	15.7	2.14	173.1	0	5.7	1.27	118
CC1622	28741	0.	130.	0.	-120.	141.	4.	4.	0.60	0.15	0.14	0.14	6.7	0.91	175.0	-47	5.1	1.13	153
CC1622	28741	0.	283.	0.	-204.	371.	4.	32.	0.77	0.15	0.37	0.37	14.8	2.01	178.8	0	5.4	1.20	119
CC1222	28741	0.	130.	0.	-120.	141.	4.	4.	0.60	0.15	0.14	0.14	6.5	0.89	171.7	-39	5.0	1.12	154
CC1222	28741	0.	280.	0.	-202.	370.	4.	32.	0.76	0.15	0.37	0.37	14.1	1.92	171.6	0	5.3	1.17	120
CC0822	28741	0.	128.	0.	-119.	141.	4.	4.	0.61	0.15	0.15	0.15	6.7	0.91	162.2	-52	5.3	1.18	146
CC0822	28741	0.	237.	0.	-174.	319.	4.	26.	0.69	0.15	0.38	0.38	12.2	1.66	175.9	0	4.9	1.09	124
STIG15	28741	0.	144.	0.	-134.	141.	4.	4.	0.58	0.15	0.05	0.05	6.9	0.94	164.2	-77	5.4	1.21	143
STIG15	28741	0.	707.	0.	-5139.	6596.	4.	790.	12.38	0.15	0.17	0.17	206.7	28.09	99.7	0	94.1	21.01	563
STIG10	28741	0.	140.	0.	-131.	141.	4.	4.	0.56	0.15	0.07	0.07	6.7	0.91	162.2	-52	5.3	1.18	146
STIG10	28741	0.	694.	0.	-515.	708.	4.	73.	1.40	0.15	0.22	0.22	23.9	3.24	117.3	0	11.3	2.52	122
STIG15	28741	0.	139.	0.	-129.	141.	4.	4.	0.56	0.15	0.08	0.08	6.6	0.89	161.8	-46	5.2	1.17	147
STIG15	28741	0.	436.	0.	-331.	460.	4.	43.	1.00	0.15	0.23	0.23	16.2	2.20	126.8	0	8.2	1.82	113
DEADV3	28741	0.	136.	0.	-126.	141.	4.	4.	0.62	0.15	0.10	0.10	8.8	1.19	220.3	0	5.4	1.22	144
DEADV3	28741	0.	437.	0.	-321.	498.	4.	48.	1.23	0.15	0.29	0.29	32.4	4.40	252.7	0	9.3	2.07	116
DEHTPM	28741	0.	129.	0.	-119.	141.	4.	4.	0.65	0.15	0.15	0.15	8.9	1.20	235.1	0	5.3	1.18	148
DEHTPM	28741	0.	214.	0.	-163.	280.	4.	21.	0.79	0.15	0.35	0.35	16.6	2.26	264.7	0	5.6	1.26	123
DES0A3	28741	138.	0.	0.	-138.	10.	4.	4.	0.60	0.15	0.08	0.08	7.8	1.07	193.7	0	6.3	1.40	149
DES0A3	28741	521.	0.	0.	-521.	135.	4.	55.	1.60	0.15	0.25	0.25	46.0	6.26	301.4	0	15.5	3.46	142
DES0A3	28741	0.	138.	0.	-128.	141.	4.	4.	0.60	0.15	0.08	0.08	7.8	1.07	193.7	0	5.4	1.20	144
DES0A3	28741	0.	521.	0.	-386.	561.	4.	55.	1.60	0.15	0.25	0.25	46.0	6.26	301.4	0	12.1	2.70	123
GTS0AD	28741	130.	0.	0.	-130.	10.	4.	4.	0.52	0.15	0.14	0.14	6.2	0.85	163.9	-53	5.7	1.28	159
GTS0AD	28741	199.	0.	0.	-199.	42.	4.	17.	0.48	0.15	0.31	0.31	8.6	1.17	147.3	0	6.0	1.34	140
GTRA08	28741	131.	0.	0.	-131.	10.	4.	4.	0.54	0.15	0.13	0.13	7.1	0.97	185.5	163	5.9	1.32	155
GTRA08	28741	269.	0.	0.	-269.	69.	4.	28.	0.65	0.15	0.34	0.34	14.5	1.97	183.6	0	7.3	1.62	128
GTRA12	28741	131.	0.	0.	-131.	10.	4.	4.	0.54	0.15	0.13	0.13	7.0	0.96	184.1	136	5.9	1.31	156
GTRA12	28741	262.	0.	0.	-262.	67.	4.	28.	0.65	0.15	0.35	0.35	14.5	1.97	188.4	0	7.1	1.59	128
GTRA16	28741	130.	0.	0.	-130.	10.	4.	4.	0.55	0.15	0.14	0.14	7.2	0.98	189.4	999	5.9	1.32	155
GTRA16	28741	251.	0.	0.	-251.	63.	4.	26.	0.65	0.15	0.34	0.34	14.6	1.98	198.4	0	7.1	1.58	129
GTR208	28741	131.	0.	0.	-131.	10.	4.	4.	0.54	0.15	0.13	0.13	6.8	0.93	178.1	-94	5.9	1.31	157
GTR208	28741	227.	0.	0.	-227.	52.	4.	21.	0.56	0.15	0.32	0.32	11.5	1.55	172.4	0	6.6	1.48	132
GTR212	28741	131.	0.	0.	-131.	10.	4.	4.	0.54	0.15	0.13	0.13	6.9	0.94	181.2	113	5.9	1.31	156
GTR212	28741	236.	0.	0.	-236.	56.	4.	23.	0.59	0.15	0.33	0.33	12.4	1.68	179.0	0	6.8	1.51	131
GTR216	28741	130.	0.	0.	-130.	10.	4.	4.	0.54	0.15	0.14	0.14	7.0	0.95	183.9	129	5.9	1.31	156
GTR216	28741	237.	0.	0.	-237.	57.	4.	23.	0.61	0.15	0.34	0.34	13.1	1.78	188.5	0	6.8	1.52	130

HONEYWELL PAGE PRINTING SYSTEM P118102

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																			
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM WRTH ENRG	
GTRW08	28741	134.	0.	0.	-134.	10.	141.	4.	4.	0.55	0.15	0.11	7.2	0.98	183.4	999	6.0	1.35	153
GTRW08	28741	327.	0.	0.	-327.	82.	384.	4.	34.	0.71	0.15	0.30	15.9	2.16	166.0	0	8.5	1.90	126
GTRW12	28741	133.	0.	0.	-133.	10.	141.	4.	4.	0.55	0.15	0.12	7.2	0.98	184.9	999	6.0	1.34	154
GTRW12	28741	321.	0.	0.	-321.	84.	389.	4.	34.	0.71	0.15	0.32	16.0	2.18	170.6	0	8.2	1.83	126
GTRW16	28741	133.	0.	0.	-133.	10.	141.	4.	4.	0.55	0.15	0.12	7.4	1.00	189.3	999	6.0	1.34	154
GTRW16	28741	303.	0.	0.	-303.	78.	369.	4.	32.	0.70	0.15	0.32	15.9	2.16	179.2	0	8.0	1.79	126
GTR308	28741	135.	0.	0.	-135.	10.	141.	4.	4.	0.54	0.15	0.10	6.9	0.94	173.5	116	6.0	1.35	153
GTR308	28741	283.	0.	0.	-283.	63.	319.	4.	26.	0.62	0.15	0.26	12.8	1.75	155.0	0	8.0	1.78	126
GTR312	28741	133.	0.	0.	-133.	10.	141.	4.	4.	0.54	0.15	0.12	7.0	0.95	179.9	127	5.9	1.33	155
GTR312	28741	276.	0.	0.	-276.	68.	335.	4.	28.	0.63	0.15	0.32	13.4	1.82	165.5	0	7.5	1.66	128
GTR316	28741	133.	0.	0.	-133.	10.	141.	4.	4.	0.55	0.15	0.12	7.2	0.97	184.3	183	6.0	1.33	154
GTR316	28741	274.	0.	0.	-274.	67.	332.	4.	27.	0.64	0.15	0.31	13.9	1.89	172.6	0	7.5	1.68	127
FCPADS	28741	137.	0.	0.	-137.	10.	141.	4.	4.	0.83	0.15	0.09	7.1	0.96	175.8	187	6.4	1.43	153
FCPADS	28741	541.	0.	0.	-541.	148.	603.	4.	60.	6.39	0.15	0.28	36.5	4.96	230.1	0	19.0	4.25	167
FCMCDS	28741	132.	0.	0.	-132.	10.	141.	4.	4.	0.80	0.15	0.12	7.2	0.98	186.1	999	6.2	1.39	156
FCMCDS	28741	395.	0.	0.	-395.	117.	500.	4.	48.	4.80	0.15	0.36	31.1	4.23	269.1	0	14.0	3.13	152

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----  
\*\*COGENERATION CASE\*\* \*\*NOCOGEN - COGEN\*\*

ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD	COGEN POWER	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EOVL	ROI (%)	LEVEL CHRG	NORM ENRG	WRTH
ONOCGN	28951	0.	33.	33.	0.	0.	0.	4.	0.	0.18	0.68	0.	1.4	1.00	202.3	0	2.2	1.00	80
STM141	28951	0.	36.	21.	0.	-2.	12.	4.	1.	0.27	0.68	0.15	2.6	1.83	297.1	8	2.2	0.98	116
STM141	28951	0.	6.	50.	0.	27.	-17.	F 4.	1.	0.43	0.68	0.15	4.4	3.13	506.9	6	2.2	0.98	107
STM141	28951	0.	6.	50.	0.	27.	-17.	A 4.	1.	0.38	0.68	0.15	4.0	2.84	460.0	9	2.1	0.94	108
STM088	28951	0.	35.	24.	0.	-2.	9.	4.	1.	0.26	0.68	0.11	2.2	1.56	265.6	9	2.2	0.98	113
STM088	28951	0.	7.	52.	0.	26.	-19.	F 4.	1.	0.42	0.68	0.11	4.0	2.85	484.1	6	2.2	0.99	102
STM088	28951	0.	7.	52.	0.	26.	-19.	A 4.	1.	0.37	0.68	0.11	3.7	2.65	451.5	8	2.1	0.95	102
PFBSTM	28951	0.	4.	47.	0.	29.	-14.	4.	2.	0.48	0.68	0.22	5.9	4.21	613.4	5	2.2	0.99	117
TISTMT	28951	0.	38.	9.	0.	-5.	24.	4.	3.	0.49	0.68	0.29	11.0	7.89	1055.5	0	3.0	1.37	131
TISTMT	28951	0.	3.	44.	0.	31.	-12.	4.	3.	0.69	0.68	0.29	14.0	10.03	1342.7	0	3.1	1.41	130
TIHRSG	28951	0.	37.	23.	0.	-3.	10.	4.	1.	0.36	0.68	0.10	9.1	6.51	1032.4	0	3.0	1.36	101
TIHRSG	28951	0.	7.	53.	0.	27.	-20.	4.	1.	0.53	0.68	0.10	11.7	8.41	1333.1	0	3.1	1.42	101
STIRL	28951	43.	1.	5.	-43.	32.	28.	4.	3.	0.25	0.68	0.25	2.7	1.92	211.2	3	2.2	1.01	135
STIRL	28951	0.	45.	5.	0.	-11.	28.	4.	3.	0.25	0.68	0.25	2.7	1.92	211.4	17	2.0	0.89	132
STIRL	28951	0.	1.	48.	0.	32.	-15.	4.	3.	0.42	0.68	0.25	5.0	3.55	390.2	12	1.9	0.84	121
HEGT85	28951	0.	0.	55.	0.	33.	-23.	A 4.	4.	0.79	0.68	0.16	15.5	11.13	956.9	0	3.4	1.53	129
HEGT85	28951	0.	0.	54.	0.	45.	-21.	A 4.	9.	0.89	0.68	0.20	23.3	16.70	849.9	0	4.1	1.85	122
HEGT60	28951	0.	0.	55.	0.	33.	-22.	A 4.	4.	0.68	0.68	0.17	14.0	10.05	875.4	0	3.1	1.40	127
HEGT60	28951	0.	0.	57.	0.	34.	-22.	A 4.	4.	0.59	0.68	0.18	14.2	10.19	843.8	0	3.0	1.36	116
HEGT00	28951	0.	5.	56.	0.	29.	-23.	A 4.	2.	0.41	0.68	0.09	8.6	6.16	741.1	0	2.6	1.17	100
FCMCL	28951	0.	1.	44.	0.	33.	-11.	4.	4.	0.56	0.68	0.32	10.3	7.42	838.2	2	2.5	1.12	130
FCSTCL	28951	0.	0.	42.	0.	33.	-10.	4.	4.	0.79	0.68	0.36	11.3	8.12	911.1	0	2.8	1.24	148
FCSTCL	28951	0.	0.	52.	0.	39.	-2.	4.	6.	0.74	0.68	0.41	12.9	9.25	838.9	1	2.7	1.20	139
IGGTST	28951	0.	0.	47.	0.	33.	-14.	4.	4.	0.73	0.68	0.29	11.4	8.18	827.7	0	2.8	1.26	139
IGGTST	28951	0.	0.	49.	0.	34.	-13.	4.	4.	0.64	0.68	0.30	11.3	8.14	791.5	1	2.7	1.20	128
GTSOAR	28951	0.	46.	1.	0.	-12.	31.	4.	4.	0.24	0.68	0.29	3.6	2.57	270.9	12	2.0	0.89	133
GTAC08	28951	0.	41.	7.	0.	-8.	25.	4.	3.	0.21	0.68	0.26	2.7	1.97	240.1	19	1.9	0.86	133
GTAC12	28951	0.	43.	1.	0.	-10.	31.	4.	4.	0.23	0.68	0.33	3.0	2.18	242.5	19	1.8	0.83	138
GTAC16	28951	0.	44.	0.	0.	-10.	33.	4.	4.	0.30	0.68	0.34	3.4	2.47	268.3	14	1.9	0.87	150
GTAC16	28951	0.	45.	0.	0.	-11.	35.	4.	4.	0.24	0.68	0.35	3.4	2.42	254.4	17	1.8	0.83	139
GTWC16	28951	0.	46.	0.	0.	-13.	33.	4.	4.	0.32	0.68	0.30	3.8	2.73	281.0	10	2.1	0.93	145
GTWC16	28951	0.	50.	0.	0.	-15.	38.	4.	5.	0.25	0.68	0.31	3.8	2.72	261.5	12	2.0	0.89	135
CC1626	28951	0.	46.	0.	0.	-13.	33.	4.	4.	0.43	0.68	0.30	4.2	3.03	312.0	5	2.2	1.00	145
CC1626	28951	0.	67.	0.	0.	-25.	63.	4.	8.	0.40	0.68	0.36	5.3	3.82	270.8	5	2.2	1.01	134
CC1622	28951	0.	45.	0.	0.	-12.	33.	4.	4.	0.42	0.68	0.32	4.0	2.84	297.9	7	2.2	0.97	147
CC1622	28951	0.	61.	0.	0.	-21.	57.	4.	7.	0.37	0.68	0.37	4.7	3.39	263.7	7	2.1	0.95	137
CC1222	28951	0.	45.	0.	0.	-12.	33.	4.	4.	0.42	0.68	0.32	3.8	2.74	288.6	7	2.1	0.96	148
CC1222	28951	0.	61.	0.	0.	-20.	56.	4.	7.	0.37	0.68	0.37	4.5	3.23	253.8	8	2.1	0.94	137
CC0822	28951	0.	44.	0.	0.	-10.	33.	4.	4.	0.41	0.68	0.34	3.9	2.78	303.6	9	2.1	0.94	150
CC0822	28951	0.	51.	0.	0.	-14.	45.	4.	6.	0.35	0.68	0.38	4.1	2.95	274.3	10	2.0	0.90	140
STIG15	28951	0.	59.	0.	0.	-25.	33.	4.	4.	0.43	0.68	0.11	4.5	3.19	258.3	0	2.6	1.17	125
STIG15	28951	0.	1538.	0.	0.	-1094.	1410.	4.	172.	3.19	0.68	0.17	51.1	36.63	113.3	0	22.2	10.01	288
STIG10	28951	0.	56.	0.	0.	-22.	33.	4.	4.	0.40	0.68	0.16	4.1	2.96	253.3	0	2.4	1.10	130



GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																			
**COGENERATION CASE** **NOCOGEN - COGEN**																			
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD MW	COGEN POWER MW	GCM	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EGVL	ROI (%)	LEVEL CHRG	NORM ENRG	WRTH
STIG10	28951	0.	151.	0.	0.	-88.	130.	4.	16.	0.52	0.68	0.22	7.8	5.61	176.9	0	3.5	1.58	109
STIG1S	28951	0.	54.	0.	0.	-21.	33.	4.	4.	0.39	0.68	0.18	4.0	2.84	249.8	0	2.4	1.07	130
STIG1S	28951	0.	95.	0.	0.	-48.	77.	4.	9.	0.39	0.68	0.23	5.4	3.88	194.6	0	2.7	1.23	119
DEADV3	28951	0.	50.	0.	0.	-17.	33.	4.	4.	0.43	0.68	0.24	5.7	4.07	385.5	0	2.5	1.12	137
DEADV3	28951	0.	86.	0.	0.	-39.	76.	4.	9.	0.43	0.68	0.30	7.9	5.66	314.6	0	2.8	1.24	125
DEHTPM	28951	0.	43.	0.	0.	-9.	33.	4.	4.	0.42	0.68	0.36	5.3	3.81	425.5	5	2.2	0.99	149
DEHTPM	28951	0.	46.	0.	0.	-11.	39.	4.	5.	0.35	0.68	0.38	5.4	3.89	401.6	7	2.1	0.95	139
DESOA3	28951	52.	0.	0.	-52.	33.	33.	4.	4.	0.41	0.68	0.21	4.8	3.42	310.5	0	2.8	1.25	138
DESOA3	28951	100.	0.	0.	-100.	50.	87.	4.	11.	0.48	0.68	0.27	9.3	6.70	318.3	0	3.8	1.71	127
DESOA3	28951	0.	52.	0.	0.	-19.	33.	4.	4.	0.41	0.68	0.21	4.8	3.42	310.5	0	2.4	1.09	134
DESOA3	28951	0.	100.	0.	0.	-51.	87.	4.	11.	0.48	0.68	0.27	9.3	6.70	318.3	0	3.1	1.42	120
GTSOAD	28951	43.	1.	3.	-43.	32.	30.	4.	4.	0.22	0.68	0.30	2.8	2.01	224.6	9	2.1	0.96	140
GTRA08	28951	45.	0.	0.	-45.	33.	33.	4.	4.	0.35	0.68	0.31	4.3	3.07	321.5	0	2.4	1.08	148
GTRA08	28951	55.	0.	0.	-55.	38.	47.	4.	6.	0.28	0.68	0.35	4.7	3.37	290.6	0	2.4	1.08	140
GTRA12	28951	45.	0.	0.	-45.	33.	33.	4.	4.	0.35	0.68	0.32	4.2	3.01	317.2	0	2.4	1.07	149
GTRA12	28951	54.	0.	0.	-54.	38.	47.	4.	6.	0.28	0.68	0.36	4.6	3.30	288.9	0	2.4	1.07	140
GTRA16	28951	45.	0.	0.	-45.	33.	33.	4.	4.	0.35	0.68	0.32	4.4	3.12	329.6	0	2.4	1.08	149
GTRA16	28951	52.	0.	0.	-52.	37.	44.	4.	5.	0.28	0.68	0.35	4.7	3.35	304.3	0	2.4	1.07	140
GTR208	28951	45.	0.	0.	-45.	33.	33.	4.	4.	0.32	0.68	0.32	3.8	2.71	285.5	1	2.3	1.04	150
GTR208	28951	48.	0.	0.	-48.	35.	37.	4.	4.	0.25	0.68	0.33	3.8	2.69	267.5	4	2.2	1.01	140
GTR212	28951	45.	0.	0.	-45.	33.	33.	4.	4.	0.33	0.68	0.31	4.0	2.85	299.2	0	2.3	1.06	149
GTR212	28951	50.	0.	0.	-50.	35.	40.	4.	5.	0.26	0.68	0.33	4.0	2.90	276.8	2	2.3	1.03	140
GTR216	28951	45.	0.	0.	-45.	33.	33.	4.	4.	0.33	0.68	0.32	4.1	2.92	309.5	0	2.3	1.06	150
GTR216	28951	50.	0.	0.	-50.	36.	40.	4.	5.	0.26	0.68	0.34	4.2	3.01	286.8	2	2.3	1.04	140
GTRW08	28951	49.	0.	0.	-49.	33.	33.	4.	4.	0.37	0.68	0.26	4.5	3.19	311.1	0	2.6	1.15	143
GTRW08	28951	67.	0.	0.	-67.	41.	57.	4.	7.	0.31	0.68	0.31	5.3	3.83	269.9	0	2.7	1.22	134
GTRW12	28951	48.	0.	0.	-48.	33.	33.	4.	4.	0.36	0.68	0.28	4.5	3.19	317.9	0	2.5	1.14	145
GTRW12	28951	67.	0.	0.	-67.	41.	58.	4.	7.	0.31	0.68	0.33	5.4	3.88	276.3	0	2.7	1.20	136
GTRW16	28951	48.	0.	0.	-48.	33.	33.	4.	4.	0.37	0.68	0.28	4.6	3.29	328.6	0	2.5	1.14	145
GTRW16	28951	64.	0.	0.	-64.	40.	55.	4.	7.	0.31	0.68	0.33	5.4	3.88	290.3	0	2.6	1.19	136
GTR308	28951	50.	0.	0.	-50.	33.	33.	4.	4.	0.34	0.68	0.25	4.0	2.86	274.1	0	2.5	1.13	143
GTR308	28951	58.	0.	0.	-58.	36.	43.	4.	5.	0.27	0.68	0.27	4.2	3.00	246.2	0	2.5	1.14	133
GTR312	28951	47.	0.	0.	-47.	33.	33.	4.	4.	0.35	0.68	0.28	4.1	2.97	298.3	0	2.5	1.11	146
GTR312	28951	59.	0.	0.	-59.	38.	48.	4.	6.	0.23	0.68	0.32	4.6	3.26	264.5	0	2.5	1.12	137
GTR316	28951	48.	0.	0.	-48.	33.	33.	4.	4.	0.35	0.68	0.28	4.3	3.10	309.8	0	2.5	1.12	145
GTR316	28951	58.	0.	0.	-58.	38.	48.	4.	6.	0.29	0.68	0.32	4.7	3.40	277.0	0	2.5	1.13	136
FCPADS	28951	52.	0.	0.	-52.	33.	33.	4.	4.	0.65	0.68	0.21	4.0	2.90	264.1	0	2.9	1.32	142
FCPADS	28951	118.	0.	0.	-118.	56.	108.	4.	13.	1.47	0.68	0.28	8.6	6.15	249.0	0	4.9	2.19	137
FCMCDS	28951	48.	0.	0.	-48.	33.	33.	4.	4.	0.62	0.68	0.28	4.2	2.98	298.3	0	2.7	1.23	149
FCMCDS	28951	86.	0.	0.	-86.	49.	85.	4.	10.	1.12	0.68	0.36	7.3	5.21	289.0	0	3.7	1.69	141

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																				
**COGENERATION CASE** **NOCOGEN - COGEN**																				
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REGD	COGEN POWER	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVEL CHRG	NORM ENRG	WRTH	
ONOCGN	29111	0.	34.	556.	0.	0.	0.	F	14.	0.	1.47	0.13	0.	23.8	1.00	183.9	0	16.9	1.00	80
STM141	29111	0.	497.	0.	0.	-463.	556.		14.	14.	1.05	0.13	0.16	15.1	0.64	103.7	-16	18.5	1.09	164
STM141	29111	0.	512.	0.	0.	-469.	586.		14.	18.	0.88	0.13	0.19	15.9	0.67	106.1	-15	18.2	1.07	155
STM141	29111	0.	0.	497.	0.	34.	59.	F	14.	14.	2.21	0.13	0.16	33.4	1.40	229.2	17	15.0	0.89	139
STM141	29111	0.	0.	512.	0.	43.	74.	F	14.	18.	1.83	0.13	0.19	29.8	1.25	198.9	32	13.8	0.82	132
STM141	29111	0.	0.	497.	0.	34.	59.	A	14.	14.	2.05	0.13	0.16	26.3	1.10	180.2	59	14.1	0.83	143
STM141	29111	0.	0.	512.	0.	43.	74.	A	14.	18.	1.66	0.13	0.19	21.1	0.89	140.8	999	12.7	0.75	133
STM088	29111	0.	494.	19.	0.	-459.	537.		14.	12.	0.83	0.13	0.13	14.1	0.59	98.6	-16	18.7	1.10	152
STM088	29111	0.	6.	507.	0.	29.	49.	F	14.	12.	1.72	0.13	0.13	27.5	1.16	192.4	38	14.5	0.86	128
STM088	29111	0.	6.	507.	0.	29.	49.	A	14.	12.	1.60	0.13	0.13	19.9	0.84	139.2	999	13.6	0.80	135
PFBSTM	29111	0.	0.	500.	0.	34.	56.		14.	14.	2.64	0.13	0.15	35.9	1.51	244.7	11	15.8	0.93	138
PFBSTM	29111	0.	0.	573.	0.	77.	126.		14.	31.	2.89	0.13	0.26	35.9	1.51	213.9	19	13.9	0.82	130
TISTMT	29111	0.	499.	0.	0.	-465.	556.		14.	14.	1.80	0.13	0.15	44.4	1.87	303.6	0	22.5	1.33	143
TISTMT	29111	0.	619.	0.	0.	-513.	794.		14.	43.	2.77	0.13	0.31	89.1	3.75	490.9	0	26.3	1.55	132
TISTMT	29111	0.	0.	499.	0.	34.	57.		14.	14.	3.03	0.13	0.15	65.6	2.76	448.7	0	19.4	1.14	132
TISTMT	29111	0.	0.	619.	0.	106.	175.		14.	43.	3.99	0.13	0.31	112.8	4.75	622.1	0	21.8	1.29	122
TIHRSG	29111	0.	539.	0.	0.	-504.	556.		14.	14.	2.07	0.13	0.09	58.8	2.47	372.5	0	25.4	1.50	134
TIHRSG	29111	0.	619.	0.	0.	-556.	651.		14.	26.	2.52	0.13	0.13	85.2	3.58	469.9	0	28.9	1.71	124
TIHRSG	29111	0.	0.	539.	0.	34.	17.		14.	14.	3.39	0.13	0.09	82.4	3.46	521.9	0	22.3	1.32	124
TIHRSG	29111	0.	0.	619.	0.	63.	32.		14.	26.	3.77	0.13	0.13	109.0	4.58	601.1	0	24.7	1.46	115
STIRL	29111	528.	0.	0.	-528.	34.	556.		14.	14.	1.20	0.13	0.11	22.1	0.93	142.7	149	24.1	1.43	156
STIRL	29111	744.	0.	0.	-744.	120.	843.		14.	49.	1.49	0.13	0.23	39.3	1.65	180.1	0	27.6	1.63	134
STIRL	29111	0.	528.	0.	0.	-493.	556.		14.	14.	1.20	0.13	0.11	22.1	0.93	142.8	-77	20.4	1.20	150
STIRL	29111	0.	744.	0.	0.	-624.	843.		14.	49.	1.49	0.13	0.23	39.3	1.65	180.3	0	22.3	1.32	126
STIRL	29111	0.	0.	528.	0.	34.	28.		14.	14.	2.39	0.13	0.11	41.3	1.74	267.0	7	16.5	0.98	130
STIRL	29111	0.	0.	744.	0.	120.	99.		14.	49.	2.99	0.13	0.23	69.4	2.92	318.3	5	17.0	1.00	108
HEGT60	29111	0.	0.	586.	0.	34.	-32.	A	14.	14.	2.61	0.13	0.00	52.3	2.20	303.5	0	19.1	1.13	117
HEGT60	29111	0.	0.	2144.	0.	399.	-367.	A	14.	163.	7.44	0.13	0.01	182.0	7.65	289.6	0	36.7	2.17	79
HEGT00	29111	0.	0.	564.	0.	34.	-7.	A	14.	14.	2.55	0.13	0.05	49.6	2.09	300.4	0	18.3	1.08	121
HEGT00	29111	0.	0.	804.	0.	102.	-22.	A	14.	41.	3.10	0.13	0.09	72.0	3.03	305.5	0	20.2	1.19	99
FCMCCL	29111	0.	0.	511.	0.	34.	45.		14.	14.	2.72	0.13	0.13	48.4	2.04	323.3	3	17.5	1.04	132
FCMCCL	29111	0.	0.	797.	0.	174.	227.		14.	71.	4.75	0.13	0.34	83.8	3.52	358.9	4	17.2	1.02	109
FCSTCL	29111	0.	0.	508.	0.	34.	48.		14.	14.	2.72	0.13	0.14	47.4	1.99	318.3	3	17.4	1.03	133
FCSTCL	29111	0.	0.	915.	0.	243.	339.		14.	99.	5.57	0.13	0.39	97.4	4.10	363.3	6	16.1	0.95	106
IGGTST	29111	0.	0.	527.	0.	34.	30.		14.	14.	2.46	0.13	0.11	46.5	1.95	301.2	3	17.3	1.02	129
IGGTST	29111	0.	0.	852.	0.	165.	143.		14.	67.	2.71	0.13	0.27	74.9	3.15	299.8	6	16.0	0.94	101
GTSOAR	29111	0.	530.	0.	0.	-496.	556.		14.	14.	1.13	0.13	0.10	21.9	0.92	140.6	-71	20.3	1.20	150
GTSOAR	29111	0.	963.	0.	0.	-762.	1113.		14.	82.	1.32	0.13	0.27	34.3	1.44	121.7	0	21.9	1.29	120
GTAC08	29111	0.	511.	0.	0.	-476.	556.		14.	14.	1.03	0.13	0.14	17.7	0.74	118.3	-24	19.2	1.13	158
GTAC08	29111	0.	727.	0.	0.	-586.	913.		14.	58.	1.01	0.13	0.31	23.5	0.99	110.3	-55	17.8	1.05	137
GTAC12	29111	0.	512.	0.	0.	-478.	556.		14.	14.	1.10	0.13	0.13	20.9	0.88	138.8	-44	19.6	1.16	154
GTAC12	29111	0.	810.	0.	0.	-632.	1036.		14.	72.	1.14	0.13	0.33	28.2	1.19	118.9	0	18.1	1.07	130
GTAC16	29111	0.	516.	0.	0.	-481.	556.		14.	14.	1.11	0.13	0.13	21.3	0.90	141.0	-52	19.8	1.17	153

HONEYWELL PAGE PRINTING SYSTEM- P1188-02

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----

ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQLV	ROI (%)	LEVL CHRG	NORM WRTH ENRG
GTAC16	29111	0.	888.	0.	0.	-682.	1132.	14.	84.	1.27	0.13	0.34	32.8	1.38	126.1	0	18.9	1.11 125
GTWC16	29111	0.	520.	0.	0.	-486.	556.	14.	14.	1.12	0.13	0.12	21.5	0.91	141.1	-58	20.0	1.18 152
GTWC16	29111	0.	925.	0.	0.	-715.	1142.	14.	85.	1.23	0.13	0.32	30.8	1.30	113.7	0	19.5	1.15 125
CC1626	29111	0.	522.	0.	0.	-488.	556.	14.	14.	1.21	0.13	0.12	21.6	0.91	141.2	-76	20.2	1.19 152
CC1626	29111	0.	1168.	0.	0.	-861.	1472.	14.	126.	1.69	0.13	0.34	41.8	1.76	122.0	0	20.9	1.23 118
CC1622	29111	0.	519.	0.	0.	-484.	556.	14.	14.	1.20	0.13	0.12	21.4	0.90	140.5	-67	20.0	1.18 153
CC1622	29111	0.	1066.	0.	0.	-790.	1367.	14.	113.	1.60	0.13	0.35	39.9	1.68	127.6	0	19.9	1.18 120
CC1222	29111	0.	518.	0.	0.	-484.	556.	14.	14.	1.20	0.13	0.12	21.0	0.88	138.3	-58	20.0	1.18 153
CC1222	29111	0.	1057.	0.	0.	-782.	1360.	14.	112.	1.57	0.13	0.35	37.7	1.59	121.8	0	19.5	1.15 121
CC0822	29111	0.	513.	0.	0.	-479.	556.	14.	14.	1.20	0.13	0.13	21.1	0.89	140.1	-56	19.8	1.17 154
CC0822	29111	0.	893.	0.	0.	-677.	1165.	14.	88.	1.37	0.13	0.35	31.0	1.30	118.5	0	18.2	1.07 127
DEHTPM	29111	0.	525.	0.	0.	-491.	556.	14.	14.	1.37	0.13	0.11	27.6	1.16	179.2	0	21.0	1.24 146
DEHTPM	29111	0.	872.	0.	0.	-696.	1032.	14.	72.	2.26	0.13	0.28	65.5	2.76	256.4	0	25.3	1.49 117
GTSCAD	29111	517.	0.	0.	-517.	34.	556.	14.	14.	1.09	0.13	0.12	20.2	0.85	133.5	-81	23.4	1.38 159
GTSCAD	29111	826.	0.	0.	-826.	173.	1022.	14.	71.	1.06	0.13	0.31	25.0	1.05	103.2	0	24.5	1.45 140
GTRA08	29111	530.	0.	0.	-530.	34.	556.	14.	14.	1.14	0.13	0.10	22.3	0.94	143.9	169	24.2	1.43 155
GTRA08	29111	1316.	0.	0.	-1316.	338.	1571.	14.	138.	1.87	0.13	0.31	54.2	2.28	140.7	0	34.0	2.01 128
GTRA12	29111	527.	0.	0.	-527.	34.	556.	14.	14.	1.14	0.13	0.11	22.4	0.94	144.8	167	24.1	1.42 156
GTRA12	29111	1235.	0.	0.	-1235.	318.	1505.	14.	130.	1.72	0.13	0.32	48.7	2.05	134.4	0	31.7	1.87 128
GTRA16	29111	526.	0.	0.	-526.	34.	556.	14.	14.	1.15	0.13	0.11	22.8	0.96	148.2	999	24.1	1.42 155
GTRA16	29111	1151.	0.	0.	-1151.	289.	1408.	14.	118.	1.69	0.13	0.32	48.0	2.02	142.2	0	30.7	1.82 128
GTR208	29111	525.	0.	0.	-525.	34.	556.	14.	14.	1.12	0.13	0.11	21.7	0.91	140.8	124	23.9	1.41 157
GTR208	29111	999.	0.	0.	-999.	230.	1211.	14.	94.	1.39	0.13	0.31	36.9	1.55	125.9	0	28.2	1.67 131
GTR212	29111	525.	0.	0.	-525.	34.	556.	14.	14.	1.13	0.13	0.11	22.0	0.92	143.0	140	23.9	1.41 156
GTR212	29111	1040.	0.	0.	-1040.	247.	1267.	14.	101.	1.47	0.13	0.31	39.7	1.67	130.1	0	28.8	1.70 130
GTR216	29111	523.	0.	0.	-523.	34.	556.	14.	14.	1.14	0.13	0.11	22.3	0.94	145.4	160	23.9	1.41 156
GTR216	29111	1050.	0.	0.	-1050.	254.	1292.	14.	104.	1.54	0.13	0.32	42.6	1.79	138.5	0	28.9	1.71 129
GTRW08	29111	539.	0.	0.	-539.	34.	556.	14.	14.	1.14	0.13	0.09	22.4	0.94	141.7	179	24.6	1.45 154
GTRW08	29111	1564.	0.	0.	-1564.	395.	1762.	14.	161.	1.98	0.13	0.27	57.2	2.41	124.9	0	39.4	2.33 129
GTRW12	29111	533.	0.	0.	-533.	34.	556.	14.	14.	1.14	0.13	0.10	22.4	0.94	143.1	173	24.3	1.44 155
GTRW12	29111	1484.	0.	0.	-1484.	388.	1741.	14.	158.	1.79	0.13	0.30	49.9	2.10	114.7	0	35.8	2.12 130
GTRW16	29111	532.	0.	0.	-532.	34.	556.	14.	14.	1.15	0.13	0.10	22.7	0.95	145.8	206	24.3	1.44 155
GTRW16	29111	1360.	0.	0.	-1360.	349.	1609.	14.	142.	1.73	0.13	0.31	48.4	2.03	121.4	0	34.0	2.01 129
GTR308	29111	544.	0.	0.	-544.	34.	556.	14.	14.	1.13	0.13	0.08	21.8	0.92	136.7	142	24.7	1.46 154
GTR308	29111	1316.	0.	0.	-1316.	293.	1422.	14.	120.	1.49	0.13	0.23	39.0	1.64	101.1	0	35.6	2.11 128
GTR312	29111	529.	0.	0.	-529.	34.	556.	14.	14.	1.13	0.13	0.10	21.8	0.92	141.0	136	24.1	1.42 156
GTR312	29111	1180.	0.	0.	-1180.	290.	1412.	14.	118.	1.50	0.13	0.31	40.3	1.69	116.5	0	30.8	1.82 129
GTR316	29111	529.	0.	0.	-529.	34.	556.	14.	14.	1.14	0.13	0.10	22.2	0.94	143.4	160	24.1	1.43 156
GTR316	29111	1169.	0.	0.	-1169.	285.	1395.	14.	116.	1.53	0.13	0.30	41.4	1.74	120.7	0	30.9	1.83 129
FCPADS	29111	542.	0.	0.	-542.	34.	556.	14.	14.	2.45	0.13	0.08	24.7	1.04	155.8	0	26.2	1.55 153
FCPADS	29111	2206.	0.	0.	-2206.	602.	2458.	14.	246.	27.73	0.13	0.28	141.3	5.94	218.6	0	81.9	4.84 180
FCHCDS	29111	525.	0.	0.	-525.	34.	556.	14.	14.	2.35	0.13	0.11	25.2	1.06	164.0	0	25.5	1.51 155
FCHCDS	29111	1609.	0.	0.	-1609.	477.	2037.	14.	194.	20.74	0.13	0.36	121.2	5.10	257.0	0	59.9	3.54 160

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----

\*\*COGENERATION CASE\*\* \*\*NOCOGEN - COGEN\*\*

ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM ENRG	WRTH
ONOCGN	29112	0.	128.	1995.	0.	0.	0.	F 52.	0.	3.85	0.13	0.	77.5	1.00	168.7	0	58.8	1.00	80
STM141	29112	0.	1777.	0.	0.	-1649.	1995.	52.	52.	2.08	0.13	0.16	44.9	0.58	86.2	-14	63.6	1.08	167
STM141	29112	0.	1811.	0.	0.	-1663.	2064.	52.	60.	1.80	0.13	0.18	44.0	0.57	83.0	-12	62.6	1.06	158
STM141	29112	0.	0.	1777.	0.	128.	218.	F 52.	52.	4.99	0.13	0.16	90.4	1.17	173.6	48	47.6	0.81	142
STM141	29112	0.	0.	1811.	0.	148.	253.	F 52.	60.	4.69	0.13	0.18	93.8	1.21	176.7	43	46.6	0.79	132
STM141	29112	0.	0.	1777.	0.	128.	218.	A 52.	52.	4.87	0.13	0.16	72.0	0.93	138.4	999	45.5	0.77	147
STM141	29112	0.	0.	1811.	0.	148.	253.	A 52.	60.	4.50	0.13	0.18	69.6	0.90	131.2	999	43.8	0.75	138
STN088	29112	0.	1758.	101.	0.	-1630.	1894.	52.	40.	1.69	0.13	0.12	39.8	0.51	78.7	-15	65.2	1.11	155
STN088	29112	0.	30.	1829.	0.	97.	167.	F 52.	40.	4.36	0.13	0.12	87.7	1.13	173.3	48	50.0	0.85	127
STN088	29112	0.	30.	1829.	0.	97.	167.	A 52.	40.	4.20	0.13	0.12	61.3	0.79	121.0	999	46.9	0.80	135
PFBSTM	29112	0.	0.	1788.	0.	128.	207.	52.	52.	6.57	0.13	0.16	91.5	1.18	174.7	38	49.5	0.84	142
PFBSTM	29112	0.	0.	2030.	0.	260.	436.	52.	109.	7.86	0.13	0.26	84.8	1.09	142.5	103	43.0	0.73	136
T1STMT	29112	0.	1783.	0.	0.	-1656.	1995.	52.	52.	4.21	0.13	0.16	126.0	1.63	241.1	0	74.7	1.27	145
T1STMT	29112	0.	2190.	0.	0.	-1821.	2803.	52.	150.	6.71	0.13	0.31	234.2	3.02	364.9	0	81.9	1.39	132
T1STMT	29112	0.	0.	1783.	0.	128.	212.	52.	52.	7.18	0.13	0.16	177.6	2.29	339.8	4	59.4	1.01	132
T1STMT	29112	0.	0.	2190.	0.	369.	613.	52.	150.	9.91	0.13	0.31	294.5	3.80	458.9	3	62.4	1.06	120
TIHRSG	29112	0.	1930.	0.	0.	-1803.	1995.	52.	52.	4.95	0.13	0.09	160.8	2.07	284.4	0	83.4	1.42	136
TIHRSG	29112	0.	2200.	0.	0.	-1977.	2313.	52.	91.	6.28	0.13	0.13	226.2	2.92	351.0	0	92.4	1.57	125
TIHRSG	29112	0.	0.	1930.	0.	128.	65.	52.	52.	8.09	0.13	0.09	213.4	2.75	377.4	0	66.9	1.14	124
TIHRSG	29112	0.	0.	2200.	0.	222.	113.	52.	91.	9.61	0.13	0.13	286.8	3.70	444.9	0	73.5	1.25	113
STIRL	29112	1890.	0.	0.	-1890.	128.	1995.	52.	52.	2.92	0.13	0.11	76.7	0.99	138.6	999	84.8	1.44	155
STIRL	29112	2644.	0.	0.	-2644.	427.	2997.	52.	174.	4.15	0.13	0.23	133.8	1.73	172.7	0	96.9	1.65	134
STIRL	29112	0.	1890.	0.	0.	-1762.	1995.	52.	52.	2.92	0.13	0.11	76.8	0.99	138.7	999	71.3	1.21	149
STIRL	29112	0.	2644.	0.	0.	-2218.	2997.	52.	174.	4.15	0.13	0.23	134.0	1.73	173.0	0	77.9	1.32	126
STIRL	29112	0.	0.	1890.	0.	128.	105.	52.	52.	6.06	0.13	0.11	130.0	1.68	234.8	10	54.8	0.93	130
STIRL	29112	0.	0.	2644.	0.	427.	353.	52.	174.	8.92	0.13	0.23	239.3	3.09	308.7	5	58.4	0.99	108
HEGT60	29112	0.	0.	2112.	0.	128.	-117.	A 52.	52.	6.64	0.13	0.00	147.7	1.91	238.7	1	61.7	1.05	117
HEGT60	29112	0.	0.	7623.	0.	1419.	-1304.	A 52.	579.	22.61	0.13	0.01	545.7	7.04	244.3	0	116.1	1.98	75
HEGT00	29112	0.	0.	2023.	0.	128.	-28.	A 52.	52.	6.25	0.13	0.05	130.7	1.69	220.4	6	57.8	0.98	123
HEGT00	29112	0.	0.	2857.	0.	361.	-79.	A 52.	147.	8.12	0.13	0.09	176.8	2.28	211.2	3	60.8	1.03	101
FCMCCL	29112	0.	0.	1829.	0.	128.	167.	52.	52.	6.95	0.13	0.14	131.1	1.69	244.7	9	55.3	0.94	134
FCMCCL	29112	0.	0.	2832.	0.	619.	808.	52.	252.	13.65	0.13	0.34	212.3	2.74	255.8	10	49.1	0.83	109
FCSTCL	29112	0.	0.	1817.	0.	128.	178.	52.	52.	6.79	0.13	0.14	128.9	1.66	242.0	10	54.7	0.93	134
FCSTCL	29112	0.	0.	3238.	0.	855.	1193.	52.	349.	15.82	0.13	0.39	245.9	3.17	259.1	11	43.0	0.73	104
IGGTST	29112	0.	0.	1886.	0.	128.	109.	52.	52.	5.43	0.13	0.11	121.7	1.57	220.3	12	53.8	0.92	131
IGGTST	29112	0.	0.	3015.	0.	581.	497.	52.	237.	6.38	0.13	0.26	206.4	2.66	233.6	11	47.7	0.81	102
GTSOAR	29112	0.	1900.	0.	0.	-1772.	1995.	52.	52.	2.36	0.13	0.11	58.3	0.75	104.7	-31	69.1	1.17	155
GTSOAR	29112	0.	3422.	0.	0.	-2709.	3956.	52.	291.	3.50	0.13	0.27	110.6	1.43	110.3	0	75.9	1.29	122
GTAC08	29112	0.	1827.	0.	0.	-1699.	1995.	52.	52.	2.28	0.13	0.14	55.1	0.71	103.0	-23	66.3	1.13	160
GTAC08	29112	0.	2584.	0.	0.	-2082.	3247.	52.	204.	2.57	0.13	0.31	76.3	0.98	100.8	-57	62.1	1.06	139
GTAC12	29112	0.	1833.	0.	0.	-1706.	1995.	52.	52.	2.31	0.13	0.14	56.6	0.73	105.4	-25	66.7	1.13	159
GTAC12	29112	0.	2879.	0.	0.	-2248.	3681.	52.	257.	2.99	0.13	0.33	92.2	1.19	109.3	0	62.9	1.07	131
GTAC16	29112	0.	1845.	0.	0.	-1717.	1995.	52.	52.	2.34	0.13	0.13	58.1	0.75	107.4	-27	67.3	1.14	158

HONEYWELL PAGE PRINTING SYSTEM - P1188-02

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

ECS	PROCS	FUEL USE IN BTU*10**6		COGEN** POWER REQD MW	08N	POWER /HEAT RATIO	CAPITAL COST *10**6	NORM COST	\$/KW EQLV	LEVEL CHRG	NORM WRTH ENRG
		COAL	DISTIL RESIDL								
GTAC16	29112	0.	3158.	52.	299.	3.49	111.3	1.44	120.3	0	65.9
GTWC16	29112	0.	1863.	52.	52.	2.32	111.3	0.74	104.6	-27	67.7
CC1626	29112	0.	1870.	52.	304.	3.15	97.2	1.25	100.8	0	67.3
CC1626	29112	0.	4134.	52.	52.	2.44	57.3	0.74	104.5	-30	68.2
CC1622	29112	0.	1857.	52.	442.	4.23	128.9	1.66	106.4	0	70.9
CC1622	29112	0.	3773.	52.	52.	2.44	57.9	1.70	119.4	0	68.9
CC1222	29112	0.	1854.	52.	397.	4.18	132.0	1.70	119.4	0	68.9
CC0822	29112	0.	3738.	52.	52.	2.43	56.8	0.73	104.6	-28	67.7
CC0822	29112	0.	1835.	52.	394.	4.05	123.2	1.59	112.5	0	67.3
CC0822	29112	0.	3159.	52.	52.	2.42	56.1	0.72	104.3	-26	67.0
DEHTPM	29112	0.	1800.	52.	310.	3.26	94.0	1.21	101.5	0	61.9
DEHTPM	29112	0.	3100.	52.	52.	3.21	86.0	1.11	156.2	0	72.2
GTSOAD	29112	1851.	0.	52.	256.	6.63	225.6	2.91	248.3	C	88.0
GTSOAD	29112	2937.	0.	52.	52.	2.26	54.4	0.70	100.3	-49	80.3
GTRA08	29112	1899.	0.	52.	251.	2.80	84.3	1.09	98.0	0	86.1
GTRA08	29112	4677.	0.	52.	52.	2.39	59.8	0.77	107.5	-65	82.9
GTRA12	29112	1887.	0.	52.	489.	5.11	171.6	2.21	125.2	0	117.4
GTRA12	29112	4391.	0.	52.	52.	2.40	60.3	0.78	109.0	-65	82.5
GTRA16	29112	1882.	0.	52.	461.	4.94	165.6	2.14	128.7	0	111.3
GTRA16	29112	4091.	0.	52.	52.	2.43	61.4	0.79	111.4	-69	82.4
GTR208	29112	1878.	0.	52.	418.	4.87	163.5	2.11	135.4	0	107.8
GTR208	29112	3552.	0.	52.	52.	2.35	58.2	0.75	105.7	-59	81.8
GTR212	29112	1878.	0.	52.	333.	3.72	119.3	1.54	114.7	0	98.2
GTR212	29112	3698.	0.	52.	52.	2.37	59.0	0.76	107.2	-61	82.0
GTR216	29112	1873.	0.	52.	359.	3.97	128.7	1.66	118.8	0	100.2
GTR216	29112	3731.	0.	52.	52.	2.40	60.2	0.78	109.6	-64	81.9
GTRV08	29112	1931.	0.	52.	369.	4.23	139.0	1.79	127.1	0	100.6
GTRV08	29112	5559.	0.	52.	52.	2.46	62.5	0.81	110.5	-78	84.5
GTRV12	29112	1911.	0.	52.	572.	4.87	159.3	2.06	98.1	0	133.7
GTRV12	29112	5273.	0.	52.	52.	2.45	62.5	0.81	111.6	-76	83.7
GTRV16	29112	1904.	0.	52.	563.	4.81	158.1	2.04	102.3	0	124.2
GTRV16	29112	4833.	0.	52.	52.	2.39	59.8	0.77	107.3	-66	83.1
GTR308	29112	1949.	0.	52.	506.	4.66	153.3	1.98	108.3	0	117.9
GTR308	29112	4676.	0.	52.	52.	2.36	58.0	0.75	101.6	-64	84.6
GTR312	29112	1893.	0.	52.	425.	4.07	130.0	1.68	94.9	0	125.0
GTR312	29112	4194.	0.	52.	52.	2.34	57.6	0.75	104.3	-59	82.4
GTR316	29112	1894.	0.	52.	420.	4.03	129.7	1.67	105.5	0	137.0
GTR316	29112	4157.	0.	52.	52.	2.36	58.7	0.76	105.8	-61	82.6
FCPADS	29112	1942.	0.	52.	413.	4.12	133.3	1.72	109.4	0	107.5
FCPADS	29112	7841.	0.	52.	52.	7.71	77.8	1.00	136.6	959	91.8
FCMCDS	29112	1881.	0.	52.	873.	96.88	459.1	5.92	199.8	C	265.5
FCMCDS	29112	5721.	0.	52.	52.	7.36	79.6	1.03	144.5	0	89.2
FCMCDS	29112	1694.	0.	52.	691.	72.32	397.3	5.12	237.0	0	208.5

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																			
**COGENERATION CASE** **NOCOGEN - COGEN**																			
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD	COGEN POWER	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EOVL	ROI (%)	LEVL CHRG	NORM WRTH ENRG	
ONCOGN	29113	0.	309.	4613.	0.	0.	0.	F 126.	0.	7.69	0.14	0.	167.8	1.00	160.0	0	134.5	1.00	80
STM141	29113	0.	4085.	0.	0.	-3776.	4613.	126.	126.	3.75	0.14	0.17	100.3	0.60	83.8	-14	144.8	1.08	167
STM141	29113	0.	4165.	0.	0.	-3807.	4777.	126.	146.	3.30	0.14	0.19	96.1	0.57	78.7	-12	142.4	1.06	159
STM141	29113	0.	0.	4005.	0.	309.	529.	F 126.	126.	9.85	0.14	0.17	202.1	1.20	168.8	45	107.3	0.80	142
STM141	29113	0.	0.	4165.	0.	358.	612.	F 126.	146.	9.50	0.14	0.19	206.5	1.23	169.2	44	104.9	0.78	132
STM141	29113	0.	0.	4085.	0.	309.	529.	A 126.	126.	9.51	0.14	0.17	150.5	0.90	125.7	999	101.4	0.75	148
STM141	29113	0.	0.	4165.	0.	358.	612.	A 126.	146.	9.10	0.14	0.19	145.2	0.87	119.0	999	97.8	0.73	140
STM088	29113	0.	4041.	229.	0.	-3732.	4365.	126.	98.	3.00	0.14	0.13	84.5	0.50	72.6	-15	148.1	1.10	156
STM088	29113	0.	68.	4201.	0.	241.	412.	F 126.	98.	8.49	0.14	0.13	182.0	1.08	156.3	82	111.1	0.83	129
STM088	29113	0.	68.	4201.	0.	241.	412.	A 126.	98.	8.70	0.14	0.13	137.8	0.82	118.4	999	106.5	0.79	135
PFBSTM	29113	0.	0.	4109.	0.	309.	505.	126.	126.	12.85	0.14	0.17	174.4	1.04	144.9	179	107.7	0.80	145
PFBSTM	29113	0.	0.	4665.	0.	633.	1034.	126.	258.	17.06	0.14	0.26	191.1	1.14	139.8	78	97.3	0.72	136
TISTMT	29113	0.	4099.	0.	0.	-3790.	4613.	126.	126.	7.71	0.14	0.17	251.8	1.50	209.6	0	165.6	1.23	147
TISTMT	29113	0.	5037.	0.	0.	-4172.	6477.	126.	353.	15.39	0.14	0.31	566.8	3.38	383.9	0	191.3	1.42	132
TISTMT	29113	0.	0.	4099.	0.	309.	514.	126.	126.	13.55	0.14	0.17	352.7	2.10	293.6	8	127.6	0.95	133
TISTMT	29113	0.	0.	5037.	0.	866.	1440.	126.	353.	22.61	0.14	0.31	715.0	4.26	484.3	3	147.2	1.09	121
TIHRSG	29113	0.	4456.	0.	0.	-4147.	4613.	126.	126.	10.45	0.14	0.09	368.9	2.20	282.5	0	191.4	1.42	135
TIHRSG	29113	0.	5020.	0.	0.	-4512.	5278.	126.	207.	14.47	0.14	0.13	545.4	3.25	370.8	0	215.6	1.60	124
TIHRSG	29113	0.	0.	4456.	0.	309.	157.	126.	126.	17.30	0.14	0.09	496.2	2.96	380.0	0	153.4	1.14	123
TIHRSG	29113	0.	0.	5020.	0.	508.	259.	126.	207.	21.96	0.14	0.13	693.2	4.13	471.3	0	173.4	1.29	113
STIRL	29113	4358.	0.	0.	-4358.	309.	4613.	126.	126.	5.52	0.14	0.11	167.0	1.00	130.8	999	193.4	1.44	156
STIRL	29113	6035.	0.	0.	-6035.	974.	6840.	126.	397.	8.19	0.14	0.23	284.5	1.70	160.9	0	219.1	1.63	136
STIRL	29113	0.	4358.	0.	0.	-4049.	4613.	126.	126.	5.52	0.14	0.11	167.2	1.00	130.9	999	162.0	1.20	150
STIRL	29113	0.	6035.	0.	0.	-5061.	6840.	126.	397.	8.20	0.14	0.23	284.9	1.70	161.1	0	175.7	1.31	128
STIRL	29113	0.	0.	4358.	0.	309.	255.	126.	126.	12.33	0.14	0.11	295.2	1.76	231.2	11	124.1	0.92	129
STIRL	29113	0.	0.	6035.	0.	974.	805.	126.	397.	18.69	0.14	0.23	524.2	3.12	296.4	6	130.8	0.97	108
HEGT60	29113	0.	0.	4897.	0.	309.	-264.	A 126.	126.	12.73	0.14	0.01	286.7	1.71	199.8	5	134.4	1.00	118
HEGT60	29113	0.	0.	17396.	0.	3238.	-2976.	A 126.	1321.	51.49	0.14	0.01	1279.6	7.63	251.0	0	270.1	2.01	76
HEGT00	29113	0.	0.	4681.	0.	309.	-67.	A 126.	126.	12.09	0.14	0.05	256.3	1.53	186.8	11	126.4	0.94	125
HEGT00	29113	0.	0.	6520.	0.	825.	-180.	A 126.	336.	17.45	0.14	0.09	387.4	2.31	202.8	4	137.4	1.02	101
FCMCL	29113	0.	0.	4210.	0.	309.	403.	126.	126.	14.12	0.14	0.14	272.8	1.63	221.1	12	122.2	0.91	135
FCMCL	29113	0.	0.	6462.	0.	1412.	1844.	126.	576.	27.43	0.14	0.34	367.0	2.19	193.8	16	96.7	0.72	112
FCSTCL	29113	0.	0.	4181.	0.	309.	432.	126.	126.	13.65	0.14	0.15	269.6	1.61	220.1	13	120.9	0.90	135
FCSTCL	29113	0.	0.	7445.	0.	1983.	2772.	126.	809.	32.01	0.14	0.39	430.9	2.57	197.5	17	79.4	0.59	105
IGGTST	29113	0.	0.	4346.	0.	309.	268.	126.	126.	10.27	0.14	0.12	255.8	1.52	200.9	15	119.0	0.88	132
IGGTST	29113	0.	0.	6936.	0.	1353.	1172.	126.	552.	12.06	0.14	0.27	419.5	2.50	206.4	13	100.8	0.75	103
GTSOAR	29113	0.	4382.	0.	0.	-4073.	4613.	126.	126.	4.44	0.14	0.11	129.3	0.77	100.7	-34	157.7	1.17	155
GTSOAR	29113	0.	7809.	0.	0.	-6182.	9028.	126.	664.	6.70	0.14	0.27	228.6	1.36	99.9	0	170.9	1.27	123
GTAC08	29113	0.	4205.	0.	0.	-3896.	4613.	126.	126.	4.08	0.14	0.15	115.4	0.69	93.6	-21	150.3	1.12	161
GTAC08	29113	0.	5896.	0.	0.	-4752.	7410.	126.	467.	4.71	0.14	0.31	153.0	0.91	88.6	-21	139.9	1.04	142
GTAC12	29113	0.	4221.	0.	0.	-3912.	4613.	126.	126.	4.17	0.14	0.14	119.2	0.71	96.4	-23	151.2	1.12	160
GTAC12	29113	0.	6570.	0.	0.	-5129.	8400.	126.	587.	5.63	0.14	0.33	188.3	1.12	97.8	0	141.6	1.05	134
GTAC16	29113	0.	4249.	0.	0.	-3940.	4613.	126.	126.	4.33	0.14	0.14	125.8	0.75	101.0	-27	153.0	1.14	158

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																		
**COGENERATION CASE** **NO COGEN - COGEN**																		
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	REQD MW	COGEN MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM WRTH ENRG
GTAC16	29113	0.	7207.	0.	0.	-5534.	9180.	126.	682.	6.58	0.14	0.34	225.1	1.34	106.6	0	147.5	1.10 127
GTWC16	29113	0.	4293.	0.	0.	-3984.	4613.	126.	126.	4.23	0.14	0.13	121.6	0.73	96.7	-26	153.9	1.14 158
GTWC16	29113	0.	7502.	0.	0.	-5804.	9265.	126.	693.	5.75	0.14	0.32	191.3	1.14	87.0	0	150.4	1.12 129
CC1626	29113	0.	4308.	0.	0.	-3999.	4613.	126.	126.	4.38	0.14	0.12	122.1	0.73	96.7	-29	154.9	1.15 158
CC1626	29113	0.	9508.	0.	0.	-6996.	11991.	126.	1025.	7.86	0.14	0.34	258.3	1.54	92.7	0	157.0	1.17 120
CC1622	29113	0.	4277.	0.	0.	-3968.	4613.	126.	126.	4.43	0.14	0.13	125.3	0.75	100.0	-30	154.3	1.15 158
CC1622	29113	0.	8677.	0.	0.	-6421.	11131.	126.	920.	8.02	0.14	0.35	275.7	1.64	108.4	0	153.7	1.14 121
CC1222	29113	0.	4271.	0.	0.	-3962.	4613.	126.	126.	4.40	0.14	0.13	122.9	0.73	98.2	-28	153.8	1.14 158
CC1222	29113	0.	8599.	0.	0.	-6358.	11082.	126.	914.	7.75	0.14	0.35	256.0	1.53	101.6	0	150.1	1.12 122
CC0822	29113	0.	4224.	0.	0.	-3915.	4613.	126.	126.	4.35	0.14	0.14	120.5	0.72	97.4	-25	152.0	1.13 160
CC0822	29113	0.	7267.	0.	0.	-5499.	9495.	126.	721.	6.24	0.14	0.35	199.4	1.19	93.6	0	139.1	1.03 130
DEHTPM	29113	0.	4334.	0.	0.	-4025.	4613.	126.	126.	6.23	0.14	0.12	192.4	1.15	151.5	0	164.6	1.22 147
DEHTPM	29113	0.	7075.	0.	0.	-5644.	8371.	126.	584.	13.41	0.14	0.28	483.4	2.88	233.2	0	197.3	1.47 118
GTSOAD	29113	4265.	0.	0.	-4265.	309.	4613.	126.	126.	4.12	0.14	0.13	117.0	0.70	93.6	-50	183.1	1.36 165
GTSOAD	29113	6703.	0.	0.	-6703.	1407.	8268.	126.	574.	5.00	0.14	0.31	162.7	0.97	82.8	999	193.5	1.44 145
GTRA08	29113	4379.	0.	0.	-4379.	309.	4613.	126.	126.	4.51	0.14	0.11	132.9	0.79	103.6	-73	189.6	1.41 160
GTRA08	29113	10673.	0.	0.	-10673.	2739.	12748.	126.	1117.	10.13	0.14	0.31	361.2	2.15	115.5	0	264.8	1.97 128
GTRA12	29113	4351.	0.	0.	-4351.	309.	4613.	126.	126.	4.42	0.14	0.12	129.4	0.77	101.5	-66	188.0	1.40 161
GTRA12	29113	10021.	0.	0.	-10021.	2578.	12211.	126.	1051.	9.72	0.14	0.32	345.6	2.06	117.7	0	250.4	1.86 129
GTRA16	29113	4338.	0.	0.	-4338.	309.	4613.	126.	126.	4.47	0.14	0.12	131.6	0.78	103.5	-69	187.8	1.40 161
GTRA16	29113	9335.	0.	0.	-9335.	2342.	11419.	126.	955.	9.50	0.14	0.32	338.1	2.02	123.6	0	242.2	1.80 129
GTR208	29113	4329.	0.	0.	-4329.	309.	4613.	126.	126.	4.42	0.14	0.12	129.2	0.77	101.8	-65	187.2	1.39 162
GTR208	29113	8106.	0.	0.	-8106.	1864.	9820.	126.	760.	7.21	0.14	0.31	248.5	1.48	104.6	0	221.8	1.65 133
GTR212	29113	4329.	0.	0.	-4329.	309.	4613.	126.	126.	4.36	0.14	0.12	126.7	0.76	99.9	-62	186.8	1.39 162
GTR212	29113	8440.	0.	0.	-8440.	2002.	10280.	126.	816.	7.74	0.14	0.31	269.0	1.60	108.8	0	226.2	1.68 132
GTR216	29113	4318.	0.	0.	-4318.	309.	4613.	126.	126.	4.42	0.14	0.12	129.5	0.77	102.3	-65	186.8	1.39 162
GTR216	29113	8515.	0.	0.	-8515.	2063.	10484.	126.	841.	8.32	0.14	0.32	292.2	1.74	117.1	0	227.2	1.69 131
GTRW08	29113	4458.	0.	0.	-4458.	309.	4613.	126.	126.	4.37	0.14	0.09	127.0	0.76	97.2	-67	191.9	1.43 160
GTRW03	29113	12687.	0.	0.	-12687.	3201.	14294.	126.	1305.	9.65	0.14	0.27	347.3	2.07	93.4	0	393.6	2.26 131
GTRW12	29113	4409.	0.	0.	-4409.	309.	4613.	126.	126.	4.36	0.14	0.10	126.9	0.76	98.2	-65	190.0	1.41 161
GTRW12	29113	12034.	0.	0.	-12034.	3149.	14119.	126.	1284.	9.53	0.14	0.30	335.3	2.00	95.1	0	280.8	2.09 131
GTRW16	29113	4392.	0.	0.	-4392.	309.	4613.	126.	126.	4.44	0.14	0.11	130.2	0.78	101.2	-69	189.8	1.41 160
GTRW16	29113	11030.	0.	0.	-11030.	2830.	13054.	126.	1154.	9.07	0.14	0.31	318.3	1.90	98.5	0	265.6	1.97 130
GTR308	29113	4501.	0.	0.	-4501.	309.	4613.	126.	126.	4.25	0.14	0.09	121.6	0.72	92.2	-62	192.9	1.43 160
GTR308	29113	10671.	0.	0.	-10671.	2378.	11539.	126.	970.	7.60	0.14	0.23	259.9	1.55	83.1	0	281.2	2.09 130
GTR312	29113	4366.	0.	0.	-4366.	309.	4613.	126.	126.	4.27	0.14	0.11	123.2	0.73	96.3	-59	187.8	1.40 162
GTR312	29113	9571.	0.	0.	-9571.	2353.	11455.	126.	959.	7.59	0.14	0.31	261.4	1.56	93.2	0	240.5	1.79 132
GTR316	29113	4369.	0.	0.	-4369.	309.	4613.	126.	126.	4.31	0.14	0.11	124.8	0.74	97.5	-61	188.1	1.40 162
GTR316	29113	9486.	0.	0.	-9436.	2311.	11316.	126.	942.	7.79	0.14	0.30	269.4	1.61	96.9	0	241.6	1.80 131
FCPADS	29113	4484.	0.	0.	-4484.	309.	4613.	126.	126.	17.46	0.14	0.09	170.6	1.02	129.8	999	210.6	1.57 155
FCPADS	29113	17894.	0.	0.	-17894.	4887.	19941.	126.	1993.	219.61	0.14	0.28	1007.8	6.01	192.2	0	647.3	4.81 180
FCMCDS	29113	4336.	0.	0.	-4336.	309.	4613.	126.	126.	16.62	0.14	0.12	175.4	1.05	138.1	0	204.5	1.52 157
FCMCDS	29113	13056.	0.	0.	-13056.	3866.	16522.	126.	1576.	163.96	0.14	0.36	880.1	5.25	230.0	0	473.4	3.52 159

HONEYWELL PAGE PRINTING SYSTEM- P1185-02

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----

ECS	PROCS	**COGENERATION CASE**				**NO COGEN - COGEN**				POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM ENRG	WRTH
		DISTIL	RESIDL	COAL		DISTIL	RESIDL	COAL													
ONOCGN	33121	0.	147.	602.	0.	0.	0.	A	60.	0.	0.65	2.20	0.	7.4	1.00	230.9	0	18.5	1.00	80	
STM141	33121	0.	261.	468.	0.	-114.	134.		60.	3.	0.45	2.20	0.03	5.4	0.73	152.1	-12	18.7	1.01	106	
STM141	33121	0.	140.	589.	0.	7.	13.	F	60.	3.	0.80	2.20	0.03	10.8	1.46	302.9	7	18.4	1.00	88	
STM141	33121	0.	140.	589.	0.	7.	13.	A	60.	3.	0.70	2.20	0.03	8.5	1.15	238.7	27	18.0	0.98	94	
STM088	33121	0.	259.	479.	0.	-112.	123.		60.	2.	0.42	2.20	0.01	4.6	0.63	136.7	-13	18.8	1.02	105	
STM088	33121	0.	143.	595.	0.	4.	7.	F	60.	2.	0.76	2.20	0.01	9.8	1.33	289.3	3	18.5	1.00	86	
STM088	33121	0.	143.	595.	0.	4.	7.	A	60.	2.	0.67	2.20	0.01	7.9	1.07	233.3	30	18.2	0.99	90	
PFBSTM	33121	0.	132.	577.	0.	16.	25.		60.	6.	1.00	2.20	0.05	13.8	1.86	344.8	7	18.3	0.99	92	
TISTMT	33121	0.	272.	419.	0.	-125.	183.		60.	9.	1.09	2.20	0.08	30.3	4.09	704.0	0	21.1	1.14	90	
TISTMT	33121	0.	125.	565.	0.	22.	37.		60.	9.	1.53	2.20	0.08	38.7	5.22	899.2	0	20.9	1.13	87	
TIHRSG	33121	0.	283.	441.	0.	-136.	161.		60.	6.	0.98	2.20	0.03	29.8	4.02	671.8	0	21.7	1.17	82	
TIHRSG	33121	0.	132.	593.	0.	15.	9.		60.	6.	1.43	2.20	0.03	38.3	5.18	865.4	0	21.6	1.17	79	
STIRL	33121	187.	116.	389.	-187.	31.	213.		60.	13.	0.57	2.20	0.08	10.5	1.42	191.5	0	19.5	1.05	109	
STIRL	33121	0.	303.	389.	0.	-156.	213.		60.	13.	0.57	2.20	0.08	10.5	1.42	191.7	6	18.4	1.00	108	
STIRL	33121	0.	116.	576.	0.	31.	26.		60.	13.	1.01	2.20	0.08	17.9	2.42	327.9	10	17.8	0.96	96	
HEGT00	33121	0.	62.	666.	0.	86.	-64.	A	60.	35.	2.28	2.20	0.03	61.4	8.29	455.3	0	21.9	1.19	92	
HEGT00	33121	0.	122.	606.	0.	25.	-4.	A	60.	10.	1.11	2.20	0.03	26.7	3.60	460.9	0	19.6	1.06	84	
FCMCCL	33121	0.	104.	546.	0.	43.	56.		60.	18.	1.50	2.20	0.13	30.7	4.15	531.2	4	18.6	1.01	100	
FCSTCL	33121	0.	92.	526.	0.	55.	76.		60.	22.	1.75	2.20	0.17	34.3	4.63	538.1	5	18.3	0.99	106	
IGGTST	33121	0.	111.	573.	0.	36.	29.		60.	15.	1.25	2.20	0.09	28.1	3.79	472.7	3	18.9	1.02	94	
GTSOAR	33121	0.	332.	329.	0.	-185.	273.		60.	20.	0.56	2.20	0.12	11.4	1.54	165.7	16	17.8	0.96	115	
GTAC08	33121	0.	292.	376.	0.	-145.	227.		60.	14.	0.46	2.20	0.11	8.3	1.13	157.9	67	17.5	0.95	117	
GTAC12	33121	0.	304.	345.	0.	-157.	257.		60.	18.	0.50	2.20	0.13	9.7	1.30	164.0	36	17.3	0.93	119	
GTAC16	33121	0.	316.	322.	0.	-168.	280.		60.	21.	0.55	2.20	0.15	11.1	1.50	172.3	26	17.2	0.93	119	
GTWC16	33121	0.	325.	319.	0.	-177.	283.		60.	21.	0.56	2.20	0.14	11.3	1.52	167.6	23	17.4	0.94	118	
CC1626	33121	0.	354.	258.	0.	-207.	344.		60.	29.	0.75	2.20	0.18	13.7	1.85	168.7	18	17.1	0.92	122	
CC1622	33121	0.	338.	282.	0.	-190.	320.		60.	26.	0.71	2.20	0.17	12.9	1.74	173.2	19	17.1	0.93	121	
CC1222	33121	0.	336.	284.	0.	-188.	318.		60.	25.	0.70	2.20	0.17	12.2	1.65	165.8	22	17.1	0.92	122	
CC0822	33121	0.	311.	330.	0.	-163.	272.		60.	20.	0.64	2.20	0.14	10.5	1.42	169.0	26	17.3	0.94	120	
DEADV3	33121	0.	548.	5.	0.	-400.	597.		60.	59.	1.46	2.20	0.26	40.1	5.42	250.8	3	19.2	1.04	123	
DEHTPM	33121	0.	319.	340.	0.	-171.	262.		60.	19.	0.80	2.20	0.12	17.0	2.29	267.2	4	18.6	1.01	108	
DESOA3	33121	586.	0.	0.	-586.	147.	602.		60.	60.	1.87	2.20	0.22	51.1	6.91	298.1	0	24.8	1.34	134	
DESOA3	33121	682.	0.	0.	-682.	177.	702.		60.	72.	1.99	2.20	0.22	59.8	8.08	299.3	0	26.8	1.45	125	
DESOA3	33121	0.	586.	0.	0.	-438.	602.		60.	60.	1.87	2.20	0.22	51.1	6.91	298.1	0	21.5	1.17	130	
DESOA3	33121	0.	682.	0.	0.	-505.	702.		60.	72.	1.99	2.20	0.22	59.8	8.08	299.3	0	23.0	1.25	120	
GTSOAD	33121	205.	104.	349.	-205.	43.	253.		60.	18.	0.48	2.20	0.12	8.8	1.19	146.4	4	18.5	1.00	121	
GTRA08	33121	313.	67.	224.	-313.	80.	378.		60.	33.	0.71	2.20	0.19	16.0	2.16	174.6	1	18.8	1.02	124	
GTRA12	33121	297.	71.	237.	-297.	76.	365.		60.	31.	0.70	2.20	0.19	15.8	2.13	181.3	2	18.7	1.01	124	
GTRA16	33121	278.	77.	259.	-278.	70.	343.		60.	28.	0.69	2.20	0.18	15.7	2.12	192.2	1	18.8	1.02	121	
GTR208	33121	244.	91.	305.	-244.	56.	297.		60.	23.	0.58	2.20	0.15	12.1	1.63	168.6	0	18.7	1.01	120	
GTR212	33121	254.	87.	291.	-254.	60.	311.		60.	25.	0.61	2.20	0.16	13.0	1.76	175.0	0	18.7	1.01	121	
GTR216	33121	256.	85.	285.	-256.	62.	317.		60.	25.	0.63	2.20	0.16	13.8	1.87	184.2	1	18.7	1.01	121	
GTRW08	33121	374.	53.	177.	-374.	94.	425.		60.	38.	0.76	2.20	0.19	17.4	2.34	158.3	0	19.3	1.05	125	

HONEYWELL PAGE PRINTING SYSTEM- P1185-02



GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----

ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM WRTH ENRG
GTRW12	33121	358.	54.	179.	-358.	94.	423.	60.	38.	0.75	2.20	0.21	17.2	2.33	164.3	0	18.9	1.02 126
GTRW16	33121	330.	62.	209.	-330.	85.	393.	60.	35.	0.74	2.20	0.20	16.9	2.28	174.0	0	18.9	1.03 124
GTR308	33121	318.	76.	256.	-318.	71.	347.	60.	29.	0.66	2.20	0.13	13.9	1.87	148.7	0	19.6	1.06 119
GTR312	33121	290.	76.	254.	-290.	71.	348.	60.	29.	0.65	2.20	0.17	13.9	1.87	163.1	0	18.8	1.02 123
GTR316	33121	288.	77.	258.	-288.	70.	344.	60.	29.	0.66	2.20	0.17	14.3	1.94	170.2	0	18.9	1.02 122
FCPADS	33121	540.	0.	0.	-540.	147.	602.	60.	60.	5.62	2.20	0.28	36.3	4.90	229.1	0	25.7	1.39 146
FCPADS	33121	547.	0.	0.	-547.	149.	610.	60.	61.	5.64	2.20	0.28	36.8	4.98	229.9	0	25.7	1.39 135
FCMCDS	33121	399.	29.	97.	-399.	118.	505.	60.	48.	4.26	2.20	0.30	31.4	4.25	268.9	0	22.6	1.22 135

HONEYWELL PAGE PRINTING SYSTEM - P1115-02

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----

ECS	**COGENERATION CASE**				**NOCOGEN - COGEN**				POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM WRTH ENRG
	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL												
ONOCGN 33251	0.	687.	2842.	0.	0.	0.	F	280.	0.	2.64	1.05	0.	53.1	1.00	168.8	0	88.3	1.00	80
STM141 33251	0.	1276.	2056.	0.	-590.	787.		280.	30.	1.41	1.05	0.06	31.6	0.60	90.6	999	85.6	0.97	120
STM141 33251	0.	614.	2718.	0.	73.	124.	F	280.	30.	3.13	1.05	0.06	62.1	1.17	177.9	31	83.8	0.95	102
STM141 33251	0.	614.	2718.	0.	73.	124.	A	280.	30.	2.78	1.05	0.06	42.3	0.80	121.0	999	81.3	0.92	111
STM088 33251	0.	1256.	2166.	0.	-569.	677.		280.	16.	1.31	1.05	0.03	28.1	0.53	84.3	-1	87.2	0.99	116
STM088 33251	0.	647.	2774.	0.	40.	68.	F	280.	16.	2.92	1.05	0.03	57.6	1.08	172.6	34	85.8	0.97	96
STM088 33251	0.	647.	2774.	0.	40.	68.	A	280.	16.	2.67	1.05	0.03	40.1	0.76	120.2	999	83.7	0.95	105
PFBSTM 33251	0.	534.	2599.	0.	153.	243.		280.	62.	4.80	1.05	0.11	62.0	1.17	157.8	54	79.1	0.90	115
T1STMT 33251	0.	1306.	1930.	0.	-620.	912.		280.	45.	3.78	1.05	0.08	113.0	2.13	306.3	0	94.4	1.07	99
T1STMT 33251	0.	469.	2482.	0.	217.	360.		280.	89.	6.99	1.05	0.16	211.4	3.98	500.8	3	92.1	1.04	106
TIHRSG 33251	0.	1362.	2045.	0.	-675.	798.		280.	31.	3.60	1.05	0.03	111.7	2.10	297.7	0	97.9	1.11	91
TIHRSG 33251	0.	537.	2750.	0.	150.	92.		280.	61.	6.88	1.05	0.07	210.7	3.97	485.0	0	99.6	1.13	93
ST1RL 33251	928.	533.	1784.	-928.	154.	1059.		280.	63.	2.58	1.05	0.08	65.9	1.24	154.2	0	93.3	1.06	114
ST1RL 33251	0.	1460.	1784.	0.	-774.	1059.		280.	63.	2.58	1.05	0.08	65.9	1.24	154.4	6	88.2	1.00	112
ST1RL 33251	0.	383.	2584.	0.	304.	259.		280.	124.	6.16	1.05	0.16	167.2	3.15	311.6	9	82.5	0.93	110
HEGT60 33251	0.	0.	3355.	0.	687.	-512.	A	280.	280.	11.27	1.05	0.05	279.5	5.27	245.6	5	89.0	1.01	107
HEGT60 33251	0.	0.	3982.	0.	840.	-627.	A	280.	342.	13.86	1.05	0.05	376.5	7.09	284.8	1	101.3	1.15	97
HEGT00 33251	0.	442.	2886.	0.	245.	-44.	A	280.	100.	5.53	1.05	0.06	134.2	2.53	236.4	7	86.4	0.98	99
FCNCL 33251	0.	264.	2818.	0.	423.	24.		280.	172.	8.67	1.05	0.13	160.3	3.02	282.7	9	81.6	0.92	109
FCSTCL 33251	0.	147.	2627.	0.	539.	215.		280.	220.	9.73	1.05	0.21	179.1	3.37	286.5	11	75.3	0.85	118
IGGST 33251	0.	329.	3087.	0.	357.	-245.		280.	146.	4.63	1.05	0.03	142.1	2.68	244.2	9	83.1	0.94	98
GTSOAR 33251	0.	1607.	1489.	0.	-920.	1355.		280.	99.	2.26	1.05	0.12	55.1	1.04	111.2	999	83.1	0.94	125
GTAC08 33251	0.	1408.	1717.	0.	-722.	1125.		280.	71.	1.97	1.05	0.11	45.5	0.86	108.9	999	82.5	0.93	125
GTAC12 33251	0.	1466.	1566.	0.	-779.	1276.		280.	89.	2.13	1.05	0.14	51.2	0.96	114.3	999	81.1	0.92	128
GTAC16 33251	0.	1523.	1452.	0.	-837.	1391.		280.	103.	2.28	1.05	0.16	56.5	1.06	119.0	178	80.4	0.91	129
GTWC16 33251	0.	1568.	1435.	0.	-882.	1407.		280.	105.	2.22	1.05	0.15	53.8	1.01	109.9	999	80.7	0.91	129
CC1626 33251	0.	2711.	0.	0.	-2024.	2842.		280.	280.	3.09	1.05	0.23	86.4	1.63	108.6	22	78.5	0.89	145
CC1626 33251	0.	1716.	1130.	0.	-1029.	1713.		280.	142.	2.60	1.05	0.19	61.4	1.16	109.8	63	78.3	0.89	134
CC1622 33251	0.	1633.	1252.	0.	-947.	1550.		280.	127.	2.57	1.05	0.18	62.2	1.17	118.8	53	79.3	0.90	131
CC1222 33251	0.	1623.	1262.	0.	-937.	1581.		280.	126.	2.53	1.05	0.18	59.6	1.12	114.5	73	79.0	0.89	132
CC0822 33251	0.	1499.	1462.	0.	-812.	1351.		260.	98.	2.24	1.05	0.15	49.5	0.93	106.8	999	80.1	0.91	131
DEADV3 33251	0.	2503.	0.	0.	-1916.	2842.		280.	280.	6.14	1.05	0.26	198.4	3.74	216.1	4	90.5	1.03	138
DEADV3 33251	0.	2713.	0.	0.	-1990.	2965.		280.	295.	6.37	1.05	0.26	207.3	3.90	218.1	2	92.1	1.04	127
DEHTPM 33251	0.	1538.	1542.	0.	-851.	1301.		280.	92.	3.49	1.05	0.13	97.2	1.83	206.4	5	88.4	1.00	114
DESOA3 33251	2766.	0.	0.	-2766.	687.	2842.		280.	280.	7.31	1.05	0.22	244.0	4.60	252.7	0	115.7	1.31	137
DESOA3 33251	3390.	0.	0.	-3390.	880.	3488.		280.	359.	8.85	1.05	0.22	303.5	5.72	264.2	0	130.0	1.47	128
DESOA3 33251	0.	2766.	0.	0.	-2079.	2842.		280.	280.	7.31	1.05	0.22	244.0	4.60	252.7	0	100.5	1.14	133
DESOA3 33251	0.	3390.	0.	0.	-2510.	3488.		280.	359.	8.85	1.05	0.22	303.5	5.72	264.2	0	111.3	1.26	123
GTSCAD 33251	1016.	473.	1585.	-1016.	213.	1257.		280.	87.	2.04	1.05	0.13	47.2	0.89	104.2	999	87.2	0.99	130
GTRA08 33251	2676.	0.	0.	-2676.	687.	2842.		280.	280.	3.61	1.05	0.24	107.8	2.03	130.8	0	95.0	1.08	146
GTRA08 33251	1555.	288.	963.	-1555.	399.	1880.		280.	163.	2.92	1.05	0.20	79.3	1.49	129.8	6	88.0	1.00	133
GTRA12 33251	2669.	0.	0.	-2669.	687.	2842.		280.	280.	3.59	1.05	0.24	108.2	2.04	133.9	0	94.7	1.07	146
GTRA12 33251	1474.	307.	1029.	-1474.	379.	1813.		280.	155.	2.65	1.05	0.20	76.9	1.45	131.0	8	87.3	0.99	133

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----

\*\*COGENERATION CASE\*\* \*\*NOCOGEN - COGEN\*\*

ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EVL	ROI (%)	LEVL CHRG	NORM WRTH ENRG
GTRA16	33251	1382.	340.	1138.	-1382.	347.	1704.	280.	141.	2.82	1.05	0.19	76.4	1.44	136.5	6	87.9	1.00 131
GTR208	33251	1212.	408.	1366.	-1212.	279.	1477.	280.	114.	2.34	1.05	0.15	58.3	1.10	114.2	16	87.6	0.99 130
GTR212	33251	1261.	388.	1297.	-1261.	299.	1545.	280.	122.	2.43	1.05	0.17	61.5	1.16	117.1	14	87.4	0.99 131
GTR216	33251	1271.	379.	1268.	-1271.	308.	1574.	280.	126.	2.52	1.05	0.17	64.9	1.22	123.1	12	87.2	0.99 131
GTRW08	33251	2722.	0.	0.	-2722.	687.	2842.	280.	280.	3.35	1.05	0.23	94.4	1.78	107.4	0	94.6	1.07 147
GTRW08	33251	1859.	218.	729.	-1859.	469.	2113.	280.	191.	2.98	1.05	0.21	80.4	1.51	114.9	0	89.9	1.02 134
GTRW12	33251	2625.	0.	0.	-2625.	687.	2842.	280.	280.	3.33	1.05	0.26	94.1	1.77	110.9	0	91.7	1.04 150
GTRW12	33251	1778.	222.	742.	-1778.	465.	2101.	280.	190.	2.96	1.05	0.22	79.9	1.51	118.2	6	87.8	0.99 136
GTRW16	33251	2676.	0.	0.	-2676.	687.	2842.	280.	280.	3.36	1.05	0.24	96.8	1.82	115.3	0	93.5	1.06 148
GTRW16	33251	1642.	265.	889.	-1642.	421.	1954.	280.	172.	2.72	1.05	0.21	70.9	1.34	111.4	10	87.2	0.99 136
GTR308	33251	3082.	0.	0.	-3082.	687.	2842.	280.	280.	3.04	1.05	0.13	88.9	1.67	98.0	0	104.5	1.18 139
GTR308	33251	1579.	335.	1121.	-1579.	352.	1721.	280.	143.	2.50	1.05	0.14	62.4	1.18	101.1	0	91.5	1.04 130
GTR312	33251	2793.	0.	0.	-2793.	687.	2842.	280.	280.	3.01	1.05	0.21	87.9	1.66	106.6	0	95.7	1.08 146
GTR312	33251	1441.	333.	1113.	-1441.	354.	1729.	280.	144.	2.47	1.05	0.18	62.1	1.17	107.5	15	87.0	0.99 135
GTR316	33251	2818.	0.	0.	-2818.	687.	2842.	280.	280.	2.99	1.05	0.20	90.4	1.70	109.5	0	96.7	1.10 145
GTR316	33251	1429.	339.	1134.	-1429.	348.	1709.	280.	142.	2.50	1.05	0.18	63.3	1.19	110.3	11	87.5	0.99 134
FCPADS	33251	2555.	0.	0.	-2555.	687.	2842.	280.	280.	25.99	1.05	0.28	177.7	3.35	196.6	0	121.1	1.37 150
FCPADS	33251	2718.	0.	0.	-2718.	742.	3028.	280.	303.	27.97	1.05	0.28	189.7	3.57	199.4	0	125.7	1.42 140
FCMCDS	33251	2319.	0.	0.	-2319.	687.	2842.	280.	280.	24.59	1.05	0.34	188.0	3.54	232.8	0	113.7	1.29 155
FCMCDS	33251	1983.	99.	333.	-1983.	587.	2509.	280.	239.	21.25	1.05	0.32	165.5	3.12	224.8	0	108.4	1.23 141

ORIGINAL PAGE IS  
OF POOR QUALITY

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	COGEN**	POWER	COGEN	REQD	POWER	MW	O&M	POWER	FESR	CAPITAL	NORM	\$/KW	ROJ	LEVEL	NORM	WRTH
-----FUEL USE IN BTU*10**6-----																							
**COGENERATION CASE** *NOCOGEN - COGEN**																							
*****																							
ONOCGN	33254	0.	98.	435.	0.	0.	0.	0.	A	40.	0.	0.64	1.50	0.	0.64	7.3	1.00	233.0	0	13.3	1.00	80	
STM141	33254	0.	210.	304.	0.	-112.	131.	40.	F	40.	3.	0.44	1.50	0.04	0.44	5.3	0.73	153.4	-12	13.5	1.02	110	
STM141	33254	0.	91.	423.	0.	7.	12.	F	A	40.	3.	0.79	1.50	0.04	0.79	10.6	1.45	304.9	7	13.2	0.99	92	
STM141	33254	0.	91.	423.	0.	7.	12.	A	A	40.	3.	0.69	1.50	0.04	0.69	10.6	1.15	240.8	27	12.8	0.97	97	
STM088	33254	0.	208.	315.	0.	-110.	120.	40.	F	40.	2.	0.42	1.50	0.02	0.42	4.6	0.63	137.8	-12	13.6	1.02	108	
STM088	33254	0.	94.	429.	0.	4.	7.	F	A	40.	2.	0.76	1.50	0.02	0.76	9.7	1.32	291.2	3	13.3	1.00	89	
STM088	33254	0.	94.	429.	0.	4.	7.	A	A	40.	2.	0.67	1.50	0.02	0.67	9.7	1.07	235.4	30	13.0	0.98	93	
PFBSTM	33254	0.	83.	411.	0.	15.	24.	40.	A	40.	6.	0.99	1.50	0.07	0.99	13.6	1.86	347.5	7	13.1	0.99	98	
TISTMT	33254	0.	220.	256.	0.	-122.	179.	40.	A	40.	9.	1.08	1.50	0.11	1.08	29.8	4.08	708.0	0	15.8	1.19	99	
TISTMT	33254	0.	76.	400.	0.	22.	36.	40.	A	40.	9.	1.51	1.50	0.11	1.51	38.1	5.21	904.4	0	15.7	1.18	96	
TIHRSG	33254	0.	231.	278.	0.	-133.	157.	40.	A	40.	6.	0.97	1.50	0.05	0.97	29.3	4.01	675.6	0	16.4	1.24	89	
TIHRSG	33254	0.	83.	426.	0.	15.	9.	40.	A	40.	6.	1.41	1.50	0.05	1.41	37.7	5.16	870.4	0	16.3	1.23	86	
STIRL	33254	183.	68.	227.	-183.	30.	209.	40.	A	40.	12.	0.56	1.50	0.11	0.56	10.3	1.40	191.7	0	14.2	1.07	118	
STIRL	33254	0.	251.	227.	0.	-152.	209.	40.	A	40.	12.	0.56	1.50	0.11	0.56	10.3	1.41	191.9	6	13.2	1.00	116	
STIRL	33254	0.	68.	410.	0.	30.	26.	40.	A	40.	12.	0.99	1.50	0.11	0.99	17.6	2.41	329.2	10	12.6	0.95	104	
HEGT60	33254	0.	14.	498.	0.	84.	-63.	A	A	40.	34.	2.25	1.50	0.04	2.25	60.4	8.27	458.2	0	16.7	1.26	97	
HEGT00	33254	0.	74.	440.	0.	24.	-4.	A	A	40.	10.	1.09	1.50	0.04	1.09	26.3	3.59	463.9	0	14.4	1.09	90	
FCMCL	33254	0.	56.	380.	0.	42.	55.	40.	A	40.	17.	1.48	1.50	0.18	1.48	30.2	4.14	534.5	4	13.4	1.01	111	
FCSTCL	33254	0.	44.	361.	0.	54.	74.	40.	A	40.	22.	1.72	1.50	0.24	1.72	33.8	4.62	541.5	5	13.1	0.99	118	
IGGTST	33254	0.	63.	407.	0.	36.	28.	40.	A	40.	15.	1.23	1.50	0.12	1.23	27.7	3.78	477.1	3	13.7	1.03	103	
GTSOAR	33254	0.	279.	169.	0.	-181.	267.	40.	A	40.	19.	0.56	1.50	0.16	0.56	11.2	1.53	166.7	16	12.5	0.95	124	
GTAC08	33254	0.	240.	214.	0.	-142.	222.	40.	A	40.	14.	0.46	1.50	0.15	0.46	8.2	1.12	158.9	69	12.6	0.93	126	
GTAC12	33254	0.	252.	184.	0.	-154.	251.	40.	A	40.	18.	0.50	1.50	0.18	0.50	9.5	1.30	164.9	37	12.1	0.91	129	
GTAC16	33254	0.	263.	162.	0.	-165.	274.	40.	A	40.	20.	0.54	1.50	0.20	0.54	10.9	1.49	173.2	26	12.0	0.90	130	
GTVC16	33254	0.	272.	158.	0.	-174.	277.	40.	A	40.	21.	0.55	1.50	0.19	0.55	11.1	1.52	168.6	23	12.2	0.92	128	
CC1626	33254	0.	301.	98.	0.	-203.	337.	40.	A	40.	28.	0.74	1.50	0.25	0.74	13.5	1.85	169.8	18	11.9	0.90	133	
CC1622	33254	0.	284.	123.	0.	-186.	313.	40.	A	40.	25.	0.70	1.50	0.24	0.70	12.6	1.73	174.1	19	12.0	0.90	132	
CC1222	33254	0.	283.	124.	0.	-184.	311.	40.	A	40.	25.	0.69	1.50	0.24	0.69	12.0	1.64	166.7	22	11.9	0.90	133	
CC0822	33254	0.	258.	170.	0.	-160.	266.	40.	A	40.	19.	0.63	1.50	0.20	0.63	10.3	1.41	170.0	26	12.1	0.91	130	
DEADV3	33254	0.	401.	0.	0.	-303.	435.	40.	A	40.	40.	1.28	1.50	0.25	1.28	29.2	3.99	248.1	1	14.1	1.07	136	
DEADV3	33254	0.	534.	0.	0.	-392.	584.	40.	A	40.	58.	1.43	1.50	0.26	1.43	39.3	5.38	251.0	0	15.8	1.19	126	
DEHTPM	33254	0.	266.	179.	0.	-168.	256.	40.	A	40.	18.	0.79	1.50	0.17	0.79	16.6	2.28	267.5	4	13.4	1.01	118	
DES0A3	33254	424.	0.	0.	-424.	98.	435.	40.	A	40.	40.	1.47	1.50	0.20	1.47	35.9	4.91	288.7	0	17.9	1.35	138	
DES0A3	33254	668.	0.	0.	-668.	173.	687.	40.	A	40.	71.	1.95	1.50	0.22	1.95	58.6	8.01	299.4	0	23.3	1.76	130	
DES0A3	33254	0.	424.	0.	0.	-326.	435.	40.	A	40.	40.	1.47	1.50	0.20	1.47	35.9	4.91	288.7	0	15.6	1.18	131	
DES0A3	33254	0.	668.	0.	0.	-494.	687.	40.	A	40.	71.	1.95	1.50	0.22	1.95	58.6	8.01	299.4	0	19.7	1.48	123	
GTSGAD	33254	200.	56.	108.	-200.	42.	248.	40.	A	40.	17.	0.48	1.50	0.17	0.48	8.6	1.18	147.2	5	13.3	1.00	131	
GTRA08	33254	306.	19.	65.	-306.	79.	370.	40.	A	40.	32.	0.70	1.50	0.27	0.70	15.8	2.16	175.6	1	13.6	1.02	136	
GTRA16	33254	290.	23.	78.	-290.	75.	357.	40.	A	40.	30.	0.69	1.50	0.27	0.69	15.5	2.12	182.3	2	13.5	1.01	135	
GTRA12	33254	272.	30.	100.	-272.	68.	336.	40.	A	40.	28.	0.68	1.50	0.25	0.68	15.4	2.11	193.3	1	13.6	1.02	133	
GTR208	33254	239.	43.	145.	-239.	55.	291.	40.	A	40.	22.	0.58	1.50	0.20	0.58	11.9	1.62	169.5	0	13.5	1.02	131	
GTR212	33254	248.	39.	131.	-248.	59.	304.	40.	A	40.	24.	0.60	1.50	0.22	0.60	12.8	1.75	176.0	0	13.5	1.02	132	
GTR216	33254	250.	37.	125.	-250.	61.	310.	40.	A	40.	25.	0.62	1.50	0.23	0.62	13.6	1.86	185.2	1	13.5	1.02	132	

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																				
ECS	PROCS	**COGENERATION CASE**				**NOCOGEN - COGEN**				POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM WRTH ENRG
		DISTIL	RESIDL	COAL		DISTIL	RESIDL	COAL												
GTRW08	33254	366.	6.	19.	-366.	92.	416.	40.	38.	0.75	1.50	0.27	17.1	2.34	159.3	0	14.1	1.06	136	
GTRW12	33254	350.	6.	22.	-350.	92.	414.	40.	37.	0.75	1.50	0.29	17.0	2.32	165.3	0	13.7	1.03	138	
GTRW16	33254	323.	15.	51.	-323.	83.	385.	40.	34.	0.73	1.50	0.27	16.6	2.27	175.2	0	13.7	1.04	136	
GTR308	33254	311.	29.	96.	-311.	69.	339.	40.	28.	0.65	1.50	0.18	13.6	1.86	149.6	0	14.4	1.09	129	
GTR312	33254	284.	28.	95.	-284.	70.	341.	40.	28.	0.64	1.50	0.24	13.6	1.87	164.1	0	13.5	1.02	134	
GTR316	33254	281.	30.	99.	-281.	69.	337.	40.	28.	0.65	1.50	0.23	14.1	1.93	171.3	0	13.7	1.03	133	
FCPADS	33254	394.	0.	0.	-394.	98.	435.	40.	40.	3.96	1.50	0.26	26.2	3.59	227.0	0	18.5	1.40	148	
FCPADS	33254	535.	0.	0.	-535.	146.	597.	40.	60.	5.52	1.50	0.28	35.8	4.90	228.4	0	22.3	1.68	141	
FCMCDS	33254	348.	0.	0.	-348.	98.	435.	40.	40.	3.71	1.50	0.35	27.4	3.75	269.1	0	17.0	1.28	155	
FCMCDS	33254	391.	0.	0.	-391.	116.	494.	40.	47.	4.17	1.50	0.36	30.8	4.22	269.3	0	18.0	1.36	146	

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																				
**COGENERATION CASE** **NOCOGEN - COGEN**																				
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD	COGEN POWER	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVEL CHRGR	NORM WRTH ENRG		
ONOCGN	33314	0.	25.	130.	0.	0.	0.	A	10.	0.	0.45	0.86	0.	4.6	1.00	330.6	0	4.7	1.00	80
STM141	33314	0.	75.	65.	0.	-50.	65.		10.	2.	0.34	0.86	0.09	3.6	0.79	221.1	999	4.6	0.99	124
STM141	33314	0.	20.	121.	0.	5.	9.	F	10.	2.	0.57	0.86	0.09	6.6	1.44	402.4	10	4.5	0.97	109
STM141	33314	0.	20.	121.	0.	5.	9.	A	10.	2.	0.50	0.86	0.09	5.6	1.23	343.1	23	4.3	0.93	112
STM088	33314	0.	74.	71.	0.	-49.	59.		10.	2.	0.32	0.86	0.06	3.1	0.68	199.0	-4	4.6	1.00	122
STM088	33314	0.	21.	124.	0.	4.	6.	F	10.	2.	0.54	0.86	0.06	6.0	1.31	385.1	9	4.6	0.98	104
STM088	33314	0.	21.	124.	0.	4.	6.	A	10.	2.	0.48	0.86	0.06	5.2	1.15	336.8	24	4.4	0.95	107
PFBSTM	33314	0.	16.	115.	0.	9.	15.		10.	4.	0.66	0.86	0.15	8.6	1.89	472.4	8	4.5	0.96	116
TISTMT	33314	0.	80.	43.	0.	-55.	87.		10.	5.	0.70	0.86	0.21	17.3	3.80	878.3	0	6.0	1.28	123
TISTMT	33314	0.	13.	110.	0.	12.	20.		10.	5.	0.98	0.86	0.21	22.1	4.85	1119.7	0	6.0	1.28	120
TIHRSG	33314	0.	80.	62.	0.	-56.	68.		10.	3.	0.56	0.86	0.08	15.4	3.38	849.8	0	6.1	1.31	102
TIHRSG	33314	0.	19.	124.	0.	6.	6.		10.	3.	0.82	0.86	0.08	19.9	4.36	1096.9	0	6.2	1.33	99
STIRL	33314	84.	10.	32.	-84.	15.	98.		10.	6.	0.35	0.86	0.19	5.0	1.09	201.3	0	4.9	1.04	140
STIRL	33314	0.	93.	32.	0.	-69.	98.		10.	6.	0.35	0.86	0.19	5.0	1.09	201.6	61	4.3	0.93	137
STIRL	33314	0.	10.	116.	0.	15.	14.		10.	6.	0.61	0.86	0.19	8.4	1.84	341.6	16	4.0	0.85	123
HEGT85	33314	0.	0.	139.	0.	25.	-9.	A	10.	10.	1.34	0.86	0.10	29.6	6.48	725.0	0	6.8	1.45	123
HEGT85	33314	0.	0.	330.	0.	76.	-28.	A	10.	31.	2.06	0.86	0.13	56.8	12.46	587.6	0	9.8	2.11	112
HEGT60	33314	0.	0.	134.	0.	25.	-4.	A	10.	10.	1.11	0.86	0.13	26.1	5.73	663.5	0	6.1	1.31	124
HEGT60	33314	0.	0.	137.	0.	25.	-4.	A	10.	10.	1.03	0.86	0.13	26.1	5.73	651.9	0	6.0	1.29	113
HEGT00	33314	0.	14.	130.	0.	10.	-0.	A	10.	4.	0.64	0.86	0.07	14.3	3.14	597.7	0	5.2	1.12	102
FCMCCL	33314	0.	6.	106.	0.	18.	24.		10.	8.	0.87	0.86	0.28	16.9	3.70	680.5	3	4.8	1.04	129
FCSTCL	33314	0.	0.	95.	0.	25.	35.		10.	10.	1.18	0.86	0.38	19.9	4.36	712.5	4	4.9	1.05	152
FCSTCL	33314	0.	0.	100.	0.	27.	38.		10.	11.	1.08	0.86	0.39	20.0	4.39	685.8	4	4.7	1.02	141
IGGTST	33314	0.	6.	113.	0.	19.	17.		10.	8.	0.86	0.86	0.23	17.0	3.74	627.2	3	5.0	1.07	123
GTSGAR	33314	0.	99.	17.	0.	-75.	113.		10.	8.	0.35	0.86	0.25	6.0	1.32	218.6	24	4.2	0.90	141
GTAC08	33314	0.	87.	32.	0.	-63.	98.		10.	6.	0.30	0.86	0.23	4.6	1.01	201.9	999	4.1	0.88	142
GTAC12	33314	0.	92.	20.	0.	-67.	110.		10.	8.	0.32	0.86	0.28	5.2	1.14	205.4	72	4.0	0.85	146
GTAC16	33314	0.	96.	11.	0.	-71.	119.		10.	9.	0.34	0.86	0.31	5.8	1.28	215.3	39	3.9	0.84	148
GTWC16	33314	0.	101.	8.	0.	-76.	122.		10.	9.	0.36	0.86	0.29	6.3	1.37	216.3	27	4.0	0.87	145
CC1626	33314	0.	105.	0.	0.	-80.	130.		10.	10.	0.59	0.86	0.32	7.4	1.62	240.2	13	4.3	0.92	157
CC1626	33314	0.	127.	0.	0.	-93.	161.		10.	14.	0.52	0.86	0.35	8.1	1.79	218.7	12	4.3	0.91	146
CC1622	33314	0.	103.	0.	0.	-78.	130.		10.	10.	0.57	0.86	0.34	7.0	1.54	233.5	17	4.2	0.90	159
CC1622	33314	0.	116.	0.	0.	-85.	150.		10.	12.	0.49	0.86	0.36	7.4	1.62	217.6	17	4.1	0.88	149
CC1222	33314	0.	102.	0.	0.	-78.	130.		10.	10.	0.56	0.86	0.34	6.7	1.48	224.9	19	4.1	0.89	160
CC1222	33314	0.	115.	0.	0.	-85.	149.		10.	12.	0.49	0.86	0.36	7.0	1.54	208.9	20	4.0	0.86	150
CC0822	33314	0.	98.	2.	0.	-73.	128.		10.	10.	0.45	0.86	0.35	6.3	1.37	220.1	29	3.9	0.84	152
STIG15	33314	0.	136.	0.	0.	-111.	130.		10.	10.	0.65	0.86	0.12	7.9	1.74	198.8	0	5.3	1.13	136
STIG15	33314	0.	3077.	0.	0.	-2234.	2868.		10.	344.	5.82	0.86	0.17	99.7	21.88	110.6	0	43.0	9.21	269
STIG10	33314	0.	128.	0.	0.	-103.	130.		10.	10.	0.59	0.86	0.17	7.3	1.61	195.2	0	4.9	1.05	142
STIG10	33314	0.	302.	0.	0.	-224.	308.		10.	32.	0.79	0.86	0.22	12.9	2.83	145.9	0	6.7	1.44	120
STIG1S	33314	0.	124.	0.	0.	-100.	130.		10.	10.	0.58	0.86	0.20	7.0	1.53	191.7	1	4.8	1.02	145
STIG1S	33314	0.	190.	0.	0.	-144.	200.		10.	19.	0.58	0.86	0.23	8.8	1.94	159.1	0	5.3	1.13	132
DEADV3	33314	0.	117.	0.	0.	-93.	130.		10.	10.	0.63	0.86	0.24	9.8	2.15	285.1	0	4.9	1.06	145

-----FUEL USE IN BTU*10**6-----																			
**COGENERATION CASE** **NO COGEN - COGEN**																			
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD MW	COGEN POWER MW	G&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVEL CHRG	NORM WRTH ENRG	
DEADV3	33314	0.	194.	0.	0.	-143.	221.	10.	21.	0.68	0.86	0.29	14.8	3.25	260.5	0	5.7	1.22	131
DEHTPM	33314	0.	96.	9.	0.	-71.	121.	10.	9.	0.49	0.86	0.32	8.5	1.87	312.2	11	4.3	0.93	143
DESOA3	33314	123.	0.	0.	-123.	25.	130.	10.	10.	0.66	0.86	0.20	10.6	2.32	292.3	0	6.0	1.28	144
DESOA3	33314	233.	0.	0.	-233.	60.	249.	10.	25.	0.86	0.86	0.25	21.1	4.62	308.8	0	8.4	1.81	133
DESOA3	33314	0.	123.	0.	0.	-98.	130.	10.	10.	0.66	0.86	0.20	10.6	2.32	292.3	0	5.2	1.11	140
DESOA3	33314	0.	233.	0.	0.	-172.	249.	10.	25.	0.86	0.86	0.25	21.1	4.62	308.8	0	7.0	1.50	125
GTSOAD	33314	87.	7.	22.	-87.	18.	108.	10.	7.	0.31	0.86	0.26	4.8	1.05	187.4	69	4.6	0.98	149
GTRA08	33314	105.	0.	0.	-105.	25.	130.	10.	10.	0.50	0.86	0.32	7.7	1.68	248.8	0	4.9	1.05	159
GTRA08	33314	119.	0.	0.	-119.	30.	149.	10.	12.	0.42	0.86	0.34	8.1	1.77	231.8	0	4.9	1.05	149
GTRA12	33314	104.	0.	0.	-104.	25.	130.	10.	10.	0.49	0.86	0.33	7.6	1.68	250.7	0	4.8	1.04	160
GTRA12	33314	115.	0.	0.	-115.	30.	146.	10.	12.	0.41	0.86	0.35	8.0	1.75	235.6	0	4.8	1.03	150
GTRA16	33314	104.	0.	0.	-104.	25.	130.	10.	10.	0.49	0.86	0.33	7.9	1.73	260.3	0	4.8	1.04	160
GTRA16	33314	110.	0.	0.	-110.	28.	140.	10.	11.	0.41	0.86	0.34	8.0	1.76	248.7	1	4.8	1.03	150
GTR208	33314	99.	2.	6.	-99.	23.	124.	10.	9.	0.36	0.86	0.30	6.4	1.39	218.3	6	4.6	1.00	149
GTR212	33314	103.	0.	1.	-103.	25.	129.	10.	10.	0.38	0.86	0.32	6.9	1.50	226.3	6	4.6	1.00	150
GTR216	33314	103.	0.	0.	-103.	25.	130.	10.	10.	0.43	0.86	0.33	7.2	1.59	239.9	4	4.7	1.01	161
GTR216	33314	104.	0.	0.	-104.	25.	131.	10.	10.	0.39	0.86	0.34	7.2	1.57	236.0	5	4.6	1.00	151
GTRW08	33314	113.	0.	0.	-113.	25.	130.	10.	10.	0.53	0.86	0.27	7.9	1.74	239.6	0	5.2	1.12	154
GTRW08	33314	144.	0.	0.	-144.	36.	169.	10.	15.	0.46	0.86	0.30	9.0	1.98	213.9	0	5.5	1.17	144
GTRW12	33314	110.	0.	0.	-110.	25.	130.	10.	10.	0.52	0.86	0.29	7.9	1.74	246.2	0	5.1	1.09	156
GTRW12	33314	141.	0.	0.	-141.	37.	170.	10.	15.	0.46	0.86	0.32	9.1	1.99	220.0	0	5.3	1.14	146
GTRW16	33314	109.	0.	0.	-109.	25.	130.	10.	10.	0.52	0.86	0.29	8.2	1.79	254.7	0	5.1	1.09	156
GTRW16	33314	133.	0.	0.	-133.	34.	161.	10.	14.	0.45	0.86	0.32	9.0	1.98	231.7	0	5.3	1.13	146
GTR308	33314	116.	0.	0.	-116.	25.	130.	10.	10.	0.48	0.86	0.25	7.2	1.57	210.3	0	5.2	1.11	153
GTR308	33314	124.	0.	0.	-124.	28.	140.	10.	11.	0.40	0.86	0.26	7.2	1.58	197.9	0	5.2	1.11	143
GTR312	33314	109.	0.	0.	-109.	25.	130.	10.	10.	0.49	0.86	0.30	7.3	1.61	230.3	0	4.9	1.06	158
GTR312	33314	121.	0.	0.	-121.	30.	146.	10.	12.	0.41	0.86	0.31	7.5	1.66	213.6	0	5.0	1.06	146
GTR316	33314	109.	0.	0.	-109.	25.	130.	10.	10.	0.49	0.86	0.30	7.6	1.67	239.1	0	5.0	1.07	157
GTR316	33314	120.	0.	0.	-120.	29.	145.	10.	12.	0.41	0.86	0.31	7.8	1.72	223.3	0	5.0	1.07	147
FCPADS	33314	120.	0.	0.	-120.	25.	130.	10.	10.	1.32	0.86	0.23	8.5	1.86	241.9	0	6.3	1.35	153
FCPADS	33314	235.	0.	0.	-235.	64.	262.	10.	26.	2.77	0.86	0.28	16.4	3.59	237.6	0	9.7	2.07	145
FCMCDS	33314	108.	0.	0.	-108.	25.	130.	10.	10.	1.24	0.86	0.30	8.6	1.88	272.0	0	5.8	1.25	160
FCMCDS	33314	172.	0.	0.	-172.	51.	217.	10.	21.	2.09	0.86	0.36	14.0	3.06	277.4	0	7.5	1.61	151

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																				
**COGENERATION CASE** **NOCOGEN - COGEN**																				
ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	RECD	POWER	O&M	POWER	FESR	CAPITAL	NORM	\$/KW	ROI	LEVEL	NORM		
								MW	MW		/HEAT		*10**6	COST	EQVL	(%)	CHRG	ENRG		
											RATIO									
ONCOGN	33315	0.	45.	222.	0.	0.	0.	A	19.	0.	0.54	1.05	0.	5.7	1.00	277.9	0	7.7	1.00	80
STM141	33315	0.	121.	126.	0.	-76.	97.		19.	3.	0.39	1.05	0.08	4.6	0.80	188.7	-3	7.7	1.00	120
STM141	33315	0.	38.	209.	0.	8.	13.	F	19.	3.	0.68	1.05	0.08	8.6	1.50	353.7	11	7.5	0.96	104
STM141	33315	0.	38.	209.	0.	6.	13.	A	19.	3.	0.60	1.05	0.08	7.1	1.24	290.7	26	7.2	0.93	108
STM088	33315	0.	119.	134.	0.	-74.	89.		19.	2.	0.38	1.05	0.06	4.0	0.69	171.2	-7	7.8	1.01	118
STM088	33315	0.	40.	213.	0.	5.	9.	F	19.	2.	0.65	1.05	0.06	7.9	1.38	339.2	10	7.6	0.98	100
STM088	33315	0.	40.	213.	0.	5.	9.	A	19.	2.	0.58	1.05	0.06	6.7	1.16	285.8	27	7.4	0.95	103
PFBSTM	33315	0.	32.	201.	0.	13.	22.		19.	5.	0.83	1.05	0.13	11.1	1.94	407.1	9	7.4	0.95	111
TISTMT	33315	0.	128.	92.	0.	-83.	131.		19.	7.	0.88	1.05	0.18	23.3	4.05	788.0	0	9.5	1.23	115
TISTNT	33315	0.	27.	193.	0.	18.	30.		19.	7.	1.24	1.05	0.18	29.7	5.16	1004.2	0	9.3	1.21	112
TIHRSG	33315	0.	129.	120.	0.	-84.	102.		19.	4.	0.72	1.05	0.07	20.8	3.61	763.0	0	9.8	1.27	97
TIHRSG	33315	0.	36.	213.	0.	9.	9.		19.	4.	1.05	1.05	0.07	26.8	4.66	984.2	0	9.7	1.26	94
STIRL	33315	126.	23.	76.	-126.	23.	147.		19.	9.	0.45	1.05	0.16	7.2	1.26	196.6	0	8.2	1.06	132
STIRL	33315	0.	148.	76.	0.	-103.	147.		19.	9.	0.45	1.05	0.16	7.3	1.26	196.9	19	7.4	0.96	129
STIRL	33315	0.	23.	201.	0.	23.	21.		19.	9.	0.80	1.05	0.16	13.1	2.27	354.6	12	6.9	0.89	116
HEGT85	33315	0.	0.	240.	0.	45.	-17.	A	19.	19.	1.87	1.05	0.10	44.1	7.67	627.5	0	10.5	1.36	119
HEGT85	33315	0.	0.	507.	0.	117.	-45.	A	19.	48.	2.78	1.05	0.12	77.1	13.40	518.1	0	14.1	1.83	109
HEGT60	33315	0.	7.	230.	0.	38.	-7.	A	19.	16.	1.35	1.05	0.12	34.9	6.07	576.9	0	9.3	1.20	106
HEGT00	33315	0.	30.	223.	0.	16.	-0.	A	19.	6.	0.83	1.05	0.06	19.1	3.32	530.2	0	8.4	1.09	97
FCMCCL	33315	0.	18.	186.	0.	28.	37.		19.	11.	1.14	1.05	0.24	22.4	3.90	604.0	5	7.8	1.01	121
FCSTCL	33315	0.	5.	166.	0.	40.	57.		19.	16.	1.41	1.05	0.36	26.6	4.63	608.9	6	7.4	0.95	135
IGGTST	33315	0.	18.	198.	0.	28.	25.		19.	11.	1.04	1.05	0.20	22.2	3.87	546.4	4	7.8	1.02	116
GTSOAR	33315	0.	157.	53.	0.	-112.	169.		19.	12.	0.43	1.05	0.21	8.0	1.40	193.5	22	7.1	0.92	134
GTAC08	33315	0.	139.	76.	0.	-94.	146.		19.	9.	0.37	1.05	0.20	6.1	1.07	179.6	149	7.0	0.90	136
GTAC12	33315	0.	146.	57.	0.	-101.	165.		19.	12.	0.40	1.05	0.24	7.0	1.22	184.6	50	6.8	0.88	140
GTAC16	33315	0.	152.	44.	0.	-107.	178.		19.	13.	0.43	1.05	0.27	7.9	1.37	194.2	33	6.7	0.87	141
GTWC16	33315	0.	160.	39.	0.	-115.	183.		19.	14.	0.44	1.05	0.25	8.3	1.45	191.5	26	6.8	0.89	139
CC1626	33315	0.	177.	0.	0.	-132.	222.		19.	19.	0.71	1.05	0.34	10.6	1.65	204.4	17	6.8	0.88	155
CC1626	33315	0.	190.	0.	0.	-139.	241.		19.	21.	0.63	1.05	0.35	10.8	1.88	194.2	17	6.7	0.87	145
CC1622	33315	0.	173.	0.	0.	-127.	222.		19.	19.	0.64	1.05	0.36	10.1	1.75	198.7	21	6.5	0.84	158
CC1622	33315	0.	174.	0.	0.	-128.	224.		19.	19.	0.60	1.05	0.36	10.0	1.74	196.3	22	6.5	0.84	158
CC1222	33315	0.	172.	0.	0.	-126.	222.		19.	19.	0.62	1.05	0.36	9.6	1.66	189.7	24	6.4	0.83	159
CC1222	33315	0.	172.	0.	0.	-127.	223.		19.	19.	0.59	1.05	0.36	9.5	1.65	188.3	25	6.4	0.83	159
CC0822	33315	0.	155.	31.	0.	-109.	191.		19.	15.	0.54	1.05	0.31	8.3	1.45	195.6	29	6.6	0.85	144
STIG15	33315	0.	234.	0.	0.	-188.	222.		19.	19.	0.88	1.05	0.13	11.6	2.02	169.8	0	8.6	1.11	133
STIG15	33315	0.	4615.	0.	0.	-3351.	4302.		19.	515.	8.40	1.05	0.17	145.9	25.39	107.9	0	64.3	8.33	247
STIG10	33315	0.	219.	0.	0.	-174.	222.		19.	19.	0.79	1.05	0.18	10.7	1.86	166.8	0	8.0	1.03	140
STIG10	33315	0.	453.	0.	0.	-336.	462.		19.	48.	1.03	1.05	0.22	17.4	3.02	131.0	0	10.3	1.33	122
STIG1S	33315	0.	212.	0.	0.	-167.	222.		19.	19.	0.76	1.05	0.21	10.1	1.76	162.9	5	7.7	1.00	143
STIG1S	33315	0.	285.	0.	0.	-216.	300.		19.	28.	0.75	1.05	0.23	11.9	2.06	142.2	0	8.2	1.07	131
DEADV3	33315	0.	200.	0.	0.	-154.	222.		19.	19.	0.82	1.05	0.25	14.7	2.56	251.7	3	7.9	1.02	142
DEADV3	33315	0.	293.	0.	0.	-215.	332.		19.	32.	0.91	1.05	0.29	22.0	3.83	256.3	0	9.0	1.17	130
DEHTPM	33315	0.	152.	42.	0.	-107.	181.		19.	13.	0.60	1.05	0.27	11.1	1.93	270.7	12	7.1	0.93	136



GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----

ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVEL CHRG	NORM WRTH ENRG
DESOA3	33315	210.	0.	0.	-210.	45.	222.	19.	19.	0.91	1.05	0.21	17.9	3.11	290.0	0	9.9	1.29 141
DESOA3	33315	351.	0.	0.	-351.	91.	375.	19.	37.	1.17	1.05	0.25	31.3	5.45	304.8	0	13.1	1.70 132
DESOA3	33315	0.	210.	0.	0.	-165.	222.	19.	19.	0.91	1.05	0.21	17.9	3.11	290.0	0	8.6	1.12 137
DESOA3	33315	0.	351.	0.	0.	-260.	375.	19.	37.	1.17	1.05	0.25	31.3	5.45	304.8	0	10.9	1.42 125
GTSOAD	33315	130.	18.	60.	-130.	27.	162.	19.	11.	0.38	1.05	0.22	6.4	1.11	167.0	17	7.6	0.99 142
GTRA08	33315	177.	0.	0.	-177.	45.	222.	19.	19.	0.57	1.05	0.34	10.8	1.88	208.4	5	7.7	1.00 158
GTRA08	33315	178.	0.	0.	-178.	46.	224.	19.	19.	0.52	1.05	0.34	10.8	1.87	206.0	5	7.7	1.00 158
GTRA12	33315	173.	1.	3.	-173.	45.	220.	19.	18.	0.52	1.05	0.34	10.7	1.86	210.8	6	7.6	0.99 147
GTRA16	33315	166.	4.	13.	-166.	42.	210.	19.	17.	0.52	1.05	0.32	10.8	1.88	222.3	5	7.7	1.00 145
GTR208	33315	149.	11.	37.	-149.	34.	185.	19.	14.	0.45	1.05	0.26	8.5	1.48	194.4	4	7.7	1.00 142
GTR212	33315	155.	9.	29.	-155.	37.	194.	19.	15.	0.47	1.05	0.28	9.2	1.59	201.6	5	7.7	1.00 143
GTR216	33315	156.	8.	29.	-156.	38.	197.	19.	15.	0.48	1.05	0.29	9.6	1.68	211.2	5	7.7	1.00 144
GTRW08	33315	192.	0.	0.	-192.	45.	222.	19.	19.	0.65	1.05	0.28	11.4	1.98	202.3	0	8.4	1.08 152
GTRW08	33315	216.	0.	0.	-216.	55.	253.	19.	22.	0.57	1.05	0.30	12.0	2.08	188.5	0	8.5	1.10 142
GTRW12	33315	186.	0.	0.	-186.	45.	222.	19.	19.	0.65	1.05	0.30	11.4	1.98	208.5	0	8.2	1.06 154
GTRW12	33315	212.	0.	0.	-212.	55.	256.	19.	23.	0.57	1.05	0.32	12.0	2.09	194.0	0	8.3	1.08 144
GTRW16	33315	185.	0.	0.	-185.	45.	222.	19.	19.	0.64	1.05	0.31	11.6	2.03	214.9	0	8.2	1.06 154
GTRW16	33315	200.	0.	0.	-200.	51.	242.	19.	21.	0.56	1.05	0.32	11.9	2.08	204.1	0	8.2	1.06 144
GTR308	33315	187.	4.	12.	-187.	42.	210.	19.	17.	0.50	1.05	0.24	9.6	1.67	175.6	0	8.3	1.08 139
GTR312	33315	181.	1.	3.	-181.	44.	220.	19.	18.	0.50	1.05	0.31	10.0	1.74	188.6	3	7.8	1.01 146
GTR316	33315	180.	2.	5.	-180.	44.	217.	19.	18.	0.51	1.05	0.30	10.4	1.80	196.9	1	7.9	1.02 144
FCPAD6	33315	203.	0.	0.	-203.	45.	222.	19.	19.	2.20	1.05	0.24	13.7	2.38	229.4	0	10.6	1.37 151
FCPAD6	33315	353.	0.	0.	-353.	96.	393.	19.	39.	4.09	1.05	0.28	24.0	4.18	232.1	0	15.0	1.94 144
FCMCDS	33315	182.	0.	0.	-182.	45.	222.	19.	19.	2.07	1.05	0.32	14.2	2.47	266.9	0	9.7	1.26 157
FCMCDS	33315	256.	0.	0.	-256.	76.	326.	19.	31.	3.09	1.05	0.36	20.7	3.60	274.3	0	11.8	1.53 149

ORIGINAL PAGE IS  
OF POOR  
QUALITY

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU*10**6-----																				
ECS	PROCS	**COGENERATION CASE**				**NOCOGEN - COGEN**				O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVL CHRG	NORM ENRG	WRTH	
		DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	REQD	POWER											REQD
ONOCGN	33316	0.	39.	202.	0.	0.	0.	A	16.	0.	0.54	0.91	0.	5.7	1.00	277.9	0	7.0	1.00	80
STM141	33316	0.	115.	105.	0.	-76.	97.		16.	3.	0.39	0.91	0.09	4.6	0.80	188.7	-3	7.0	1.00	123
STM141	33316	0.	31.	189.	0.	8.	13.	F	16.	3.	0.68	0.91	0.09	8.6	1.50	353.7	11	6.7	0.96	107
STM141	33316	0.	31.	189.	0.	8.	13.	A	16.	3.	0.60	0.91	0.09	7.1	1.24	290.7	26	6.5	0.93	110
STM088	33316	0.	113.	113.	0.	-74.	89.		16.	2.	0.38	0.91	0.06	4.0	0.69	171.2	-7	7.1	1.01	120
STM088	33316	0.	34.	193.	0.	5.	9.	F	16.	2.	0.65	0.91	0.06	7.9	1.38	339.2	10	6.8	0.98	102
STM088	33316	0.	34.	193.	0.	5.	9.	A	16.	2.	0.58	0.91	0.06	6.7	1.16	285.8	27	6.6	0.95	105
PFBST11	33316	0.	26.	180.	0.	13.	22.		16.	5.	0.83	0.91	0.15	11.1	1.94	407.1	9	6.6	0.95	114
TISTMT	33316	0.	122.	71.	0.	-83.	131.		16.	7.	0.88	0.91	0.20	23.3	4.05	788.0	0	8.7	1.25	119
TISTMT	33316	0.	21.	172.	0.	18.	30.		16.	7.	1.24	0.91	0.20	29.7	5.16	1004.2	0	8.6	1.23	116
TIHRSG	33316	0.	123.	100.	0.	-84.	102.		16.	4.	0.72	0.91	0.08	20.8	3.61	763.0	0	9.1	1.30	100
TIHRSG	33316	0.	30.	193.	0.	9.	9.		16.	4.	1.05	0.91	0.08	26.8	4.66	984.2	0	9.0	1.29	97
STIRL	33316	126.	16.	55.	-126.	23.	147.		16.	9.	0.45	0.91	0.18	7.2	1.26	196.6	0	7.5	1.07	136
STIRL	33316	0.	142.	55.	0.	-103.	147.		16.	9.	0.45	0.91	0.18	7.3	1.26	196.9	19	6.7	0.95	133
STIRL	33316	0.	16.	181.	0.	23.	21.		16.	9.	0.80	0.91	0.18	13.1	2.27	354.6	12	6.2	0.88	119
HEGT85	33316	0.	0.	217.	0.	39.	-15.	A	16.	16.	1.75	0.91	0.10	40.5	7.05	637.3	0	9.6	1.38	120
HEGT85	33316	0.	0.	507.	0.	117.	-45.	A	16.	48.	2.78	0.91	0.12	77.1	13.40	518.1	0	13.7	1.96	109
HEGT60	33316	0.	1.	209.	0.	38.	-7.	A	16.	16.	1.35	0.91	0.13	34.9	6.07	576.9	0	8.5	1.22	110
HEGT00	33316	0.	24.	202.	0.	16.	-0.	A	16.	6.	0.83	0.91	0.06	19.1	3.32	530.2	0	7.7	1.10	100
FCMCCL	33316	0.	12.	165.	0.	28.	37.		16.	11.	1.14	0.91	0.27	22.4	3.90	604.0	5	7.0	1.01	126
FCSTCL	33316	0.	0.	147.	0.	39.	55.		16.	16.	1.50	0.91	0.39	26.7	4.65	621.2	5	6.8	0.98	150
FCSTCL	33316	0.	0.	149.	0.	40.	57.		16.	16.	1.41	0.91	0.39	26.6	4.63	608.9	6	6.7	0.96	139
IGGTST	33316	0.	11.	177.	0.	28.	25.		16.	11.	1.04	0.91	0.22	22.2	3.87	546.4	4	7.1	1.02	120
GTSGAR	33316	0.	151.	33.	0.	-112.	169.		16.	12.	0.43	0.91	0.24	8.0	1.40	193.5	22	6.4	0.91	138
GTAC08	33316	0.	133.	56.	0.	-94.	146.		16.	9.	0.37	0.91	0.22	6.1	1.07	179.6	149	6.2	0.89	140
GTAC12	33316	0.	140.	36.	0.	-101.	165.		16.	12.	0.40	0.91	0.27	7.0	1.22	184.6	50	6.0	0.86	144
GTAC16	33316	0.	146.	24.	0.	-107.	178.		16.	13.	0.43	0.91	0.30	7.9	1.37	194.2	33	5.9	0.85	145
GTWC16	33316	0.	154.	19.	0.	-115.	183.		16.	14.	0.44	0.91	0.28	8.3	1.45	191.5	26	6.1	0.87	142
CC1626	33316	0.	163.	0.	0.	-124.	202.		16.	16.	0.71	0.91	0.32	10.0	1.75	210.4	15	6.3	0.90	155
CC1626	33316	0.	190.	0.	0.	-139.	241.		16.	21.	0.63	0.91	0.35	10.8	1.88	194.2	14	6.2	0.89	145
CC1622	33316	0.	159.	0.	0.	-120.	202.		16.	16.	0.68	0.91	0.34	9.7	1.68	207.5	18	6.1	0.88	158
CC1622	33316	0.	174.	0.	0.	-128.	224.		16.	19.	0.60	0.91	0.36	10.0	1.74	196.3	19	6.0	0.86	147
CC1222	33316	0.	158.	0.	0.	-119.	202.		16.	16.	0.67	0.91	0.34	9.2	1.61	199.6	20	6.1	0.87	139
CC1222	33316	0.	172.	0.	0.	-127.	223.		16.	19.	0.59	0.91	0.36	9.5	1.65	108.3	21	5.9	0.85	148
CC0822	33316	0.	149.	11.	0.	-109.	191.		16.	15.	0.54	0.91	0.34	8.3	1.45	195.6	29	5.9	0.84	149
STIG15	33316	0.	212.	0.	0.	-172.	202.		16.	16.	0.82	0.91	0.12	10.8	1.87	173.7	0	7.8	1.12	134
STIG15	33316	0.	4615.	0.	0.	-3351.	4302.		16.	515.	8.40	0.91	0.17	145.9	25.39	107.9	0	63.9	9.14	267
STIG10	33316	0.	199.	0.	0.	-160.	202.		16.	16.	0.75	0.91	0.18	10.0	1.73	170.9	0	7.3	1.05	140
STIG10	33316	0.	453.	0.	0.	-336.	462.		16.	48.	1.03	0.91	0.22	17.4	3.02	131.0	0	9.8	1.41	120
STIG1S	33316	0.	193.	0.	0.	-154.	202.		16.	16.	0.72	0.91	0.20	9.5	1.65	167.7	3	7.1	1.01	144
STIG1S	33316	0.	285.	0.	0.	-216.	300.		16.	28.	0.75	0.91	0.23	11.9	2.06	142.2	0	7.8	1.11	131
DEADV3	33316	0.	182.	0.	0.	-143.	202.		16.	16.	0.78	0.91	0.24	13.3	2.31	248.2	2	7.2	1.03	143
DEADV3	33316	0.	293.	0.	0.	-215.	332.		16.	32.	0.91	0.91	0.29	22.0	3.83	256.3	0	8.6	1.22	129

GENERAL ELECTRIC COMPANY  
COGENERATION TECHNOLOGY ALTERNATIVES STUDY  
REPORT 5.2  
SUMMARY OF FUEL SAVED BY TYPE & ECONOMICS

-----FUEL USE IN BTU\*10\*\*6-----

\*\*COGENERATION CASE\*\* \*\*NO COGEN - COGEN\*\*

ECS	PROCS	DISTIL	RESIDL	COAL	DISTIL	RESIDL	COAL	POWER REQD MW	COGEN POWER MW	O&M	POWER /HEAT RATIO	FESR	CAPITAL COST *10**6	NORM COST	\$/KW EQVL	ROI (%)	LEVEL CHRG	NORM WRTH ENRG
DEHTPM	33316	0.	146.	21.	0.	-107.	181.	16.	13.	0.60	0.91	0.31	11.1	1.93	270.7	12	6.4	0.92 140
DESOA3	33316	191.	0.	0.	-191.	39.	202.	16.	16.	0.85	0.91	0.21	16.0	2.78	284.6	0	9.0	1.29 142
DESOA3	33316	351.	0.	0.	-351.	91.	375.	16.	37.	1.17	0.91	0.25	31.3	5.45	304.8	0	12.7	1.81 132
DESOA3	33316	0.	191.	0.	0.	-152.	202.	16.	16.	0.85	0.91	0.21	16.0	2.78	284.6	0	7.8	1.12 138
DESOA3	33316	0.	351.	0.	0.	-260.	375.	16.	37.	1.17	0.91	0.25	31.3	5.45	304.8	0	10.5	1.50 125
GTSOAD	33316	130.	12.	40.	-130.	27.	162.	16.	11.	0.38	0.91	0.25	6.4	1.11	167.0	17	6.9	0.99 146
GTRA08	33316	163.	0.	0.	-163.	39.	202.	16.	16.	0.61	0.91	0.32	10.4	1.81	218.0	0	7.2	1.04 158
GTRA08	33316	178.	0.	0.	-178.	46.	224.	16.	19.	0.52	0.91	0.34	10.8	1.87	205.0	0	7.3	1.04 148
GTRA12	33316	161.	0.	0.	-161.	39.	202.	16.	16.	0.60	0.91	0.33	10.4	1.82	221.2	1	7.2	1.03 159
GTRA12	33316	173.	0.	0.	-173.	45.	220.	16.	18.	0.52	0.91	0.34	10.7	1.86	210.8	1	7.2	1.02 149
GTRA16	33316	160.	0.	0.	-160.	39.	202.	16.	16.	0.59	0.91	0.34	10.8	1.87	229.2	1	7.2	1.03 158
GTRA16	33316	166.	0.	0.	-166.	42.	210.	16.	17.	0.52	0.91	0.34	10.8	1.88	222.3	2	7.1	1.02 148
GTR208	33316	149.	5.	16.	-149.	34.	185.	16.	14.	0.45	0.91	0.29	8.5	1.48	194.4	4	7.0	1.00 146
GTR212	33316	155.	2.	8.	-155.	37.	194.	16.	15.	0.47	0.91	0.31	9.2	1.59	201.6	5	7.0	1.00 147
GTR216	33316	156.	1.	5.	-156.	38.	197.	16.	15.	0.48	0.91	0.33	9.6	1.68	211.2	5	7.0	1.00 148
GTRW08	33316	175.	0.	0.	-175.	39.	202.	16.	16.	0.64	0.91	0.27	10.7	1.86	208.4	0	7.7	1.11 153
GTRV08	33316	216.	0.	0.	-216.	55.	253.	16.	22.	0.57	0.91	0.30	12.0	2.08	188.5	0	8.1	1.16 143
GTRV12	33316	171.	0.	0.	-171.	39.	202.	16.	16.	0.64	0.91	0.29	10.7	1.86	214.2	0	7.6	1.08 155
GTRW12	33316	212.	0.	0.	-212.	55.	256.	16.	23.	0.57	0.91	0.32	12.0	2.09	194.0	0	7.9	1.13 145
GTRV16	33316	169.	0.	0.	-169.	39.	202.	16.	16.	0.64	0.91	0.30	11.0	1.91	221.5	0	7.6	1.08 155
GTRW16	33316	200.	0.	0.	-200.	51.	242.	16.	21.	0.56	0.91	0.32	11.9	2.08	204.1	0	7.7	1.11 145
GTR308	33316	180.	0.	0.	-180.	39.	202.	16.	16.	0.57	0.91	0.25	9.7	1.68	182.7	0	7.7	1.10 152
GTR308	33316	187.	0.	0.	-187.	42.	210.	16.	17.	0.50	0.91	0.26	9.6	1.67	175.6	0	7.7	1.10 142
GTR312	33316	168.	0.	0.	-168.	39.	202.	16.	16.	0.59	0.91	0.30	9.8	1.71	200.0	0	7.3	1.05 157
GTR312	33316	181.	0.	0.	-181.	44.	220.	16.	18.	0.50	0.91	0.31	10.0	1.74	188.6	0	7.3	1.05 147
GTR316	33316	168.	0.	0.	-168.	39.	202.	16.	16.	0.60	0.91	0.30	10.2	1.78	207.5	0	7.4	1.06 156
GTR316	33316	180.	0.	0.	-180.	44.	217.	16.	18.	0.51	0.91	0.31	10.4	1.80	196.9	0	7.4	1.06 146
FCPADS	33316	186.	0.	0.	-186.	39.	202.	16.	16.	1.95	0.91	0.23	12.4	2.16	228.3	0	9.6	1.37 151
FCPADS	33316	353.	0.	0.	-353.	96.	393.	16.	39.	4.09	0.91	0.23	24.0	4.18	232.1	0	14.5	2.08 145
FCMCDS	33316	167.	0.	0.	-167.	39.	202.	16.	16.	1.85	0.91	0.31	12.9	2.24	263.7	0	8.9	1.27 158
FCMCDS	33316	258.	0.	0.	-258.	76.	326.	16.	31.	3.09	0.91	0.36	20.7	3.60	274.3	0	11.4	1.63 150