

N O T I C E

THIS DOCUMENT HAS BEEN REPRODUCED FROM
MICROFICHE. ALTHOUGH IT IS RECOGNIZED THAT
CERTAIN PORTIONS ARE ILLEGIBLE, IT IS BEING RELEASED
IN THE INTEREST OF MAKING AVAILABLE AS MUCH
INFORMATION AS POSSIBLE

ORIGINAL PAGE IS
OF POOR QUALITY

JPL NO. 9950 - 663



FINAL REPORT
FOR TASK 12 OF THE SMALL COMMUNITY
SOLAR THERMAL POWER EXPERIMENT

PARABOLIC DISH TECHNOLOGY FOR INDUSTRIAL
PROCESS HEAT APPLICATION

April 9, 1981

Prepared for:

California Institute of Technology
Jet propulsion Laboratory
4800 Oak Grove Drive
Pasadena, California 91103

Contract 955637

CDRL Item No. 41

(NASA-CR-169061) THE SMALL COMMUNITY SOLAR
THERMAL POWER EXPERIMENT. PARABOLIC DISH
TECHNOLOGY FOR INDUSTRIAL PROCESS HEAT
APPLICATION Final Report (Ford Aerospace
and Communications) 169 p HC A08/MF A01

N82-26784

Unclas
G3/44 23512

Ford Aerospace &
Communications Corporation
Aeronutronic Division
Newport Beach, California 92663

ORIGINAL PAGE IS
OF POOR QUALITY

SCSE Report 010
April 9, 1981



FINAL REPORT
FOR TASK 12 OF THE SMALL COMMUNITY
SOLAR THERMAL POWER EXPERIMENT

PARABOLIC DISH TECHNOLOGY FOR INDUSTRIAL
PROCESS HEAT APPLICATION

Prepared for:


California Institute of Technology
Jet Propulsion Laboratory
4800 Oak Grove Drive
Pasadena, California 91103

Contract 955637


CDRL Item No. 41


Prepared by: R. E. Polzien and D. Rodriguez

Approved by:


R. L. Pons, Technical Manager

Approved by:


R. H. Babbe, Program Manager

 Ford Aerospace &
Communications Corporation
Aeronutronic Division
Newport Beach, California 92663

ORIGINAL PAGE IS
OF POOR QUALITY



Ford Aerospace &
Communications Corporation
Aeronutronic Division

Ford Road
Newport Beach, California 92660

G081-81-0061

April 30, 1981

California Institute of Technology
Jet Propulsion Laboratory
4800 Oak Grove Drive
Pasadena, California 91103

Attention: Mr. G. E. Saunders, MS 506/439
Senior Contract Negotiator

Subject: Final Technical Report
(CDRL) Task 12

Reference: Contract 955637

Gentlemen:

In accordance with the Contract Data Requirements List (CDRL), Item Number 41 of the referenced contract, enclosed is the Parabolic Dish Technology for Industrial Process Heat (IPH) Application Final Technical Report, SCSE-010.

Should you have any questions concerning this submittal or the referenced contract in general, please contact me at (714) 759-6068.

Very truly yours,

G. Kim Cashmer
Contract Administrator
Advanced Development Operation

GKC:TLG:rw
Enclosures

CONTENTS

SECTION	PAGE
1	INTRODUCTION AND SUMMARY 1
1.1	Introduction 1
1.2	Summary of Results 1
2	STUDY REQUIREMENTS 3
2.1	Statement of Work 3
2.2	Structure of Study 5
2.3	Selection of Baseline IPH Application 7
	2.3.1 Exxon Application 7
	2.3.2 Field Geometry 11
	2.3.3 Thermal Conversion Processes 11
3	OPTIMIZATION CODE VERIFICATION 21
3.1	Precontractual Work. 21
3.2	Contracted Optimization Code Verification 24
	3.2.1 Baseline Application Results 24
	3.2.2 JPL Coupling Effects 24
	3.2.3 Standard Pipe Sizes. 28
	3.2.4 Cost of Energy 28
4	CONVENTIONAL CONSTRUCTION COST MODEL 30
4.1	Pipe Network Detailed Design 30
4.2	Costing Assumptions 39
4.3	Cost Data. 41
4.4	Cost Matrix 43
4.5	Results. 43
5	UNCONVENTIONAL CONSTRUCTION 51
5.1	Pre-fabricated Omega-Shaped Expansion Joints 51
5.2	Flexible Hose Expansion Joint 53
5.3	Prefabricated Post Supports 53
5.4	Automated Welding 57
5.5	Buried Pipe 60
5.6	Cost Results 60

CONTENTS (Continued)

SECTION		PAGE
6	PARAMETRIC STUDY RESULTS	63
	6.1 Alternate Temperatures	63
	6.2 Alternate Plant Size	63
	6.3 Results	65
7	RISER AND DOWNCOMER DESIGN	68
	7.1 Design Considerations	68
	7.2 Selected Design	73
	7.3 Cost Estimates	76
	7.4 Cost Reduction Modifications	76
	7.4.1 Modifications to the LCC Design	76
	7.4.2 HA/DEC Dish Design	80
	7.4.3 Single Post Design	80
8	CONCLUSIONS AND RECOMMENDATIONS	83
	8.1 Conclusions	83
	8.2 Recommendations	84
APPENDICES		
A	Shading Loss Analysis	A-1
B	Optimization of Pipe Network Costs	B-1
C	Computer Cost Matrix Printouts	C-1
D	Cost Data	D-1
E	FACC Network Optimization Computer Output Sheets and Input Data	E-1

ILLUSTRATIONS

FIGURE		PAGE
2-1	IPH Study Program Structure.	6
2-2	Location of California Heavy Oil Fields.	9
2-3	72 Dish Field Geometry	13
2-4	Unfired Boiler System Schematic.	16
2-5	Unfired Boiler Sensitivity of Mass Flowrate to Solar Field Discharge Temperature.	17
2-6	Direct Generation of Steam in Receiver	19
4-1	Baseline STEOR Pipe Network.	31
4-2	Feeder Piping Network.	32
4-3	Weld and Pipefitting Labor Estimate.	33
4-4	Loads and Stresses for Field Constructed Expansion Joints. .	35
4-5	Maximum Stress and Thermal Expansion Loads in Factory Fabricated Bent Omega Joints	36
4-6	Combined Flexural and Pressure Stress in Water Line.	37
4-7	Maximum Spacing Between Water Pipeline Supports.	38
4-8	Insulation Cost Comparison	42
4-9	Baseline Pipe Network Cost Matrix.	44
4-10	Comparison of FACC and JPL Pipe Network Cost for STEOR Application.	45
4-11	Comparison of Labor and Material Cost for STEOR Pipe Network.	46
4-12	Overall Comparison of Pipe Network Cost for STEOR Application.	48
4-13	Distribution of Labor and Material Costs	49
4-14	Analysis of Labor and Material Costs, 72 Dish STEOR Pipe Network, FACC Cost Analysis.	50

ILLUSTRATIONS (Continued)

FIGURE		PAGE
5-1	Flexible Hose Thermal Expansion Joint.	54
5-2	Pipe Anchors	55
5-3	Pipe Supports.	56
5-4	AV-2 Pipe Welder	58
5-5	Astromatic Tube Welding System	59
5-6	Buried Pipe Concept.	61
5-7	Cost Reductions Using Unconventional Construction Techniques	62
6-1	Steam Pressure Requirements for STEOR.	64
7-1	Flexible Hose Design Across Gimbal Joints.	69
7-2	Flexible Hose Design Across Azimuth Gimbal	70
7-3	Coil Radius vs. Number of Turns for Coiled Tube Flexible Azimuth Joint	72
7-4	Flex Hose Assembly, LCC Elevation Gimbal	74
7-5	Flex Hose Assembly, LCC Azimuth Gimbal	75
7-6	12 Meter Diameter Collector, Equatorial Mount.	81
7-7	Post Supported Dish Design	82

ORIGINAL PAGE IS
OF POOR QUALITY

TABLES

TABLE		PAGE
2-1	Task 12 - IPH Study Requirements	4
2-2	Baseline IPH Application Solar Thermal Enhanced Oil Recovery	10
2-3	Baseline Case Field Geometry	12
2-4	STEOR Thermal Conversion Processes Considered for Baseline IPH Network	14
2-5	Comparative Costs for Alternate STEOR Thermal Conversion Processes.	20
3-1	Optimization Code Verification Procedure	22
3-2	FACC Optimization Algorithm.	23
3-3	Comparison of Pipe Network Optimization Computations FACC vs. JPL Code.	25
3-4	Comparison of JPL and FACC Cost Optimization Techniques - Essential Features.	26
3-5	Optimization Code Comparison Results	27
3-6	FACC Optimization Results Comparison of Real Vs. Mathematical Pipe Sizes.	29
4-1	Cost Estimating Assumptions.	40
5-1	Approaches to Reduced Cost	52
6-1	Results of Optimization Analyses for Alternate STEOR Pipe Networks - \$1500/kW _e Cost of Energy	66
6-2	Results of Optimization Analyses for Alternate STEOR Pipe Networks - \$500/kW _e Cost of Energy.	67
7-1	Cost Estimate, Thermal Transport Modifications to LCC Dish .	77
7-2	Breakdown on Production Cost Estimate to Incorporate Risers/Downcomers on LCC Dish.	78
7-3	Potential Riser/Downcomer Cost Reductions for LCC.	79

SECTION 1

INTRODUCTION AND SUMMARY

1.1 INTRODUCTION

This report summarizes the results of a study performed by the Aeronutronic Division of Ford Aerospace & Communications Corporation (FACC) for the Jet Propulsion Laboratory (JPL) as part (Task 12) of the Small Community Solar Thermal Power Experiment, Phase II. The study objectives were to investigate several aspects of incorporating a thermal energy transport system (ETS) into a field of parabolic dish collectors for industrial process heat (IPH) applications. Specific objectives were to:

- Verify the mathematical optimization of pipe diameters and insulation thicknesses calculated by a JPL computer code.
- Verify the cost model developed by JPL for pipe network costs using conventional pipe network construction.
- Develop a design and the associated production costs for incorporating risers and downcomers on a JPL specified Low Cost Concentrator (LCC).
- Investigate the cost reduction of using unconventional pipe construction technology. This investigation was an uncontracted effort performed by FACC in connection with this study.

These objectives were accomplished by a detailed analysis of the pipe network design and costs for a particular IPH application, specifically solar thermally enhanced oil recovery (STEOR). The selected application has been under study by Exxon Research and Engineering Company, Linden, New Jersey and involves the hybrid operation of a solar powered steam generator in conjunction with a steam generator using fossil fuels to generate STEOR steam for the wells in Exxon's Edison Field, located near Bakersfield, California.

The STEOR application provided a baseline pipe network geometry used for optimization studies of pipe diameter and insulation thickness, and for development of comparative cost data. It also provided operating parameters for the design of riser/downcomer modifications to the Low Cost Concentrator (LCC).

1.2 SUMMARY OF RESULTS

The JPL methodology and mathematical procedures for optimization of pipe network diameters and insulation thicknesses are substantially validated by comparing results calculated by the JPL code with those computed for an identical case (pipe network geometry and cost model) using a FACC-derived optimization code based on a different mathematical approach. The comparison was based on conventional pipe network construction.

ORIGINAL PAGE IS
OF POOR QUALITY

A detailed design and cost analysis of the solar thermally enhanced oil recovery (STEOR) pipe network shows that the pipe network costs compare reasonably well (within 20%) with those predicted by the JPL cost model. FACC recommends a minor modification in the way which the JPL code calculates the cost of thermal expansion joints which will bring the cost comparison within 10 percent. Other than this suggested change in calculation technique the JPL conventional pipe network cost model is substantially verified based on the results of this study.

The non-contracted FACC study conducted as part of this overall effort shows that the introduction of various non-conventional pipe network construction techniques can reduce the conventional costs by about 33%. The techniques which offer the reduction are:

- Use of flexible hose to replace field constructed expansion joints
- Use of pile driven prefabricated pipe supports
- Use of field shop construction and automated welding equipment

In addition a buried pipe approach is described herein which may offer large potential cost reductions.

The addition of risers and downcomers to the LCC presents a significant cost increase (\$29/m²) to the overall IPH system costs. The high costs are a particular problem with the LCC due to its design characteristics which increase the difficulty of providing flexible gimbal lines at the azimuth and elevation joints. The LCC design characteristics which contribute to the difficulty are: 1) the large separation between elevation and azimuth axes, 2) the large diameter azimuth wheel and track design, and 3) the unique outboard location of the elevation trunnions which are designed solely for inverting the dish.

Risers and downcomers for more conventional dishes show significant cost reductions since the orthogonal axes are generally co-located. It is estimated, for example, that riser/downcomer costs for a single post design could be reduced between 40 and 50 percent based on a design rationale presented in this report.

A more detailed summary of the conclusions and recommendations of the study is presented in Section 8 of this report.

SECTION 2

STUDY REQUIREMENTS

2.1 STATEMENT OF WORK

The key requirements of the JPL Statement of Work are summarized in Table 2-1. The work is divided into Tasks A and B. Task A includes assessment of the JPL piping methodology (computer code) and verification of the JPL conventional cost model. Task B includes the design of modifications to the SCSE (EE-1) solar electric system to incorporate IPH features, developing costs for the modifications, and generating pipe network costs parametrically as a function of IPH temperature and plant size.

Task A

The JPL pipe network optimization methodology utilizes a Lagrange multiplier method for calculating the pipe diameters and insulation thickness of individual pipe segments. This was used to find the minimum overall pipe network costs. The computed pipe diameters, lengths, and insulation thicknesses were then applied to the JPL conventional construction cost model to calculate the cost of the thermal transport network.

A pipe network optimization computer program based on a different mathematical approach was developed by FACC. Both the FACC and JPL programs were used to calculate the baseline STEOR pipe/insulation sizes and cost (based on the JPL conventional cost model). Assessment of the JPL optimization methodology consisted of comparing the results of these two codes.

Evaluation of the JPL conventional cost model was accomplished by comparing the results of a detailed cost analysis of the baseline STEOR pipe network with those predicted by the JPL cost model.

Task B

The major modification to the SCSE system required for its use in the selected IPH application would be the addition of riser/downcomer assemblies to the dish (no significant modifications will be required for the receiver to be used for steam generation). These assemblies must be capable of accommodating the dish motion about the elevation/azimuth gimbals.

The portion of Task B related to the parametric development of pipe network cost estimates as a function of IPH temperature and plant size was addressed by using the FACC pipe network optimization code and the JPL conventional cost model. Temperature variation was examined by generating pipe network costs for the baseline STEOR application and for two other oil field pressures corresponding to two lower steam temperatures. The variation of plant size was examined by maintaining the baseline STEOR temperature/pressure conditions, and increasing the plant size.

ORIGINAL PAGE IS
OF POOR QUALITY

TABLE 2-1. TASK 12 - IPH STUDY REQUIREMENTS

• REQUIRED BY JPL STATEMENT OF WORK

* NON-CONTRACTED WORK INCLUDED BY FACC

TASK A

- ASSESS THE JPL/TURNER PIPING OPTIMIZATION METHODOLOGY (COMPUTER CGPE)
- VERIFY THE JPL CONCEPT (PRIMARILY COST) FOR CONVENTIONAL IPH THERMAL TRANSPORT
- * EVALUATE THE IMPACT OF ADVANCED (NONCONVENTIONAL) CONSTRUCTION TECHNOLOGY ON TRANSPORT SYSTEM COST

TASK B

- CONDUCT A PRELIMINARY DESIGN (CONVENTIONAL CONSTRUCTION) TO MODIFY THE SCSE (EE-1) SOLAR ELECTRIC SYSTEM TO INCORPORATE IPH FEATURES
- DEVELOP COST MODELS FOR PRELIMINARY DESIGN THUS DEFINED
- GENERATE COST ESTIMATES PARAMETRICALLY AS A FUNCTION OF IPH TEMPERATURE REQUIREMENTS (3) AND PLANT SIZE (2)
- * RERUN AT LEAST ONE OF THE ABOVE CASES USING AN ADVANCED (NONCONVENTIONAL) COST MODEL

ORIGINAL PAGE IS
OF POOR QUALITY

Uncontracted Effort

FACC also conducted additional work to enhance the overall effort as indicated by the items in Table 2-1 flagged with an asterisk. The use of unconventional pipe network construction technology was studied and evaluated as part of Task A. The cost benefits derived from these approaches were incorporated as modifications to the conventional cost matrix in order to predict potential reductions in pipe network costs.

As part of the parametric study conducted in Task B, an additional case was computed based on the use of advanced, reduced cost, construction techniques.

2.2 STRUCTURE OF STUDY

The various elements of the IPH study have been addressed by selecting a baseline IPH application which provided the input data and requirements for all of the tasks to be performed. Figure 2-1 illustrates the interrelationship between the selection of the baseline IPH application and the work elements comprising the overall study effort.

All elements were keyed to the baseline solar thermal enhanced oil recovery (STEOR) application. The requirements of this application were used to size the solar collector field and define the thermal process parameters: pressure, temperature, and flowrates. The baseline field geometry and thermal properties were then specified in both JPL and FACC computer codes. These were used to calculate the pipe diameters and insulation thicknesses which in turn yielded minimum cost of the pipe network system*. A favorable comparison of the two sets of diameters and thicknesses served as a mutual validation of the two codes, thereby satisfying part of the Task A study requirement.

The remainder of Task A was completed by using the field geometry, pipe sizes, and insulation thicknesses calculated in the baseline optimization as the basis for generating an actual pipe network design. This involved the specification of fittings, valves, expansion joints, pipe guides, and anchors for the network. A bill of material was constructed and a detailed, bottoms-up costing of labor and material elements performed. These costs were entered into a cost matrix from which the total network cost was computed using appropriate labor rates, taxes, and indirect charges. The resulting pipe network cost was compared to the corresponding cost predicted by the JPL model as part of the earlier pipe network optimization computer code verification task. An analysis and evaluation of these results provided the basis for verification of the JPL conventional cost model.

The additional (uncontracted) effort performed as part of Task A was to identify and evaluate several unconventional or advanced approaches to pipe network construction which have the potential of reducing construction costs. This was accomplished by modifying the conventional cost matrix to account for the benefit of alternate low cost construction techniques and computing the

*Capital cost plus cost of thermal and frictional energy losses.

ORIGINAL PAGE IS
OF POOR QUALITY

resultant pipe network costs for comparison with the conventional construction cost estimate. Two of the advanced construction techniques, automated welding and prefabricated pipe supports, had been previously identified in JPL studies. Two other approaches were originated by FACC.

As shown in Figure 2-1, Task B was accomplished by performing a detailed design of the riser/downcomer assembly for the JPL-specified Low Cost Concentrator (LCC) using the baseline STEOR thermal parameters and flowrate requirements. Figure 2-1 identifies this task as the LCC flexible gimbal joint design. A cost analysis of the detailed riser/downcomer design was then prepared.

The second portion of Task B, the parametric study, used the baseline STEOR network and heat requirement, but recomputed the flowrates to correspond to two lower field pressures and temperatures. The lower temperature STEOR requirements were then input to the FACC pipe optimization code which re-optimized the pipe and insulation sizes and recomputed the pipe network cost for the reduced temperature conditions. The JPL conventional cost model was used for the pipe network cost calculation.

The baseline STEOR network and parametric analyses were computed using a JPL specified cost-of-energy of \$1500/kW_t. JPL later requested that the parametric study cases be reoptimized using a cost-of-energy of \$500/kW_t. Parametric results were, therefore, calculated for both cost-of-energy values.

The baseline STEOR case was also modified to study the effect of a larger network size (by 4.8 times) for the same temperature/pressure conditions as the baseline case. This larger size corresponds to the solar system required to completely replace the annual steam output of a fossil fuel generator.

An additional computer analysis (uncontracted work) was performed to determine the cost of the baseline STEOR pipe network using the JPL advanced (or unconventional) pipe network cost model.

2.3 SELECTION OF BASELINE IPH APPLICATION

A realistic solar IPH application was selected to define the field geometry and thermal requirements for the baseline pipe network. Potential process heat applications for the baseline case were identified at the SERI Solar Industrial Process Heat Conference held in Houston, Texas during December 16-19, 1980. A review of the potential applications showed that most were either too small (repowering of food processing plants, etc.) or too constrained by interfacing requirements with existing plant equipment or plant real estate limitations to be well suited to the purposes of this study. The exceptions were the STEOR applications described below.

2.3.1 EXXON APPLICATION

An application which appeared well suited to the objectives of this study was the solar thermal technology for enhanced oil recovery application described in a special presentation made by the Solar Thermal Systems Division of Exxon Enterprises, at the SERI IPH Meeting. In this application, injection

ORIGINAL PAGE IS
OF POOR QUALITY

of steam into oil fields is used to increase the production of heavy oil - like that found in southern California - from less than 10% to as much as 50% of the oil in place. The increases are currently realized by using steam produced from burning fossil fuels. The technique used is one in which steam is continuously injected into injection wells to force out oil in adjacent or producing wells. A considerable potential for energy savings exists because from one-sixth to one-third of the oil recovered is normally used to fire the fossil fueled steam generators.

The Exxon application is based on the Edison Field located about seven miles southeast of Bakersfield, California, as shown in Figure 2-2. The Edison field requirements are reasonably representative of Kern County, California heavy oil fields, except that the steam injection pressure is among the highest found in the area.

Separate investigations have been conducted by Exxon on the technical and economic feasibility of solar thermal technologies for enhanced oil recovery applications at the Edison field. Under DOE Contract No. DE-AC03-79CS30307, an Exxon-led team investigated the use of line focusing distributed receiver systems. Also Exxon was a subcontractor to Martin-Marietta on a team which examined the use of heliostat central receiver systems under DOE Contract No. DE-AC03-79SF10737. These studies suggested that solar energy systems could be technically capable of displacing fossil energy for enhanced oil recovery. Predicted system economic performance was highly dependent on uncertain future factors including: energy displaced, capital and operating costs, special tax and regulatory incentives, and displaced fossil energy cost determinants including taxes and escalation. A preliminary market screening analysis of California oil reservoirs indicated a significant potential for solar applications.

FACC contacted Exxon Enterprises for additional information on the STEOR application. Exxon was very helpful and provided copies of the final report for the line focusing distributed receiver system study. When the intent of the pipe network study was explained, Exxon suggested a "starter" solar system for which they had examined alternate solar collection technologies: 1) central receiver heliostats, 2) line focusing troughs, and 3) point focusing dishes. In the "starter" system application, a solar powered system would work in parallel with a fossil fueled steam generator to deliver steam continuously to the injection wells. The solar unit was sized to supply or replace about 20% of the annual fossil fuel steam generator output, rated at 25 MRTU/hour. At conditions of maximum insolation the solar generator contributes about 75% of the total steam generation and the fossil fuel unit is modulated to contribute the 25% balance. During the night, or conditions of zero insolation, all the steam is provided by the fossil fuel unit.

Table 2-2 summarizes the basic requirements of the STEOR requirement. The hybrid mode of operation has been described in conversations with Exxon Enterprises and has not been independently investigated by FACC.




FIGURE 2-2. LOCATION OF CALIFORNIA HEAVY OIL FIELDS

ORIGINAL PAGE IS
OF POOR QUALITY

TABLE 2-2. BASELINE IPH APPLICATION SOLAR THERMAL ENHANCED OIL RECOVERY

- APPLICATION:
 - SOLAR THERMAL ENHANCED OIL RECOVERY - EXXON COMPANY U.S.A.'s EDISON FIELD - BAKERSFIELD, CA
 - "STARTER" SOLAR APPLICATION INVESTIGATED BY EXXON ENTERPRISES, INC., FLORHAM PARK, N.J.
 - SOLAR STEAM GENERATOR TO OPERATE IN HYBRID MODE WITH 25 MBTU (RATED) FOSSIL FUELED STEAM GENERATOR
 - SOLAR GENERATOR SUPPLIES ABOUT 20 PERCENT OF HEAT
- STEAM GENERATION REQUIREMENTS:
 - INPUT - PRESSURIZED & TREATED FEEDWATER
 - OUTPUT - SATURATED STEAM AT 527°F, 850 psig, AT SOLAR FIELD DISCHARGE HEADER (80% QUALITY STEAM AT WELL HEAD)
 - TOTAL HEAT LOAD: 39000 MBTU/YEAR (11.42 x 10⁶ KWH/YR)
 - ANNUAL INSOLATION: 720000 BTU/FT² - YEAR (FRESNO TMY) (2270 KWH/M² - YEAR)

2.3.2 FIELD GEOMETRY

The Low Cost Concentrator (LCC) development by General Electric Company was designated by JPL as the baseline dish for the present IPH study. The LCC was selected by JPL because it has well documented design characteristics. Table 2-3 summarizes the LCC dish spacing and field sizing parameters used to determine the baseline field geometry. A simplified layout of the field is shown in Figure 2-3.

Ideally, the optimum sizing and geometry of a dish-solar array should take into account all of the system cost elements, including the cost of real estate, the pipe-network costs and thermal and shading losses. Selection of the baseline field geometry did not include the cost of real estate. Instead, the field was made as compact as possible to minimize the lengths of pipe required, but with sufficient spacing between dishes to:

- (1) Have acceptable mutual shading losses from adjacent dishes and,
- (2) Permit truck access for construction and maintenance.

A brief analysis of shading losses was performed to determine their variation with ground cover ratio (packing density) and for various north-south (LNS) and east-west (LEW) spacings (expressed in dish diameters). The results of this study are documented in Appendix A. The results show that a ground cover ratio of 0.42 and a 1.25 LNS x 1.50 LEW dish spacing will result in an annual shading loss of about 8 percent. When this shading loss was combined with the LCC collection efficiency and a nominal allowance made for thermal losses (see Table 2-3), the field size calculated to satisfy the STEOR thermal requirement was 72-1/2 dishes. For purposes of this study a 72 dish, 9x8 field array was used as shown in Figure 2-3. This field geometry is about the most compact considered practical within the constraints of vehicle access and acceptable shading losses.

The pipe network configuration consists of 18 identical feeder lines, each servicing four dishes and oriented in a north-south direction. The feeders supply (and tap) a centralized header which discharges at the east end of the field. The orientation of feeder and header lines was derived by minimizing the number of pipe sizes and the summed product of diameter times length for the various segments, both of which translate directly to pipe network cost.

2.3.3 THERMAL CONVERSION PROCESSES

The optimum thermal process for converting treated and pressurized feedwater to saturated steam at the solar field discharge header was not self-evident. In earlier studies of trough collector fields for an Edison field application, Exxon Enterprises had considered several thermal processes. These were re-evaluated for the dish-solar system. Table 2-4 lists the three thermal conversion processes examined and a brief summary of the evaluations.

TABLE 2-3. BASELINE CASE FIELD GEOMETRY

- SHADING CONSIDERATIONS: 1.25 LNS x 1.50 LEW (0.83 AR) SELECTED AS OPTIMUM DISH SPACING FOR 0.45 PACKING FRACTION
 - THIS GEOMETRY CONSIDERED MINIMUM SPACING FOR DISH CONSTRUCTION AND MAINTENANCE OF FIELD
 - ANNUAL SHADING LOSS - 8 PERCENT
- FIELD SIZING: LCC 12m DIA DISH, $\eta_{COL} = 0.68$, $A_C = 113.1 \text{ m}^2$
 - SHADING LOSS, $\eta_{SHADE} = 0.92$
 - THERMAL TRANSPORT LOSS $\eta_{ETS} = 0.98$
 - ANNUAL INSOLATION, $H = 2270 \text{ KWH/m}^2$ - YEAR (FRESNO TMY)
 - ANNUAL HEAT LOAD, $Q_R = 11.42 \times 10^6 \text{ KWH/YEAR}$
 - NUMBER DISHES REQUIRED:
 - $N = Q_R / A_C \eta_{COL} \eta_{SHADE} \eta_{ETS} H$
 - $= [11.42 \times 10^6 / (113.1)(0.68)(0.92)(0.98)(2270)]$
 - $= 72.5 \text{ DISHES}$
 - (72 DISHES USED FOR FIELD SYMMETRY)




FIGURE 2-3. 72 DISH FIELD GEOMETRY

TABLE 2-4. STEOR THERMAL CONVERSION PROCESSES
CONSIDERED FOR BASELINE IPH NETWORK

PROCESS	DESCRIPTION	EVALUATION
<ul style="list-style-type: none"> ● FLASH SEPARATOR. 	<p>HIGH PRESSURE (1200 PSI) WATER DIRECT HEATED TO 600°F IN SOLAR RECEIVERS. FLASHED (THROUGH VALVE) TO WATER/STEAM AT 850 PSIA.</p>	<ol style="list-style-type: none"> 1. RESULTS IN ONLY 2 PERCENT OF WATER CONVERTING TO STEAM. 2. LARGE FLOW RATE AND TRANSPORT LOSSES.
<ul style="list-style-type: none"> ● UNFIRED BOILER 	<p>HEAT TRANSFER FLUID (THERMINOL 88) HEATED IN RECEIVERS AND PASSED IN SERIES THROUGH CENTRAL BOILER AND FEED WATER HEAT EXCHANGER.</p>	<ol style="list-style-type: none"> 1. LOW STRESS UNPRESSURIZED PIPE NETWORK. 2. EFFICIENCY VERY SENSITIVE TO TEMPERATURE OF DELIVERED H.T. FLUID. 3. COST OF UNFIRED BOILER AND FEED-WATER HEAT EXCHANGERS IS CHARGEABLE TO ETS. 4. FIRE HAZARD OF THERMINOL. 5. HIGH THERMINOL FLOW RATES.
<ul style="list-style-type: none"> ● DIRECT GENERATION OF 850 PSI STEAM WITHIN RECEIVER. 	<p>70°F FEEDWATER PUMPED TO 850 PSI AND CONVERTED DIRECTLY TO STEAM WITHIN INDIVIDUAL RECEIVERS.</p>	<ol style="list-style-type: none"> 1. NO NEED TO INSULATE FEED WATER LINES. 2. NO THERMAL CONVERSION EQUIPMENT. 3. ACCEPTABLE SAFETY. 4. SOME RECEIVER MODIFICATION MAY BE REQUIRED.

Flash Separator. The flash separator consists of heating water pressurized to 1200 psia in the individual receivers and passing the collected hot water through a central expansion valve where it is isenthalpically expanded to 850 psia to produce a liquid/vapor mixture. However, this process results in only 2% of the water converting to steam. The residual water must then be repumped to 1200 psia and returned to the individual receivers for reheat. The large flowrates and heat losses which result from this process eliminated it from further consideration.


Unfired Boiler. The second process considered was an unfired boiler in which low pressure heat transfer fluid is circulated through the solar field and steam is generated in two centrally located heat exchange units. A schematic of this approach is shown in Figure 2-4. Two separate heat exchangers are required, a feedwater heater and a boiler.

The apparent advantage of the unfired boiler approach is that the pipe transport network is unpressurized. In the particular STEOR application selected, this benefit is greatly offset by the upper operating temperature limit of the heat exchange fluid which results in low temperature differentials across the heat exchangers and large flowrates and line sizes. Figure 2-5 shows the problems encountered with the unfired boiler heat exchanger. Therminol 88 was selected for the heat transfer fluid because it has one of the highest operating temperature capabilities of all the available commercial candidates. From Figure 2-5A, it is obvious that the temperature of Therminol leaving the boiler must exceed 527°F steam saturation temperature. If the boiler inlet temperature of the Therminol (T_H) is set by the maximum service temperature of the fluid - about 750°F - and the exit temperature (T_E) set above the saturation temperature (e.g.; 527°F), the boiler effectiveness was a reasonable value of about 0.80. The mass flowrate of the Therminol is then automatically set by the relationship

$$\dot{m} = \frac{Q_B}{C_p (T_H - T_E)} \quad (1)$$

where Q_B is the latent heat of vaporization required to vaporize the steam flowrate required for TEOR injection. Note that all values of Equation (1) are relatively fixed; Q_B by the thermal load requirements, T_H by the upper operating temperature limit for Therminol, and T_E by the saturation temperature of the steam.

In the series-connected heat exchanger arrangement shown in Figure 2-4 the mass flowrates of both Therminol and water are fixed by the boiler heat exchange, and hence the inlet and discharge temperature of both water and Therminol in the feedwater heater is also fixed. Figure 2-5B shows the variation of Therminol return temperature to the solar field as a function of discharge temperature from the field for two assumed boiler efficiencies. Also shown is the variation in required flowrate of Therminol, nondimensionalized in terms of the steam flowrate. As shown in Figure 2-5B, operation at the highest temperature allowed for Therminol 88 results in a flowrate requirement six times that of the water or steam flowrate.



- FLOW PARAMETER FOR $I_{d,n} = 1000 \text{ W/m}^2$
- $Q_{\text{TOTAL}} = 18.44 \times 10^6 \text{ BTU/HR (5402 KW}_t\text{)}$

FIGURE 2-4. UNFIRED BOILER SYSTEM SCHEMATIC





FIGURE 2-5. UNFIRED BOILER SENSITIVITY OF MASS FLOWRATE TO SOLAR FIELD DISCHARGE TEMPERATURE

ORIGINAL PAGE IS
OF POOR QUALITY

The primary disadvantage of the unfired boiler is that large flowrates of fluid (Therminol 88) are required to achieve the desired heat transfer. This results in large pipe sizes, and a larger volume of heat transfer fluid. In addition to the more expensive pipe and fluid, the cost of the two heat exchangers should also be assigned to the pipe network cost.

Direct Generation of Steam in Receiver

Direct generation of steam within the solar receiver is shown schematically in Figure 2-6. The disadvantage of this approach is that the entire pipe network and receiver must be pressurized to 850 psig. However, pressurized steam pipe networks are very common industrial installations and are routinely constructed of carbon steel pipe. The ASME Standard Code for Pressure Piping for schedule 80 pipe allows A-53B and A-106B carbon steel pipe to operate at temperatures to 600°F and pressures of 1200 psia. At a temperature of 800°F the allowable pressure is 800 psia.

The direct heated receiver FACC has developed during the SCSE Phase II program is designed to heat toluene at supercritical pressure (≈ 650 psia) to a temperature of 750°F. Examination of the receiver design indicates it is structurally capable of operating with 527°F steam at 850 psig at about one-half the allowable ASME stress level.

As indicated in Table 2-4 the direct generation of steam within the receivers has the benefits that there is no need to insulate the feedwater supply lines, and no need to provide additional heat exchanger units as in the case of the unfired boiler.

Comparative Pipe Network Costs.

In order to make a comparison of the pipe network costs for the unfired boiler with that for the direct generation of steam, the data for both approaches was input to the FACC pipe network optimization program. This program incorporated the JPL conventional pipe network cost model. The 72-dish network geometry was the same as shown in Figure 2-3, except that an equal north-south and east-west spacing of 1.5 dish diameters was used, which did not affect the comparison. (The dish spacing was later refined to a more compact field for the baseline network.) The results of the optimization for the two thermal processes are presented in Table 2-5 and show clearly that direct generation of steam in the receivers has about a 28 percent lower pipe network cost. The costs of feedwater and boiler heat exchangers were not included in the cost of the unfired boiler (Therminol 88) pipe network costs; these would drive the cost comparison even more to the approach of direct generation of steam within the receivers. Thus, direct generation of steam was the thermal process selected for the baseline STEOR pipe network application.

ORIGINAL PAGE IS
OF POOR QUALITY




FIGURE 2-6. DIRECT GENERATION OF STEAM IN RECEIVER

ORIGINAL PAGE IS
OF POOR QUALITY

TABLE 2-5. COMPARATIVE COSTS FOR ALTERNATE STEOR
THERMAL CONVERSION PROCESSES

THERMAL CONVERSION PROCESS	SOURCE TEMP. (°F)	RETURN TEMP. (°F)	BASIC FLOW UNIT (LB/SEC)	HEAT DELIVERED (KW _P)	PIPE NETWORK COST (\$/KWe)
● UNFIRED BOILER THERMINOL 88	750	430	.300	5162	124.77
● DIRECT GENERATION OF STEAM IN RECEIVER	550	70	.0616	5263	99.04

1. COSTS CALCULATED ONLY TO COMPARE THERMAL PROCESSES

2. 72 DISH FIELD SPACED 1.5 LNS (60') x 1.5 LEW (60')

3. JPL INSULATION (20 \$/CU FT) AND INSTALLED PIPE COSTS (CONVENTIONAL
CONSTRUCTION - SCHEDULE 40)

ORIGINAL PAGE IS
OF POOR QUALITY

SECTION 3

OPTIMIZATION CODE VERIFICATION

JPL pipe network optimization code uses the input data for the pipe geometry and thermal input/output requirements, and calculates the diameters and insulation thicknesses of the individual pipe segments to yield a minimum overall pipe network cost.* The minimization process includes the following:

- 1) Cost of installed pipe
- 2) Cost of insulation surrounding the pipe
- 3) Cost of energy (or power) loss by heat conduction
- 4) Cost of energy required to pump the fluid
- 5) Cost of the fluid which fills the network.

A major portion of Task A of the Statement of Work was for FACC to independently verify the JPL pipe optimization code. The procedure by which this verification was accomplished is summarized in Table 3-1.

3.1 CONTRACTUAL WORK

As indicated in Table 3-1 the verification process was started on a pre-contract basis. JPL supplied their pipe optimization code and documentation to FACC for review. In addition JPL supplied the input data for a 512-dish network. These inputs included the data for the five cost elements of the pipe network identified at the beginning of this section. The cost-of-energy required to pump fluid or to evaluate thermal losses was specified as \$1500/kWh.

FACC reviewed the JPL supplied documentation, generated a FACC optimization code which used a different mathematical approach, and performed comparative optimization calculations on the 512-dish network using the JPL and FACC codes. Examination of the JPL mathematical optimization showed that the equations for calculating friction and heat loss were conventional relationships.

The mathematical optimization procedure used by FACC was based on a Lagrange multiplier technique, in which the optimization of the insulation thickness was coupled from the optimization of the pipe diameter. The details of the procedure used are described in Appendix B. FACC utilized a different mathematical approach than JPL for determining the minimum pipeline cost (Appendix B). The FACC approach, summarized in Table 3-2, minimized the total cost function for each pipe segment by setting to zero the partial derivatives of total cost with respect to diameter (d_i) and with respect to insulation thickness (δ_i). The result was a coupled pair of transcendental equations in d_i and δ_i . These

*Capital cost plus cost of thermal and frictional energy losses.

ORIGINAL PAGE IS
POOR QUALITY

TABLE 3-1. OPTIMIZATION CODE VERIFICATION PROCEDURE

PRECONTRACTUAL

POST CONTRACTUAL

- REVIEWED TURNER CODE DOCUMENTATION
- MODIFIED FACCC PIPE COST CODE TO PERFORM SIMILAR OPTIMIZATION USING DIFFERENT MATHEMATICAL APPROACH
- RAN COMPARATIVE OPTIMIZATION SOLUTIONS USING BOTH CODES ON A JPL SPECIFIED FIELD ARRAY OF 512 DISHES
- OBTAINED GOOD COST COMPARISON (WITHIN 1/2 PERCENT) AND REASONABLE PIPE DIA. / INSULATION THICKNESS COMPARISON
- REPORTED RESULTS
 - JANUARY 8, 1981 FACCC INTERNAL MEMO
 - COPY TO JPL

- RAN COMPARATIVE OPTIMIZATION SOLUTIONS USING BOTH CODES ON BASELINE STEOR 72 DISH NETWORK
- RESULTS - COSTS IN GOOD AGREEMENT (WITHIN 5%)
 - VERY GOOD COMPARISON OF HOT SIDE PIPE DIAMETERS & INSULATION THICKNESSES
 - MODERATE DIFFERENCES IN COLD SIDE PIPE DIAS.
- RECONCILED DIFFERENCES
 - DIFFERENCES IN COLD SIDE PIPE DIAMETERS RESULT FROM MATHEMATICAL COUPLING IN JPL CODE BETWEEN HOT AND COLD SIDES
 - DECOUPLING HOT/COLD SIDES OF JPL CODE PRODUCES COLD PIPE DIAS. IN AGREEMENT WITH FACCC CODE
 - FURTHER SMALL IMPROVEMENT IN COST BY HOT/COLD SIDE DECOUPLING

TABLE 3-2. FACC OPTIMIZATION ALGORITHM

TOTAL COST FUNCTION

$$C_T = \sum_{i=1}^N \left\{ C_{P_i}(d_i) + C_{I_i}(d_i, \delta_i) + C_{\theta_i}(d_i, \delta_i) + C_{f_i}(d_i) + C_{FL_i}(d_i) \right\}$$

PIPE COST
INSULATION COST
COST OF THERMAL LOSS
COST OF FLUID

COST OF FRICTIONAL LOSS

- N = NUMBER OF SEGMENTS
- d_i = PIPE DIAMETER OF i th SEGMENTS
- δ_i = INSULATION THICKNESS OF i th SEGMENT

FOR EACH SEGMENT, SOLVE

$$\left. \begin{aligned} \frac{\partial C_T}{\partial d_i} &= 0 \\ \frac{\partial C_T}{\partial \delta_i} &= 0 \end{aligned} \right\}$$

THESE EQUATIONS ARE A PAIR OF COUPLED TRANSCENDENTAL EQUATIONS IN d_i AND δ_i .

THESE EQUATIONS ARE SOLVED INDEPENDENTLY FOR EACH PIPE SEGMENT

equations were solved independently for each pipe segment and the resultant diameters and thicknesses were used to compute the minimum value of the total cost function.

An existing FACC pipe network code was modified to incorporate the optimization technique described above as part of the precontractual effort. The case of the 512-dish network specified by JPL was then optimized using both the FACC and the JPL codes. A comparison of the results is presented in Appendix B and shows that the two codes are in good agreement, with the minimum network pipe cost agreeing within one-half percent. Hot side pipe sizes and insulation distributions compared reasonably well, but minor disagreements were obtained between the cold side diameters calculated by the two codes. These disagreements became more pronounced in subsequent verification comparisons of the baseline STEOR application and are discussed later in this section.

3.2 CONTRACTED OPTIMIZATION CODE VERIFICATION

As described in Section 2.2 the baseline IPH network was used as an additional case for mutual verification of the JPL and FACC pipe network optimization codes. The pipe network geometry shown in Figure 2-3 was input to both codes along with the steam system thermal inputs shown on Figure 2-6. There was no cold side insulation since 70°F feedwater was used.

3.2.1 BASELINE APPLICATION RESULTS

Table 3-3 compares the pipe diameters and insulation thicknesses calculated by the two codes for the baseline STEOR pipe network. A comparison of the calculated hot side pipe diameters and insulation thicknesses shows very good agreement, however, the agreement for the cold side pipe diameters was not good. For example, the smallest cold side pipe diameter calculated by the FACC code is 0.234 inch and is 0.160 inch for the JPL code (see Table 3-3). The reason is discussed in Paragraph 3.2.2.

The cost comparison shown in Table 3-3 indicates agreement within about 5%, which is reasonably good.

3.2.2 JPL COUPLING EFFECTS

The essential features of each code are compared in Table 3-4. The source of the difference was found to be due to the mathematical coupling of hot and cold side diameters in the JPL code. If the cold side network optimization is decoupled from the hot side optimization, the JPL code calculates the cold side pipe sizes shown in the last column of Table 3.3. The recalculated cold side diameters are then in much better agreement with the FACC code results.

Table 3-5 is a summary of the pipe size and pipe network costs calculated by the two codes. Good agreement is obtained when the optimization of pipe size and insulation thicknesses on the hot and cold side are decoupled in the JPL code. A slight improvement in network costs (which were already in reasonably good agreement, as indicated above) is achieved by this decoupling. The lower pipe network costs calculated by the FACC code (4.8 percent lower) are

ORIGINAL PAGE IS
OF POOR QUALITY

TABLE 3-3. COMPARISON OF PIPE NETWORK OPTIMIZATION
COMPUTATIONS FACC VS. JPL CODE

BASELINE STEOR PIPE NETWORK
72 DISH - 9 x 8 ARRAY
N-S SPACING - 45 FEET
E-W SPACING - 60 FEET
FACC CODE USES JPL FRICTION MODEL

PIPE NO.	FLOW(1) UNITS	HOT SIDE PIPE I. D. (INCHES)		HOT SIDE INSULATION (INCHES)		COLD SIDE PIPE I. D. (INCHES)	
		FACC	JPL	FACC	JPL	FACC	JPL
1	1	.446	.450	2.92	3.00	.234	.160
2	2	.639	.636	3.15	3.20	.326	.217
3	3	.788	.779	3.31	3.32	.396	.263
4	4	.913	.900	3.42	3.42	.454	.302
5	8	1.302	1.273	3.71	3.68	.633	.422
6	16	1.853	1.800	4.02	3.96	.882	.588
7	24	2.274	2.205	4.21	4.14	1.070	.714
8	32	2.629	2.546	4.35	4.27	1.228	.819
9	40	2.941	2.846	4.46	4.37	1.366	.912
10	48	3.223	3.118	4.55	4.46	1.491	.995
11	56	3.482	3.367	4.63	4.53	1.605	1.071
12	64	3.723	3.600	4.70	4.59	1.711	1.142
13	72	3.948	3.818	4.76	4.65	1.810	1.208

PIPE NETWORK COST =
FACC 71.81 \$/KW_t
JPL 75.45 \$/KW_t (2)

*(1) FLOW UNIT = .061 LB/SEC
*(2) TURNER CODE HOT/COLD SIDES COUPLED
*(3) TURNER CODE HOT/COLD SIDED DECOUPLED

TABLE 3-4. COMPARISON OF JPL AND FACC COST OPTIMIZATION TECHNIQUES - ESSENTIAL FEATURES

JPL

FACC

- PARTIALLY DECOUPLES FRICTIONAL AND THERMAL LOSS EFFECTS
- USES LAGRANGE MULTIPLIER METHOD WHICH RELATES DIAMETER OF EACH PIPE SEGMENT TO THE DIAMETER OF SMALLEST HOT SIDE SEGMENT - BASED ON CONSIDERATION OF FRICTIONAL LOSSES ONLY
- INSULATION THICKNESS OF EACH SEGMENT IS DEPENDENT ON THICKNESS OF INSULATION ON SMALLEST HOT SIDE SEGMENT
- MINIMUM COST IS FOUND BY VARYING TWO PARAMETER-DIAMETER AND INSULATION THICKNESS OF SMALL EST HOT SIDE PIPE SEGMENT
- MAINTAINS COUPLING BETWEEN THERMAL AND FRICTIONAL LOSSES
- USES PARTIAL DIFFERENTIATION OF TOTAL COST FUNCTION TO OBTAIN OPTIMUM PIPE DIAMETER AND INSULATION THICKNESS
- OPTIMIZATION OF EACH SEGMENT IS INDEPENDENT OF THE OTHER SEGMENTS
- MINIMUM COST IS FOUND BY SOLVING A PAIR OF COUPLED TRANSCENDENTAL EQUATIONS FOR PIPE DIAMETER AND INSULATION THICKNESS ON EACH SEGMENT

ORIGINAL PAGE IS
OF POOR QUALITY

TABLE 3-5. OPTIMIZATION CODE COMPARISON RESULTS

<u>CODE</u>	<u>MINIMUM DIAMETER</u>		<u>COST</u> \$/kW _t	<u>COMMENT</u>
	HOT SIDE	COLD SIDE		
FACC	.446	.234	71.81	
JPL (CASE 1)	.450	.160	75.45	HOT AND COLD SIDE COUPLED *
JPL (CASE 2)	.450	.234	75.14	HOT AND COLD SIDE DECOUPLED

APPROXIMATE RECONCILIATION OF FACC & JPL RESULTS

	<u>FACC</u>	<u>JPL CASE #2</u>	<u>DIFFERENCE</u> \$/kW _t
THERMAL LOSS	94 kW _t	104 kW _t	2.83*
FRICTION LOSS	10.5 kW _t	11.8 kW _t	.37*
INSULATION COST	\$32819	\$32248	<.11>
PIPE	\$187353	\$188690	<u>.24</u>
			\$ 3.33 (JPL HIGHER)
			<u>\$71.81 (FACC)</u>

*LOSSES @ 1500 \$/kW_t
COST OF ENERGY

attributed to the fact that the optimization procedure of the JPL code is not mathematically exact; that is, the decoupling of the pipe diameter optimization from the insulation thickness optimization introduces a certain degree of approximation into the results. The FACC procedure avoids mathematical approximations and yields a lower value for the optimized network cost.

3.2.3 STANDARD PIPE SIZES

In the comparisons of the JPL and FACC optimization codes described above the minimum cost pipe was first calculated based on the computed minimum inside pipe diameter. The FACC program also has the capability to select the diameter which yield the minimum cost from a table of standard pipe sizes (using the appropriate pipe schedule). The results shown in Table 3-6 for the baseline STEOR network compare pipe diameters and costs for optimum networks constructed of mathematical and standard pipe sizes. Table 3-6 shows the total cost of a network constructed of standard pipe sizes is \$78.53/kW_t versus \$73.60/kW_t for a network constructed of mathematical sizes, or 6.7 percent higher. The total system cost includes all system costs, both capital as well as the cost of lost energy due to friction and heat loss.

3.2.4 COST OF ENERGY

The cost of lost energy is part of the pipe network optimization code input data. In the 512-dish network input data originally supplied by JPL for the pre-contractual effort, the cost of energy was assessed at \$1500/kW_t. This value was used in computing the pipe diameters and insulation thicknesses for the baseline STEOR pipe network design and also for detailed analysis of conventional construction costs (discussed below). Near the end of this study JPL requested that parametric optimization results be generated using a cost-of-energy of \$1500/kW_t and \$500/kW_t. The influence of specified cost-of-energy on pipe network optimization results is discussed in Section 6.0.

ORIGINAL PAGE IS
OF POOR QUALITY

TABLE 3-6. FACC OPTIMIZATION RESULTS COMPARISON OF REAL VS. MATHEMATICAL PIPE SIZES

- 72 DISH ARRAY
- N-S SPACING 49 FEET
- E-W SPACING 60 FEET
- SCHEDULE 80 PIPE

TYPICAL PIPE SEGMENT COMPUTATIONS - HOT SIDE

PIPE NO.	FLOW UNITS	OPTIMUM MATHEMATICAL		OPTIMUM REAL PIPE DIAMETERS		O.D. (INCHES)	OPTIMUM MATHEMATICAL INSULATION (INCHES)	OPTIMUM INSULATION FOR REAL PIPE OUTSIDE DIA. (INCHES)
		I. D. (INCHES)	I. D. (INCHES)	NOM. (INCHES)	O.D. (INCHES)			
1	1	.50	.546	.500	.840		2.99	3.35
2	2	.713	.742	.750	1.050		3.23	3.52
0	4	1.012	.957	1.000	1.315		3.50	3.71
6	18	2.026	1.939	2.000	2.375		4.10	4.24
8	32	2.861	2.900	3.000	3.500		4.43	4.63
10	48	3.498	3.364	3.500	4.000		4.63	4.76
12	64	3.944	3.944	4.000	4.500		4.76	4.85

PIPE NETWORK COSTS

MATHEMATICAL SIZES	73.60 \$/kW _t
REAL PIPE SIZES	78.53 \$/kW _t

ORIGINAL PAGE IS
OF POOR QUALITY

SECTION 4

CONVENTIONAL CONSTRUCTION COST MODEL

The second part of Task A of this study was to verify the JPL cost model for IPH thermal transport based on the use of conventional pipe network construction technology. This was accomplished by using the baseline STEOR pipe network geometry shown in Figure 2-3 and the optimized standard (real) pipe diameters and insulation thicknesses shown in Table 3-6 to construct a detailed pipe network. This network included a specification of the pipe, fittings, valves, expansion joints, pipe supports, and insulation. From the detailed pipe network design a bill of material was constructed and material and labor costs were estimated. This bottoms-up cost estimate of the network was then compared to the costs predicted by the JPL conventional cost model.

4.1 PIPE NETWORK DETAILED DESIGN

Figure 4-1 shows a layout of the baseline STEOR pipe network. As shown in Figure 4-1 (and previously in Figure 2-3) the network consists of an 8x9 dish array with four dishes connected to eighteen north-south running feeder lines. Each feeder line is connected to four dishes and consists of both the feedwater supply and steam discharge pipe. The eighteen feeders are connected to a central east-west header running the length of the field and discharge at the east end of the field. The feedwater supply line runs parallel to the steam lines except they span the steam-line expansion joints.

Figure 4-2 shows two of the feeder lines which are typical of all eighteen feeders. The north-south axis of the feeders has been rotated 90 degrees for easier presentation. The outer circle at each dish location represents the diameter of the concrete pad on which the LCC is mounted.

Arrangement of Pipe Anchors

The riser/downcomer design discussed in Section 7 emerges at the edge of each pad and enters the feeder line using welded 3,000 lb 'sockolet' fittings of the type shown in Figure 4-3. The feeder lines are anchored at the point where the riser/downcomer enters the dish. The anchor is a reinforced steel concrete pillar to which the steam feeder line is welded and the water line is clamped. A similar pipe anchor, shared by both water and steam lines, is located on each header at the location where opposing feeder lines penetrate the header. Details of the construction are given in Section 5.

Pipe Size

All pipe in the proposed network is schedule 80 type A-106B or A-53B carbon steel. The ASME Standard Code for Pressure Piping specifies an allowable stress level of 15,000 psi at operating temperatures to 600°F for A-106B and A-53B welded pipe construction.

SOURCE: GENERAL CONSTRUCTION & ESTIMATING STANDARDS - VOL. 3
RICHARDSON ENGINEERING SERVICES, INC.
SAN MARCOS, CALIFORNIA - 1980

ORIGINAL PAGE IS OF POOR QUALITY




FIGURE 4-3. WELD & PIPEFITTING LABOR ESTIMATE

Fittings

Fittings selected for pipe sizes up to 2-1/2 inch nominal diameter were the welded 'sockolet' design. This type of fitting is more expensive than butt-welded fittings but requires less labor for joint preparation, installation and welding. Characteristics of the sockolet design and line penetration are shown in Figure 4-3. The sockolet fitting would be used in place of tees at the penetration points of risers and downcomers into feeders, and penetrations of feeders into headers. Sockolet unions were assumed to occur over every 20 ft span of pipe not otherwise interrupted by a reducer, elbow, or tee.

Expansion Joints

Approximately 2.5 inches of thermal expansion will occur between the anchor points of each feeder line and 3.0 inches between the anchor points on each header. This expansion was accommodated by field fabricated expansion joints constructed of elbows and straight sections of pipe. The construction of an expansion joint involves at least eight elbow welds and also the placement of additional pipe supports to support the offset sections of pipe.

The expansion joint dimensions for the baseline STEOR network were selected by calculating the maximum combined (pressure plus bending) pipe stresses and axial loads for a range of pipe diameters and joint dimensions as shown in Figure 4-4. The design points, indicated by the circles in Figure 4-4, were selected to provide some uniformity of construction while affording comfortable margins of stress. The use of factory fabricated 'omega-shaped' joints was also investigated as an alternative to the field fabricated expansion joints. The design curves used to size and cost the omega joints are shown in Figure 4-5.

Pipe Guides

In addition to the anchors some guide-type pipe supports will be required to support the weight of the pipe against bending. For example, a roller type guide will be required at both ends of the field-fabricated expansion joints as well as at the middle of the joint to support the offset sections of pipe. Since these guides require a concrete support pillar, the pillar is also used to mount a simple water line pipe support (shown in Section 5, Figure 5-3A). In the case of the steam lines the larger pipe diameter yields a stiffness (high section modulus) such that the distance between anchors and pipe guides used to support the expansion joints provides sufficient vertical support to the steam line. However, calculations presented in Figures 4-6 and 4-7 show that additional guide-type pipe supports are required at more frequent spacing along the water lines (lower pipe diameters and section modulus).

ORIGINAL PAGE IS
OF POOR QUALITY





FIGURE 4-4. LOADS AND STRESSES FOR FIELD CONSTRUCTED EXPANSION JOINTS

ORIGINAL PAGE IS
OF POOR QUALITY





FIGURE 4-5. MAXIMUM STRESS AND THERMAL EXPANSION LOADS
IN FACTORY FABRICATED BENT OMEGA JOINTS

14

ORIGINAL PAGE IS
OF POOR QUALITY




FIGURE 4-6. COMBINED FLEXURAL AND PRESSURE STRESS IN WATER LINE

ORIGINAL PAGE IS
OF POOR QUALITY




FIGURE 4-7. MAXIMUM SPACING BETWEEN WATER PIPELINE SUPPORTS

ORIGINAL PAGE IS
OF POOR QUALITY

Valves

Shutoff valves were assumed to be required to shut off the water and steam lines to each dish (144 valves) as well as to each feeder line (36 valves). Hand operated socket welded globe valves were specified at all locations. In addition it was assumed that each steam line would include a pressure relief valve (18 valves). A valve was not used at the steam header discharge point, but a 2-inch main feedwater inlet valve was specified, as well as a main water-line checkvalve.

All valves were assumed to be hand operated types, but it is likely that some valves in a real application would be automatically operated and integrated into the overall control system. Since this study did not address the control aspects of the IPH application, the cost for addition of automatic pneumatic or electromechanical valve operators was not included as a pipe network cost.

Insulation

The steam line was insulated using molded high temperature calcium silicate insulation. This material was specified because of the 530°F steam application. The insulation would be field installed over the pipes and valves using standard thicknesses that most closely approximate the thicknesses calculated by the pipe-network optimization computer code. A field installed, prefabricated aluminum jacket would be used to weather-seal the insulation.

4.2 COSTING ASSUMPTIONS

The purpose of specifying a detailed design for the baseline STEOR piping network was to conduct a detailed, bottoms-up cost analysis with which to compare similar costs obtained from the JPL cost model for conventional pipe construction. The cost estimating assumptions used in performing this task are listed in Table 4-1. Conventional field construction would be used to perform all tasks on the pipe network construction site. This includes all cutting and preparation (end beveling, etc.) of pipe, and welding of pipe joints and the joints of the fittings and valves. The foundations and pillars for pipe supports would be reinforced concrete with the concrete poured into hand framed forms or preformed fiber 'sonotubes'. The pipe insulation would be premolded sections installed in the field.

The majority of pipe network material and labor costs were obtained from General Construction Cost Estimating, Volumes 1 and 3, Richardson Engineering Services, Inc., San Marcos, California, 1980. Some of the material costs in this reference were independently checked by consulting suppliers or supplier's catalogs. A formal quotation was obtained on mill-run quantities of A-106 and A-53 pipe and the responses are presented in Appendix D. The independent checks of material prices indicated that the Richardson estimating costs may be a few percent high, which probably reflects a nominal allowance for delivery of materials.

ORIGINAL PAGE IS
OF POOR QUALITY

TABLE 4-1. COST ESTIMATING ASSUMPTIONS

- CONVENTIONAL FIELD CONSTRUCTION
- SCHEDULE 80 CARBON STEEL (A-106) PIPE CONSTRUCTION
- IDEAL SURFACE, ACCESSIBILITY, LABOR AVAILABILITY CONDITIONS (NO CONTINGENCY FACTORS USED)
- ALL LABOR AND MATERIAL RATES OBTAINED FROM

GENERAL CONSTRUCTION & ESTIMATING STANDARDS
 VOLS. 1 & 3
 RICHARDSON ENGINEERING SERVICES, INC.
 SAN MARCOS, CALIF. - 1980

PIPE AND FITTING COSTS VERIFIED BY PURCHASING INQUIRIES TO SUPPLIERS:

KILSBY TUBE SUPPLY
 TUBE SALES
 FUTURE METALS
 JMC SALES
 FEE AND MASON

INSULATION COSTS - INDASCO, INC.

	<u>DIRECT</u> \$/HR.	<u>INDIRECT</u> \$/HR.
PIPEFITTING, WELDING	16.95	10.00
CONCRETE	12.85	5.90
INSULATION	9.00	5.40
INSPECTION	16.95	10.00
SALES TAX	6% OF MATERIAL	
PERFORMANCE BONDS	1.5% OF TOTAL	
PROFIT	10%	

• 1980 RATES

ORIGINAL PAGE IS
OF POOR QUALITY

The 1981 labor rates specified by Richardson are shown on Table 4-1 and include no allowances for contingencies such as remote site travel, hazard pay, or other factors. The indirect cost is the contractor's overhead cost. A sales tax of six percent was assumed on all material, and 1.5 percent allowed for the cost of insurance and performance bonds. A contractor's profit of 10 percent was included.

4.3 COST DATA

As previously stated the majority of material and labor cost data was obtained from the Richardson book. However this reference did not have data for the two items of the construction costs discussed below, i.e., insulation and inspection.

Insulation

Premolded calcium-silicate insulation was used for the steam line because the 530°F condition precludes use of slightly less expensive insulating materials (e.g., fiberglass). A quotation was solicited from INDASCO, Inc., for the insulation sizes required on the baseline network. A quotation was also obtained for aluminum weather seal jacketing for the insulation. A copy of the INDASCO quotation is presented in Appendix D. The labor to field install the insulation and weather seal was estimated with the assistance of FACC plant engineering personnel. A direct labor rate of \$9/hr was applied to the estimated labor hours.

The JPL conventional cost model uses an insulation cost of \$20 per cubic foot to account for material and direct labor for all pipe sizes. The FACC data for insulation was recomputed on a cubic foot basis and the cost distribution versus nominal pipe diameter is shown in Figure 4-8. The lower line of the figure shows the insulation material cost for straight sections of pipe. An additional material cost allowance of 10 percent was used to account for insulation around valves and fittings as shown by the second lowest line. To this was added the cost of aluminum jacketing to arrive at the total insulation material cost. Direct labor for installation was added to arrive at total insulation cost. The JPL estimate of \$20/cubic foot is shown for reference. The JPL estimate appears to be lower for small pipe sizes, but nears the FACC cost for larger pipe sizes.

Inspection

Inspection requirements for the baseline network were defined to consist of dye penetrant inspection of all welds followed by a low pressure (snoop) leak check, followed by static hydrostatic proof testing. The majority of the costs were related to the dye penetrant and leak checks on the individual welds. The number of welds of each pipe diameter were counted and a reasonable labor effort per joint for the inspection described was assigned. A direct labor rate of \$16.95 per hour (equivalent to a pipefitter or welder) was applied to the labor hour estimate.

ORIGINAL PAGE IS
OF POOR QUALITY

LABOR & MATERIAL COSTS
EXPRESSED ON \$/CU FT. BASIS

KAYLO-10 CALCIUM SILICATE
PIPE INSULATION


TOTAL LABOR + MATERIAL
TOTAL MATERIAL

STRAIGHT SECTIONS

FITTINGS & VALVES

ALUMINUM JACKET WEATHER-SEAL

INSTALLATION LABOR (DIRECT)



NOMINAL PIPE DIAMETER - INCHES

FIGURE 4-8. INSULATION COST COMPARISON

50

4.4 COST MATRIX

The cost data obtained for the various categories of pipe network labor and material were entered into a cost matrix having the format shown in Figure 4-9. The costs were classified by pipe diameter and included the cost categories of pipe, expansion joints, fixtures, valves, anchors, pipe guides, foundations, insulation, and inspection. The costs of each category were separated into labor, material, direct, indirect and surcharges as shown under the "pipe" category in Figure 4-9. The matrix of network costs was entered into a computer code to perform various accounting functions and arrive at totals. A sample of the computerized matrix for the baseline pipe network is included in Appendix C (Figure C-1). The utility of a computerized cost matrix is that the costs of alternate construction techniques can be introduced and the total network cost recomputed with minimum effort and good accuracy.

4.5 RESULTS

An over-all comparison of the pipe network costs obtained from the detailed (bottoms-up) cost analysis and the costs predicted by the JPL cost model is shown in Figure 4-10. The JPL cost model does not include indirect contractor costs, profit, or taxes and bonds, which should be considered an accounting omission. Therefore, a fair comparison of costs required the use of only the direct labor and material costs, as indicated by the line of comparison shown in Figure 4-10. All subsequent comparisons made in this report will address only direct labor plus material costs.

As indicated in Figure 4-10, the JPL cost model predicts a labor plus material cost about 20 percent lower than the detailed FACC cost model. This is considered a fair comparison of the two methods. An examination of the JPL cost model revealed the likely source of the difference was the method by which JPL accounts for the cost of expansion joints. JPL employs a curve of installed pipe cost (excluding insulation) versus nominal pipe diameter. The pipe cost includes material and direct labor for pipe, fittings, valves, etc. To account for the thermal expansion joints in hot-side pipes, the length of hot pipe segments are multiplied by $\sqrt{2}$ and then multiplied by the cost-per-foot (\$/ft) value for the corresponding pipe diameter. JPL has indicated that the $\sqrt{2}$ factor to account for expansion joints represents an approximate average of a rather wide range of observed values (≈ 1.2 to 1.6). In the FACC detailed network cost the addition of field fabricated expansion joints actually added about 24 percent to the straight runs of pipe. If a 1.24 factor were applied to the JPL hot-side pipe cost instead of a $\sqrt{2}$ factor, the total pipe network cost predicted by the JPL model would reduce from \$237K to \$212K, which was within 10 percent of the detailed overall pipe network cost.

Figure 4-11 shows the over all cost comparison for labor plus material for both steam and water-side pipelines. As shown, the majority of the difference occurs on the water-side of the network. Since 86 percent of the water-side pipe is of nominal diameters between 1/8 and 1/2-inch, the JPL model may not be accurate for these small sizes.

ORIGINAL PAGE 10
OF POOR QUALITY

	.50	.75	1.00	1.50	2.00	2.50	3.00	3.50	4.00	TOTAL
NOMINAL DIA										
STRAIGHT LENGTH	882	882	1323	60	60	60	60	120	134	
EXP JOINT LENGTH	216	216	324	12	12	12	16	32	32	
TOTAL LENGTH	1098	1098	1647	72	72	72	70	152	166	
PIPE COST										
LABOR HOURS										
LABOR \$										
MATERIAL \$										
SALES TAX										
INDIRECT										
PROFIT										
BONDS										
EXPANSION JOINTS										
FIXTURES										
VALVES										
ANCHORS										
GUIDES										
FOUNDATIONS										
INSULATION										
INSPECTION										
TOTALS										

FIGURE 4-9. BASELINE PIPE NETWORK COST MATRIX

ORIGINAL PAGE IS
OF POOR QUALITY




FIGURE 4-10. COMPARISON OF EACC AND JPL PIPE NETWORK COST FOR STEOR APPLICATION

ORIGINAL PAGE IS
OF POOR QUALITY




FIGURE 4-11. COMPARISON OF LABOR AND MATERIAL COST FOR STEAM PIPE NETWORK

59.

ORIGINAL PAGE IS
OF POOR QUALITY

Figure 4-12 compares the makeup of costs for the steam-side 1-inch diameter pipe (which makes up 37 percent of the hot side STEOR network) with a similar breakdown for 1-inch pipe reported by JPL. Since the JPL cost breakdown was for schedule 40 pipe, the JPL breakdown was adjusted to schedule 80 by fixing the cost of supports and proportioning the other costs based on the ratio 22.00 (\$/ft)/19.60 (\$/ft) totals (schedule 80/schedule 40) reported by JPL. As shown the installed pipe cost per linear foot for the 1-inch (most common) pipe size agrees within 10 percent. The comparison shown in Figure 4-12 does not include the $\sqrt{2}$ factor for expansion joints previously discussed.

Figure 4-13 shows the labor plus material cost breakdowns obtained from the bottoms-up STEOR analysis distributed according to nominal pipe diameter. The dotted line shows the total labor plus material cost distribution predicted by the JPL cost model. Since the majority of STEOR pipe sizes are less than 1-inch diameter, the comparisons shown in Figure 4-13 resulted in predicting a lower detailed network cost than predicted by the JPL cost model. The large cost for the 1-1/2 to 4 inch pipe diameters may occur because these are the header size pipes and have a larger number of penetrations, etc.

Figure 4-14 shows a more detailed analysis of a breakdown on the total STEOR costs. The left hand column refers to total cost with no breakdown between labor and material. The right hand column breaks down the total cost between labor and material.

The significant conclusions from Figure 4-14 are:

1. Dominant elements of labor plus material cost are:

- A. Cost of insulation (26.3%)
- B. Cost of pipe supports (37%)

2. Use of automated welding and field shop construction has the potential of reducing the following labor costs:

- A. Cutting and welding costs 21% of total cost
- B. Mechanical costs* 15%

TOTAL 36% (Maximum possible reduction
if all labor eliminated)

The areas outlined above have the greatest potential for cost reduction by the use of nonconventional and advanced construction techniques.

* Mechanical fastening, aligning, etc.

ORIGINAL PAGE IS
OF POOR QUALITY




FIGURE 4-12. OVERALL COMPARISON OF PIPE NETWORK COST FOR STEAM APPLICATION

ORIGINAL PAGE IS
OF POOR QUALITY




FIGURE 4-13. DISTRIBUTION OF LABOR & MATERIAL COST




FIGURE 4-14. ANALYSIS OF LABOR AND MATERIAL COST, 72 DISH STEOR PIPE NETWORK, FACC COST ANALYSIS

COST - \$100

ORIGINAL PAGE IS
OF POOR QUALITY

SECTION 5

UNCONVENTIONAL CONSTRUCTION

This section discusses some approaches to pipe network construction to reduce overall cost. These represent existing or near-term technology not traditionally used in pipe network construction. The use of technologies that require major capital investment, such as new factories or automated tooling to manufacture prefabricated assemblies, is not included.

The approaches that were investigated to reduce cost are summarized in Table 5-1. Two of these, automated welding and prefabricated pipe supports, have previously been identified by JPL. The FACC study independently defined the application of these approaches to the baseline STEOR network and used the cost matrix developed for the network to assess the impact on overall pipe network cost.

In addition to the unconventional construction approaches listed in Table 5-1, a brief investigation was conducted to determine the cost benefit of using prefabricated expansion loops in place of field constructed expansion joints. These results are reported in this section.

5.1 PRE-FABRICATED OMEGA-SHAPED EXPANSION JOINTS

Substitution of prefabricated omega-shaped expansion joints in place of field constructed expansion joints made of welded elbows and straight sections of pipe offers a cost savings in total labor plus material of about five percent. The factory fabricated joint would be bent from a single piece of pipe into an omega shape. The prefabricated omega joints would be slightly more cumbersome to ship and handle in the field, but would reduce the number of field welds from eight elbow welds to two welds for installing an omega.

The cost evaluation of using omega joints was made by designing the joints for the STEOR pipe network using design curves shown in Figure 4-6 and submitting these designs to an outside fabricator for quotation. A copy of the quotation is presented in Appendix D. The cost matrix for the baseline pipe network was modified to include the quoted material cost of the prefabricated omega joints and the reduced labor to install the joints. The result was the net five percent reduction in labor plus material cost quoted above.

An interesting aspect of using the omega joint is that if the joints are mounted vertically, their higher stiffness may permit elimination of at least one pipe support per expansion joint. If this support can be eliminated, the overall pipe network cost reduction is 11 percent. The cost matrix corresponding to the vertical omega is presented in Appendix C, Figure C-2. The analyses and investigation required to make a thorough evaluation of the vertically mounted omega could not be included in the scope of this study.

ORIGINAL PAGE IS
OF POOR QUALITY

TABLE 5-1. APPROACHES TO REDUCED COST

- A. USE OF FLEX HOSE
 - REDUCES COST TO FIELD CONSTRUCT EXPANSION JOINTS
 - REDUCES NUMBER OF SUPPORTS
- B. USE OF PILE DRIVEN POSTS FOR PIPE SUPPORTS
 - ELIMINATES EXCAVATION AND CONCRETE COSTS
 - REDUCES MATERIAL AND LABOR COSTS FOR INSTALLING PIPE GUIDES AND ANCHORS
- C. AUTOMATED WELDING AND USE OF FIELD SHOPS
 - REDUCES CUTTING AND WELDING LABOR COSTS
 - PERFECT WELDS--NO REWORK
- D. BURIED PIPE
 - POTENTIAL TO GREATLY REDUCE COST OF SUPPORTS
 - PERMITS USE OF MUCH LESS EXPENSIVE BLOWN OR CAST SLURRY INSULATION

5.2 FLEXIBLE HOSE EXPANSION JOINT

The elimination of expansion joints by use of flexible hoses to accommodate the thermal expansion at each dish was found to offer about a 15 percent reduction to the baseline STEOR costs. Figure 5-1 shows the flexible hose installation at the downcomer of a dish. In this arrangement the symmetrically arranged feeder lines, Figure 2-3, would be allowed to grow away from the central header. No pipe anchors would be used on the feeder lines, and the number of pipe supports (guides) can be reduced because all support foundations and pillars are shared by both water and steam lines. There are no supports required to carry the offset sections of the field constructed expansion joints.

The flexible hose installed farthest from the header must accommodate about 8.5 to 9.0 inches of pipe expansion, which will be no problem for a hose installation. At dish locations closer to the header the expansion is proportionally less.

A similar installation of hoses would also be used where the 1-inch diameter feeder lines penetrate the header. Three anchor points are used along the length of the header. Expansion of the header between the anchor points is accommodated by large diameter flexible hoses installed in series with the header. These are expensive, but are not as costly as the expensive field fabricated expansion joints and additional pipe supports.

An informal quotation was obtained from Anaconda Metal Hose for the insulated hose assemblies required for the thermal expansion loops. The material cost of the hoses and their weld installation labor costs were substituted in the baseline STEOR cost matrix in place of the cost of the field fabricated expansion joints. Also, the number of anchors, pipe guides, and related foundation and pillars was reduced to account for a fewer number of pipe supports. The resulting cost matrix is shown in Appendix C (Figure C-3) and indicates a 15 percent reduction in total labor plus material cost.

5.3 PREFABRICATED POST SUPPORTS

In the conventional construction costing performed for the baseline STEOR network it was assumed that each pipe anchor and each pipe guide will be affixed to a reinforced concrete pillar. Construction of the pillar involves excavation to a shallow depth, wood forming of a footing, placement of steel reinforcing rod and a fiber pillar (sonotube) form, and pouring of concrete. The labor also included fastening steel anchor fixtures and roller guides to studs cast into the concrete.

Figures 5-2 and 5-3 compare the alternate construction techniques. The left side of each figure shows the conventional concrete construction and the right side shows prefabricated steel channels which are driven 3 to 4 feet into the ground using a post driver.

The steel channels would be purchased as predrilled and pointed posts. A fence company was contacted which stated that its fee is \$600 per day for driving 200 posts per day, including equipment and crew. A more generous

ORIGINAL PAGE IS
OF POOR QUALITY





FIGURE 5-1. FLEXIBLE HOSE THERMAL EXPANSION JOINT

ORIGINAL PAGE IS
OF POOR QUALITY




LOWER COST NON-CONVENTIONAL


CONVENTIONAL SUPPORT

FIGURE 5-2. PIPE ANCHORS

ORIGINAL PAGE IS
OF POOR QUALITY



LOWER COST NON-CONVENTIONAL



CONVENTIONAL SUPPORT

FIGURE 5-3. PIPE SUPPORTS

68

allowance of \$6.00 per piling was used in the cost estimating, plus additional labor for trimming, aligning, and mechanical attachment of fittings.

When the revised costs for pile or post driven supports were substituted for the costs of concrete supports (Appendix C, Figure C-4) a cost savings of 10 percent was obtained for the total labor plus material cost estimate.

5.4 AUTOMATED WELDING

The use of automated welding and field shop construction is considered as conventional technology by many people. Although the equipment for automated welding is available and well developed, its use is still primarily for factory environments and its introduction as a pipe network fabrication approach is just beginning.

As part of this investigation a meeting was held at Astro-Arc Co., Sun Valley, California. This company is a leading supplier of automated pipe welding equipment and recently provided equipment and services to the U.S. Navy for construction of a large pipe network on Diego Garcia Island.

Photographs of Astro-Arc automated welding heads are shown in Figure 5-4 and 5-5. The weld head shown in Figure 5-5 is used for smaller diameter tubes and pipes (1/8 to 2.0 inch pipe) and the head shown in Figure 5-4 is used on pipe sizes from 2.0 inches to 42 inches diameter. The weld heads use an identical power source and programmer, cabinet mounted and portable for field use. A portable control unit, attached by cable to the power source, can be used adjacent to the work to permit in-process adjustment of the weld control parameters.

In addition to the automated welding equipment, Astro-Arc demonstrated the use of portable field equipment manufactured by TRI TOOL INC., Placerville, California, which automatically self-aligns and bevels to precise shapes the pipe ends of small and large diameter pipes in a few minutes. The butt welding of a 4-inch diameter, schedule 40 pipe was demonstrated in a 17-minute period.

A schedule was generated using Astro-Arc assistance to estimate labor hours for performing automated butt welds on various pipe diameters. Reasonable times for setup and teardown were determined. A moderate weld speed of 4 inches/minute and three weld passes were used for each weld. Butt weld joints up to 1-inch diameter were assumed made under field shop conditions with minimum setup times. Subassemblies of pipe 1-inch and smaller would then be transported to the field adjacent to the shop and welded in place. Automated welds on larger diameter (greater than 1-inch diameter) were assumed to be made under field conditions and larger setup and teardown labor was estimated.

Applying the automated weld labor estimate to the field welded labor costs tabulated in the baseline cost matrix resulted in a 14 percent reduction in the total labor plus material cost for the network.

ORIGINAL PAGE IS
OF POOR QUALITY




FIGURE 5-4. AV-2 PIPE WELDER

66




FIGURE 5-5. ASTROMATIC TUBE WELDING SYSTEM

5.5 BURIED PIPE

An unconventional pipe network construction approach identified by FACC is the buried pipe concept shown in Figure 5-6. In this approach the pipe is layed in a trench dug in the earth. This trench is sealed with a polyethylene plastic line. The pipe is suspended in the middle of the trench with simple wire hangars, and is coated on the outside diameter with a thick wax or organic mold release material. Foamed insulation is piped into the trench cavity around the pipe and cures to a rigid mass which supports the pipe within the trench. A possible insulating material is foamed slip-cast silica, commonly used as a refractory type insulator to temperatures up to 2200°F. After the insulation is cured, the pipe is released from the insulation by running hot water through the pipe to melt or degrade the mold release. The top of the cast insulation surface is moisture sealed by vacuum sealing the polyethylene liner or spraying a sealant coat of plastic or elastomeric material. The trench is then covered with earth.

This pipe concept should significantly reduce two major pipe network costs: 1) the cost of pipe supports (37 percent of total cost) and 2) the cost of insulation (26.3 percent of total cost). There is, of course, an offsetting disadvantage to this approach because of less accessibility for some of the field welds that must be performed in place. The installation expansion joints and valves may also present problems in an underground installation. Although a complete design and cost evaluation of this concept was not permitted by the funds and time available in this study, the concept has been identified as having potential merit and worthy of more complete investigation.


5.6 COST RESULTS

Figure 5-7 summarizes the cost reductions which may be available using some of the unconventional construction techniques described in this section. The cost reduction estimates were made by applying the estimated labor and material savings to the 72-dish STEOR pipe network cost matrix.

The bar on the left side of Figure 5-7 represents the labor plus material cost of the baseline STEOR network of \$192K. The four bars to the right of the baseline cost show the reductions estimated for applying various cost reduction techniques to the baseline network. The remaining bars represent the pipe network costs obtained by applying combinations of the same techniques.

The cost reductions obtained by the various techniques are shown in the figure and have also been summarized in previous paragraphs. If the more promising techniques are combined the cost reductions become more attractive. Using flexible hose expansion joints in combination with post supports reduces cost by 23 percent (Appendix C, Figure C-5). If the automated welding is used in conjunction with the use of flexible hose and post supports, a total labor plus material cost reduction of 33 percent is predicted.

ORIGINAL PAGE IS
OF POOR QUALITY,



- ADVANTAGES
- REDUCED INSULATION COSTS
 - ELLIMINATION OF PIPE SUPPORTS

FIGURE 5-6. BURIED PIPE CONCEPT

69

ORIGINAL PAGE IS
OF POOR QUALITY

\$ VALUE FOR LABOR & MATERIAL ONLY




FIGURE 5-7. COST REDUCTIONS USING UNCONVENTIONAL CONSTRUCTION TECHNIQUES

70

ORIGINAL PAGE IS
OF POOR QUALITY

SECTION 6

PARAMETRIC STUDY RESULTS

A pipe network optimization for two alternate IPH temperature applications and one additional plant size were part of Task B. The optimization was based on a cost model reflecting conventional construction technology. The JPL conventional cost model was used because the previous results of this study provided a reasonably good validation of its adequacy. In addition, FACC also reoptimized the baseline STEOR pipe network and recalculated the pipe network cost using the JPL advanced construction cost model. The JPL advanced cost model predicted cost savings that slightly exceed the 33 percent reduction identified by FACC in the previous section of this report.

The parametric optimizations were initially calculated using a cost of energy of \$1500/kW_e for heat and frictional losses. At JPL's request the optimizations were also calculated for a cost of energy of \$500/kW_e. The results of both sets of calculations are presented in this section.

6.1 ALTERNATE TEMPERATURES

The selection of two alternate IPH temperatures was based on a rationale related to the baseline STEOR application. Figure 6-1 represents the distribution of required injection steam pressures for several California heavy oil fields where steam STEOR currently is used and can be expanded. The selected Edison Field has the second highest injection steam pressure requirement, with only the Cat Canyon-Sisquoc Field having a higher value.

It was decided to select two lower injection pressures and the corresponding saturation temperatures for the alternate IPH temperature applications. Alternate injection pressures of 400 and 600 psi were selected which correspond to satisfying about 30 and 50 percent, respectively, of the potential STEOR steam applications. The corresponding injection temperatures are 355°F at 400 psi and 489°F at 600 psi. The pipe network optimization was recomputed using these alternate temperatures, but maintaining the baseline 72-dish field geometry.

6.2 ALTERNATE PLANT SIZE

The rationale for increasing the solar network size was to provide an annual thermal output equivalent to that of a single 25 MBTU/HR fossil fueled steam generator operating continuously. This translated to a 352 dish array containing 22 rows with 16 dishes each. Using a pipe network geometry similar to the baseline geometry, each 16-dish feeder row supplies a central header. The supply and steam discharge temperature and pressure are the same as for the baseline network.

ORIGINAL PAGE IS
OF POOR QUALITY




FIGURE 6-1. STEAM PRESSURE REQUIREMENTS FOR STEOR

72

6.3 RESULTS

Tables 6-1 and 6-2 tabulate the results of the optimization calculations made for the alternate STEOR network temperatures and plant size. Table 6-1 presents the results for \$1500/kW_t cost of energy and Table 6-2 presents the results for \$500/kW_t cost-of-energy.

The pipe network costs are expressed as both total system cost and capital cost. The total system cost is the capital cost plus the cost of the pipe network thermal and frictional losses evaluated at the appropriate cost-of-energy. The pipe network costs are expressed in terms of \$/kW_t and \$/m² of concentrator, which are figures of merit commonly used to evaluate solar sub-systems. The results presented in Tables 6-1 and 6-2 are reasonably compatible with results previously calculated by JPL. Total system cost increases about 14 percent (\$/kW_t) as the process temperature increases from 355°F to 530°F (Table 6-1). The increase is primarily due to the increased heat loss, evaluated at \$1500/kW_t. If a lower cost of energy is assumed, the effect of process temperature on total cost is less pronounced. As shown in Table 6-2, only a 5.1 percent increase in total system cost occurs as the process temperature increases over the same temperature range from 355°F to 530°F. Both tables show the capital cost (pipe plus insulation) is relatively insensitive to the influence of process temperature.

When the baseline STEOR network (corresponding to a 530°F process temperature) is reoptimized using the JPL Advanced Cost Model, the results shown in line 4 of Tables 6-1 and 6-2 are obtained. At a \$1500/kW_t cost-of-energy (Table 6-1) a 21 percent reduction is obtained in total system cost (capital plus energy) and a 38 percent reduction in capital cost. At a \$500/kW_t cost-of-energy the total system cost is reduced 31 percent and capital cost is reduced 42 percent.

The increased unit capital cost for larger plant sizes (6.3 percent in Table 6-1) results from the cost of additional larger feeders and additional headers to carry steam to the edge of the field. An improved arrangement of feeders and headers may reduce or eliminate this cost difference.

TABLE 6-1. RESULTS OF OPTIMIZATION ANALYSES FOR ALTERNATE STEOR PIPE NETWORKS
 -1500 \$/KW_T COST OF ENERGY-

- FACC OPTIMIZATION CODE
- JPL ESTIMATES FOR PIPELINE COSTS

NETWORK SIZE	COST MODEL	STEAM DELIVERY PARAMETERS			TOTAL SYSTEM COST		CAPITAL COST	
		TRANSPORT CAPACITY KW _T	PRESSURE (PSIG)	TEMPERATURE (°F)	\$/KW _T	\$/M ²		
72	CONVENTIONAL	5318	400	355.0	68.93	44.77	44.69	29.18
72	CONVENTIONAL	5295	600	488.7	74.76	48.21	43.65	28.38
72 ⁽¹⁾	CONVENTIONAL	5284	850	529.6	78.53	50.45	43.88	28.48
72	ADVANCED (4)	5284	850	529.6	61.85	39.64	27.33	17.74
352 ⁽²⁾	CONVENTIONAL	25766	850	527.8	84.67	54.23	46.67	30.22

(1) BASELINE STEOR NETWORK - ABOUT 20% OF FOSSIL-FUELED TEOR STEAMER CAPACITY

(2) CAPACITY ABOUT EQUAL TO FOSSIL FUELED STEAMER CAPACITY

(3) TEMPERATURE AT FIELD DISCHARGE POINT

(4) JPL ADVANCED COST MODEL

ORIGINAL PAGE IS
 OF POOR QUALITY

TABLE 6-2. RESULTS OF OPTIMIZATION ANALYSES FOR ALTERNATE STEOR PIPE NETWORKS
-500 \$/KW_t COST OF ENERGY-

- FACC OPTIMIZATION CODE
- JPL ESTIMATES FOR PIPELINE COSTS

NETWORK SIZE		COST MODEL			STEAM DELIVERY PARAMETERS			TOTAL SYSTEM COST		CAPITAL COST
NO. DISHES	TRANSPORT CAPACITY KW _T	CONVENTIONAL	CONVENTIONAL	CONVENTIONAL	ADVANCED ⁽⁴⁾	CONVENTIONAL	CONVENTIONAL	CONVENTIONAL	CONVENTIONAL	CONVENTIONAL
		PRESSURE (PSIG)	TEMPERATURE (°F)	TEMPERATURE (°F) ⁽³⁾						
72	5318	400	349.9	51.14	52.36	53.76	33.09	33.09	40.41	26.26
72	5295	600	484.3	52.36	53.76	34.44	33.68	33.68	39.43	25.52
72 ⁽¹⁾	5284	850	525.4	53.76	53.76	34.44	34.44	34.44	39.32	25.38
72	5284	850	525.1	37.23	37.23	23.76	23.76	23.76	22.86	14.75
352 ⁽²⁾	25766	850	523.1	57.38	57.38	36.60	36.60	36.60	41.26	26.55

(1) BASELINE STEOR NETWORK - ABOUT 20% OF FOSSIL FUELED TEOR STEAMER CAPACITY

(2) CAPACITY ABOUT EQUAL TO FOSSIL FUELED STEAMER CAPACITY

(3) TEMPERATURE AT FIELD DISCHARGE POINT

(4) JPL ADVANCED COST MODEL

SECTION 7

RISER AND DOWNCOMER DESIGN

Task B of the Statement of Work includes a preliminary design study to define concepts for modifying the SCSE (EE-1) solar thermal electric system to incorporate IPH features. This task consists primarily of modifications to the dish installation to incorporate thermal transport riser and downcomer assemblies. The baseline parabolic dish for the SCSE system design is the LCC supplied by General Electric. The LCC was also designated by JPL as the baseline dish for the present IPH study. The remainder of this section describes the design and costing results of this effort.

7.1 DESIGN CONSIDERATIONS

The installation and kinematics of motion of the selected flexible coupling approach on the LCC are briefly summarized. Alternate design approaches are then addressed in light of the selected design.

It was recognized that the LCC posed a particularly difficult design problem to provide flexible thermal transport lines across the dish azimuth and elevation gimbals. The two gimbal points are separated by over twenty feet so that two completely different sets of flexible couplings are required. In addition the azimuth gimbal consists of the base truss structure mounted on ground level wheels which run on a 40-ft diameter track. The center of rotation is not very precise so that some design approaches, such as swiveled mechanical couplings, are difficult to incorporate.

The LCC is designed for field erection and adjustment. Virtually every truss member includes adjustable turnbuckles which are adjusted and pinned in place. There exists no opportunity to make an efficient integration of the riser/downcomer assemblies into the LCC without major redesign of the dish and base structures.

The flexible joint design eventually selected for the LCC is four separate flexible hose assemblies, two for the elevation gimbal and two for the azimuth gimbal. Pictorial drawings of the LCC base truss structure with the flexible hoses installed are shown in Figures 7-1 and 7-2. These hose assemblies are mounted on the opposed elevation trunnions of the LCC dish. Stationary lines clamped to vertical members of the base truss carry feed water up to one side of the dish trunnion and steam down the opposite side of the base truss. The elevation flexible hoses are shown in the dish-down position. As the dish rotates 180-degrees to the up position, thermal transport lines connected to the dish truss rotate the hose support "arms" and cause the hose to unwind to an hour-glass shape. Rigid lines attached to members of the dish truss carry the water and steam to and from the focal-point mounted receiver and the hose support arm.

As shown in Figure 7-1, hose assemblies are used to accommodate 300-degrees of azimuth rotation. Two sets of semi-circular tracks are used to cage the hose, one set for the water hose and an opposite set for the steam hose. In




FIGURE 7-1. FLEXIBLE HOSE DESIGN ACROSS GIMBAL JOINTS




FIGURE 7-2. FLEXIBLE HOSE DESIGN ACROSS AZIMUTH GIMBAL

87

each set of tracks an inner track is attached to the fixed central pivot point of the dish and an outer track is suspended from the rotating base truss. As the base truss rotates from East to West, flexible hose is uncoiled from the outer track onto the inner track, and vice versa.

The selected design is described in greater detail in a later part of this section.

Alternative Design Approaches

Two alternative design approaches were considered: 1) the use of mechanical swivel joints, and 2) replacement of the hose assemblies with coiled tube assemblies which elastically deflect through the required motion.

The use of swivels such as the hydraulic swivel assemblies manufactured by Parker Hannifin were considered for the flexible coupling application, especially for the elevation gimbal water line. The following factors eliminated the possible use of this type of joint:

- (1) The swivels employ both static and dynamic O-ring seals. Even the highest temperature-rated elastomers (fluorocarbons and silicones) are not rated for continuous service above 400°F, and seal life decreases rapidly at these high temperature conditions.
- (2) The LCC gimbal joints do not have precise centers of rotation, especially the azimuth gimbal. To accommodate this condition would require two hydraulic swivels interconnected by flexible hose. This was considered a complicated design with a greatly increased number of potential leak points.
- (3) The swivel type joints use dynamic O-ring seals to seal a mechanical interface against rotational motion. This type of dynamic O-ring application is demonstrated to be leak and failure prone, especially as the O-ring ages and swells and/or in the absence of a good lubricating agent.

The second alternate approach considered was a coil of stainless steel tubing to replace the hose assemblies. The tubing would be stressed to deflect elastically to provide the required total motion. A simplified stress/deflection analysis of this approach was performed for the 300-degree deflection of the azimuth gimbal. The results are shown in Figure 7-3. The tube size was the same as that used in the SCSE receiver and the maximum allowable stress, 15 ksi, was determined from ASME piping code. Figure 7-3 indicates that three turns of tubing mounted at the maximum allowable radius (20 feet) are required to accommodate the 300-degree deflection while not exceeding a 15 ksi stress level (bending plus pressure) within the tubing. This corresponds to an unacceptable of 339 feet of tubing. In the case of the azimuth steam coupling, both the cost of insulation (at about \$3.00 per foot) and the frictional pressure drop imposed by this design eliminated it from additional consideration. The same negative reasons apply to the use of this design on the steam side of the elevation flexible coupling.

ORIGINAL PAGE
OF POOR QUALITY




FIGURE 7-3. COIL RADIUS VS. NUMBER OF TURNS FOR COILED TUBE FLEXIBLE AZIMUTH JOINT

Although slightly more attractive for the water lines because of the absence of insulation, the coiled tube design is still expensive, poses a high friction loss, and is difficult to package.

7.2 SELECTED DESIGN

Details of the selected design are shown in Figures 7-4 and 7-5. The steam side flexible hose assembly for the elevation gimbal is shown in Figure 7-4. A rigid insulated steam tube is attached to a dish truss member and connects the receiver, located at the dish focal point, to a hose arm that swivels on the elevation trunnion. A flexible metal hose insulated on the outside diameter connects the rotating hose arm to a stationary downcomer line attached to the dish base truss. An identical, uninsulated assembly is used on the opposite side of the dish to carry feed water up to the trunnion-mounted hose arm, and then to the receiver.

At the base of the dish assembly, shown in Figure 7-5, the steam and water lines from the elevation trunnions are directed radially inward through rigid lines to the outer hose track attached to the rotating base truss. The steam and water flow are transported through the flexible hoses inward to the stationary mounted hose track attached to the central pivot. From hose termination points on the stationary track the flow is again transported radially outward at nearly grade level in rigid lines through perforations in the LCC azimuth track to discharge steam into or pick up water from the pipe network feeder lines.

The selected design consists primarily of rigid tube assemblies (0.625-inch diameter X 0.035-inch wall, 347 CRES) and brackets and fittings to attach the tube assemblies to the LCC dish and base truss structures. The steam lines are insulated with about three-inches of calcium silicate enclosed by an aluminum weather seal jacket. The elevation hose support arm and azimuth hose tracks are fabricated (cut, drilled, bent, and welded) from standard steel channel, as are all brackets and hangers.

Approximately 80 percent of the material cost is attributable to the flexible hose assemblies. These are manufactured by Anaconda Metal Hose and consist of an inner liner of deep convoluted (7.5 convolutions per inch) 321 stainless steel bellows, 0.75-inch internal diameter by 1.25-inch outer diameter. The outer diameter of the bellows is structurally supported by a stainless steel metal braid against internal fluid pressure loads. The steam line is insulated with one-inch thick Carborundum Durablanket insulation and sealed on the 3.25-inch outside diameter by a wire reinforced Hypalon polyester jacket to protect against weather and abrasion. The water line flexible hose has no insulation, but does have the polyester jacket. The elevation flexible hoses are 81-inches long and azimuth hoses are 186-inches long.

The flexible hoses have been conservatively designed to function at the minimum bend radii recommended by the manufacturer for maximum cyclic life. The reverse bending of the hose is accounted for in determining the minimum bend radii. The hose inside diameter was made intentionally large to account for the higher fluid friction caused by the internal corrugations, which is

estimated to increase the friction factor (4EL/D) by 10 to 12 times compared to that for straight pipe. This design conservatism leads to higher cost. The impact of design conservatism on cost will be discussed in Paragraph 7.4.

7.3 COST ESTIMATES

A detailed cost estimate was performed for the LCC riser/downcomer assemblies for two quantities: a prototype quantity of 50-100 units and a production quantity of about 1000 units/year. The labor costs for the prototype quantity assemblies assumed field installation of the riser/downcomer assemblies to the dish. Labor costs for the production quantities assumed factory installation of the riser/downcomer assemblies to the truss members of the dish and its base.

A summary of the cost estimates is presented in Table 7-1. It is seen that even in production quantities the cost of incorporating riser/downcomer assemblies is \$3277 per dish, which is equivalent to about \$29/m². This value is comparable to the capital cost of the thermal transport field pipe network.

The very large cost to incorporate risers and downcomers is analyzed in Table 7-2 which gives a further breakdown on the production costs. Examination of this table shows that 65 percent of the total cost is due to flexible lines at the gimbal joints whereas the remaining 35 percent is for the rigid lines running from the ground to the focal point. The influence of the LCC dish design on high gimbal (flexible) line cost is also shown by the fact that the azimuth gimbal lines are more than double the cost of the elevation gimbal. This indicates that a short coupled azimuth gimbal alone could reduce total cost by 22 percent.

7.4 COST REDUCTION MODIFICATIONS

This section addresses the potential design modifications which could be employed to reduce the cost of riser/downcomer assemblies. The recommended modifications are divided into two classes: 1) modifications which could be incorporated into the basic LCC dish, and 2) modifications which would require a different dish structure.

7.4.1 MODIFICATIONS TO THE LCC DESIGN

a. Smaller Diameter Flexible Hose. The first modification recommended for the basic LCC design is the use of a reduced diameter flexible hose assembly. This will reduce the cost of the hose in two ways: 1) smaller diameter hose is less expensive, and 2) the smaller diameter hose can be coiled to a smaller radius resulting in shorter lengths being required (15 percent length reduction). The penalty of using smaller diameter hose would be a greater frictional loss. The proposed riser/downcomer flexible hoses use 0.75-inch internal diameter (I.D.) hose. If this hose was reduced to 0.50-inch I.D., the projected cost changes are those summarized in Table 7-3A. The negative impact of this design change would be to increase the estimated frictional energy loss through the hoses (primarily in the steam side) by a factor of five. The convoluted bellows frictional parameter is estimated to be twelve times

ORIGINAL PAGE IS
OF POOR QUALITY

9950-663

TABLE 7-1. COST ESTIMATE, THERMAL TRANSPORT MODIFICATIONS TO LCC DISH

<u>MATERIAL COSTS</u>	<u>PROTOTYPE QUANTITY (50-100 UNITS)</u>	<u>PRODUCTION QUANTITY (>1000 UNITS/YEAR)</u>
STRUCTURE, FITTINGS, ETC.	\$ 1318 EACH	\$ 988 EACH
FLEXIBLE HOSE ASSEMBLIES		
ELEVATION GIMBAL		
STEAM SIDE	915	375
WATER SIDE	448	200
AZIMUTH GIMBAL		
STEAM SIDE	1405	703
WATER SIDE	639	328
TOTAL MATERIAL	4725	2594
<u>LABOR COSTS</u>	<u>1367</u>	<u>683</u>
TOTAL COST*	\$ 6092 EACH	\$ 3277 EACH

*TOTAL COSTS EXCLUDE PROFIT, SALES TAX, CONTRACTOR INDIRECT CHARGES

TABLE 7-2. BREAKDOWN OF PRODUCTION COST ESTIMATE
TO INCORPORATE RISERS/DOWNCOMERS ON LCC DISH

	<u>PERCENT OF TOTAL COST</u>		
	<u>MATERIAL</u>	<u>LABOR</u>	<u>TOTAL</u>
<u>AZIMUTH GIMBAL</u>			
HOSES	31.3		
OTHER STRUCTURE	<u>10.6</u>		
TOTAL	41.9	2.4	44.3
<u>ELEVATION GIMBAL</u>			
HOSES	17.5		
OTHER STRUCTURE	<u>1.2</u>		
TOTAL	18.7	1.4	20.1
<u>RIGID LINES</u>			
	<u>18.2</u>	<u>17.4</u>	<u>35.6</u>
	78.8	21.2	100.0

PRODUCTION COST = 100% = \$3277 EACH

TABLE 7-3. POTENTIAL RISER/DOWNCOMER COST REDUCTIONS FOR LCC

A. <u>Use of Smaller Diameter (0.50-inch I.D.) Hose</u>		B. <u>Use of Smaller Diameter Hose and Less Conservative Bend Radii</u>	
1. Baseline Total Cost	\$3277	1. Baseline Total Cost	\$3277
2. Cost Changes (\$)		2. Cost Changes (\$)	
• Reduced hose cost	-400	• Reduced hose cost ⁽²⁾	-640
• Other hardware reductions ⁽³⁾	-78	• Other hardware reductions ⁽³⁾	-96
• Increased pumping (friction loss)	+242 ⁽¹⁾	• Increased pumping (friction loss)	+145 ⁽¹⁾
3. Net Cost Reduction	-\$236 or -7.2%	3. Net Cost Reduction	-18%
<p>(1) Cost of Non-recoverable Frictional Pumping Energy = \$500/kW_t (2) 40% reduction in azimuth and elevation hose costs (3) 25% reduction in other hardware cost</p>			

higher than that for a straight pipe of equivalent I.D. In Table 7-3 the cost of pumping energy is assessed at \$500/kW_t. The increased frictional loss is offset by a 15 percent reduction in hose cost and 8 percent reduction in other related hardware cost. The net cost reduction is \$236 or 7.2 percent as shown in Table 7-3A.

b. Reduced Design Conservatism. The flexible hose assemblies for the LCC dish gimbals were designed with generous bend radii to provide maximum hose life under continuous cycling. The design conservatism stems in part from the use of double the manufacturer's recommended bend radii to account for the reverse bending the hoses undergo in the proposed design. The manufacturer's design recommendation applies to bending in one direction only. The reverse bending imposes a positive-to-negative bending stress on the hose bellows as opposed to only a zero-to-positive or zero-to-negative encountered in bending in only one direction.

Use of a smaller bend radius in the hose assemblies will also shorten the length of the hose assemblies to reduce cost. The potential to reduce cost by using 0.50-inch I.D. hoses shortened to one half the length used in the baseline design is shown in Table 7-3B. The net cost reduction is \$591 or 18 percent. It is likely that this cost reduction would be offset by increased replacement costs due to reduced cyclic life. However, the hose life/bending data to evaluate the life cycle cost was not available from the hose manufacturer.

ORIGINAL PAGE IS
OF POOR QUALITY

7.4.2 HA/DEC DISH DESIGN

If alternate dish designs were considered for IPH applications, a conventional equatorial mount configuration (HA/DEC) of the type shown in Figure 7-6 would be an excellent candidate with respect to reduced cost of risers and downcomers. The lengths of the rigid lines from the ground to the receiver are less than required for the LCC, and only a single flexible joint assembly would be required to accommodate motion along the hour-angle drive axis. The flexible hose could be designed as a compact assembly located at the declination drive location shown in Figure 7-6. An inexpensive, short link of flexible hose could accommodate the small changes in declination drive angle which occur. The savings in riser/downcomer costs permitted by this alternate dish drive is probably in the range of 40 to 60 percent of the costs estimated for the baseline LCC modifications.

7.4.3 SINGLE POST DESIGN

Another dish design approach which would greatly reduce the costs of the IPH risers and downcomers compared to the LCC installation is a single post, pedestal type support such as shown in Figure 7-7. A close coupled azimuth/elevation drive at the interface of the dish/pedestal would permit the use of a single compact hose assembly capable of compound motion in both azimuth and elevation axes.

An alternative approach is to package the riser/downcomer rigid lines within the center post as a torsional spring. In this configuration the lines would be held fixed at the base of the post and undergo +150 degrees of azimuth twist as they emerge at the post/dish interface. The two lines are preformed together in the form of a high lead angle torsional spring, 20 to 30 feet long. In this configuration the lines could undergo the required +150 degrees of elastic deflection at low stress and low spring rate.

The elevation rotation is accommodated at the interface of the post with the dish with a short coupled flexible hose assembly similar to that described for the LCC installation.

Examination of Table 7-2 shows that the entire cost of the azimuth gimbal hose assembly could be eliminated with the design described, or a 44 percent reduction. The cost of the twisted torsion lines would be more than absorbed by reductions in the rigid line costs (35.6 percent) listed in Table 7-2 for the LCC, which include the cost of large amounts of extra line imposed by the LCC.

ORIGINAL PAGE IS
OF POOR QUALITY




FIGURE 7-6. 12 METER DIAMETER COLLECTOR, EQUATORIAL MOUNT

ORIGINAL PAGE IS
OF POOR QUALITY.




FIGURE 7-7. POST SUPPORTED DISH DESIGN

SECTION 8

CONCLUSIONS AND RECOMMENDATIONS

8.1 CONCLUSIONS

The following conclusions summarize the main results of the IPH pipe network optimization studies documented in this report:

- (1) The JPL pipe network optimization computer code gives results which are in good agreement with the FACC code when the JPL hot and cold side network optimizations are decoupled.
- (2) The results obtained from two different cost models applied to the baseline ST²OR application indicate the JPL conventional pipe network cost model yields costs which are approximately 20 percent higher than the FACC bottoms-up costs for comparable elements.
- (3) Because the JPL cost model does not include indirect contractor costs, sales taxes, performance bonds (insurance), or profit, the total FACC cost is 18 percent greater than the JPL cost.
- (4) Dominant elements of labor and material costs are the procurement and installation of insulation and supports; 63 percent of the total.
- (5) Studies of potential cost reductions show:
 - A. The use of automated welding and field shop construction would yield a cost reduction of less than 36 percent.
 - B. A total labor and material cost reduction of 33 percent could be obtained from a combination of non-conventional construction techniques described herein.
 - C. Additional cost reduction could be obtained using a buried pipe concept.
- (6) Over-the-gimbals thermal transport (piping) cost for the LCC is \$3277 per dish (\$29/m²) or \$236,000 for the 72-dish field - approximately equal to the overall capital cost of the entire baseline pipe network system.
- (7) Lower cost designs for over-the-gimbals thermal transport could be obtained with:
 - A. Lower pressure and/or lower temperature IPH applications.
 - B. An alternate post or pedestal mounted dish design with close-coupled elevation and azimuth gimbals. The estimated cost

ORIGINAL PAGE IS
OF POOR QUALITY

reduction is between 40 and 50 percent of the cost to modify the LCC for installation of riser/downcomer assemblies.

(8) Conclusions from the parametric study are:

- A. Total pipe network system cost (including cost of energy losses) increases with increased process temperature (e.g., 355°F to 530°F) because of:
- Greater thermal loss (5.1 percent increase in system cost at \$500/kW_t cost-of-energy)
 - Greater insulation cost (1.6 percent increase)
- B. Network capital costs are relatively insensitive to the influence of process temperature.
- C. Increased unit capital cost (\$/m² or \$/kW_t) for larger plant size results from the use of additional larger feeders and additional headers to carry steam (and feedwater) to the edge of the field. An improved arrangement of headers and feeder lines may reduce or eliminate this cost difference.

8.2 RECOMMENDATIONS

The following recommendations are made based on the results of this study:

- (1) The JPL pipe network optimization code and conventional cost model are substantially verified as a result of this study, except that the following modifications are suggested:
- The pipe network optimization code should be modified to decouple the hot/cold side solutions.
 - The JPL conventional pipe network cost model should be revised to include indirect costs, taxes, bonds, and profit.
 - The $\sqrt{2}$ approach used by JPL to calculate the cost of expansion joints should be re-examined.

ORIGINAL PAGE IS
OF POOR QUALITY

APPENDIX A
SHADING LOSS ANALYSIS

ORIGINAL PAGE IS
OF POOR QUALITY

APPENDIX A
SHADING LOSS ANALYSIS

ORIGINAL PAGE IS
OF POOR QUALITY

Inter Office

Ford Aerospace &
Communications Corporation18 February 1981
SCSE-81-21

To: D. A. Rodriguez
From: A. F. Dugan
Subject: Shading Losses for a 9x8 Collector Array

An evaluation of the shading loss for a 9x8 collector array arranged in a rectangular pattern was made. The technique used has been documented elsewhere¹, and will not be described here.

The results are summarized in the four figures included. In Figure 1, fractional energy available to mirrors is plotted as a function of ground cover ration (GCR) for various aspect ratios. GCR is defined as $\pi / (4 \text{ LEW} \cdot \text{LNS})$, where LEW and LNS are the north-south and east-west spacings expressed in dish diameters. Results obtained by JPL² for a 10x10 array are also shown. The GCR is the same as the packing fraction for an infinite field. The aspect ratio is LNS/LEW. The curves in Figure 1 are based on a reduced year, that is, the data base consists of twelve days, one from each month for Barstow 1976. The days chosen were free of dropouts. It is difficult to see from Figure 1 whether or not there is an optimum aspect ratio.

Shading calculations performed by different method from ours indicate an optimum aspect ratio of .71 for one particular GCR². JPL³ indicated that this optimum holds for all aspect ratios. This study does not corroborate this result.

In Figure 2, the fractional energy available to the dishes is plotted as a function of aspect ratio for various GCR. The solid curves are for the short year, while the dotted curves are for the full 366 day year. Each of the curves shows a maximum, but the maximum clearly varies with GCR. The maxima are very broad, which implies that little penalty is incurred if the field is off optimum.

In Figure 3, the fractional loss is plotted for the same conditions used in Figure 2. In Figure 4, the fractional loss for the full year only is plotted.

¹ D. B. Osborn, "Generalized Shading Analysis for Paraboloidal Collector Fields". ASME 80-Pet-33.

² W. J. Eppley, "Shade - A Computer Model for Evaluating the Optical Performance of Two Axis Tracking Parabolic Concentrators", ASME 79-WA/SOL-13.

³ J. R. Biddle (Memo to T. Fujita) 8/2/79.

D. A. Rodriguez

-2-

18 February 1981

**ORIGINAL PAGE IS
OF POOR QUALITY**

The loss for the full year is less than that for the ideal year. The reason for this is that dropouts are more likely to occur early and late in the day than at mid-day. Early and late, the elevation of the sun is low, and the shading loss is high. At noon, the shading loss is small. Both the total energy collected and the energy lost due to shading are lower than on a perfectly clear day, but the ratio is smaller for the conditions of this study. The fractional loss is defined as the ratio of the lost energy to the collected energy.

A. F. Dugan
A. F. Dugan

C-2

ORIGINAL PAGE IS
OF POOR QUALITY




FIGURE 1. FRACTIONAL ENERGY COLLECTED VS.
GROUND COVER RATIO

Parameters Indicate Aspect Ratio. Also Shown are
JPL Results for a 10x10 Array.

ORIGINAL PAGE IS
OF POOR QUALITY




FIGURE 2. FRACTIONAL ENERGY COLLECTED VS. ASPECT RATIO FOR VARIOUS GCR

Solid Curves are Based on 1 Day Per Month, While Dotted Curves are Based on Full Year.

ORIGINAL PAGE IS
OF POOR QUALITY




FIGURE 3. ANNUAL FRACTIONAL LOSS VS. ASPECT RATIO

One Day Per Month is Solid Curve, While Dotted Curve is Full Year.

120

ORIGINAL DATA
OF POOR QUALITY




FIGURE 4. ANNUAL FRACTIONAL LOSS VS. ASPECT RATIO FOR FULL YEAR DATA

101

ORIGINAL PAGE IS
OF POOR QUALITY

APPENDIX B
OPTIMIZATION OF PIPE NETWORK COST

77.10 002

ORIGINAL PAGE IS
OF POOR QUALITY

APPENDIX B
OPTIMIZATION OF PIPE NETWORK COST

B-1

103

January 8, 1981

cc: R. Pons
T. Clark
R. Polzien
H. Haskins
R. Irwin

TO: D. A. Rodriguez
FROM: A. F. Dugan
SUBJECT: Optimization of Pipe Network Cost

I. Introduction

The problem of finding the minimum cost of a piping network has been studied by JPL and independently by FACC. The two approaches are different, but yield comparable results. In the following discussion, the JPL approach is briefly summarized, and the FACC approach is developed in more detail since the formulation used by JPL has been documented elsewhere¹.

II. Statement of the Problem

The problem is to find the optimum distribution of pipe sizes and insulation thicknesses to be used in a pipe network in which a hot fluid circulates. The total cost of the system is the sum of the following:

- 1) Cost of pipe.
- 2) Cost of insulation surrounding pipe.
- 3) Cost of energy (or power) lost by conduction.
- 4) Cost of energy required to pump the fluid.
- 5) Cost of the fluid which fills the network.

The cost of each item is assumed as follows:

- 1) Pipe Cost (for i th segment)

$$C_{Pi} = (A_i + B_i d_i) L_i \quad (1)$$

L_i = pipe length

d_i = diameter

A_i and B_i are constants obtained from a pipe cost curve. Eq 1 assumes that pipe cost is a linear function of diameter. Actual pipe cost is a series of linear segments. For pipes of the different diameters, the constants A_i and B_i may be different.

- 2) Cost of insulation

$$C_I = C_{IV} \pi L_i \delta_i (d_i + \delta_i) \quad (2)$$

Eq 2 states that insulation cost is proportional to the volume of material involved.

C_{IV} is the cost per unit volume of insulation

δ_i = insulation thickness

ORIGINAL PAGE IS
OF POOR QUALITY

3) Energy lost by conduction:

$$C_{\theta 1} = H_E \dot{M}_1 C_p (T_1 - T_A) \left\{ 1 - \exp \left[- \frac{2\pi L_1 k}{\dot{M}_1 C_p \log \left(1 + \frac{2\delta_1}{d_1} \right)} \right] \right\} \quad (3)$$

T_1 is the temperature of the fluid as it enters the pipe

\dot{M}_1 is the mass flow rate

C_p is the specific heat of the fluid

T_A is the ambient temperature

k is the thermal conductivity of the insulation

H_E is the assumed value of energy

Note that if the argument of the exponential is small, eq 3 reduces to

$$C_{\theta 1} = \frac{H_E 2\pi L_1 k (T_1 - T_A)}{\log \left(1 + \frac{2\delta_1}{d_1} \right)} \quad (3a)$$

This is the form used by JPL

4) Cost of energy to pump fluid

$$C_{f_1} = \frac{1 - \eta_e}{\eta_e \eta_p} \frac{f \rho L_1 \dot{M}_1^3}{\pi^2 d_1^5} \quad (4)$$

η_e is the electrical conversion efficiency

η_p is the pump efficiency

f is the pipe friction factor (a function of Reynolds number)

ρ is the density of the fluid

5) Cost of fluid

$$C_{FL_1} = C_{FLM} \pi L_1 \left(\frac{d_1}{2} \right)^2 \rho_1 \quad (5)$$

C_{FLM} is the cost per unit mass of the fluid.

The total cost is then

$$C_T = \sum_{i=1}^N \left\{ C_{P_1} + C_{T_1} + C_{\theta_1} + C_{f_1} + C_{FL_1} \right\} \quad (6)$$

where N is the number of pipe segments in the network. The problem is then to find, for each i , the insulation thickness and pipe diameter which minimizes C_T .

III. JPL Approach

The JPL method is based on a Lagrange multiplier technique, and decouples the insulation thickness from the pipe diameter. Their procedure assumes a pump power level

$$W = \sum_i W_i = \frac{8}{\pi^2 \eta_P} \sum_i \frac{f_i L_i \dot{m}_i^3}{\rho_i^2 d_i^5} \quad (7)$$

It then seeks to minimize pipe cost (not overall system cost) using eq (6) as a constraint. The set equations to be solved is:

$$\frac{\partial C_P}{\partial d_i} + \lambda \frac{\partial W}{\partial d_i} = 0 \quad (8)$$

On carrying out the indicated differentiations, they obtain

$$L_i B_i - \lambda \frac{8 f_i L_i \dot{m}_i^3 \cdot 5}{\pi^2 \eta_P \rho_i^2 d_i^6} = 0 \quad (9)$$

$$\lambda = \frac{\pi^2 \eta_P B_i d_i^6}{40 f_i \dot{m}_i^3} \quad (10)$$

Equation 10 permits the determination of N-1 pipe diameters in terms of the other one. The method therefore requires that one pipe diameter (say the one with the smallest flow rate) be assumed. In terms of d_1 ,

$$d_i = d_1 \left[\frac{f_i \rho_i^2 B_i}{f_1 \rho_1^2 B_1} \right]^{1/6} \left(\frac{\dot{m}_i}{\dot{m}_1} \right)^{1/2} \quad (11)$$

A simplified version of eq 11 is used in the JPL computer code to determine the d_i . It will be shown in section V that the simplification used is unjustified.

For the pipe size distribution found above, the insulation thickness distribution is found next. The procedure used is identical to the one just described. The heat loss is

$$Q_c = \sum_{i=1}^N Q_{2i} = \sum_{i=1}^N \frac{2\pi k L_i (T_i - T_A)}{\log(1 + \frac{2r_i}{d_i})} \quad (12)$$

This is eq 3a. It assumes that the temperature of the fluid is the same everywhere. This, of course, is not true, but it is usually not that bad an assumption.

The cost of insulation is then minimized using eq 12 as the constraint.

$$\frac{\partial C_I}{\partial \delta_i} + \lambda \frac{\partial Q_D}{\partial \delta_i} = 0 \quad (13)$$

is the set which must be solved. Explicitly,

$$\frac{\partial C_I}{\partial \delta_i} = \pi C_{IV} L_c (d_c + 2\delta_i) \quad (14)$$

$$\frac{\partial Q_D}{\partial \delta_i} = \frac{4\pi k L_c (T_i - T_A)}{\left[\log\left(1 + \frac{2\delta_i}{d_c}\right) \right]^2} \frac{1}{d_c + 2\delta_i} \quad (15)$$

In terms of δ_1 , λ is

$$\lambda = \frac{C_{IV} \left[(d_c + 2\delta_i) \log\left(1 + \frac{2\delta_i}{d_c}\right) \right]^2}{4\pi k L_c (T_i - T_A)} \quad (16)$$

With equations 16, 14 and 15, eq 13 becomes a transcendental equation for δ_1 . This equation is solved by the Newton-Raphson method. Having found the pipe diameter and insulation thicknesses as above, for assumed values of d_1 and δ_1 , the capital cost is computed as

$$C_c = C_p + C_{FL} + C_I \quad (17)$$

Next, the power losses are computed from eqs 3a and 4. The cost per kW_e is determined by dividing C_c by the total power collected less the power losses. The following method is used to compute the adjusted cost per kwt:

$$\begin{aligned} Q_c &= \text{power collected} \\ Q_L &= \text{power lost} \\ g &= \frac{Q_L}{Q_c} \end{aligned}$$

$$\text{Adjusted Cost} = \frac{C_c}{Q_c - Q_L} + H_E Q_L g / (1-g) \quad (18)$$

The whole procedure is then repeated with different values δ_1 and d_1 until a 2x2 matrix of adjusted cost is assembled. The optimum system is then taken to be the one with the minimum adjusted cost.

IV. FACC Approach

The FACC approach avoids the use of Lagrange multipliers and optimizes the overall system cost directly. No assumed values of any pipe diameters or insulation thicknesses, other than initial guesses, are required. The initial guesses are used to get an iteration loop started, and their exact values do not effect the final results.

The overall system cost is given by eq 6.

$$C_T = \sum_{i=1}^N (C_{PI} + C_{I_i} + C_{O_i} + C_{f_i} + C_{FL_i}) \quad (6)$$

The values of d_i and δ_i which minimize C_T are to be found from

$$\frac{\partial C_T}{\partial d_i} = 0 \quad (19)$$

$$\frac{\partial C_T}{\partial \delta_i} = 0 \quad (20)$$

Each segment is optimized indendently. For the i^{th} segment, eq (19) becomes,

$$\frac{\partial C_T}{\partial d_i} = B_i L_i + C_{IV} \pi L_i \delta_i - H_E \frac{1-\eta_e}{\eta_e \eta_P} \frac{5 \cdot 2 f_i L_i m_i^3}{\pi^2 f_i^2 d_i^5} + \frac{4 \pi H_E L_i k_i (T_i - T_a) \delta_i}{d_i (d_i + 2\delta_i) [\log(1 + \frac{2\delta_i}{d_i})]^2} + 2 C_{FLV} \pi \rho_i \frac{d_i}{2} = 0 \quad (21)$$

It is convenient to express the terms in eq (21) as values relative to some reference diameter d_0 .

$$\frac{\partial C_I}{\partial \delta_i} = C_{IV} \pi \frac{L_i \delta_i (d_i + d_0)}{\delta_i + d_0} = \frac{C_I}{\delta_i + d_0} \quad (22)$$

$$\frac{\partial C_O}{\partial d_i} = C_{O_i} \frac{2 \delta_i}{d_0 (d_i + 2\delta_i) \log(1 + \frac{2\delta_i}{d_i})} \quad (23)$$

$$\frac{\partial C_f}{\partial d_i} = - 5 C_f \frac{d_i^5}{d_i^6} \quad (24)$$

$$\frac{\partial C_{FL}}{\partial d_i} = C_{FL} / d_0 \quad (25)$$

ORIGINAL PA. IS
OF POOR QUALITY

where the C's in eqs (22-25) are the values for d_0 . When eq 12, is expressed in terms of these C's, the result is

$$\frac{\partial C_T}{\partial d_1} = B_c L_c + \frac{C_T}{d_1 + d_c} - \sqrt{C_f} \frac{d_1^2}{d_c^2} + \frac{\sqrt{C_f} L_c}{d_0} + C_0 \frac{\partial d_c}{\partial d_1} \frac{1}{d_0 (d_0 + d_c) \log(1 + \frac{d_1}{d_c})} \quad (26)$$

on solving eq 26 for d_1 , we obtain,

$$d_1 = d_0 \left\{ \frac{\sqrt{C_f}}{B_c L_c d_c + C_T \frac{d_1}{d_1 + d_c} + \sqrt{C_f} L_c + \frac{\partial C_0 \delta_c}{(d_0 + 2d_c) \log(1 + \frac{d_1}{d_c})}} \right\}^{1/6} \quad (27)$$

In eq 27, C_0 is computed from eq 3 even though the derivative was computed from 3a.

The explicit form of eq 20 is

$$\frac{\partial C_T}{\partial d_c} = \pi C_{TV} (2d_c + d_1) - \frac{4HE \pi L_c d_c (T_1 - T_A)}{(d_1 + 2d_c) [\log(1 + \frac{d_1}{d_c})]^2} = - \frac{\pi L_c d_c}{m_{SP} d_c^2 (1 + \frac{d_1}{d_c})} \quad (28)$$

On setting eq 28 to zero and solving for d_1 , we obtain

$$d_1 = \frac{1}{2} \left\{ \left(\frac{4HE \pi (T_1 - T_A)}{C_{TV}} \right)^{1/2} \frac{e^{-\frac{\pi L_c d_c}{m_{SP} d_c^2 (1 + \frac{d_1}{d_c})}}}{\log(1 + \frac{d_1}{d_c})} - d_c \right\} \quad (29)$$

Equations 27 and 29, if they can be solved will yield the values of d_1 and δ_1 which minimize the overall cost of the i^{th} segment. The solution of this pair of equations turns out to be remarkably simple and rapid. The following algorithm has been implemented for their solution.

1) Assume values for d_0 and δ_1 . Compute d_1 using these assumed values. Let the new d_0 be the value just computed and repeat the process until two successive calculations of d_1 yield the same result to within some specified tolerance (say .0001).

2) Using the value of d_1 in eq 29, compute an improved value of δ_1 by the same method.

3) Repeat step 1 using the value of δ_1 obtained from step 2.

After an improved value of d_1 has been obtained, repeat step 2. Continue this process until the convergence criterion is met. In actual practice, the procedure converges in four of five iterations.

To verify that this procedure indeed minimizes system cost, C_T was recalculated using slightly perturbed values of d_1 & δ_1 . In all cases, C_T was higher with the perturbed values.

V. Comparison of Test Case Results

In order to make a sensible comparison of the JPL and FACC approaches, test cases were run on each program. The FACC program was run using the inputs supplied by JPL. The input data is included in Section VI.

a) JPL Results

The JPL program generates a substantial amount of output. Input diameters for pipe number 1 ranged from .7" to .2". Insulation thickness on pipe 1 ranged from 1" to 6". A matrix of 6 x 6 points was generated. The optimum was found to lie between .4" and .5" diameter with an insulation thickness of about 3" on the first segment. At .4" and .5", the pipe diameter for the other segments increased as the square root of the mass flow rate for the hot side. For the cold side, pipe 1 was reduced by the cube root of the fluid density ratio as indicated by eq 11. As stated earlier, JPL used a simplified version of this equation. They neglected the variation of f . This factor cannot be neglected. The viscosity of the cold fluid is twice that of the hot fluid, so f for the cold side is about 20% higher on the cold side than on the hot side. This increase will offset the density ratio. (The FACC result showed the cold side diameters larger than the hot side).

The JPL code requires mass flow units to be input. In the test case, there were 19 different mass flow rates. These were 1, 2, 3, 4, 5, 6, 7, 8, 9, 16, 24, 25, 32, 36, 40, 48, 49, 56 and 64. The JPL input used 11 different flow rates. They lumped 5 and 6 into 6, 7, 8 and 9 into 9, 24 and 25 into 25, 32, 36 and 40 into 40 and 48, 49 and 56 into 56.

The fluid temperature is considered constant throughout the network (actually, two constants, one for the hot side and one for the cold side). The JPL code has an additional requirement built in. There is a maximum permitted pressure drop within a pipe. If the pressure drop exceeds this value, the pipe size is adjusted upward until the pressure drop criterion is satisfied. In the region of the minimum, this restriction was not invoked.

b) FACC Results

The FACC code was used to analyse the same network. The results were as follows. On the hot side, the optimum diameter was .44" with 3" of insulation. The pipes carrying more fluid were larger with more insulation. An examination of the diameters showed that they increased approximately as the square root of the mass flow rate, the maximum deviation being about 6%.

110

ORIGINAL PAGE IS
OF POOR QUALITY

The cold side diameters were all about 7% higher than the hot side. They also followed the same approximate square root relationship, although there is nothing in the program which explicitly imposes this relationship.

In the FACC code, the number of flow units in each pipe is not an input. The program determines it from the geometry of the network. Furthermore in each segment, the temperature drop is determined. The thermal losses are computed from the more exact eq 3., and in each segment, T_1 is different.

The conclusion is that although the two programs approach the problem differently, they yield substantially the same result. The most glaring difference is that JPL finds smaller cold side pipes than hot. This discrepancy, however, would be eliminated by a proper treatment of the friction factor in eq 11.

V. Appendix - Data input

The test case considered a system with 512 collectors in which the heat transfer fluid was Therminol 66. The input data is tabulated below.

<u>Variable</u>	<u>Value</u>	
N_{COL}	512	number of collectors
A_{COL}	1017 ft ²	area of one collector
I_d, n	800 watts/m ²	insolation level
η_{COL}	.81	collector efficiency
T_A	100°F	ambient temperature
T_1^H	600°F	hot side temperature
T_1^C	400°F	cold side temperature
D	47 ft	spacing between collectors
η_P	.8	pump efficiency
η_e	.34	Rankine efficiency
H_E	\$1500/kWt	value of power
C_P^H	.628 BTU/lb°F	specific heat of hot fluid
C_P^C	.534 BTU/lb°F	specific heat of cold fluid
M	.499 lb/sec	mass flow rate in pipe 1
k_H	.516 BTU in/hr ft ²	thermal conductivity or hot side
k_c	.456 BTU in/hr ft ²	thermal conductivity cold side

ORIGINAL PAGE IS
OF POOR QUALITY

<u>Variable</u>	<u>Value</u>	
μ_H	.0049 stokes	viscosity of hot fluid
μ_c	.0098 stokes	viscosity of cold fluid
C_{IV}	\$20/ft ³	insulation cost
C_{FL}	\$.20/lb	cost of fluid

Pipe cost is given by


$$C_p = (10 + .625d) L \quad (\$) \quad d < 4''$$

$$= (5 + 1.9 d) L \quad (\$) \quad d > 4''$$


REFERENCES

- 1 R.H.Turner, "Economic Optimization of Energy Transport", 11th IECEC, p 1239

COST/KWT OF THERMAL TRANSPORT SYSTEM
JPL & FACG CODES
PARAMETER DI, SMALLEST PIPE DIAMETER (IN)
FRICTION CORRECTION INCLUDED IN JPL CODE
CONVENTIONAL PIPING METHODS



COST/KW OF THERMAL TRANSPORT SYSTEM
JPL & FACG CODES
PARAMETER D1, SMALLEST PIPE DIAMETER (IN)
FRICTION CORRECTION INCLUDED IN
JPL CODE
ADVANCED PIPING METHODS



• FACG (RESULT D1 = .44)

112

ORIGINAL PAGE IS
OF POOR QUALITY

APPENDIX C
COMPUTER COST MATRIX PRINTOUTS

ORIGINAL PAGE IS
OF POOR QUALITY

APPENDIX C
COMPUTER COST MATRIX PRINTOUTS

MATRIX FOR BASELINE
STEOR PIPE NETWORK.

ORIGINAL PAGE IS
OF POOR QUALITY.

		TEOR PIPE NETWORK					STEOR PIPE NETWORK					TOTAL								
		STEAM SIDE COST SUMMARY					STEAM SIDE COST SUMMARY					TOTAL								
		0.500	0.750	1.000	1.500	2.000	2.500	3.000	3.500	4.000	2.000	2.500	3.000	3.500	4.000	2.000	2.500	3.000	3.500	4.000
NON PIPE DIA		0.500	0.750	1.000	1.500	2.000	2.500	3.000	3.500	4.000	2.000	2.500	3.000	3.500	4.000	2.000	2.500	3.000	3.500	4.000
LENGTHS ST		882.	882.	1323.	50.	60.	60.	60.	120.	134.	60.	60.	60.	120.	134.	60.	60.	60.	120.	134.
EXPANSION JOINTS		216.	216.	324.	12.	12.	12.	12.	24.	32.	12.	12.	12.	24.	32.	12.	12.	12.	24.	32.
TOTAL		1098.	1098.	1647.	72.	72.	72.	72.	152.	166.	72.	72.	72.	152.	166.	72.	72.	72.	152.	166.
PIFF COST																				
LABOR HRS		39.8	39.8	61.5	3.5	3.8	4.7	8.3	19.1	204.4	3.8	4.7	8.3	19.1	204.4	3.8	4.7	8.3	19.1	204.4
LABOR \$		675.	675.	1042.	59.	64.	80.	141.	324.	3465.	64.	80.	141.	324.	3465.	64.	80.	141.	324.	3465.
MATERIAL \$		1197.	1295.	2309.	157.	188.	267.	351.	860.	7760.	188.	267.	351.	860.	7760.	188.	267.	351.	860.	7760.
SALES TAX		72.	78.	139.	9.	11.	16.	21.	52.	466.	11.	16.	21.	52.	466.	11.	16.	21.	52.	466.
INDIRECT		398.	398.	615.	35.	38.	47.	83.	191.	2044.	38.	47.	83.	191.	2044.	38.	47.	83.	191.	2044.
PROFIT		238.	248.	417.	26.	31.	42.	61.	145.	1394.	31.	42.	61.	145.	1394.	31.	42.	61.	145.	1394.
BONDS		35.	37.	62.	4.	5.	5.	9.	21.	206.	5.	5.	9.	21.	206.	5.	5.	9.	21.	206.
TOTAL \$		2615.	2731.	4583.	291.	336.	458.	666.	1593.	15335.	336.	458.	666.	1593.	15335.	336.	458.	666.	1593.	15335.
EXPANSION JOINTS \$																				
LABOR HRS		18	18	27	1	1	1	1	2	71	1	1	1	2	71	1	1	1	2	71
LABOR \$		106.5	117.8	193.2	8.0	8.6	25.1	29.0	67.8	633.9	8.6	25.1	29.0	67.8	633.9	8.6	25.1	29.0	67.8	633.9
MATERIAL \$		1805.	1997.	3275.	336.	146.	425.	492.	1149.	10745.	146.	425.	492.	1149.	10745.	146.	425.	492.	1149.	10745.
SALES TAX		480.	547.	449.	61.	86.	88.	127.	319.	384.	61.	88.	127.	319.	384.	61.	88.	127.	319.	384.
INDIRECT		29.	33.	27.	4.	5.	5.	8.	19.	152.	5.	5.	8.	19.	152.	5.	5.	8.	19.	152.
PROFIT		1065.	1178.	1932.	80.	85.	251.	290.	678.	6339.	85.	251.	290.	678.	6339.	85.	251.	290.	678.	6339.
BONDS		343.	381.	577.	28.	33.	78.	93.	220.	2007.	33.	78.	93.	220.	2007.	33.	78.	93.	220.	2007.
TOTAL \$		3772.	4192.	6345.	313.	361.	859.	1023.	2417.	22082.	361.	859.	1023.	2417.	22082.	361.	859.	1023.	2417.	22082.
FIXTURES \$																				
LABOR HRS		18	36	54	4	3	3	3	7	130	3	3	3	7	130	3	3	3	7	130
LABOR \$		243.	67.5	121.5	9.8	7.8	12.0	12.5	38.0	353.9	7.8	12.0	12.5	38.0	353.9	7.8	12.0	12.5	38.0	353.9
MATERIAL \$		412.	1144.	2059.	166.	132.	203.	212.	644.	5997.	132.	203.	212.	644.	5997.	132.	203.	212.	644.	5997.
SALES TAX		47.	106.	179.	13.	16.	17.	17.	43.	517.	13.	16.	17.	43.	517.	13.	16.	17.	43.	517.
INDIRECT		3.	6.	11.	1.	1.	1.	1.	3.	31.	1.	1.	1.	3.	31.	1.	1.	1.	3.	31.
PROFIT		72.	196.	352.	28.	23.	35.	36.	109.	1024.	23.	35.	36.	109.	1024.	23.	35.	36.	109.	1024.
BONDS		11.	29.	52.	4.	3.	5.	5.	16.	151.	3.	5.	5.	16.	151.	3.	5.	5.	16.	151.
TOTAL \$		787.	2156.	3847.	310.	253.	381.	395.	1194.	11259.	253.	381.	395.	1194.	11259.	253.	381.	395.	1194.	11259.
VALUES \$																				
LABOR HRS		37.8	37.8	75.8	9.2	9.2	9.2	9.2	14.6	226.3	9.2	9.2	9.2	14.6	226.3	9.2	9.2	9.2	14.6	226.3
LABOR \$		641.	641.	1282.	156.	156.	156.	156.	247.	3837.	156.	156.	156.	247.	3837.	156.	156.	156.	247.	3837.
MATERIAL \$		1544.	1544.	3088.	697.	697.	697.	697.	1394.	13346.	697.	697.	697.	1394.	13346.	697.	697.	697.	1394.	13346.
SALES TAX		93.	93.	185.	42.	42.	42.	42.	84.	741.	42.	42.	42.	84.	741.	42.	42.	42.	84.	741.
INDIRECT		378.	378.	756.	92.	92.	92.	92.	146.	2263.	92.	92.	92.	146.	2263.	92.	92.	92.	146.	2263.
PROFIT		270.	270.	539.	100.	100.	100.	100.	190.	1947.	100.	100.	100.	190.	1947.	100.	100.	100.	190.	1947.
BONDS		40.	40.	80.	15.	15.	15.	15.	28.	288.	15.	15.	15.	28.	288.	15.	15.	15.	28.	288.
TOTAL \$		2985.	2985.	5930.	1102.	1102.	1102.	1102.	2089.	21422.	1102.	1102.	1102.	2089.	21422.	1102.	1102.	1102.	2089.	21422.
ANCHORS \$																				
LABOR HRS		4.0	4.0	8.0	1.0	1.0	1.0	1.0	2.0	25.5	1.0	1.0	1.0	2.0	25.5	1.0	1.0	1.0	2.0	25.5
LABOR \$		68.	68.	136.	17.	17.	17.	17.	34.	433.	17.	17.	17.	34.	433.	17.	17.	17.	34.	433.
MATERIAL \$		216.	216.	432.	22.	22.	22.	22.	45.	1077.	22.	22.	22.	45.	1077.	22.	22.	22.	45.	1077.
SALES TAX		13.	13.	26.	1.	1.	1.	1.	3.	65.	1.	1.	1.	3.	65.	1.	1.	1.	3.	65.
INDIRECT		40.	40.	80.	10.	10.	10.	10.	20.	255.	10.	10.	10.	20.	255.	10.	10.	10.	20.	255.
PROFIT		34.	34.	68.	5.	5.	5.	5.	10.	186.	5.	5.	5.	10.	186.	5.	5.	5.	10.	186.
BONDS		5.	5.	10.	1.	1.	1.	1.	2.	27.	1.	1.	1.	2.	27.	1.	1.	1.	2.	27.
TOTAL \$		376.	376.	752.	56.	56.	56.	56.	114.	2043.	56.	56.	56.	114.	2043.	56.	56.	56.	114.	2043.
PIPE GUIDES \$																				
LABOR HRS		167.4	167.4	299.7	11.1	13.8	13.0	16.8	33.6	768.4	13.8	13.0	16.8	33.6	768.4	13.8	13.0	16.8	33.6	768.4
LABOR \$		2837.	2837.	5080.	188.	234.	234.	234.	570.	13023.	234.	234.	234.	570.	13023.	234.	234.	234.	570.	13023.
MATERIAL \$		3596.	3596.	5394.	200.	202.	212.	331.	992.	11590.	202.	212.	331.	992.	11590.	202.	212.	331.	992.	11590.
SALES TAX		1674.	1674.	2997.	111.	12.	12.	20.	60.	941.	12.	12.	20.	60.	941.	12.	12.	20.	60.	941.
INDIRECT		845.	845.	1400.	52.	59.	61.	101.	336.	7604.	59.	61.	101.	336.	7604.	59.	61.	101.	336.	7604.
PROFIT		125.	125.	207.	8.	9.	9.	12.	29.	560.	9.	9.	12.	29.	560.	9.	9.	12.	29.	560.
BONDS		9292.	9292.	15402.	571.	654.	666.	895.	2166.	41600.	654.	666.	895.	2166.	41600.	654.	666.	895.	2166.	41600.
TOTAL \$		9292.	9292.	15402.	571.	654.	666.	895.	2166.	41600.	654.	666.	895.	2166.	41600.	654.	666.	895.	2166.	41600.
FOUNDATIONS & PILLA																				
LABOR HRS		18	18	36	1	1	1	1	2	81	1	1	1	2	81	1	1	1	2	81
LABOR \$		4.0	4.0	8.0	1.0	1.0	1.0	1.0	2.0	25.5	1.0	1.0	1.0	2.0	25.5	1.0	1.0	1.0	2.0	25.5
MATERIAL \$		216.	216.	432.	22.	22.	22.	22.	45.	1077.	22.	22.	22.	45.	1077.	22.	22.	22.	45.	1077.
SALES TAX		13.	13.	26.	1.	1.	1.	1.	3.	65.	1.	1.	1.	3.	65.	1.	1.	1.	3.	65.
INDIRECT		40.	40.	80.	10.	10.	10.	10.	20.	255.	10.	10.	10.	20.	255.	10.	10.	10.	20.	255.
PROFIT		34.	34.	68.	5.	5.	5.	5.	10.	186.	5.	5.	5.	10.	186.	5.	5.	5.	10.	186.
BONDS		5.	5.	10.	1.	1.	1.	1.	2.	27.	1.	1.	1.	2.	27.	1.	1.	1.	2.	27.
TOTAL \$		376.	376.	752.	56.	56.	56.	56.	114.	2043.	56.	56.	56.	114.	2043.	56.	56.	56.	114.	2043.
PIPE GUIDES \$																				
LABOR HRS		167.4	167.4	299.7	11.1	13.8	13.0	16.8	33.6	768.4	13.8	13.0	16.8	33.6	768.4	13.8	13.0	16.8	33.6	768.4
LABOR \$		2837.	2837.	5080.	188.	234.	234.	234.	570.	13023.	234.	234.	234.	570.	13023.	234.	234.	234.	570.	13023.
MATERIAL \$		3596.	3596.	5394.	200.	202.	212.	331.	992.	11590.	202.	212.	331.	992.	11590.	202.	212.	331.	992.	11590.
SALES TAX		1674.	1674.	2997.	111.	12.														

FIGURE C-1.
COMPUTER COST
MATRIX FOR BASELINE
STEOR PIPE NETWORK
(CONTINUED)

LABOR	147.7	147.7	201.9	2.1	0.1	0.1	0.1	17	13.6	10.5	633.4
LABOR HRS	1074.	1074.	3577.	26.	103.	103.	103.	73.	172.	235.	8037.
MATERIAL \$	1102.	1102.	2103.	15.	60.	60.	60.	43.	101.	148.	4733.
SALES TAX	66.	66.	126.	1.	4.	4.	4.	3.	6.	9.	284.
INDIRECT	872.	872.	1663.	12.	48.	48.	48.	34.	80.	109.	3737.
PROFIT	59.	59.	112.	1.	3.	3.	3.	2.	5.	8.	252.
BONDS	4370.	4370.	8340.	61.	239.	239.	239.	170.	400.	558.	18747.
TOTAL \$	144.9	144.9	217.4	9.5	15.8	15.8	15.8	16.7	33.4	36.5	635.4
LABOR HRS	1304.	1304.	1957.	85.	142.	142.	142.	150.	301.	329.	5710.
MATERIAL \$	5795.	5795.	18045.	885.	953.	953.	953.	1196.	2968.	4630.	44836.
SALES TAX	348.	348.	1083.	53.	57.	57.	57.	72.	170.	278.	2690.
INDIRECT	782.	782.	1174.	51.	85.	85.	85.	90.	180.	197.	3431.
PROFIT	835.	835.	2259.	109.	126.	126.	126.	153.	368.	552.	5753.
BONDS	123.	123.	334.	16.	19.	19.	19.	23.	54.	82.	850.
TOTAL \$	9188.	9188.	24852.	1200.	1382.	1382.	1382.	1684.	4050.	6067.	63270.
INSPECTION	79.2	45.0	94.5	11.0	3.5	3.5	3.5	5.0	8.0	9.0	258.7
LABOR HRS	1342.	762.	1601.	106.	59.	59.	59.	84.	136.	153.	4382.
MATERIAL \$	134.	76.	160.	19.	6.	6.	6.	8.	14.	15.	430.
SALES TAX	8.	5.	10.	1.	0.	0.	0.	0.	1.	1.	26.
INDIRECT	792.	450.	945.	110.	35.	35.	35.	50.	80.	90.	2587.
PROFIT	231.	131.	276.	32.	10.	10.	10.	14.	23.	26.	754.
BONDS	34.	19.	41.	5.	2.	2.	2.	2.	3.	4.	111.
TOTAL \$	2541.	1443.	3032.	353.	112.	112.	112.	159.	258.	209.	8299.

ORIGINAL PAGE IS
OF POOR QUALITY

STEAM SIDE TOTALS

LABOR HRS	751.6	771.9	1353.3	65.2	71.6	93.7	104.2	230.1	298.3	3739.9
LABOR \$	10958.	11302.	20009.	1019.	1053.	1423.	1609.	3577.	4687.	55637.
MATERIAL \$	14111.	17695.	32159.	2049.	2330.	2520.	2792.	6736.	9237.	89938.
SALES TAX	847.	1062.	1930.	124.	134.	151.	167.	404.	578.	5396.
INDIRECT	6244.	6447.	11377.	600.	610.	829.	942.	2071.	2739.	31879.
PROFIT	3264.	3705.	6646.	387.	409.	500.	559.	1300.	1709.	18559.
BONDS	482.	548.	982.	57.	60.	74.	83.	192.	264.	2743.
TOTAL \$	35907.	40759.	73103.	4257.	4495.	5496.	6152.	14300.	17604.	204152.

WATER SIDE SUMMARY

NON PIPE DIA LENGTHS ST	0.125	0.250	0.375	0.500	0.750	1.000	1.250	1.500	2.000	
PIPE COST	802.	882.	882.	441.	60.	60.	120.	180.	74.	
LABOR HRS	39.8	39.8	39.8	19.0	2.7	2.9	8.3	10.4	4.5	166.0
LABOR \$	675.	675.	675.	336.	46.	49.	107.	176.	81.	2820.
MATERIAL \$	750.	820.	1013.	598.	88.	105.	261.	471.	332.	4346.
SALES TAX	45.	50.	61.	36.	5.	6.	13.	20.	14.	261.
INDIRECT	398.	390.	398.	198.	27.	29.	63.	104.	45.	1650.
PROFIT	190.	198.	218.	119.	17.	19.	45.	79.	38.	922.
BONDS	20.	29.	32.	18.	2.	3.	7.	12.	6.	136.
TOTAL \$	2086.	2170.	2397.	1304.	186.	211.	499.	870.	415.	10145.
FIXTURES \$	18	10	18	18	2	3	7	10	3	97
LABOR HRS	21.6	13.5	13.5	13.5	6.0	6.8	16.4	24.3	7.2	122.8
LABOR \$	366.	229.	229.	229.	102.	115.	278.	412.	122.	2082.
MATERIAL \$	29.	27.	28.	30.	7.	10.	22.	30.	11.	202.
SALES TAX	2.	2.	2.	2.	0.	1.	1.	2.	1.	12.
INDIRECT	216.	135.	135.	135.	60.	60.	164.	243.	72.	1228.
PROFIT	62.	40.	40.	40.	17.	20.	47.	71.	21.	358.
BONDS	9.	6.	6.	6.	3.	3.	7.	10.	3.	53.
TOTAL \$	604.	438.	440.	442.	189.	216.	520.	774.	230.	3935.
VALVES \$	18	10	10	18	2	2	4	6	4	90
LABOR HRS	32.4	32.4	32.4	32.4	4.2	4.2	0.4	12.6	9.9	160.9
LABOR \$	549.	549.	549.	549.	71.	142.	142.	214.	168.	2062.
MATERIAL \$	813.	813.	813.	813.	90.	90.	100.	370.	436.	4380.

FIGURE C-2. COMPUTER COST MATRIX FOR
BASELINE STEOR PIPE NETWORK-
MODIFIED FOR FACTORY FABRICATED
OMEGA EXPANSION JOINTS

	0.500	C.750	1.000	1.500	2.000	2.500	3.000	3.500	4.000	TOTAL
STEAM SIDE COST SUMMARY										
NON PIPE DIA	39.8	37.8	61.5	5.5	3.8	4.7	8.3	19.1	23.9	204.4
LENGTHS ST	882.	675.	1042.	59.	64.	80.	141.	324.	405.	3465.
EXPANSION JOINTS	216.	1295.	2309.	157.	188.	257.	351.	860.	1130.	7763.
TOTAL	1098.	1078.	1647.	72.	72.	72.	76.	152.	166.	4496.
TEOR PIPE NETWORK										
PIPE COST	39.8	37.8	61.5	5.5	3.8	4.7	8.3	19.1	23.9	204.4
LABOR \$	675.	675.	1042.	59.	64.	80.	141.	324.	405.	3465.
MATERIAL \$	1197.	1295.	2309.	157.	188.	257.	351.	860.	1130.	7763.
SALES TAX	72.	78.	139.	9.	11.	15.	21.	52.	68.	449.
INDIRECT	398.	578.	615.	35.	38.	47.	83.	191.	239.	2044.
PROFIT	238.	243.	417.	26.	31.	42.	61.	145.	188.	1374.
WONDS	35.	37.	62.	4.	5.	6.	9.	21.	28.	208.
TOTAL \$	2615.	2731.	4583.	291.	336.	458.	666.	1593.	2063.	15335.
EXPANSION JOINTS #										
LABOR HRS	18	18	27	1	1	1	1	2	2	71
LABOR \$	18.0	23.4	48.6	2.5	3.2	4.0	4.6	11.0	13.4	128.7
MATERIAL \$	305.	536.	824.	42.	96.	154.	78.	186.	227.	2313.
SALES TAX	828.	1236.	2295.	101.	149.	224.	318.	848.	1082.	7051.
INDIRECT	50.	72.	138.	6.	9.	13.	19.	51.	65.	423.
PROFIT	190.	234.	486.	25.	32.	40.	46.	110.	134.	1287.
WONDS	138.	174.	380.	13.	29.	35.	47.	121.	153.	1125.
TOTAL \$	1521.	2031.	4179.	194.	319.	493.	515.	1334.	1684.	12373.
FIXTURES #										
LABOR HRS	18	36	54	6	3	3	3	7	10	138
LABOR \$	24.3	67.5	101.5	9.8	7.8	12.0	12.5	38.0	60.5	553.9
MATERIAL \$	412.	1144.	2059.	166.	132.	203.	212.	654.	1025.	5997.
SALES TAX	47.	36.	119.	15.	16.	17.	17.	45.	79.	517.
INDIRECT	3.	6.	11.	1.	1.	1.	1.	5.	5.	31.
PROFIT	243.	675.	1215.	98.	78.	123.	125.	380.	605.	3533.
WONDS	11.	29.	52.	4.	3.	5.	5.	16.	26.	151.
TOTAL \$	787.	2156.	3867.	310.	253.	381.	396.	1174.	1913.	11259.
VALVES #										
LABOR HRS	18	18	36	4	4	4	4	10	4	108
LABOR \$	37.8	37.8	75.6	9.2	9.2	9.2	9.2	24.6	23.7	226.3
MATERIAL \$	641.	541.	1282.	156.	156.	156.	156.	402.	402.	3837.
SALES TAX	1544.	1544.	3088.	697.	697.	697.	697.	1394.	1988.	12345.
INDIRECT	93.	75.	185.	42.	42.	42.	42.	84.	119.	741.
PROFIT	378.	578.	756.	92.	92.	92.	92.	146.	237.	2263.
WONDS	270.	270.	539.	100.	100.	100.	100.	170.	279.	1947.
TOTAL \$	2965.	2355.	5930.	1102.	1102.	1132.	1102.	2039.	3066.	21422.
ANCHORS #										
LABOR HRS	4.0	4.0	8.0	1.0	1.0	1.0	1.0	2.0	3.5	25.5
LABOR \$	68.	58.	136.	17.	17.	17.	17.	34.	59.	433.
MATERIAL \$	216.	216.	432.	22.	22.	22.	22.	45.	80.	1072.
SALES TAX	13.	13.	26.	1.	1.	1.	1.	3.	5.	65.
INDIRECT	40.	40.	80.	10.	10.	10.	10.	20.	35.	255.
PROFIT	34.	34.	68.	5.	5.	5.	5.	10.	18.	185.
WONDS	5.	5.	10.	1.	1.	1.	1.	2.	3.	27.
TOTAL \$	376.	376.	752.	56.	56.	56.	56.	114.	200.	2043.
PIPE GUIDES #										
LABOR HRS	111.6	36	54	2	2	2	2	4	5	143
LABOR \$	1892.	111.6	199.8	7.4	9.2	2.2	11.2	22.5	32.0	514.5
MATERIAL \$	2397.	1372.	3387.	125.	156.	150.	190.	341.	542.	8721.
SALES TAX	144.	237.	3596.	133.	135.	1.1	221.	665.	668.	10353.
INDIRECT	144.	144.	216.	8.	8.	8.	8.	13.	40.	621.

ORIGINAL PAGE IS
OF POOR QUALITY

FIGURE C-2. COMPUTER COST MATRIX FOR
 BASELINE STEOR PIPE NETWORK-
 MODIFIED FOR FACTORY FABRICATED
 OMEGA EXPANSION JOINTS
 (CONTINUED)

	03/11/81	JJT	UJ	PAGE JJ2	FIGURE C-2.
INDIRECT	1116.	1116.	74.	92.	112.
PROFIT	533.	933.	35.	40.	54.
ORDS	83.	138.	5.	6.	8.
TOTAL \$	6195.	10268.	383.	437.	599.
FOUNDATIONS & PILLA	54	90	3	3	6
LAJOR HRS	110.8	216.9	1.6	6.1	10.2
LAJOR \$	1405.	2769.	20.	77.	127.
MATERIAL \$	826.	1618.	12.	45.	75.
SALES TAX	50.	97.	3.	3.	5.
INDIRECT	654.	1280.	9.	36.	60.
PROFIT	298.	583.	4.	16.	27.
ORDS	44.	86.	1.	2.	6.
TOTAL \$	3276.	6412.	46.	179.	300.
INSULATION					
LAJOR HRS	144.9	217.4	9.5	15.8	16.7
LAJOR \$	1304.	1957.	85.	142.	150.
MATERIAL \$	5795.	16045.	885.	953.	1196.
SALES TAX	348.	1083.	53.	57.	72.
INDIRECT	782.	1174.	51.	85.	90.
PROFIT	835.	2259.	109.	126.	153.
ORDS	123.	334.	16.	19.	23.
TOTAL \$	9188.	24852.	1200.	1382.	1684.
INSPECTOR					
LAJOR HRS	79.2	45.0	11.0	3.5	5.0
LAJOR \$	1342.	732.	186.	59.	84.
MATERIAL \$	134.	160.	19.	6.	8.
SALES TAX	8.	10.	1.	0.	1.
INDIRECT	752.	945.	110.	35.	50.
PROFIT	231.	131.	32.	10.	14.
ORDS	34.	41.	5.	2.	3.
TOTAL \$	2541.	3032.	353.	112.	159.

ORIGINAL PAGE IS
 OF POOR QUALITY

	STEAM SIDE TOTALS	WATER SIDE SUMMARY
LAJOR HRS	570.4	534.8
LAJOR \$	8044.	1043.8
MATERIAL \$	12984.	15037.
SALES TAX	779.	16879.
INDIRECT	4583.	1013.
PROFIT	2679.	4727.
ORDS	396.	3137.
TOTAL \$	29465.	34536.
LAJOR HRS	59.6	59.6
LAJOR \$	899.	1058.
MATERIAL \$	2211.	2970.
SALES TAX	133.	134.
INDIRECT	498.	560.
PROFIT	380.	441.
ORDS	56.	65.
TOTAL \$	4177.	4843.
LAJOR HRS	2.7	2.9
LAJOR \$	46.	49.
MATERIAL \$	88.	105.
SALES TAX	5.	6.
INDIRECT	27.	29.
PROFIT	17.	19.
ORDS	2.	3.
TOTAL \$	186.	211.

	0.125	0.250	0.375	0.500	0.750	1.000	1.250	1.500	2.000
INDIRECT	882.	332.	882.	441.	60.	60.	120.	180.	240.
PROFIT	39.8	57.8	39.8	19.8	2.7	2.9	6.3	13.4	4.5
ORDS	675.	675.	675.	335.	46.	49.	107.	176.	81.
MATERIAL \$	750.	328.	1013.	598.	88.	105.	261.	471.	232.
SALES TAX	45.	30.	61.	36.	5.	6.	16.	23.	261.
INDIRECT	398.	523.	393.	193.	27.	29.	63.	104.	45.
PROFIT	190.	178.	218.	119.	17.	19.	45.	79.	38.
ORDS	28.	29.	32.	18.	2.	3.	7.	12.	6.
TOTAL \$	2086.	2178.	2397.	1304.	186.	211.	499.	870.	415.

ORIGINAL PAGE 10
OF POOR QUALITY

FIGURE C-2. COMPUTER COST MATRIX FOR
BASELINE STEOR PIPE NETWORK-
MODIFIED FOR FACTORY FABRICATED
OMEGA EXPANSION JOINTS
(CONCLUDED)

	03/11/81	JUL	PAGE	JUL	PAGE	JUL	PAGE	JUL	PAGE	JUL	PAGE	JUL	PAGE
LAJOUR HNS	395.2	336.7	398.0	293.0	74.8	29.8	42.8	71.1	43.1	102.2			
LAJOUR \$	5749.	5033.	5782.	4458.	1213.	450.	688.	1152.	666.	2322.			
MATERIAL \$	4035.	4336.	4447.	3276.	404.	332.	600.	974.	801.	1525.			
SALES TAX	242.	243.	267.	197.	24.	20.	36.	53.	48.	1135.			
INDIRECT	3041.	2636.	2958.	2345.	697.	247.	395.	662.	370.	1353.			
PROFIT	1326.	1213.	1368.	1043.	237.	136.	175.	287.	191.	5951.			
UNJDS	196.	130.	202.	154.	35.	16.	26.	43.	28.	830.			
TOTAL \$	14589.	13326.	15022.	11474.	2611.	1171.	1920.	3172.	2104.	65466.			

OVERAL TOTALS
 LAJOUR HNS
 LAJOUR \$
 MATERIAL \$
 SALES TAX
 INDIRECT
 PROFIT
 UNJDS
 TOTAL \$

965.6	937.5	1441.8	368.5	134.6	95.8	115.1	229.9	260.4	4531.0
13793.	13350.	20819.	5314.	2112.	1508.	1771.	3534.	3995.	66195.
17019.	20335.	36169.	5315.	2615.	2932.	3462.	7887.	10589.	106393.
1021.	1236.	2170.	319.	157.	174.	203.	473.	635.	6416.
7624.	7353.	11507.	2850.	1195.	807.	1029.	2054.	2315.	36744.
4005.	4355.	7172.	1403.	617.	547.	657.	1415.	1780.	21949.
592.	544.	1063.	207.	91.	31.	97.	209.	263.	3244.
44054.	47733.	78897.	15405.	6788.	6019.	7223.	15574.	19577.	241639.

SF13141 03/11/81 JJT

PAGE 001

FIGURE C-3. COMPUTER COST MATRIX BASELINE

STEOR PIPE NETWORK-MODIFIED FOR USE OF FLEXIBLE HOSE EXPANSION JOINTS

FILE OK

	0.500	C.750	1.500	2.000	2.500	3.000	3.500	4.000	TOTAL
NON PIPE DIA	39.8	37.8	3.5	3.8	4.7	8.3	19.1	23.9	204.4
LENGTHS ST	882	675	59	64	30	141	324	405	3455
EXPANSION JOINTS	216	1275	197	188	207	351	863	1136	7763
TOTAL	1098	1378	1647	72	72	76	152	166	
PIPE COST									
LABOR HRS	39.8	37.8	3.5	3.8	4.7	8.3	19.1	23.9	204.4
LABOR \$	675	615	59	64	30	141	324	405	3455
MATERIAL \$	1197	1042	59	64	30	141	324	405	3455
SALES TAX	72	72	9	11	16	21	52	68	465
INDIRECT	398	378	35	38	47	85	191	239	2044
PROFIT	238	248	26	31	42	61	145	188	1594
BONDS	35	37	4	5	6	9	21	28	206
TOTAL \$	2615	2731	291	336	458	666	1593	2063	15335
EXPANSION JOINTS #	18	18	2	2	3	2	4	5	90
LABOR HRS	12.0	12.0	3.0	3.0	3.0	3.0	6.0	7.0	79.0
LABOR \$	203	233	51	51	102	51	102	118	1339
MATERIAL \$	2340	2700	400	400	1096	400	1400	1635	17013
SALES TAX	140	137	24	24	66	24	84	98	1021
INDIRECT	120	120	30	30	60	30	60	70	790
PROFIT	295	333	51	51	134	51	157	195	2047
BONDS	42	42	8	8	20	8	25	29	302
TOTAL \$	3130	3633	564	564	1478	564	1833	2145	22512
FIXTURES #	18	36	3	3	3	3	7	10	138
LABOR HRS	24.3	67.5	9.8	7.8	12.0	12.5	33.0	60.5	353.9
LABOR \$	412	1144	166	132	293	212	644	1025	5997
MATERIAL \$	47	136	13	16	17	17	45	79	517
SALES TAX	3	6	1	1	1	1	3	5	31
INDIRECT	243	375	98	78	120	125	380	605	3539
PROFIT	72	176	28	23	35	36	109	174	1024
BONDS	11	29	4	3	5	5	16	26	151
TOTAL \$	787	2136	310	253	381	396	1194	1913	11259
VALVES #	18	18	4	4	4	4	16	4	108
LABOR HRS	37.8	37.8	9.2	9.2	9.2	9.2	14.6	23.7	226.3
LABOR \$	641	641	156	156	156	156	247	402	3837
MATERIAL \$	1544	1544	697	697	697	697	1394	1988	12345
SALES TAX	93	73	42	42	42	42	84	119	741
INDIRECT	378	378	92	92	92	92	146	237	2263
PROFIT	270	270	100	100	100	100	193	279	1947
BONDS	40	40	15	15	15	15	23	41	288
TOTAL \$	2965	2965	1102	1102	1102	1102	2039	3066	21422
ANCHORS #	0	0	0	0	0	0	0	0	0
LABOR HRS	0	0	0	0	0	0	0	0	0
LABOR \$	0	0	0	0	0	0	0	0	0
MATERIAL \$	0	0	0	0	0	0	0	0	0
SALES TAX	0	0	0	0	0	0	0	0	0
INDIRECT	0	0	0	0	0	0	0	0	0
PROFIT	0	0	0	0	0	0	0	0	0
BONDS	0	0	0	0	0	0	0	0	0
TOTAL \$	0	0	0	0	0	0	0	0	0
PIPE GUIDES #	36	36	2	2	2	2	3	4	159
LABOR HRS	112.0	112.0	7.4	9.2	9.2	11.2	16.8	22.3	463.6
LABOR \$	1898	1898	125	156	156	190	285	387	7943
MATERIAL \$	2397	2397	134	136	141	221	695	671	11385
SALES TAX	144	144	8	8	8	13	30	40	683

ORIGINAL PAGE IS OF POOR QUALITY

FIGURE C-3. COMPUTER COST M X BASELINE STEOR PIPE NETWORK-MODIFIED FOR USE OF FLEXIBLE HOSE EXPANSION JOINTS (CONTINUED)

5/13 03/11/81 JJJ

PAGE

INDIRECT	1120.	1680.	74.	92.	92.	112.	153.	228.	4685.
PROFIT	564.	99.	35.	40.	40.	54.	99.	135.	2507.
BONDS	83.	144.	5.	6.	6.	3.	15.	20.	371.
TOTAL	6206.	10730.	381.	438.	444.	599.	1093.	1481.	27578.
FOUNDATIONS & PILLA	36	72	2	2	2	2	4	5	162
LAJOR HRS	73.9	173.5	1.3	4.0	6.1	2.9	7.8	10.1	353.2
LAJOR \$	937.	2201.	13.	51.	77.	36.	99.	129.	4481.
MATERIAL \$	551.	1294.	8.	30.	45.	21.	50.	69.	2620.
SALES TAX	33.	73.	0.	2.	3.	1.	3.	4.	157.
INDIRECT	436.	1024.	0.	24.	36.	17.	46.	60.	2084.
PROFIT	199.	467.	3.	11.	16.	8.	20.	27.	948.
BONDS	29.	69.	0.	2.	2.	1.	3.	4.	143.
TOTAL \$	2185.	5132.	31.	119.	179.	85.	221.	293.	10431.
INSULATION									
LAJOR HRS	117.1	174.6	7.9	13.2	15.2	13.2	26.4	29.5	512.2
LAJOR \$	1054.	1572.	71.	118.	118.	113.	233.	265.	4608.
MATERIAL \$	4884.	14495.	737.	794.	934.	944.	2344.	3011.	33226.
SALES TAX	281.	870.	44.	48.	56.	57.	141.	217.	1994.
INDIRECT	632.	943.	43.	71.	71.	71.	143.	159.	2765.
PROFIT	675.	1815.	91.	105.	120.	121.	291.	432.	4323.
BONDS	100.	268.	13.	15.	18.	18.	43.	64.	639.
TOTAL \$	7426.	19963.	999.	1151.	1316.	1329.	3199.	4747.	47556.
INSPECTION									
LAJOR HRS	79.2	94.5	11.0	3.5	3.5	5.0	3.0	9.0	258.7
LAJOR \$	1342.	1601.	185.	59.	59.	84.	136.	153.	4382.
MATERIAL \$	134.	160.	19.	6.	6.	8.	14.	15.	438.
SALES TAX	792.	945.	110.	35.	35.	50.	83.	90.	2537.
INDIRECT	231.	276.	32.	10.	10.	14.	23.	26.	754.
PROFIT	34.	41.	5.	2.	2.	2.	3.	4.	111.
BONDS	2541.	3032.	555.	112.	112.	159.	253.	289.	8299.
TOTAL \$									

STEAM SIDE TOTALS										
LAJOR HRS	496.1	533.1	896.2	52.3	53.7	64.9	65.3	137.7	188.0	2459.8
LAJOR \$	7162.	7314.	13063.	827.	787.	968.	983.	2092.	2910.	36112.
MATERIAL \$	12894.	13445.	32872.	2165.	2267.	3224.	2659.	6623.	9239.	85387.
SALES TAX	774.	837.	1972.	130.	136.	193.	160.	397.	554.	5123.
INDIRECT	4119.	4239.	7442.	488.	460.	563.	580.	1223.	1703.	20793.
PROFIT	2532.	2616.	5619.	366.	371.	502.	445.	1049.	1462.	14963.
BONDS	374.	337.	830.	54.	55.	74.	66.	155.	216.	2211.
TOTAL \$	27856.	28776.	61804.	4030.	4076.	5525.	4899.	11540.	16085.	164590.

WATER SIDE SUMMARY

NON PIPE DIA	0.125	0.250	0.375	0.500	0.750	1.000	1.250	1.500	2.000	
LEUTHS ST	882.	332.	882.	441.	60.	60.	120.	180.	74.	
PIPE COST										
LAJOR HRS	39.8	37.8	39.8	19.8	2.7	2.9	6.3	10.4	4.5	166.0
LAJOR \$	675.	675.	675.	336.	46.	49.	107.	176.	81.	2820.
MATERIAL \$	750.	328.	1013.	598.	88.	105.	261.	471.	232.	4346.
SALES TAX	45.	50.	67.	36.	5.	6.	16.	28.	14.	261.
INDIRECT	398.	378.	398.	198.	27.	29.	63.	104.	45.	1603.
PROFIT	190.	178.	218.	119.	17.	19.	45.	79.	38.	923.
BONDS	28.	29.	32.	18.	2.	3.	7.	12.	6.	136.
TOTAL \$	2086.	2174.	2397.	1304.	186.	211.	499.	870.	415.	10145.

ORIGINAL PAGE 11
OF POOR QUALITY

FIGURE C-3. COMPUTER COST MATRIX BASELINE
STEOR PIPE NETWORK-MODIFIED
FOR USE OF FLEXIBLE HOSE
EXPANSION JOINTS
(CONCLUDED)

FIGURE C-3.

PAGE 004

JJT

03/11/81

SA1314T

LABOR HRS	365.5	323.0	374.8	289.9	73.2	22.8	40.0	63.3	38.4	1605.0
LABOR \$	5374.	4939.	5489.	4418.	1192.	450.	660.	1117.	607.	23994.
MATERIAL \$	5814.	3835.	4274.	3252.	391.	332.	583.	945.	760.	18185.
SALES TAX	229.	230.	256.	195.	23.	20.	35.	57.	46.	1091.
INDIRECT	2866.	2431.	2821.	2326.	688.	247.	382.	645.	343.	12779.
PROFIT	1247.	1133.	1303.	1034.	233.	136.	168.	281.	178.	5639.
BURDS	184.	153.	193.	153.	34.	16.	25.	41.	26.	841.
TOTAL \$	13713.	12523.	14356.	11379.	2561.	1171.	1852.	3086.	1960.	62579.

OVERAL TOTALS										
LABOR HRS	861.6	853.1	1271.0	342.7	126.9	94.7	105.3	200.0	226.5	4064.8
LABOR \$	12536.	12022.	18552.	5245.	1979.	1418.	1648.	3209.	3517.	60106.
MATERIAL \$	16708.	17278.	37146.	5417.	2658.	3556.	3242.	7558.	9999.	103572.
SALES TAX	1002.	1017.	2229.	325.	159.	213.	195.	454.	600.	6214.
INDIRECT	4985.	6370.	10268.	2816.	1148.	810.	962.	1869.	2046.	33573.
PROFIT	3729.	3734.	6922.	1401.	603.	609.	614.	1330.	1640.	20652.
BURDS	558.	535.	1023.	207.	89.	20.	91.	195.	242.	3052.
TOTAL \$	41569.	41275.	76140.	15409.	6637.	6697.	6751.	14626.	18045.	227159.

FIGURE C-4. COMPUTER COST MATRIX
BASELINE STEOR PIPE
NETWORK-MODIFIED FOR
PREFAB POST SUPPORTS

	0.500	0.750	1.000	1.500	2.000	2.500	3.000	3.500	4.000	TOTAL
TEOR PIPE NETWORK										
STEEL SIDE COST SUMMARY										
NON PIPE DIA	39.8	57.8	61.5	3.5	3.8	4.7	8.3	19.1	23.9	204.6
LENGTHS ST	882	675	1042	59	64	80	141	324	405	3465
EXPANSION JOINTS	216	1275	2309	157	188	267	351	862	1136	7760
TOTAL	1098	1078	1647	72	72	72	76	152	166	
PIPE CJST										
LAJOR HRS	39.8	57.8	61.5	3.5	3.8	4.7	8.3	19.1	23.9	204.6
LAJOR \$	675	1042	1323	60	60	60	60	120	134	134
MATERIAL \$	1197	1275	2309	157	188	267	351	862	1136	7760
SALES TAX	72	78	139	9	11	16	21	52	68	455
INDIRECT	398	578	615	35	38	47	83	191	239	2044
PROFIT	238	248	417	26	31	42	61	145	188	1394
UOHDS	35	37	62	4	5	6	9	21	28	205
TOTAL \$	2615	2751	4533	291	336	458	666	1593	2063	15335
EXPANSION JOINTS #										
LAJOR HRS	18	18	27	1	1	1	1	2	2	71
LAJOR \$	106.5	117.8	193.2	8.3	8.6	25.1	29.0	67.8	77.9	633.9
MATERIAL \$	1805	1777	3275	136	146	425	492	1149	1320	10745
SALES TAX	480	57	469	61	86	88	127	319	384	2541
INDIRECT	1065	1178	1932	80	86	251	290	678	779	6339
PROFIT	343	331	577	28	33	78	93	220	254	2007
UOHDS	51	58	85	4	5	12	14	32	38	297
TOTAL \$	3772	4172	6345	315	361	859	1023	2417	2798	22082
FIXTURES #										
LAJOR HRS	18	36	54	4	3	3	3	7	10	138
LAJOR \$	24.3	67.5	121.5	9.8	7.8	12.0	12.5	33.0	60.5	353.9
MATERIAL \$	412	1144	2059	166	132	203	212	644	1025	5937
SALES TAX	47	136	179	13	16	17	17	43	79	517
INDIRECT	3	6	11	1	1	1	1	3	5	31
PROFIT	243	675	1215	98	78	120	125	380	605	3539
UOHDS	72	176	352	28	23	35	36	109	174	1026
TOTAL \$	787	2156	3867	310	253	381	396	1194	1913	11259
VALVES #										
LAJOR HRS	18	18	36	4	4	4	4	16	4	108
LAJOR \$	37.8	37.8	75.6	9.2	9.2	9.2	9.2	14.6	23.7	226.3
MATERIAL \$	641	641	1282	156	156	156	156	247	402	3837
SALES TAX	1544	1544	3088	697	697	697	697	1394	1938	12345
INDIRECT	93	93	185	42	42	42	42	84	119	741
PROFIT	378	378	756	92	92	92	92	146	237	2263
UOHDS	270	270	539	100	100	100	100	190	279	1947
TOTAL \$	2965	2965	5930	1102	1102	1102	1102	2087	3066	21422
ANCHORS #										
LAJOR HRS	4.0	4.0	8.0	1.0	1.0	1.0	1.0	2.0	3.5	25.5
LAJOR \$	68	68	136	17	17	17	17	34	59	433
MATERIAL \$	216	216	432	22	22	22	22	45	80	1077
SALES TAX	13	13	26	1	1	1	1	3	5	65
INDIRECT	40	40	80	10	10	10	10	20	35	255
PROFIT	34	34	68	5	5	5	5	10	18	186
UOHDS	5	5	10	1	1	1	1	2	3	27
TOTAL \$	376	376	752	56	56	56	56	114	200	2043
PIPE GUIDES #										
LAJOR HRS	54	54	81	3	3	3	3	6	7	214
LAJOR \$	167.4	167.4	299.7	11.1	13.8	13.8	16.8	33.6	44.8	768.4
MATERIAL \$	2837	2357	5080	186	234	234	284	570	759	13023
SALES TAX	216	216	324	20	20	20	20	40	70	567
INDIRECT	3596	3596	5394	209	202	212	331	992	1167	15673
TOTAL \$	216	216	324	12	12	15	20	60	70	941

ORIGINAL PAGE IS
OF POOR QUALITY

FIGURE C-4. COMPUTER COST RIX
 BASELINE STEOR PIPE
 NETWORK-MODIFIED FOR
 PREFAB POST SUPPORTS
 (CONTINUED)

ORIGINAL PAGE IS
 OF POOR QUALITY

PAGE 3

JJT

03/11/81

SM1317

INDIRECT	1674.	1076.	2997.	111.	138.	158.	168.	336.	448.	7684.
PROFIT	845.	443.	1400.	52.	59.	61.	81.	192.	248.	3720.
WORDS	125.	125.	207.	8.	9.	9.	12.	37.	37.	563.
TOTAL \$	9292.	5222.	15402.	571.	654.	666.	896.	2186.	2729.	41633.
FOUNDATIONS & PILLA	72	72	117	4	4	4	4	8	10	295
LAJOUR HRS	39.9	37.9	76.2	0.5	2.5	2.5	1.7	4.1	5.8	173.2
LAJOUR \$	677.	577.	1291.	11.	41.	41.	29.	70.	98.	2935.
MATERIAL \$	1741.	1741.	3322.	24.	212.	212.	150.	356.	540.	8297.
SALES TAX	104.	104.	199.	1.	13.	13.	2.	21.	32.	498.
INDIRECT	236.	236.	450.	4.	14.	14.	10.	24.	34.	1022.
PROFIT	280.	230.	534.	4.	28.	28.	20.	43.	71.	1294.
WORDS	41.	41.	79.	1.	4.	4.	3.	7.	11.	191.
TOTAL \$	5079.	3079.	5875.	45.	313.	313.	222.	527.	785.	14238.
INSULATION	144.9	144.9	217.4	9.5	15.8	16.3	16.7	33.4	36.5	635.4
LAJOUR HRS	1304.	1336.	1957.	85.	142.	146.	150.	301.	329.	5718.
LAJOUR \$	5795.	9213.	18045.	885.	953.	1151.	1196.	2968.	4630.	44835.
MATERIAL \$	348.	333.	1083.	55.	57.	59.	72.	173.	278.	2693.
SALES TAX	782.	732.	1174.	51.	85.	88.	90.	130.	197.	3431.
INDIRECT	835.	1203.	2259.	109.	126.	148.	153.	368.	552.	5753.
PROFIT	123.	173.	334.	16.	19.	22.	23.	54.	82.	850.
WORDS	9188.	13233.	24852.	1200.	1382.	1623.	1634.	4050.	6067.	63278.
INSPECTION	79.2	43.0	94.5	11.0	3.5	3.5	5.0	8.0	9.0	258.7
LAJOUR HRS	1342.	752.	1601.	146.	59.	59.	84.	136.	153.	4382.
LAJOUR \$	134.	76.	160.	19.	6.	6.	8.	14.	15.	438.
MATERIAL \$	8.	5.	10.	1.	0.	0.	0.	1.	1.	26.
SALES TAX	792.	430.	945.	110.	35.	35.	50.	80.	90.	2587.
INDIRECT	231.	131.	276.	32.	10.	10.	14.	23.	26.	754.
PROFIT	34.	19.	41.	5.	2.	2.	2.	5.	6.	111.
WORDS	2541.	1443.	3032.	353.	112.	112.	157.	258.	289.	8299.

STEAM SIDE TOTALS

LAJOUR HRS	643.8	664.1	1147.6	63.7	66.0	88.1	100.2	220.6	285.5	3279.7
LAJOUR \$	9761.	10105.	17723.	1004.	991.	1361.	1565.	3475.	4550.	50535.
MATERIAL \$	14750.	18336.	33378.	2078.	2382.	2672.	2899.	6991.	10019.	93502.
SALES TAX	885.	1100.	2003.	125.	143.	160.	174.	419.	601.	5610.
INDIRECT	5608.	5311.	10164.	591.	577.	796.	918.	2036.	2664.	29164.
PROFIT	3147.	3586.	6422.	385.	415.	506.	564.	1312.	1810.	18149.
WORDS	465.	530.	949.	57.	41.	75.	83.	194.	267.	2682.
TOTAL \$	34615.	35433.	70633.	4240.	4570.	5570.	6205.	14427.	19911.	199643.

WATER SIDE SUMMARY

NON PIPE DIA	0.125	0.350	0.375	0.500	0.750	1.000	1.250	1.500	2.000	
LENGTHS FT	882.	332.	882.	441.	60.	60.	120.	180.	74.	
PIPE COST	39.8	32.8	39.8	19.8	2.1	2.9	6.3	10.4	4.5	166.0
LAJOUR \$	675.	675.	675.	336.	45.	49.	107.	176.	81.	2820.
MATERIAL \$	750.	323.	1015.	598.	88.	105.	261.	471.	232.	4346.
SALES TAX	45.	30.	61.	5.	5.	6.	16.	14.	14.	261.
INDIRECT	398.	323.	398.	193.	27.	29.	63.	104.	45.	1663.
PROFIT	190.	173.	218.	117.	17.	19.	45.	79.	38.	922.
WORDS	28.	27.	32.	18.	2.	3.	7.	12.	6.	136.
TOTAL \$	2086.	2173.	2397.	1304.	186.	211.	499.	870.	415.	10145.

FIGURE C-4. COMPUTER COST MATRIX
 BASELINE STEOR PIPE
 NETWORK-MODIFIED FOR
 PREFAB POST SUPPORTS
 (CONTINUED)

ORIGINAL PAGE IS
 OF POOR QUALITY

	JUL		AUG		SEP		OCT		NOV		DEC		TOTAL	
	18	18	18	18	18	18	18	18	18	18	18	18	18	18
FIXTURES #	18	18	18	18	18	18	18	18	18	18	18	18	18	18
LABOR HRS	21.6	13.5	13.5	13.5	13.5	13.5	13.5	13.5	13.5	13.5	13.5	13.5	13.5	13.5
LABOR \$	366.	229.	229.	229.	229.	229.	229.	229.	229.	229.	229.	229.	229.	229.
MATERIAL \$	29.	27.	28.	28.	28.	28.	28.	28.	28.	28.	28.	28.	28.	28.
SALES TAX	2.	2.	2.	2.	2.	2.	2.	2.	2.	2.	2.	2.	2.	2.
INDIRECT	216.	135.	135.	135.	135.	135.	135.	135.	135.	135.	135.	135.	135.	135.
PROFIT	62.	40.	40.	40.	40.	40.	40.	40.	40.	40.	40.	40.	40.	40.
UOHDS	9.	6.	6.	6.	6.	6.	6.	6.	6.	6.	6.	6.	6.	6.
TOTAL \$	684.	433.	440.	442.	442.	442.	442.	442.	442.	442.	442.	442.	442.	442.
VALVES #	18	18	18	18	18	18	18	18	18	18	18	18	18	18
LABOR HRS	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4
LABOR \$	549.	549.	549.	549.	549.	549.	549.	549.	549.	549.	549.	549.	549.	549.
MATERIAL \$	813.	813.	813.	813.	813.	813.	813.	813.	813.	813.	813.	813.	813.	813.
SALES TAX	49.	49.	49.	49.	49.	49.	49.	49.	49.	49.	49.	49.	49.	49.
INDIRECT	324.	324.	324.	324.	324.	324.	324.	324.	324.	324.	324.	324.	324.	324.
PROFIT	176.	176.	176.	176.	176.	176.	176.	176.	176.	176.	176.	176.	176.	176.
UOHDS	26.	26.	26.	26.	26.	26.	26.	26.	26.	26.	26.	26.	26.	26.
TOTAL \$	1937.	1937.	1937.	1937.	1937.	1937.	1937.	1937.	1937.	1937.	1937.	1937.	1937.	1937.
ANCHORS #	18	18	18	18	18	18	18	18	18	18	18	18	18	18
LABOR HRS	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4
LABOR \$	91.	91.	91.	91.	91.	91.	91.	91.	91.	91.	91.	91.	91.	91.
MATERIAL \$	90.	90.	90.	90.	90.	90.	90.	90.	90.	90.	90.	90.	90.	90.
SALES TAX	5.	5.	5.	5.	5.	5.	5.	5.	5.	5.	5.	5.	5.	5.
INDIRECT	54.	54.	54.	54.	54.	54.	54.	54.	54.	54.	54.	54.	54.	54.
PROFIT	24.	24.	24.	24.	24.	24.	24.	24.	24.	24.	24.	24.	24.	24.
UOHDS	4.	4.	4.	4.	4.	4.	4.	4.	4.	4.	4.	4.	4.	4.
TOTAL \$	268.	268.	268.	268.	268.	268.	268.	268.	268.	268.	268.	268.	268.	268.
PIPE GUIDES #	72	72	72	72	72	72	72	72	72	72	72	72	72	72
LABOR HRS	36.0	36.0	36.0	36.0	36.0	36.0	36.0	36.0	36.0	36.0	36.0	36.0	36.0	36.0
LABOR \$	610.	610.	610.	610.	610.	610.	610.	610.	610.	610.	610.	610.	610.	610.
MATERIAL \$	632.	632.	632.	632.	632.	632.	632.	632.	632.	632.	632.	632.	632.	632.
SALES TAX	38.	38.	38.	38.	38.	38.	38.	38.	38.	38.	38.	38.	38.	38.
INDIRECT	360.	360.	360.	360.	360.	360.	360.	360.	360.	360.	360.	360.	360.	360.
PROFIT	166.	166.	166.	166.	166.	166.	166.	166.	166.	166.	166.	166.	166.	166.
UOHDS	25.	25.	25.	25.	25.	25.	25.	25.	25.	25.	25.	25.	25.	25.
TOTAL \$	1831.	1831.	1831.	1831.	1831.	1831.	1831.	1831.	1831.	1831.	1831.	1831.	1831.	1831.
FOUNDATIONS & PILLA	36	36	36	36	36	36	36	36	36	36	36	36	36	36
LABOR HRS	50.1	50.1	50.1	50.1	50.1	50.1	50.1	50.1	50.1	50.1	50.1	50.1	50.1	50.1
LABOR \$	848.	848.	848.	848.	848.	848.	848.	848.	848.	848.	848.	848.	848.	848.
MATERIAL \$	2506.	2506.	2506.	2506.	2506.	2506.	2506.	2506.	2506.	2506.	2506.	2506.	2506.	2506.
SALES TAX	150.	150.	150.	150.	150.	150.	150.	150.	150.	150.	150.	150.	150.	150.
INDIRECT	295.	295.	295.	295.	295.	295.	295.	295.	295.	295.	295.	295.	295.	295.
PROFIT	386.	386.	386.	386.	386.	386.	386.	386.	386.	386.	386.	386.	386.	386.
UOHDS	57.	57.	57.	57.	57.	57.	57.	57.	57.	57.	57.	57.	57.	57.
TOTAL \$	4243.	4243.	4243.	4243.	4243.	4243.	4243.	4243.	4243.	4243.	4243.	4243.	4243.	4243.
INSPECTOR	37.8	37.8	37.8	37.8	37.8	37.8	37.8	37.8	37.8	37.8	37.8	37.8	37.8	37.8
LABOR \$	640.	640.	640.	640.	640.	640.	640.	640.	640.	640.	640.	640.	640.	640.
MATERIAL \$	64.	64.	64.	64.	64.	64.	64.	64.	64.	64.	64.	64.	64.	64.
SALES TAX	4.	4.	4.	4.	4.	4.	4.	4.	4.	4.	4.	4.	4.	4.
INDIRECT	378.	378.	378.	378.	378.	378.	378.	378.	378.	378.	378.	378.	378.	378.
PROFIT	110.	110.	110.	110.	110.	110.	110.	110.	110.	110.	110.	110.	110.	110.
UOHDS	16.	16.	16.	16.	16.	16.	16.	16.	16.	16.	16.	16.	16.	16.
TOTAL \$	1212.	1212.	1212.	1212.	1212.	1212.	1212.	1212.	1212.	1212.	1212.	1212.	1212.	1212.

WATER SIDE TOTALS

ORIGINAL PAGE IS
OF POOR QUALITY

FIGURE C-4. COMPUTER COST MATRIX
BASELINE ESTIMATE 7/72
NETWORK-MODIFIED FOR
PREFAB POST SUPPORTS
(CONCLUDED)

FIGURE C-4.

	JUL	PAGE JD4	JUL	PAGE JD4	JUL	PAGE JD4	JUL	PAGE JD4	JUL	PAGE JD4
LAJOR HRSE	222.2	53.4	297.5	172.2	63.4	23.4	33.3	36.1	1.1	1.1
LAJOR \$	277.5	34.5	347.5	507.7	34.5	64.9	64.9	57.6	17.5	17.5
MATERIAL \$	423.4	54.9	567.5	367.0	54.9	78.7	105.1	123.1	250.5	250.5
SALES TAX	293	33	328	203	33	47	74	74	138.5	138.5
INDIRECT	2025	1620	1834	1632	642	371	620	317	925.4	925.4
PROFIT	1115	1036	1142	845	237	188	313	223	517.6	517.6
WORDS	165	35	169	125	35	28	40	33	7.5	7.5
TOTAL \$	12262	1105.4	12565	9297	2605	2069	3448	2453	56932	56932
OVERAL TOTALS										
LAJOR HRSE	866.9	131.4	1355.1	255.9	108.5	138.5	285.6	319.6	4287.2	4287.2
LAJOR \$	1354.0	2100	21340	4021	1737	2214	4553	5125	67803	67803
MATERIAL \$	1963.4	2931	38853	5548	3149	3686	8298	11249	116587	116587
SALES TAX	1178	176	2331	333	139	221	438	675	6995	6995
INDIRECT	7633	1219	11997	2223	987	1290	2655	2981	38418	38418
PROFIT	4262	652	7564	1231	612	752	1625	2033	23325	23325
WORDS	630	96	679	182	70	111	250	300	3447	3447
TOTAL \$	46877	7174	83205	13537	6735	8274	17874	22363	256575	256575

ORIGINAL PAGE IS OF POOR QUALITY

FIGURE C-5. COMPUTER COST MATRIX BASELINE

STEOR PIPE NETWORK MODIFIED FOR:
1. FLEXIBLE HOSE EXPANSION JOINTS
2. PREFABRICATED POST PIPE SUPPORTS

PAGE JJ1

OUT

04/01/81

SM1105T

TEOR PIPE NETWORK.
STEAM SIDE COST SUMMARY.

	0.500	0.750	1.000	1.500	2.000	2.500	3.000	3.500	4.000	TOTAL
NUM PIPE DIA LENGTHS ST EXPANSION JOINTS TOTAL	892. 216. 1098.	892. 216. 1098.	1323. 324. 1647.	636. 12. 722.	60. 12. 72.	50. 16. 72.	60. 16. 72.	120. 32. 152.	114. 32. 155.	4,300
PIPE COST										
LABOR HRS	59.8	32.8	61.5	5.5	3.8	4.7	8.3	17.1	23.9	204.4
LABOR \$	675.	675.	1042.	59.	64.	80.	141.	324.	435.	3465.
MATERIAL \$	1197.	1295.	2309.	157.	188.	267.	357.	860.	1136.	7763.
SALES TAX	72.	78.	139.	9.	11.	15.	21.	52.	55.	465.
INDIRECT	378.	378.	615.	35.	38.	47.	83.	191.	237.	2046.
PROFIT	238.	248.	417.	26.	31.	42.	61.	145.	178.	1394.
WORDS	55.	57.	62.	4.	5.	5.	9.	21.	28.	235.
TOTAL \$	2615.	2731.	4583.	291.	336.	458.	666.	1593.	2353.	15335.
EXPANSION JOINTS #	18	18	27	1	1	1	1	2	2	71
LABOR HRS	18.0	14.0	27.0	1.5	1.5	1.5	1.5	2.0	2.0	73.0
LABOR \$	305.	305.	458.	26.	26.	26.	26.	34.	34.	1243.
MATERIAL \$	745.	735.	1177.	258.	258.	258.	258.	516.	515.	4811.
SALES TAX	47.	47.	71.	15.	15.	15.	15.	31.	31.	232.
INDIRECT	180.	180.	270.	15.	15.	15.	15.	20.	20.	733.
PROFIT	134.	134.	201.	32.	32.	32.	32.	61.	61.	478.
WORDS	20.	20.	30.	5.	5.	5.	5.	9.	9.	105.
TOTAL \$	1471.	1471.	2206.	351.	351.	351.	351.	671.	671.	7893.
FIXTURES #	18	56	54	6	3	3	3	7	10	138
LABOR HRS	24.3	67.5	121.5	9.8	7.8	12.0	12.5	38.0	53.5	353.9
LABOR \$	412.	1144.	2059.	165.	132.	233.	212.	644.	1325.	5997.
MATERIAL \$	47.	106.	179.	15.	16.	17.	17.	43.	79.	517.
SALES TAX	3.	6.	11.	1.	1.	1.	1.	3.	5.	31.
INDIRECT	243.	675.	1215.	96.	78.	123.	125.	380.	535.	3539.
PROFIT	72.	196.	352.	28.	23.	35.	36.	109.	174.	1024.
WORDS	11.	29.	52.	4.	3.	5.	5.	16.	25.	151.
TOTAL \$	787.	2150.	3867.	313.	253.	331.	395.	1194.	1713.	11259.
VALVES #	18	18	36	6	4	4	4	15	6	138
LABOR HRS	37.6	37.8	75.6	9.2	9.2	9.2	9.2	14.6	23.7	226.3
LABOR \$	641.	641.	1282.	156.	156.	156.	156.	247.	432.	3837.
MATERIAL \$	1544.	1544.	3088.	697.	697.	697.	697.	1394.	1398.	12345.
SALES TAX	93.	93.	185.	42.	42.	42.	42.	84.	119.	741.
INDIRECT	378.	378.	756.	92.	92.	92.	92.	146.	237.	2263.
PROFIT	270.	270.	539.	103.	103.	103.	103.	190.	279.	1947.
WORDS	40.	40.	80.	15.	15.	15.	15.	28.	41.	283.
TOTAL \$	2965.	2965.	5930.	1102.	1102.	1102.	1102.	2089.	3356.	21422.
ANCHORS #	U	0	0	U	0	1	U	1	1	3
LABOR HRS	U	U	0.	U	0.	1.0	0.	1.0	1.5	3.5
LABOR \$	0.	0.	0.	0.	0.	17.	0.	17.	26.	60.
MATERIAL \$	0.	0.	0.	0.	0.	22.	0.	22.	35.	79.
SALES TAX	0.	0.	0.	0.	0.	1.	0.	1.	2.	5.
INDIRECT	0.	0.	0.	0.	0.	13.	0.	13.	15.	35.
PROFIT	0.	0.	0.	0.	0.	5.	0.	5.	8.	18.
WORDS	0.	0.	0.	0.	0.	1.	0.	1.	3.	3.
TOTAL \$	0.	0.	0.	0.	0.	56.	0.	56.	87.	202.
PIPE GUIDES #	50	56	72	2.	2	2	2	3	6	159
LABOR HRS	112.0	112.0	168.0	7.6	9.2	9.2	11.2	15.8	22.3	653.6
LABOR \$	1896.	1896.	2848.	125.	156.	156.	190.	285.	387.	2973.
MATERIAL \$	2397.	2397.	4795.	136.	136.	141.	221.	496.	671.	11388.
SALES TAX	144.	144.	288.	8.	8.	8.	11.	30.	60.	683.

ORIGINAL PAGE IS OF POOR QUALITY

COMPUTER COST MATR... BASELINE
STEOR PIPE NETWORK MODIFIED

FIGURE C-5.

PAGE

OUT

06/01/81

SM11C

FOR:
1. FLEXIBLE HOSE EXPANSION JOINTS
2. PREFABRICATED POST PIPE SUPPORTS
(CONTINUED)

INDIRECT PROFIT	1120.	1683.	74.	92.	72.	112.	158.	225.	4585.
WORKS	504.	975.	55.	40.	63.	54.	99.	155.	2537.
TOTAL \$	6200.	10730.	381.	438.	464.	599.	1395.	1681.	27578.
FOUNDATIONS & FILLA	36	72	2	2	3	2	6	5	152
LABOR HRS	73.9	173.5	1.0	4.0	6.1	2.9	7.8	12.1	353.2
LABOR \$	937.	2201.	13.	51.	77.	36.	129.	129.	4481.
MATERIAL \$	551.	1294.	3.	30.	65.	21.	50.	59.	2523.
SALES TAX	33.	78.	3.	2.	3.	1.	5.	6.	157.
INDIRECT PROFIT	436.	1024.	6.	24.	55.	17.	46.	50.	2084.
WORKS	199.	467.	5.	11.	16.	8.	20.	27.	943.
TOTAL \$	2165.	5132.	31.	119.	179.	85.	221.	293.	10431.
INSULATION									
LABOR HRS	117.1	174.6	7.9	13.2	13.2	13.2	26.4	29.5	512.2
LABOR \$	1054.	1572.	71.	118.	118.	118.	238.	255.	4533.
MATERIAL \$	4084.	14495.	757.	794.	933.	944.	2344.	3511.	33225.
SALES TAX	281.	870.	44.	48.	56.	57.	141.	217.	1996.
INDIRECT PROFIT	632.	943.	43.	71.	71.	71.	143.	159.	2765.
WORKS	675.	1815.	91.	105.	123.	121.	291.	432.	4323.
TOTAL \$	7426.	19963.	999.	1151.	1315.	1329.	3199.	4747.	47555.
INSPECTION									
LABOR HRS	79.2	45.0	11.0	3.5	3.5	5.0	8.0	9.0	258.7
LABOR \$	1342.	762.	186.	59.	59.	84.	136.	153.	4382.
MATERIAL \$	154.	160.	19.	6.	6.	8.	14.	15.	439.
SALES TAX	8.	5.	1.	0.	0.	0.	1.	1.	26.
INDIRECT PROFIT	792.	945.	110.	35.	35.	50.	80.	93.	2587.
WORKS	231.	276.	32.	10.	13.	14.	23.	26.	756.
TOTAL \$	2541.	1443.	355.	112.	112.	159.	258.	289.	8299.

STEAM SIDE TOTALS

LABOR HRS	502.1	896.2	51.3.	52.2	63.4	63.8	133.7	133.3	2453.8
LABOR \$	7204.	13063.	802.	762.	892.	963.	2026.	2326.	36313.
MATERIAL \$	11539.	27497.	2023.	2125.	2335.	2517.	5739.	8123.	73185.
SALES TAX	680.	1653.	121.	128.	143.	151.	344.	487.	4391.
INDIRECT PROFIT	4179.	7447.	473.	445.	518.	565.	1183.	1553.	20733.
WORKS	2361.	5060.	347.	351.	433.	426.	943.	1328.	13636.
TOTAL \$	26196.	55443.	3817.	3863.	4373.	4686.	10374.	14511.	149772.

WATER SIDE SUMMARY

LABOR HRS	0.125	0.250	0.375	0.500	0.750	1.000	1.250	1.500	2.000
LABOR \$	882.	882.	882.	441.	60.	53.	120.	180.	74.
MATERIAL \$	39.8	39.8	39.8	19.8	2.7	2.9	6.3	10.4	4.5
SALES TAX	675.	675.	675.	336.	46.	49.	107.	176.	31.
INDIRECT PROFIT	750.	750.	750.	375.	88.	135.	261.	471.	232.
WORKS	45.	45.	45.	22.5.	5.	5.	16.	28.	14.
TOTAL \$	2086.	2178.	2397.	1506.	186.	211.	494.	870.	10145.

FIGURE C-5. COMPUTER COST MATRIX

PAGE 333

OUT

04/31/81

581165T

FIXTURES #	16	18	18	18	18	2	3	7	10	3	37
LABOR HRS	21.6	13.5	13.5	13.5	13.5	6.0	6.8	16.4	24.3	7.2	122.8
LABOR \$	300	229	229	229	229	102	115	278	412	122	2382
MATERIAL \$	29	27	28	30	30	7	13	22	38	11	202
SALES TAX	2	2	2	2	2	0	2	2	2	2	12
INDIRECT	216	135	135	135	135	60	53	164	243	72	1223
PROFIT	62	40	40	40	40	17	23	47	71	21	353
UNDS	9	6	6	6	6	3	3	7	10	5	53
TOTAL \$	684	438	440	442	442	189	216	520	776	230	3935
VALVLS #	18	18	18	18	18	2	2	4	6	4	90
LABOR HRS	52.4	32.4	32.4	32.4	32.4	4.2	4.2	8.4	12.6	7.9	168.7
LABOR \$	549	549	549	549	549	71	71	142	214	153	2852
MATERIAL \$	813	813	813	813	813	90	93	180	270	635	6233
SALES TAX	49	49	49	49	49	5	5	11	16	24	257
INDIRECT	324	324	324	324	324	42	42	84	126	71	1689
PROFIT	176	176	176	176	176	21	21	42	64	71	923
UNDS	26	26	26	26	26	3	3	6	9	10	136
TOTAL \$	1937	1937	1937	1937	1937	233	233	465	599	779	13155
ANCHORS #	18	18	18	18	18	1	1	2	3	1	83
LABOR HRS	5.4	5.4	5.4	5.4	5.4	0.5	0.5	1.0	1.5	0.5	25.6
LABOR \$	91	91	91	91	91	8	8	16	25	8	430
MATERIAL \$	90	90	90	90	90	14	14	28	42	15	473
SALES TAX	5	5	5	5	5	1	1	2	3	1	23
INDIRECT	54	54	54	54	54	5	5	10	15	5	256
PROFIT	24	24	24	24	24	3	3	6	9	3	121
UNDS	4	4	4	4	4	0	0	1	1	0	13
TOTAL \$	268	268	268	268	268	31	31	63	94	32	1325
PIPE GUIDES #	72	72	72	72	72	4	4	8	12	2	306
LABOR HRS	30.0	30.0	30.0	30.0	30.0	4.0	4.0	8.0	12.0	4.0	193.6
LABOR \$	610	610	610	610	610	68	68	136	204	51	3476
MATERIAL \$	632	632	632	632	632	36	36	72	108	22	2722
SALES TAX	38	38	38	38	38	2	2	4	6	2	153
INDIRECT	360	360	360	360	360	40	40	80	120	34	1935
PROFIT	166	166	166	166	166	15	15	30	45	11	862
UNDS	25	25	25	25	25	2	2	4	6	2	126
TOTAL \$	1831	1831	1831	1831	1831	163	163	326	486	121	9262
FOUNDATIONS & PILLA	50	50	50	50	50	2	2	4	6	0	168
LABOR HRS	77.3	77.3	77.3	77.3	77.3	4.4	4.4	8.8	13.2	4.4	324.2
LABOR \$	1058	1058	1058	1058	1058	60	60	120	180	60	4630
MATERIAL \$	1551	1551	1551	1551	1551	87	87	174	261	59	6437
SALES TAX	93	93	93	93	93	5	5	10	15	4	384
INDIRECT	456	456	456	456	456	26	26	52	78	60	1913
PROFIT	321	321	321	321	321	18	18	36	54	27	1333
UNDS	47	47	47	47	47	3	3	6	9	4	197
TOTAL \$	3526	3526	3526	3526	3526	198	198	396	594	293	14564
INSPECTION	37.8	37.8	37.8	37.8	37.8	45.0	45.0	90.0	135.0	45.0	133.3
LABOR \$	60	60	60	60	60	762	762	1524	2286	762	2205
MATERIAL \$	4	4	4	4	4	76	76	152	228	76	221
SALES TAX	1	1	1	1	1	5	5	10	15	5	13
INDIRECT	378	378	378	378	378	450	450	900	1350	450	1303
PROFIT	110	110	110	110	110	131	131	262	393	131	380
UNDS	16	16	16	16	16	19	19	38	57	19	55
TOTAL \$	1212	1212	1212	1212	1212	1443	1443	2886	4329	1443	4179

ALUMINUM
OF GOOD QUALITY

WATER SIDE TOTALS

139

COMPUTER COST MATRIX BASE-

FIGURE C-5.

LINE STEOR PIPE NETWORK
 MODIFIED FOR:
 1. FLEXIBLE HOSE EXPANSION JOINS
 2. PREFABRICATED POST PIPE SUPPORTS

	04/01/81	OUT		PAGE J34				
LAJOR HRS	250.3	207.8	259.6	174.7	66.8	23.4	40.0	53.5
LAJOR \$	5989.	3303.	4104.	3033.	1117.	575.	660.	1117.
MATERIAL \$	3929.	3950.	4387.	3367.	398.	332.	583.	945.
SALES TAX	236.	237.	263.	202.	24.	23.	35.	57.
INDIRECT	2180.	1731.	2141.	1647.	650.	213.	382.	645.
PROFIT	1049.	941.	1106.	837.	222.	95.	168.	231.
UNDS	155.	159.	163.	124.	33.	14.	25.	41.
TOTAL \$	11544.	10351.	12167.	9213.	2443.	1056.	1852.	3336.

(CONCLUDED)

OVERAL TOTALS								
LAJOR HRS	752.4	720.9	1155.8	226.0	119.0	85.8	103.8	202.0
LAJOR \$	11253.	10719.	17167.	3635.	1879.	1257.	1623.	3141.
MATERIAL \$	15208.	15358.	31886.	5390.	2523.	2725.	3100.	6684.
SALES TAX	910.	923.	1913.	323.	151.	156.	185.	431.
INDIRECT	6365.	6050.	9589.	2120.	1095.	723.	947.	1329.
PROFIT	3431.	3358.	6146.	1186.	573.	476.	594.	1224.
UNDS	507.	476.	908.	175.	85.	73.	88.	181.
TOTAL \$	37740.	36935.	67610.	13027.	6306.	5452.	6538.	13459.

ORIGINAL PAGE IS OF POOR QUALITY

ORIGINAL PAGE IS
OF POOR QUALITY

APPENDIX D

COST DATA

ORIGINAL PAGE IS
OF POOR QUALITY

APPENDIX D
COST DATA

ORIGINAL PAGE IS
OF POOR QUALITY

PIPE COSTS

ORIGINAL PAGE IN
OF POOR QUALITY

QUOTATION

TUBESALES

2211 TUBEWAY • LOS ANGELES • CALIFORNIA • 90040 ☐ PHONE 722-7781

Date 2-17-81

FORD AEROSPACE AND COMMUNICATIONS CORP. F.O.B. NEWPORT BEACH, CA
AERONUTRONIC DIV.
FORD ROAD, BLDG. 10, ROOM 295
NEWPORT BEACH, CALIFORNIA 92660

Terms SEE BELOW

ATTENTION: MR. J.E. MAYER

REFERENCE: 083305

We are pleased to quote as follows:

ITEM NO.	QUANTITY	DESCRIPTION	PRICE PER 100 FT	
<u>CD SMLS BLK PE ASTM-A-106 GR B</u>				
1	9200'	17"/24" RL 3/8 SCH 40 675 X 091	97.08	120 DAYS A.R.O.
2	8200'	17"/24" RL 1/2 SCH 40 840 X 109	112.85	
<u>HF SMLS BLK PE ASTM-A-106 GR B</u>				
4	13,000'	17"/24" RL 3/4 SCH 40 1.050 X 113	128.98	"
	3,000'	17"/24" RL 1 SCH 40 1.315 X 133	153.86	"
5	13,000'	17"/24" RL 1 1/4 SCH 40 1.660 X 140	189.18	"
6	700'	17"/24" RL 1 1/2 SCH 40 1.900 X 145	214.47	"
<u>SMLS BLK PE ASTM-A-53 GR B</u>				
7	700'	17"/24" RL 2" SCH 40 2 3/8 X 154	238.48	"
8	700'	17"/24" RL 2 1/2 SCH 40 2 7/8 X 203	296.96	"
9	1000'	17"/24" RL 3" SCH 40 3 1/2 X 216	399.93	"
<u>SMLS BLK PE ASTM-A-106 GR B</u>				
10	1500'	17"/24" RL 3 1/2 SCH 40 4 X 226	864.08	"

DELIVERY WOULD BE MADE VIA OUR TUBESALES TRUCKS.
TERMS ITEMS 1 THRU 6 AND ITEM 10 1/2% 10/25TH
ITEMS 7,8,9, 2% 10TH PROX.
PRICES FIRM EXCEPT IN THE EVENT OF PRICE INCREASE
AT PRODUCING MILL LEVEL AND INCREASES IN
FREIGHT RATES.
STOCK LISTS AVAILABLE ON REQUEST

Prices quoted may be increased or decreased by changes in mill prices and freight rates.

Shipping schedule is based upon immediate placement of your order.

All materials offered from stock are subject to prior sale.

Quotation is made in accordance with trade customs and practices printed on the reverse side.

SALES COPY TO:

TUBESALES

REQUEST FOR QUOTATION

KILSBY TUBESUPPLY CO.
3750 S. Capitol Av.
City of Industry, CA 91749

ORIGINAL PAGE IS
OF POOR QUALITY



RECEIVED

GENTLEMEN
PLEASE QUOTE YOUR PRICE LESS TRADE DISCOUNTS AND TERMS OF PAYMENT AS LISTED BELOW
UNIT SALES AND USE TAX FROM YOUR PRICE BUT INCLUDE ALL OTHER APPLICABLE TAXES. SALES AND USE TAX STATUS AND THE RESPONSIBILITY FOR PAYMENT THEREOF WILL BE INDICATED ON THE PURCHASE ORDER.
IF UNABLE TO QUOTE AS SPECIFIED PLEASE SHOW HEREON THE QUANTITY YOU CAN SUPPLY AND YOUR GUARANTEED DELIVERIES.
PLEASE INSERT UNIT PRICE OPPOSITE EACH ITEM AND MAIL COPY PROPERLY SEALED TO THIS COMPANY RETAINING BIDDER'S COPY FOR YOUR REFERENCE.

1901 FEB 25 AM 10:44

WITH CORRESPONDING PLEASE REFER TO NO 083302

REPLY TO FORD AEROSPACE AND COMMUNICATIONS CORPORATION
AERONUTRONIC DIVISION
FORD ROAD
NEWPORT BEACH, CA 92660

ATTENTION PHONE FAX

F. E. Mayer, Buyer 714-759-6486

Bldg. 10, Rm. 295 FACCT PMT TERMS

OUR BID SHOULD REACH NO LATER THAN 2-19-81

REQUEST FOR QUOTATION IS ALSO SUBJECT TO CONDITIONS ON THE LISTED ATTACHMENTS

NONE

ARD-7110A

Net 20th Day

QUANTITY	U.M.	DESCRIPTION	UNIT PRICE
		Seamless Carbon Steel Pipe per ASTM 106B	
9200	ft	Schedule 80 - 3/8 inch Dia	122.75
8200	ft	Schedule 80 - 1/2 inch Dia	138.20
18000	ft	Schedule 80 - 3/4 inch Dia	138.09
30000	ft	Schedule 80 - 1.00 inch Dia	199.33
18000	ft	Schedule 80 - 1-1/4 inch Dia	258.25
7000	ft	Schedule 80 - 1-1/2 inch Dia	295.53
7000	ft	Schedule 80 - 2.00 inch Dia	456.40
7000	ft	Schedule 80 - 2-1/2 inch Dia	624.21
10000	ft	Schedule 80 - 3.00 inch Dia	703.87
15000	ft	Schedule 80 - 3-1/2 inch Dia	735.75

NOTE: PRICES ARE IN CFT.

PLEASE CONTACT DAN EATON WHEN PLACING YOUR ORDER.
"PRICE IN EFFECT AT TIME OF SHIPMENT TO APPLY."

SPECIFY MAX. LENGTHS AND IDENTIFY POINTS OF QUANTITY, LENGTH AND DELIVERY PRICE BREAKS.

150 days ARO	QUOTE MUST BE VALID UNTIL 90 days	FOR FORD AEROSPACE AND COMMUNICATIONS CORPORATION BY <i>F. E. Mayer</i> DATE 2/10/81
DELIVERED	TRANSPORTATION TERMS Our Truck	KILSBY TUBESUPPLY COMPANY
CITY OF INDUSTRY	PROPOSED METHOD OF SHIPMENT Our Truck	
NOT 30 Days	YOUR BEST DELIVERY ARO 90 Days	SIGNATURE OF AUTHORIZED COMPANY REPRESENTATIVE <i>Dan Eaton</i>
		DATE 2/19/81

(Dan Eaton, Inside Sales Supervisor)

RETURN THIS COPY TO AERONUTRONIC

KILSBY TUBE SUPPLY CO.
60 S. Capitol Av.
City of Industry, CA 91749

RECEIVED

9950-863
GENTLE 1981 FEB 25 AM 10:44
PLEASE DISCOUNTS AND TERMS OF PAYMENT ON MATERIALS OR SERVICES LISTED BELOW
UNIT SALES AND TAX FROM YOUR PRICE BUT INCLUDE ALL OTHER APPLICABLE TAXES. EXCHANGE TAX STATUS AND THE RESPONSIBILITY FOR DEPARTMENT WILL BE INDICATED ON THE PURCHASE ORDER.
IF UNABLE TO SUPPLY AMOUNT SPECIFIED PLEASE SHOW HEREON THE QUANTITY YOU CAN SUPPLY AND YOUR GUARANTEED DELIVERIES
PLEASE INSERT UNIT PRICE OPPOSITE EACH ITEM AND MAIL COPY PROMPTLY SHIPPED TO THIS COMPANY RETAINING BIDDERS COPY FOR YOUR REFERENCE

WHEN CORRESPONDING PLEASE REFER TO NO 083303

REPLY TO FORD AEROSPACE AND COMMUNICATIONS CORPORATION
AERONUTRONIC DIVISION
FORD ROAD
NEWPORT BEACH, CA 92660

ATTENTION J. E. Mayer, Buyer PHONE 714-759-6486

IF BID SHOULD REACH US LATER THAN

PHONE

WRITTEN

2-19-81

REQUEST FOR QUOTATION IS ALSO SUBJECT TO CONDITIONS ON THE LISTED ATTACHMENTS

NONE

ARD 7110A

FACC PYMT TERMS
Net-20th-Proc

QUANTITY	U/M	DESCRIPTION	UNIT PRICE
		Seamless Carbon Steel Pipe per ASTM 106B	
5200	ft	Schedule 40 - 3/8 inch Dia	105.41
3200	ft	Schedule 40 - 1/2 inch Dia	125.40
13000	ft	Schedule 40 - 3/4 inch Dia	136.83
5000	ft	Schedule 40 - 1.00 inch Dia	177.21
1300	ft	Schedule 40 - 1-1/4 inch Dia	222.00
700	ft	Schedule 40 - 1-1/2 inch Dia	245.00
700	ft	Schedule 40 - 2.00 inch Dia	343.42
700	ft	Schedule 40 - 2-1/2 inch Dia	490.15
1000	ft	Schedule 40 - 3.00 inch Dia	617.29
1500	ft	Schedule 40 - 3-1/2 inch Dia	742.16

DESCRIPTION

UNIT PRICE

NOTE: PRICED IN CFT.

PLEASE CONTACT DAN EATON WHEN PLACING YOUR ORDER.
"PRICE IN EFFECT AT TIME OF SHIPMENT TO APPLY."
SPECIFY MAX. LENGTHS AND IDENTIFY POINTS OF QUANTITY, LENGTH AND DELIVERY PRICE BREAKS

Quote Valid Until	Quote Must Be Valid Until	For Ford Aerospace and Communications Corporation
120 days ARO	90 days	BY <i>J. E. Mayer</i> DATE 2/10/81
FOLLOWING INFORMATION MUST BE FILLED IN		BY <i>Dan Eaton</i> DATE 2/19/81
Delivered	TRANSPORTATION TERMS	KILSBY TUBESUPPLY COMPANY
City of Industry	Our Truck	
City of Industry	PROPOSED METHOD OF SHIPMENT	SIGNATURE OF AUTHORIZED COMPANY REPRESENTATIVE
30 Days	Our Truck	
30 Days	YOUR BEST DELIVERY ARO	DATE
	90 Days	2/19/81

(Dan Eaton, Inside Sales Supv.)
RETURN THIS COPY TO AERONUTRONIC

ORIGINAL PAGE IS
OF POOR QUALITY

PREMOLDED CALCIUM SILICATE PIPE INSULATION

INDASCO INC.

11966 RIVERA ROAD • SANTA FE SPRINGS, CALIFORNIA 90870

PROJECT Pipe Insulation

QUOTATION

TO Ford Aerospace
Ford Rd.
Newport Beach, CA 92660

DATE 2-13-81

QUOTATION No. 1700

TERMS Net 30 Days, No Retention Allowed.

ATTENTION
Ron Polziun

F.O.B. Our Warehouse

DELIVERY See Below

GENTLEMEN: THANK YOU FOR YOUR INQUIRY, WE ARE PLEASED TO SUBMIT THIS PROPOSAL FOR YOUR CONSIDERATION.

Owens-Corning Kaylo 10 calcium silicate pipe insulation. All prices in 36" lengths.

Inside Dia.	Wall Thickness	Price per lin. ft. 2000 lf. or less	Price per lin. ft. 2000 lf. or greater	Price per lf. Alum. Jacket
1/2"	3"	\$ 3.88	\$ 3.60	\$.92
1/2"	3-1/2"	\$ 6.47	\$ 6.01	\$.97
3/4"	3-1/2"	\$ 6.62	\$ 6.15	\$1.01
1"	3-1/2"	\$ 9.11	\$ 8.46	\$1.05
1-1/4"	4"	\$ 9.32	\$ 8.66	\$1.18
1-1/2"	4"	\$10.05	\$ 9.33	\$1.19
2"	4"	\$10.78	\$10.01	\$1.26
2-1/2"	4-1/2"	\$12.64	\$11.64	\$1.51
3"	4-1/2"	\$12.81	\$11.89	\$1.51
3-1/2"	5"	\$16.11	\$14.96	\$1.64

Delivery: 2 to 3 weeks from receipt of order.

NOTE: Prices quoted are those in effect at the date shown on this quotation. Cost increases incurred from material manufacturers between quotation date and date of delivery will necessitate an increase in the price shown on this quotation.

Quoted by: Michael P. O'Rourke

THE TERMS AND CONDITIONS ON THE REVERSE SIDE OF THIS PAGE ARE A PART OF THIS QUOTATION

This quotation is hereby accepted and this will serve as your order to proceed.

The above prices
 Include Sales Tax
 For Resale — Excludes Sales Taxes

ACCEPTED BY: _____

INDASCO, INC.

TITLE: _____

BY: Michael P. O'Rourke
MICHAEL T. O'ROURKE President

DATE: _____

ORIGINAL PAGE IS
OF POOR QUALITY

PREFABRICATED OMEGA EXPANSION JOINT

145

ORIGINAL PAGE OF
OF POOR QUALITY

25
3/2/81

ADVANCE PIPE FINDING & FAB. CO.

HUNTINGTON PARK

PHONE: 714-531-8288


MR. GARY McCRAY

TYPE A EXPANSION JOINT: (CARBON STL. A 106B; ASTM 106)

COST FOR 100, 500, 1000 JOINTS (SCHEDULE 70 PIPE)

NOMINAL PIPE SIZE (INCHES)	RADIUS R (FT.)	LENGTH L (FT.)	HEIGHT H (FT.)	PIPE LENGTH (FT.)	STD. LENGTH PIPE	MAX STRESS REF. (PSI)	LOAD P (LBS)	COST \$/EA		
								100	500	1000
1/4	1.5			16.14		3108	1	39	36	34
3/8	1.5			16.14		2500	1	48	39	37
1/2	2.0			20.95		2780	2.0	46	42	40
3/4	2.0			20.95		3477	4.6	67	62	60
1.0	2.25			24.00		3458	7.3	85	80	78
1 1/2	2.5			25.5		3434	12.9	101	95	92
2.0	2.75			28.0		3589	32.5	149	143	139
2 1/2	3.00			30.3		3691	56.3	224	215	211
3.0	3.25			33.4		3869	75	318	307	301
3 1/2	3.75			37.4		3589	132	424	411	400
4.0	4.00			40.8				541	525	516
5.0	4.50			46.0				880	862	853

ASSUM CAN GET LENGTHS ON ORDER OF MILL RUNS



NOTE: PRICES BASED ON CURRENT OUTLET SUPPLIERS PRICES PER FT OF PIPE

ORIGINAL PAGE IS
OF POOR QUALITY

PROTOTYPE INSTALLATION OF
RISER/DOWNCOMER ASSEMBLIES ON LCC

ORIGINAL PAGE IS
OF POOR QUALITY

3/11/41
MFT

AZIMUTH: (FLEX HOSES)

FIELD LABOR \$ 27.00 HR
SHOP LABOR \$ 22.50 HR

INNER RING:

	<u>MATERIAL</u>	<u>LABOR</u>
1. CLAMP-BAND (2 HALVES)	2.00	4.75
2. SUPPORT BRACKETS-BAND CLAMP L 4x4x 1/4x LGC (4 ea)	6.60	8.50
3. L 4x6x 5/16 x LG. 120" (10.3#/FT.)	51.50	7.50
4. L 3x3x 1/4 x LG 120" (4.9#/FT.)	24.50	7.50
5. CLIP 2x 4 1/2 x 1/4 (4 ea) \$.32	1.28	1.00
6. NUTS & BOLTS 3/8 DIA (13 ea) \$.75 ea	9.75	~
7. WELD ASSY	~	5.62
8. INSTALLATION	~	13.50
	<u>\$ 95.63</u>	<u>\$ 48.37</u>
	+10% 9.56	+20% 9.67
	<u>\$ 105.19</u>	<u>\$ 58.00</u>

OUTER SUPPORT RING:

1. L 4x6x 5/16 x LG. 122" (10.5#/FT.)	53.37	7.50
2. L 3x4x 1/4 x LG. 122" (5.8#/FT.)	29.43	7.50
3. L 2x3x 1/4 x LG 118" (4.1#/FT.)	20.16	7.50
4. CLIP 2 1/2 x 3 x 1/4 x LG 5 1/2" (4.5#/FT) (8 ea)	9.00	5.60
5. TEE HANGER (ST-3-B 4.25#/FT., LG. 23" (2 ea)	2.13	6.75
6. TEE HANGER (ST-3-B 4.25#/FT., LG 24" (2 ea)	2.13	6.75
7. ANCHOR (POINT "A") WELDMENT	4.20	5.60
8. ANCHOR (POINT "B") WELDMENT	4.20	5.60
9. NUTS & BOLTS 3/8 DIA (12 ea) \$.75 ea	9.00	~
10. U" BOLTS 3/8 DIA (12 ea) \$ 2.67 ea	32.00	~
11. WELD ASSY	~	6.25
12. INSTALLATION	~	15.60
	<u>\$ 165.67</u>	<u>\$ 74.85</u>
	+10% 16.56	+20% 14.93
	<u>\$ 182.23</u>	<u>\$ 89.58</u>

SUB TOTAL \$ 287.42 \$ 147.58

3/17/81
H/T

ORIGINAL PAGE IS
OF POOR QUALITY

ELEVATION: (FLEX HOSES)

TRUNNION - STEAM SIDE:

1. ARM-CHANNEL 5X1 3/4 X 5/8 X LG 21" (6.7 1/2')
2. BRACKET-ANCHOR-WELDMENT
3. "U" BOLTS 3/8 DIA (2 ea) @ 2.67 ea
4. BOLTS 3/8 DIA (12 ea) @ .75 ea
5. INSTALLATION

FIELD LABOR \$27.00/HR
SHOP LABOR \$22.50/HR

MATERIAL	LABOR
5.86	6.00
4.20	9.62
5.34	~
9.00	~
~	13.50
<u>\$ 24.40</u>	<u>\$ 29.12</u>

TRUNNION - WATER SIDE
(SAME AS ABOVE - STEAM SIDE)

<u>\$ 24.40</u>	<u>\$ 29.12</u>
\$ 48.80	\$ 58.24
+10% 4.88	+20% 16.65
<u>\$ 53.68</u>	<u>\$ 74.89</u>

SUB TOTAL

3/17/81
R.F.

INTERMEDIATE LINES & CONNECTIONS:

STEAM LINE:

	MATERIAL	LABOR
1. 5/8 DIA TUBING FROM RECEIVER (LG. 369") @ 1.95/FT. TO ELEVATION TRUNNION	\$ 59.96	135.00
2. 5/8 DIA TUBING FROM ELEVATION (LG. 284 + 203" = 487") TO AZIMUTH CENTER PINTLE	79.14	135.00
3. WELD JOINTS (5 JOINTS)	~	67.50

WATER LINE:

4. (SAME AS ABOVE STEAM LINE)	139.10	337.50
5. CLAMP - INSULATION (STEAMLINE) INSULATION BLOCK (EVERY 10 FT, 7 ea) "U" BOLT (7 ea) @ 2.67 ea	\$ 84.00 18.69	\$ 38.94 39.20
6. "U" BOLT (WATER LINE) (7 ea) INSULATION (STEAM LINE, 71 FT @ 4.60/FT)	18.69 326.60	39.20 162.00

\$ 726.18	954.34
+10% 72.61	+20% 190.87
\$ 798.79	\$ 1145.21

SUB TOTAL

TOTAL OF SUB TOTALS: \$11318⁽¹⁾
~~\$1129.89~~ \$ 1367.68

FLEX HOSE ELEVATION (STEAM LINE)	915
FLEX HOSE ELEVATION (WATER LINE)	448
FLEX HOSE AZIMUTH (STEAM LINE)	1405.00
FLEX HOSE AZIMUTH (WATER LINE)	639.00
SUBTOTAL FLEX HOSE	3407
GRAND TOTAL	\$4725 1367.68

(1) CORRECTIONS:

21' 5/8" DIA INSULATED TUBING
BETWEEN PINTLE & OUTER RAIL

WATER LINE	\$141
STEAM LINE	158
	179

D-14

TOTAL 6092

ORIGINAL PAGE IS
OF POOR QUALITY.


INSULATED FLEXIBLE HOSE ASSEMBLIES
FOR EXPANSION JOINT APPLICATION

FD 7 AEROSPACE, AERONAUTRONIC DIV.
 TPA FIELD GEOMETRY, FLEXIBLE - JUNCTIONS, STAINLESS STEEL WITH DURAL IMMET
 INSULATION TAPED + GASED, WITH STEEL WELD NIPPLES EA END
 TO YOUR PIPE SIZES. 930 PSIG AT 600°F EXCEPT WHERE NOTED.
 PIPE RUNS = 60' BETWEEN ANCHORS

ANACONDA

12/81

PIPE SIZE	HOSE ID & TYPE	ORL	PIPE GAP "A" COLD	TRAVEL "T"	PIPE GAP "B" HOT	LOOP HGT "C" HOT	EST. COST NET
FOR 1/2"	3/4" BWH21-1H	44"	20.6"	3.5"	17"	15"	\$ 122.50 EA (SUB STAINLESS NIPPLES ADD \$14.00)
FOR 3/4"	1" BWH21-1H	46"	21.6"	3.6"	18"	16"	\$ 144.60 EA (SUB STAINLESS NIPPLES ADD \$16.00)
FOR 1"	1 1/4" BWH21-2H	50"	23.6"	3.6"	20"	17.5"	\$ 192.00 EA (SUB STAINLESS NIPPLES ADD \$17.00)
FOR 1 1/2"	2" BWH21-2	69"	32.6"	3.6"	29"	24"	\$ 390.50 EA (SUB STAINLESS NIPPLES ADD \$22.00)
FOR 2"	2 1/2" BWH21-2	76"	36"	3.6"	32.4"	27"	\$ 497.40 EA (SUB STAINLESS NIPPLES ADD \$46.00)
FOR 2 1/2"	3" BWH21-2	101"	49"	3.6"	45.4"	35"	\$ 696.75 EA (SUB STAINLESS NIPPLES ADD \$65.00)
FOR 3 1/2"	4" BWF w/SPEC. BR.*	116"	61"	3.6"	57.4"	44"	\$ 1319.00 EA (SUB STAINLESS NIPPLES ADD \$104.00)



NOTES: 1. HOSE ID'S JUMP ONE SIZE TO OFFSET PRESSURE DROP THROUGH LOOP.

2. LOOPS SHOULD BE LOCATED CLOSE TO AN ANCHOR POINT.

* 3. ABOVE COSTS ARE FOR ESTIMATING PURPOSES AND ARE NOT A QUOTATION.

Orin printed

ANACONDA 12/81

AND AEROSPACE, AERONAUTRONIC & I.P.H. FIELD GEOMETRY, COLD SIDE

FLEXIBLE CONNECTIONS, STAINLESS STEEL, NO INSULATION, STEEL 4-ELB NIPPLES EACH END TO YOUR PIPE SIZES, 1000 PSIG AT 70°F EXCEPT WHERE

NOTED. PIPE RUNS = 60' BETWEEN ANCHORS HOSE IDS JUMPED ONE SIZE TO OFFSET ANY PRESSURE DROP THROUGH LOOP.

PIPE SIZE	HOSE ID & TYPE	OAL	PIPE GAP "N" COLD	TRAVEL "T" AT 140°F	PIPE GAP "B" LOOP HSTC	EST. COST NET
FDR 1/2"	1/4" BW21-1	20"	8.5"	.5"	8" HUT 6 1/4" (SUB STAINLESS NIPPLES, ADD \$7.00)	\$34.20 EA
FDR 1/4"	3/8" BW21-1H	28"	12.5"	.5"	12" HUT 9" (SUB STAINLESS NIPPLES, ADD \$8.00)	\$43.70 EA
FDR 3/8"	1/2" BW21-1H	35"	16.5"	.5"	16" HUT 12" (SUB STAINLESS NIPPLES, ADD \$10.00)	\$51.70 EA
FDR 1/2"	3/4" BW21-1H	38"	17.5"	.5"	17" HUT 13" (SUB STAINLESS NIPPLES, ADD \$12.00)	\$63.15 EA
HDR 3/4"	1" BW21-1H	41"	18.5"	.5"	18" HUT 14" (SUB STAINLESS NIPPLES, ADD \$14.00)	\$74.30 EA
HDR 1"	1 1/4" BW21-2H	45"	20.5"	.5"	20" HUT 15" (SUB STAINLESS NIPPLES, ADD \$16.00)	\$114.85 EA
HDR 1 1/4"	1 1/2" BW21-2H	51"	22.5"	.5"	22" HUT 16" (SUB STAINLESS NIPPLES, ADD \$18.00)	\$154.80 EA
HDR 1 1/2"	2" BWH21-2	64"	29.5"	.5"	29" HUT 21" (SUB STAINLESS NIPPLES, ADD \$20.00)	\$291.70 EA
HDR 2"	2 1/2" BWH21-2*	71"	33"	.5"	32.5" HUT 24" (SUB STAINLESS NIPPLES, ADD \$45.00)	\$381.60 EA

ORIGINAL PAGE IS OF POOR QUALITY

* 750 PSIG MAX OPERATING PRESSURE.

- NOTES: 1. REFER TO SKETCH ON PG. #1
2. ABOVE COSTS ARE FOR ESTIMATING PURPOSES ONLY, AND ARE NOT A QUOTATION.

John Mott

POSTS FOR PIPE SUPPORTS

158

ORIGINAL PAGE IS SIGN POSTS AND ACCESSORIES
OF POOR QUALITY


TRAFFIC SIGN POSTS

Sign Posts are manufactured from a rail steel flanged channel section. The design of this section makes it one of the strongest possible for use as Route Marker Posts and Highway Sign Posts. The use of rail steel in rolling this section gives it the high tensile strength desirable for this use.

Each of these posts is punched with sixty 3/8" hole on 1" centers beginning 1" from the top of the post.

In erecting — sign post should be driven 18" to 24" into ground for rigidity and stability.


Mounting of Traffic Signs — for commercial and business districts — The distance from the bottom of the sign to the ground should be 7 feet.



Sign Posts are to be used with Traffic Signs Pages 103-107.

Code No.	Length Feet	Weight Per Foot	*Price Ea., Per Post	
			5 Post	10 Over
68-34-080	8' 0"	2 lbs.	\$13.75 ea.	\$13.30 ea.
69-34-090	9' 0"	2 lbs.	15.10 ea.	14.65 ea.
70-34-100	10' 0"	2 lbs.	16.35 ea.	16.70 ea.

five



Extra Heavy


Speeds Up Installation
Prevents Marring the Post Ends, For Traffic Sign Series Posts, 68-34-080 thru 70-34-100 (Not for 66-34-006 posts)

Code No.	Price
51-85-012	\$17.25 ea.

Code No.	Length Feet	*Price Ea., Per Post	
		5-Post	10-Over
66-34-006	6'	\$9.75 ea.	\$8.30 ea.

five

WT. PER FT. 1.12 Lbs.



PORTABLE STANDARD T-90 (Portable Traffic Stanchion)

No Rusting, Made of lifetime cast iron. (Not stamped metal) Overall height is 42", diameter of base is 15", approximate weight is 38 pounds. 12" x 18", 18" x 24" and Square 24" x 24" Traffic Signs Fit the T-90



Code No.	Description	Price Ea.
T-90	Portable Traffic Stanchion (without sign)	\$73.95 ea.

12-10-019 (See Pg. 105)

66-34-006

Delimitor Not Included With Post

Sign Not Included With Stanchion



WOOD OR STEEL POSTS

Code No.	Price
52-85-020	\$12.55 Per Pair

No. 52-85-020

See Page 103 to 107.

of traffic signs on pages 103 thru 109 to Traffic Sign Posts 68-34-080 thru 70-34-100, also 66-34-006 Delimitor posts. Each sign takes two bolts.

Code No.	Size	Material	Box of 50 Bolts and Nuts
57-85-002	2 x 3 1/8"	Aluminum Bolts & Nuts	\$22.35 Per Box

fits pipe post 1 1/4" to 2 1/4" diameter

These pipe post brackets are designed to give a wide bearing surface for signs that are to be mounted on pipe posts. No drilling is necessary and signs can be easily adjusted to desired position. Cadmium plated bolts are furnished with each bracket.

Code No.	Bracket Size	Outside Dia. of Post	Price
54-85-010	2"	1 1/4" x 2 1/4"	\$12.75 Per Pair

54-85-010 Bracket is to be used for mounting of Traffic Signs Pages 103 to 107. Two Brackets required for each sign.

51-35-010

Cross Section Detail of No. 54-35-010 Bracket

ORIGINAL PAGE IS
OF POOR QUALITY

APPENDIX E

FACC NETWORK OPTIMIZATION COMPUTER

OUTPUT SHEETS AND INPUT DATA

ORIGINAL PAGE IS
OF POOR QUALITY

APPENDIX E
FACC NETWORK OPTIMIZATION COMPUTER
OUTPUT SHEETS AND INPUT DATA

26

ORIGINAL PAGE IS
OF POOR QUALITY

E-1 FACC NETWORK OPTIMIZATION
BASELINE STEOR NETWORK 72 DISH FIELD
STEAM TEMPERATURE = 530 F
JPL CONVENTIONAL SCHEDULE 80 COST MODEL
COST OF ENERGY = 1500 \$/KW_T

CONVECTION \$7 - CH

SPACING 120/STEAM 0. \$/LB
49.0 60.0 FT
HEIGHT TO COLLECTOR 0.5 FT
OF COLLECTORS H-S 8 E-W 9
INSULATION COST 20.00 \$/LB
MASS FLOW RATE PER UNIT 0.03 LB/SEC
SPECIFIC HEAT HOT 1.1500 COOL 1.0000 BTU/LB-DEG F
CONDUCTIVITY 0.6000 HOT 0.3100 COOL BTU-IN/(FT**2-DEG F-HR)
SOURCE TEMPERATURE 550.0 DEG F AMBIENT TEMP 100.0 DEG F
RETURN TEMPERATURE 70.0 DEG F
DENSITY HOT 0.031 COOL 1.000 GM/CM3
VISCOSITY HOT 0.011 COOL 0.010 STKS
CONVENTIONAL PIPING METHODS SCHEDULED
INSULATION 1.000 KM/M**2
COLLECTOR DIAM 12. H
COLLECTOR EFFICIENCY 0.6635

	INS	NUM	D	IN	LENG	MASS	PCOST	QTH	CRTH	QF	COF	TOTAL	GRAND TOTAL
					FT	UNITS	\$	KW	\$	KW	\$	KW	E-\$
COLLECTOR	3.40	72	0.500	51.	1	1369.42	0.95	1431.66	0.02	66.61	1490.27	2887.69	
FIBER S	1 3.35	10	0.750	1247.	1	33030.51	23.07	34603.97	0.56	1631.88	36235.85	70656.36	
FIBER S	2 3.52	10	0.500	1247.	2	35583.67	24.53	36795.77	0.88	2556.20	39352.04	74935.71	
FIBER S	3 3.71	10	1.000	1247.	3	37572.29	26.35	39530.64	0.77	2240.67	41779.31	79351.60	
FIBER S	4 3.71	18	1.000	624.	4	18003.07	13.17	19752.08	0.91	2644.93	22297.81	41200.88	
INNER S	1 4.04	1	1.500	85.	0	2839.27	2.04	3066.66	0.09	269.57	3336.23	6175.50	
INNER S	2 4.24	1	2.000	85.	16	3076.50	2.22	3327.41	0.19	555.22	3082.63	5959.12	
INNER S	3 4.43	1	2.500	85.	24	3319.08	2.39	3599.16	0.25	723.62	4312.78	7631.86	
INNER S	4 4.63	1	3.000	85.	32	3599.45	2.60	3898.43	0.18	535.76	4435.19	8033.64	
INNER S	5 4.76	1	3.500	85.	40	3837.24	2.76	4133.62	0.17	482.05	4615.67	8452.91	
INNER S	6 4.76	1	3.500	85.	40	3836.88	2.75	4131.64	0.20	829.13	4950.77	8797.65	
INNER S	7 4.89	1	4.000	85.	56	4074.91	2.91	4350.28	0.23	672.20	5030.47	9105.31	
INNER S	8 4.89	1	4.000	85.	54	4074.60	2.90	4356.97	0.34	1000.17	5357.14	9431.73	
INNER S	9 4.99	1	4.000	14.	72	679.21	0.46	726.14	0.08	236.74	952.88	1642.09	
						156515.02	109.14	153703.22	4.96	14453.82	114.10	170157.05	334672.07

COST OF FLUID 0.
INSULATION COST 43227.

	TEMPERATURE AT STORE	529.6	DEG-F	QTH	CRTH	QF	COF	TOTAL	GRAND TOTAL
				KW	\$	KW	\$	KW	E-\$
INNER S	2 0.	1	2.000	10.	72	240.00	6.51	0.00	246.51
INNER S	3 0.	1	2.000	60.	64	1440.00	27.70	0.01	1467.70
INNER S	4 0.	1	1.500	60.	56	1300.00	59.46	0.02	1449.46
INNER S	5 0.	1	1.500	60.	48	1300.00	44.34	0.02	1424.34
INNER S	6 0.	1	1.500	60.	40	1300.00	25.12	0.01	1406.13
INNER S	7 0.	1	1.250	60.	32	1350.00	30.65	0.01	1380.65
INNER S	8 0.	1	1.250	60.	24	1350.00	13.42	0.00	1363.43
INNER S	9 0.	1	1.000	60.	16	1320.00	16.01	0.01	1338.01
INNER S	10 0.	1	0.750	60.	8	1290.00	8.86	0.00	1290.86
FIBER S	1 0.	18	0.500	441.	4	9241.00	41.96	0.01	9302.96
FIBER S	2 0.	18	0.375	882.	3	18301.50	134.19	0.05	18355.69
FIBER S	3 0.	18	0.250	882.	2	16081.00	233.74	0.06	16314.71
FIBER S	4 0.	18	0.125	882.	1	17660.50	180.94	0.06	18041.45
COLLECTOR	0.	72	0.125	36.	1	729.00	7.39	0.00	736.39
						75353.00	843.58	0.29	76206.58

COST OF FLUID 0.
INSULATION COST 5284. KW AT A COST OF 70.53 \$/KW

ORIGINAL PAGE IS
OF POOR QUALITY

E-2 FACC NETWORK OPTIMIZATION
ALTERNATE PROCESS TEMPERATURE
72 DISH NETWORK
STEAM TEMPERATURE = 489°F
JPL CONVENTIONAL SCHEDULE 80 COST MODEL
COST OF ENERGY = 1500 \$/KW_T

INPUT CONFIGURATION 17 - 63

SPACING 120/311 ft 0. \$/LB
HEIGHT TO COILS 50.0 FT
OF COILS 8-5 0 F-U 9
INSULATION COST 20.00 \$/LB
WASS FLOW RATE PER UNIT 0.06 LB/SEC
SPECIFIC HEAT HOT 0.9700 COOL 1.0000 BTU/LB DEG F
CONDUCTIVITY 0.5300 HOT 0.3100 COOL BTU-IN/(FT-HR DEG F-HR)
SOURCE TEMPERATURE 316.0 DEG F AMBIENT TEMP 100.0 DEG F
RETURN TEMPERATURE 70.0 DEG F
DENSITY HOT 0.621 COOL 1.000 GR/CM3
VIScosity HOT 0.013 COOL 0.010 STES
CUMULATIVE FLOW LOSS THROUGH SCHED 1007
INSULATION 1.000 FLOW LOSS
COILS PER UNIT 3.0
EFFICIENCY 0.6635

	IPS	HR	D	IN	LCRG	MASS	PCOST	RUH	CRUH	BI	COF	TOTAL	TOTAL	GRAND
					FT	UNITS	\$	KW	\$	KU	\$	KW	KW	\$
COILS	3.15	72	0.500	51.	1	1344.64	0.79	1192.37	0.65	156.70	0.85	1351.27	2655.91	
HR S	1 3.00	18	0.500	1247.	1	32752.78	19.20	28798.19	1.34	3093.06	20.54	32691.25	65444.03	
HR S	2 3.40	18	1.000	1247.	2	36180.07	22.05	33073.01	0.55	1667.61	22.60	34740.62	70860.89	
HR S	3 3.40	18	1.000	1247.	3	55170.50	31.95	32927.29	1.04	5363.87	26.77	38791.16	74459.45	
HR S	4 3.40	18	1.250	623.	4	19174.95	11.92	17698.27	0.48	1288.99	12.41	17267.26	38262.21	
HR S	1 3.90	1	2.000	95.	0	2941.93	1.87	2298.20	0.02	160.69	1.92	2458.89	5708.82	
HR S	2 4.06	1	2.500	85.	16	2125.44	2.01	3015.19	0.18	516.76	2.19	3531.94	8097.28	
HR S	3 4.24	1	3.000	85.	24	3422.46	2.19	3279.30	0.19	584.24	2.37	3823.53	7245.99	
HR S	4 4.37	1	3.500	85.	32	3644.06	2.32	3480.83	0.20	592.16	2.52	4072.98	7717.04	
HR S	5 4.48	1	4.000	85.	40	3864.58	2.45	3576.33	0.20	589.50	2.65	4255.83	8130.41	
HR S	6 4.48	1	4.000	85.	48	3864.58	2.45	3576.33	0.35	1014.17	2.80	4588.65	8587.92	
HR S	7 4.48	1	4.000	85.	56	3864.58	2.45	3576.33	0.55	1605.21	3.00	5278.00	9141.61	
HR S	8 4.60	1	5.000	85.	64	4513.81	2.72	4073.25	0.25	735.42	2.98	4769.77	9412.57	
HR S	9 4.60	1	5.000	14.	72	769.14	0.45	628.21	0.06	171.65	0.51	800.56	1619.70	
						155781.07	94.83	142738.42	6.39	10339.73	101.12	160540.14	314359.16	

COST OF FLOW 0.
DREDCALCOST 40000.

TEMPERATURE AT STAGE 400.7 DEG F

HR S	7 0.	1 2.000	10.	72	240.00	0.	0.	0.	0.	0.	0.	0.	0.	0.
HR S	3 0.	1 2.000	60.	64	1440.00	0.	0.	0.	0.	0.	0.	0.	0.	0.
HR S	4 0.	1 1.500	60.	56	1380.00	0.	0.	0.	0.	0.	0.	0.	0.	0.
HR S	5 0.	1 1.500	60.	48	1500.00	0.	0.	0.	0.	0.	0.	0.	0.	0.
HR S	6 0.	1 1.500	60.	40	1380.00	0.	0.	0.	0.	0.	0.	0.	0.	0.
HR S	7 0.	1 1.250	60.	32	1356.00	0.	0.	0.	0.	0.	0.	0.	0.	0.
HR S	8 0.	1 1.250	60.	24	1350.00	0.	0.	0.	0.	0.	0.	0.	0.	0.
HR S	9 0.	1 1.000	60.	16	1370.00	0.	0.	0.	0.	0.	0.	0.	0.	0.
HR S	10 0.	1 0.750	60.	8	1290.00	0.	0.	0.	0.	0.	0.	0.	0.	0.
HR S	1 0.	10 0.500	441.	4	9261.60	0.	0.	0.	0.	0.	0.	0.	0.	0.
HR S	2 0.	10 0.375	887.	3	10301.50	0.	0.	0.	0.	0.	0.	0.	0.	0.
HR S	3 0.	10 0.250	887.	2	12081.60	0.	0.	0.	0.	0.	0.	0.	0.	0.
HR S	4 0.	10 0.125	887.	1	17060.50	0.	0.	0.	0.	0.	0.	0.	0.	0.
COILS	0.	72 0.125	36.	1	729.00	0.	0.	0.	0.	0.	0.	0.	0.	0.

COST OF FLOW 0.
DREDCALCOST 40000.

TEMPERATURE AT STAGE 400.7 DEG F

ORIGINAL PAGE IS
OF POOR QUALITY

E-4 FAC NETWORK OPTIMIZATION
LARGE PLANT SIZE 352 DISH FIELD
STEAM TEMPERATURE = 529 F
JPL CONVENTIONAL SCHEDULE 80 COST MODEL
COST OF ENERGY = 1500 \$/KW_T

H2O/STEAM 0. \$/LD
SPACING 49.0 60.0 FT
HEIGHT TO COLLECTOR 0.5 FT
OF COLLECTORS N-S 16 E-W 22
INSULATION COST 20.00 \$/LB
MASS FLOW RATE PER UNIT 0.06 LB/SEC
SPECIFIC HEAT HOT 1.1500 COOL 1.0000 BTU/LB-DEG F
CONDUCTIVITY 0.6000 HOT 0.3100 COOL BTU-IN/(FT**2-DEG F-HR)
SOURCE TEMPERATURE 550.0 DEG F AMBIENT TEMP 100.0 DEG F
RETURN TEMPERATURE 70.0 DEG F
DENSITY HOT 0.031 COOL 1.000 GM/CM3
VISCOSITY HOT 0.011 COOL 0.010 STKS
CONVENTIONAL PIPING METHODS SCHEDULED;
INSULATION 1.000 KW/H**2
COLLECTOR DIAM 12. H
COLLECTOR EFFICIENCY 0.6635

	INS	NUM	D	IN	LENG	MASS	PCOST	QTH	CRTH	RT	COF	TOTAL	TOTAL	GRAND
					FT	UNITS	\$	KW	\$	KW		KW	Γ\$	\$
COLLECTOR	3.40	352	0.500		249.	1	6792.73	4.57	6999.25	0.11	325.64	4.78	7324.88	14117.61
FIBER S 1	3.35	44	0.500		3049.	1	82696.80	56.39	84587.48	1.37	3939.04	57.76	88576.53	171273.33
FIBER S 2	3.52	44	0.750		3049.	2	86982.30	59.98	89945.20	2.15	6240.68	62.11	96193.88	183176.18
FIBER S 3	3.71	44	1.000		3049.	3	91843.37	64.42	96630.46	1.89	5496.74	66.31	103127.20	193970.58
FIBER S 4	3.71	44	1.000		3049.	4	91832.11	64.26	96391.22	4.44	12930.75	68.70	109321.97	201154.07
FIBER S 5	3.91	44	1.250		3049.	5	97533.40	69.64	104459.64	1.90	5259.88	71.54	109909.52	207522.92
FIBER S 6	3.91	44	1.250		3049.	6	97521.04	69.55	104318.52	3.26	7504.86	72.81	113023.38	211344.42
FIBER S 7	3.90	44	1.250		3049.	7	97512.13	69.48	104210.48	5.16	15034.90	74.64	112253.46	216765.58
FIBER S 8	4.03	44	1.500		1525.	8	50968.62	36.52	54780.75	1.66	4843.30	38.18	59624.05	110592.67
HIER S 1	4.24	1	2.000		85.	16	3075.26	2.21	3322.41	0.19	555.22	2.41	3877.63	6952.88
HIER S 2	4.62	1	3.000		85.	32	3597.25	2.60	3094.15	0.10	536.76	2.78	4430.91	8028.16
HIER S 3	4.76	1	3.500		85.	48	3835.81	2.75	4127.96	0.28	829.13	3.04	4957.09	8792.90
HIER S 4	4.89	1	4.000		85.	64	4073.64	2.90	4353.80	0.34	1000.17	3.25	5353.97	9427.61
HIER S 5	5.11	1	5.000		85.	80	4858.63	3.21	4815.08	0.20	590.56	3.41	5405.64	10264.27
HIER S 6	5.11	1	5.000		85.	96	4858.35	3.21	4813.76	0.25	1015.69	3.56	5829.45	10687.80
HIER S 7	5.11	1	5.000		85.	112	4858.21	3.21	4812.80	0.55	1507.37	3.76	6420.17	11270.38
HIER S 8	5.30	1	6.000		85.	128	5641.21	3.50	5251.19	0.32	741.36	3.82	6192.55	11833.76
HIER S 9	5.30	1	6.000		85.	144	5641.02	3.50	5250.46	0.46	1336.55	3.96	6587.01	12278.03
HIER S 10	5.30	1	6.000		85.	160	5640.80	3.50	5249.80	0.63	1829.20	4.13	7079.01	12719.81
HIER S 11	5.30	1	6.000		85.	176	5640.53	3.50	5248.98	0.83	2430.07	4.33	7679.05	13319.58
HIER S 12	5.59	1	8.000		85.	192	7165.67	4.02	6033.02	0.25	737.11	4.20	6770.92	13936.60
HIER S 13	5.59	1	8.000		85.	208	7165.47	4.02	6033.25	0.32	935.08	4.34	6968.32	14133.79
HIER S 14	5.59	1	8.000		85.	224	7165.29	4.02	6033.70	0.40	1165.63	4.42	7198.33	14363.63
HIER S 15	5.59	1	8.000		85.	240	7165.14	4.02	6032.02	0.49	1431.26	4.51	7463.28	14620.42
HIER S 16	5.59	1	8.000		85.	256	7165.01	4.02	6031.58	0.60	1734.43	4.62	7766.02	14931.03
HIER S 17	5.59	1	8.000		85.	272	7165.12	4.02	6031.11	0.71	2077.64	4.73	8108.74	15272.07
HIER S 18	5.59	1	8.000		85.	288	7164.96	4.02	6030.38	0.85	2423.35	4.87	8493.74	15650.70
HIER S 19	5.59	1	8.000		85.	304	7165.28	4.02	6029.27	0.99	2894.06	5.01	8923.33	16088.61
HIER S 20	5.59	1	8.000		85.	320	7164.86	4.02	6029.02	1.16	3372.24	5.18	9401.26	16566.13
HIER S 21	5.83	110.000		85.	336	8726.07	4.55	6821.64	9.41	1266.92	4.94	9029.55	16754.63	
HIER S 22	5.83	110.000		14.	352	1454.43	0.76	1137.06	0.88	231.06	0.84	1348.06	2322.49	
							830070.50	570.48	855713.24	35.57	94824.67	603.04	950537.91	1780608.44

COST OF FLUID 0.
INSULATION COST 245559.

TEMPERATURE AT STAKE 527.8 DEG F
HIER S 2 0. 1 4.000 10. 352 280.00
HIER S 3 0. 1 4.000 60. 336 1680.00

0.01 20.26 300.26
0.04 109.82 1789.82
0.03 94.37 1225.37

ORIGINAL PAGE IS OF POOR QUALITY

\$ 54.23/m²

HDNR S 1	4.000	1	7.000	0.02	70.12	0.02	70.12	0.02	70.12	1750.12
HDNR S 2	3.500	1	3.500	0.04	113.99	0.04	113.99	0.04	113.99	1733.99
HDNR S 3	3.500	1	3.500	0.03	95.52	0.03	95.52	0.03	95.52	1715.52
HDNR S 4	3.500	1	3.500	0.03	79.16	0.03	79.16	0.03	79.16	1699.16
HDNR S 5	3.500	1	3.500	0.02	64.77	0.02	64.77	0.02	64.77	1684.77
HDNR S 6	3.000	1	3.000	0.04	110.84	0.04	110.84	0.04	110.84	1670.84
HDNR S 7	3.000	1	3.000	0.03	87.77	0.03	87.77	0.03	87.77	1647.77
HDNR S 8	3.000	1	3.000	0.02	68.13	0.02	68.13	0.02	68.13	1628.13
HDNR S 9	3.000	1	3.000	0.02	51.65	0.02	51.65	0.02	51.65	1611.65
HDNR S 10	3.000	1	3.000	0.01	38.05	0.01	38.05	0.01	38.05	1598.05
HDNR S 11	2.500	1	2.500	0.03	83.19	0.03	83.19	0.03	83.19	1583.19
HDNR S 12	2.500	1	2.500	0.02	56.40	0.02	56.40	0.02	56.40	1556.40
HDNR S 13	2.000	1	2.000	0.03	90.26	0.03	90.26	0.03	90.26	1530.26
HDNR S 14	2.000	1	2.000	0.02	53.07	0.02	53.07	0.02	53.07	1493.07
HDNR S 15	2.000	1	2.000	0.01	27.70	0.01	27.70	0.01	27.70	1467.70
HDNR S 16	1.500	1	1.500	0.02	44.34	0.02	44.34	0.02	44.34	1424.34
HDNR S 17	1.250	1	1.250	0.01	30.85	0.01	30.85	0.01	30.85	1380.85
HDNR S 18	1.000	1	1.000	0.01	18.01	0.01	18.01	0.01	18.01	1329.01
HDNR S 19	0.750	44	0.750	0.05	159.16	0.05	159.16	0.05	159.16	23336.16
HDNR S 20	0.500	44	0.500	0.35	1033.61	0.35	1033.61	0.35	1033.61	46300.61
HDNR S 21	0.500	44	0.500	0.23	660.63	0.23	660.63	0.23	660.63	45936.63
HDNR S 22	0.500	44	0.500	0.13	389.88	0.13	389.88	0.13	389.88	45685.88
HDNR S 23	0.375	44	0.375	0.07	205.13	0.07	205.13	0.07	205.13	45481.13
HDNR S 24	0.250	44	0.250	0.11	328.01	0.11	328.01	0.11	328.01	45065.01
HDNR S 25	0.125	44	0.125	0.20	571.37	0.20	571.37	0.20	571.37	44769.37
COLLECTOR	0.125	352	0.125	0.15	442.31	0.15	442.31	0.15	442.31	44101.31
				0.01	36.11	0.01	36.11	0.01	36.11	3600.11
				1.03	5318.22	1.03	5318.22	1.03	5318.22	378407.21

COST OF FLUID 0.0
INSULATION COST 0.0
SYSTEM DELIVERS 25777. KW AT A COST OF 84.67 \$/KW

**BYE
**CPU = 5.60 units
**cost: \$ 1.04 to date: \$12328.63= 6%
**on at 10.499 - off at 10.661 on 03/20/81

ORIGINAL DESIGN OF POOR QUALITY

E-5 FACG NETWORK OPTIMIZATION
 BASELINE STEOR NETWORK
 72 DISH FIELD
 STEAM TEMPERATURE = 529 °F
 JPL ADVANCED CONSTRUCTION COST MODEL
 COST OF ENERGY = 1500 \$/KW_T

INSULATION 17 → 26
 120/STEAM 0. 4/LB
 SPACING 49.0 60.0 FT
 HEIGHT TO COLLECTOR 0.5 FT
 # OF COLLECTORS HS 3 E-W 9
 INSULATION COST 20.00 4/LB
 MASS FLOW RATE PER UNIT 0.06 LB/SEC
 SPECIFIC HEAT 1.1500 COOL 1.0000 HTU/LB-DEG F
 VISCOSITY 0.6000 HOT 0.3100 COOL HTU-IR/(FT**2-DEG F-IR)
 SURFACE TEMPERATURE 550.0 DEG F AMBIENT TEMP 100.0 DEG F
 DENSITY 70.0 DEG F
 HEAT CAPACITY 0.031 COOL 1.000 GM/CM3
 VISCOSITY HOT 0.011 COOL 0.010 STAS
 APPARENT PIPING HEATLOSS SCHEIDT
 INSULATION 1.000 NB/H442
 COLLECTOR DIAH 12. H
 COLLECTOR EFFICIENCY 0.6635

	INS	RUH	D	LENG	MASS	PEOST	QTH	CRTH	GF	COF	TOTAL	TOTAL	GRAND
			IN	FT	UNITS	\$	KW	\$	KW	\$	KW	KW	TOTAL
COLLECTOR	3.40	72	0.500	51.	1	897.81	0.95	1431.66	0.62	66.61	0.98	1478.27	2396.08
PIPER S	1 3.35	18	0.500	1247.	1	21785.92	23.07	34603.97	0.56	1631.88	23.63	36235.85	53021.77
PIPER S	2 3.52	18	0.750	1247.	2	23129.79	24.53	36795.77	0.80	2556.28	25.41	39352.04	42481.84
PIPER S	3 3.71	18	1.000	1247.	3	24709.13	26.35	39530.64	0.77	2248.67	27.13	41779.31	56498.44
PIPER S	4 3.71	18	1.000	624.	4	12371.45	13.17	19752.88	0.91	2644.93	14.08	22397.81	34769.26
PIPER S	1 4.04	1	1.500	85.	8	1998.54	2.04	3066.66	0.09	269.57	2.14	3336.23	5244.72
PIPER S	2 4.24	1	2.000	85.	16	2090.06	2.22	3327.44	0.12	555.22	2.41	3882.66	5772.72
PIPER S	3 4.43	1	2.500	85.	24	2276.97	2.39	3589.18	0.25	724.62	2.64	4312.80	6649.77
PIPER S	4 4.63	1	3.000	85.	32	2500.66	2.60	3894.46	0.18	526.76	2.78	4435.22	6935.07
PIPER S	5 4.76	1	3.500	85.	40	2683.66	2.76	4143.31	0.17	482.05	2.92	4615.26	7296.92
PIPER S	6 4.76	1	3.500	85.	48	2883.31	2.75	4131.31	0.28	629.13	3.04	4940.44	7643.76
PIPER S	7 4.99	1	4.000	85.	56	2874.98	2.91	4357.94	0.23	672.20	3.14	5030.14	7905.12
PIPER S	8 4.99	1	4.000	85.	64	2874.52	2.90	4355.26	0.24	1000.17	3.25	5356.43	8230.95
PIPER S	9 5.12	1	5.000	14.	72	562.53	0.51	803.29	0.62	71.97	0.56	875.27	1432.93
						103347.46	109.19	161778.67	4.91	14209.85	114.09	178867.73	281317.19

COST OF FLUID 0.
 INSULATION COST 43280.

TEMPERATURE AT	STOR	29.5	DEG F	TEMPERATURE	AT	STOR	29.5	DEG F	TEMPERATURE	AT	STOR	29.5	DEG F
PIPER S	2 0.	1	2.500	10.	72	127.19	0.	0.	0.00	2.62	0.00	2.62	129.90
PIPER S	3 0.	1	2.000	30.	64	742.50	0.	0.	0.01	27.78	0.01	27.78	776.28
PIPER S	4 0.	1	2.000	60.	56	742.50	0.	0.	0.01	18.88	0.01	18.88	761.38
PIPER S	5 0.	1	2.000	60.	48	742.50	0.	0.	0.00	12.11	0.00	12.11	754.61
PIPER S	6 0.	1	1.500	60.	40	721.87	0.	0.	0.01	26.13	0.01	26.13	748.00
PIPER S	7 0.	1	1.500	60.	32	721.87	0.	0.	0.00	13.71	0.00	13.71	735.59
PIPER S	8 0.	1	1.250	60.	24	711.56	0.	0.	0.00	13.43	0.00	13.43	724.99
PIPER S	9 0.	1	1.250	60.	16	711.56	0.	0.	0.00	4.20	0.00	4.20	715.78
PIPER S	10 0.	1	0.750	60.	8	690.94	0.	0.	0.00	8.85	0.00	8.85	699.69
PIPER S	1 0.	18	0.500	441.	4	5002.59	0.	0.	0.01	41.96	0.01	41.96	5044.55
PIPER S	2 0.	18	0.500	882.	3	10005.19	0.	0.	0.01	32.67	0.01	32.67	10042.06
PIPER S	3 0.	18	0.375	882.	2	9929.39	0.	0.	0.01	41.93	0.01	41.93	9971.32
PIPER S	4 0.	18	0.375	882.	1	9853.59	0.	0.	0.01	31.84	0.01	31.84	9885.44
COLLECTOR	0.	72	0.250	36.	1	402.19	0.	0.	0.00	1.30	0.00	1.30	403.49
						41103.45	0.	0.	0.10	281.62	0.10	281.62	41387.67

COST OF FLUID 0.
 INSULATION COST 5204. IN AT A COST OF 61.05 47AM

ORIGINAL PAGE IS
OF POOR QUALITY

E-7 FACCC NETWORK OPTIMIZATION
ALTERNATE PROCESS TEMPERATURE
72 DEISE NETWORK
STEAM TEMPERATURE = 489°F
JPL CONVENTIONAL SCHEDULE 80 COST MODEL
COST OF ENERGY = 500 \$/KW_T

INSULATION #7 - C3
SPACING 49.0 50.0 FT \$/LB
HEIGHT 10 COLLECTOR 0.5 FT
OF COLLECTORS M-S 0 E W 9
INSULATION COST 20.00 \$/LB
MASS FLOW RATE PER UNIT 0.06 LB/SEC
SPECIFIC HEAT HOT 0.9700 COOL 1.0000 BTU/LB-DEG F
CONDUCTIVITY 0.5300 HOT 0.3100 COOL BTU-IN/(FT*2-DEG F-HR)
SOURCE TEMPERATURE 510.0 DEG F AMBIENT TEMP 100.0 DEG F
RETURN TEMPERATURE 70.0 DEG F
DENSITY HOT 0.021 COOL 1.000 GM/CM3
VISCOSITY HOT 0.012 COOL 0.010 SIKS
CONVENTIONAL PIPING METHODS SCHEMRO;
INSULATION 1.000 KW/M*2
COLLECTOR HEAT 12. H
COLLECTOR EFFICIENCY 0.6635

	INS	MUH	D	LENG	MASS	PCOST	QTH	COTH	BF	CRF	TOTAL	TOTAL	GRAND
			IN	FT	UNITS	\$	KW	\$	KW	\$	KW	E\$	\$
COLLECTOR	2.05	72	0.500	51.	1	1200.46	0.96	470.08	0.05	52.97	1.01	531.05	1732.31
FHR S	1 2.01	10	0.500	1247.	1	29306.74	23.09	11544.13	1.34	1297.69	24.43	12841.81	42148.53
FHR S	2 2.11	10	0.750	1247.	2	30447.20	24.72	12361.30	2.10	2033.97	26.82	14395.35	44842.55
FHR S	3 2.22	10	1.000	1247.	3	31709.16	26.84	13420.25	1.84	1707.96	28.68	15208.21	45917.37
FHR S	4 2.34	10	1.250	624.	4	16507.43	14.77	7386.64	0.48	463.00	15.25	7849.64	24457.07
FHR S	1 2.41	1	1.500	85.	8	2337.14	2.13	1064.97	0.22	214.47	2.35	1279.44	3616.58
FHR S	2 2.53	1	2.000	85.	16	2495.89	2.34	1170.98	0.46	442.24	2.80	1613.23	4109.11
FHR S	3 2.74	1	3.000	85.	24	2840.23	2.83	1412.73	0.19	181.41	3.01	1594.14	4434.37
FHR S	4 2.74	1	3.000	85.	32	2839.85	3.02	1410.86	0.44	427.26	3.26	1838.12	4677.97
FHR S	5 2.82	1	3.500	85.	40	3001.84	3.02	1511.31	0.40	383.54	3.42	1894.85	4896.69
FHR S	6 2.88	1	4.000	85.	48	3163.25	3.22	1609.60	0.35	338.06	3.57	1947.66	5110.90
FHR S	7 2.88	1	4.000	85.	56	3163.03	3.22	1600.78	0.55	535.10	3.77	2143.88	5306.91
FHR S	8 2.88	1	4.000	85.	64	3162.80	3.22	1607.82	0.82	796.01	4.04	2404.63	5567.43
FHR S	9 2.88	1	4.000	14.	72	527.25	0.54	267.90	0.19	150.73	0.73	456.63	983.87
						132702.26	113.71	56856.23	9.42	9143.19	123.13	65999.42	198781.69

COST OF FLUID 0.
INSULATION COST 19012.

TEMPERATURE AT STORL	404.3	DEG-F
FHR S	2 0.	1 1.500
FHR S	3 0.	1 1.500
FHR S	4 0.	1 1.500
FHR S	5 0.	1 1.250
FHR S	6 0.	1 1.250
FHR S	7 0.	1 1.250
FHR S	8 0.	1 1.000
FHR S	9 0.	1 0.750
FHR S	10 0.	1 0.500
FHR S	1 0.	18 0.375
FHR S	2 0.	18 0.375
FHR S	3 0.	18 0.250
FHR S	4 0.	18 0.125
COLLECTOR	0.	72 0.175

COST OF FLUID 0.
INSULATION COST 19012.
SYSTEM DELIVERS 5270. KW AT A COST OF 52.36 \$/KW
CAPITAL COST/KW = 39.43 CAPITAL COST/HR = 25.52

166

INPUT CONVECTION #Y = C4

E-8 FACN NETWORK OPTIMIZATION
 ALTERNATE PROCESS TEMPERATURE
 72 DISH NETWORK
 STEAM TEMPERATURE = 355°F
 CONVENTIONAL SCHEDULE 80 COST MODEL
 COST OF ENERGY = 500 \$/KW_E

SPACING 49.0 \$/LD
 HEIGHT TO COLLECTOR 60.0 FT
 # OF COLLECTORS N-S 8 E-W 9
 INSULATION COST 20.00 \$/LB
 MASS FLOW RATE PER UNIT 0.06 LB/SEC
 SPECIFIC HEAT HOT 0.6300 COOL 1.0000 BTU/LB-DEG F
 CONDUCTIVITY 0.4700 HOT 0.3100 COOL (FT**2-DEG F-HR)
 SOURCE TEMPERATURE 300.0 F AMBIENT TEMP 100.0 DEG F
 RETURN TEMPERATURE 70.0 F
 DENSITY HOT 0.007 COOL 1.500 GM/CM³
 VISCOSITY HOT 0.025 COOL 0.010 ST.²
 CONVENTIONAL PIPING METHODS SCHEDULE 80
 INSULATION 1.000 KW/M**2
 COLLECTOR DIAH 12. H
 COLLECTOR EFFICIENCY 0.6535

INS	NUM	IF	LENG	MASS	PCOST	QTH	CATH	QF	CRF	TOTAL	GRAND TOTAL
			FT	UNITS	\$	KW	\$	KW	\$	KW	\$
COLLECTOR	1.78	72	0.750	1	1206.06	0.69	347.49	0.10	93.97	0.79	441.45
FIBER S	1.72	10	0.750	1	29410.82	16.61	8306.06	2.37	2302.23	18.98	1647.51
FIBER S	2.19	10	1.250	2	31735.89	19.73	9863.33	1.68	1051.32	20.81	40019.11
FIBER S	3.19	10	1.500	3	32775.23	20.80	10409.80	1.57	1519.32	22.37	42650.54
FIBER S	4.19	18	1.500	4	16402.14	10.38	5189.67	1.84	1764.44	12.22	44395.84
FIBER S	5.19	1	2.500	8	2516.39	1.73	866.10	0.20	195.23	1.93	2337.62
FIBER S	6.19	1	3.500	16	2816.26	2.05	1026.21	0.23	233.79	2.28	3577.73
FIBER S	7.19	1	4.000	24	2958.85	2.19	1093.49	0.39	337.85	2.58	4046.26
FIBER S	8.19	1	4.000	32	2957.77	2.18	1090.41	0.93	900.77	3.11	4435.20
FIBER S	9.19	1	5.000	40	3543.87	2.47	1236.33	0.55	531.07	3.02	4948.95
FIBER S	10.19	1	5.000	85	3543.87	2.47	1234.54	0.94	914.75	3.41	5313.07
FIBER S	11.19	1	6.000	56	4129.80	2.75	1376.43	0.59	570.00	3.34	5693.15
FIBER S	12.19	1	6.000	64	4129.47	2.75	1375.32	0.87	847.80	3.62	6076.31
FIBER S	13.19	1	6.000	72	688.30	0.46	229.16	0.21	200.62	0.67	6352.59
FIBER S	14.19	1	6.000	72	138814.80	0.46	229.16	0.21	200.62	0.67	1118.00
COST OF FLUID										99.14	55154.31
INSULATION COST											193969.11

ORIGINAL PAGE IS
 OF POOR QUALITY

TEMPERATURE AT STORE	349.9	DEG-F	TEMPERATURE AT STORE	349.9	DEG-F
FIBER S	2.0	10	72	230.00	0.01
FIBER S	3.0	60	64	1380.00	0.04
FIBER S	4.0	60	56	1300.00	0.03
FIBER S	5.0	60	40	1350.00	0.04
FIBER S	6.0	60	32	1350.00	0.02
FIBER S	7.0	60	32	1350.00	0.01
FIBER S	8.0	60	24	1320.00	0.02
FIBER S	9.0	60	16	1290.00	0.02
FIBER S	10.0	60	8	1280.00	0.02
FIBER S	11.0	441	4	9150.75	0.06
FIBER S	12.0	802	3	18301.50	0.05
FIBER S	13.0	802	2	10001.00	0.05
FIBER S	14.0	802	1	17060.50	0.09
COLLECTOR	0	36	1	729.00	0.07
COLLECTOR	0	36	1	75032.75	0.46

COST OF FLUID 0.
 INSULATION COST 5292. KW AT A COST OF 51.14 \$/KW
 SYSTEM DELIVERS 40.41 CAPITAL COST/HR = 26726
 CAPITAL COST/KW = 40.41 CAPITAL COST/HR = 26726

#FRN

INPUT IRRADIATION #7 = CL.

E-9 FAC NETWORK OPTIMIZATION
 LARGE PLANT SIZE 352 DISH FIELD
 STEAM TEMPERATURE = 529 F
 JPL CONVENTIONAL SCHEDULE 80 COST MODEL
 COST OF ENERGY = 500 \$/KW_T

H2O/STEAM 49.0 60.0 FT \$/L/D
 SPACING 49.0 60.0 FT
 HEIGHT TO COLLECTOR 0.5 FT
 # OF COLLECTORS N-S 16 E-W 22
 INSULATION COST 20.00 \$/L/D
 MASS FLOW RATE PER UNIT 0.06 LB/SEC
 SPECIFIC HEAT HOT 1.1500 COOL 1.0000 BTU/LB-DEG F
 CONDUCTIVITY 0.6000 HOT 0.3100 COOL BTU-IN/(FT*2-DEG F-HR)
 SOURCE TEMPERATURE 550.0 DEG F AMBIENT TEMP 100.0 DEG F
 RETURN TEMPERATURE 70.0 DEG F
 DENSITY HOT 0.031 COOL 1.000 GM/CM3
 VISCOSITY HOT 0.011 COOL 0.010 STKS
 CONVENTIONAL PIPING METHODS SCHEDULE 80
 INSULATION 2.000 KW/HR*2
 COLLECTOR DIAM 12.0 H
 COLLECTOR EFFICIENCY 0.6635

INS	NUM	D	IN	LENG	MASS	PCOST	QTH	CRTH	QF	COF	TOTAL	TOTAL	GRAND
				FT	UNITS	\$	KW	\$	KW	\$	KW	E\$	\$
COLLECTOR	3	12	0.375	249.	1	5806.64	5.19	2596.03	0.43	417.24	5.62	3013.30	8819.94
FIBER S	1	2.00	44	0.375	3049.	1	709037.00	313407.66	5.27	5111.24	67.95	35451.90	107354.99
FIBER S	2	2.30	44	0.750	3049.	2	75000.51	36160.00	2.15	2002.89	74.48	30251.69	114052.20
FIBER S	3	2.30	44	0.750	3049.	3	75797.35	36000.68	7.10	6964.75	79.18	42965.43	110762.78
FIBER S	4	2.42	44	1.000	3049.	4	79091.58	39098.42	4.44	4310.25	82.64	43408.67	122500.24
FIBER S	5	2.42	44	1.000	3049.	5	79687.37	39026.36	0.63	8379.27	86.69	47405.64	126493.01
FIBER S	6	2.55	44	1.250	3049.	6	82859.35	42790.25	3.26	3168.29	88.84	45958.53	120817.09
FIBER S	7	2.55	44	1.250	3049.	7	82052.54	42733.15	3.16	5011.55	90.63	47744.82	130527.33
FIBER S	8	2.55	44	1.250	1525.	8	41440.66	21339.16	3.04	3729.47	46.58	25098.63	66539.30
HBR S	1	2.76	1	2.000	85.	16	2561.03	1309.22	0.19	105.07	3.97	1574.29	4135.32
HBR S	2	3.00	1	3.000	85.	32	2926.62	1666.45	0.18	178.92	3.52	1845.37	4771.99
HBR S	3	3.08	1	3.500	85.	48	3097.79	1781.42	0.20	276.38	3.85	2057.00	5155.50
HBR S	4	3.15	1	4.000	85.	64	3268.90	1893.69	0.34	333.39	4.13	2227.08	5495.98
HBR S	5	3.15	1	4.000	85.	80	3268.74	1892.80	0.67	648.17	4.45	2540.96	5809.71
HBR S	6	3.15	1	4.000	85.	96	3268.44	1892.09	1.15	1116.55	4.93	3008.64	6277.00
HBR S	7	3.28	1	4.000	85.	112	3913.48	2124.72	0.55	535.79	4.80	2660.51	6573.99
HBR S	8	3.28	1	4.000	85.	120	3913.36	2124.25	0.82	797.70	5.07	2921.95	6835.32
HBR S	9	3.39	1	5.000	85.	144	3913.42	2123.76	1.17	1133.46	5.42	3257.22	7170.64
HBR S	10	3.39	1	5.000	85.	160	4558.64	2347.10	0.63	609.73	5.32	2956.84	7515.47
HBR S	11	3.39	1	6.000	85.	176	4558.57	2346.73	0.83	810.02	5.53	3156.75	7715.27
HBR S	12	3.39	1	6.000	85.	192	4558.30	2346.46	1.08	1049.96	5.77	3396.41	7954.80
HBR S	13	3.39	1	6.000	85.	208	4558.18	2345.03	1.37	1333.12	6.07	3679.15	8237.33
HBR S	14	3.39	1	6.000	85.	224	4557.74	2345.91	1.71	1663.09	6.41	4009.00	8566.74
HBR S	15	3.39	1	6.000	85.	240	4557.76	2345.42	2.11	2043.44	6.80	4308.07	8946.63
HBR S	16	3.55	1	8.000	85.	256	5926.59	2750.97	0.60	578.14	6.10	3329.12	9155.71
HBR S	17	3.55	1	8.000	85.	272	5926.48	2750.67	0.71	692.55	6.21	3443.22	9269.70
HBR S	18	3.55	1	8.000	85.	288	5926.38	2750.39	0.85	821.12	6.35	3571.51	9397.89
HBR S	19	3.55	1	8.000	85.	304	5926.29	2750.14	0.99	964.69	6.49	3714.83	9541.12
HBR S	20	3.55	1	8.000	85.	320	5926.21	2749.96	1.16	1124.08	6.66	3874.04	9700.24
HBR S	21	3.55	1	8.000	85.	336	5925.61	2750.25	1.34	1300.13	6.84	4050.38	9875.99
HBR S	22	3.55	1	8.000	14.	352	970.98	450.38	0.26	249.94	1.17	707.32	1678.30
COST OF FIBER 0.													
IRRADIATION COST 113801.													
TEMPERATURE AT STAKE 523.1 DEG-F													
HBR S	2	0.	1	3.500	10.	352	270.00	0.	0.01	13.45	0.01	13.45	203.45
HBR S	3	0.	1	3.500	50.	336	1620.00	0.	0.07	70.45	0.07	70.45	1670.45
HBR S	4	0.	1	3.500	50.	320	1620.00	0.	0.06	61.00	0.06	61.00	1581.00
HBR S	5	0.	1	3.000	50.	304	1560.00	0.	0.12	112.92	0.12	112.92	1622.92

ORIGINAL PAGE
 OF POOR QUALITY

