

RTR 218 - 01

CONTENTS

APPENDIX 3: NLS Cycle 1 and NLS 2 Base Heating Technical Notes

- "Preliminary Cycle 1 NLS Base Heating Environments" SEPTEMBER 13, 1991
- "Cycle 1 NLS Base Heating Environments" JANUARY 24, 1992
- "NLS 2 650K STME Base Heating Environments" AUGUST 7, 1992

(NASA-CR-192454) NLS CYCLE 1 AND  
 NLS 2 BASE HEATING TECHNICAL NOTES.  
 APPENDIX 3: PRELIMINARY CYCLE 1 NLS  
 BASE HEATING ENVIRONMENTS. CYCLE 1  
 NLS BASE HEATING ENVIRONMENTS. NLS  
 2 650K STME BASE HEATING  
 ENVIRONMENTS (Remtech) 174 p

N93-22012

Unclass

G3/20 0148121

( 0 ) ( 2 )  
 CN22  
 TURNER J/PUBLICATION  
 MARSHALL SPACE FLIGHT CENTER  
 HUNTSVILLE AL.

DEFITIONS OR CHANGES 544-4494  
 RETURN ADDRESS CN22D 000002444

## REMTECH TECHNICAL NOTE

---

**SUBJECT:** Preliminary Cycle 1 NLS Base Heating Environments

**DATE:** September 13, 1991

**AUTHORS:** Robert L. Bender and John E. Reardon

**CONTRACT NO.:** NAS8-38141

**PREPARED FOR:** Marshall Space Flight Center ED33

---

### INTRODUCTION

A preliminary analysis of National Launch System ascent plume induced base heating environments has been completed to support the Induced Environments Panel's objective to assist in maturing the NLS vehicle (1.5 stage and HLLV) design. Environments during ascent have been determined from this analysis for a few selected locations on the engine nozzles and base heat shield for both vehicles. The environments reflect early summer 1991 configurations and performance data and conservative methodology. A more complete and thorough analysis is under way to update these environments for the Cycle 1 review in January 1992.

### INPUTS

HLLV and 1.5 stage base configuration data were provided by MSFC PD-24 in a NLS data package dated April 12, 1991. The pertinent base geometry dimensions are reproduced in this report as Figs. 1 through 3.

NLS performance data and STME/ASRM motor nozzle data were also provided by MSFC in an April 23, 1991, data package and are summarized in Fig. 4. Chamber pressure histories for the core main engines and boosters are shown in Fig. 5.

The HLLV and 1.5 stage vehicle trajectories were prepared by MSFC EP55 and transmitted to REMTECH May 10, 1991. These were preliminary engine out trajectories based upon the assumptions listed in Fig. 6. Time-altitude plots from these trajectories are shown in Fig. 7.

### BODY POINT SELECTION

This was a preliminary study performed on short notice so the body points were limited to two per vehicle. The criteria for selecting the points was to choose a location on the engine nozzle and a location on the base heat shield where base heating would be most severe. For the HLLV the nozzle point was located on the STME aft lip at an angular position which has maximum view of the ASRM plume. The heat shield location

was the center of the core vehicle base, assuming the shield was located approximately 150 in. forward of the nozzle exit plane.

For the 1.5 stage reference vehicle, the heat shield point was between outboard engines and the nozzle point was on one center engine nozzle lip facing the other center engine nozzle. The six pack 1.5 stage vehicle points were selected between a four engine cluster on the heat shield, and on one center engine nozzle lip facing across the base toward the opposed center engine. The body points selected for this study are displayed in Fig. 8.

## METHODOLOGY

Ascent base heating is a combination of plume radiation and convection occurring when plume gases are recirculated into the base. Both heating modes are basically a function of altitude, with flight-time effects also entering through variations in engine thrust. Radiation occurs throughout ascent and is often a maximum at lift-off, usually decreases with altitude, and may exhibit spikes (increases) when gas recirculation occurs or during engine shutdown. Recirculated gas convection is initiated in multiple engine launch vehicles such as the NLS at higher altitudes when large plume expansions and plume interactions occur. Once initiated, base convection normally continues to increase with altitude until a mass exchange balance is achieved in the base (often referred to as choked base flow); at that altitude and above, the convective heating remains constant.

Infrared radiation from the rocket exhaust plumes varies strongly with surface position as the view of the plumes and shading by other surfaces change. In contrast, the convective heating environment resulting from reversed plume boundary layer gases is specified as relatively constant over zones. The choice of propellants and operating conditions of the engines are important to both components of base heating because they dictate (1) the thermochemistry of the exhaust products which either radiate or are reversed into the base, and (2) transport properties which determine the fundamental processes for energy exchange in the base. Specific adaptations of the general base heating methodology to the NLS vehicles are summarized in the following discussion.

## PLUME RADIATION

Plume radiation estimates were made by scaling available plume data to approximate the STME plumes and by modifying Cycle 1 ASRM methodology for the ASRM plumes. The procedures used for each plume source are described in this subsection.

The STME plumes were approximated using similar O<sub>2</sub>/H<sub>2</sub> plumes previously generated for the Advanced Launch System studies ( $Re=52.4$ ,  $P_c=2250$  psia,  $O/F=6.0$ , and  $A/A^*=60$ ). These plumes have an exit pressure below that of the  $A/A^*=45$  engines on the NLS vehicles, so it was necessary to compensate for this by scaling the plume size, pressure, and temperature to simulate the size and properties required for the NLS. The scaled plumes approximated STME plumes at altitude pressures ranging from below sea level to 190 kft. The radiation rates predicted using the scaled plumes were plotted and the resulting functions of altitude pressure were interpolated at the correct altitude

pressures to obtain STME rates from sea level to 160 kft. It was assumed that the base pressure, plume shapes, and plume radiation above 160 kft are constant.

Because the plume predictions were made using simple axisymmetric plumes, it was necessary to approximate effects anticipated as a result of two characteristics which were not modeled: shock regions between the plumes at high altitudes and turbine exhaust injection into the nozzle.

Although the shock regions between plumes represent a significant fraction of the radiation source at high altitude, the overall high altitude radiation is relatively low because of the very low temperatures and pressures in the balance of the combined plume. The difference between axisymmetric plumes and the true 3-D plume at high altitude were estimated for NLS stages based on experience from the Saturn S-II and Shuttle SSME.

The effect of afterburning and base burning can be a significant radiation and convection source, but there is no experience with these effects for a vehicle with O<sub>2</sub>/H<sub>2</sub> propellants. The contribution of these sources for the NLS vehicles were predicted based on estimates of the increase in radiation resulting from afterburning and estimates from characteristics of turbine exhaust reversal and base burning on Saturn S-IC.

The Cycle 1 ASRM methodology was used to predict the radiation source at sea level and at the shutdown spike, but the altitude adjustment function was reduced based on estimates of two effects: differences in plumes caused by the powered center body and attenuation of ASRM radiation by the STME plumes.

The Shuttle Cycle 1 ASRM altitude adjustment function (which describes the ratio of altitude to sea-level radiation) was extrapolated from the empirically determined RSRM altitude adjustment which was based primarily on measurements in the ET base region. The altitude adjustment function increases from 1.0 to 1.3 during the first 10 kft of ascent and indicates significant radiation from reversed gases in the 90 to 120 kft range. These effects appear to be caused in some part by the expansion of the plume into the ET base region, and these same effects are not expected to be seen in the HLLV vehicle because STME plume flow will occupy the center of the base. As a result, the altitude adjustments for the HLLV were reduced slightly from those used for the Shuttle ASRM Cycle 1 predictions.

The combined STME and ASRM radiation were predicted separately using different methodologies and then added to determine the plume radiation environment for the HLLV. This procedure does not recognize the attenuation of the ASRM plume radiation by the STME plumes, so an estimated adjustment was made to account for STME plume absorption. As the ASRM methodology is developed, it is anticipated that this effect can be modeled more realistically.

## PLUME-INDUCED CONVECTION

Convective heating from recirculated plume gases is not determined by a rigorous computational procedure or computer code, but relies on judicious scaling and application of existing flight and model data. For this study, which considered the STME LO<sub>2</sub>/LH<sub>2</sub>

The study did not address plume induced flow separation which will likely ingest hot plume recirculated gases into the separated region along the tank sidewall of the core stage. Heating in the PIFS region is less severe than the normal base heating to the engines and heat shield, but has not been quantified in this analysis.

**PRECEDING PAGE BLANK NOT FILMED**




Figure 1: In-Line HLLV Reference Base Geometry




Figure 2: 1.5 Stage Reference Base Geometry




Figure 3: 1.5 Stage Six-Pack Base Geometry



● STME

Propellants:	LO <sub>2</sub> /LH <sub>2</sub>
Mixture Ratio:	6.0
Throat Diameter:	13.1 inches (ID)
Expansion Ratio:	45:1
Nozzle Exit Diameter:	87.8 inches (ID)
Chamber Pressure:	2250 psia

● ASRM

Propellants:	19% Aluminum 69% Amonium Perchlorate 9% HTPB
Throat Diameter:	54.48 inches
Expansion Ratio:	7.54:1
Nozzle Exit Diameter:	149.64 inches
Chamber Pressure:	Variable (See next chart)

Figure 4: STME and ASRM Performance Data




Figure 5: STME and ASRM Chamber Pressure Histories

### HLLV TRAJECTORY

— NEW ED35 AERO DATA 3/2  
6/91 — HLLV W/ASRM 4g cons  
DEG TO 220 X 30 with 4  
10-APR-1991 12:59:52.61

Input File: DISK\$USER5: [MASTRE.OPG.HLLV.MARCUS]HLLV5FT\_4G.DAT;11  
Output File: DISK\$USER5: [MASTRE.OPG.HLLV.MARCUS]HLLV5FT\_4G.OPG;12  
Plot File: DISK\$USER5: [MASTRE.OPG.HLLV.MARCUS]HLLV5FT\_4G.PLT;12  
Scratch File: DISK\$USER5: [MASTRE.OPG.HLLV.MARCUS]HLLV5FT\_4G.ASC;12

### 1.5 STAGE TRAJECTORY

@ 400K' — STAGE 1.5 — 4  
0:1 — 6.0:1 — STANDARD ET  
10-MAY-1991 09:03:24.68

Input File: DISK\$USER5: [MASTRE.OPG.STAGE.DAVE]S24C3A.DAT;1  
Output File: DISK\$USER5: [MASTRE.OPG.STAGE.DAVE]S24C3A.OPG;2  
Plot File: DISK\$USER5: [MASTRE.OPG.STAGE.DAVE]S24C3A.PLT;2  
Scratch File: DISK\$USER5: [MASTRE.OPG.STAGE.DAVE]S24C3A.ASC;2

Figure 6: HLLV and 1.5 Stage Preliminary Trajectory Descriptions




Figure 7: Preliminary Trajectory Time-Altitude Comparisons




Figure 8: Body Points Selected for Analysis




Figure 9: HLLV Radiative Base Heating Environments




Figure 10: HLLV Convective Base Heating Environments




Figure 11: 1.5 Stage Reference Radiative Base Heating Environments






Figure 13: 1.5 Stage Six-Pack Radiative Base Heating Environments





Figure 14: 1.5 Stage Six-Pack Convective Base Heating Environments



## REMTECH TECHNICAL NOTE

---

**SUBJECT:** Cycle 1 NLS Base Heating Environments  
**DATE:** January 24, 1992  
**AUTHORS:** Robert L. Bender, Maurice J. Prendergast, and John E. Reardon  
**CONTRACT NO.:** NAS8-38141  
**PREPARED FOR:** Marshall Space Flight Center ED33

---

### INTRODUCTION

Preliminary NLS Cycle 1 base heating environments have been previously reported in Refs. [1,2]. The environments reported in those references represented early efforts to quantify the base heating for a few selected points in the base region. Both HLLV and 1.5 Stage vehicles were considered. In recent months an intensive effort has been under way to better understand and quantify the additional base heating resulting from burning of the STME turbine exhaust discharge gases. Improved plume models have also been developed to improve plume radiation predictions. Additional body points in the base region were also considered to assist the TPS designers and STPT engine thermal analysts. In addition, the analyses reflect trajectories tailored to maximize base heating and operational parameters such as throttling and engine out which are part of the latest reference mission. The environments presented in this technical note reflect conservative assumptions and methodology and are representative of typical preliminary design estimates.

### INPUTS

The base configurations for the HLLV and 1.5 Stage vehicles shown in Figs. 1 and 2 were provided by MSFC in the NLS System Definition data package dated May 31, 1991 [3]. General design information specifying the shape and location of proposed base heat shield and STME heat shields was extracted from Boeing presentation material [4] updated by the telephone conversation with Keith Luschei [5] of the Boeing Defense and Space Group. Configuration data defining the ASRB utilized on the HLLV was extracted from Refs. [6-8]. Similar information describing the STME was provided by the STPT in an engine characteristics description package [9].

The HLLV and 1.5 Stage vehicle trajectories were prepared by MSFC EP55 and reported in Refs. [10,11], respectively. The trajectories reflect long-burn-time exposure to heating which is accomplished through  $3\sigma$  low ASRM and STME thrust dispersions. HLLV trajectories also reflect one STME out from lift-off; 1.5 Stage trajectories include STME throttling in the 40 to 120 second time interval.






Figure 1: NLS HLLV Base Configuration



HLLV  
VIEW A - A

Figure 1: (Continued) NLS HLLV Base Configuration



HLLV  
VIEW B - B

Figure 1: (Concluded) NLS HLLV Base Configuration




Figure 2: NLS 1.5 Stage Base Configuration






Figure 2: (Continued) NLS 1.5 Stage Base Configuration




Figure 2: (Continued) NLS 1.5 Stage Base Configuration




Figure 3: HLLV Body Points Selected for Base Heating Analysis

REMTECH

RTN 218-04




Figure 4: 1.5 Stage Body Points Selected for Base Heating Analysis




Figure 5: Radiation and Total Base Heating —  
HLLV Core Base Heat Shield Body Point 101




Figure 6: Radiation and Total Base Heating —  
HLLV Core Base Heat Shield Body Point 102




Figure 7: Radiation and Total Base Heating —  
HLLV Core Base Heat Shield Body Point 103




Figure 9: Radiation and Total Base Heating —  
HLLV Core Base Heat Shield Body Point 105






Figure 10: Radiation and Total Base Heating —  
HLLV Core Base Heat Shield Body Point 106




Figure 11: Radiation and Total Base Heating — HLLV STME Heat Shield Body Point 107




Figure 12: Radiation and Total Base Heating — HLLV STME Heat Shield Body Point 108




Figure 13: Radiation and Total Base Heating —  
HLLV ASRB Skirt Trailing Edge Body Point 109




Figure 14: Radiation and Total Base Heating —  
HLLV ASRB Skirt Trailing Edge Body Point 110




Figure 15: Radiation and Total Base Heating — HLLV STME Nozzle Exit Body Point 111




Figure 17: Radiation and Total Base Heating — HLLV STME Nozzle Exit Body Point 113




Figure 18: Radiation and Total Base Heating — HLLV STME Nozzle Exit Body Point 114






Figure 19: Radiation and Total Base Heating — HLLV ASRB Nozzle Exit Body Point 115




Figure 20: Radiation and Total Base Heating — HLLV ASRB Nozzle Exit Body Point 116




Figure 21: Radiation and Total Base Heating —  
1.5 Stage Core Base Heat Shield Body Point 201




Figure 22: Radiation and Total Base Heating —  
1.5 Stage Core Base Heat Shield Body Point 202




Figure 23: Radiation and Total Base Heating —  
1.5 Stage Core Base Heat Shield Body Point 203




Figure 24: Radiation and Total Base Heating —  
1.5 Stage Core Base Heat Shield Body Point 204




Figure 25: Radiation and Total Base Heating — 1.5 Stage Inboard STME Heat Shield Body Point 205




Figure 26: Radiation and Total Base Heating — 1.5  
Stage Inboard STME Heat Shield Body Point 206






Figure 27: Radiation and Total Base Heating — 1.5 Stage Outboard STME Heat Shield Body Point 207




Figure 28: Radiation and Total Base Heating — 1.5 Stage Inboard STME Nozzle Exit Body Point 208




Figure 29: Radiation and Total Base Heating — 1.5 Stage Inboard STME Nozzle Exit Body Point 209




Figure 30: Radiation and Total Base Heating — 1.5 Stage Outboard STME Nozzle Exit Body Point 210




Figure 31: Radiation and Total Base Heating — 1.5 Stage Outboard STME Nozzle Exit Body Point 211




Figure 32: Radiation and Total Base Heating — 1.5 Stage Outboard STME Nozzle Exit Body Point 212

Table 1: HLLV and 1.5 Stage Body Point Location Definitions

HLLV					
Location	B.P.	Facing Direction	X (in)	Y (in)	Z (in)
Heat Shield	101	Aft (+X)	4393.6	.0	.0
	102			.0	58.5
	103			.0	117.0
	104			- 41.4	41.4
	105			- 58.5	.0
	106	↓	↓		-117.0
STME Heat Shield	107	Aft (+X)	4453.1	- 88.0	88.0
	108	Aft (+X)	4453.1	-146.0	88.0
ASRB Aft Skirt Trailing Edge	109	+Y	4465.6	-146.4	.0
	110	YZ*	↓	-176.9	73.6
STME Nozzle Exit	111	YZ	4535.0	- 84.8	84.8
	112	-Z		-117.0	71.5
	113	YZ*		-149.2	84.8
	114	-Y	↓	-162.5	117.0
ASRB Nozzle Exit	115	+Y	4535.0	-174.4	0.0
	116	YZ*	↓	-196.7	53.8

1.5 Stage					
Location	B.P.	Facing Direction	X (in)	Y (in)	Z (in)
Heat Shield	201	Aft (+X)	4393.6	.0	.0
	202			- 58.5	.0
	203			-117.0	.0
	204	↓	↓	- 58.5	89.8
STME Heat Shield	205	Aft (+X)	4453.1	.0	21.6
	206			- 37.2	79.9
	207	↓	↓	- 79.8	99.8
STME Nozzle	208	-Z	4535.0	.0	17.1
	209	YZ*		- 41.3	81.8
	210	+Y		- 71.5	117.0
	211	YZ		- 75.8	97.8
	212	-Z	↓	-117.0	71.5

\* Unit Normal Parallel to Y-Z Plane

Table 2: HLLV Radiation Environments

TOTAL PLUME RADIATION FOR:  
 HLLV Environment with an STME Out (Margins ME=1.20 DE=1.25)  
 HLLV STME Altitude Adjustment From 1000  
 HLLV Cycle 1 Radiation Trajectory Booster Adjustment  
 HLLV STME Altitude Adjustment From 1000  
 HLLV STME Altitude Adjustment From 1000

Alt (kft)	Time* (sec)	101	102	103	104	105	106	107	100	111	112	113	114
0.	0.0	26.52	25.56	20.51	25.48	25.65	21.24	23.69	21.08	17.27	20.83	33.39	17.59
0.	5.0	26.36	25.41	20.39	25.32	25.49	21.12	23.54	20.93	17.16	20.69	33.13	17.45
1.	10.0	27.21	26.22	21.01	26.15	26.31	21.77	24.33	21.75	17.71	21.43	34.57	18.27
1.	12.0	28.11	27.08	21.66	27.02	27.17	22.46	25.16	22.59	18.29	22.21	36.05	19.12
2.	14.0	29.22	28.13	22.47	28.10	28.23	23.31	26.17	23.63	19.00	23.17	37.88	20.16
2.	15.0	29.85	28.74	22.93	28.71	28.84	23.79	26.76	24.22	19.41	23.71	38.93	20.75
2.	16.0	29.98	28.86	23.01	28.85	28.97	23.88	26.89	24.41	19.48	23.85	39.29	20.98
3.	18.0	29.75	28.63	22.79	28.64	28.73	23.66	26.71	24.36	19.27	23.70	39.35	21.10
4.	20.0	28.79	27.70	22.02	27.72	27.80	22.88	25.86	23.66	18.59	22.93	38.29	20.59
4.	22.0	27.58	26.54	21.08	26.57	26.63	21.90	24.79	22.73	17.74	21.95	36.83	19.86
6.	25.0	26.56	25.54	20.25	25.60	25.64	21.06	23.91	22.06	16.97	21.13	35.86	19.45
9.	30.0	26.10	25.08	19.75	25.18	25.18	20.61	23.55	22.00	16.64	20.93	35.11	19.74
12.	35.0	25.76	24.73	19.45	24.87	24.83	20.28	23.29	21.99	16.40	20.80	36.38	20.02
16.	40.0	25.50	24.48	19.19	24.64	24.57	20.03	23.10	21.96	16.19	20.66	36.51	20.18
20.	45.0	24.64	23.64	18.51	23.82	23.74	19.33	22.34	21.34	15.62	20.02	35.60	19.74
24.	50.0	23.55	22.59	17.65	22.78	22.69	18.45	21.38	20.52	14.95	19.22	34.37	19.11
29.	55.0	22.94	21.99	17.15	22.20	22.09	17.94	20.84	20.11	14.57	18.81	33.83	18.86
34.	60.0	22.57	21.63	16.84	21.85	21.73	17.62	20.53	19.93	14.36	18.61	33.67	18.83
40.	65.0	21.73	20.83	16.18	21.05	20.92	16.94	19.79	19.28	13.85	18.00	32.69	18.31
46.	70.0	20.92	20.05	15.55	20.28	20.13	16.29	19.08	18.67	13.36	17.42	31.78	17.84
52.	75.0	19.65	18.82	14.57	19.05	18.90	15.27	17.93	17.63	12.58	16.44	30.13	16.96
59.	80.0	18.46	17.68	13.68	17.91	17.76	14.34	16.86	16.61	11.83	15.49	28.43	16.01
66.	85.0	17.29	16.56	12.82	16.77	16.63	13.44	15.78	15.53	11.09	14.49	26.55	14.96
73.	90.0	17.19	16.46	12.74	16.66	16.53	13.36	15.70	15.39	11.21	14.52	26.26	14.76
81.	95.0	19.76	18.91	14.64	19.16	19.00	15.34	18.11	17.64	13.42	17.06	30.00	16.79
89.	100.0	20.67	19.78	15.32	20.04	19.87	16.05	18.88	18.43	13.88	17.72	31.40	17.59
90.	105.0	19.89	19.04	14.75	19.28	19.12	15.45	18.10	17.64	13.24	16.93	30.05	16.85
107.	110.0	18.47	17.68	13.72	17.90	17.76	14.35	16.73	16.27	12.20	15.60	27.69	15.53
116.	115.0	14.91	14.28	11.11	14.44	14.34	11.61	13.39	12.91	9.77	12.43	21.87	12.26
125.	120.0	11.19	10.72	8.33	10.84	10.77	8.72	10.19	9.92	7.20	9.33	16.84	9.47
134.	125.0	9.38	8.99	7.01	9.08	9.03	7.33	8.53	8.25	6.04	7.78	13.94	7.83
144.	130.0	7.70	7.38	5.77	7.44	7.41	6.03	6.98	6.70	4.97	6.35	11.25	6.31
149.	133.0	7.15	6.87	5.37	6.92	6.89	5.61	6.49	6.20	4.62	5.89	10.39	5.82
151.	134.0	11.84	11.35	8.81	11.48	11.40	9.23	10.79	10.54	7.65	9.97	17.96	10.10
153.	135.0	18.06	17.30	13.37	17.52	17.37	14.02	16.50	16.30	11.66	15.26	28.00	15.77
155.	136.0	22.77	21.79	16.81	22.10	21.89	17.65	20.82	20.66	14.70	19.30	35.59	20.06
156.	137.0	22.77	21.79	16.81	22.10	21.89	17.65	20.82	20.66	14.70	19.30	35.59	20.06
150.	138.0	20.47	19.59	15.13	19.86	19.68	15.87	18.71	18.53	13.22	17.32	31.88	17.97
160.	139.0	17.33	16.60	12.83	16.82	16.67	13.46	15.83	15.63	11.20	14.64	26.84	15.12
162.	140.0	14.21	13.61	10.54	13.78	13.67	11.05	12.96	12.74	9.18	11.96	21.79	12.27
167.	140.3	13.39	12.83	9.94	12.98	12.89	10.42	12.22	11.98	8.66	11.26	20.48	11.52
169.	144.3	0.88	0.87	0.78	0.82	0.87	0.78	0.73	0.40	0.59	0.53	0.30	0.12
170.	150.0	0.88	0.87	0.78	0.82	0.87	0.78	0.73	0.40	0.59	0.53	0.30	0.12
161.	432.6	0.88	0.87	0.78	0.82	0.87	0.78	0.73	0.40	0.59	0.53	0.30	0.12
Heat Load		3215.15	3092.65	2451.79	3098.94	3104.26	2549.45	2892.99	2667.82	2082.73	2501.91	4345.12	2388.44



Table 3: HLLV Radiation Environments

TOTAL PLUME RADIATION FOR:  
 HLLV Environment with an STME Out (Margins ME=1.20 BE=1.25)  
 HLLV STME Attitude Adjustment Functions  
 HLLV Cycle 1 Radiation Trajectory Booster Adjustment  
 NLS HLLV Plume Radiation Trajectory with STME Out (EP55 (91-125) Sep. 26 1991)

Alt (kft)	Time* (sec)	Heating Rate (Btu/ft <sup>2</sup> -sec) for Points Listed
	109	110 115 116
0.	0.0	7.15 2.27 19.28 15.26
0.	5.0	7.10 2.26 19.17 15.19
1.	10.0	7.37 2.36 19.67 15.47
1.	12.0	7.65 2.46 20.20 15.78
2.	14.0	8.00 2.59 20.86 16.16
2.	15.0	8.19 2.66 21.24 16.37
2.	16.0	8.25 2.69 21.24 16.31
3.	18.0	8.21 2.70 20.87 15.87
4.	20.0	7.96 2.64 20.03 15.12
4.	22.0	7.63 2.55 19.03 14.28
6.	25.0	7.37 2.50 18.00 13.30
9.	30.0	7.33 2.54 17.36 12.52
12.	35.0	7.31 2.57 16.88 11.90
16.	40.0	7.28 2.59 16.47 11.42
20.	45.0	7.07 2.54 15.78 10.81
24.	50.0	6.80 2.46 15.00 10.17
29.	55.0	6.66 2.43 14.53 9.74
34.	60.0	6.61 2.42 14.21 9.40
40.	65.0	6.39 2.36 13.65 8.96
46.	70.0	6.20 2.30 13.10 8.52
52.	75.0	5.86 2.19 12.26 7.89
59.	80.0	5.53 2.08 11.51 7.38
66.	85.0	5.19 1.96 10.80 6.96
73.	90.0	5.20 1.95 10.91 6.96
81.	95.0	6.09 2.25 12.99 8.03
89.	100.0	6.46 2.38 13.41 8.32
98.	105.0	6.31 2.31 12.81 7.98
107.	110.0	5.97 2.17 11.82 7.40
116.	115.0	4.96 1.79 9.53 6.04
125.	120.0	3.46 1.35 7.15 4.75
134.	125.0	2.92 1.16 6.05 4.09
144.	130.0	2.43 0.98 5.04 3.48
149.	133.0	2.28 0.93 4.72 3.28
151.	134.0	3.73 1.45 7.57 5.00
153.	135.0	5.65 2.15 11.35 7.28
155.	136.0	7.10 2.60 14.21 9.01
156.	137.0	7.10 2.60 14.21 9.01
158.	138.0	6.40 2.42 12.81 8.17
160.	139.0	5.44 2.00 10.91 7.02
162.	140.0	4.40 1.71 9.01 5.87
162.	140.3	4.23 1.64 8.52 5.58
166.	144.3	0.37 0.74 0.92 0.99
Heat Load	868.30	311.16 1946.83 1345.72

ORIGINAL PAGE IS  
 OF POOR QUALITY

*[Handwritten Signature]*  
 COLOR PHOTOGRAPH

Table 4: HLLV Convective Environments for Body Point 101

101 HLLV  
BODY POINT # 101 -- CORE BASE HEAT SHIELD  
4.5KJ -- ENGINE OUT @ 11FT00, 111.00 LOFT, 10HG, BURH CONVECTIVE PLUME HEATING TRAJECTORY FROM EP 55 (91-125) SEP. 26, 1991

ALT (FT)	TIME (SEC)	TR (DEG R)	FILM COEFF. (BTU/FT <sup>2</sup> SEC-DEG R)	CONVECTIVE HEATING RATE (BTU/FT <sup>2</sup> *SEC) FOR VARIOUS WALL TEMPERATURES (DEG R)					
				460	540	960	1460	1960	2460
0.0	0.0	4190.	2.200E-02	82.06	80.30	71.06	60.06	49.06	38.06
0.8	10.0	4180.	2.170E-02	80.72	78.99	69.87	59.02	48.17	37.32
3.6	20.0	4165.	2.110E-02	78.18	76.49	67.63	57.08	46.53	35.98
8.6	30.0	4140.	2.040E-02	75.07	73.44	64.87	54.67	44.47	34.27
15.6	40.0	4120.	1.930E-02	70.64	69.09	60.99	51.34	41.69	32.04
24.4	50.0	4100.	1.780E-02	64.79	63.37	55.89	46.99	38.09	29.19
34.6	60.0	4080.	1.620E-02	58.64	57.35	50.54	42.44	34.34	26.24
46.3	70.0	4060.	1.380E-02	49.68	48.58	42.78	35.88	28.98	22.08
59.4	80.0	4040.	1.190E-02	42.60	41.65	36.65	30.70	24.75	18.80
74.2	90.0	3950.	9.500E-03	33.15	32.40	28.40	23.65	18.90	14.15
90.4	100.0	3870.	7.500E-03	25.58	24.98	21.83	18.08	14.33	10.58
107.8	110.0	3760.	5.697E-03	18.80	18.34	15.95	13.10	10.25	7.41
126.0	120.0	3640.	4.200E-03	13.36	13.02	11.26	9.16	7.06	4.96
146.0	130.0	3500.	3.167E-03	9.91	7.98	5.88	3.78	1.68	-0.42
167.9	140.0	3399.	2.477E-03	7.91	9.50	7.35	4.80	2.24	-0.31
191.3	150.0	3277.	1.988E-03	6.37	9.00	7.05	4.73	2.40	0.08
216.3	160.0	3155.	1.646E-03	5.25	8.50	6.73	4.62	2.51	0.40
242.8	170.0	3033.	1.382E-03	4.43	8.00	6.39	4.40	2.57	0.66
270.8	180.0	2910.	1.167E-03	3.84	7.25	5.67	4.09	2.50	0.92
300.2	190.0	2800.	9.857E-04	3.36	6.00	4.73	3.45	2.17	0.89
331.1	200.0	2707.	8.257E-04	2.97	5.00	4.09	3.01	1.92	0.84
363.4	210.0	2630.	7.000E-04	2.66	4.20	3.45	2.55	1.66	0.76
397.1	220.0	2560.	6.000E-04	2.41	3.40	2.80	2.10	1.30	0.60
432.2	230.0	2500.	5.200E-04	2.19	2.70	2.23	1.67	1.11	0.55
468.6	240.0	2450.	4.600E-04	2.02	2.10	1.70	1.20	0.80	0.40
506.3	250.0	2410.	4.100E-04	1.90	1.60	1.30	0.80	0.60	0.30
545.3	260.0	2380.	3.700E-04	1.80	1.20	1.00	0.60	0.40	0.20
585.5	270.0	2360.	3.400E-04	1.70	0.90	0.70	0.40	0.30	0.16
626.8	280.0	2350.	3.200E-04	1.60	0.70	0.50	0.30	0.25	0.16
669.2	290.0	2350.	3.100E-04	1.50	0.60	0.40	0.25	0.25	0.16
712.6	300.0	2350.	3.000E-04	1.40	0.50	0.30	0.25	0.25	0.16
757.0	310.0	2350.	2.900E-04	1.30	0.40	0.25	0.25	0.25	0.16
802.4	320.0	2350.	2.800E-04	1.20	0.30	0.20	0.25	0.25	0.16
848.8	330.0	2350.	2.700E-04	1.10	0.20	0.16	0.25	0.25	0.16
896.2	340.0	2350.	2.600E-04	1.00	0.16	0.16	0.25	0.25	0.16
944.6	350.0	2350.	2.500E-04	0.90	0.16	0.16	0.25	0.25	0.16
994.0	360.0	2350.	2.400E-04	0.80	0.16	0.16	0.25	0.25	0.16
1044.4	370.0	2350.	2.300E-04	0.70	0.16	0.16	0.25	0.25	0.16
1095.8	380.0	2350.	2.200E-04	0.60	0.16	0.16	0.25	0.25	0.16
1148.2	390.0	2350.	2.100E-04	0.50	0.16	0.16	0.25	0.25	0.16
1201.6	400.0	2350.	2.000E-04	0.40	0.16	0.16	0.25	0.25	0.16
1256.0	410.0	2350.	1.900E-04	0.30	0.16	0.16	0.25	0.25	0.16
1311.4	420.0	2350.	1.800E-04	0.20	0.16	0.16	0.25	0.25	0.16
1367.8	430.0	2350.	1.700E-04	0.16	0.16	0.16	0.25	0.25	0.16
1425.2	440.0	2350.	1.600E-04	0.16	0.16	0.16	0.25	0.25	0.16
1483.6	450.0	2350.	1.500E-04	0.16	0.16	0.16	0.25	0.25	0.16
1543.0	460.0	2350.	1.400E-04	0.16	0.16	0.16	0.25	0.25	0.16
1603.4	470.0	2350.	1.300E-04	0.16	0.16	0.16	0.25	0.25	0.16
1664.8	480.0	2350.	1.200E-04	0.16	0.16	0.16	0.25	0.25	0.16
1727.2	490.0	2350.	1.100E-04	0.16	0.16	0.16	0.25	0.25	0.16
1790.6	500.0	2350.	1.000E-04	0.16	0.16	0.16	0.25	0.25	0.16
1855.0	510.0	2350.	9.000E-05	0.16	0.16	0.16	0.25	0.25	0.16
1920.4	520.0	2350.	8.000E-05	0.16	0.16	0.16	0.25	0.25	0.16
1986.8	530.0	2350.	7.000E-05	0.16	0.16	0.16	0.25	0.25	0.16
2054.2	540.0	2350.	6.000E-05	0.16	0.16	0.16	0.25	0.25	0.16
2122.6	550.0	2350.	5.000E-05	0.16	0.16	0.16	0.25	0.25	0.16
2192.0	560.0	2350.	4.000E-05	0.16	0.16	0.16	0.25	0.25	0.16
2262.4	570.0	2350.	3.000E-05	0.16	0.16	0.16	0.25	0.25	0.16
2333.8	580.0	2350.	2.000E-05	0.16	0.16	0.16	0.25	0.25	0.16
2406.2	590.0	2350.	1.000E-05	0.16	0.16	0.16	0.25	0.25	0.16
2479.6	600.0	2350.	0.000E-05	0.16	0.16	0.16	0.25	0.25	0.16

SUMMARY @ TW = 540 R  
\*\*\*\*\*

PEAK HEATING RATE: 80.30 (BTU/FT<sup>2</sup>\*SEC)

TOTAL HEAT LOAD: 6564.34 (BTU/FT<sup>2</sup>)

Table 5: HLLV Convective Environments for Body Point 102

U.S. FEET  
BODY POINT # 102 -- CORE BASE HEAT SHIELD  
ASRM/3 ENGINE OUT @ LIFTOFF, HIGH LOFT, LONG BURN CONVECTIVE PLUME HEATING TRAJECTORY FROM EP 55 (91-125) SEP. 26, 1991

ALT (FT)	TIME (SEC)	TR (DEG R)	FILM COEFF. (BTU/FT <sup>2</sup> SEC-DEG R)	CONVECTIVE HEATING RATE (BTU/FT <sup>2</sup> *SEC) FOR VARIOUS WALL TEMPERATURES (DEG R)					
				460	540	960	1460	1960	2460
0.0	0.0	4190.	2.200E-02	82.06	80.30	71.06	60.06	49.06	38.06
0.8	10.0	4180.	2.170E-02	80.72	78.99	69.87	59.02	48.17	37.32
3.6	20.0	4165.	2.110E-02	78.18	76.49	67.63	57.08	46.53	35.98
8.6	30.0	4140.	2.040E-02	75.07	73.44	64.87	54.67	44.47	34.27
15.6	40.0	4120.	1.930E-02	70.64	69.09	60.99	51.34	41.69	32.04
24.4	50.0	4100.	1.780E-02	64.79	63.37	55.89	46.99	38.09	29.19
34.6	60.0	4080.	1.620E-02	58.64	57.35	50.54	42.44	34.34	26.24
46.3	70.0	4060.	1.380E-02	49.68	48.58	42.78	35.88	28.98	22.08
59.4	80.0	4040.	1.190E-02	42.60	41.65	36.65	30.70	24.75	18.80
74.2	90.0	3950.	9.500E-03	33.15	32.40	28.40	23.65	18.90	14.15
90.4	100.0	3870.	7.500E-03	25.58	24.98	21.83	18.08	14.33	10.58
107.8	110.0	3760.	5.697E-03	18.80	18.34	15.95	13.10	10.25	7.41
126.0	120.0	3640.	4.200E-03	13.36	13.02	11.26	9.16	7.06	4.96
126.0	120.0	2360.	4.198E-03	7.98	7.64	5.88	3.78	1.68	-0.42
126.9	121.0	2399.	3.927E-03	7.61	7.30	5.65	3.69	1.72	-0.24
130.6	123.0	2477.	3.562E-03	7.18	6.90	5.40	3.62	1.84	0.06
134.3	125.0	2555.	3.176E-03	6.65	6.40	5.07	3.48	1.89	0.30
138.1	127.0	2633.	2.819E-03	6.13	5.90	4.72	3.31	1.90	0.49
144.5	130.0	2750.	2.262E-03	5.18	5.00	4.05	2.92	1.79	0.66
149.2	133.0	2808.	1.808E-03	4.24	4.10	3.34	2.44	1.53	0.63
152.9	135.0	2847.	1.517E-03	3.62	3.50	2.86	2.10	1.35	0.59
156.4	137.0	2886.	1.236E-03	3.00	2.90	2.38	1.76	1.14	0.53
162.8	140.3	2950.	8.714E-04	2.17	2.10	1.73	1.30	0.86	0.43
170.8	140.3	2950.	1.660E-04	0.41	0.40	0.33	0.25	0.16	0.08
178.8	150.0	2950.	1.660E-04	0.41	0.40	0.33	0.25	0.16	0.08
246.4	200.0	2950.	1.660E-04	0.41	0.40	0.33	0.25	0.16	0.08
361.5	432.6	2950.	1.660E-04	0.41	0.40	0.33	0.25	0.16	0.08

SUMMARY @ Tw = 540 R  
=====

PEAK HEATING RATE: 80.30 (BTU/FT<sup>2</sup>\*SEC)

TOTAL HEAT LOAD: 6529.70 (BTU/FT<sup>2</sup>)

Table 6: HLLV Convective Environments for Body Point 103

BODY POINT # 103 -- CORE BASE HEAT SHIELD		LONG BURN CONVECTIVE PLUME HEATING TRAJECTORY FROM EP 55 (91-125) SEP. 26, 1951									
SHIELD EFFICIENCY (OUT) = LIFTOFF, HIGH LOFT,		CONVECTIVE HEATING RATE (BTU/FT2*SEC)									
		FOR VARIOUS WALL TEMPERATURES (DEG R)									
ALT (KFT)	TIME (SEC)	TR (DEG R)	FILM COEFF. (BTU/FT2* SEC-DEG R)	460	540	960	1460	1960	2460		
0.0	0.0	4190.	2.200E-02	82.06	80.30	71.06	60.06	49.06	38.06		
0.8	10.0	4180.	2.170E-02	80.72	78.99	69.87	59.02	48.17	37.32		
3.6	20.0	4165.	2.110E-02	78.18	76.49	67.63	57.08	46.53	35.98		
8.6	30.0	4140.	2.040E-02	75.07	73.44	64.87	54.67	44.47	34.27		
15.6	40.0	4120.	1.930E-02	70.64	69.09	60.99	51.34	41.69	32.04		
24.4	50.0	4100.	1.780E-02	64.79	63.37	55.89	46.99	38.09	29.19		
34.6	60.0	4080.	1.620E-02	58.64	57.35	50.54	42.44	34.34	26.24		
46.3	70.0	4060.	1.380E-02	49.68	48.58	42.78	35.88	28.98	22.08		
59.4	80.0	4040.	1.190E-02	42.60	41.65	36.65	30.70	24.75	18.80		
74.2	90.0	3950.	9.500E-03	33.15	32.40	28.40	23.65	18.90	14.15		
90.4	100.0	3870.	7.500E-03	25.58	24.98	21.83	18.08	14.33	10.58		
107.8	110.0	3760.	5.697E-03	18.80	18.34	15.95	13.10	10.25	7.41		
126.0	120.0	3640.	4.200E-03	13.36	13.02	11.26	9.16	7.06	4.96		
144.9	120.0	2360.	4.198E-03	7.98	7.64	5.88	3.78	1.68	-0.42		
161.9	121.0	2399.	2.313E-03	4.49	4.30	3.33	2.17	1.02	-0.14		
180.6	123.0	2477.	2.142E-03	4.32	4.15	3.25	2.18	1.11	0.04		
194.3	125.0	2555.	1.935E-03	4.05	3.90	3.09	2.12	1.15	0.18		
198.1	127.0	2633.	1.768E-03	3.84	3.70	2.96	2.07	1.19	0.31		
144.5	130.0	2750.	1.493E-03	3.42	3.30	2.67	1.93	1.18	0.43		
149.2	133.0	2808.	1.190E-03	2.80	2.70	2.20	1.60	1.01	0.41		
152.9	135.0	2847.	9.970E-04	2.38	2.30	1.88	1.38	0.88	0.39		
156.4	137.0	2886.	7.673E-04	1.86	1.80	1.48	1.09	0.71	0.33		
162.8	140.3	2950.	4.564E-04	1.14	1.10	0.91	0.68	0.45	0.22		
162.8	140.3	2950.	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04		
178.8	150.0	2950.	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04		
246.4	200.0	2950.	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04		
361.5	432.6	2950.	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04		

SUMMARY @ TW = 540 R  
 =====

PEAK HEATING RATE: 80.30 (BTU/FT2\*SEC)  
 TOTAL HEAT LOAD: 6435.18 (BTU/FT2)

REMTECH

RTN 218-04

Table 7: HLLV Convective Environments for Body Point 104

HLS HLLV BODY POINT # 104 -- CORE BASE HEAT SHIELD ASRM/3 ENGINE OUT & LIFTOFF. HIGH LOFT. LONG BURR. CURVE TIVE PLUME HEATING TRAJECTORY FROM EP 55 (91-125) SEP. 26, 1991		CONVECTIVE HEATING RATE (BTU/FT <sup>2</sup> *SEC) FOR VARIOUS WALL TEMPERATURES (DEG. R)							
ALT (KFT)	TIME (SEC)	TR (DEG. R)	FILM COEFF. (BTU/FT <sup>2</sup> * SEC-DEG. R)	460	540	960	1460	1960	2460
0.0	0.0	4190.	2.200E-02	82.06	80.30	71.06	60.06	49.06	38.06
0.8	10.0	4180.	2.170E-02	80.72	78.99	69.87	59.02	48.17	37.32
3.6	20.0	4165.	2.110E-02	78.18	76.49	67.63	57.08	46.53	35.98
8.6	30.0	4140.	2.040E-02	75.07	73.44	64.87	54.67	44.47	34.27
15.6	40.0	4120.	1.930E-02	70.64	69.09	60.99	51.34	41.69	32.04
24.4	50.0	4100.	1.780E-02	64.79	63.37	55.89	46.99	38.09	29.19
34.6	60.0	4080.	1.620E-02	58.64	57.35	50.54	42.44	34.34	26.24
46.3	70.0	4060.	1.380E-02	49.68	48.58	42.78	35.08	28.98	22.08
59.4	80.0	4040.	1.190E-02	42.60	41.65	36.65	30.70	24.75	18.80
74.2	90.0	3950.	9.500E-03	33.15	32.40	28.40	23.65	18.90	14.15
90.4	100.0	3870.	7.500E-03	25.58	24.98	21.83	18.08	14.33	10.58
107.8	110.0	3760.	5.697E-03	18.80	18.34	15.95	13.10	10.25	7.41
126.0	120.0	3640.	4.200E-03	13.36	13.02	11.26	9.16	7.06	4.96
144.5	130.0	3500.	3.190E-03	9.79	9.50	8.11	6.52	5.11	3.82
162.8	140.0	3350.	2.580E-03	7.34	7.10	6.00	4.91	3.96	2.92
178.8	150.0	3190.	2.280E-03	5.78	5.59	4.75	3.93	3.11	2.31
201.5	160.0	3020.	2.100E-03	4.76	4.62	3.96	3.20	2.52	1.86
229.9	170.0	2847.	1.951E-03	3.83	3.73	3.13	2.54	1.98	1.47
256.4	180.0	2666.	1.810E-03	2.98	2.92	2.43	1.96	1.48	1.04
282.8	190.0	2479.	1.680E-03	2.29	2.26	1.87	1.47	1.05	0.67
301.5	200.0	2287.	1.560E-03	1.73	1.71	1.39	1.04	0.75	0.42
301.5	432.6	2950.	2.490E-04	0.62	0.60	0.50	0.37	0.25	0.12
301.5	432.6	2950.	2.490E-04	0.62	0.60	0.50	0.37	0.25	0.12

SUMMARY @ Tw = 540 R  
\*\*\*\*\*

PEAK HEATING RATE: 80.30 (BTU/FT<sup>2</sup>\*SEC)

TOTAL HEAT LOAD: 6613.72 (BTU/FT<sup>2</sup>)

Table 8: HLLV Convective Environments for Body Point 105

PLS. HLLV  
BODY POINT # 105 -- CORE BASE HEAT SHIELD  
ASRM/3 ENGLISH OUT @ LIFT OFF, HIGH LOFT, LONG BURH CONVECTIVE PLUME HEATING TRAJECTORY FROM EP 55 (91-125) SEP. 26, 199\*

ALT (KFT)	TIME (SEC)	TR (DEG R)	FILM COEFF. (BTU/FT2* SEC-DEG R)	CONVECTIVE HEATING RATE (BTU/FT2*SEC) FOR VARIOUS WALL TEMPERATURES (DEG R)					
				460	540	960	1460	1960	2460
0.0	0.0	4190.	2.200E-02	82.06	80.30	71.06	60.06	49.06	38.06
0.8	10.0	4180.	2.170E-02	80.72	78.99	69.87	59.02	48.17	37.37
3.6	20.0	4165.	2.110E-02	78.18	76.49	67.63	57.08	46.53	35.98
8.6	30.0	4140.	2.040E-02	75.07	73.44	64.87	54.67	44.47	34.27
15.6	40.0	4120.	1.930E-02	70.64	69.09	60.99	51.34	41.69	32.04
24.4	50.0	4100.	1.780E-02	64.79	63.37	55.89	46.99	38.09	29.19
34.6	60.0	4080.	1.620E-02	58.64	57.35	50.54	42.44	34.34	26.24
46.3	70.0	4060.	1.380E-02	49.68	48.58	42.78	35.88	28.98	22.08
59.4	80.0	4040.	1.190E-02	42.60	41.65	36.65	30.70	24.75	18.80
74.2	90.0	3950.	9.500E-03	33.15	32.40	28.40	23.65	18.90	14.15
90.4	100.0	3870.	7.500E-03	25.58	24.98	21.83	18.08	14.33	10.58
107.8	110.0	3760.	5.697E-03	18.80	18.34	15.95	13.10	10.25	7.41
126.0	120.0	3640.	4.200E-03	13.36	13.02	11.26	9.16	7.06	4.96
126.9	121.0	2399.	4.198E-03	7.98	7.64	5.88	3.78	1.68	-0.42
130.6	123.0	2477.	5.379E-03	10.43	10.00	7.74	5.05	2.36	-0.33
134.3	125.0	2555.	4.956E-03	10.00	9.60	7.52	5.04	2.56	0.08
138.1	127.0	2633.	4.467E-03	9.36	9.00	7.12	4.89	2.66	0.42
144.5	130.0	2750.	3.966E-03	8.62	8.30	6.63	4.65	2.67	0.69
149.2	133.0	2808.	3.303E-03	7.56	7.30	5.91	4.26	2.61	0.96
152.9	135.0	2847.	2.646E-03	6.21	6.00	4.89	3.57	2.24	0.92
156.4	137.0	2886.	2.254E-03	5.38	5.20	4.25	3.13	2.00	0.87
162.8	140.3	2950.	1.833E-03	4.45	4.30	3.53	2.61	1.70	0.78
162.8	140.3	2950.	1.079E-03	2.69	2.60	2.15	1.61	1.07	0.53
170.8	150.0	2950.	1.660E-04	0.41	0.40	0.33	0.25	0.16	0.08
246.4	200.0	2950.	1.660E-04	0.41	0.40	0.33	0.25	0.16	0.08
361.5	432.6	2950.	1.660E-04	0.41	0.40	0.33	0.25	0.16	0.08

SUMMARY @ Tw = 540 R  
=====

PEAK HEATING RATE: 80.30 (BTU/FT2\*SEC)

TOTAL HEAT LOAD: 6569.94 (BTU/FT2)

Table 9: HILLY Convective Environments for Body Point 106

HILLY		COPE BASE HEAT SHIELD		CONVECTIVE PLUME HEATING TRAJECTORY FROM EP 55 (91-125) SEP. 26, 1991												
BODY POINT # 106		LIFT OFF. HIG. LOFT.		CONVECTIVE HEATING RATE (BTU/FT <sup>2</sup> *SEC)												
ASMM'S ENGINE OUT		LONG		FOR VARIOUS WALL TEMPERATURES (DEG R)												
ALT (KFT)	TIME (SEC)	TP (DEG R)	FILM COEFF. (BTU/FT <sup>2</sup> *SEC (DEG R))	460	540	960	1460	1960	2460							
0.0	0.0	4180.	2.200E-02	82.06	80.30	71.06	60.06	49.06	38.06							
0.0	10.0	4180.	2.170E-02	80.72	78.99	69.87	59.02	48.17	37.32							
3.6	20.0	4165.	2.110E-02	78.18	76.49	67.63	57.08	46.53	35.98							
8.6	30.0	4140.	2.040E-02	75.07	73.44	64.87	54.67	44.47	34.27							
15.6	40.0	4120.	1.930E-02	70.64	69.09	60.99	51.34	41.69	32.04							
24.4	50.0	4100.	1.780E-02	64.79	63.37	55.89	46.99	38.09	29.19							
34.6	60.0	4080.	1.620E-02	58.64	57.35	50.54	42.44	34.34	26.24							
46.3	70.0	4060.	1.380E-02	49.88	48.58	42.78	35.88	28.98	22.08							
59.4	80.0	4040.	1.190E-02	42.60	41.65	36.65	30.70	24.75	18.80							
74.2	90.0	3950.	9.500E-03	33.15	32.40	28.40	23.65	18.90	14.15							
90.4	100.0	3870.	7.500E-03	25.58	24.98	21.83	18.08	14.33	10.58							
107.8	110.0	3760.	5.697E-03	18.80	18.34	15.95	13.10	10.25	7.41							
126.0	120.0	3640.	4.200E-03	13.36	13.02	11.26	9.16	7.06	4.96							
126.0	120.0	2360.	4.198E-03	7.98	7.64	5.88	3.78	1.68	-0.42							
126.9	121.0	2399.	5.917E-03	11.47	11.00	8.51	5.56	2.60	-0.36							
130.6	123.0	2477.	5.524E-03	11.14	10.70	8.38	5.62	2.86	0.09							
134.3	125.0	2555.	5.161E-03	10.81	10.40	8.23	5.65	3.07	0.49							
138.1	127.0	2633.	4.730E-03	10.28	9.90	7.91	5.55	3.18	0.82							
144.5	130.0	2750.	4.072E-03	9.33	9.00	7.29	5.25	3.22	1.18							
149.2	133.0	2808.	3.351E-03	7.87	7.60	6.19	4.52	2.84	1.17							
152.9	135.0	2847.	2.904E-03	6.93	6.70	5.48	4.03	2.58	1.12							
156.4	137.0	2886.	2.344E-03	5.69	5.50	4.52	3.34	2.17	1.00							
162.0	140.3	2950.	1.203E-03	3.00	2.90	2.39	1.79	1.19	0.59							
162.0	140.3	2950.	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04							
178.8	150.0	2950.	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04							
246.4	200.0	2950.	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04							
361.5	432.6	2950.	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04							

SUMMARY @ Tw = 540 R  
=====

PEAK HEATING RATE: 80.30 (BTU/FT<sup>2</sup>\*SEC)

TOTAL HEAT LOAD: 6537.75 (BTU/FT<sup>2</sup>)

Table 10: HLLV Convective Environments for Body Point 107

HLLV PLATE  
BODY POINT # 107 -- STEAM HEAT SHIELD  
ASPH + ENAMEL OUT @ LIFTOFF, HIGH LOFT, LONG BURH (CONVECTIVE PLUME HEATING TRAJECTORY FROM EP 55 (91-125) SEP. 26, 1991

ALT (FEET)	TIME (SEC)	TR (DEG R)	FILM COEFF. (BTU/FT2* SEC-DEG R)	460	540	960	1460	1960	2460
0.0	0.0	4190.	2.200E-02	82.06	80.30	71.06	60.06	49.06	38.06
0.8	10.0	4180.	2.170E-02	80.72	78.99	69.87	59.02	48.17	37.32
3.6	20.0	4165.	2.110E-02	78.18	76.49	67.63	57.08	46.53	35.98
8.6	30.0	4140.	2.040E-02	75.07	73.44	64.87	54.67	44.47	34.27
15.6	40.0	4120.	1.930E-02	70.64	69.09	60.99	51.34	41.69	32.04
24.4	50.0	4100.	1.780E-02	64.79	63.37	55.89	46.99	38.09	29.19
34.6	60.0	4080.	1.620E-02	58.64	57.35	50.54	42.44	34.34	26.24
46.3	70.0	4060.	1.380E-02	49.68	48.58	42.78	35.88	28.98	22.08
59.4	80.0	4040.	1.190E-02	42.60	41.65	36.65	30.70	24.75	18.80
74.2	90.0	3950.	9.500E-03	33.15	32.40	28.40	23.65	18.90	14.15
90.4	100.0	3870.	7.500E-03	25.58	24.98	21.83	18.08	14.33	10.58
107.8	110.0	3760.	5.697E-03	18.80	18.34	15.95	13.10	10.25	7.41
126.0	120.0	3640.	4.200E-03	13.36	13.02	11.26	9.16	7.06	4.96
126.9	121.0	2399.	4.198E-03	7.98	7.64	5.88	3.78	1.68	-0.42
130.6	123.0	2477.	5.541E-03	10.74	10.30	7.97	5.20	2.43	-0.34
134.3	125.0	2555.	5.240E-03	10.57	10.15	7.95	5.33	2.71	0.09
138.1	127.0	2633.	4.764E-03	9.98	9.60	7.60	5.22	2.83	0.45
144.5	130.0	2750.	4.300E-03	9.34	9.00	7.19	5.04	2.89	0.74
149.2	133.0	2808.	3.620E-03	8.29	8.00	6.48	4.67	2.86	1.05
152.9	135.0	2847.	2.954E-03	6.94	6.70	5.46	3.98	2.51	1.03
156.4	137.0	2886.	2.471E-03	5.90	5.70	4.66	3.43	2.19	0.96
162.8	140.3	2950.	1.961E-03	4.76	4.60	3.78	2.80	1.82	0.84
162.8	140.3	2950.	1.037E-03	2.58	2.50	2.06	1.55	1.03	0.51
178.8	150.0	2950.	7.884E-04	1.96	1.90	1.57	1.17	0.78	0.39
246.4	200.0	2950.	7.884E-04	1.96	1.90	1.57	1.17	0.78	0.39
361.5	432.6	2950.	7.884E-04	1.96	1.90	1.57	1.17	0.78	0.39

SUMMARY @ Tm = 540 R  
\*\*\*\*\*

PEAK HEATING RATE: 80.30 (BTU/FT2\*SEC)  
TOTAL HEAT LOAD: 7018.37 (BTU/FT2)



Table 11: HLLV Convective Environments for Body Point 108

TABLE 11  
BODY POINT # 108 -- STIME HEAT SHIELD  
45RM'S ENGINE OUT + LIFTOFF, HIGH LOFT, LONG BURH CONVECTIVE PLUME HEATING TRAJECTORY FROM EI 55 (91-125) SEP. 26, 1991

ALT (KFE)	TIME (SEC)	TR (DEG R)	FILM COEFF. (BTU/FT <sup>2</sup> SEC-DEG R)	CONVECTIVE HEATING RATE (BTU/FT <sup>2</sup> *SEC) FOR VARIOUS WALL TEMPERATURES (DEG R)					
				460	540	960	1460	1960	2460
0.0	0.0	4190.	2.200E-02	82.06	80.30	71.06	60.06	49.06	38.06
0.8	10.0	4180.	2.170E-02	80.72	78.99	69.87	59.02	48.17	37.32
3.6	20.0	4165.	2.110E-02	78.18	76.49	67.63	57.08	46.53	35.98
8.6	30.0	4140.	2.040E-02	75.07	73.44	64.87	54.67	44.47	34.27
15.6	40.0	4120.	1.930E-02	70.64	69.09	60.99	51.34	41.69	32.04
24.4	50.0	4100.	1.780E-02	64.79	63.37	55.89	46.99	38.09	29.19
34.6	60.0	4080.	1.620E-02	58.64	57.35	50.54	42.44	34.34	26.24
46.3	70.0	4060.	1.380E-02	49.68	48.58	42.70	35.88	28.98	22.08
59.4	80.0	4040.	1.190E-02	42.60	41.65	36.65	30.70	24.75	18.80
74.2	90.0	3950.	9.500E-03	33.15	32.40	28.40	23.65	18.90	14.15
90.4	100.0	3870.	7.500E-03	25.58	24.98	21.83	18.08	14.33	10.58
107.8	110.0	3760.	5.697E-03	18.80	18.34	15.95	13.10	10.25	7.41
126.0	120.0	3640.	4.200E-03	13.36	13.02	11.26	9.16	7.06	4.96
126.9	121.0	2399.	4.198E-03	7.98	7.64	5.88	3.78	1.68	-0.42
130.6	123.0	2477.	5.756E-03	11.16	10.70	8.28	5.40	2.53	-0.35
134.3	125.0	2555.	5.369E-03	10.83	10.40	8.14	5.46	2.78	0.09
138.1	127.0	2633.	5.012E-03	10.50	10.10	7.99	5.49	2.98	0.48
144.5	130.0	2750.	4.634E-03	10.07	9.70	7.75	5.44	3.12	0.80
149.2	133.0	2808.	4.027E-03	9.22	8.90	7.21	5.20	3.18	1.17
152.9	135.0	2847.	3.395E-03	7.97	7.70	6.27	4.50	2.88	1.18
156.4	137.0	2886.	2.948E-03	7.04	6.80	5.56	4.09	2.61	1.14
162.8	140.3	2950.	2.302E-03	5.58	5.40	4.43	3.28	2.13	0.98
162.8	140.3	2950.	1.120E-03	2.79	2.70	2.23	1.67	1.11	0.55
178.8	156.0	2950.	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04
246.4	200.0	2950.	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04
361.5	432.6	2950.	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04

SUMMARY @ TW = 540 R  
=====

PEAK HEATING RATE: 80.30 (BTU/FT<sup>2</sup>\*SEC)

TOTAL HEAT LOAD: 6535.16 (BTU/FT<sup>2</sup>)

Table 13: HILLY Convective Environments for Body Point 110

HLS DATA  
 BODY POINT # 110 -- ASRB SEPT TRAILING EDGE  
 ASRB-3 ENGINE OUT & LIFTOFF, 10000 LBS L, LONG BURST (CONVECTIVE PLUME HEATING TRAJECTORY FROM EP-55 (91-125) SEP. 26, 1991)

ALT (KFT)	TIME (SEC)	TR (DEG F)	FILM COEFF. (BTU/FT <sup>2</sup> *SEC-DEG F)	4100	540	960	1460	1960	2460
0.0	0.0	4190.	2.200E-02	82.06	80.30	71.06	60.06	49.06	38.06
0.8	10.0	4180.	2.170E-02	80.72	78.99	69.87	59.02	48.17	37.32
3.6	20.0	4165.	2.110E-02	78.18	76.49	67.63	57.08	46.53	35.98
8.6	30.0	4140.	2.040E-02	75.07	73.44	64.87	54.67	44.47	34.27
15.6	40.0	4120.	1.930E-02	70.64	69.09	60.99	51.34	41.69	32.04
24.4	50.0	4100.	1.780E-02	64.79	63.37	55.89	46.99	38.09	29.19
34.6	60.0	4080.	1.620E-02	58.64	57.35	50.54	42.44	34.34	26.24
46.3	70.0	4060.	1.380E-02	49.68	48.58	42.78	35.88	28.98	22.08
59.4	80.0	4040.	1.190E-02	42.60	41.65	36.65	30.70	24.75	18.80
74.2	90.0	3950.	9.500E-03	33.15	32.40	28.40	23.65	18.90	14.15
90.4	100.0	3870.	7.500E-03	25.58	24.98	21.83	18.08	14.33	10.58
107.8	110.0	3760.	5.697E-03	18.80	18.34	15.95	13.10	10.25	7.41
126.0	120.0	3640.	4.200E-03	13.36	13.02	11.26	9.16	7.06	4.96
126.9	121.0	2399.	4.198E-03	7.98	7.64	5.88	3.78	1.68	-0.42
130.6	123.0	2477.	7.262E-03	14.08	13.50	10.45	6.82	3.19	-0.44
134.3	125.0	2555.	6.415E-03	13.75	13.20	10.34	6.93	3.52	0.12
138.1	127.0	2633.	6.303E-03	13.20	12.70	10.05	6.90	3.75	0.60
144.5	130.0	2750.	5.781E-03	12.56	12.10	9.67	6.78	3.89	1.00
149.2	133.0	2808.	4.977E-03	11.40	11.00	8.91	6.42	3.93	1.44
152.9	135.0	2847.	4.189E-03	9.84	9.50	7.74	5.65	3.55	1.46
156.4	137.0	2886.	3.511E-03	8.38	8.10	6.63	4.87	3.11	1.36
162.8	140.3	2950.	2.771E-03	6.72	6.50	5.34	3.95	2.57	1.18
162.8	140.3	2950.	1.079E-03	2.69	2.60	2.15	1.61	1.07	0.53
178.8	150.0	2950.	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
246.4	200.0	2950.	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
361.5	432.6	2950.	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00

SUMMARY @ TW = 540 R  
 =====

PEAK HEATING RATE: 80.30 (BTU/FT<sup>2</sup>\*SEC)

TOTAL HEAT LOAD: 6513.85 (BTU/FT<sup>2</sup>)

Table 14: HLLV Convective Environments for Body Point 111

HLS FILE  
 BODY POINT # 111 -- STME NOZZLE, EXIT  
 4.5 CM 5 ENGINE OUT 6 LIFTOFF, HIGH LOFT, LONG BURN CONVECTIVE PLUME HEATING TRAJECTORY FROM EI 55 (01/25) SET. 26, 1991

A: T (INFT)	TIME (SEC)	TR (DEG R)	FILM COEFF. (BTU/FT <sup>2</sup> SEC-DEG R)	CONVECTIVE HEATING RATE (BTU/FT <sup>2</sup> *SEC) FOR VARIOUS WALL TEMPERATURES (DEG R)					
				460	540	960	1460	1960	2460
0.0	0.0	4190.	2.200E-02	82.06	80.30	71.06	60.06	49.06	38.06
0.8	10.0	4180.	2.170E-02	80.72	78.99	69.87	59.02	48.17	37.32
3.6	20.0	4165.	2.110E-02	78.18	76.49	67.53	57.08	46.53	35.98
8.6	30.0	4140.	2.040E-02	75.07	73.44	64.87	54.67	44.47	34.27
15.6	40.0	4120.	1.930E-02	70.64	69.09	60.99	51.34	41.69	32.04
24.4	50.0	4100.	1.780E-02	64.79	63.37	55.89	46.99	38.09	29.19
34.6	60.0	4080.	1.620E-02	58.64	57.35	50.54	42.44	34.34	26.24
46.3	70.0	4060.	1.380E-02	49.68	48.58	42.78	35.88	28.98	22.08
59.4	80.0	4040.	1.190E-02	42.60	41.65	36.65	30.70	24.75	18.80
74.2	90.0	3950.	9.500E-03	33.15	32.40	28.40	23.65	18.90	14.15
90.4	100.0	3870.	7.500E-03	25.58	24.98	21.83	18.08	14.33	10.58
107.8	110.0	3760.	5.697E-03	18.80	18.34	15.95	13.10	10.25	7.41
126.0	120.0	3640.	4.200E-03	13.36	13.02	11.26	9.16	7.06	4.96
126.0	120.0	2360.	4.198E-03	7.98	7.64	5.88	3.78	1.68	-0.42
126.0	120.0	2399.	6.455E-03	12.52	12.00	9.29	6.06	2.83	-0.39
130.6	123.0	2477.	5.989E-03	12.08	11.60	9.08	6.09	3.10	0.10
134.3	125.0	2555.	5.509E-03	11.54	11.10	8.79	6.03	3.28	0.52
138.1	127.0	2633.	4.969E-03	10.80	10.40	8.31	5.83	3.34	0.86
141.5	130.0	2750.	4.118E-03	9.43	9.10	7.37	5.31	3.25	1.19
149.2	133.0	2808.	3.395E-03	7.97	7.70	6.27	4.58	2.88	1.18
152.9	135.0	2847.	2.861E-03	6.83	6.60	5.40	3.97	2.54	1.11
156.4	137.0	2886.	2.344E-03	5.69	5.50	4.52	3.34	2.17	1.00
162.8	140.3	2950.	1.286E-03	3.20	3.10	2.56	1.92	1.27	0.63
162.8	140.3	2950.	1.079E-03	2.69	2.60	2.15	1.61	1.07	0.53
178.8	150.0	2950.	1.079E-03	2.69	2.60	2.15	1.61	1.07	0.53
246.4	200.0	2950.	1.079E-03	2.69	2.60	2.15	1.61	1.07	0.53
361.5	432.6	2950.	1.079E-03	2.69	2.60	2.15	1.61	1.07	0.53

SUMMARY @ Tw = 540 R  
 =====

PEAK HEATING RATE: 80.30 (BTU/FT<sup>2</sup>\*SEC)

TOTAL HEAT LOAD: 7245.91 (BTU/FT<sup>2</sup>)

Table 15: HLLV Convective Environments for Body Point 112

ALT (FT)	TIME (SEC)	TF (DEG R)	FILM COEFF. (BTU/FT <sup>2</sup> SEC-DEG R)	460	540	960	1460	1960	2460
0.0	0.0	4190.	2.200E-02	82.06	80.30	71.06	60.06	49.06	38.06
0.8	10.0	4180.	2.170E-02	80.72	78.99	69.87	59.02	48.17	37.32
3.6	20.0	4165.	2.110E-02	78.18	76.49	67.63	57.08	46.53	35.98
8.6	30.0	4140.	2.040E-02	75.07	73.44	64.87	54.67	44.47	34.27
15.6	40.0	4120.	1.930E-02	70.64	69.09	60.99	51.34	41.69	32.04
24.4	50.0	4100.	1.780E-02	64.79	63.37	55.89	46.99	38.09	29.19
34.6	60.0	4080.	1.620E-02	58.64	57.35	50.54	42.44	34.34	26.24
46.3	70.0	4060.	1.380E-02	49.68	48.58	42.78	35.80	28.98	22.08
59.4	80.0	4040.	1.190E-02	42.60	41.65	36.65	30.70	24.75	18.80
74.2	90.0	3950.	9.500E-03	33.15	32.40	28.40	23.65	18.90	14.15
90.4	100.0	3870.	7.500E-03	25.58	24.98	21.83	18.08	14.33	10.58
107.8	110.0	3760.	5.697E-03	18.80	18.34	15.95	13.10	10.25	7.41
126.0	120.0	3640.	4.200E-03	13.36	13.02	11.26	9.16	7.06	4.96
126.0	120.0	2360.	4.198E-03	7.98	7.64	5.88	3.78	1.68	-0.42
126.9	121.0	2399.	6.939E-03	13.46	12.90	9.99	6.57	3.05	-0.42
130.6	123.0	2477.	6.402E-03	12.91	12.40	9.71	6.51	3.31	0.11
134.3	125.0	2555.	5.856E-03	12.27	11.80	9.34	6.41	3.48	0.56
138.1	127.0	2633.	5.351E-03	11.63	11.20	8.95	6.28	3.60	0.93
144.5	130.0	2750.	4.480E-03	10.26	9.90	8.02	5.78	3.54	1.30
149.2	133.0	2808.	3.704E-03	8.70	8.40	6.84	4.99	3.14	1.29
152.9	135.0	2847.	3.164E-03	7.55	7.30	5.97	4.39	2.81	1.22
156.4	137.0	2886.	2.600E-03	6.31	6.10	5.01	3.71	2.41	1.11
162.8	140.3	2950.	1.411E-03	3.51	3.40	2.81	2.10	1.40	0.69
162.8	140.3	2950.	7.469E-04	1.86	1.80	1.49	1.11	0.74	0.37
178.8	150.0	2950.	7.469E-04	1.86	1.80	1.49	1.11	0.74	0.37
246.4	200.0	2950.	7.469E-04	1.86	1.80	1.49	1.11	0.74	0.37
361.5	432.6	2950.	7.469E-04	1.86	1.80	1.49	1.11	0.74	0.37

SUMMARY @ Tm = 540 R  
 =====

PEAK HEATING RATE: 80.30 (BTU/FT<sup>2</sup>\*SEC)

TOTAL HEAT LOAD: 7026.05 (BTU/FT<sup>2</sup>)

Table 16: HLLV Convective Environments for Body Point 113

HLLV FILE  
BODY POINT # 113 -- STME HOZZLE EXTT  
ASHM/3 ENGINE OUT & LIFTOFF, HIGH LOFT, LONG BURN CONVECTIVE PLUME HEATING TRAJECTORY FROM EP 55 (91-125) SEP. 26, 1964

Z (FT)	TIME (SEC)	TR (DEG R)	FILM COEFF. (BTU/FT <sup>2</sup> *SEC-DEG R)	CONVECTIVE HEATING RATE (BTU/FT <sup>2</sup> *SEC) FOR VARIOUS WALL TEMPERATURES (DEG R)					
				460	540	960	1460	1960	2460
0.0	0.0	4190.	2.200E-02	82.06	80.30	71.06	60.06	49.06	38.06
0.8	10.0	4180.	2.170E-02	80.72	78.99	69.87	59.02	48.17	37.32
3.6	20.0	4165.	2.110E-02	78.18	76.49	67.63	57.08	46.53	35.98
8.6	30.0	4140.	2.040E-02	75.07	73.44	64.87	54.67	44.47	34.27
15.6	40.0	4120.	1.930E-02	70.64	69.09	60.99	51.34	41.69	32.04
24.4	50.0	4100.	1.780E-02	64.79	63.37	55.89	46.99	38.09	29.19
34.6	60.0	4080.	1.620E-02	58.64	57.35	50.54	42.44	34.34	26.24
46.3	70.0	4060.	1.380E-02	49.68	48.58	42.78	35.88	28.90	22.00
59.4	80.0	4040.	1.190E-02	42.60	41.65	36.65	30.70	24.75	18.80
74.2	90.0	3950.	9.500E-03	33.15	32.40	28.40	23.85	18.90	14.15
90.4	100.0	3870.	7.500E-03	25.58	24.98	21.83	18.08	14.33	10.58
107.8	110.0	3760.	5.697E-03	18.80	18.34	15.95	13.10	10.25	7.41
126.0	120.0	3640.	4.200E-03	13.36	13.02	11.26	9.16	7.06	4.96
126.0	120.0	2360.	4.198E-03	7.98	7.64	5.88	3.78	1.68	-0.42
126.9	121.0	2399.	7.800E-03	15.12	14.50	11.22	7.32	3.42	-0.48
130.6	123.0	2477.	7.279E-03	14.68	14.10	11.04	7.40	3.76	0.12
134.3	125.0	2555.	6.700E-03	14.04	13.50	10.69	7.34	3.99	0.64
138.1	127.0	2633.	6.116E-03	13.29	12.80	10.23	7.17	4.12	1.06
144.5	130.0	2750.	5.204E-03	11.92	11.50	9.31	6.71	4.11	1.51
149.2	133.0	2808.	4.409E-03	10.35	10.00	8.15	5.94	3.74	1.53
152.9	135.0	2847.	3.771E-03	9.00	8.70	7.12	5.23	3.34	1.46
156.4	137.0	2886.	3.154E-03	7.65	7.40	6.08	4.50	2.92	1.34
162.8	140.3	2950.	1.701E-03	4.24	4.10	3.39	2.53	1.68	0.83
162.8	140.3	2950.	2.905E-04	0.72	0.70	0.58	0.43	0.29	0.14
178.8	150.0	2950.	2.905E-04	0.72	0.70	0.58	0.43	0.29	0.14
246.4	200.0	2950.	2.905E-04	0.72	0.70	0.58	0.43	0.29	0.14
361.5	432.6	2950.	2.905E-04	0.72	0.70	0.58	0.43	0.29	0.14

SUMMARY @ Tw = 540 R  
=====

PEAK HEATING RATE: 80.30 (BTU/FT<sup>2</sup>\*SEC)

TOTAL HEAT LOAD: 6733.92 (BTU/FT<sup>2</sup>)

Table 17: HLLV Convective Environments for Body Point 114

HLLV  
BODY POINT # 114 -- STIME NOZZLE EXIT  
ASRM/3 ENGINE OUT @ LIFTOFF, HIGH LOFT, LONG BURH CONVECTIVE PLUME HEATING TRAJECTORY FROM EP 55 (91-125) SEP. 26. 1991

ALT (FT)	TIME (SEC)	TR (DEG R)	FILM COEFF. (BTU/FT <sup>2</sup> · SEC-DEG R)	CONVECTIVE HEATING RATE (BTU/FT <sup>2</sup> ·SEC) FOR VARIOUS WALL TEMPERATURES (DEG R)					
				460	540	960	1460	1960	2460
0.0	0.0	4190.	2.200E-02	82.06	80.30	71.06	60.06	49.06	38.06
0.8	10.0	4180.	2.170E-02	80.72	78.99	69.87	59.02	48.17	37.32
3.6	20.0	4165.	2.110E-02	78.10	76.49	67.63	57.08	46.53	35.98
8.6	30.0	4140.	2.040E-02	75.07	73.44	64.87	54.67	44.47	34.27
15.6	40.0	4120.	1.930E-02	70.64	69.09	60.99	51.34	41.69	32.04
24.4	50.0	4100.	1.780E-02	64.79	63.37	55.89	46.99	38.09	29.19
34.6	60.0	4080.	1.620E-02	58.64	57.35	50.54	42.44	34.34	26.24
46.3	70.0	4060.	1.380E-02	49.68	48.58	42.78	35.88	28.98	22.08
59.4	80.0	4040.	1.190E-02	42.60	41.65	36.65	30.70	24.75	18.80
74.2	90.0	3950.	9.500E-03	33.15	32.40	28.40	23.65	18.90	14.15
90.4	100.0	3870.	7.500E-03	25.58	24.88	21.83	18.08	14.33	10.58
107.8	110.0	3760.	5.697E-03	18.80	18.34	15.95	13.10	10.25	7.41
126.0	120.0	3640.	4.200E-03	13.36	13.02	11.26	9.16	7.06	4.96
126.9	121.0	2360.	4.198E-03	7.98	7.64	5.88	3.78	1.68	-0.42
130.6	123.0	2477.	2.152E-03	4.17	4.00	3.10	2.02	0.94	-0.13
134.3	125.0	2555.	2.013E-03	4.06	3.90	3.05	2.05	1.04	0.03
138.1	127.0	2633.	1.836E-03	3.85	3.70	2.93	2.01	1.09	0.17
144.5	130.0	2750.	1.672E-03	3.63	3.50	2.80	1.96	1.13	0.29
149.2	133.0	2808.	1.403E-03	3.21	3.10	2.51	1.81	1.11	0.41
152.9	135.0	2847.	1.190E-03	2.80	2.70	2.20	1.60	1.01	0.41
156.4	137.0	2886.	9.970E-04	2.38	2.30	1.88	1.38	0.88	0.39
162.8	140.3	2950.	7.673E-04	1.86	1.80	1.48	1.09	0.71	0.33
162.8	140.3	2950.	4.564E-04	1.14	1.10	0.91	0.68	0.45	0.22
178.8	150.0	2950.	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04
246.4	200.0	2950.	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04
361.5	432.6	2950.	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04

SUMMARY @ Tw = 540 R  
=====

PEAK HEATING RATE: 80.30 (BTU/FT<sup>2</sup>·SEC)

TOTAL HEAT LOAD: 6432.73 (BTU/FT<sup>2</sup>)

Table 18: HLLV Convective Environments for Body Point 115

BOEING 747-400 - ASRB NOZZLE EXIT  
 4.543 ENGINE OUT & LIFTOFF, HIGH LOFT, LONG BURR CONVECTIVE PLUME HEATING TRAJECTORY FROM EP 55 (91-125) SEP. 26, 1991

ALT (KFT)	TIME (SEC)	TR (DEG R)	FILM COEFF. (BTU/FT <sup>2</sup> · SEC-DEG R)	CONVECTIVE HEATING RATE (BTU/FT <sup>2</sup> ·SEC) FOR VARIOUS WALL TEMPERATURES (DEG R)					
				410	540	960	1460	1960	2460
0.0	0.0	4190.	2.200E-02	82.06	80.30	71.06	60.06	49.06	38.06
0.8	10.0	4180.	2.170E-02	80.72	78.99	69.87	59.02	48.17	37.32
3.6	20.0	4165.	2.110E-02	78.18	76.44	67.63	57.08	46.53	35.98
8.6	30.0	4140.	2.040E-02	75.07	73.44	64.87	54.67	44.47	34.27
15.6	40.0	4120.	1.930E-02	70.64	69.09	60.99	51.34	41.69	32.04
24.4	50.0	4100.	1.780E-02	64.79	63.37	55.89	46.99	38.09	29.19
34.6	60.0	4080.	1.620E-02	58.64	57.35	50.54	42.44	34.34	26.24
46.3	70.0	4060.	1.380E-02	49.68	48.58	42.78	35.88	28.98	22.08
59.4	80.0	4040.	1.190E-02	42.60	41.65	36.65	30.70	24.75	18.80
74.2	90.0	3950.	9.500E-03	33.15	32.40	28.40	23.65	18.90	14.15
90.4	100.0	3870.	7.500E-03	25.58	24.98	21.83	18.08	14.33	10.58
107.8	110.0	3760.	5.697E-03	18.80	18.34	15.95	13.10	10.25	7.41
126.0	120.0	3640.	4.200E-03	13.36	13.02	11.26	9.16	7.06	4.96
144.9	121.0	2360.	4.190E-03	7.98	7.64	5.88	3.78	1.68	-0.42
160.6	121.0	2399.	6.885E-03	13.35	12.80	9.91	6.47	3.02	-0.42
174.1	123.0	2477.	6.402E-03	12.91	12.40	9.71	6.51	3.31	0.11
188.1	125.0	2555.	5.856E-03	12.27	11.80	9.34	6.41	3.48	0.56
199.2	127.0	2633.	5.256E-03	11.42	11.00	8.79	6.16	3.54	0.91
193.5	130.0	2750.	4.344E-03	9.95	9.60	7.78	5.60	3.43	1.26
149.2	133.0	2808.	3.483E-03	8.18	7.90	6.44	4.70	2.95	1.21
152.9	135.0	2847.	2.940E-03	7.04	6.80	5.56	4.09	2.61	1.14
156.4	137.0	2886.	2.344E-03	5.69	5.50	4.52	3.34	2.17	1.00
162.8	140.3	2950.	1.328E-03	3.31	3.20	2.64	1.98	1.31	0.65
162.8	140.3	2950.	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
178.8	150.0	2950.	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
246.4	200.0	2950.	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
301.5	432.6	2950.	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00

SUMMARY @ Tw = 540 R  
 =====

PEAK HEATING RATE: 80.30 (BTU/FT<sup>2</sup>·SEC)

TOTAL HEAT LOAD: 6494.19 (BTU/FT<sup>2</sup>)

Table 19: HLLV Convective Environments for Body Point 116

HLLV  
BODY POINT # 116 -- ASWB NOZZLE EXIT  
ASWB/3 ENGINE OUT @ LIFTOFF, HIGH LOFT, LONG BURN CONVECTIVE PLUME HEATING TRAJECTORY FROM EP 55 (91-125) SET. 26, 1991

Z (KFT)	TIME (SEC)	TR (DEG R)	FILM COEFF. (BTU/FT <sup>2</sup> SEC -DEG R)	CONVECTIVE HEATING RATE (BTU/FT <sup>2</sup> *SEC) FOR VARIOUS WALL TEMPERATURES (DEG R)					
				460	540	960	1460	1960	2460
0.0	0.0	4190.	2.200E-02	82.06	80.30	71.06	60.06	49.06	38.06
0.8	10.0	4180.	2.170E-02	80.72	78.99	69.87	59.02	48.17	37.32
3.6	20.0	4165.	2.110E-02	78.18	76.49	67.63	57.08	46.53	35.98
8.6	30.0	4140.	2.040E-02	75.07	73.44	64.87	54.67	44.47	34.27
15.6	40.0	4120.	1.930E-02	70.64	69.09	60.99	51.34	41.69	32.04
24.4	50.0	4100.	1.780E-02	64.79	63.37	55.89	46.99	38.09	29.19
34.6	60.0	4080.	1.620E-02	58.64	57.35	50.54	42.44	34.34	26.24
46.3	70.0	4060.	1.380E-02	49.68	48.58	42.78	35.88	28.98	22.08
59.4	80.0	4040.	1.190E-02	42.60	41.65	36.65	30.70	24.75	18.80
74.2	90.0	3950.	9.500E-03	33.15	32.40	28.40	23.65	18.90	14.15
90.4	100.0	3870.	7.500E-03	25.58	24.98	21.83	18.08	14.33	10.58
107.8	110.0	3760.	5.697E-03	18.80	18.34	15.95	13.10	10.25	7.41
126.0	120.0	3640.	4.200E-03	13.36	13.02	11.26	9.16	7.06	4.96
145.0	120.0	2360.	4.198E-03	7.98	7.64	5.88	3.78	1.68	-0.42
176.9	121.0	2399.	7.800E-03	15.12	14.50	11.22	7.32	3.42	-0.48
130.1	123.0	2477.	7.220E-03	14.58	14.00	10.96	7.35	3.74	0.12
134.3	125.0	2555.	6.650E-03	13.93	13.40	10.61	7.28	3.96	0.63
138.1	127.0	2633.	6.060E-03	13.19	12.70	10.15	7.12	4.08	1.05
144.5	130.0	2750.	5.150E-03	11.81	11.40	9.23	6.65	4.08	1.50
149.2	133.0	2808.	4.321E-03	10.15	9.80	7.99	5.82	3.66	1.50
152.9	135.0	2847.	3.684E-03	8.79	8.50	6.95	5.11	3.27	1.43
156.4	137.0	2886.	3.069E-03	7.45	7.20	5.91	4.38	2.84	1.31
162.8	140.3	2950.	1.577E-03	3.93	3.80	3.14	2.35	1.56	0.77
162.8	140.3	2950.	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
178.0	150.0	2950.	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
246.4	200.0	2950.	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
361.5	432.6	2950.	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00

SUMMARY @ TW = 540 R  
=====

PEAK HEATING RATE: 80.30 (BTU/FT<sup>2</sup>\*SEC)

TOTAL HEAT LOAD: 6526.44 (BTU/FT<sup>2</sup>)



Table 21: 1.5 Stage Radiation Environments

TOTAL PLUME RADIATION FOR:  
 1.5 Stage Plume Radiation for 6/2 with BE 75% 36-121 seconds  
 Estimated Base-Gas Burning Added 50-120 ft  
 NLS 1.5 Stage Plume Heating Trajectory (6/2 EP55 (91-126) Sep. 1991)

Alt (kft)	Time* (sec)	Heating Rate (Btu/ft <sup>2</sup> -sec) for Points Listed	201	205	206	208	209
0.	0.0	4.98	9.82	5.90	13.48	6.72	6.70
0.	5.0	4.97	9.78	5.88	13.42	6.70	6.70
1.	10.0	4.93	9.66	5.81	13.23	6.61	6.46
2.	15.0	4.86	9.46	5.68	12.91	6.46	6.46
3.	20.0	4.70	8.97	5.39	12.14	6.11	6.11
5.	25.0	4.38	8.15	4.89	10.90	5.53	5.53
8.	30.0	3.91	6.94	4.14	9.05	4.65	4.65
11.	35.0	3.43	5.71	3.41	7.24	3.80	3.80
12.	37.0	3.27	5.36	3.19	6.70	3.53	3.53
13.	38.0	3.56	6.41	3.90	7.80	4.92	4.92
14.	40.0	3.31	5.88	3.56	7.17	4.46	4.46
18.	45.0	2.83	4.89	2.92	5.97	3.62	3.62
23.	50.0	2.50	4.20	2.50	5.10	3.06	3.06
28.	55.0	2.23	3.63	2.18	4.36	2.64	2.64
33.	60.0	1.93	3.02	1.84	3.55	2.19	2.19
38.	65.0	1.63	2.42	1.48	2.81	1.71	1.71
44.	70.0	1.43	2.03	1.25	2.32	1.40	1.40
51.	75.0	1.72	2.50	1.68	3.48	2.30	2.30
57.	80.0	2.02	2.98	2.11	4.69	3.20	3.20
65.	85.0	1.90	2.85	2.18	4.23	2.91	2.91
72.	90.0	1.83	2.80	2.11	3.86	2.73	2.73
80.	95.0	1.74	2.74	2.15	3.48	2.55	2.55
89.	100.0	1.59	2.37	1.85	3.05	2.24	2.24
97.	105.0	1.42	2.01	1.57	2.62	1.93	1.93
106.	110.0	1.26	1.65	1.27	2.19	1.62	1.62
115.	115.0	1.08	1.26	0.97	1.76	1.31	1.31
125.	120.0	0.68	0.83	0.62	1.36	1.04	1.04
127.	121.0	0.67	0.81	0.61	1.35	1.05	1.05
129.	122.0	0.77	0.92	0.64	1.40	0.95	0.95
135.	125.0	0.71	0.85	0.60	1.38	0.94	0.94
145.	130.0	0.62	0.74	0.55	1.35	0.93	0.93
149.	132.0	0.58	0.70	0.52	1.34	0.93	0.93
151.	132.9	0.48	0.57	0.46	1.31	0.91	0.91
177.	146.0	0.48	0.57	0.46	1.31	0.91	0.91
499.	403.0	0.48	0.57	0.46	1.31	0.91	0.91
501.	421.9	0.48	0.57	0.46	1.31	0.91	0.91
Heat Load **		469.62	731.45	491.01	1131.08	693.57	

PRECEDING PAGE BLANK NOT FILMED

Table 22: 1.5 Stage Convective Environments for Body Point 201

MIL-15 STAGE REFERENCE VEHICLE  
 BODY POINT # 201 -- (CORE BASE HEAT SHIELD  
 5/2 HIGH LOW, LONG BURR CONVECTIVE PLUME HEATING TRAJECTORY FROM EP 55 (91-126) SEP. 26, 1991

ALT (KFT)	TIME (SEC)	TP (DEG R)	FILM COEFF. (BTU/FT <sup>2</sup> * SEC-DEG R)	CONVECTIVE HEATING RATE (BTU/FT <sup>2</sup> *SEC) FOR VARIOUS WALL TEMPERATURES (DEG R)					
				460	540	960	1460	1960	2460
0.0	0.0	4190.	2.200E-02	82.06	80.30	71.06	60.06	49.06	38.06
0.8	10.0	4180.	2.170E-02	80.72	78.99	69.87	59.02	48.17	37.32
3.2	20.0	4165.	2.110E-02	78.18	76.49	67.63	57.08	46.53	35.98
7.7	30.0	4145.	2.060E-02	75.91	74.26	65.61	55.31	45.01	34.71
12.1	37.0	4130.	2.000E-02	73.40	71.80	63.40	53.40	43.40	33.40
12.9	38.0	4130.	2.000E-02	73.40	71.80	63.40	53.40	43.40	33.40
22.8	50.0	4110.	1.950E-02	71.17	69.61	61.42	51.67	41.92	32.17
32.7	60.0	4085.	1.650E-02	59.81	58.49	51.56	43.31	35.06	26.81
44.2	70.0	4065.	1.400E-02	50.47	49.35	43.47	36.47	29.47	22.47
57.4	80.0	4045.	1.200E-02	43.02	42.06	37.02	31.02	25.02	19.02
72.3	90.0	3960.	9.600E-03	33.60	32.83	28.80	24.00	19.20	14.40
88.6	100.0	3880.	7.600E-03	25.99	25.38	22.19	18.39	14.59	10.79
106.1	110.0	3765.	5.800E-03	19.17	18.70	16.27	13.37	10.47	7.57
124.8	120.0	3645.	4.300E-03	13.70	13.35	11.55	9.40	7.25	5.10
124.8	120.0	2355.	4.300E-03	8.15	7.80	6.00	3.85	1.70	-0.45
126.7	121.0	2388.	3.517E-03	6.78	6.50	5.02	3.26	1.51	-0.25
130.6	123.0	2454.	3.292E-03	6.56	6.30	4.92	3.27	1.63	-0.02
134.5	125.0	2520.	3.081E-03	6.35	6.10	4.81	3.27	1.73	0.10
130.5	127.0	2586.	2.786E-03	5.92	5.70	4.53	3.14	1.74	0.35
144.6	130.0	2684.	2.332E-03	5.19	5.00	4.02	2.85	1.69	0.52
150.6	132.9	2780.	1.830E-03	4.25	4.10	3.33	2.42	1.50	0.59
150.6	132.9	2780.	9.375E-04	2.17	2.10	1.71	1.24	0.77	0.30
158.9	136.9	2930.	8.787E-04	2.17	2.10	1.73	1.29	0.85	0.41
177.4	146.0	2950.	8.714E-04	2.17	2.10	1.73	1.30	0.86	0.43
490.6	393.0	2950.	8.714E-04	2.17	2.10	1.73	1.30	0.86	0.43
490.7	403.0	2500.	1.071E-03	2.19	2.10	1.65	1.11	0.58	0.04
501.1	421.9	2500.	1.071E-03	2.19	2.10	1.65	1.11	0.58	0.04

SUMMARY @ Tw = 540 R  
 =====

PEAK HEATING RATE: 80.30 (BTU/FT<sup>2</sup>\*SEC)

TOTAL HEAT LOAD: 7122.42 (BTU/FT<sup>2</sup>)

Table 24: 1.5 Stage Convective Environments for Body Point 203

III. 1.5 STAGE REFERENCE VEHICLE  
 BODY POINT # 203 -- CORE BASE HEAT SHIELD  
 6% HIGH LOW, LONG BURST CONVECTIVE PLUME HEATING TRAJECTORY FROM EP 55 (91-126) SEC. 26, 1991

ALT (KFT)	TIME (SEC)	TP (DEG R)	FILM COEFF. (BTU/FT <sup>2</sup> SEC-DEG R)	CONVECTIVE HEATING RATE (BTU/FT <sup>2</sup> SEC) FOR VARIOUS WALL TEMPERATURES (DEG R)					
				460	540	960	1460	1960	2460
0.0	0.0	4190.	2.200E-02	82.06	80.30	71.06	60.06	49.06	38.06
0.8	10.0	4180.	2.170E-02	80.72	78.99	69.87	59.02	48.17	37.32
3.2	20.0	4165.	2.110E-02	78.18	76.49	67.63	57.08	46.53	35.98
7.7	30.0	4145.	2.060E-02	75.91	74.26	65.61	55.31	45.01	34.71
12.1	37.0	4130.	2.000E-02	73.40	71.80	63.40	53.40	43.40	33.40
12.9	38.0	4130.	2.000E-02	73.40	71.80	63.40	53.40	43.40	33.40
22.8	50.0	4110.	1.950E-02	71.17	69.61	61.42	51.67	41.92	32.17
32.7	60.0	4085.	1.850E-02	59.81	58.49	51.56	43.31	35.06	26.81
44.2	70.0	4065.	1.400E-02	50.47	49.35	43.47	36.47	29.47	22.47
57.4	80.0	4045.	1.200E-02	43.02	42.06	37.02	31.02	25.02	19.02
72.3	90.0	3960.	9.600E-03	33.60	32.83	28.80	24.00	19.20	14.40
88.6	100.0	3880.	7.600E-03	25.99	25.38	22.19	18.39	14.59	10.79
106.1	110.0	3765.	5.800E-03	19.17	18.70	16.27	13.37	10.47	7.57
124.8	120.0	3645.	4.300E-03	13.70	13.35	11.55	9.40	7.25	5.10
126.7	121.0	2388.	4.300E-03	8.15	7.80	6.00	3.85	1.70	-0.45
130.6	123.0	2454.	7.576E-04	1.46	1.40	1.08	0.70	0.32	-0.05
134.5	125.0	2520.	7.053E-04	1.41	1.35	1.05	0.70	0.35	0.00
138.5	127.0	2586.	6.566E-04	1.35	1.30	1.02	0.70	0.37	0.04
144.6	130.0	2684.	6.109E-04	1.30	1.25	0.99	0.69	0.38	0.08
150.6	132.9	2780.	5.364E-04	1.19	1.15	0.97	0.66	0.39	0.12
150.6	132.9	2780.	4.911E-04	1.14	1.10	0.89	0.65	0.40	0.16
150.9	136.9	2930.	8.929E-05	0.21	0.20	0.16	0.12	0.07	0.03
177.4	146.0	2950.	8.368E-05	0.21	0.20	0.16	0.12	0.08	0.04
495.6	393.0	2950.	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04
498.7	403.0	2500.	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04
501.1	421.9	2500.	1.020E-04	0.21	0.20	0.16	0.11	0.06	0.00
			1.020E-04	0.21	0.20	0.16	0.11	0.06	0.00

SUMMARY @ T<sub>w</sub> = 540 R  
 =====

PEAK HEATING RATE: 80.30 (BTU/FT<sup>2</sup>SEC)

TOTAL HEAT LOAD: 6519.36 (BTU/FT<sup>2</sup>)

Table 25: 1.5 Stage Convective Environments for Body Point 204

PHASE 1.5 STAGE REFERENCE VEHICLE  
BODY POINT # 204 -- CORE BASE HEAT SHIELD  
LONG BURST CONVECTIVE PLUME HEATING TRAJECTORY FROM EP 55 (91-126) SEP. 26. 1991

TIME (FT)	TIME (SEC)	TR (DEG R)	FILM COEFF. (BTU/FT <sup>2</sup> * SEC-DEG R)	460	540	960	1460	1960	2460
0.0	0.0	4190.	2.200E-02	82.06	80.30	71.06	60.06	49.06	38.06
0.8	10.0	4180.	2.170E-02	80.72	78.99	69.87	59.02	48.17	37.32
3.2	20.0	4165.	2.110E-02	78.18	76.49	67.63	57.08	46.53	35.98
7.7	30.0	4145.	2.060E-02	75.91	74.26	65.61	55.31	45.01	34.71
12.1	37.0	4130.	2.000E-02	73.40	71.80	63.40	53.40	43.40	33.40
22.9	38.0	4130.	2.000E-02	73.40	71.80	63.40	53.40	43.40	33.40
22.9	50.0	4110.	1.950E-02	71.17	69.61	61.42	51.67	41.92	32.17
32.7	60.0	4085.	1.650E-02	59.81	58.49	51.56	43.31	35.06	26.81
44.2	70.0	4065.	1.400E-02	50.47	49.35	43.47	36.47	29.47	22.47
57.4	80.0	4045.	1.200E-02	43.02	42.06	37.02	31.02	25.02	19.02
72.3	90.0	3960.	9.600E-03	33.60	32.83	28.80	24.00	19.20	14.40
88.6	100.0	3880.	7.600E-03	25.99	25.38	22.19	18.39	14.59	10.79
106.1	110.0	3765.	5.800E-03	19.17	18.70	16.27	13.37	10.47	7.57
124.8	120.0	3645.	4.300E-03	13.70	13.35	11.55	9.40	7.25	5.10
124.8	120.0	2355.	4.300E-03	8.15	7.80	6.00	3.85	1.70	-0.45
126.7	121.0	2388.	2.760E-03	5.37	5.10	3.94	2.56	1.18	-0.20
130.6	123.0	2454.	2.612E-03	5.21	5.00	3.90	2.60	1.29	-0.02
134.5	125.0	2520.	2.374E-03	4.89	4.70	3.70	2.52	1.33	0.14
138.5	127.0	2586.	2.151E-03	4.57	4.40	3.50	2.42	1.35	0.27
144.6	130.0	2684.	1.772E-03	3.94	3.80	3.06	2.17	1.28	0.40
150.6	132.9	2780.	1.362E-03	3.16	3.05	2.48	1.80	1.12	0.44
150.6	132.9	2780.	8.929E-05	0.21	0.20	0.16	0.12	0.07	0.03
158.9	136.9	2930.	8.368E-05	0.21	0.20	0.16	0.12	0.08	0.04
177.4	146.0	2950.	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04
495.6	393.0	2950.	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04
498.7	403.0	2500.	1.020E-04	0.21	0.20	0.16	0.11	0.06	0.00
503.1	421.9	2500.	1.020E-04	0.21	0.20	0.16	0.11	0.06	0.00

SUMMARY @ Tw = 540 R  
=====

PEAK HEATING RATE: 80.30 (BTU/FT<sup>2</sup>\*SEC)

TOTAL HEAT LOAD: 6557.53 (BTU/FT<sup>2</sup>)

Table 26: 1.5 Stage Convective Environments for Body Point 205

ML: 1.5 STAGE REFERENCE VENT-11  
 BODY POINT # 205 -- STIME HEAT SHIELD  
 6/2 HIGH LOW, LONG BURD CONVECTIVE PLUME HEATING TRAJECTORY FROM EF 55 (91-126) SEP. 26, 1991

ALT (REF)	TIME (SEC)	TP (DEG R)	FILM COEFF. (BTU/FT <sup>2</sup> SEC-DEG R)		460	540	960	1460	1960	2460
			BTU/FT <sup>2</sup>	SEC-DEG R						
0.0	0.0	4190.	2.200E-02		82.06	80.30	71.06	60.06	49.06	38.06
0.8	10.0	4180.	2.170E-02		80.72	78.99	69.87	59.02	48.17	37.32
3.2	20.0	4165.	2.110E-02		78.18	76.49	67.63	57.08	46.53	35.98
7.7	30.0	4145.	2.060E-02		75.91	74.26	65.61	55.31	45.01	34.71
12.1	37.0	4130.	2.000E-02		73.40	71.80	63.40	53.40	43.40	33.40
12.9	38.0	4130.	2.000E-02		73.40	71.80	63.40	53.40	43.40	33.40
22.8	50.0	4110.	1.950E-02		71.17	69.61	61.42	51.67	41.92	32.17
32.7	60.0	4085.	1.650E-02		59.81	58.49	51.56	43.31	35.06	26.81
44.2	70.0	4065.	1.400E-02		50.47	49.35	43.47	36.47	29.47	22.47
57.4	80.0	4045.	1.200E-02		43.02	42.06	37.02	31.02	25.02	19.02
72.3	90.0	3960.	9.600E-03		33.60	32.83	28.80	24.00	19.20	14.40
88.6	100.0	3880.	7.600E-03		25.99	25.38	22.19	18.39	14.59	10.79
106.1	110.0	3765.	5.800E-03		19.17	18.70	16.27	13.37	10.47	7.57
124.8	120.0	3645.	4.300E-03		13.70	13.35	11.55	9.40	7.25	5.10
126.7	120.0	2355.	4.300E-03		8.15	7.80	6.00	3.85	1.70	-0.45
130.6	121.0	2300.	5.898E-03		11.37	10.90	8.42	5.47	2.52	-0.42
134.5	123.0	2454.	5.590E-03		11.15	10.70	8.35	5.56	2.76	-0.03
138.5	125.0	2520.	5.253E-03		10.82	10.40	8.19	5.57	2.94	0.32
144.6	127.0	2586.	4.888E-03		10.39	10.00	7.95	5.50	3.06	0.62
150.6	130.0	2684.	3.965E-03		8.82	8.50	6.83	4.85	2.87	0.89
150.6	132.9	2780.	3.000E-03		7.15	6.90	5.61	4.07	2.53	0.99
158.9	132.9	2780.	1.786E-03		4.14	4.00	3.25	2.36	1.46	0.57
177.4	136.9	2930.	1.674E-03		4.13	4.00	3.30	2.46	1.62	0.79
495.6	146.0	2950.	1.660E-03		4.13	4.00	3.30	2.47	1.64	0.81
498.7	393.0	2950.	1.660E-03		4.13	4.00	3.30	2.47	1.64	0.81
501.1	403.0	2500.	2.041E-03		4.16	4.00	3.14	2.12	1.10	0.08
501.1	421.9	2500.	2.041E-03		4.16	4.00	3.14	2.12	1.10	0.08

SUMMARY Ψ T<sub>w</sub> = 540 R  
 =====

PEAK HEATING RATE: 80.30 (BTU/FT<sup>2</sup>•SEC)

TOTAL HEAT LOAD: 7720.64 (BTU/FT<sup>2</sup>)

Table 27: 1.5 Stage Convective Environments for Body Point 206

1.5 STAGE REFERENCE VEHICLE  
 BODY POINT # 206 -- 5 TIME HEAT SHIELD  
 6.2: HIGH LOW: LONG BURN CONVECTIVE PLUME HEATING TRAJECTORY FROM EP 55 (91-126) SEP. 26, 1951

ALT (KFT)	TIME (SEC)	TK (DEG R)	FILM COEFF. (BTU/FT <sup>2</sup> SEC-DEG R)	CONVECTIVE HEATING RATE (BTU/FT <sup>2</sup> *SEC) FOR VARIOUS WALL TEMPERATURES (DEG R)					
				460	540	960	1460	2460	
0.0	0.0	4190.	2.200E-02	82.06	80.30	71.06	60.06	49.06	38.06
0.8	10.0	4180.	2.170E-02	80.72	78.99	69.87	59.02	48.17	37.32
3.2	20.0	4165.	2.110E-02	78.18	76.49	67.63	57.08	46.53	35.98
7.7	30.0	4145.	2.060E-02	75.91	74.26	65.61	55.31	45.01	34.71
12.1	37.0	4130.	2.000E-02	73.40	71.80	63.40	53.40	43.40	33.40
12.9	38.0	4130.	2.000E-02	73.40	71.80	63.40	53.40	43.40	33.40
22.8	50.0	4110.	1.950E-02	71.17	69.61	61.42	51.67	41.92	32.17
32.7	60.0	4085.	1.650E-02	59.81	58.49	51.56	43.31	35.06	26.81
44.2	70.0	4065.	1.400E-02	50.47	49.35	43.47	36.47	29.47	22.47
57.4	80.0	4045.	1.200E-02	43.02	42.06	37.02	31.02	25.02	19.02
72.3	90.0	3960.	9.600E-03	33.60	32.83	28.80	24.00	19.20	14.40
88.6	100.0	3880.	7.600E-03	25.99	25.38	22.19	18.39	14.59	10.79
106.1	110.0	3765.	5.800E-03	19.17	18.70	16.27	13.37	10.47	7.57
124.8	120.0	3645.	4.300E-03	13.70	13.35	11.55	9.40	7.25	5.10
144.7	121.0	2355.	4.300E-03	8.15	7.80	6.00	3.85	1.70	-0.45
130.6	123.0	2454.	4.232E-03	8.66	8.30	6.41	4.17	1.92	-0.32
134.5	125.0	2520.	4.040E-03	8.44	8.10	6.32	4.21	2.09	-0.03
138.5	127.0	2586.	3.617E-03	8.32	8.00	6.30	4.28	2.26	0.24
144.6	130.0	2684.	3.032E-03	7.69	7.40	5.88	4.07	2.26	0.46
150.6	132.9	2780.	2.277E-03	6.74	6.50	5.23	3.71	2.19	0.68
150.6	132.9	2780.	8.929E-05	5.28	5.10	4.14	3.01	1.87	0.73
158.9	136.9	2930.	8.368E-05	0.21	0.20	0.16	0.12	0.07	0.03
177.4	146.0	2950.	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04
495.6	393.0	2950.	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04
498.7	403.0	2500.	1.020E-04	0.21	0.20	0.16	0.11	0.06	0.00
501.1	421.9	2500.	1.020E-04	0.21	0.20	0.16	0.11	0.06	0.00

SUMMARY @ Tw = 540 R  
 =====

PEAK HEATING RATE: 80.30 (BTU/FT<sup>2</sup>\*SEC)

TOTAL HEAT LOAD: 6593.57 (BTU/FT<sup>2</sup>)

Table 28: 1.5 Stage Convective Environments for Body Point 207

REF: 1.5 STAGE REFERENCE CELL  
 BODY POINT # 207 -- STME HEAT SHIELD  
 (2) HIGH LOW, LONG BURD, CONVECTIVE PLUME HEATING TRAJECTORY FROM ET 55 (91-126) SEP. 26, 1991

ALT (FT)	TIME (SEC)	TW (DEG R)	FILM COEFF. (BTU/FT <sup>2</sup> SEC-DEG R)	CONVECTIVE HEATING RATE (BTU/FT <sup>2</sup> *SEC) FOR VARIOUS WALL TEMPERATURES (DEG R)					
				460	540	960	1460	1960	2460
0.0	0.0	4190.	2.200E-02	82.06	80.30	71.06	60.06	49.06	38.06
0.8	10.0	4180.	2.170E-02	80.72	78.99	69.87	59.02	48.17	37.32
3.2	20.0	4165.	2.110E-02	78.18	76.49	67.63	57.08	46.53	35.98
7.7	30.0	4145.	2.060E-02	75.91	74.26	65.61	55.31	45.01	34.71
12.1	37.0	4130.	2.000E-02	73.40	71.80	63.40	53.40	43.40	33.40
12.9	38.0	4130.	2.000E-02	73.40	71.80	63.40	53.40	43.40	33.40
22.8	50.0	4110.	1.950E-02	71.17	69.61	61.42	51.67	43.40	33.40
32.7	60.0	4085.	1.650E-02	59.81	58.49	51.56	43.31	35.06	26.81
44.2	70.0	4065.	1.400E-02	50.47	49.35	43.47	36.47	29.47	22.47
57.4	80.0	4045.	1.200E-02	43.02	42.06	37.02	31.02	25.02	19.02
72.3	90.0	3960.	9.600E-03	33.60	32.83	28.80	24.00	19.20	14.40
88.6	100.0	3880.	7.600E-03	25.99	25.38	22.19	18.39	14.59	10.79
106.1	110.0	3765.	5.800E-03	19.17	18.70	16.27	13.37	10.47	7.57
124.8	120.0	3645.	4.300E-03	13.70	13.35	11.55	9.40	7.25	5.10
126.7	121.0	2380.	4.491E-03	8.15	7.80	6.00	3.85	1.70	-0.45
130.0	123.0	2454.	4.232E-03	8.66	8.30	6.41	4.17	1.92	-0.32
134.5	125.0	2520.	4.040E-03	8.44	8.10	6.32	4.21	2.09	-0.03
138.5	127.0	2586.	3.617E-03	8.32	8.00	6.30	4.28	2.26	0.24
144.6	130.0	2684.	3.032E-03	7.69	7.40	5.88	4.07	2.26	0.46
150.6	132.9	2780.	2.277E-03	6.74	6.50	5.23	3.71	2.19	0.68
150.6	132.9	2780.	0.000E+00	5.28	5.10	4.14	3.01	1.87	0.73
158.9	136.9	2930.	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
177.4	146.0	2950.	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
495.6	393.0	2950.	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
498.7	403.0	2500.	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
501.1	421.9	2500.	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00

SUMMARY @ Tw = 540 R  
 =====

PEAK HEATING RATE: 80.30 (BTU/FT<sup>2</sup>\*SEC)

TOTAL HEAT LOAD: 6535.77 (BTU/FT<sup>2</sup>)

Table 29: 1.5 Stage Convective Environments for Body Point 208

NLS 1.5 STAGE REFERENCE VEHICLE  
 BODY POINT # 208 -- 1000 STME NOZZLE (LIP)  
 6.72 HIGH LOW, LONG BURH CONVECTIVE PLUME HEATING TRAJECTORY FROM EP-55 (91-126) SEP. 26, 1981

ALT (KFT)	TIME (SEC)	TR (DEG R)	FILM COEFF. (BTU/FT <sup>2</sup> · SEC-DEG R)	CONVECTIVE HEATING RATE (BTU/FT <sup>2</sup> ·SEC) FOR VARIOUS WALL TEMPERATURES (DEG R)					
				460	540	960	1460	1960	2460
0.0	0.0	4190.	2.200E-02	82.06	80.30	71.06	60.06	49.06	38.06
0.8	10.0	4180.	2.170E-02	80.72	78.99	69.87	59.02	48.17	37.32
3.2	20.0	4165.	2.110E-02	78.18	76.49	67.63	57.08	46.53	35.98
7.7	30.0	4145.	2.060E-02	75.91	74.26	65.61	55.31	45.01	34.71
12.1	37.0	4130.	2.000E-02	73.40	71.80	63.40	53.40	43.40	33.40
12.9	38.0	4130.	2.000E-02	73.40	71.80	63.40	53.40	43.40	33.40
22.0	50.0	4110.	1.950E-02	71.17	69.61	61.42	51.67	41.92	32.17
32.7	60.0	4085.	1.650E-02	59.81	58.49	51.56	43.31	35.06	26.81
44.2	70.0	4065.	1.400E-02	50.47	49.35	43.47	36.47	29.47	22.47
57.4	80.0	4045.	1.200E-02	43.02	42.06	37.02	31.02	25.02	19.02
72.3	90.0	3960.	9.600E-03	33.60	32.83	28.80	24.00	19.20	14.40
88.6	100.0	3880.	7.600E-03	25.99	25.38	22.19	18.39	14.59	10.79
106.1	110.0	3765.	5.800E-03	19.17	18.70	16.27	13.37	10.47	7.57
124.8	120.0	3645.	4.300E-03	13.70	13.35	11.55	9.40	7.25	5.10
144.8	120.0	2355.	4.300E-03	8.15	7.80	6.00	3.85	1.70	-0.45
170.7	121.0	2388.	9.416E-03	18.15	17.40	13.45	8.74	4.03	-0.68
190.6	123.0	2454.	8.986E-03	17.92	17.20	13.43	8.93	4.44	-0.05
194.5	125.0	2520.	8.586E-03	17.69	17.00	13.39	9.10	4.81	0.52
198.5	127.0	2586.	7.918E-03	16.83	16.20	12.87	8.92	4.96	1.00
194.6	130.0	2684.	6.670E-03	14.83	14.30	11.50	8.16	4.83	1.49
150.6	132.9	2780.	5.804E-03	13.46	13.00	10.56	7.66	4.76	1.86
150.6	132.9	2780.	2.857E-03	6.63	6.40	5.20	3.77	2.34	0.91
150.9	136.9	2930.	2.678E-03	6.61	6.40	5.28	3.94	2.60	1.26
177.4	146.0	2950.	2.656E-03	6.61	6.40	5.28	3.96	2.63	1.30
499.6	393.0	2950.	2.656E-03	6.61	6.40	5.28	3.96	2.63	1.30
490.7	403.0	2500.	3.265E-03	6.66	6.40	5.03	3.40	1.76	0.13
501.1	421.9	2500.	3.265E-03	6.66	6.40	5.03	3.40	1.76	0.13

SUMMARY @ Tw = 540 R  
 =====

PEAK HEATING RATE: 80.30 (BTU/FT<sup>2</sup>·SEC)

TOTAL HEAT LOAD: #491.62 (BTU/FT<sup>2</sup>)



Table 30: 1.5 Stage Convective Environments for Body Point 209

MILS 1.5 STAGE REFERENCE VEHICLE  
 BODY POINT # 209 -- 1480 STAGE NOZZLE (LIP)  
 67: HIGH LOW, LONG BURD CONVECTIVE PLUME HEATING TRAJECTORY FROM EP 55 (91-126) SEP. 26, 1991

ALT (FEET)	TIME (SEC)	TEMP (DEG F)	FILM (COEFF. (BTU/FT <sup>2</sup> · SEC-DEG R)	CONVECTIVE HEATING RATE (BTU/FT <sup>2</sup> ·SEC) FOR VARIOUS WALL TEMPERATURES (DEG R)					
				340	540	960	1460	1960	2460
0.0	0.0	4190.	2.200E-02	82.06	80.30	71.06	60.06	49.06	38.06
0.8	10.0	4180.	2.170E-02	80.77	78.99	69.87	59.02	48.17	37.32
3.2	20.0	4165.	2.110E-02	78.18	76.49	67.63	57.08	46.53	35.98
7.7	30.0	4145.	2.060E-02	75.91	74.26	65.61	55.31	45.01	34.71
12.1	37.0	4130.	2.000E-02	73.40	71.80	63.40	53.40	43.40	33.40
12.9	38.0	4130.	2.000E-02	73.40	71.80	63.40	53.40	43.40	33.40
22.8	50.0	4110.	1.950E-02	71.17	69.61	61.42	51.67	41.92	32.17
32.7	60.0	4085.	1.650E-02	59.81	58.49	51.56	43.31	35.06	26.81
44.2	70.0	4065.	1.400E-02	50.47	49.35	43.47	36.47	29.47	22.47
57.4	80.0	4045.	1.200E-02	43.02	42.06	37.02	31.02	25.02	19.02
72.3	90.0	3960.	9.600E-03	33.60	32.83	28.80	24.00	19.20	14.40
88.6	100.0	3880.	7.600E-03	25.99	25.38	22.19	18.39	14.59	10.79
106.1	110.0	3765.	5.800E-03	19.17	18.70	16.27	13.37	10.47	7.57
124.8	120.0	3645.	4.300E-03	13.70	13.35	11.55	9.40	7.25	5.10
126.7	121.0	2355.	4.300E-03	8.15	7.80	6.00	3.85	1.70	-0.45
130.6	123.0	2388.	6.981E-03	13.46	12.90	9.97	6.48	2.99	-0.50
134.5	125.0	2454.	6.583E-03	13.13	12.60	9.84	6.54	3.25	-0.04
138.5	127.0	2520.	6.111E-03	12.59	12.10	9.53	6.48	3.42	0.37
144.6	130.0	2586.	5.767E-03	12.26	11.80	9.38	6.49	3.61	0.73
146.6	132.9	2684.	4.664E-03	10.37	10.00	8.04	5.71	3.38	1.04
150.6	132.9	2780.	3.661E-03	8.49	8.20	6.66	4.83	3.00	1.17
158.9	136.9	2830.	8.929E-05	0.21	0.20	0.16	0.12	0.07	0.03
177.4	146.0	2950.	8.368E-05	0.21	0.20	0.16	0.12	0.08	0.04
495.6	393.0	2950.	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04
498.7	403.0	2500.	1.020E-04	0.21	0.20	0.16	0.11	0.08	0.04
503.1	421.9	2500.	1.020E-04	0.21	0.20	0.16	0.11	0.06	0.00

SUMMARY @ TW = 540 R  
 =====

PEAK HEATING RATE: 80.30 (BTU/FT<sup>2</sup>·SEC)

TOTAL HEAT LOAD: 6643.49 (BTU/FT<sup>2</sup>)

Table 31: 1.5 Stage Convective Environments for Body Point 210

1.5 STAGE REFERENCE VELOCITY  
 BODY POINT # 210 -- OUTRIG-STEM NOZZLE (LIF)  
 C. HIGH LOW, LONG BURH (CONVECTIVE PLUME HEATING TRAJECTORY FROM EP 55 (91-126) SEP. 26, 1961

ALT (KFT)	TIME (SEC)	TH (DEG R)	FILM COEFF. (BTU/FT <sup>2</sup> · SEC-DEG K)	CONVECTIVE HEATING RATE (BTU/FT <sup>2</sup> ·SEC) FOR VARIOUS WALL TEMPERATURES (DEG R)					
				460	540	960	1460	1960	2460
0.0	0.0	4190.	2.200E-02	82.06	80.30	71.06	60.06	49.06	38.06
0.8	10.0	4180.	2.170E-02	80.72	78.99	69.87	59.02	48.17	37.32
3.2	20.0	4165.	2.110E-02	78.18	76.49	67.63	57.08	46.53	35.98
7.7	30.0	4145.	2.060E-02	75.91	74.26	65.61	55.31	45.01	34.71
12.1	37.0	4130.	2.000E-02	73.40	71.80	63.40	53.40	43.40	33.40
12.9	38.0	4130.	2.000E-02	73.40	71.80	63.40	53.40	43.40	33.40
22.8	50.0	4110.	1.950E-02	71.17	69.61	61.42	51.67	41.92	32.17
32.7	60.0	4085.	1.650E-02	59.81	58.49	51.56	43.31	35.06	26.81
44.2	70.0	4065.	1.400E-02	50.47	49.35	43.47	36.47	29.47	22.47
57.4	80.0	4045.	1.200E-02	43.02	42.06	37.02	31.02	25.02	19.02
72.3	90.0	3960.	9.600E-03	33.60	32.80	28.80	24.00	19.20	14.40
88.6	100.0	3880.	7.600E-03	25.99	25.38	22.19	18.39	14.59	10.79
106.1	110.0	3765.	5.800E-03	19.17	18.70	16.27	13.37	10.47	7.57
124.8	120.0	3645.	4.300E-03	13.70	13.35	11.55	9.40	7.25	5.10
126.7	120.0	3355.	4.300E-03	8.15	7.80	6.00	3.85	1.70	-0.45
130.6	123.0	3388.	4.654E-03	8.97	8.60	6.65	4.32	1.99	-0.34
134.5	125.0	2454.	4.441E-03	8.86	8.50	6.63	4.41	2.19	-0.03
138.5	127.0	2520.	4.192E-03	8.64	8.30	6.54	4.44	2.35	0.25
143.6	130.0	2586.	3.812E-03	8.10	7.80	6.20	4.29	2.39	0.48
150.6	132.9	2684.	3.218E-03	7.16	6.90	5.55	3.94	2.33	0.72
150.6	132.9	2780.	2.411E-03	5.59	5.40	4.39	3.18	1.98	0.77
158.9	136.9	2930.	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
177.4	146.0	2950.	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
495.6	393.0	2500.	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
498.7	403.0	2500.	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
501.1	421.9	2500.	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00

SUMMARY @ Tw = 540 R  
 =====

PEAK HEATING RATE: 80.30 (BTU/FT<sup>2</sup>·SEC)

TOTAL HEAT LOAD: 6540.23 (BTU/FT<sup>2</sup>)

Table 32: 1.5 Stage Convective Environments for Body Point 211

1.5 STAGE REFERENCE VEHICLE  
BODY POINT # 211 -- OUTBO STME NOZZLE (LIP)  
-- HIGH LOW, LONG BURN CONVECTIVE PLUME HEATING TRAJECTORY FROM EP 55 (91-126) SEP. '66, 1991

ALT (FEET)	TIME (SEC)	TW (DEG R)	FILM COEFF. (BTU/FT <sup>2</sup> SEC-DEG R)	CONVECTIVE HEATING RATE (BTU/FT <sup>2</sup> *SEC) FOR VARIOUS WALL TEMPERATURES (DEG R)					
				460	540	960	1460	1960	2460
0.0	0.0	4190.	2.200E-02	82.06	80.30	71.06	60.06	49.06	38.06
0.8	10.0	4180.	2.170E-02	80.72	78.99	69.87	59.02	48.17	37.32
3.2	20.0	4165.	2.110E-02	78.18	76.49	67.63	57.08	46.53	35.98
7.7	30.0	4145.	2.060E-02	75.91	74.26	65.61	55.31	45.01	34.71
12.1	37.0	4130.	2.000E-02	73.40	71.80	63.40	53.40	43.40	33.40
12.9	38.0	4130.	2.000E-02	73.40	71.80	63.40	53.40	43.40	33.40
22.8	50.0	4110.	1.950E-02	71.17	69.61	61.42	51.67	41.92	32.17
32.7	60.0	4085.	1.650E-02	59.81	58.49	51.56	43.31	35.06	26.81
44.2	70.0	4065.	1.400E-02	50.47	49.35	43.47	36.47	29.47	22.47
57.4	80.0	4045.	1.200E-02	43.02	42.06	37.02	31.02	25.02	19.02
72.3	90.0	3960.	9.600E-03	33.60	32.83	28.80	24.00	19.20	14.40
88.6	100.0	3880.	7.600E-03	25.99	25.38	22.19	18.39	14.59	10.79
106.1	110.0	3765.	5.800E-03	19.17	18.70	16.27	13.37	10.47	7.57
124.8	120.0	3645.	4.300E-03	13.70	13.35	11.55	9.40	7.25	5.10
141.7	121.0	2355.	4.300E-03	8.15	7.80	6.00	3.85	1.70	-0.45
130.6	123.0	2388.	6.439E-03	12.42	11.90	9.20	5.9H	2.76	-0.46
134.5	125.0	2454.	6.113E-03	12.19	11.70	9.13	6.08	3.02	-0.04
138.5	127.0	2520.	5.707E-03	11.76	11.30	8.90	6.05	3.20	0.34
144.6	130.0	2586.	5.230E-03	11.12	10.70	8.50	5.89	3.27	0.66
150.6	132.9	2684.	4.338E-03	9.65	9.30	7.48	5.31	3.14	0.97
150.6	132.9	2780.	3.348E-03	7.77	7.50	6.09	4.42	2.75	1.07
158.9	136.9	2830.	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
177.4	146.0	2950.	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
495.6	393.0	2950.	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
498.7	403.0	2500.	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
501.1	421.9	2500.	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00

SUMMARY @ Tw = 540 R  
=====

PEAK HEATING RATE: 80.30 (BTU/FT<sup>2</sup>\*SEC)

TOTAL HEAT LOAD: 6574.96 (BTU/FT<sup>2</sup>)


Table 33: 1.5 Stage Convective Environments for Body Point 212

MIS 1.5 STAGE REFERENCE VEHICLE  
 BODY POINT # 212 -- OUTBD SINE NOZZLE (LIP)  
 CASE HIGH LOW, LONG BURH CONVECTIVE PLUME HEATING TRAJECTORY FROM EI 55 (91-126) SEP. 26, 1961

ALT (KFI)	TIME (SEC)	TR (DEG R)	FILM COEFF. (BTU/FT <sup>2</sup> · SEC-DEG R)	CONVECTIVE HEATING RATE (BTU/FT <sup>2</sup> ·SEC) FOR VARIOUS WALL TEMPERATURES (DEG R)					
				460	540	960	1460	1960	2460
0.0	0.0	4190.	2.200E-02	82.06	80.30	71.06	60.06	49.06	38.06
0.8	10.0	4180.	2.170E-02	80.72	78.99	69.87	59.02	48.17	37.32
3.2	20.0	4165.	2.110E-02	78.18	76.49	67.63	57.08	46.53	35.98
7.7	30.0	4145.	2.060E-02	75.91	74.26	65.61	55.31	45.01	34.71
12.1	37.0	4130.	2.000E-02	73.40	71.80	63.40	53.40	43.40	33.40
12.9	38.0	4130.	2.000E-02	73.40	71.80	63.40	53.40	43.40	33.40
22.8	50.0	4110.	1.950E-02	71.17	69.61	61.42	51.67	41.92	32.17
32.7	60.0	4085.	1.650E-02	59.81	58.49	51.56	43.31	35.06	26.81
44.2	70.0	4065.	1.400E-02	50.47	49.35	43.47	36.47	29.47	22.47
57.4	80.0	4045.	1.200E-02	43.02	42.06	37.02	31.02	25.02	19.02
72.3	90.0	3960.	9.600E-03	33.60	32.83	28.80	24.00	19.20	14.40
88.6	100.0	3800.	7.600E-03	25.99	25.38	22.19	18.39	14.59	10.79
106.1	110.0	3765.	5.800E-03	19.17	18.70	16.27	13.37	10.47	7.57
124.8	120.0	3645.	4.300E-03	13.70	13.35	11.55	9.40	7.25	5.10
126.7	121.0	2335.	4.300E-03	0.15	7.80	6.00	3.85	1.70	-0.45
130.6	123.0	2388.	3.084E-03	5.95	5.70	4.40	2.86	1.32	-0.22
134.5	125.0	2454.	2.926E-03	5.83	5.60	4.37	2.91	1.45	-0.02
130.5	127.0	2520.	2.778E-03	5.72	5.50	4.33	2.94	1.56	0.17
144.6	130.0	2586.	2.493E-03	5.30	5.10	4.05	2.81	1.56	0.31
150.6	132.9	2684.	2.099E-03	4.67	4.50	3.62	2.57	1.52	0.47
150.6	132.9	2780.	1.607E-03	3.73	3.60	2.92	2.12	1.32	0.51
158.9	136.9	2930.	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
177.4	146.0	2950.	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
495.6	393.0	2950.	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
498.7	403.0	2500.	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
501.1	421.9	2500.	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00

SUMMARY @ Tw = 540 R  
 =====

PEAK HEATING RATE: 80.30 (BTU/FT<sup>2</sup>·SEC)  
 TOTAL HEAT LOAD: 6508.04 (BTU/FT<sup>2</sup>)



## REMTECH TECHNICAL NOTE

---

**SUBJECT:** August 1992 NLS 2 650K STME Base Heating Environments  
**DATE:** August 7, 1992  
**AUTHORS:** Robert L. Bender, John E. Reardon, Craig P. Schmitz and John R. Brown  
**CONTRACT NO.:** NAS8-39235  
**PREPARED FOR:** George C. Marshall Space Flight Center

---

### INTRODUCTION

Cycle 1 base heating environments for the NLS 1.5 stage vehicle were previously reported in Ref. [1]. Those environments were based upon "upper limit" methodology and conservative assumptions and, consequently, had significant impact on selection of the thermal protection system (TPS) for the base region. Following publication of Ref. [1], analyses continued in an attempt to improve our understanding of the low altitude convective base heating which was the largest contributor to the high heating levels specified for Cycle 1. A working group was formed at MSFC to direct this follow-on analysis and to coordinate the combined activities of the flowfield, environment, and thermal response analysts.

REMTECH participated in this working group and developed the engineering approach (updated methodology) used to generate the NLS 2 650K STME environments. The NLS 2 environments are specified for 13 body point locations in the base region of the NLS 2 vehicle which is the latest designation for the six-engine 1.5 stage concept. The NLS 2 engineering approach utilizes scaled Saturn V flight data and results in environments substantially lower than Cycle 1.

### INPUTS

The Cycle 2 environments have been specifically determined for the August 1992 NLS 2 vehicle with 650K thrust STMEs and trajectories [2-3] reflecting summer 1992 design and performance estimates. It was assumed that the May 1991 reference 1.5 stage vehicle base geometry was essentially unchanged for NLS 2. Base diameter, engine arrangement, and engine spacing are shown in Fig. 1. The base heat shield, engine heat shield, and nozzle closure configurations are similar to those considered in Cycle 1 and shown in Fig. 2. These schematics do not reflect the slightly larger nozzle resulting from the thrust upgrade from 583K to 650K.

The 650K STME, Rev. 26b, operates at 2250 psia chamber pressure (at full thrust) with a nozzle expansion ratio of 44/1. Increased thrust is partially accomplished by enlarging the throat which results in a larger diameter exit plane than the Cycle 1 583K engine. Essential features of the inviscid exhaust plume are unchanged from the earlier 583K STME. However, the larger nozzle does affect radiation viewfactors and reduces the spacing between the six engines which impacts the reversed plume flowfields and intensity of the resulting convection. A summary of STME 650K engine characteristics based upon engine cycle Rev. 26b is presented in Fig. 3.

The updated trajectories for NLS 2 were obtained from MSFC EP-55. Four trajectories were provided: Mission 1 nominal and engine-out, and Mission 2 nominal and engine-out. The NLS 2 nominal trajectories generally lofted more than the Cycle 1 trajectory as shown in the comparisons of Fig. 4.

## BODY POINT SELECTION

The 1.5 stage body points selected for Cycle 1 base heating analysis were retained for NLS 2. One additional point was added so environments could be specified to the sustainer thrust structure following separation of the outboard booster engines and associated heat shield/booster thrust structure. The original body point locations are shown in Fig. 5 and the new point on the schematic of Fig. 6. These locations were originally selected to provide environments at maximum heating locations on both the booster and sustainer engines as well as the heat shield. These conditions are also met for NLS 2.

## METHODOLOGY

The methodology for predicting base heating during ascent for the NLS 2 was dramatically altered following publication of Cycle 1. Of the two heating components, radiation and convective, heavy emphasis was placed on understanding and improving the convective component, particularly during the first 100 seconds of flight when burning of the STME turbine exhaust in the base region could occur. Cycle 1 convective environments were essentially upper limit estimates reflecting stoichiometric burning of the turbine exhaust with air in the base from liftoff to 100,000 ft. For NLS 2, the burning potential was addressed in detail to assess the likelihood of the stoichiometric assumption and to relate previous flight vehicle turbine exhaust disposal experience to the NLS 2 vehicle.

Since the NLS 2 is an all-liquid propellant vehicle, radiation from solid propellant boosters is not an issue and overall levels of radiation are reduced from that previously reported for the HLLV concept. However, the six engines do produce substantial levels of radiation at low altitudes for points in the base which can see the highly radiating Mach discs in the plumes from several STMEs. For this study the plume radiation models were generated by the Base Heating Design Code currently under development for NASA MSFC ED-22 [4]. A summary of previously published base heating environment reports

for NLS is presented in Fig. 7. Overviews of the radiation and convective methodologies for NLS 2 are presented in the following paragraphs.

## CONVECTION

Conventional convective base heating from plume-to-plume interactions normally begins at higher altitudes and can be determined by judicious scaling of existing launch vehicle flight environment data from vehicles with similar engines. This methodology was followed for NLS 2 where higher altitude environments were scaled from Shuttle Orbiter and Saturn V/S-II flight data as reported in Ref. [5]. The important question for NLS 2 was how to extend the methodology to treat potential heating which may result from STME turbine exhaust burning at the lower altitude, which may be substantially higher than conventional heating as depicted in the schematic of Fig. 8. In order to understand this "base burning" phenomenon better and in an attempt to verify or improve the Cycle 1 estimates, a detailed review of applicable Saturn flight data during early ascent was recommended. The Saturn vehicles utilized gas generator cycle LO<sub>2</sub>/RP-1 engines with various turbine exhaust disposal schemes during first stage ascent, so their flight experience was germane to the NLS 2 STME problem.

Defining convection requires a definition of the local heat transfer coefficient ( $h_c$ ) in the base as well as a definition of the gas temperature ( $T_g$ ) which drives the heat transfer. Following Cycle 1, the convective methodology development was conducted as shown in Fig. 9. The primary paths followed utilized Saturn flight data for  $h_c$  and Saturn gas temperature envelopes for  $T_g$ . The specific objectives of the Saturn flight data review were:

OBJECTIVE 1: Reduce heat load accumulated early in flight by refining Cycle 1 film heat transfer coefficient ( $h_2$ ) based on Saturn flight data

$$h_c = \frac{Q_{Total} - Q_{Radiation}}{T_{Gas} - T_{Wall\ of\ Total\ Cal}}$$

OBJECTIVE 2: Based on Saturn flight data, develop a methodology to reduce base gas temperature early in flight below stoichiometric if possible.

The Cycle 1 heat transfer coefficient was taken from Ref. [6] and was essentially a flight deduced  $h_c$  from the Saturn I Block II flight data. REMTECH's review of all Saturn flight data was targeted at verifying or replacing the Cycle 1  $h_c$ ; however, because the flight data were based on measurements with large uncertainty and inherent error, this effort was, for the most part, inconclusive. The salient results of the Objective 1 effort are summarized in Fig. 10. In general, the flight data were not useful in defining a "better" value of  $h_c$  at lower altitudes and a different approach was indicated.

The Saturn gas temperature data (investigated under Objective 2) were relatively consistent and repeatable, and were more useful to the NLS study. The data were separated into two main groups: the base heat shield data and the engine data. Envelopes of all data were determined as well as the statistical mean and  $1\sigma$ ,  $2\sigma$ , and  $3\sigma$



standard deviations. These envelopes showed that, early in flight, base gas temperatures are greater than the free-stream air total temperature so recirculation of some hot plume gases or turbine exhaust discharge gases had to occur. After reviewing all the flight data, it was evident that the Saturn V/S-1C stage data were more appropriate for comparison with NLS since they did not have the center cluster of four engines which affected the flowfields as do the Saturn 1 and 1B vehicles. As a result of these comparisons and after a detailed look at the S-1C stage F-1 engine turbine exhaust discharge, methodology to scale the Saturn V data to NLS conditions to predict a better base gas temperature for NLS 2 was pursued.

Details of the Saturn flight data review and comparisons of the Saturn V/S-1C stage with NLS 2 will be presented in a REMTECH technical note scheduled for release in September 1992. Some of the more important similarities in NLS 2 and the S-1C stage are summarized in Fig. 11. The basic rationale for Saturn V to NLS scaling involved the fundamental assumption that the volumetric mixing of turbine exhaust with air at the plume boundary was similar between the two vehicles, or

$$\left( \frac{\dot{V}_{AIR}}{\dot{V}_{FUEL}} \right)_{SAT V} = \left( \frac{\dot{V}_{AIR}}{\dot{V}_{FUEL}} \right)_{NLS}$$

Shear layer development/mixing along the plume boundary is assumed to be independent of turbine exhaust disposal scheme. It was also assumed that mixing differences are driven by exhaust product density differences. Justification for these assumptions and background for the scaling rationale can be summarized as follows:

#### Similar Base Geometry

- Engine spacing, total engine exit area/base area, engine length/base diameter

#### Similar External Flow

- Trajectories are comparable below 100 kft, free-stream approach flow to plume boundary shear layer, and expansion into base are similar

#### Turbine Exhaust Disposal Schemes

- Combustible turbine exhaust/total engine flow approximately equal, total turbine exhaust/total engine flow comparable

Step-by-step methodology for applying the Saturn trends to NLS 2 are described in the following paragraphs.

As noted in Fig. 10, above 40,000 ft the  $h_c$  used in Cycle 1 did envelope the flight data and was, therefore, retained for NLS 2. Below 40,000 ft, a base region Reynolds number correlation was developed to adjust  $h_c$  to a more realistic trend accounting for the simultaneous drop in base region density as altitude increases and the increase in base region velocity as the vehicle accelerates. Instead of computing specific values of local Reynolds number which requires a length or size estimate, it was decided to compute the relative change in unit Reynolds number versus the unit value at 40,000 ft, which corresponds to the initial attitude where the value of  $h_c$  was acceptable.

Using the Colburn analogy for turbulent flow where the heat transfer coefficient is proportional to Reynolds number to the 0.8 power, the local density and velocity terms in the Reynolds number were estimated and the ratios computed for various times in the trajectory between sea level and 40,000 ft. The steps are defined in Fig. 12. NLS 2 velocity was assumed to be equal at corresponding altitudes to flight deduced Saturn V velocities measured on the center F-1 engine nozzle near the lip. Measured Saturn gas temperature and pressure were used to compute base region density at each altitude considered. After applying the Reynolds number correlation to the coefficient at 40,000 ft (step 3 in Fig. 12), a coefficient history with altitude was developed as shown in Fig. 13. REMTECH and the working group agreed that this more accurately represents the variation in  $h_c$  at low altitude than the  $h_c$  previously considered in Cycle 1.

The methodology for applying the Saturn V/S-1C stage flight data to the NLS 2 gas temperature involved eight (8) distinct steps as shown schematically in Fig. 14. The starting-point was to select the Saturn flight data envelopes (from all flights where measurements were made) as reasonable upper limits on the base gas temperature for that vehicle. In step 2, the flight envelopes were corrected for gas probe errors as discussed in Ref. [7]. Next, chemical equilibrium composition (CEC) code runs were made to construct a series of combustion gas temperature curves versus air/fuel ratios for the Saturn vehicle (step 3). Fuel for these computations was assumed to be the turbine exhaust products of the F-1 engine. By comparing the envelope values of gas temperature with the combustion temperatures, it was possible to deduce a value of air-to-turbine exhaust ratio occurring in the Saturn V/S-1C base region at various altitudes as shown in step 4.

From Ref. [8], the differences in the plume shear layer mixing between the F-1 engine (Saturn) and the STME (NLS) are essentially correlatable to differences in density of the mixing gases. Thus the air-fuel ratio determined from Saturn V flight data can be scaled to NLS 2 by applying the Saturn to NLS turbine exhaust density ratio at the nozzle lip as illustrated in step 5. This produces a new air-fuel ratio for NLS 2 versus altitude as shown in step 7 which, when combined with CEC combustion temperatures for STME turbine exhaust with air, step 6, produced an estimate of gas temperature for NLS 2 as depicted in step 8.

This scaling process is more easily understood by referring to the flowfield schematic in Fig. 15. We are assuming that the mixing processes at location (A) in Fig. 15 are similar between Saturn V and NLS 2. The measured gas temperatures for Saturn V at locations (B) and (C) were used to define the amount of air mixed and burned with turbine exhaust at location (A). Conservatism was added by computing the combustion temperatures for Saturn V (step 3 in Fig. 14) turbine exhaust excluding the heat released by burning the free carbon constituent. Typical values of gas temperature for the NLS 2 STME nozzle and heat shield utilizing the methodology of Fig. 14 are shown in the right-hand graph of Fig. 15. Those temperatures represent application of the methodology to earlier 583K STME turbine exhaust composition. Temperatures utilized to compute heating rates for this report were derived from the same methodology updated to 650K STME turbine exhaust density and composition. These latest temperatures are shown in Fig. 16.

## Plume Radiation

The band-model radiation codes [9-10] which have been used for predictions of the Space Shuttle Main Engines have proven to be very reliable, but there is usually a problem obtaining the necessary flowfield descriptions for preliminary design predictions. Proper treatment of 1.5-Stage plume radiation would require a 3-D flowfield with booster and main engines at the proper thrust levels and radiation models for the burning gases in the base regions. With relative minor modification of an existing code [10], a good approximation could be made at low altitude using axisymmetric plumes representing the three radiation sources, but it would require property predictions of all three sources (booster STMEs, main-stage STMEs, and the base gas) at the same altitudes. These data were not available for this analysis, so each source was evaluated individually and the radiation from each was summed. This is a reasonable approximation for some base locations, but is generally conservative. Because of this conservatism, no safety margins were added to the predictions.

Previous work had provided STME nozzle axisymmetric plumes with a mixture ratio (MR = O<sub>2</sub>/H<sub>2</sub>) of 6 at both 75 and 100 percent thrust. These predictions were used with scaling procedures described below and estimates of the base-gas properties for the current radiation predictions. The methods used to provide estimates of the complex flowfields using these data are described below.

The STME and the application have changed slightly since the previous predictions. The nozzle size has increased slightly, and the throttled condition is now 70-percent instead of the previous 75 percent. It also appears more appropriate to use an MR of 7 rather than 6 for the main chamber.

The change in dimensions of the nozzle were made by a simple geometric scaling of the plumes to match the current nozzle exit diameter, and the 70 percent thrust condition was accommodated by pressure scaling. The pressure scaling essentially uses the previous plumes with scaled pressures which then represent plumes at a slightly higher altitude. Scaling for the change in MR was based on an evaluation of equilibrium plume conditions which indicated that a 20 percent increase in plume temperatures could be expected for the change in mixture ratio from 6 to 7. However, it was found that the 20 percent increase was too great in regions behind strong shocks, so the adjustment was reduced as the temperature increased above 3000 R so that the increase was only 5 percent at 6000 R. The H<sub>2</sub>O mole fraction was increased along with the temperature to the correct fraction for MR = 7. In order to limit the temperature and mole fraction adjustments to the unmixed portion of the plume, they were only applied to points with an N<sub>2</sub> mole fraction of less than 0.01. Conditions in the mixing layer are rather complex because of the multiple turbine exhaust injections, but the expected results of these streams are conservatively treated in the base burning model used for convection and radiation. The current plume predictions with MR=6 are conservative in mixing layer temperatures compared with an MR=7 prediction because of the increase H<sub>2</sub> fraction at MR=6.

The base burning gas properties used for radiation were those developed for the convection predictions. It was conservatively assumed that the gas extended from the

base heat shield to the nozzle exits with a diameter of 330 inches, which is approximately equal to the stage diameter. The properties were obtained from sea level to 100 kft at 20 kft intervals. Above 100 kft it is assumed that all burning stops and at 120 kft and above, the base gas is modeled as the reversed flow from the plume cluster. This is also terminated at staging.

The radiation from the plumes is most significant at low altitudes, and radiation from the base gases is most significant at 40 kft. As altitude increases, radiation from both sources decays rapidly. Mission 1 trajectories were used for all predictions, and predictions with booster engines at 100 percent and 70 percent were pieced together to represent the nominal mission without engine failure.

## 1.7 RESULTS

The radiation and convective environments are presented in both graphical and tabular format. Both nominal and engine-out Mission 1 trajectories were considered; Mission 2 was not specifically addressed since it was very close to Mission 1 for those parameters affecting base heating. The graphical results combining the radiation and convection components for cold wall conditions of 540 R are presented in Figs. 17 through 29 for the nominal engine-out Mission 1.

Convective heating rate predictions for various wall temperatures are presented versus time in Tables 1 through 26. Heat transfer coefficient and base gas temperature are included in these tables to assist the thermal analyst in assessing TPS temperature response and ablation rates. For those body points on structure (heat shield or STME TPS) which is jettisoned at separation, the environment is shown as zero after separation. Plume impingement heating and aerodynamic heating affects after separation were not addressed in this analysis. In general, peak convective heating rates now occur about 50 sec into flight and are reduced below sea level Cycle 1 heating rates by about 40 percent. Convective heat load is substantially reduced for these latest environments to magnitudes about one-third of those associated with Cycle 1.

The predictions for plume radiation for the nominal and engine-out missions are shown in Tables 27 and 28. In each table the body points on the booster engine structure are presented separately, so heating is terminated at separation. Since the peak plume radiation rate occurs at sea level, the peak plume radiation is identical for both trajectories. The heating rates for the normal trajectory generally rise when the booster engines are throttled, but the longer-duration engine-out trajectory produces the highest radiation heating loads. The increase in radiation with throttling at low altitude is caused by a reduction in expansion ratio which increases the temperatures in the plume. At high altitude, the higher thrust plume often has higher radiation.

The predictions for radiation from the base gases for the nominal and engine-out missions are shown in Tables 29 and 30. The same radiation model was used for both the nominal and engine-out missions because current knowledge of the base gas is limited. Currently, there is no effect modeled in one region of the base for the loss of a booster engine on the far corner of the base. The reverse gas rate peak occurs at 40 kft,

so the trajectory that has an increment closest to 40 kft will appear to have a slightly higher rate. The longer duration of the engine-out trajectory produced the highest heat load.

## REFERENCES

- [1] MSFC Memo ED33(15-92), "Cycle 1 NLS Base Heating Environments," Feb. 2, 1992 (also REMTECH RTN 218-04, Jan. 24, 1992).
- [2] MSFC ED55 Note from Dan Adams to David Anderson, "Summary of NLS 2 Mission 2 Reference Trajectories," July 6, 1992.
- [3] MSFC ED55 Note from Ray Bailey to David Anderson, "Summary of NLS 2 Mission 1 Reference Trajectories," July 1992.
- [4] NASA Contract NAS8-38141, "Base Heating Methodology Improvements," initiated September 8, 1989.
- [5] MSFC Memo ED33(98-91), "Preliminary Cycle 1 NLS Base Heating Environments," Sep. 25, 1991 (also REMTECH RTN 218-03, Sep. 13, 1991).
- [6] Mullen, C. R. et al., "Saturn Base Heating Handbook," The Boeing Company, NASA/MSFC CR-61390, May 1, 1972.
- [7] McAnelly, W. B. and Young, C. T. K., "Space Vehicle Engine and Heat Shield Environment Review," Volume I — Engineering Analysis, Teledyne Brown Report EE-MSFC-1774, Dec. 1973.
- [8] Dimotakis, P. E., "Turbulent Free Shear Layer Mixing and Combustion," Chapter 5, Volume 137, *High-Speed Flight Propulsion Systems*, Progress In Astronautics and Aeronautics, 1991.
- [9] Reardon, J. E. and Lee, Y. C., "A Computer Program for Thermal Radiation from Gaseous Rocket Exhaust Plumes (GASRAD)," REMTECH RTR 014-09, Dec. 1979.
- [10] Reardon, J. E., "A Computer Program for Thermal Radiation from Shuttle Exhaust Plumes (SEPRAD)," REMTECH RTR 109-01, July 1987.




Figure 1: NLS 2 Launch Vehicle Base Geometry




Figure 2: NLS 2 Launch Vehicle Base Region Side Views

**STME 650K Design Data  
(Rev. 26b)**

Power, %	100	70
Gas Gen. Temp. °R	1580	1200
<b>Nozzle Manifold:</b>		
Pressure, psia	257	140
Temp., °R	1165	920
Flow, pps	65.9	37.7
Mixture Ratio, lb./lb.	0.868	0.658
<b>Primary Film Injector:</b>		
Total Thrust Pressure psia	216	118
Static Exit Pressure, psia	65	35
Temp., °R	1165	920
Flow, pps	33.1	18.9
<b>Secondary Film Injector:</b>		
Total Inlet Pressure, psia	80	52
Static Exit Pressure, psia	65	45
Temp., °R	1165	920
Flow, pps	6.6	3.8
<b>Nozzettes:</b>		
Total Thrust Pressure, psia	77.2	43.9
Static Exit Pressure, psia	7.8	5.5
Temp., °R	1458	1264
Flow, pps	26.2	15.0
Main Stream Static Pressure, psia	57	40
<b>Main Chamber:</b>		
pc, psia	2250	1581
MR, lb./lb.	6.993	6.935
Flow, pps	1447.0	1020.6
<b>Geometry:</b>		
Chamber:		
Throat Area, in <sup>2</sup>	149.45	
Exit Area, in <sup>2</sup>	6577.0	
Nozzettes:		
Throat Area, in <sup>2</sup>	67.83	
Exit Area, in <sup>2</sup>	145.16	

Figure 3: STME 650K Engine Characteristics (Rev. 26b)






Figure 4: NLS 2 Trajectories Compared with Cycle 1 1.5 Stage Vehicle

				X	Y	Z
BP	201	1.5	Stage Base HS Center	4393.62	0.00	0.00
BP	202	1.5	Stage Base HS	4393.62	-58.50	0.00
BP	203	1.5	Stage Base HS	4393.62	-117.00	0.00
BP	204	1.5	Stage Base HS	4393.62	-58.51	89.83
BP	205	1.5	Stage STME 1 HS at 180 deg	4453.13	0.00	21.63
BP	206	1.5	Stage STME 1 HS at 295 deg	4453.13	-37.18	79.91
BP	207	1.5	Stage STME 3 HS at 155 deg	4453.13	-79.85	99.75
BP	208	1.5	Stage STME 1 Exit Lip Top at 180 deg	4535.00	0.00	14.93
BP	209	1.5	Stage STME 1 Exit Lip Top at 295 deg	4535.00	-43.26	82.74
BP	210	1.5	Stage STME 3 Exit Lip Top at 135 deg	4535.00	-69.32	117.02
BP	211	1.5	Stage STME 3 Exit Lip Top at 155 deg	4535.00	-73.66	97.14
BP	212	1.5	Stage STME 3 Exit Lip Top at 225 deg	4535.00	-117.02	69.32
BP	213	1.5	Stage Second Stage Thrust Cone	4315.50	114.07	0.00




Figure 5: NLS 2 Body Points Selected for Base Heating Analysis




Figure 6: Body Point 213 Location on Sustainer Thrust Structure

**PRELIMINARY CYCLE 1: ED33 (98 - 91) September 1991**

- Base burning effect on convection not considered
- Base burning effect on radiation approximated

**PRELIMINARY CYCLE 1 UPDATE: ED33 (03 - 92) JANUARY 1992**

- Base burning effect on convection from ED31 (06 - 89) gas temperature and Saturn I heat transfer coefficient
- base burning effect on radiation same as ED33 (98 - 91)

**CYCLE 1 ENVIRONMENT ED33 (15 - 92) February 1992**

- Base burning effect on convection updated to stoichiometric air - T.E. exhaust mixture at estimated base pressure; Saturn I heat transfer coefficient retained. (Reduction in  $\Delta$  enthalpy from ED33 [03 - 92])
- Local radiation in base estimated from base burning gas composition and thermodynamic properties
- Main plumes radiation from updated plume models

Figure 7: NLS Base Heating Environment Prediction Chronology

- Base burning convection may be large in relation to conventional convection




Figure 8: Low Altitude versus High Altitude Convective Base Heating





Figure 9: Application of Saturn Flight Data Review Results to NLS 2 Vehicle



- Above 40,000 Kft, Cycle 1  $h_c$  envelopes Saturn flight data and is valid for NLS 1.5 stage.
- A technique to correlate  $h_c$  with base flow conditions for altitudes below 40,000 feet was indicated.

Figure 10: Results of Objective 1 — Flight Deduced  $h_c$




Figure 11: Similarities in NLS 2 and Saturn V S-1C Stage



- Below 40,000 feet

**BASE REGION REYNOLDS NUMBER LOW ALTITUDE CORRELATION**

$$h_c \propto Re_B^8 Pr^{.33} \text{ (Colburn Analogy for Turbulent Flow)}$$

**Steps:**

1. Use velocity deduced from Saturn V pitot-static pressure data and compute  $(\rho_B V_B)^{0.8}$  at initial plume-to-plume recirculation assuming  $P_B = P_\infty$  and  $T_B =$  measured base gas temperature.
2. Compute ratio  $\frac{(\rho_B V_B)^{0.8}}{(\rho_B V_B)^{0.8}_{REF}}$
3. Then  $h_c = \frac{(\rho_B V_B)^{0.8}}{(\rho_B V_B)^{0.8}_{REF}} h_{cREF}$  for  $0 \leq \text{altitude} \leq 40 \text{ Kft}$

- Above 40,000 feet

$h_c$  envelopes Saturn flight data

Figure 12: Methodology for Improving  $h_c$  Early in Flight




Figure 13: Low Altitude Reynolds Number Correlation for  $h_c$




Figure 14: Methodology for Applying Saturn Flight Data to NLS 2 Gas Temperature Predictions




Figure 15: NLS Simplified Base Region Flowfield at Low Altitude





Figure 16: NLS 2 Base Gas Temperature Estimates

BP 201: Core Base Heat Shield  
 NLS 2 Mission 1 Nominal - July 1992



BP 201: Core Base Heat Shield  
 NLS 2 Mission 1 Engine Out - July 1992





Figure 17: NLS 2 Mission 1 Base Heating Environment — Body Point 201

BP 202: Core Base Heat Shield  
 NLS 2 Mission 1 Nominal - July 1992



BP 202: Core Base Heat Shield  
 NLS 2 Mission 1 Engine Out - July 1992





Figure 18: NLS 2 Mission 1 Base Heating Environment — Body Point 202

BP 203: Core Base Heat Shield  
NLS 2 Mission 1 Nominal - July 1992



BP 203: Core Base Heat Shield  
NLS 2 Mission 1 Engine Out - July 1992





Figure 19: NLS 2 Mission 1 Base Heating Environment — Body Point 203



BP 204: Core Base Heat Shield  
 NLS 2 Mission 1 Nominal - July 1992



BP 204: Core Base Heat Shield  
 NLS 2 Mission 1 Engine Out - July 1992





Figure 20: NLS 2 Mission 1 Base Heating Environment — Body Point 204

BP 205: STME Heat Shield  
 NLS 2 Mission 1 Nominal - July 1992



BP 205: STME Heat Shield  
 NLS 2 Mission 1 Engine Out - July 1992





Figure 21: NLS 2 Mission 1 Base Heating Environment — Body Point 205

BP 206: STME Heat Shield  
NLS 2 Mission 1 Nominal - July 1992



BP 206: STME Heat Shield  
NLS 2 Mission 1 Engine Out - July 1992





Figure 22: NLS 2 Mission 1 Base Heating Environment — Body Point 206

BP 207: STME Heat Shield  
NLS 2 Mission 1 Nominal - July 1992



BP 207: STME Heat Shield  
NLS 2 Mission 1 Engine Out - July 1992





Figure 23: NLS 2 Mission 1 Base Heating Environment — Body Point 207

BP 208: Inboard STME Nozzle (Lip)  
NLS 2 Mission 1 Nominal - July 1992



BP 208: Inboard STME Nozzle (Lip)  
NLS 2 Mission 1 Engine Out - July 1992





Figure 24: NLS 2 Mission 1 Base Heating Environment — Body Point 208

BP 209: Inboard STME Nozzle (Lip)  
 NLS 2 Mission 1 Nominal - July 1992



BP 209: Inboard STME Nozzle (Lip)  
 NLS 2 Mission 1 Engine Out - July 1992





Figure 25: NLS 2 Mission 1 Base Heating Environment — Body Point 209

BP 210: Outboard STME Nozzle (Lip)  
 NLS 2 Mission 1 Nominal - July 1992



BP 210: Outboard STME Nozzle (Lip)  
 NLS 2 Mission 1 Engine Out - July 1992





Figure 26: NLS 2 Mission 1 Base Heating Environment — Body Point 210

BP 211: Outboard STME Nozzle (Lip)  
NLS 2 Mission 1 Nominal - July 1992



BP 211: Outboard STME Nozzle (Lip)  
NLS 2 Mission 1 Engine Out - July 1992





Figure 27: NLS 2 Mission 1 Base Heating Environment — Body Point 211





BP 212: Outboard STME Nozzle (Lip)  
 NLS 2 Mission 1 Engine Out - July 1992





Figure 28: NLS 2 Mission 1 Base Heating Environment — Body Point 212

BP 213: Sustainer Thrust Structure (External Conical Section)  
NLS 2 Mission 1 Nominal - July 1992



BP 213: Sustainer Thrust Structure (External Conical Section)  
NLS 2 Mission 1 Engine Out - July 1992




Figure 29: NLS 2 Mission 1 Base Heating Environment — Body Point 213

Table 1

1.5 Stage Cycle 2 Convective Base Heating  
 BP 201 - Core Base Heat Shield  
 NLS 2 Mission 1 Nominal - July 1992

Alt Kft	Time Sec	Tr deg R	Hc BTU/FT <sup>2</sup> -S-R	Convective Heating Rate (BTU/FT <sup>2</sup> -S) for Various Wall Temperatures					
				qc@460 R	qc@540 R	qc@960 R	qc@1460 R	qc@1960 R	qc@2460 R
0.0	0.0	921	6.000E-04	0.28	0.23	-0.02	-0.32	-0.62	-0.92
1.0	10.0	878	4.081E-03	1.71	1.38	-0.33	-2.37	-4.41	-6.45
2.4	15.0	917	7.985E-03	3.65	3.01	-0.35	-4.34	-8.33	-12.33
4.4	20.0	1019	1.211E-02	6.76	5.80	0.71	-5.34	-11.40	-17.45
7.0	25.0	1158	1.433E-02	10.00	8.86	2.84	-4.33	-11.49	-18.66
10.2	30.0	1380	1.551E-02	14.27	13.03	6.52	-1.24	-9.00	-16.75
14.1	35.0	1552	1.619E-02	17.68	16.38	9.58	1.49	-6.61	-14.70
16.8	38.0	1622	1.653E-02	19.21	17.89	10.94	2.68	-5.59	-13.85
16.8	38.0	1622	1.653E-02	19.21	17.89	10.94	2.68	-5.59	-13.85
18.6	40.0	1711	1.672E-02	20.92	19.58	12.56	4.20	-4.16	-12.53
23.6	45.0	1874	1.707E-02	24.14	22.77	15.60	7.07	-1.47	-10.00
28.9	50.0	2030	1.696E-02	26.63	25.27	18.15	9.67	1.19	-7.29
34.6	55.0	2157	1.652E-02	28.03	26.71	19.77	11.51	3.25	-5.01
40.7	60.0	2515	1.532E-02	31.49	30.26	23.83	16.17	8.50	0.84
47.2	65.0	3813	1.381E-02	46.31	45.21	39.41	32.50	25.60	18.69
54.1	70.0	4091	1.251E-02	45.41	44.41	39.16	32.90	26.65	20.40
61.4	75.0	4088	1.136E-02	41.23	40.32	35.55	29.87	24.18	18.50
69.0	80.0	4089	1.013E-02	36.76	35.95	31.70	26.63	21.57	16.50
77.0	85.0	4090	9.023E-03	32.75	32.03	28.24	23.73	19.22	14.71
85.3	90.0	4085	8.005E-03	29.02	28.38	25.02	21.01	17.01	13.01
93.9	95.0	4078	7.055E-03	25.52	24.96	22.00	18.47	14.94	11.41
102.8	100.0	4030	3.496E-03	12.48	12.20	10.73	8.98	7.24	5.49
121.2	110.0	3750	2.025E-03	6.66	6.50	5.65	4.64	3.62	2.61
140.5	120.0	3360	1.986E-03	5.76	5.60	4.77	3.77	2.78	1.79
160.3	130.0	3120	1.395E-03	3.71	3.60	3.01	2.32	1.62	0.92
180.7	140.0	3000	1.179E-03	2.99	2.90	2.40	1.82	1.23	0.64
201.4	150.0	2950	1.079E-03	2.69	2.60	2.15	1.61	1.07	0.53
221.5	159.6	2950	9.544E-04	2.38	2.30	1.90	1.42	0.94	0.47
221.5	159.6	2950	8.714E-04	2.17	2.10	1.73	1.30	0.86	0.43
301.1	200.0	2950	8.714E-04	2.17	2.10	1.73	1.30	0.86	0.43
471.1	331.8	2950	8.714E-04	2.17	2.10	1.73	1.30	0.86	0.43

Summary @ T<sub>wall</sub> = 540 R

Peak Heating Rate: 45.21 BTU/FT<sup>2</sup>-S  
 Total Heat Load: 2800.77 BTU/FT<sup>2</sup>

Table 2

1.5 Stage Cycle 2 Convective Base Heating  
 BP 201 - Core Base Heat Shield  
 NLS 2 Mission 1 Engine Out - July 1992

All K/h	Time Sec	Tr deg R	Hc BTU/FT <sup>2</sup> -S-R	Convective Heating Rate (BTU/FT <sup>2</sup> -S) for Various Wall Temperatures					
				qc@460 R	qc@540 R	qc@960 R	qc@1460 R	qc@1960 R	qc@2460 R
0.0	0.0	921	6.00E-04	0.28	0.23	-0.02	-0.32	-0.62	-0.92
0.6	10.0	866	2.62E-03	1.06	0.85	-0.25	-1.56	-2.87	-4.18
1.4	15.0	888	5.109E-03	2.19	1.78	-0.37	-2.92	-5.48	-8.03
2.5	20.0	920	8.278E-03	3.81	3.15	-0.33	-4.47	-8.61	-12.75
4.1	25.0	1000	1.175E-02	6.34	5.40	0.47	-5.41	-11.28	-17.16
6.0	30.0	1097	1.351E-02	8.61	7.53	1.86	-4.90	-11.65	-18.41
8.4	35.0	1272	1.519E-02	12.34	11.12	4.74	-2.86	-10.45	-18.05
11.3	40.0	1434	1.569E-02	15.29	14.03	7.44	-0.41	-8.25	-16.10
14.6	45.0	1569	1.628E-02	18.04	16.74	9.91	1.77	-6.37	-14.51
18.4	50.0	1700	1.670E-02	20.70	19.36	12.35	4.00	-4.35	-12.70
22.7	55.0	1844	1.709E-02	23.65	22.28	15.10	6.56	-1.99	-10.53
27.5	60.0	1998	1.699E-02	26.13	24.77	17.64	9.14	0.65	-7.85
32.7	65.0	2124	1.676E-02	27.89	26.55	19.51	11.13	2.75	-5.63
38.5	70.0	2286	1.585E-02	28.95	27.68	21.02	13.09	5.17	-2.76
44.7	75.0	3364	1.438E-02	41.76	40.61	34.57	27.38	20.19	13.00
51.3	80.0	4085	1.292E-02	46.83	45.80	40.37	33.91	27.45	20.99
58.4	85.0	4089	1.184E-02	42.97	42.02	37.05	31.13	25.21	19.29
65.9	90.0	4089	1.063E-02	38.58	37.73	33.26	27.95	22.63	17.32
73.8	95.0	4089	9.418E-03	34.18	33.42	29.47	24.76	20.05	15.34
82.0	100.0	4088	8.398E-03	30.47	29.80	26.27	22.07	17.87	13.67
90.6	105.0	4081	7.394E-03	26.77	26.18	23.08	19.38	15.68	11.99
99.5	110.0	4074	6.489E-03	23.45	22.93	20.21	16.96	13.72	10.47
118.1	120.0	3820	3.201E-03	10.76	10.50	9.16	7.55	5.95	4.35
137.6	130.0	3400	2.028E-03	5.96	5.80	4.95	3.93	2.92	1.91
158.0	140.0	3130	1.815E-03	4.85	4.70	3.94	3.03	2.12	1.22
179.0	150.0	3000	1.199E-03	3.05	2.95	2.45	1.85	1.25	0.65
200.6	160.0	2950	1.037E-03	2.58	2.50	2.06	1.55	1.03	0.51
222.9	170.0	2950	9.544E-04	2.38	2.30	1.90	1.42	0.94	0.47
231.5	173.8	2950	9.129E-04	2.27	2.20	1.82	1.36	0.90	0.45
231.5	173.8	2950	8.714E-04	2.17	2.10	1.73	1.30	0.86	0.43
292.4	203.0	2950	8.714E-04	2.17	2.10	1.73	1.30	0.86	0.43
422.2	306.0	2950	8.714E-04	2.17	2.10	1.73	1.30	0.86	0.43
469.8	450.2	2950	8.714E-04	2.17	2.10	1.73	1.30	0.86	0.43

Summary @ T<sub>wall</sub> = 540 R

Peak Heating Rate: 45.80 BTU/FT<sup>2</sup>-S  
 Total Heat Load: 3224.44 RTU/FT<sup>2</sup>

Table 3

1.5 Stage Cycle 2 Convective Base Heating  
 BP 202 - Core Base Heat Shield  
 NLS 2 Mission 1 Nominal - July 1992

Alt Kft	Time Sec	Tr deg R	Hc BTU/FT <sup>2</sup> -S-R	Convective Heating Rate (BTU/FT <sup>2</sup> -S) for Various Wall Temperatures					
				qc@460 R	qc@540 R	qc@960 R	qc@1460 R	qc@1960 R	qc@2460 R
0.0	0.0	921	6.000E-04	0.28	0.23	-0.02	-0.32	-0.62	-0.92
1.0	10.0	878	4.081E-03	1.71	1.38	-0.33	-2.37	-4.41	-6.45
2.4	15.0	917	7.985E-03	3.65	3.01	-0.35	-4.34	-8.33	-12.33
4.4	20.0	1019	1.211E-02	6.76	5.80	0.71	-5.34	-11.40	-17.45
7.0	25.0	1158	1.433E-02	10.00	8.86	2.84	-4.33	-11.49	-18.66
10.2	30.0	1380	1.551E-02	14.27	13.03	6.52	-1.24	-9.00	-16.75
14.1	35.0	1552	1.619E-02	17.68	16.38	9.58	1.49	-6.61	-14.70
16.8	38.0	1622	1.653E-02	19.21	17.89	10.94	2.68	-5.59	-13.85
16.8	38.0	1622	1.653E-02	19.21	17.89	10.94	2.68	-5.59	-13.85
18.6	40.0	1711	1.672E-02	20.92	19.58	12.56	4.20	-4.16	-12.53
23.6	45.0	1874	1.707E-02	24.14	22.77	15.60	7.07	-1.47	-10.00
28.9	50.0	2030	1.696E-02	26.63	25.27	18.15	9.67	1.19	-7.29
34.6	55.0	2157	1.652E-02	28.03	26.71	19.77	11.51	3.25	-5.01
40.7	60.0	2515	1.532E-02	31.49	30.26	23.83	16.17	8.50	0.84
47.2	65.0	3813	1.381E-02	46.31	45.21	39.41	32.50	25.60	18.69
54.1	70.0	4091	1.251E-02	45.41	44.41	39.16	32.90	26.65	20.40
61.4	75.0	4088	1.136E-02	41.23	40.32	35.55	29.87	24.18	18.50
69.0	80.0	4089	1.013E-02	36.76	35.95	31.70	26.63	21.57	16.50
77.0	85.0	4090	9.023E-03	32.75	32.03	28.24	23.73	19.22	14.71
85.3	90.0	4085	8.005E-03	29.02	28.38	25.02	21.01	17.01	13.01
93.9	95.0	4078	7.055E-03	25.52	24.96	22.00	18.47	14.94	11.41
102.8	100.0	4030	2.636E-03	9.41	9.20	8.09	6.77	5.46	4.14
121.2	110.0	3750	8.411E-04	2.77	2.70	2.35	1.93	1.51	1.09
140.5	120.0	3360	7.801E-04	2.26	2.20	1.87	1.48	1.09	0.70
160.3	130.0	3120	5.426E-04	1.44	1.40	1.17	0.90	0.63	0.36
180.7	140.0	3000	4.268E-04	1.08	1.05	0.87	0.66	0.44	0.23
201.4	150.0	2950	3.320E-04	0.83	0.80	0.66	0.49	0.33	0.16
221.5	159.6	2950	2.905E-04	0.72	0.70	0.58	0.43	0.29	0.14
221.5	159.6	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
301.1	200.0	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
471.1	331.8	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00

Summary @ T<sub>wall</sub> = 540 R

Peak Heating Rate: 45.21 BTU/FT<sup>2</sup>-S

Total Heat Load: 2278.80 BTU/FT<sup>2</sup>

1.5 Stage Cycle 2 Convective Base Heating  
 BP 202 - Core Base Heat Shield  
 NLS 2 Mission 1 Engine Out - July 1992

Table 4

Alt Kft	Time Sec	Tr deg R	Hc BTU/FT <sup>2</sup> -S-R	Convective Heating Rate (BTU/FT <sup>2</sup> -S) for Various Wall Temperatures					
				qc@460 R	qc@540 R	qc@960 R	qc@1460 R	qc@1960 R	qc@2460 R
0.0	0.0	921	6.000E-04	0.28	0.23	-0.02	-0.32	-0.62	-0.92
0.6	10.0	866	2.620E-03	1.06	0.85	-0.25	-1.56	-2.87	-4.18
1.4	15.0	888	5.109E-03	2.19	1.78	-0.37	-2.92	-5.48	-8.03
2.5	20.0	920	8.278E-03	3.81	3.15	-0.33	-4.47	-8.61	-12.75
4.1	25.0	1000	1.175E-02	6.34	5.40	0.47	-5.41	-11.28	-17.16
6.0	30.0	1097	1.351E-02	8.61	7.53	1.86	-4.90	-11.65	-18.41
8.4	35.0	1272	1.519E-02	12.34	11.12	4.74	-2.86	-10.45	-18.05
11.3	40.0	1434	1.569E-02	15.29	14.03	7.44	-0.41	-8.25	-16.10
14.6	45.0	1569	1.628E-02	18.04	16.74	9.91	1.77	-6.37	-14.51
18.4	50.0	1700	1.670E-02	20.70	19.36	12.35	4.00	-4.35	-12.70
22.7	55.0	1844	1.709E-02	23.65	22.28	15.10	6.56	-1.99	-10.53
27.5	60.0	1998	1.699E-02	26.13	24.77	17.64	9.14	0.65	-7.85
32.7	65.0	2124	1.676E-02	27.89	26.55	19.51	11.13	2.75	-5.63
38.5	70.0	2286	1.585E-02	28.95	27.68	21.02	13.09	5.17	-2.76
44.7	75.0	3364	1.438E-02	41.76	40.61	34.57	27.38	20.19	13.00
51.3	80.0	4085	1.292E-02	46.83	45.80	40.37	33.91	27.45	20.99
58.4	85.0	4089	1.184E-02	42.97	42.02	37.05	31.13	25.21	19.29
65.9	90.0	4089	1.063E-02	38.58	37.73	33.26	27.95	22.63	17.32
73.8	95.0	4089	9.418E-03	34.18	33.42	29.47	24.76	20.05	15.34
82.0	100.0	4088	8.398E-03	30.47	29.80	26.27	22.07	17.87	13.67
90.6	105.0	4081	7.394E-03	26.77	26.18	23.08	19.38	15.68	11.99
99.5	110.0	4074	6.489E-03	23.45	22.93	20.21	16.96	13.72	10.47
118.1	120.0	3820	9.146E-04	3.07	3.00	2.62	2.16	1.70	1.24
137.6	130.0	3400	7.692E-04	2.26	2.20	1.88	1.49	1.11	0.72
158.0	140.0	3130	5.598E-04	1.49	1.45	1.21	0.93	0.66	0.38
179.0	150.0	3000	4.472E-04	1.14	1.10	0.91	0.69	0.47	0.24
200.6	160.0	2950	3.320E-04	0.83	0.80	0.66	0.49	0.33	0.16
222.9	170.0	2950	2.905E-04	0.72	0.70	0.58	0.43	0.29	0.14
231.5	173.8	2950	2.490E-04	0.62	0.60	0.50	0.37	0.25	0.12
231.5	173.8	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
292.4	203.0	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
422.2	306.0	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
469.8	450.2	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00

Summary @ T<sub>wall</sub> = 540 R

Peak Heating Rate: 45.80 BTU/FT<sup>2</sup>-S  
 Total Heat Load: 2450.78 BTU/FT<sup>2</sup>

Table 5  
 1.5 Stage Cycle 2 Convective Base Heating  
 BP 203 - Core Base Heat Shield  
 NLS 2 Mission 1 Nominal - July 1992

Alt Kft	Time Sec	Tr deg R	Hc BTU/FT <sup>2</sup> -S-R	Convective Heating Rate (BTU/FT <sup>2</sup> -S) for Various Wall Temperatures					
				qc@460 R	qc@540 R	qc@960 R	qc@1460 R	qc@1960 R	qc@2460 R
0.0	0.0	921	6.00E-04	0.28	0.23	-0.02	-0.32	-0.62	-0.92
1.0	10.0	878	4.081E-03	1.71	1.38	-0.33	-2.37	-4.41	-6.45
2.4	15.0	917	7.985E-03	3.65	3.01	-0.35	-4.34	-8.33	-12.33
4.4	20.0	1019	1.211E-02	6.76	5.80	0.71	-5.34	-11.40	-17.45
7.0	25.0	1158	1.433E-02	10.00	8.86	2.84	-4.33	-11.49	-18.66
10.2	30.0	1380	1.551E-02	14.27	13.03	6.52	-1.24	-9.00	-16.75
14.1	35.0	1552	1.619E-02	17.68	16.38	9.58	1.49	-6.61	-14.70
16.8	38.0	1622	1.653E-02	19.21	17.89	10.94	2.68	-5.59	-13.85
16.8	38.0	1622	1.653E-02	19.21	17.89	10.94	2.68	-5.59	-13.85
18.6	40.0	1711	1.672E-02	20.92	19.58	12.56	4.20	-4.16	-12.53
23.6	45.0	1874	1.707E-02	24.14	22.77	15.60	7.07	-1.47	-10.00
28.9	50.0	2030	1.696E-02	26.63	25.27	18.15	9.67	1.19	-7.29
34.6	55.0	2157	1.652E-02	28.03	26.71	19.77	11.51	3.25	-5.01
40.7	60.0	2515	1.532E-02	31.49	30.26	23.83	16.17	8.50	0.84
47.2	65.0	3813	1.381E-02	46.31	45.21	39.41	32.50	25.60	18.69
54.1	70.0	4091	1.251E-02	45.41	44.41	39.16	32.90	26.65	20.40
61.4	75.0	4088	1.136E-02	41.23	40.32	35.55	29.87	24.18	18.50
69.0	80.0	4089	1.013E-02	36.76	35.95	31.70	26.63	21.57	16.50
77.0	85.0	4090	9.023E-03	32.75	32.03	28.24	23.73	19.22	14.71
85.3	90.0	4085	8.005E-03	29.02	28.38	25.02	21.01	17.01	13.01
93.9	95.0	4078	7.055E-03	25.52	24.96	22.00	18.47	14.94	11.41
102.8	100.0	4030	2.579E-03	9.21	9.00	7.92	6.63	5.34	4.05
121.2	110.0	3750	4.361E-04	1.43	1.40	1.22	1.00	0.78	0.56
140.5	120.0	3360	4.433E-04	1.29	1.25	1.06	0.84	0.62	0.40
160.3	130.0	3120	3.488E-04	0.93	0.90	0.75	0.58	0.40	0.23
180.7	140.0	3000	2.642E-04	0.67	0.65	0.54	0.41	0.27	0.14
201.4	150.0	2950	2.075E-04	0.52	0.50	0.41	0.31	0.21	0.10
221.5	159.6	2950	1.245E-04	0.31	0.30	0.25	0.19	0.12	0.06
221.5	159.6	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
301.1	200.0	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
471.1	331.8	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00

Summary @ T<sub>wall</sub> = 540 R

Peak Heating Rate: 45.21 BTU/FT<sup>2</sup>-S  
 Total Heat Load: 2240.95 BTU/FT<sup>2</sup>

Table 6

1.5 Stage Cycle 2 Convective Base Heating  
 BP 203 - Core Base Heat Shield  
 NLS 2 Mission 1 Engine Out - July 1992

Alt Kft	Time Sec	Tr deg R	Hc BTU/Ft <sup>2</sup> -S-R	Convective Heating Rate (BTU/Ft <sup>2</sup> -S) for Various Wall Temperatures					
				qc@460 R	qc@540 R	qc@960 R	qc@1460 R	qc@1960 R	qc@2460 R
0.0	0.0	921	6.00E-04	0.28	0.23	-0.02	-0.32	-0.62	-0.92
0.6	10.0	866	2.620E-03	1.06	0.85	-0.25	-1.56	-2.87	-4.18
1.4	15.0	888	5.109E-03	2.19	1.78	-0.37	-2.92	-5.48	-8.03
2.5	20.0	920	8.278E-03	3.81	3.15	-0.33	-4.47	-8.61	-12.75
4.1	25.0	1000	1.175E-02	6.34	5.40	0.47	-5.41	-11.28	-17.16
6.0	30.0	1097	1.351E-02	8.61	7.53	1.86	-4.90	-11.65	-18.41
8.4	35.0	1272	1.519E-02	12.34	11.12	4.74	-2.86	-10.45	-18.05
11.3	40.0	1434	1.569E-02	15.29	14.03	7.44	-0.41	-8.25	-16.10
14.6	45.0	1569	1.628E-02	18.04	16.74	9.91	1.77	-6.37	-14.51
18.4	50.0	1700	1.670E-02	20.70	19.36	12.35	4.00	-4.35	-12.70
22.7	55.0	1844	1.709E-02	23.65	22.28	15.10	6.56	-1.99	-10.53
27.5	60.0	1998	1.699E-02	26.13	24.77	17.64	9.14	0.65	-7.85
32.7	65.0	2124	1.676E-02	27.89	26.55	19.51	11.13	2.75	-5.63
38.5	70.0	2286	1.585E-02	28.95	27.68	21.02	13.09	5.17	-2.76
44.7	75.0	3364	1.438E-02	41.76	40.61	34.57	27.38	20.19	13.00
51.3	80.0	4085	1.292E-02	46.83	45.80	40.37	33.91	27.45	20.99
58.4	85.0	4089	1.184E-02	42.97	42.02	37.05	31.13	25.21	19.29
65.9	90.0	4089	1.063E-02	38.58	37.73	33.26	27.95	22.63	17.32
73.8	95.0	4089	9.418E-03	34.18	33.42	29.47	24.76	20.05	15.34
82.0	100.0	4088	8.398E-03	30.47	29.80	26.27	22.07	17.87	13.67
90.6	105.0	4081	7.394E-03	26.77	26.18	23.08	19.38	15.68	11.99
99.5	110.0	4074	6.489E-03	23.45	22.93	20.21	16.96	13.72	10.47
118.1	120.0	3820	6.098E-04	2.05	2.00	1.74	1.44	1.13	0.83
137.6	130.0	3400	4.545E-04	1.34	1.30	1.11	0.88	0.65	0.43
158.0	140.0	3130	3.475E-04	0.93	0.90	0.75	0.58	0.41	0.23
179.0	150.0	3000	2.846E-04	0.72	0.70	0.58	0.44	0.30	0.15
200.6	160.0	2950	2.075E-04	0.52	0.50	0.41	0.31	0.21	0.10
222.9	170.0	2950	1.037E-04	0.26	0.25	0.21	0.15	0.10	0.05
231.5	173.8	2950	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04
231.5	173.8	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
292.4	203.0	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
422.2	306.0	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
469.8	450.2	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00

Summary @ T<sub>wall</sub> = 540 R

Peak Heating Rate: 45.80 BTU/Ft<sup>2</sup>-S

Total Heat Load: 2415.43 BTU/Ft<sup>2</sup>



Table 7

1.5 Stage Cycle 2 Convective Base Heating  
 BP 204 - Core Base Heat Shield  
 NLS 2 Mission 1 Nominal - July 1992

Alt Kft	Time Sec	Tr deg R	Hc BTU/FT <sup>2</sup> -S-R	Convective Heating Rate (BTU/FI <sup>2</sup> -S) for Various Wall Temperatures					
				qc@460 R	qc@540 R	qc@960 R	qc@1460 R	qc@1960 R	qc@2460 R
0.0	0.0	921	6.00E-04	0.28	0.23	-0.02	-0.32	-0.62	-0.92
1.0	10.0	878	4.081E-03	1.71	1.38	-0.33	-2.37	-4.41	-6.45
2.4	15.0	917	7.985E-03	3.65	3.01	-0.35	-4.34	-8.33	-12.33
4.4	20.0	1019	1.211E-02	6.76	5.80	0.71	-5.34	-11.40	-17.45
7.0	25.0	1158	1.433E-02	10.00	8.86	2.84	-4.33	-11.49	-18.66
10.2	30.0	1380	1.551E-02	14.27	13.03	6.52	-1.24	-9.00	-16.75
14.1	35.0	1552	1.619E-02	17.68	16.38	9.58	1.49	-6.61	-14.70
16.8	38.0	1622	1.653E-02	19.21	17.89	10.94	2.68	-5.59	-13.85
16.8	38.0	1622	1.653E-02	19.21	17.89	10.94	2.68	-5.59	-13.85
18.6	40.0	1711	1.672E-02	20.92	19.58	12.56	4.20	-4.16	-12.53
23.6	45.0	1874	1.707E-02	24.14	22.77	15.60	7.07	-1.47	-10.00
28.9	50.0	2030	1.696E-02	26.63	25.27	18.15	9.67	1.19	-7.29
34.6	55.0	2157	1.652E-02	28.03	26.71	19.77	11.51	3.25	-5.01
40.7	60.0	2515	1.532E-02	31.49	30.26	23.83	16.17	8.50	0.84
47.2	65.0	3813	1.381E-02	46.31	45.21	39.41	32.50	25.60	18.69
54.1	70.0	4091	1.251E-02	45.41	44.41	39.16	32.90	26.65	20.40
61.4	75.0	4088	1.136E-02	41.23	40.32	35.55	29.87	24.18	18.50
69.0	80.0	4089	1.013E-02	36.76	35.95	31.70	26.63	21.57	16.50
77.0	85.0	4090	9.023E-03	32.75	32.03	28.24	23.73	19.22	14.71
85.3	90.0	4085	8.005E-03	29.02	28.38	25.02	21.01	17.01	13.01
93.9	95.0	4078	7.055E-03	25.52	24.96	22.00	18.47	14.94	11.41
102.8	100.0	4030	3.295E-03	11.76	11.50	10.12	8.47	6.82	5.17
121.2	110.0	3750	1.589E-03	5.23	5.10	4.43	3.64	2.84	2.05
140.5	120.0	3360	1.525E-03	4.42	4.30	3.66	2.90	2.13	1.37
160.3	130.0	3120	1.047E-03	2.78	2.70	2.26	1.74	1.21	0.69
180.7	140.0	3000	8.537E-04	2.17	2.10	1.74	1.31	0.89	0.46
201.4	150.0	2950	7.054E-04	1.76	1.70	1.40	1.05	0.70	0.35
221.5	159.6	2950	5.809E-04	1.45	1.40	1.16	0.87	0.58	0.28
221.5	159.6	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
301.1	200.0	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
471.1	331.8	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00

Summary @ T<sub>wall</sub> = 540 R

Peak Heating Rate: 45.21 BTU/FI<sup>2</sup>-S  
 Total Heat Load: 2376.70 BTU/FI<sup>2</sup>

Table 8

1.5 Stage Cycle 2 Convective Base Heating  
 BP 204 - Core Base Heat Shield  
 NLS 2 Mission 1 Engine Out - July 1992

Alt Kft	Time Sec	Tr deg R	Hc BTU/FT <sup>2</sup> -S-R	Convective Heating Rate (BTU/FT <sup>2</sup> -S) for Various Wall Temperatures					
				qc@460 R	qc@540 R	qc@960 R	qc@1460 R	qc@1960 R	qc@2460 R
0.0	0.0	921	6.000E-04	0.28	0.23	-0.02	-0.32	-0.62	-0.92
0.6	10.0	866	2.620E-03	1.06	0.85	-0.25	-1.56	-2.87	-4.18
1.4	15.0	888	5.109E-03	2.19	1.78	-0.37	-2.92	-5.48	-8.03
2.5	20.0	920	8.278E-03	3.81	3.15	-0.33	-4.47	-8.61	-12.75
4.1	25.0	1000	1.175E-02	6.34	5.40	0.47	-5.41	-11.28	-17.16
6.0	30.0	1097	1.351E-02	8.61	7.53	1.86	-4.90	-11.65	-18.41
8.4	35.0	1272	1.519E-02	12.34	11.12	4.74	-2.86	-10.45	-18.05
11.3	40.0	1434	1.569E-02	15.29	14.03	7.44	-0.41	-8.25	-16.10
14.6	45.0	1569	1.628E-02	18.04	16.74	9.91	1.77	-6.37	-14.51
18.4	50.0	1700	1.670E-02	20.70	19.36	12.35	4.00	-4.35	-12.70
22.7	55.0	1844	1.709E-02	23.65	22.28	15.10	6.56	-1.99	-10.53
27.5	60.0	1998	1.699E-02	26.13	24.77	17.64	9.14	0.65	-7.85
32.7	65.0	2124	1.676E-02	27.89	26.55	19.51	11.13	2.75	-5.63
38.5	70.0	2286	1.585E-02	28.95	27.68	21.02	13.09	5.17	-2.76
44.7	75.0	3364	1.438E-02	41.76	40.61	34.57	27.38	20.19	13.00
51.3	80.0	4085	1.292E-02	46.83	45.80	40.37	33.91	27.45	20.99
58.4	85.0	4089	1.184E-02	42.97	42.02	37.05	31.13	25.21	19.29
65.9	90.0	4089	1.063E-02	38.58	37.73	33.26	27.95	22.63	17.32
73.8	95.0	4089	9.418E-03	34.18	33.42	29.47	24.76	20.05	15.34
82.0	100.0	4088	8.398E-03	30.47	29.80	26.27	22.07	17.87	13.67
90.6	105.0	4081	7.394E-03	26.77	26.18	23.08	19.38	15.68	11.99
99.5	110.0	4074	6.489E-03	23.45	22.93	20.21	16.96	13.72	10.47
118.1	120.0	3820	2.134E-03	7.17	7.00	6.10	5.04	3.97	2.90
137.6	130.0	3400	1.573E-03	4.63	4.50	3.84	3.05	2.27	1.48
158.0	140.0	3130	1.081E-03	2.89	2.80	2.35	1.81	1.26	0.72
179.0	150.0	3000	8.537E-04	2.17	2.10	1.74	1.31	0.89	0.46
200.6	160.0	2950	7.054E-04	1.76	1.70	1.40	1.05	0.70	0.35
222.9	170.0	2950	5.809E-04	1.45	1.40	1.16	0.87	0.58	0.28
231.5	173.8	2950	5.809E-04	1.45	1.40	1.16	0.87	0.58	0.28
231.5	173.8	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
292.4	203.0	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
422.2	306.0	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
469.8	450.2	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00

Summary @ Twall = 540 R

Peak Heating Rate: 45.80 BTU/FT<sup>2</sup>-S  
 Total Heat Load: 2552.61 BTU/FT<sup>2</sup>

Table 9

1.5 Stage Cycle 2 Convective Base Heating  
BP 205 - STME Heat Shield

NLS-2 Mission 1 Nominal - July 1992

Alt Kft	Time Sec	Tr deg R	Hc BTU/FT <sup>2</sup> -S-R	Convective Heating Rate (BTU/FT <sup>2</sup> -S) for Various Wall Temperatures					
				qc@460 R	qc@540 R	qc@960 R	qc@1460 R	qc@1960 R	qc@2460 R
0.0	0.0	871	4.00E-04	0.16	0.13	-0.04	-0.24	-0.44	-0.64
1.0	10.0	831	2.72E-03	1.01	0.79	-0.35	-1.72	-3.08	-4.44
2.4	15.0	1486	5.17E-03	5.31	4.90	2.72	0.14	-2.45	-5.04
4.4	20.0	1538	7.96E-03	8.59	7.95	4.61	0.62	-3.36	-7.35
7.0	25.0	1715	1.08E-02	13.58	12.71	8.17	2.76	-2.65	-8.06
10.2	30.0	1859	1.31E-02	18.32	17.27	11.77	5.22	-1.33	-7.88
14.1	35.0	2107	1.52E-02	25.13	23.91	17.50	9.87	2.24	-5.39
16.8	38.0	2177	1.59E-02	27.40	26.13	19.42	11.44	3.46	-4.52
16.8	38.0	2177	1.59E-02	27.40	26.13	19.42	11.44	3.46	-4.52
18.6	40.0	2180	1.62E-02	28.03	26.73	19.88	11.73	3.59	-4.56
23.6	45.0	2168	1.69E-02	28.92	27.56	20.45	11.99	3.52	-4.94
28.9	50.0	2618	1.70E-02	36.77	35.41	28.25	19.73	11.21	2.69
34.6	55.0	3551	1.66E-02	51.50	50.16	43.17	34.84	26.51	18.18
40.7	60.0	3930	1.53E-02	53.34	52.11	45.65	37.97	30.28	22.59
47.2	65.0	4095	1.38E-02	50.21	49.10	43.30	36.40	29.49	22.58
54.1	70.0	4091	1.25E-02	45.41	44.41	39.16	32.90	26.65	20.40
61.4	75.0	4088	1.13E-02	41.23	40.32	35.55	29.87	24.18	18.50
69.0	80.0	4089	1.01E-02	36.76	35.95	31.70	26.63	21.57	16.50
77.0	85.0	4090	9.02E-03	32.75	32.03	28.24	23.73	19.22	14.71
85.3	90.0	4085	8.00E-03	29.02	28.38	25.02	21.01	17.01	13.01
93.9	95.0	4078	7.05E-03	25.52	24.96	22.00	18.47	14.94	11.41
102.8	100.0	4030	4.58E-03	16.37	16.00	14.07	11.78	9.49	7.20
121.2	110.0	3750	3.36E-03	11.07	10.80	9.39	7.70	6.02	4.34
140.5	120.0	3360	3.36E-03	9.77	9.50	8.09	6.40	4.72	3.03
160.3	130.0	3120	2.20E-03	5.88	5.70	4.77	3.67	2.56	1.46
180.7	140.0	3000	1.82E-03	4.65	4.50	3.73	2.82	1.90	0.99
201.4	150.0	2950	1.76E-03	4.39	4.25	3.51	2.63	1.75	0.86
221.5	159.6	2950	1.72E-03	4.29	4.15	3.43	2.57	1.70	0.84
221.5	159.6	2950	1.66E-03	4.13	4.00	3.30	2.47	1.64	0.81
301.1	200.0	2950	1.66E-03	4.13	4.00	3.30	2.47	1.64	0.81
471.1	331.8	2950	1.66E-03	4.13	4.00	3.30	2.47	1.64	0.81

Summary @ T<sub>wall</sub> = 540 R

Peak Heating Rate: 52.11 BTU/FT<sup>2</sup>-S  
Total Heat Load: 3752.74 BTU/FT<sup>2</sup>

Table 10

1.5 Stage Cycle 2 Convective Base Heating  
 BP 205 - STME Heat Shield  
 NLS 2 Mission 1 Engine Out - July 1992

All Kft	Time Sec	Tr deg R	Hc BTU/FT <sup>2</sup> -S-R	Convective Heating Rate (BTU/FT <sup>2</sup> -S) for Various Wall Temperatures					
				qc@460 R	qc@540 R	qc@960 R	qc@1460 R	qc@1960 R	qc@2460 R
0.0	0.0	871	4.00E-04	0.16	0.13	-0.04	-0.24	-0.44	-0.64
0.6	10.0	810	1.764E-03	0.62	0.48	-0.26	-1.15	-2.03	-2.91
1.4	15.0	1078	3.369E-03	2.08	1.81	0.40	-1.29	-2.97	-4.65
2.5	20.0	1502	5.366E-03	5.59	5.16	2.91	0.22	-2.46	-5.14
4.1	25.0	1536	7.602E-03	8.18	7.57	4.38	0.58	-3.22	-7.03
6.0	30.0	1635	9.761E-03	11.47	10.69	6.59	1.71	-3.17	-8.05
8.4	35.0	1780	1.209E-02	15.96	14.99	9.91	3.87	-2.18	-8.22
11.3	40.0	1946	1.368E-02	20.33	19.23	13.49	6.65	-0.19	-7.03
14.6	45.0	2126	1.553E-02	25.88	24.64	18.12	10.35	2.59	-5.18
18.4	50.0	2184	1.625E-02	28.01	26.71	19.89	11.77	3.64	-4.48
22.7	55.0	2092	1.691E-02	27.60	26.25	19.15	10.69	2.24	-6.22
27.5	60.0	2527	1.701E-02	35.15	33.79	26.65	18.14	9.64	1.13
32.7	65.0	3202	1.694E-02	46.45	45.10	37.98	29.51	21.04	12.57
38.5	70.0	3546	1.593E-02	49.16	47.88	41.19	33.22	25.26	17.29
44.7	75.0	4094	1.438E-02	52.26	51.11	45.07	37.88	30.69	23.50
51.3	80.0	4093	1.292E-02	46.93	45.90	40.47	34.01	27.56	21.10
58.4	85.0	4089	1.184E-02	42.97	42.02	37.05	31.13	25.21	19.29
65.9	90.0	4089	1.063E-02	38.58	37.73	33.26	27.95	22.63	17.32
73.8	95.0	4089	9.418E-03	34.18	33.42	29.47	24.76	20.05	15.34
82.0	100.0	4088	8.398E-03	30.47	29.80	26.27	22.07	17.87	13.67
90.6	105.0	4081	7.394E-03	26.77	26.18	23.08	19.38	15.68	11.99
99.5	110.0	4074	6.489E-03	23.45	22.93	20.21	16.96	13.72	10.47
118.1	120.0	3820	4.421E-03	14.85	14.50	12.64	10.43	8.22	6.01
137.6	130.0	3400	3.497E-03	10.28	10.00	8.53	6.78	5.03	3.29
158.0	140.0	3130	2.355E-03	6.29	6.10	5.11	3.93	2.76	1.58
179.0	150.0	3000	1.870E-03	4.75	4.60	3.81	2.88	1.94	1.01
200.6	160.0	2950	1.763E-03	4.39	4.25	3.51	2.63	1.75	0.86
222.9	170.0	2950	1.743E-03	4.34	4.20	3.47	2.60	1.73	0.85
231.5	173.8	2950	1.701E-03	4.24	4.10	3.39	2.53	1.68	0.83
231.5	173.8	2950	1.660E-03	4.13	4.00	3.30	2.47	1.64	0.81
292.4	203.0	2950	1.660E-03	4.13	4.00	3.30	2.47	1.64	0.81
422.2	306.0	2950	1.660E-03	4.13	4.00	3.30	2.47	1.64	0.81
469.8	450.2	2950	1.660E-03	4.13	4.00	3.30	2.47	1.64	0.81

Summary @ T<sub>wall</sub> = 540 R

Peak Heating Rate: 51.11 BTU/FT<sup>2</sup>-S  
 Total Heat Load: 4363.41 BTU/FT<sup>2</sup>

Table 11

1.5 Stage Cycle 2 Convective Base Heating  
 BP 206 - STME Heat Shield  
 NLS 2 Mission 1 Nominal - July 1992

Alt Kft	Time Sec	Tr deg R	Hc BTU/FT <sup>2</sup> -S-R	Convective Heating Rate (BTU/FT <sup>2</sup> -S) for Various Wall Temperatures					
				qc@460 R	qc@540 R	qc@960 R	qc@1460 R	qc@1960 R	qc@2460 R
0.0	0.0	871	4.00E-04	0.16	0.13	-0.04	-0.24	-0.44	-0.64
1.0	10.0	831	2.725E-03	1.01	0.79	-0.35	-1.72	-3.08	-4.44
2.4	15.0	1486	5.178E-03	5.31	4.90	2.72	0.14	-2.45	-5.04
4.4	20.0	1538	7.968E-03	8.59	7.95	4.61	0.62	-3.36	-7.35
7.0	25.0	1715	1.082E-02	13.58	12.71	8.17	2.76	-2.65	-8.06
10.2	30.0	1859	1.310E-02	18.32	17.27	11.77	5.22	-1.33	-7.88
14.1	35.0	2107	1.526E-02	25.13	23.91	17.50	9.87	2.24	-5.39
16.8	38.0	2177	1.596E-02	27.40	26.13	19.42	11.44	3.46	-4.52
16.8	38.0	2177	1.596E-02	27.40	26.13	19.42	11.44	3.46	-4.52
18.6	40.0	2180	1.629E-02	28.03	26.73	19.88	11.73	3.59	-4.56
23.6	45.0	2168	1.693E-02	28.92	27.56	20.45	11.99	3.52	-4.94
28.9	50.0	2618	1.704E-02	36.77	35.41	28.25	19.73	11.21	2.69
34.6	55.0	3551	1.666E-02	51.50	50.16	43.17	34.84	26.51	18.18
40.7	60.0	3930	1.537E-02	53.34	52.11	45.65	37.97	30.28	22.59
47.2	65.0	4095	1.381E-02	50.21	49.10	43.30	36.40	29.49	22.58
54.1	70.0	4091	1.251E-02	45.41	44.41	39.16	32.90	26.65	20.40
61.4	75.0	4088	1.136E-02	41.23	40.32	35.55	29.87	24.18	18.50
69.0	80.0	4089	1.013E-02	36.76	35.95	31.70	26.63	21.57	16.50
77.0	85.0	4090	9.023E-03	32.75	32.03	28.24	23.73	19.22	14.71
85.3	90.0	4085	8.005E-03	29.02	28.38	25.02	21.01	17.01	13.01
93.9	95.0	4078	7.055E-03	25.52	24.96	22.00	18.47	14.94	11.41
102.8	100.0	4030	4.069E-03	14.53	14.20	12.49	10.46	8.42	6.39
121.2	110.0	3750	2.586E-03	8.51	8.30	7.21	5.92	4.63	3.34
140.5	120.0	3360	2.553E-03	7.40	7.20	6.13	4.85	3.57	2.30
160.3	130.0	3120	1.318E-03	3.51	3.40	2.85	2.19	1.53	0.87
180.7	140.0	3000	9.146E-04	2.32	2.25	1.87	1.41	0.95	0.49
201.4	150.0	2950	7.884E-04	1.96	1.90	1.57	1.17	0.78	0.39
221.5	159.6	2950	7.469E-04	1.86	1.80	1.49	1.11	0.74	0.37
221.5	159.6	2950	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04
301.1	200.0	2950	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04
471.1	331.8	2950	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04

Summary @ lwall = 540 ft

Peak Heating Rate: 52.11 BTU/FT<sup>2</sup>-S  
 Total Heat Load: 2956.91 BTU/FT<sup>2</sup>

1.5 Stage Cycle 2 Convective Base Heating  
 BP 206 - STME Heat Shield  
 NLS 2 Mission 1 Engine Out - July 1992

Table 12

Alt Kft	Time Sec	Tr deg R	Hc BTU/FT <sup>2</sup> -S-R	Convective Heating Rate (BTU/FT <sup>2</sup> -S) for Various Wall Temperatures					
				qc@460 R	qc@540 R	qc@960 R	qc@1460 R	qc@1960 R	qc@2460 R
0.0	0.0	871	4.00E-04	0.16	0.13	-0.04	-0.24	-0.44	-0.64
0.6	10.0	810	1.764E-03	0.62	0.48	-0.26	-1.15	-2.03	-2.91
1.4	15.0	1078	3.369E-03	2.08	1.81	0.40	-1.29	-2.97	-4.65
2.5	20.0	1502	5.366E-03	5.59	5.16	2.91	0.22	-2.46	-5.14
4.1	25.0	1536	7.602E-03	8.18	7.57	4.38	0.58	-3.22	-7.03
6.0	30.0	1635	9.761E-03	11.47	10.69	6.59	1.71	-3.17	-8.05
8.4	35.0	1780	1.209E-02	15.96	14.99	9.91	3.87	-2.18	-8.22
11.3	40.0	1946	1.368E-02	20.33	19.23	13.49	6.65	-0.19	-7.03
14.6	45.0	2126	1.553E-02	25.88	24.64	18.12	10.35	2.59	-5.18
18.4	50.0	2184	1.625E-02	28.01	26.71	19.89	11.77	3.64	-4.48
22.7	55.0	2092	1.691E-02	27.60	26.25	19.15	10.69	2.24	-6.22
27.5	60.0	2527	1.701E-02	35.15	33.79	26.65	18.14	9.64	1.13
32.7	65.0	3202	1.694E-02	46.45	45.10	37.98	29.51	21.04	12.57
38.5	70.0	3546	1.593E-02	49.16	47.88	41.19	33.22	25.26	17.29
44.7	75.0	4094	1.438E-02	52.26	51.11	45.07	37.88	30.69	23.50
51.3	80.0	4093	1.292E-02	46.93	45.90	40.47	34.01	27.56	21.10
58.4	85.0	4089	1.184E-02	42.97	42.02	37.05	31.13	25.21	19.29
65.9	90.0	4089	1.063E-02	38.58	37.73	33.26	27.95	22.63	17.32
73.8	95.0	4089	9.418E-03	34.18	33.42	29.47	24.76	20.05	15.34
82.0	100.0	4088	8.398E-03	30.47	29.80	26.27	22.07	17.87	13.67
90.6	105.0	4081	7.394E-03	26.77	26.18	23.08	19.38	15.68	11.99
99.5	110.0	4074	6.489E-03	23.45	22.93	20.21	16.96	13.72	10.47
118.1	120.0	3820	3.811E-03	12.80	12.50	10.90	8.99	7.09	5.18
137.6	130.0	3400	2.640E-03	7.76	7.55	6.44	5.12	3.80	2.48
158.0	140.0	3130	1.467E-03	3.92	3.80	3.18	2.45	1.72	0.98
179.0	150.0	3000	9.553E-04	2.43	2.35	1.95	1.47	0.99	0.52
200.6	160.0	2950	7.884E-04	1.96	1.90	1.57	1.17	0.78	0.39
222.9	170.0	2950	7.469E-04	1.86	1.80	1.49	1.11	0.74	0.37
231.5	173.8	2950	7.261E-04	1.81	1.75	1.45	1.08	0.72	0.36
231.5	173.8	2950	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04
292.4	203.0	2950	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04
422.2	306.0	2950	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04
469.8	450.2	2950	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04

Summary @ T<sub>wall</sub> = 540 R

Peak Heating Rate: 51.11 BTU/FT<sup>2</sup>-S  
 Total Heat Load: 3178.18 BTU/FT<sup>2</sup>

Table 13

1.5 Stage Cycle 2 Convective Base Heating

BP 207 - STME Heat Shield

NLS 2 Mission 1 Nominal - July 1992

Alt Kft	Time Sec	Tr deg R	Hc BTU/FT <sup>2</sup> -S-R	Convective Heating Rate (BTU/FT <sup>2</sup> -S) for Various Wall Temperatures					
				qc@460 R	qc@540 R	qc@960 R	qc@1460 R	qc@1960 R	qc@2460 R
0.0	0.0	871	4.000E-04	0.16	0.13	-0.04	-0.24	-0.44	-0.64
1.0	10.0	831	2.725E-03	1.01	0.79	-0.35	-1.72	-3.08	-4.44
2.4	15.0	1486	5.178E-03	5.31	4.90	2.72	0.14	-2.45	-5.04
4.4	20.0	1538	7.968E-03	8.59	7.95	4.61	0.62	-3.36	-7.35
7.0	25.0	1715	1.082E-02	13.58	12.71	8.17	2.76	-2.65	-8.06
10.2	30.0	1859	1.310E-02	18.32	17.27	11.77	5.22	-1.33	-7.88
14.1	35.0	2107	1.526E-02	25.13	23.91	17.50	9.87	2.24	-5.39
16.8	38.0	2177	1.596E-02	27.40	26.13	19.42	11.44	3.46	-4.52
16.8	38.0	2177	1.596E-02	27.40	26.13	19.42	11.44	3.46	-4.52
18.6	40.0	2180	1.629E-02	28.03	26.73	19.88	11.73	3.59	-4.56
23.6	45.0	2168	1.693E-02	28.92	27.56	20.45	11.99	3.52	-4.94
28.9	50.0	2618	1.704E-02	36.77	35.41	28.25	19.73	11.21	2.69
34.6	55.0	3551	1.666E-02	51.50	50.16	43.17	34.84	26.51	18.18
40.7	60.0	3930	1.537E-02	53.34	52.11	45.65	37.97	30.28	22.59
47.2	65.0	4095	1.381E-02	50.21	49.10	43.30	36.40	29.49	22.58
54.1	70.0	4091	1.251E-02	45.41	44.41	39.16	32.90	26.65	20.40
61.4	75.0	4088	1.136E-02	41.23	40.32	35.55	29.87	24.18	18.50
69.0	80.0	4089	1.013E-02	36.76	35.95	31.70	26.63	21.57	16.50
77.0	85.0	4090	9.023E-03	32.75	32.03	28.24	23.73	19.22	14.71
85.3	90.0	4085	8.005E-03	29.02	28.38	25.02	21.01	17.01	13.01
93.9	95.0	4078	7.055E-03	25.52	24.96	22.00	18.47	14.94	11.41
102.8	100.0	4030	4.011E-03	14.32	14.00	12.32	10.31	8.30	6.30
121.2	110.0	3750	2.586E-03	8.51	8.30	7.21	5.92	4.63	3.34
140.5	120.0	3360	2.553E-03	7.40	7.20	6.13	4.85	3.57	2.30
160.3	130.0	3120	1.318E-03	3.51	3.40	2.85	2.19	1.53	0.87
180.7	140.0	3000	9.146E-04	2.32	2.25	1.87	1.41	0.95	0.49
201.4	150.0	2950	7.884E-04	1.96	1.90	1.57	1.17	0.78	0.39
221.5	159.6	2950	7.469E-04	1.86	1.80	1.49	1.11	0.74	0.37
221.5	159.6	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
301.1	200.0	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
471.1	331.8	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00

Summary @ Twall = 540 R

Peak Heating Rate: 52.11 BTU/FT<sup>2</sup>-S  
 Total Heat Load: 2920.96 BTU/FT<sup>2</sup>

Table 14  
 1.5 Stage Cycle 2 Convective Base Heating  
 BP 207 - STME Heat Shield  
 NLS 2 Mission 1 Engine Out - July 1992

Alt Kft	Time Sec	Tr deg R	Hc BTU/FT <sup>2</sup> -S-R	Convective Heating Rate (BTU/FT <sup>2</sup> -S) for Various Wall Temperatures					
				qc@460 R	qc@540 R	qc@960 R	qc@1460 R	qc@1960 R	qc@2460 R
0.0	0.0	871	4.000E-04	0.16	0.13	-0.04	-0.24	-0.44	-0.64
0.6	10.0	810	1.764E-03	0.62	0.48	-0.26	-1.15	-2.03	-2.91
1.4	15.0	1078	3.369E-03	2.08	1.81	0.40	-1.29	-2.97	-4.65
2.5	20.0	1502	5.366E-03	5.59	5.16	2.91	0.22	-2.46	-5.14
4.1	25.0	1536	7.602E-03	8.18	7.57	4.38	0.58	-3.22	-7.03
6.0	30.0	1635	9.761E-03	11.47	10.69	6.59	1.71	-3.17	-8.05
8.4	35.0	1780	1.209E-02	15.96	14.99	9.91	3.87	-2.18	-8.22
11.3	40.0	1946	1.368E-02	20.33	19.23	13.49	6.65	-0.19	-7.03
14.6	45.0	2126	1.553E-02	25.88	24.64	18.12	10.35	2.59	-5.18
18.4	50.0	2184	1.625E-02	28.01	26.71	19.89	11.77	3.64	-4.48
22.7	55.0	2092	1.691E-02	27.60	26.25	19.15	10.69	2.24	-6.22
27.5	60.0	2527	1.701E-02	35.15	33.79	26.65	18.14	9.64	1.13
32.7	65.0	3202	1.694E-02	46.45	45.10	37.98	29.51	21.04	12.57
38.5	70.0	3546	1.593E-02	49.16	47.88	41.19	33.22	25.26	17.29
44.7	75.0	4094	1.438E-02	52.26	51.11	45.07	37.88	30.69	23.50
51.3	80.0	4093	1.292E-02	46.93	45.90	40.47	34.01	27.56	21.10
58.4	85.0	4089	1.184E-02	42.97	42.02	37.05	31.13	25.21	19.29
65.9	90.0	4089	1.063E-02	38.58	37.73	33.26	27.95	22.63	17.32
73.8	95.0	4089	9.418E-03	34.18	33.42	29.47	24.76	20.05	15.34
82.0	100.0	4088	8.398E-03	30.47	29.80	26.27	22.07	17.87	13.67
90.6	105.0	4081	7.394E-03	26.77	26.18	23.08	19.38	15.68	11.99
99.5	110.0	4074	6.489E-03	23.45	22.93	20.21	16.96	13.72	10.47
118.1	120.0	3820	3.963E-03	13.32	13.00	11.34	9.35	7.37	5.39
137.6	130.0	3400	2.640E-03	7.76	7.55	6.44	5.12	3.80	2.48
158.0	140.0	3130	1.467E-03	3.92	3.80	3.18	2.45	1.72	0.98
179.0	150.0	3000	9.553E-04	2.43	2.35	1.95	1.47	0.99	0.52
200.6	160.0	2950	7.884E-04	1.96	1.90	1.57	1.17	0.78	0.39
222.9	170.0	2950	7.469E-04	1.86	1.80	1.49	1.11	0.74	0.37
231.5	173.8	2950	7.261E-04	1.81	1.75	1.45	1.08	0.72	0.36
231.5	173.8	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
292.4	203.0	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
422.2	306.0	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
469.8	450.2	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00

Summary @ T<sub>wall</sub> = 540 R

Peak Heating Rate: 51.11 BTU/FT<sup>2</sup>-S

Total Heat Load: 9127 Btu/ft<sup>2</sup>



Table 15  
1.5 Stage Cycle 2 Convective Base Heating  
BP 208 - Inboard STME Nozzle (Lip)  
NLS 2 Mission 1 Nominal - July 1992

Alt Kft	Time Sec	Tr deg R	Hc BTU/FT <sup>2</sup> -S-R	Convective Heating Rate (BTU/FT <sup>2</sup> -S) for Various Wall Temperatures					
				qc@460 R	qc@540 R	qc@960 R	qc@1460 R	qc@1960 R	qc@2460 R
0.0	0.0	871	4.000E-04	0.16	0.13	-0.04	-0.24	-0.44	-0.64
1.0	10.0	831	2.725E-03	1.01	0.79	-0.35	-1.72	-3.08	-4.44
2.4	15.0	1486	5.178E-03	5.31	4.90	2.72	0.14	-2.45	-5.04
4.4	20.0	1538	7.968E-03	8.59	7.95	4.61	0.62	-3.36	-7.35
7.0	25.0	1715	1.082E-02	13.58	12.71	8.17	2.76	-2.65	-8.06
10.2	30.0	1859	1.310E-02	18.32	17.27	11.77	5.22	-1.33	-7.88
14.1	35.0	2107	1.526E-02	25.13	23.91	17.50	9.87	2.24	-5.39
16.8	38.0	2177	1.596E-02	27.40	26.13	19.42	11.44	3.46	-4.52
16.8	38.0	2177	1.596E-02	27.40	26.13	19.42	11.44	3.46	-4.52
18.6	40.0	2180	1.629E-02	28.03	26.73	19.88	11.73	3.59	-4.56
23.6	45.0	2168	1.693E-02	28.92	27.56	20.45	11.99	3.52	-4.94
28.9	50.0	2618	1.704E-02	36.77	35.41	28.25	19.73	11.21	2.69
34.6	55.0	3551	1.666E-02	51.50	50.16	43.17	34.84	26.51	18.18
40.7	60.0	3930	1.537E-02	53.34	52.11	45.65	37.97	30.28	22.59
47.2	65.0	4095	1.381E-02	50.21	49.10	43.30	36.40	29.49	22.58
54.1	70.0	4091	1.251E-02	45.41	44.41	39.16	32.90	26.65	20.40
61.4	75.0	4088	1.136E-02	41.23	40.32	35.55	29.87	24.18	18.50
69.0	80.0	4089	1.013E-02	36.76	35.95	31.70	26.63	21.57	16.50
77.0	85.0	4090	9.023E-03	32.75	32.03	28.24	23.73	19.22	14.71
85.3	90.0	4085	8.005E-03	29.02	28.38	25.02	21.01	17.01	13.01
93.9	95.0	4078	7.055E-03	25.52	24.96	22.00	18.47	14.94	11.41
102.8	100.0	4030	6.017E-03	21.48	21.00	18.47	15.46	12.46	9.45
121.2	110.0	3750	5.545E-03	18.24	17.80	15.47	12.70	9.93	7.15
140.5	120.0	3360	5.426E-03	15.73	15.30	13.02	10.31	7.60	4.88
160.3	130.0	3120	3.450E-03	9.18	8.90	7.45	5.73	4.00	2.28
180.7	140.0	3000	2.927E-03	7.43	7.20	5.97	4.51	3.04	1.58
201.4	150.0	2950	2.739E-03	6.82	6.60	5.45	4.08	2.71	1.34
221.5	159.6	2950	2.697E-03	6.72	6.50	5.37	4.02	2.67	1.32
221.5	159.6	2950	2.656E-03	6.61	6.40	5.29	3.96	2.63	1.30
301.1	200.0	2950	2.656E-03	6.61	6.40	5.29	3.96	2.63	1.30
471.1	331.8	2950	2.656E-03	6.61	6.40	5.29	3.96	2.63	1.30

Summary @ T<sub>wall</sub> = 540 R  
Peak Heating Rate: 52.11 BTU/FT<sup>2</sup>-S  
Total Heat Load: 4424.90 BTU/FT<sup>2</sup>



Facsimile Transmission  
(Instructions on Reverse)

1. TRANSMITTING STATION NO.	2. VOICE PHONE CONTACT NO.	3. MESSAGE NO.	4. TOTAL PAGES (including lead) 2	5. DATE 8/18/92
6. FROM (Name, organization and location): MARK SEAFORD				7. OFFICE CODE ED33
9. TO (Include Office Code and telephone number.) (May also be used for remarks):				8. OFFICE PHONE NO. 344-1596

REMTECH

ATTN: JOHN BROWN

FAX# 536-8599

ORIGINAL PAGE IS  
OF POOR QUALITY

BASE THERMAL ENVIRONMENT SUMMARY

① CONVECTIVE HTG RATE

	BHS	STME
PEAK CONVECTIVE HTG RATE	47.4 Btu/A <sup>2</sup> ·sec	54.1 Btu/A <sup>2</sup> ·sec

ALTITUDE	—	35.8 kft
TIME	NOM —	—
	EO —	—

② PEAK TOTAL HTG RATE (CONV + ALL RAD) AND BP LOCATION ON NOZZLE & BHS

	BHS BPXXX	STME BPXXX
TOTAL HTG RATE	—	—

③ MAX TOTAL HEAT LOAD (CONV + ALL RAD) AND BP LOCATION ON NOZZLE & BHS FOR NOM & EO CASE

	BHS BPXXX	STME BPXXX
TOTAL HEAT LOAD (NOM)	—	—
" " " (EO)	—	—

A	B	C	H	E	F	H	I	K	L	M
1	NLS 2 Mission 1 Nominal									
2	Cycle 2 Environments									
3		Qconv@540								
4										
5	BP	Peak Rate	Heat Load	Heat Rate	Heat Load	Heat Rate	Heat Load	Heat Rate	Total Peak Rate	Total Heat Load
6		BTU/Ft <sup>2</sup> -S	BTU/FT <sup>2</sup>	BTU/Ft <sup>2</sup> -S	BTU/FT <sup>2</sup>	BTU/Ft <sup>2</sup> -S	BTU/FT <sup>2</sup>	BTU/Ft <sup>2</sup> -S	BTU/Ft <sup>2</sup> -S	BTU/FT <sup>2</sup>
7	201	47.4	2800.77	5.10	229.81	0.97	242.33	53.47	53.47	3272.91
8	202	47.4	2278.8	6.83	305.76	1.37	353.74	55.60	55.60	2938.30
9	203	47.4	2240.95	6.87	297.74	1.72	458.80	55.99	55.99	2997.49
10	204	47.4	2376.7	4.98	220.05	0.96	212.74	53.34	53.34	2809.49
11	205	54.1	3752.74	4.86	222.52	1.84	381.00	60.80	60.80	4356.26
12	206	54.1	2956.91	4.66	209.48	1.26	236.12	60.02	60.02	3402.51
13	207	54.1	2920.96	4.56	197.84	2.52	438.65	61.18	61.18	3557.45
14	208	54.1	4424.9	2.90	133.96	2.68	779.12	59.68	59.68	5337.98
15	209	54.1	3165.58	2.57	114.36	1.40	337.86	58.07	58.07	3617.80
16	210	54.1	2978.92	2.92	127.51	2.38	509.95	59.40	59.40	3616.38
17	211	54.1	3102.86	3.01	136.39	3.24	686.66	60.35	60.35	3925.91
18	212	54.1	2857.41	3.74	167.99	2.02	411.73	59.86	59.86	3437.13
19	213	1.05	180.86	0.00	0.00	0.00	17.20	1.05	1.05	198.06
20										
21	NLS 2 Mission 1 Engine-Out									
22	Cycle 2 Environments									
23		Qconv@540								
24										
25	BP	Peak Rate	Heat Load	Heat Rate	Heat Load	Heat Rate	Heat Load	Heat Rate	Total Peak Rate	Total Heat Load
26		BTU/Ft <sup>2</sup> -S	BTU/FT <sup>2</sup>	BTU/Ft <sup>2</sup> -S	BTU/FT <sup>2</sup>	BTU/Ft <sup>2</sup> -S	BTU/FT <sup>2</sup>	BTU/Ft <sup>2</sup> -S	BTU/Ft <sup>2</sup> -S	BTU/FT <sup>2</sup>
27	201	47.4	3224.44	5.11	242.81	0.99	298.47	53.50	53.50	3765.72
28	202	47.4	2450.78	6.84	316.88	1.42	411.95	55.66	55.66	3179.61
29	203	47.4	2415.43	6.87	308.55	1.73	540.31	56.00	56.00	3264.29
30	204	47.4	2552.61	4.99	228.26	0.98	248.83	53.37	53.37	3029.70
31	205	54.1	4363.41	4.91	235.38	1.97	477.67	60.98	60.98	5076.46
32	206	54.1	3178.18	4.71	220.99	1.22	284.84	60.03	60.03	3684.01
33	207	54.1	3127.89	4.60	205.41	2.51	514.19	61.21	61.21	3847.49
34	208	54.1	5255.1	2.93	141.53	2.68	1018.02	59.71	59.71	6414.65
35	209	54.1	3368.32	2.60	120.14	1.47	409.85	58.17	58.17	3898.31
36	210	54.1	3178.03	2.96	132.22	2.38	594.75	59.44	59.44	3905.00
37	211	54.1	3293.05	3.04	141.39	3.23	821.68	60.37	60.37	4256.12
38	212	54.1	3061.89	3.78	173.93	2.01	481.28	59.89	59.89	3717.10
39	213	1.05	290.31	0.00	0.00	0.00	27.64	1.05	1.05	317.95

	A	B	C	D	E	F	G	H
1	NLS 2 Mission 1 Nominal							
2	Cycle 2 Radiation Environments							
3								
4	Heat Shield		Grad basegas			Grad plume		
5	Body Points	@65sec	@70 sec	@66.4 sec		@65sec	@70 sec	@66.4 sec
6	201	5.29	4.61	5.10		1.03	0.83	0.97
7	202	7.08	6.19	6.83		1.45	1.17	1.37
8	203	7.12	6.22	6.87		1.84	1.42	1.72
9	204	5.17	4.49	4.98		1.01	0.83	0.96
10	213	0.00	0.00	0.00		0.00	0.00	0.00
11								
12	STME		Grad basegas			Grad plume		
13	Body Points	@55sec	@60 sec	@56.0 sec		@55sec	@60 sec	@56.0 sec
14	205	4.63	5.79	4.86		1.92	1.54	1.84
15	206	4.44	5.54	4.66		1.31	1.06	1.26
16	207	4.34	5.42	4.56		2.62	2.12	2.52
17	208	2.76	3.46	2.90		2.76	2.37	2.68
18	209	2.45	3.07	2.57		1.46	1.18	1.40
19	210	2.78	3.49	2.92		2.47	2.04	2.38
20	211	2.86	3.59	3.01		3.35	2.79	3.24
21	212	3.55	4.48	3.74		2.11	1.68	2.02
22								
23								
24	NLS 2 Mission 1 Engine-Out							
25	Cycle 2 Radiation Environments							
26								
27	Heat Shield		Grad basegas			Grad plume		
28	Body Points	@75sec	@80 sec	@78.3 sec		@75sec	@80 sec	@78.3 sec
29	201	5.54	4.89	5.11		1.14	0.92	0.99
30	202	7.41	6.55	6.84		1.62	1.31	1.42
31	203	7.44	6.58	6.87		2.03	1.57	1.73
32	204	5.42	4.77	4.99		1.11	0.92	0.98
33	213	0.00	0.00	0.00		0.00	0.00	0.00
34								
35	STME		Grad basegas			Grad plume		
36	Body Points	@65sec	@70 sec	@67.7 sec		@65sec	@70 sec	@67.7 sec
37	205	4.20	5.51	4.91		2.13	1.83	1.97
38	206	4.03	5.28	4.71		1.31	1.14	1.22
39	207	3.95	5.16	4.60		2.74	2.32	2.51
40	208	2.50	3.29	2.93		2.84	2.55	2.68
41	209	2.23	2.92	2.60		1.54	1.41	1.47
42	210	2.53	3.32	2.96		2.56	2.22	2.38
43	211	2.60	3.41	3.04		3.47	3.02	3.23
44	212	3.22	4.25	3.78		2.18	1.86	2.01

Post-It™ brand fax transmittal memo 7671 # of pages = 7

To J REARDEN	From J. BRUNN
Co.	Co.
Dept.	Phone #
Fax #	Fax #

Bob,

Mark Seaford reviewed the Cycle 2 environments & wanted to know why gc-us-alt was different in the first 100 kft for engine-out & nominal.


After discussing with Craig, we discovered that the 5sec intervals we tabulated in the report missed some of the peaks & valleys in Craig's "master" curves.

Craig & I faxed some backup material to Mark & discussed via telecon Monday (16<sup>th</sup>) afternoon. Mark said it wasn't a big issue; he just wanted to be clear. After offering to smooth Craig's curves & ~~re-doing~~ re-doing the environments, Mark said it wasn't necessary.

I'm leaving a copy of all the backup material we faxed back & forth.

j.b.

- Nom
- EO



REMTECH inc

3304 Westmill Drive

Huntsville, AL 35805

---

FACSIMILE (FAX) COVER SHEET

GROUP 3 COMPATIBILITY

(205) 536-8599

After 5 p.m. and on weekends: (205) 536-8599, Ext. 100

---

SUBJECT:

NLS CYCLE 2 CONVECTION

DATE:

AUG 16, 1992

FAX NO.:

544-1215

PLEASE DELIVER THE ATTACHED MESSAGE TO:

NAME:

MARK SEAFORD

LOCATION:

ED 33

PHONE:

544-1596

FROM:

John Brown

PHONE:

536-8581

TOTAL NUMBER OF PAGES INCLUDING THIS COVER SHEET:

4 + COVER

TRANSMISSION/LEGIBILITY PROBLEMS? CALL (205) 536-3531

REMARKS:

---

---

---

---

---






Figure 16: NLS 2 Base Gas Temperature Estimates

- sol<sup>n</sup> ) 7


881-2822-108

	NOM		ENG 0.1	
	q	Q	q	Q
BAS	47.4	2150	47.4	2254
ENG	54.1	2593	54.1	2738


7/28/92  
noon

- $P/P = 2.224$  for complete nominal flight
- CEC up-dated for 650K


NLS STME Engine Nozzle  
 $T_w = 540 \text{ R}$




NLS Base Heat Shield  
T<sub>v</sub> = 540 R




NLS Base Heat Shield  
 $T_w = 540 \text{ R}$




NLS STME Engine Nozzle  
 $T_w = 540 \text{ R}$




### NLS 2 Mission 1 Core Base Heat Shield




### NLS 2 Mission 1 STME



NLS 2 Mission 1  
BP 201: Core Base Heat Shield



NLS 2 Mission 1  
BP 212: STME Nozzle Lip







# Facsimile Transmission

(Instructions on Reverse)

1. TRANSMITTING STATION NO.	2. VOICE PHONE CONTACT NO.	3. MESSAGE NO.	4. TOTAL PAGES (including lead) 5	5. DATE 8/17/92
6. FROM (Name, organization and location): MARK SEAFORD				7. OFFICE CODE ED33
				8. OFFICE PHONE NO. 544-1596
9. TO (Include Office Code and telephone number.) (May also be used for remarks):				

REMTECH

ATTN: JOHN BROWN

FAX # 536-8599

	H (kft)	Tr (°R)	hc(Btu/ft2-s-r)
1	28.900	2618.000	0.01704
2	34.600	3551.000	0.01666
3	40.700	3930.000	0.01537
4	47.200	4095.000	0.01381
5	54.100	4091.000	0.01251
6	61.400	4088.000	0.01136
7	69.000	4089.000	0.01013

*NOM*

	H(kft)-eo	Tr(°R)	hc(Btu/ft2-s-r)
	27.500	2527.000	0.01701
	32.700	3202.000	0.01694
	38.500	3546.000	0.01593
	44.700	4094.000	0.01438
	51.300	4093.000	0.01292
	58.400	4089.000	0.01184
	65.900	4089.000	0.01063

*EO*

Data from "slime tr vs alt"




Table 16

1.5 Stage Cycle 2 Convective Base Heating  
 BP 208 - Inboard STME Nozzle (Lip)  
 NLS 2 Mission 1 Engine Out - July 1992

Alt Kft	Time Sec	Tr deg R	Hc BTU/FT <sup>2</sup> -S-R	Convective Heating Rate (BTU/FT <sup>2</sup> -S) for Various Wall Temperatures					
				qc@460 R	qc@540 R	qc@960 R	qc@1460 R	qc@1960 R	qc@2460 R
0.0	0.0	871	4.00E-04	0.16	0.13	-0.04	-0.24	-0.44	-0.64
0.6	10.0	810	1.764E-03	0.62	0.48	-0.26	-1.15	-2.03	-2.91
1.4	15.0	1078	3.369E-03	2.08	1.81	0.40	-1.29	-2.97	-4.65
2.5	20.0	1502	5.366E-03	5.59	5.16	2.91	0.22	-2.46	-5.14
4.1	25.0	1536	7.602E-03	8.18	7.57	4.38	0.58	-3.22	-7.03
6.0	30.0	1635	9.761E-03	11.47	10.69	6.59	1.71	-3.17	-8.05
8.4	35.0	1780	1.209E-02	15.96	14.99	9.91	3.87	-2.18	-8.22
11.3	40.0	1946	1.368E-02	20.33	19.23	13.49	6.65	-0.19	-7.03
14.6	45.0	2126	1.553E-02	25.88	24.64	18.12	10.35	2.59	-5.18
18.4	50.0	2184	1.625E-02	28.01	26.71	19.89	11.77	3.64	-4.48
22.7	55.0	2092	1.691E-02	27.60	26.25	19.15	10.69	2.24	-6.22
27.5	60.0	2527	1.701E-02	35.15	33.79	26.65	18.14	9.64	1.13
32.7	65.0	3202	1.694E-02	46.45	45.10	37.98	29.51	21.04	12.57
38.5	70.0	3546	1.593E-02	49.16	47.88	41.19	33.22	25.26	17.29
44.7	75.0	4094	1.438E-02	52.26	51.11	45.07	37.88	30.69	23.50
51.3	80.0	4093	1.292E-02	46.93	45.90	40.47	34.01	27.56	21.10
58.4	85.0	4089	1.184E-02	42.97	42.02	37.05	31.13	25.21	19.29
65.9	90.0	4089	1.063E-02	38.58	37.73	33.26	27.95	22.63	17.32
73.8	95.0	4089	9.418E-03	34.18	33.42	29.47	24.76	20.05	15.34
82.0	100.0	4088	8.398E-03	30.47	29.80	26.27	22.07	17.87	13.67
90.6	105.0	4081	7.394E-03	26.77	26.18	23.08	19.38	15.68	11.99
99.5	110.0	4074	6.489E-03	23.45	22.93	20.21	16.96	13.72	10.47
118.1	120.0	3820	6.098E-03	20.49	20.00	17.44	14.39	11.34	8.29
137.6	130.0	3400	5.839E-03	17.17	16.70	14.25	11.33	8.41	5.49
158.0	140.0	3130	3.668E-03	9.79	9.50	7.96	6.13	4.29	2.46
179.0	150.0	3000	2.967E-03	7.54	7.30	6.05	4.57	3.09	1.60
200.6	160.0	2950	2.759E-03	6.87	6.65	5.49	4.11	2.73	1.35
222.9	170.0	2950	2.739E-03	6.82	6.60	5.45	4.08	2.71	1.34
231.5	173.8	2950	2.697E-03	6.72	6.50	5.37	4.02	2.67	1.32
231.5	173.8	2950	2.656E-03	6.61	6.40	5.28	3.96	2.63	1.30
292.4	203.0	2950	2.656E-03	6.61	6.40	5.29	3.96	2.63	1.30
422.2	306.0	2950	2.656E-03	6.61	6.40	5.29	3.96	2.63	1.30
469.8	450.2	2950	2.656E-03	6.61	6.40	5.29	3.96	2.63	1.30

Summary @ T<sub>wall</sub> = 540 R

Peak Heating Rate: 51.11 BTU/FT<sup>2</sup>-S  
 Total Heat Load: 5255.10 BTU/FT<sup>2</sup>

Table 17

1.5 Stage Cycle 2 Convective Base Heating  
 BP 209 - Inboard STME Nozzle (Lip)  
 NLS 2 Mission 1 Nominal - July 1992

Alt Kft	Time Sec	Tr deg R	Hc BTU/FT^2-S-R	Convective Heating Rate (BTU/Ft^2-S) for Various Wall Temperatures					
				qc@460 R	qc@540 R	qc@960 R	qc@1460 R	qc@1960 R	qc@2460 R
0.0	0.0	871	4.000E-04	0.16	0.13	-0.04	-0.24	-0.44	-0.64
1.0	10.0	831	2.725E-03	1.01	0.79	-0.35	-1.72	-3.08	-4.44
2.4	15.0	1486	5.178E-03	5.31	4.90	2.72	0.14	-2.45	-5.04
4.4	20.0	1538	7.968E-03	8.59	7.95	4.61	0.62	-3.36	-7.35
7.0	25.0	1715	1.082E-02	13.58	12.71	8.17	2.76	-2.65	-8.06
10.2	30.0	1859	1.310E-02	18.32	17.27	11.77	5.22	-1.33	-7.88
14.1	35.0	2107	1.526E-02	25.13	23.91	17.50	9.87	2.24	-5.39
16.8	38.0	2177	1.596E-02	27.40	26.13	19.42	11.44	3.46	-4.52
16.8	38.0	2177	1.596E-02	27.40	26.13	19.42	11.44	3.46	-4.52
18.6	40.0	2180	1.629E-02	28.03	26.73	19.88	11.73	3.59	-4.56
23.6	45.0	2168	1.693E-02	28.92	27.56	20.45	11.99	3.52	-4.94
28.9	50.0	2618	1.704E-02	36.77	35.41	28.25	19.73	11.21	2.69
34.6	55.0	3551	1.666E-02	51.50	50.16	43.17	34.84	26.51	18.18
40.7	60.0	3930	1.537E-02	53.34	52.11	45.65	37.97	30.28	22.59
47.2	65.0	4095	1.381E-02	50.21	49.10	43.30	36.40	29.49	22.58
54.1	70.0	4091	1.251E-02	45.41	44.41	39.16	32.90	26.65	20.40
61.4	75.0	4088	1.136E-02	41.23	40.32	35.55	29.87	24.18	18.50
69.0	80.0	4089	1.013E-02	36.76	35.95	31.70	26.63	21.57	16.50
77.0	85.0	4090	9.023E-03	32.75	32.03	28.24	23.73	19.22	14.71
85.3	90.0	4085	8.005E-03	29.02	28.38	25.02	21.01	17.01	13.01
93.9	95.0	4078	7.055E-03	25.52	24.96	22.00	18.47	14.94	11.41
102.8	100.0	4030	5.301E-03	18.92	18.50	16.27	13.62	10.97	8.32
121.2	110.0	3750	4.050E-03	13.32	13.00	11.30	9.27	7.25	5.22
140.5	120.0	3360	3.901E-03	11.31	11.00	9.36	7.41	5.46	3.51
160.3	130.0	3120	2.442E-03	6.50	6.30	5.27	4.05	2.83	1.61
180.7	140.0	3000	1.992E-03	5.06	4.90	4.06	3.07	2.07	1.08
201.4	150.0	2950	1.826E-03	4.55	4.40	3.63	2.72	1.81	0.89
221.5	159.6	2950	1.743E-03	4.34	4.20	3.47	2.60	1.73	0.85
221.5	159.6	2950	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04
301.1	200.0	2950	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04
471.1	331.8	2950	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04

Summary @ T<sub>wall</sub> = 540 R  
 Peak Heating Rate: 52.11 BTU/Ft^2-S  
 Total Heat Load: 3165.58 BTU/Ft^2

Table 18  
 1.5 Stage Cycle 2 Convective Base Heating  
 BP 209 - Inboard STME Nozzle (Lip)  
 NLS 2 Mission 1 Engine Out - July 1992

Alt Kft	Time Sec	Tr deg R	Hc BTU/FT^2-S-R	Convective Heating Rate (BTU/FI^2-S) for Various Wall Temperatures					
				qc@460 R	qc@540 R	qc@960 R	qc@1460 R	qc@1960 R	qc@2460 R
0.0	0.0	871	4.000E-04	0.16	0.13	-0.04	-0.24	-0.44	-0.64
0.6	10.0	810	1.764E-03	0.62	0.48	-0.26	-1.15	-2.03	-2.91
1.4	15.0	1078	3.369E-03	2.08	1.81	0.40	-1.29	-2.97	-4.65
2.5	20.0	1502	5.366E-03	5.59	5.16	2.91	0.22	-2.46	-5.14
4.1	25.0	1536	7.602E-03	8.18	7.57	4.38	0.58	-3.22	-7.03
6.0	30.0	1635	9.761E-03	11.47	10.69	6.59	1.71	-3.17	-8.05
8.4	35.0	1780	1.209E-02	15.96	14.99	9.91	3.87	-2.18	-8.22
11.3	40.0	1946	1.368E-02	20.33	19.23	13.49	6.65	-0.19	-7.03
14.6	45.0	2126	1.553E-02	25.88	24.64	18.12	10.35	2.59	-5.18
18.4	50.0	2184	1.625E-02	28.01	26.71	19.89	11.77	3.64	-4.48
22.7	55.0	2092	1.691E-02	27.60	26.25	19.15	10.69	2.24	-6.22
27.5	60.0	2527	1.701E-02	35.15	33.79	26.65	18.14	9.64	1.13
32.7	65.0	3202	1.694E-02	46.45	45.10	37.98	29.51	21.04	12.57
38.5	70.0	3546	1.593E-02	49.16	47.88	41.19	33.22	25.26	17.29
44.7	75.0	4094	1.438E-02	52.26	51.11	45.07	37.88	30.69	23.50
51.3	80.0	4093	1.292E-02	46.93	45.90	40.47	34.01	27.56	21.10
58.4	85.0	4089	1.184E-02	42.97	42.02	37.05	31.13	25.21	19.29
65.9	90.0	4089	1.063E-02	38.58	37.73	33.26	27.95	22.63	17.32
73.8	95.0	4089	9.418E-03	34.18	33.42	29.47	24.76	20.05	15.34
82.0	100.0	4088	8.398E-03	30.47	29.80	26.27	22.07	17.87	13.67
90.6	105.0	4081	7.394E-03	26.77	26.18	23.08	19.38	15.68	11.99
99.5	110.0	4074	6.489E-03	23.45	22.93	20.21	16.96	13.72	10.47
118.1	120.0	3820	5.183E-03	17.41	17.00	14.82	12.23	9.64	7.05
137.6	130.0	3400	4.161E-03	12.23	11.90	10.15	8.07	5.99	3.91
158.0	140.0	3130	2.606E-03	6.96	6.75	5.66	4.35	3.05	1.75
179.0	150.0	3000	2.012E-03	5.11	4.95	4.10	3.10	2.09	1.09
200.6	160.0	2950	1.826E-03	4.55	4.40	3.63	2.72	1.81	0.89
222.9	170.0	2950	1.743E-03	4.34	4.20	3.47	2.60	1.73	0.85
231.5	173.8	2950	1.743E-03	4.34	4.20	3.47	2.60	1.73	0.85
231.5	173.8	2950	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04
292.4	203.0	2950	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04
422.2	306.0	2950	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04
469.8	450.2	2950	8.299E-05	0.21	0.20	0.17	0.12	0.08	0.04

Summary @ T<sub>wall</sub> = 540 R

Peak Heating Rate: 51.11 BTU/FI^2-S  
 Total Heat Load: 3368.32 BTU/FI^2

Table 19

1.5 Stage Cycle 2 Convective Base Heating  
 BP 210 - Outboard STME Nozzle (Lip)  
 NLS 2 Mission 1 Nominal - July 1992

Alt Kft	Time Sec	Tr deg R	Hc BTU/FT^2-S-R	Convective Heating Rate (BTU/FT^2-S) for Various Wall Temperatures					
				qc@460 R	qc@540 R	qc@960 R	qc@1460 R	qc@1960 R	qc@2460 R
0.0	0.0	871	4.000E-04	0.16	0.13	-0.04	-0.24	-0.44	-0.64
1.0	10.0	831	2.725E-03	1.01	0.79	-0.35	-1.72	-3.08	-4.44
2.4	15.0	1486	5.178E-03	5.31	4.90	2.72	0.14	-2.45	-5.04
4.4	20.0	1538	7.968E-03	8.59	7.95	4.61	0.62	-3.36	-7.35
7.0	25.0	1715	1.082E-02	13.58	12.71	8.17	2.76	-2.65	-8.06
10.2	30.0	1859	1.310E-02	18.32	17.27	11.77	5.22	-1.33	-7.88
14.1	35.0	2107	1.526E-02	25.13	23.91	17.50	9.87	2.24	-5.39
16.8	38.0	2177	1.596E-02	27.40	26.13	19.42	11.44	3.46	-4.52
16.8	38.0	2177	1.596E-02	27.40	26.13	19.42	11.44	3.46	-4.52
18.6	40.0	2180	1.629E-02	28.03	26.73	19.88	11.73	3.59	-4.56
23.6	45.0	2168	1.693E-02	28.92	27.56	20.45	11.99	3.52	-4.94
28.9	50.0	2618	1.704E-02	36.77	35.41	28.25	19.73	11.21	2.69
34.6	55.0	3551	1.666E-02	51.50	50.16	43.17	34.84	26.51	18.18
40.7	60.0	3930	1.537E-02	53.34	52.11	45.65	37.97	30.28	22.59
47.2	65.0	4095	1.381E-02	50.21	49.10	43.30	36.40	29.49	22.58
54.1	70.0	4091	1.251E-02	45.41	44.41	39.16	32.90	26.65	20.40
61.4	75.0	4088	1.136E-02	41.23	40.32	35.55	29.87	24.18	18.50
69.0	80.0	4089	1.013E-02	36.76	35.95	31.70	26.63	21.57	16.50
77.0	85.0	4090	9.023E-03	32.75	32.03	28.24	23.73	19.22	14.71
85.3	90.0	4085	8.005E-03	29.02	28.38	25.02	21.01	17.01	13.01
93.9	95.0	4078	7.055E-03	25.52	24.96	22.00	18.47	14.94	11.41
102.8	100.0	4030	4.241E-03	15.14	14.80	13.02	10.90	8.78	6.66
121.2	110.0	3750	2.679E-03	8.81	8.60	7.47	6.14	4.80	3.46
140.5	120.0	3360	2.730E-03	7.92	7.70	6.55	5.19	3.82	2.46
160.3	130.0	3120	1.744E-03	4.64	4.50	3.77	2.90	2.02	1.15
180.7	140.0	3000	1.504E-03	3.82	3.70	3.07	2.32	1.56	0.81
201.4	150.0	2950	1.349E-03	3.36	3.25	2.68	2.01	1.34	0.66
221.5	159.6	2950	1.203E-03	3.00	2.90	2.39	1.79	1.19	0.59
221.5	159.6	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
301.1	200.0	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
471.1	331.8	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00

Summary @ Twall = 540 R

Peak Heating Rate: 52.11 BTU/FT^2-S

Total Heat Load: 2978.92 BTU/FT^2

Table 20

1.5 Stage Cycle 2 Convective Base Heating  
 BP 210 - Outboard STME Nozzle (Lip)  
 NLS 2 Mission 1 Engine Out - July 1992

Alt Kft	Time Sec	Tr deg R	Hc BTU/FT <sup>2</sup> -S-R	Convective Heating Rate (BTU/FT <sup>2</sup> -S) for Various Wall Temperatures					
				qc@460 R	qc@540 R	qc@960 R	qc@1460 R	qc@1960 R	qc@2460 R
0.0	0.0	871	4.000E-04	0.16	0.13	-0.04	-0.24	-0.44	-0.64
0.6	10.0	810	1.764E-03	0.62	0.48	-0.26	-1.15	-2.03	-2.91
1.4	15.0	1078	3.369E-03	2.08	1.81	0.40	-1.29	-2.97	-4.65
2.5	20.0	1502	5.366E-03	5.59	5.16	2.91	0.22	-2.46	-5.14
4.1	25.0	1536	7.602E-03	8.18	7.57	4.38	0.58	-3.22	-7.03
6.0	30.0	1635	9.761E-03	11.47	10.69	6.59	1.71	-3.17	-8.05
8.4	35.0	1780	1.209E-02	15.96	14.99	9.91	3.87	-2.18	-8.22
11.3	40.0	1946	1.368E-02	20.33	19.23	13.49	6.65	-0.19	-7.03
14.6	45.0	2126	1.553E-02	25.88	24.64	18.12	10.35	2.59	-5.18
18.4	50.0	2184	1.625E-02	28.01	26.71	19.89	11.77	3.64	-4.48
22.7	55.0	2092	1.691E-02	27.60	26.25	19.15	10.69	2.24	-6.22
27.5	60.0	2527	1.701E-02	35.15	33.79	26.65	18.14	9.64	1.13
32.7	65.0	3202	1.694E-02	46.45	45.10	37.98	29.51	21.04	12.57
38.5	70.0	3546	1.593E-02	49.16	47.88	41.19	33.22	25.26	17.29
44.7	75.0	4094	1.438E-02	52.26	51.11	45.07	37.88	30.69	23.50
51.3	80.0	4093	1.292E-02	46.93	45.90	40.47	34.01	27.56	21.10
58.4	85.0	4089	1.184E-02	42.97	42.02	37.05	31.13	25.21	19.29
65.9	90.0	4089	1.063E-02	38.58	37.73	33.26	27.95	22.63	17.32
73.8	95.0	4089	9.418E-03	34.18	33.42	29.47	24.76	20.05	15.34
82.0	100.0	4088	8.398E-03	30.47	29.80	26.27	22.07	17.87	13.67
90.6	105.0	4081	7.394E-03	26.77	26.18	23.08	19.38	15.68	11.99
99.5	110.0	4074	6.489E-03	23.45	22.93	20.21	16.96	13.72	10.47
118.1	120.0	3820	3.963E-03	13.32	13.00	11.34	9.35	7.37	5.39
137.6	130.0	3400	2.797E-03	8.22	8.00	6.83	5.43	4.03	2.63
158.0	140.0	3130	1.815E-03	4.85	4.70	3.94	3.03	2.12	1.22
179.0	150.0	3000	1.504E-03	3.82	3.70	3.07	2.32	1.56	0.81
200.6	160.0	2950	1.349E-03	3.36	3.25	2.68	2.01	1.34	0.66
222.9	170.0	2950	1.203E-03	3.00	2.90	2.39	1.79	1.19	0.59
231.5	173.8	2950	1.183E-03	2.94	2.85	2.35	1.76	1.17	0.58
231.5	173.8	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
292.4	203.0	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
422.2	306.0	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
469.8	450.2	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00

Summary @ T<sub>wall</sub> = 540 R

Peak Heating Rate: 51.11 BTU/FT<sup>2</sup>-S  
 Total Heat Load: 3178.03 BTU/FT<sup>2</sup>



Table 21

1.5 Stage Cycle 2 Convective Base Heating  
 BP 211 - Outboard STME Nozzle (Lip)  
 NLS 2 Mission 1 Nominal - July 1992

Alt Kft	Time Sec	Tr deg R	Hc BTU/FT^2-S-R	Convective Heating Rate (BTU/FT^2-S) for Various Wall Temperatures					
				qc@460 R	qc@540 R	qc@960 R	qc@1460 R	qc@1960 R	qc@2460 R
0.0	0.0	871	4.000E-04	0.16	0.13	-0.04	-0.24	-0.44	-0.64
1.0	10.0	831	2.725E-03	1.01	0.79	-0.35	-1.72	-3.08	-4.44
2.4	15.0	1486	5.178E-03	5.31	4.90	2.72	0.14	-2.45	-5.04
4.4	20.0	1538	7.968E-03	8.59	7.95	4.61	0.62	-3.36	-7.35
7.0	25.0	1715	1.082E-02	13.58	12.71	8.17	2.76	-2.65	-8.06
10.2	30.0	1859	1.310E-02	18.32	17.27	11.77	5.22	-1.33	-7.88
14.1	35.0	2107	1.526E-02	25.13	23.91	17.50	9.87	2.24	-5.39
16.8	38.0	2177	1.596E-02	27.40	26.13	19.42	11.44	3.46	-4.52
16.8	38.0	2177	1.596E-02	27.40	26.13	19.42	11.44	3.46	-4.52
18.6	40.0	2180	1.629E-02	28.03	26.73	19.88	11.73	3.59	-4.56
23.6	45.0	2168	1.693E-02	28.92	27.56	20.45	11.99	3.52	-4.94
28.9	50.0	2618	1.704E-02	36.77	35.41	28.25	19.73	11.21	2.69
34.6	55.0	3551	1.666E-02	51.50	50.16	43.17	34.84	26.51	18.18
40.7	60.0	3930	1.537E-02	53.34	52.11	45.65	37.97	30.28	22.59
47.2	65.0	4095	1.381E-02	50.21	49.10	43.30	36.40	29.49	22.58
54.1	70.0	4091	1.251E-02	45.41	44.41	39.16	32.90	26.65	20.40
61.4	75.0	4088	1.136E-02	41.23	40.32	35.55	29.87	24.18	18.50
69.0	80.0	4089	1.013E-02	36.76	35.95	31.70	26.63	21.57	16.50
77.0	85.0	4090	9.023E-03	32.75	32.03	28.24	23.73	19.22	14.71
85.3	90.0	4085	8.005E-03	29.02	28.38	25.02	21.01	17.01	13.01
93.9	95.0	4078	7.055E-03	25.52	24.96	22.00	18.47	14.94	11.41
102.8	100.0	4030	4.871E-03	17.39	17.00	14.95	12.52	10.08	7.65
121.2	110.0	3750	3.738E-03	12.30	12.00	10.43	8.56	6.69	4.82
140.5	120.0	3360	3.688E-03	10.70	10.40	8.85	7.01	5.16	3.32
160.3	130.0	3120	2.326E-03	6.19	6.00	5.02	3.86	2.70	1.53
180.7	140.0	3000	2.033E-03	5.16	5.00	4.15	3.13	2.11	1.10
201.4	150.0	2950	1.867E-03	4.65	4.50	3.72	2.78	1.85	0.91
221.5	159.6	2950	1.743E-03	4.34	4.20	3.47	2.60	1.73	0.85
221.5	159.6	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
301.1	200.0	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
471.1	331.8	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00

Summary @ T<sub>wall</sub> = 540 R

Peak Heating Rate: 52.11 BTU/FT^2-S  
 Total Heat Load: 3102.86 BTU/FT^2

1.5 Stage Cycle 2 Convective Base Heating  
 BP 211 - Outboard STME Nozzle (Lip)  
 NLS 2 Mission 1 Engine Out - July 1992

Table 22

Alt Kft	Time Sec	Tr deg R	Hc BTU/FT <sup>2</sup> -S-R	Convective Heating Rate (BTU/FT <sup>2</sup> -S) for Various Wall Temperatures					
				qc@460 R	qc@540 R	qc@960 R	qc@1460 R	qc@1960 R	qc@2460 R
0.0	0.0	871	4.000E-04	0.16	0.13	-0.04	-0.24	-0.44	-0.64
0.6	10.0	810	1.764E-03	0.62	0.48	-0.26	-1.15	-2.03	-2.91
1.4	15.0	1078	3.369E-03	2.08	1.81	0.40	-1.29	-2.97	-4.65
2.5	20.0	1502	5.366E-03	5.59	5.16	2.91	0.22	-2.46	-5.14
4.1	25.0	1536	7.602E-03	8.18	7.57	4.38	0.58	-3.22	-7.03
6.0	30.0	1635	9.761E-03	11.47	10.69	6.59	1.71	-3.17	-8.05
8.4	35.0	1780	1.209E-02	15.96	14.99	9.91	3.87	-2.18	-8.22
11.3	40.0	1946	1.368E-02	20.33	19.23	13.49	6.65	-0.19	-7.03
14.6	45.0	2126	1.553E-02	25.88	24.64	18.12	10.35	2.59	-5.18
18.4	50.0	2184	1.625E-02	28.01	26.71	19.89	11.77	3.64	-4.48
22.7	55.0	2092	1.691E-02	27.60	26.25	19.15	10.69	2.24	-6.22
27.5	60.0	2527	1.701E-02	35.15	33.79	26.65	18.14	9.64	1.13
32.7	65.0	3202	1.694E-02	46.45	45.10	37.98	29.51	21.04	12.57
38.5	70.0	3546	1.593E-02	49.16	47.88	41.19	33.22	25.26	17.29
44.7	75.0	4094	1.438E-02	52.26	51.11	45.07	37.88	30.69	23.50
51.3	80.0	4093	1.292E-02	46.93	45.90	40.47	34.01	27.56	21.10
58.4	85.0	4089	1.184E-02	42.97	42.02	37.05	31.13	25.21	19.29
65.9	90.0	4089	1.063E-02	38.58	37.73	33.26	27.95	22.63	17.32
73.8	95.0	4089	9.418E-03	34.18	33.42	29.47	24.76	20.05	15.34
82.0	100.0	4088	8.398E-03	30.47	29.80	26.27	22.07	17.87	13.67
90.6	105.0	4081	7.394E-03	26.77	26.18	23.08	19.38	15.68	11.99
99.5	110.0	4074	6.489E-03	23.45	22.93	20.21	16.96	13.72	10.47
118.1	120.0	3820	4.878E-03	16.39	16.00	13.95	11.51	9.07	6.63
137.6	130.0	3400	3.846E-03	11.31	11.00	9.38	7.46	5.54	3.62
158.0	140.0	3130	2.510E-03	6.70	6.50	5.45	4.19	2.94	1.68
179.0	150.0	3000	2.073E-03	5.27	5.10	4.23	3.19	2.16	1.12
200.6	160.0	2950	1.867E-03	4.65	4.50	3.72	2.78	1.85	0.91
222.9	170.0	2950	1.701E-03	4.24	4.10	3.39	2.53	1.68	0.83
231.5	173.8	2950	1.680E-03	4.18	4.05	3.34	2.50	1.66	0.82
231.5	173.8	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
292.4	203.0	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
422.2	306.0	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
469.8	450.2	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00

Summary @ T<sub>wall</sub> = 540 R

Peak Heating Rate: 51.11 BTU/FT<sup>2</sup>-S  
 Total Heat Load: 3293.05 BTU/FT<sup>2</sup>

Table 23

1.5 Stage Cycle 2 Convective Base Heating  
 BP 212 - Outboard STME Nozzle (Lip)  
 NLS 2 Mission 1 Nominal - July 1992

Alt Kft	Time Sec	Tr deg R	Hc BTU/FT <sup>2</sup> -S-R	Convective Heating Rate (BTU/FT <sup>2</sup> -S) for Various Wall Temperatures					
				qc@460 R	qc@540 R	qc@960 R	qc@1460 R	qc@1960 R	qc@2460 R
0.0	0.0	871	4.000E-04	0.16	0.13	-0.04	-0.24	-0.44	-0.64
1.0	10.0	831	2.725E-03	1.01	0.79	-0.35	-1.72	-3.08	-4.44
2.4	15.0	1486	5.178E-03	5.31	4.90	2.72	0.14	-2.45	-5.04
4.4	20.0	1538	7.968E-03	8.59	7.95	4.61	0.62	-3.36	-7.35
7.0	25.0	1715	1.082E-02	13.58	12.71	8.17	2.76	-2.65	-8.06
10.2	30.0	1859	1.310E-02	18.32	17.27	11.77	5.22	-1.33	-7.88
14.1	35.0	2107	1.526E-02	25.13	23.91	17.50	9.87	2.24	-5.39
16.8	38.0	2177	1.596E-02	27.40	26.13	19.42	11.44	3.46	-4.52
16.8	38.0	2177	1.596E-02	27.40	26.13	19.42	11.44	3.46	-4.52
18.6	40.0	2180	1.629E-02	28.03	26.73	19.88	11.73	3.59	-4.56
23.6	45.0	2168	1.693E-02	28.92	27.56	20.45	11.99	3.52	-4.94
28.9	50.0	2618	1.704E-02	36.77	35.41	28.25	19.73	11.21	2.69
34.6	55.0	3551	1.666E-02	51.50	50.16	43.17	34.84	26.51	18.18
40.7	60.0	3930	1.537E-02	53.34	52.11	45.65	37.97	30.28	22.59
47.2	65.0	4095	1.381E-02	50.21	49.10	43.30	36.40	29.49	22.58
54.1	70.0	4091	1.251E-02	45.41	44.41	39.16	32.90	26.65	20.40
61.4	75.0	4088	1.136E-02	41.23	40.32	35.55	29.87	24.18	18.50
69.0	80.0	4089	1.013E-02	36.76	35.95	31.70	26.63	21.57	16.50
77.0	85.0	4090	9.023E-03	32.75	32.03	28.24	23.73	19.22	14.71
85.3	90.0	4085	8.005E-03	29.02	28.38	25.02	21.01	17.01	13.01
93.9	95.0	4078	7.055E-03	25.52	24.96	22.00	18.47	14.94	11.41
102.8	100.0	4030	3.438E-03	12.28	12.00	10.56	8.84	7.12	5.40
121.2	110.0	3750	1.745E-03	5.74	5.60	4.87	4.00	3.12	2.25
140.5	120.0	3360	1.773E-03	5.14	5.00	4.26	3.37	2.48	1.60
160.3	130.0	3120	1.202E-03	3.20	3.10	2.60	1.99	1.39	0.79
180.7	140.0	3000	9.756E-04	2.48	2.40	1.99	1.50	1.01	0.53
201.4	150.0	2950	8.714E-04	2.17	2.10	1.73	1.30	0.86	0.43
221.5	159.6	2950	7.469E-04	1.86	1.80	1.49	1.11	0.74	0.37
221.5	159.6	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
301.1	200.0	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
471.1	331.8	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00

Summary @ Twall = 540 R

Peak Heating Rate: 52.11 BTU/FT<sup>2</sup>-S  
 Total Heat Load: 2857.41 BTU/FT<sup>2</sup>

Table 24  
 1.5 Stage Cycle 2 Convective Base Heating  
 BP 212 - Outboard STME Nozzle (Lip)  
 NLS 2 Mission 1 Engine Out - July 1992

Alt Kft	Time Sec	Tr deg R	Hc BTU/FT <sup>2</sup> -S-R	Convective Heating Rate (BTU/FT <sup>2</sup> -S) for Various Wall Temperatures					
				qc@460 R	qc@540 R	qc@960 R	qc@1460 R	qc@1960 R	qc@2460 R
0.0	0.0	871	4.000E-04	0.16	0.13	-0.04	-0.24	-0.44	-0.64
0.6	10.0	810	1.764E-03	0.62	0.48	-0.26	-1.15	-2.03	-2.91
1.4	15.0	1078	3.369E-03	2.08	1.81	0.40	-1.29	-2.97	-4.65
2.5	20.0	1502	5.366E-03	5.59	5.16	2.91	0.22	-2.46	-5.14
4.1	25.0	1536	7.602E-03	8.18	7.57	4.38	0.58	-3.22	-7.03
6.0	30.0	1635	9.761E-03	11.47	10.69	6.59	1.71	-3.17	-8.05
8.4	35.0	1780	1.209E-02	15.96	14.99	9.91	3.87	-2.18	-8.22
11.3	40.0	1946	1.368E-02	20.33	19.23	13.49	6.65	-0.19	-7.03
14.6	45.0	2126	1.553E-02	25.88	24.64	18.12	10.35	2.59	-5.18
18.4	50.0	2184	1.625E-02	28.01	26.71	19.89	11.77	3.64	-4.48
22.7	55.0	2092	1.691E-02	27.60	26.25	19.15	10.69	2.24	-6.22
27.5	60.0	2527	1.701E-02	35.15	33.79	26.65	18.14	9.64	1.13
32.7	65.0	3202	1.694E-02	46.45	45.10	37.98	29.51	21.04	12.57
38.5	70.0	3546	1.593E-02	49.16	47.88	41.19	33.22	25.26	17.29
44.7	75.0	4094	1.438E-02	52.26	51.11	45.07	37.88	30.69	23.50
51.3	80.0	4093	1.292E-02	46.93	45.90	40.47	34.01	27.56	21.10
58.4	85.0	4089	1.184E-02	42.97	42.02	37.05	31.13	25.21	19.29
65.9	90.0	4089	1.063E-02	38.58	37.73	33.26	27.95	22.63	17.32
73.8	95.0	4089	9.418E-03	34.18	33.42	29.47	24.76	20.05	15.34
82.0	100.0	4088	8.398E-03	30.47	29.80	26.27	22.07	17.87	13.67
90.6	105.0	4081	7.394E-03	26.77	26.18	23.08	19.38	15.68	11.99
99.5	110.0	4074	6.489E-03	23.45	22.93	20.21	16.96	13.72	10.47
118.1	120.0	3820	2.744E-03	9.22	9.00	7.85	6.48	5.10	3.73
137.6	130.0	3400	1.818E-03	5.35	5.20	4.44	3.53	2.62	1.71
158.0	140.0	3130	1.236E-03	3.30	3.20	2.68	2.06	1.45	0.83
179.0	150.0	3000	1.016E-03	2.58	2.50	2.07	1.57	1.06	0.55
200.6	160.0	2950	8.714E-04	2.17	2.10	1.73	1.30	0.86	0.43
222.9	170.0	2950	7.469E-04	1.86	1.80	1.49	1.11	0.74	0.37
231.5	173.8	2950	7.261E-04	1.81	1.75	1.45	1.08	0.72	0.36
231.5	173.8	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
292.4	203.0	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
422.2	306.0	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
469.8	450.2	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00

Summary @ T<sub>wall</sub> = 540 R  
 Peak Heating Rate: 51.11 BTU/FT<sup>2</sup>-S  
 Total Heat Load: 3061.89 BTU/FT<sup>2</sup>

Table 25  
 1.5 Stage Cycle 2 Convective Base Heating  
 BP 213 - Sustainer Thrust Structure (External Conical Section)  
 NLS 2 Mission 1 Nominal - July 1992

Alt Kft	Time Sec	Tr deg R	Hc BTU/FT <sup>2</sup> -S-R	Convective Heating Rate (BTU/FT <sup>2</sup> -S) for Various Wall Temperatures					
				qc@460 R	qc@540 R	qc@960 R	qc@1460 R	qc@1960 R	qc@2460 R
0.0	0.0	921	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
1.0	10.0	878	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
2.4	15.0	917	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
4.4	20.0	1019	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
7.0	25.0	1158	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
10.2	30.0	1380	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
14.1	35.0	1552	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
16.8	38.0	1622	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
16.8	38.0	1622	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
18.6	40.0	1711	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
23.6	45.0	1874	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
28.9	50.0	2030	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
34.6	55.0	2157	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
40.7	60.0	2515	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
47.2	65.0	3813	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
54.1	70.0	4091	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
61.4	75.0	4088	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
69.0	80.0	4089	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
77.0	85.0	4090	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
85.3	90.0	4085	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
93.9	95.0	4078	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
102.8	100.0	4030	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
121.2	110.0	3750	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
140.5	120.0	3360	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
160.3	130.0	3120	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
180.7	140.0	3000	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
201.4	150.0	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
221.5	159.6	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
221.5	159.6	2950	4.357E-04	1.08	1.05	0.87	0.65	0.43	0.21
301.1	200.0	2950	4.357E-04	1.08	1.05	0.87	0.65	0.43	0.21
471.1	331.8	2950	4.357E-04	1.08	1.05	0.87	0.65	0.43	0.21

Summary @ T<sub>wall</sub> = 540 R

Peak Heating Rate: 1.05 BTU/FT<sup>2</sup>-S  
 Total Heat Load: 180.86 BTU/FT<sup>2</sup>

Table 26  
 1.5 Stage Cycle 2 Convective Base Heating  
 BP 213 - Sustainer Thrust Structure (External Conical Section)  
 NLS 2 Mission 1 Engine Out - July 1992

Alt Kft	Time Sec	Tr deg R	Hc BTU/FT <sup>2</sup> -S-R	Convective Heating Rate (BTU/Ft <sup>2</sup> -S) for Various Wall Temperatures					
				qc@460 R	qc@540 R	qc@960 R	qc@1460 R	qc@1960 R	qc@2460 R
0.0	0.0	921	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
0.6	10.0	866	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
1.4	15.0	888	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
2.5	20.0	920	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
4.1	25.0	1000	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
6.0	30.0	1097	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
8.4	35.0	1272	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
11.3	40.0	1434	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
14.6	45.0	1569	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
18.4	50.0	1700	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
22.7	55.0	1844	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
27.5	60.0	1998	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
32.7	65.0	2124	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
38.5	70.0	2286	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
44.7	75.0	3364	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
51.3	80.0	4085	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
58.4	85.0	4089	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
65.9	90.0	4089	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
73.8	95.0	4089	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
82.0	100.0	4088	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
90.6	105.0	4081	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
99.5	110.0	4074	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
118.1	120.0	3820	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
137.6	130.0	3400	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
158.0	140.0	3130	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
179.0	150.0	3000	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
200.6	160.0	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
222.9	170.0	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
231.5	173.8	2950	0.000E+00	0.00	0.00	0.00	0.00	0.00	0.00
231.5	173.8	2950	4.357E-04	1.08	1.05	0.87	0.65	0.43	0.21
292.4	203.0	2950	4.357E-04	1.08	1.05	0.87	0.65	0.43	0.21
422.2	306.0	2950	4.357E-04	1.08	1.05	0.87	0.65	0.43	0.21
469.8	450.2	2950	4.357E-04	1.08	1.05	0.87	0.65	0.43	0.21

Summary @ T<sub>wall</sub> = 540 R

Peak Heating Rate: 1.05 BTU/Ft<sup>2</sup>-S  
 Total Heat Load: 290.31 BTU/Ft<sup>2</sup>

Table 27

TOTAL PLUME RADIATION FOR:

- 1.5-Stage Booster Surfaces - 100% & 70% Booster Thrust - July 1992
- 1.5-Stage Main Engine STME 100% Altitude Adjustment Functions - July 1992
- 1.5-Stage Booster STME 100% & 70% Altitude Adjustment Functions - July 1992
- 1.5-Stage 650k STME Mission 1 Nominal - July 1992

Time* (sec)	Alt (kft)	Heating Rate (Btu/ft <sup>2</sup> -sec) for Points Listed						
		202	203	204	207	210	211	212
0.0	0.	6.98	9.84	4.14	10.23	11.38	15.79	9.54
10.0	1.	6.71	9.47	3.98	9.82	10.76	14.88	9.08
15.0	2.	6.30	8.90	3.75	9.20	9.90	13.64	8.41
20.0	4.	5.60	7.81	3.34	8.08	8.52	11.76	7.26
25.0	7.	4.67	6.38	2.82	6.61	6.72	9.29	5.74
30.0	10.	3.59	4.72	2.20	4.89	4.62	6.41	3.98
35.0	14.	3.34	4.40	2.07	4.52	4.26	5.91	3.67
38.0	17.	3.18	4.18	1.99	4.27	4.02	5.56	3.46
38.0	17.	4.11	5.21	2.45	5.14	5.20	6.95	4.63
40.0	19.	3.71	4.74	2.23	4.70	4.64	6.26	4.10
45.0	24.	2.90	3.76	1.78	3.74	3.50	4.80	3.02
50.0	29.	2.53	3.27	1.59	3.20	3.00	4.09	2.58
55.0	35.	2.14	2.75	1.38	2.62	2.47	3.35	2.11
60.0	41.	1.73	2.24	1.18	2.12	2.04	2.79	1.68
65.0	47.	1.45	1.84	1.01	1.73	1.76	2.40	1.40
70.0	54.	1.17	1.42	0.83	1.32	1.46	2.01	1.11
75.0	61.	1.00	1.15	0.68	1.03	1.27	1.77	0.90
80.0	69.	0.96	1.07	0.62	0.90	1.25	1.70	0.87
85.0	77.	0.93	1.02	0.57	0.79	1.25	1.65	0.84
90.0	85.	0.89	0.96	0.52	0.68	1.24	1.59	0.82
95.0	94.	0.86	0.89	0.47	0.56	1.24	1.53	0.80
100.0	103.	0.80	0.84	0.44	0.49	1.24	1.47	0.80
110.0	121.	0.80	0.84	0.44	0.49	1.24	1.47	0.80
120.0	140.	0.80	0.84	0.44	0.49	1.24	1.47	0.80
130.0	160.	0.80	0.84	0.44	0.49	1.24	1.47	0.80
140.0	181.	0.80	0.84	0.44	0.49	1.24	1.47	0.80
150.0	201.	0.80	0.84	0.44	0.49	1.24	1.47	0.80
159.6	221.	0.80	0.84	0.44	0.49	1.24	1.47	0.80
Heat Load **		353.74	458.80	212.74	438.65	509.95	686.66	411.73

\* Approximate time from launch

\*\* Heat load includes 0.00 to 159.56 seconds.  
BECO at 159.56 seconds.

Table 27 (Concluded)

TOTAL PLUME RADIATION FOR:

- 1.5-Stage Main-Stage Surfaces - 100% & 70% Booster Thrust - July 1992
- 1.5-Stage Main Engine STME 100% Power Altitude Adjustment Functions - July 1992
- 1.5-Stage Booster STME 100% & 70% Altitude Adjustment Functions - July 1992
- 1.5-Stage 650k STME Mission 1 Nominal - July 1992

Time* (sec)	Alt (kft)	Heating Rate (Btu/ft2-sec) for Points Listed					
		201	205	206	208	209	213
0.0	0.	3.81	7.94	4.85	12.26	6.05	0.00
10.0	1.	3.68	7.61	4.66	11.50	5.63	0.00
15.0	2.	3.49	7.12	4.36	10.49	5.10	0.00
20.0	4.	3.19	6.22	3.77	9.05	4.43	0.00
25.0	7.	2.79	5.03	2.99	7.15	3.54	0.00
30.0	10.	2.33	3.65	2.09	4.94	2.51	0.00
35.0	14.	2.19	3.39	1.96	4.58	2.34	0.00
38.0	17.	2.10	3.21	1.87	4.33	2.23	0.00
38.0	17.	2.50	3.95	2.92	5.61	3.28	0.00
40.0	19.	2.32	3.53	2.52	5.02	2.83	0.00
45.0	24.	1.95	2.67	1.74	3.81	1.96	0.00
50.0	29.	1.73	2.31	1.53	3.30	1.72	0.00
55.0	35.	1.50	1.92	1.31	2.76	1.46	0.00
60.0	41.	1.22	1.54	1.06	2.37	1.18	0.00
65.0	47.	1.03	1.28	0.90	2.15	1.08	0.00
70.0	54.	0.83	1.01	0.74	1.92	0.98	0.00
75.0	61.	0.67	0.81	0.56	1.74	0.88	0.00
80.0	69.	0.62	0.74	0.51	1.70	0.93	0.00
85.0	77.	0.58	0.68	0.47	1.66	1.01	0.00
90.0	85.	0.54	0.62	0.44	1.62	1.08	0.00
95.0	94.	0.50	0.56	0.40	1.58	1.16	0.00
100.0	103.	0.48	0.52	0.37	1.54	1.24	0.00
110.0	121.	0.48	0.52	0.37	1.54	1.24	0.00
120.0	140.	0.48	0.52	0.37	1.54	1.24	0.00
130.0	160.	0.48	0.52	0.37	1.54	1.24	0.00
140.0	181.	0.48	0.52	0.37	1.54	1.24	0.00
150.0	201.	0.48	0.52	0.37	1.54	1.24	0.00
159.6	221.	0.48	0.52	0.37	1.54	1.24	0.00
160.0	222.	0.17	0.21	0.10	1.20	0.10	0.10
200.0	301.	0.17	0.21	0.10	1.20	0.10	0.10
331.8	471.	0.17	0.21	0.10	1.20	0.10	0.10
Heat Load **		242.33	381.00	236.12	779.12	337.86	17.20

\* Approximate time from launch

\*\* Heat load includes 0.00 to 331.80 seconds.  
 BECO at 159.56 and MECO at 331.18 seconds.



Table 28

TOTAL PLUME RADIATION FOR:

- 1.5-Stage Booster Surfaces - 100% Booster & Main Engine Thrust -July 1992
- 1.5-Stage Main Engine STME 100% Power Altitude Adjustment Functions -July 1992
- 1.5-Stage Booster STME 100% Power Altitude Adjustment Functions - July1992
- 1.5 Stage 650k STME Mission 1 Engine Out - July 1992

Time* (sec)	Alt (kft)	Heating Rate (Btu/ft2-sec) for Points Listed							
		202	203	204	207	210	211	212	
0.0	0.	6.98	9.84	4.14	10.23	11.38	15.79	9.54	
10.0	1.	6.83	9.63	4.05	10.00	11.03	15.28	9.28	
15.0	1.	6.61	9.34	3.93	9.68	10.55	14.57	8.93	
20.0	3.	6.26	8.83	3.72	9.13	9.81	13.52	8.34	
25.0	4.	5.71	7.98	3.41	8.25	8.74	12.06	7.44	
30.0	6.	5.01	6.91	3.01	7.15	7.39	10.20	6.31	
35.0	8.	4.16	5.60	2.53	5.80	5.73	7.94	4.92	
40.0	11.	3.52	4.64	2.17	4.79	4.52	6.27	3.90	
45.0	15.	3.31	4.36	2.06	4.47	4.22	5.84	3.63	
50.0	18.	3.08	4.04	1.94	4.11	3.87	5.35	3.33	
55.0	23.	2.81	3.69	1.80	3.70	3.48	4.78	2.98	
60.0	27.	2.51	3.29	1.64	3.24	3.04	4.16	2.60	
65.0	33.	2.19	2.85	1.47	2.74	2.56	3.47	2.18	
70.0	38.	1.90	2.45	1.30	2.32	2.22	3.02	1.86	
75.0	45.	1.62	2.03	1.11	1.91	1.92	2.61	1.56	
80.0	51.	1.31	1.57	0.92	1.47	1.60	2.18	1.24	
85.0	58.	1.11	1.28	0.77	1.15	1.39	1.91	1.03	
90.0	66.	1.04	1.18	0.70	0.98	1.34	1.84	0.96	
95.0	74.	0.97	1.08	0.62	0.81	1.28	1.76	0.88	
100.0	82.	0.89	0.97	0.54	0.63	1.22	1.69	0.81	
105.0	91.	0.81	0.86	0.45	0.44	1.16	1.61	0.73	
110.0	99.	0.78	0.82	0.41	0.37	1.13	1.57	0.69	
120.0	118.	0.78	0.82	0.41	0.37	1.13	1.57	0.69	
130.0	138.	0.78	0.82	0.41	0.37	1.13	1.57	0.69	
140.0	158.	0.78	0.82	0.41	0.37	1.13	1.57	0.69	
150.0	179.	0.78	0.82	0.41	0.37	1.13	1.57	0.69	
160.0	201.	0.78	0.82	0.41	0.37	1.13	1.57	0.69	
170.0	223.	0.78	0.82	0.41	0.37	1.13	1.57	0.69	
173.8	232.	0.78	0.82	0.41	0.37	1.13	1.57	0.69	
Heat Load **		411.95	540.31	248.83	514.19	594.75	821.68	481.28	<-SEP

\* Approximate time from launch

\*\* Heat load includes 0.00 to 173.77 seconds.  
BECO at 173.77 seconds.

Table 28 (Concluded)

TOTAL PLUME RADIATION FOR:

- 1.5-Stage Main-Stg Surfaces - 100% Booster & Main Engine Thrust - July 1992
- 1.5-Stage Main Engine STME 100% Power Altitude Adjustment Functions - July 1992
- 1.5-Stage Booster STME 100% Power Altitude Adjustment Functions - July 1992
- 1.5 Stage 650k STME Mission 1 Engine Out - July 1992

Time* (sec)	Alt (kft)	Heating Rate (Btu/ft <sup>2</sup> -sec) for Points Listed					
		201	205	206	208	209	213
0.0	0.	3.81	7.94	4.85	12.26	6.05	0.00
10.0	1.	3.74	7.76	4.74	11.83	5.81	0.00
15.0	1.	3.63	7.50	4.60	11.25	5.49	0.00
20.0	3.	3.47	7.06	4.32	10.40	5.06	0.00
25.0	4.	3.24	6.36	3.86	9.27	4.53	0.00
30.0	6.	2.94	5.47	3.28	7.85	3.87	0.00
35.0	8.	2.58	4.38	2.57	6.11	3.06	0.00
40.0	11.	2.29	3.58	2.06	4.84	2.47	0.00
45.0	15.	2.18	3.36	1.94	4.53	2.32	0.00
50.0	18.	2.04	3.10	1.81	4.18	2.16	0.00
55.0	23.	1.89	2.81	1.66	3.78	1.98	0.00
60.0	27.	1.72	2.48	1.50	3.33	1.77	0.00
65.0	33.	1.54	2.13	1.31	2.84	1.54	0.00
70.0	38.	1.34	1.83	1.14	2.55	1.41	0.00
75.0	45.	1.14	1.54	0.97	2.30	1.29	0.00
80.0	51.	0.92	1.22	0.78	2.04	1.17	0.00
85.0	58.	0.76	1.00	0.64	1.87	1.10	0.00
90.0	66.	0.70	0.89	0.58	1.83	1.11	0.00
95.0	74.	0.63	0.78	0.51	1.78	1.11	0.00
100.0	82.	0.56	0.67	0.44	1.72	1.12	0.00
105.0	91.	0.49	0.55	0.36	1.67	1.13	0.00
110.0	99.	0.46	0.50	0.34	1.65	1.13	0.00
120.0	118.	0.46	0.50	0.34	1.65	1.13	0.00
130.0	138.	0.46	0.50	0.34	1.65	1.13	0.00
140.0	158.	0.46	0.50	0.34	1.65	1.13	0.00
150.0	179.	0.46	0.50	0.34	1.65	1.13	0.00
160.0	201.	0.46	0.50	0.34	1.65	1.13	0.00
170.0	223.	0.46	0.50	0.34	1.65	1.13	0.00
173.8	232.	0.46	0.50	0.34	1.65	1.13	0.00
203.0	292.	0.17	0.21	0.10	1.20	0.10	0.10
306.0	422.	0.17	0.21	0.10	1.20	0.10	0.10
450.2	470.	0.17	0.21	0.10	1.20	0.10	0.10
Heat Load **		298.47	477.67	284.84	1018.02	409.85	27.64

←--SEP

\* Approximate time from launch  
 \*\* Heat load includes 0.00 to 450.25 seconds.  
 BECO at 173.77 and MECO at 450.20 seconds.

Table 29

BASE GAS RADIATION FOR:

1.5-Stage Booster Surfaces - July 1992

1.5-Stage Base Gas Nominal Mission 1 Alt Adj Functions - July 1992

1.5-Stage 650k STME Mission 1 Nominal - July 1992

Time* (sec)	Alt (kft)	Heating Rate (Btu/ft <sup>2</sup> -sec) for Points Listed							
		202	203	204	207	210	211	212	
0.0	0.	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
10.0	1.	0.10	0.10	0.08	0.07	0.05	0.05	0.05	0.06
15.0	2.	0.22	0.22	0.17	0.16	0.10	0.10	0.10	0.12
20.0	4.	0.38	0.38	0.29	0.28	0.17	0.18	0.18	0.21
25.0	7.	0.60	0.60	0.46	0.44	0.27	0.28	0.28	0.33
30.0	10.	0.87	0.88	0.66	0.64	0.39	0.40	0.40	0.48
35.0	14.	1.20	1.20	0.91	0.88	0.54	0.55	0.55	0.66
38.0	17.	1.42	1.43	1.08	1.04	0.64	0.65	0.65	0.78
38.0	17.	1.42	1.43	1.08	1.04	0.64	0.65	0.65	0.78
40.0	19.	1.58	1.59	1.20	1.16	0.71	0.72	0.72	0.86
45.0	24.	2.83	2.84	2.12	2.00	1.26	1.29	1.29	1.57
50.0	29.	4.51	4.53	3.34	3.13	2.00	2.05	2.05	2.53
55.0	35.	6.30	6.34	4.64	4.34	2.78	2.86	2.86	3.55
60.0	41.	7.92	7.96	5.81	5.42	3.49	3.59	3.59	4.48
65.0	47.	7.08	7.12	5.17	4.80	3.11	3.21	3.21	4.02
70.0	54.	6.19	6.22	4.49	4.14	2.70	2.80	2.80	3.54
75.0	61.	5.22	5.24	3.76	3.43	2.26	2.35	2.35	3.01
80.0	69.	4.07	4.08	2.92	2.65	1.76	1.83	1.83	2.35
85.0	77.	2.86	2.86	2.04	1.83	1.23	1.28	1.28	1.67
90.0	85.	2.02	2.02	1.44	1.28	0.86	0.91	0.91	1.19
95.0	94.	1.41	1.41	1.00	0.88	0.60	0.63	0.63	0.83
100.0	103.	0.90	0.87	0.63	0.54	0.36	0.40	0.40	0.52
110.0	121.	0.40	0.24	0.23	0.11	0.06	0.14	0.14	0.12
120.0	140.	0.40	0.24	0.23	0.11	0.06	0.14	0.14	0.12
130.0	160.	0.40	0.24	0.23	0.11	0.06	0.14	0.14	0.12
140.0	181.	0.40	0.24	0.23	0.11	0.06	0.14	0.14	0.12
150.0	201.	0.40	0.24	0.23	0.11	0.06	0.14	0.14	0.12
159.6	221.	0.40	0.24	0.23	0.11	0.06	0.14	0.14	0.12
Heat Load **		305.76	297.74	220.05	197.84	127.51	136.39	167.99	

\* Approximate time from launch

\*\* Heat load includes 0.00 to 159.56 seconds.  
BECO at 159.56 seconds.

Table 29 (Concluded)

BASE GAS RADIATION FOR:

1.5-Stage Main-Stage Surfaces - July 1992

1.5-Stage Base Gas Nominal Mission 1 Alt Adj Functions - July 1992

1.5-Stage 650k STME Mission 1 Nominal - July 1992

Time* (sec)	Alt (kft)	Heating Rate (Btu/ft <sup>2</sup> -sec) for Points Listed					
		201	205	206	208	209	213
0.0	0.	0.01	0.01	0.01	0.01	0.01	0.00
10.0	1.	0.08	0.08	0.08	0.05	0.04	0.00
15.0	2.	0.17	0.17	0.16	0.10	0.09	0.00
20.0	4.	0.29	0.29	0.29	0.17	0.16	0.00
25.0	7.	0.46	0.46	0.45	0.27	0.25	0.00
30.0	10.	0.67	0.67	0.65	0.39	0.36	0.00
35.0	14.	0.92	0.92	0.89	0.53	0.49	0.00
38.0	17.	1.09	1.09	1.06	0.63	0.58	0.00
38.0	17.	1.09	1.09	1.06	0.63	0.58	0.00
40.0	19.	1.21	1.21	1.18	0.70	0.64	0.00
45.0	24.	2.15	2.12	2.04	1.25	1.12	0.00
50.0	29.	3.39	3.33	3.20	1.98	1.77	0.00
55.0	35.	4.73	4.63	4.44	2.76	2.45	0.00
60.0	41.	5.93	5.79	5.54	3.46	3.07	0.00
65.0	47.	5.29	5.14	4.91	3.09	2.72	0.00
70.0	54.	4.61	4.45	4.23	2.69	2.36	0.00
75.0	61.	3.88	3.70	3.51	2.27	1.96	0.00
80.0	69.	3.02	2.86	2.70	1.76	1.51	0.00
85.0	77.	2.12	1.98	1.87	1.23	1.05	0.00
90.0	85.	1.50	1.39	1.30	0.87	0.73	0.00
95.0	94.	1.05	0.96	0.90	0.61	0.51	0.00
100.0	103.	0.67	0.61	0.57	0.39	0.31	0.00
110.0	121.	0.31	0.31	0.24	0.18	0.10	0.00
120.0	140.	0.31	0.31	0.24	0.18	0.10	0.00
130.0	160.	0.31	0.31	0.24	0.18	0.10	0.00
140.0	181.	0.31	0.31	0.24	0.18	0.10	0.00
150.0	201.	0.31	0.31	0.24	0.18	0.10	0.00
159.6	221.	0.31	0.31	0.24	0.18	0.10	0.00
160.0	222.	0.00	0.00	0.00	0.00	0.00	0.00
200.0	301.	0.00	0.00	0.00	0.00	0.00	0.00
331.8	471.	0.00	0.00	0.00	0.00	0.00	0.00
Heat Load **		229.81	222.52	209.48	133.96	114.36	0.00

\* Approximate time from launch

\*\* Heat load includes 0.00 to 331.80 seconds.  
BECO at 159.56 and MECO at 331.18 seconds.

Table 30

BASE GAS RADIATION FOR:

1.5-Stage Booster Surfaces - July 1992

1.5-Stage Base-Gas Eng-Out Mission 1 Alt Adj Functions - July 1992

1.5 Stage 650k STME Mission 1 Engine Out - July 1992

Time* (sec)	Alt (kft)	Heating Rate (Btu/ft <sup>2</sup> -sec) for Points Listed						
		202	203	204	207	210	211	212
0.0	0.	0.01	0.01	0.01	0.01	0.01	0.01	0.01
10.0	1.	0.06	0.06	0.05	0.05	0.03	0.03	0.03
15.0	1.	0.13	0.13	0.10	0.10	0.06	0.06	0.07
20.0	3.	0.23	0.23	0.17	0.17	0.10	0.10	0.12
25.0	4.	0.36	0.36	0.27	0.26	0.16	0.16	0.20
30.0	6.	0.52	0.52	0.40	0.38	0.24	0.24	0.29
35.0	8.	0.72	0.72	0.55	0.53	0.33	0.33	0.39
40.0	11.	0.96	0.96	0.73	0.70	0.43	0.44	0.53
45.0	15.	1.24	1.24	0.94	0.91	0.56	0.57	0.68
50.0	18.	1.56	1.56	1.19	1.14	0.70	0.71	0.85
55.0	23.	2.54	2.56	1.91	1.81	1.14	1.16	1.41
60.0	27.	4.05	4.08	3.01	2.83	1.80	1.84	2.27
65.0	33.	5.71	5.74	4.21	3.95	2.53	2.60	3.22
70.0	38.	7.52	7.56	5.53	5.16	3.32	3.41	4.25
75.0	45.	7.41	7.44	5.42	5.04	3.26	3.36	4.20
80.0	51.	6.55	6.58	4.77	4.40	2.87	2.96	3.73
85.0	58.	5.64	5.66	4.07	3.72	2.45	2.54	3.24
90.0	66.	4.54	4.55	3.26	2.96	1.96	2.04	2.62
95.0	74.	3.34	3.35	2.39	2.16	1.44	1.50	1.94
100.0	82.	2.26	2.26	1.61	1.43	0.96	1.01	1.32
105.0	91.	1.65	1.65	1.17	1.04	0.70	0.74	0.97
110.0	99.	1.01	1.01	0.72	0.63	0.43	0.46	0.60
120.0	118.	0.46	0.31	0.27	0.16	0.09	0.17	0.17
130.0	138.	0.40	0.24	0.23	0.11	0.06	0.14	0.12
140.0	158.	0.40	0.24	0.23	0.11	0.06	0.14	0.12
150.0	179.	0.40	0.24	0.23	0.11	0.06	0.14	0.12
160.0	201.	0.40	0.24	0.23	0.11	0.06	0.14	0.12
170.0	223.	0.40	0.24	0.23	0.11	0.06	0.14	0.12
173.8	232.	0.40	0.24	0.23	0.11	0.06	0.14	0.12 <-SEP
Heat Load **		316.88	308.55	228.26	205.41	132.22	141.39	173.93

\* Approximate time from launch

\*\* Heat load includes 0.00 to 173.77 seconds.  
BECO at 173.77 seconds.

Table 30: (Concluded)

BASE GAS RADIATION FOR:

1.5-Stage Main Stage Surfaces - July 1992

1.5-Stage Base-Gas Eng-Out Mission 1 Alt Adj Functions - July 1992


1.5 Stage 650k STME Mission 1 Engine Out - July 1992

Time* (sec)	Alt (kft)	Heating Rate (Btu/ft <sup>2</sup> -sec) for Points Listed					
		201	205	206	208	209	213
0.0	0.	0.01	0.01	0.01	0.01	0.01	0.00
10.0	1.	0.05	0.05	0.05	0.03	0.03	0.00
15.0	1.	0.10	0.10	0.10	0.06	0.05	0.00
20.0	3.	0.17	0.17	0.17	0.10	0.09	0.00
25.0	4.	0.27	0.27	0.27	0.16	0.15	0.00
30.0	6.	0.40	0.40	0.39	0.23	0.21	0.00
35.0	8.	0.55	0.55	0.54	0.32	0.29	0.00
40.0	11.	0.74	0.74	0.71	0.43	0.39	0.00
45.0	15.	0.95	0.95	0.92	0.55	0.50	0.00
50.0	18.	1.20	1.20	1.16	0.69	0.63	0.00
55.0	23.	1.93	1.91	1.85	1.12	1.01	0.00
60.0	27.	3.06	3.01	2.89	1.78	1.59	0.00
65.0	33.	4.29	4.20	4.03	2.50	2.23	0.00
70.0	38.	5.64	5.51	5.28	3.29	2.92	0.00
75.0	45.	5.54	5.39	5.15	3.23	2.86	0.00
80.0	51.	4.89	4.72	4.50	2.85	2.50	0.00
85.0	58.	4.19	4.01	3.81	2.45	2.12	0.00
90.0	66.	3.37	3.20	3.03	1.97	1.69	0.00
95.0	74.	2.48	2.33	2.20	1.45	1.23	0.00
100.0	82.	1.67	1.55	1.46	0.97	0.82	0.00
105.0	91.	1.22	1.13	1.06	0.71	0.59	0.00
110.0	99.	0.76	0.69	0.64	0.44	0.36	0.00
120.0	118.	0.35	0.34	0.28	0.21	0.13	0.00
130.0	138.	0.31	0.31	0.24	0.18	0.10	0.00
140.0	158.	0.31	0.31	0.24	0.18	0.10	0.00
150.0	179.	0.31	0.31	0.24	0.18	0.10	0.00
160.0	201.	0.31	0.31	0.24	0.18	0.10	0.00
170.0	223.	0.31	0.31	0.24	0.18	0.10	0.00
173.8	232.	0.31	0.31	0.24	0.18	0.10	0.00
203.0	292.	0.00	0.00	0.00	0.00	0.00	0.00
306.0	422.	0.00	0.00	0.00	0.00	0.00	0.00
450.2	470.	0.00	0.00	0.00	0.00	0.00	0.00
Heat Load **		242.81	235.38	220.99	141.53	120.14	0.00

\* Approximate time from launch

\*\* Heat load includes 0.00 to 450.25 seconds.  
 BECO at 173.77 and MECO at 450.20 seconds.

"SME"  
 $h_c$  vs alt for ED & NOM



PEAK CONVECTIVE HEATING

STIME (Btu/AA<sup>2</sup>-sec) DHS (Btu/AA<sup>2</sup>-sec)

NOM 52.11 45.21  
h = 40.7 AA h = 47.2 AA

E.O. 51.11 45.80  
h = 44.7 AA h = 51.3 AA