


TWR-60699



(NASA-CR-192566) POSTFLIGHT
HARDWARE EVALUATION 360T025
(RSRM-25, STS-46). APPENDIX E:
INSULATION POSTFIRE DATA Final
Report (Thiokol Corp.) 33 p

N93-30621

Unclass

G3/16 0171966

Appendix E

Insulation Postfire Data

Final Postflight Hardware Evaluation Report 360T025 (RSRM-25, STS-46)

March 1993


Prepared for
National Aeronautics and Space Administration
George C. Marshall Space Flight Center
Marshall Space Flight Center, Alabama 35812

Contract No. NAS8-38100
DR No. 4-23
WBS No. 4C601-04-01
ECS No. SS4767

Thiokol CORPORATION
SPACE OPERATIONS

P.O. Box 707, Brigham City, UT 84302-0707 (801) 863-3511.

Prepared by Space Publications
Publications No. 931267



APPENDIX E INSULATION POSTFIRE DATA

Contents

<i>Tables</i>		<i>Page</i>
E-I	360T025B Nozzle-to-Case Joint Performance	E-1
E-II	360T025B Aft Field Joint Performance	E-2
E-III	360T025B Center Field Joint Performance	E-3
E-IV	360T025B Forward Field Joint Performance	E-4
E-V	360T025B Aft Dome Insulation Performance	E-5
E-VI	360T025B Aft Cylinder Insulation Performance	E-8
E-VII	360T025B Aft Center Segment Insulation Performance	E-14
E-VIII	360T025B Forward Center Segment Insulation Performance	E-17
E-IX	360T025B Forward Segment Star Tip Insulation Performance	E-20
E-X	360T025B Forward Segment Non-Star Tip Insulation Performance	E-23
E-XI	360T025A Igniter Chamber and Adapter Insulation Performance	E-26
E-XII	360T025B Igniter Chamber and Adapter Insulation Performance	E-29




Table E-I. 360T025B Nozzle-to-Case Joint Performance

DEGREE . LOCATION	PREFIRE (INCHES)	POSTFIRE (INCHES)	MDD	CSF	ASF
0.0	5.603	4.367	1.236	4.0	4.5
21.6	5.609				
46.8	5.598	4.699	0.899	5.5	6.2
68.4	5.592				
90.0	5.615	4.982	0.633	7.7	8.9
111.6	5.622				
136.8	5.593	4.817	0.776	6.3	7.2
158.4	5.615				
180.0	5.594	4.674	0.920	5.3	6.1
201.6	5.617				
226.8	5.600	4.628	0.972	5.0	5.8
248.4	5.623				
270.0	5.625	4.956	0.669	7.3	8.4
291.6	5.620				
316.8	5.636	5.043	0.593	8.3	9.5
338.4	5.610				
	MEDIAN 5.613	MEDIAN 4.758	MEDIAN 0.838	MINIMUM 4.0	MINIMUM 4.5

A SAFETY FACTOR OF 2.0 IS REQUIRED

A BLANK INDICATES THAT POSTFIRE DATA COLLECTION IS NOT REQUIRED AT THAT LOCATION

Table E-II. 360T025B Aft Field Joint Performance

DEGREE LOCATION	PREFIRE (INCHES)	POSTFIRE (INCHES)	MDD	CSF	ASF
2.0	2.762	2.272	0.490	5.3	5.6
16.0	2.757				
30.0	2.760				
46.0	2.761	2.298	0.463	5.6	6.0
60.0	2.755				
76.0	2.757				
90.0	2.761	2.248	0.513	5.1	5.4
106.0	2.765				
120.0	2.770				
136.0	2.768	2.316	0.452	5.7	6.1
150.0	2.769				
166.0	2.773				
180.0	2.772	2.390	0.382	6.8	7.3
196.0	2.757				
210.0	2.743				
226.0	2.745	2.313	0.432	6.0	6.4
242.0	2.748				
256.0	2.750				
270.0	2.753	2.280	0.473	5.5	5.8
286.0	2.747				
300.0	2.749				
316.0	2.753	2.213	0.540	4.8	5.1
330.0	2.755				
346.0	2.759				
	MEDIAN	MEDIAN	MEDIAN	MINIMUM	MINIMUM
	2.757	2.289	0.468	4.8	5.1

A SAFETY FACTOR OF 2.0 IS REQUIRED

A BLANK INDICATES THAT POSTFIRE DATA COLLECTION IS NOT REQUIRED AT THAT LOCATION

Table E-III. 360T025B Center Field Joint Performance

DEGREE LOCATION	PREFIRE (INCHES)	POSTFIRE (INCHES)	MDD	CSF	ASF
2.0	2.739	2.528	0.211	12.3	13.0
16.0	2.743				
30.0	2.784				
46.0	2.784	2.522	0.262	9.9	10.6
60.0	2.767				
76.0	2.746				
90.0	2.745	2.528	0.217	12.0	12.6
106.0	2.685				
120.0	2.704				
136.0	2.730	2.573	0.157	16.5	17.4
150.0	2.757				
166.0	2.713				
180.0	2.747	2.527	0.220	11.8	12.5
196.0	2.726				
210.0	2.733				
226.0	2.730	2.532	0.198	13.1	13.8
242.0	2.743				
256.0	2.729				
270.0	2.732	2.557	0.175	14.8	15.6
286.0	2.731				
300.0	2.731				
316.0	2.732	2.564	0.168	15.4	16.3
330.0	2.732				
346.0	2.733				
	MEDIAN 2.733	MEDIAN 2.530	MEDIAN 0.205	MINIMUM 9.9	MINIMUM 10.6

A SAFETY FACTOR OF 2.0 IS REQUIRED

A BLANK INDICATES THAT POSTFIRE DATA COLLECTION IS NOT REQUIRED AT THAT LOCATION

Table E-IV. 360T025B Forward Field Joint Performance

DEGREE LOCATION	PREFIRE (INCHES)	POSTFIRE (INCHES)	MDD	CSF	ASF
2.0	2.754	2.632	0.122	21.3	22.6
16.0	2.757				
30.0	2.770				
46.0	2.774	2.625	0.149	17.4	18.6
60.0	2.774				
76.0	2.782				
90.0	2.773	2.619	0.154	16.9	18.0
106.0	2.790				
120.0	2.768				
136.0	2.772	2.585	0.187	13.9	14.8
150.0	2.772				
166.0	2.765				
180.0	2.735	2.642	0.093	27.9	29.4
196.0	2.759				
210.0	2.754				
226.0	2.750	2.623	0.127	20.4	21.7
242.0	2.743				
256.0	2.745				
270.0	2.743	2.614	0.129	20.1	21.3
286.0	2.752				
300.0	2.751				
316.0	2.762	2.591	0.171	15.2	16.2
330.0	2.748				
346.0	2.742				
	MEDIAN 2.758	MEDIAN 2.621	MEDIAN 0.139	MINIMUM 13.9	MINIMUM 14.8

A SAFETY FACTOR OF 2.0 IS REQUIRED

A BLANK INDICATES THAT POSTFIRE DATA COLLECTION IS NOT REQUIRED AT THAT LOCATION

Table E-V. 360T025B Aft Dome Insulation Performance

COMPLIANCE SAFETY FACTOR (CSF)

STATION (IN)	DEGREE LOCATIONS									PLANE	REQUIRED S.F.
	0.0	46.8	90.0	136.8	180.0	226.8	270.0	316.8	MIN.		
9.3	5.78	5.57	4.50	5.27	4.99	6.38	5.10	5.76	4.50	90.0	1.5
10.7	4.58	4.23	3.38	4.50	6.80	5.01	3.75	4.46	3.38	90.0	1.5
12.0	4.31	4.04	3.21	4.17	5.31	4.46	3.58	4.41	3.21	90.0	1.5
13.1	4.04	4.00	3.21	3.81	4.79	4.28	3.39	4.09	3.21	90.0	1.5
14.4	3.89	4.06	3.11	3.75	5.07	4.18	3.44	4.18	3.11	90.0	1.5
16.0	3.90	4.10	2.98	3.77	5.40	4.52	3.57	3.91	2.98	90.0	1.5
17.3	4.28	4.55	3.20	3.76	5.53	4.58	3.69	4.20	3.20	90.0	1.5
18.5	4.84	4.84	3.51	4.25	5.99	5.69	4.22	4.67	3.51	90.0	1.5
19.5	6.29	4.93	4.47	4.49	5.63	6.85	4.56	4.88	4.47	90.0	1.5
21.3	5.69	5.24	4.10	4.95	5.60	6.24	4.58	4.26	4.10	90.0	1.5
24.3	4.55	3.43	3.24	3.55	3.79	4.49	3.97	3.11	3.11	316.8	1.5
33.0	2.72	2.83	2.41	2.75	2.71	2.67	2.57	2.85	2.41	90.0	1.5
45.0	2.37	2.47	2.41	2.46	2.45	2.16	2.51	2.80	2.16	226.8	1.5
53.0	3.32	3.91	3.79	4.28	3.71	3.49	4.66	3.81	3.32	0.0	1.5
56.0	3.87	4.31	4.04	4.06	3.55	3.76	4.94	4.20	3.55	180.0	2.0
72.0	3.88	4.02	4.23	3.58	3.27	4.50	3.55	4.48	3.27	180.0	1.5
75.0	3.70	3.81	4.12	4.74	3.42	4.15	3.81	4.14	3.42	180.0	1.5
78.0	3.41	3.61	3.61	4.88	3.38	3.57	3.56	4.46	3.38	180.0	1.5

SEGMENT MINIMUM = 2.16 AT THE 45.0 INCH STATION

ACTUAL SAFETY FACTOR (ASF)

STATION (IN)	DEGREE LOCATIONS									PLANE	REQUIRED S.F.
	0.0	46.8	90.0	136.8	180.0	226.8	270.0	316.8	MIN.		
9.3	6.01	5.69	4.59	5.56	5.09	6.49	5.21	6.00	4.59	90.0	1.5
10.7	4.85	4.47	3.58	4.78	7.28	5.30	4.01	4.72	3.58	90.0	1.5
12.0	4.61	4.28	3.44	4.47	5.74	4.77	3.87	4.70	3.44	90.0	1.5
13.1	4.34	4.30	3.47	4.13	5.20	4.63	3.71	4.39	3.47	90.0	1.5
14.4	4.12	4.29	3.30	3.98	5.47	4.42	3.69	4.42	3.30	90.0	1.5
16.0	4.24	4.43	3.23	4.11	5.93	4.92	3.90	4.24	3.23	90.0	1.5
17.3	4.79	5.08	3.60	4.21	6.25	5.14	4.14	4.68	3.60	90.0	1.5
18.5	5.56	5.57	4.02	4.85	6.92	6.54	4.84	5.33	4.02	90.0	1.5
19.5	7.29	5.67	5.12	5.16	6.59	7.93	5.31	5.58	5.12	90.0	1.5
21.3	6.64	6.00	4.74	5.74	6.59	7.30	5.29	4.89	4.74	90.0	1.5
24.3	5.13	3.92	3.69	4.05	4.31	5.14	4.52	3.50	3.50	316.8	1.5
33.0	2.97	3.09	2.63	2.97	2.93	2.88	2.77	3.12	2.63	90.0	1.5
45.0	2.57	2.65	2.64	2.64	2.68	2.30	2.78	3.02	2.30	226.8	1.5
53.0	3.61	4.17	4.18	4.80	4.11	3.78	5.12	4.23	3.61	0.0	1.5
56.0	4.55	5.04	4.79	4.95	4.37	4.42	5.94	4.99	4.37	180.0	2.0
72.0	4.20	4.30	4.49	4.07	3.72	4.76	3.78	4.77	3.72	180.0	1.5
75.0	3.99	4.07	4.41	5.26	3.72	4.43	4.13	4.54	3.72	180.0	1.5
78.0	3.65	3.89	3.87	5.26	3.68	3.86	3.98	4.73	3.65	0.0	1.5

SEGMENT MINIMUM = 2.30 AT THE 45.0 INCH STATION

Table E-V. 360T025B Aft Dome Insulation Performance (cont)

STATION (IN)	MATERIAL DECOMPOSITION DEPTH (MDD) INCHES										DESIGN M+3S
	0.0	46.8	90.0	136.8	180.0	226.8	270.0	316.8	DEGREE LOCATIONS MEDIAN	MAX.	
9.3	0.848	0.880	1.088	0.929	0.981	0.768	0.960	0.851	0.905	1.088	2.560
10.7	1.026	1.112	1.391	1.044	0.691	0.939	1.254	1.054	1.049	1.391	2.261
12.0	1.043	1.113	1.404	1.078	0.848	1.008	1.257	1.021	1.061	1.404	2.208
13.1	1.065	1.075	1.339	1.128	0.898	1.005	1.270	1.051	1.070	1.339	2.218
14.4	1.054	1.010	1.320	1.094	0.809	0.982	1.193	0.982	1.032	1.320	2.225
16.0	0.968	0.922	1.270	1.003	0.700	0.837	1.059	0.966	0.967	1.270	1.980
17.3	0.831	0.782	1.111	0.948	0.644	0.777	0.966	0.848	0.839	1.111	1.675
18.5	0.694	0.694	0.957	0.790	0.561	0.591	0.797	0.720	0.707	0.957	1.496
19.5	0.501	0.639	0.705	0.702	0.560	0.460	0.691	0.646	0.643	0.705	1.617
21.3	0.517	0.561	0.717	0.594	0.525	0.471	0.642	0.690	0.578	0.717	1.654
24.3	0.646	0.856	0.908	0.829	0.776	0.655	0.740	0.946	0.803	0.946	1.832
33.0	1.178	1.129	1.326	1.162	1.181	1.199	1.246	1.124	1.179	1.326	1.399
45.0	1.095	1.053	1.077	1.055	1.061	1.203	1.036	0.927	1.058	1.203	1.222
53.0	1.019	0.865	0.891	0.790	0.912	0.969	0.725	0.886	0.888	1.019	1.305
56.0	0.720	0.647	0.691	0.688	0.785	0.743	0.565	0.665	0.690	0.785	1.369
72.0	0.515	0.498	0.473	0.558	0.611	0.444	0.564	0.446	0.507	0.611	0.817
75.0	0.487	0.472	0.437	0.380	0.527	0.434	0.472	0.435	0.455	0.527	0.773
78.0	0.469	0.443	0.443	0.328	0.474	0.448	0.450	0.359	0.446	0.474	0.718

STATION (IN)	MATERIAL DECOMPOSITION RATE (MDR) MILS / SECOND									
	0.0	46.8	90.0	136.8	180.0	226.8	270.0	316.8	DEGREE LOCATIONS AVE.	EXPOSURE TIME
9.3	7.0	7.2	9.0	7.6	8.1	6.3	7.9	7.0	7.5	121.5
10.7	8.6	9.3	11.7	8.8	5.8	7.9	10.5	8.8	8.9	119.3
12.0	9.0	9.6	12.1	9.3	7.3	8.7	10.8	8.8	9.4	116.3
13.1	9.4	9.5	11.8	9.9	7.9	8.8	11.2	9.3	9.7	113.6
14.4	9.5	9.1	11.9	9.9	7.3	8.9	10.8	8.9	9.5	110.8
16.0	9.0	8.6	11.8	9.3	6.5	7.8	9.8	9.0	9.0	107.8
17.3	7.9	7.5	10.6	9.0	6.1	7.4	9.2	8.1	8.2	104.8
18.5	6.8	6.8	9.3	7.7	5.5	5.8	7.8	7.0	7.1	102.6
19.5	5.0	6.3	7.0	7.0	5.6	4.6	6.9	6.4	6.1	100.7
21.3	5.3	5.8	7.4	6.1	5.4	4.8	6.6	7.1	6.1	97.3
24.3	6.9	9.2	9.7	8.9	8.3	7.0	7.9	10.1	8.5	93.3
33.0	14.2	13.6	15.9	14.0	14.2	14.4	15.0	13.5	14.3	83.2
45.0	14.7	14.1	14.4	14.1	14.2	16.1	13.9	12.4	14.2	74.7
53.0	13.7	11.6	12.0	10.6	12.3	13.0	9.8	11.9	11.9	74.3
56.0	9.7	8.7	9.3	9.3	10.6	10.0	7.6	9.0	9.3	74.1
72.0	9.2	8.9	8.4	9.9	10.9	7.9	10.0	7.9	9.1	56.2
75.0	9.7	9.4	8.7	7.5	10.5	8.6	9.4	8.6	9.0	50.4
78.0	10.1	9.6	9.6	7.1	10.2	9.7	9.7	7.8	9.2	46.3

MOTOR ACTION TIME = 122.3 SECONDS

Table E-V. 360T025B Aft Dome Insulation Performance (cont)

PART NO. 1U76668-02 SERIAL NO. 0000019		PREFIRE MEASUREMENTS INCHES										
STATION (IN)	DEGREE									LOCATIONS		
	0.0	46.8	90.0	136.8	180.0	226.8	270.0	316.8	MIN.	MEDIAN	MDT	
9.3	5.099	5.010	4.992	5.161	4.997	4.981	5.006	5.107	4.981	5.008	4.900	
10.7	4.973	4.970	4.983	4.993	5.028	4.979	5.034	4.976	4.970	4.981	4.700	
12.0	4.809	4.765	4.830	4.823	4.869	4.812	4.864	4.795	4.765	4.818	4.500	
13.1	4.625	4.620	4.644	4.655	4.671	4.658	4.712	4.619	4.619	4.650	4.300	
14.4	4.344	4.335	4.361	4.356	4.424	4.343	4.401	4.338	4.335	4.350	4.100	
16.0	4.109	4.082	4.097	4.120	4.149	4.122	4.126	4.097	4.082	4.115	3.780	
17.3	3.984	3.969	3.997	3.989	4.026	3.994	3.998	3.967	3.967	3.992	3.560	
18.5	3.857	3.867	3.851	3.834	3.884	3.868	3.860	3.840	3.834	3.859	3.360	
19.5	3.654	3.624	3.613	3.620	3.689	3.647	3.670	3.606	3.606	3.636	3.150	
21.3	3.432	3.364	3.396	3.407	3.462	3.440	3.396	3.376	3.364	3.401	2.940	
24.3	3.317	3.357	3.349	3.354	3.344	3.365	3.346	3.310	3.310	3.348	2.940	
33.0	3.503	3.487	3.492	3.452	3.461	3.448	3.455	3.509	3.448	3.474	3.200	
45.0	2.809	2.790	2.843	2.787	2.842	2.770	2.883	2.797	2.770	2.803	2.600	
53.0	3.675	3.603	3.722	3.790	3.744	3.659	3.714	3.744	3.603	3.718	3.380	
56.0	3.273	3.258	3.311	3.409	3.432	3.283	3.355	3.319	3.258	3.315	2.790	
72.0	2.163	2.143	2.124	2.269	2.273	2.113	2.134	2.129	2.113	2.138	2.000	
75.0	1.943	1.922	1.927	1.998	1.958	1.921	1.950	1.976	1.921	1.947	1.800	
78.0	1.710	1.722	1.715	1.724	1.744	1.729	1.792	1.699	1.699	1.723	1.600	

PART NO. 1U76957-03 SERIAL NO. 0000010		POSTFIRE MEASUREMENTS INCHES										
STATION (IN)	DEGREE									LOCATIONS		
	0.0	46.8	90.0	136.8	180.0	226.8	270.0	316.8	MIN.	MEDIAN		
9.3	4.251	4.130	3.904	4.232	4.016	4.213	4.046	4.256	3.904	4.172		
10.7	3.947	3.858	3.592	3.949	4.337	4.040	3.780	3.922	3.592	3.934		
12.0	3.766	3.652	3.426	3.745	4.021	3.804	3.607	3.774	3.426	3.756		
13.1	3.560	3.545	3.305	3.527	3.773	3.653	3.442	3.568	3.305	3.553		
14.4	3.290	3.325	3.041	3.262	3.615	3.361	3.208	3.356	3.041	3.308		
16.0	3.141	3.160	2.827	3.117	3.449	3.285	3.067	3.131	2.827	3.136		
17.3	3.153	3.187	2.886	3.041	3.382	3.217	3.032	3.119	2.886	3.136		
18.5	3.163	3.173	2.894	3.044	3.323	3.277	3.063	3.120	2.894	3.141		
19.5	3.153	2.985	2.908	2.918	3.129	3.187	2.979	2.960	2.908	2.982		
21.3	2.915	2.803	2.679	2.813	2.937	2.969	2.754	2.686	2.679	2.808		
24.3	2.671	2.501	2.441	2.525	2.568	2.710	2.606	2.364	2.364	2.547		
33.0	2.325	2.358	2.166	2.290	2.280	2.249	2.209	2.385	2.166	2.285		
45.0	1.714	1.737	1.766	1.732	1.781	1.567	1.847	1.870	1.567	1.752		
53.0	2.656	2.738	2.831	3.000	2.832	2.690	2.989	2.858	2.656	2.832		
56.0	2.553	2.611	2.620	2.721	2.647	2.540	2.790	2.654	2.540	2.634		
72.0	1.648	1.645	1.651	1.711	1.662	1.669	1.570	1.683	1.570	1.656		
75.0	1.456	1.450	1.490	1.618	1.431	1.487	1.478	1.541	1.431	1.483		
78.0	1.241	1.279	1.272	1.396	1.270	1.281	1.342	1.340	1.241	1.280		

Table E-VI. 360T025B Aft Cylinder Insulation Performance

STATION (IN)	COMPLIANCE SAFETY FACTOR (CSF)								LOCATIONS		REQUIRED S.F.
	0.0	46.8	90.0	136.8	180.0	226.8	270.0	316.8	MIN.	PLANE	
85.0	3.21	3.37	3.30	4.10	2.94	2.92	4.64	3.03	2.92	226.8	1.5
90.0	3.11	3.45	3.10	2.86	4.19	3.03	4.81	3.19	2.86	136.8	1.5
98.0	2.25	2.53	2.66	2.56	3.04	2.32	3.75	2.62	2.25	0.0	1.5
105.8	2.35	2.62	2.54	2.69	2.31	2.30	3.05	2.28	2.28	316.8	1.5
116.0	2.43	2.62	2.73	2.65	2.41	2.36	2.54	2.60	2.36	226.8	1.5
124.5	2.15	2.42	2.74	2.37	2.36	2.42	4.20	2.41	2.15	0.0	1.5
133.0	2.33	2.30	2.52	2.51	2.26	2.21	4.07	2.25	2.21	226.8	1.5
145.5	2.36	2.61	2.53	2.44	2.38	2.26	2.63	2.30	2.26	226.8	1.5
158.5	2.52	2.63	2.72	2.38	2.23	2.15	2.57	2.73	2.15	226.8	1.5
166.0	2.29	2.78	2.65	2.41	2.25	2.38	2.29	2.31	2.25	180.0	1.5
177.7	3.02	2.86	2.82	2.44	2.62	2.49	2.50	2.68	2.44	136.8	2.0
192.5	2.54	2.94	2.89	2.62	2.45	2.30	3.80	2.76	2.30	226.8	1.5
202.5	2.91	3.20	3.12	3.15	2.53	3.23	4.37	2.73	2.53	180.0	1.5
214.0	2.59	2.63	2.66	2.71	2.29	2.65	3.95	2.72	2.29	180.0	1.5
227.3	2.54	2.37	2.30	3.22	2.23	2.32	2.56	2.43	2.23	180.0	1.5
238.3	2.81	2.84	2.80	2.78	2.73	2.70	2.90	2.93	2.70	226.8	1.5
250.0	2.46	2.63	2.59	2.47	2.25	2.24	2.76	2.55	2.24	226.8	1.5
269.0	2.79	2.60	2.27	2.63	2.39	4.90	2.30	2.62	2.27	90.0	1.5
283.9	2.94	2.63	2.32	2.50	3.63	3.19	3.15	3.38	2.32	90.0	1.5
299.1	3.69	3.14	3.48	2.83	3.02	2.86	3.56	4.36	2.83	136.8	2.0
322.0	4.13	4.58	5.43	3.42	3.92	3.96	3.17	2.92	2.92	316.8	1.5
339.0	4.52	4.52	3.88	4.87	5.67	4.09	4.63	6.33	3.88	90.0	1.5
358.0	7.17	8.64	8.09	+	6.44	7.17	6.67	54.29	6.44	180.0	1.5
367.0	7.60	4.75	6.91	3.19	95.00	6.03	7.45	4.47	3.19	136.8	1.5
377.5	5.96	11.04	12.05	5.52	+	6.31	5.96	11.28	5.52	136.8	1.5

SEGMENT MINIMUM = 2.15 AT THE 158.5 INCH STATION
A " + " MEANS NEGLIGIBLE MDD HAS OCCURRED

Table E-VI. 360T025B Aft Cylinder Insulation Performance (cont)

STATION (IN)	ACTUAL SAFETY FACTOR (ASF)										REQUIRED S.F.
	0.0	46.8	90.0	136.8	180.0	226.8	270.0	316.8	DEGREE	LOCATIONS	
85.0	3.85	4.05	3.96	4.91	3.56	3.62	5.68	3.70	3.56	180.0	1.5
90.0	3.57	3.91	3.60	3.27	4.70	3.45	5.62	3.56	3.27	136.8	1.5
98.0	2.91	3.25	3.42	3.19	3.85	2.94	4.85	3.33	2.91	0.0	1.5
105.8	2.45	2.75	2.69	2.80	2.47	2.39	3.23	2.40	2.39	226.8	1.5
116.0	2.53	2.72	2.86	2.78	2.55	2.45	2.64	2.77	2.45	226.8	1.5
124.5	2.30	2.55	2.91	2.52	2.51	2.54	4.41	2.56	2.30	0.0	1.5
133.0	2.83	2.81	3.10	2.99	2.71	2.64	4.95	2.77	2.64	226.8	1.5
145.5	2.37	2.60	2.52	2.44	2.37	2.26	2.59	2.28	2.26	226.8	1.5
158.5	2.59	2.69	2.79	2.47	2.29	2.19	2.57	2.77	2.19	226.8	1.5
166.0	2.81	3.37	3.14	2.95	2.73	2.86	2.77	2.80	2.73	180.0	1.5
177.7	4.66	4.36	4.29	3.76	4.03	3.83	3.85	4.05	3.76	136.8	2.0
192.5	2.98	3.48	3.37	2.96	2.79	2.63	4.53	3.18	2.63	226.8	1.5
202.5	2.96	3.24	3.16	3.21	2.55	3.27	4.52	2.75	2.55	180.0	1.5
214.0	2.67	2.67	2.72	2.75	2.33	2.70	4.12	2.76	2.33	180.0	1.5
227.3	3.00	2.88	2.73	3.80	2.59	2.72	3.02	2.76	2.59	180.0	1.5
238.3	2.84	2.86	2.83	2.81	2.76	2.74	2.92	2.95	2.74	226.8	1.5
250.0	2.50	2.69	2.66	2.52	2.31	2.29	2.79	2.57	2.29	226.8	1.5
269.0	3.27	3.03	2.62	3.04	2.78	5.71	2.64	2.99	2.62	90.0	1.5
283.9	3.20	2.96	2.53	2.75	3.99	3.55	3.46	3.92	2.53	90.0	1.5
299.1	5.97	5.10	5.59	4.56	4.90	4.63	5.68	7.06	4.56	136.8	2.0
322.0	4.46	4.98	5.74	3.71	4.21	4.27	3.30	3.15	3.15	316.8	1.5
339.0	4.79	4.85	4.18	5.10	6.03	4.34	4.90	6.80	4.18	90.0	1.5
358.0	7.89	9.34	9.00	+	6.83	7.77	7.49	60.00	6.83	180.0	1.5
367.0	9.34	5.87	8.43	4.04	+	7.65	8.59	5.25	4.04	136.8	1.5
377.5	7.38	13.69	14.32	7.75	+	7.33	7.24	13.15	7.24	270.0	1.5

SEGMENT MINIMUM = 2.19 AT THE 158.5 INCH STATION
A " + " MEANS NEGLIGIBLE MDD HAS OCCURRED

Table E-VI. 360T025B Aft Cylinder Insulation Performance (cont)

STATION (IN)	MATERIAL DECOMPOSITION DEPTH (MDD) INCHES								DEGREE LOCATIONS		DESIGN M+3S
	0.0	46.8	90.0	136.8	180.0	226.8	270.0	316.8	MEDIAN	MAX.	
85.0	0.405	0.386	0.394	0.317	0.442	0.445	0.280	0.429	0.399	0.445	0.618
90.0	0.407	0.367	0.408	0.443	0.302	0.417	0.263	0.396	0.402	0.443	0.576
98.0	0.505	0.449	0.427	0.443	0.373	0.489	0.303	0.433	0.438	0.505	0.582
105.8	0.460	0.413	0.426	0.401	0.468	0.469	0.354	0.474	0.443	0.474	0.559
116.0	0.432	0.401	0.384	0.396	0.435	0.444	0.413	0.404	0.409	0.444	0.527
124.5	0.479	0.426	0.376	0.435	0.437	0.426	0.245	0.428	0.427	0.479	0.522
133.0	0.421	0.426	0.389	0.391	0.434	0.444	0.241	0.436	0.424	0.444	0.516
145.5	0.394	0.356	0.368	0.381	0.390	0.412	0.353	0.405	0.386	0.412	0.493
158.5	0.349	0.334	0.323	0.369	0.394	0.410	0.343	0.322	0.346	0.410	0.491
166.0	0.371	0.306	0.321	0.352	0.378	0.357	0.371	0.368	0.362	0.378	0.466
177.7	0.331	0.350	0.354	0.409	0.381	0.401	0.400	0.373	0.377	0.409	0.452
192.5	0.307	0.265	0.270	0.298	0.318	0.339	0.205	0.283	0.291	0.339	0.400
202.5	0.251	0.228	0.234	0.232	0.289	0.226	0.167	0.267	0.233	0.289	0.376
214.0	0.270	0.266	0.263	0.258	0.306	0.264	0.177	0.257	0.264	0.306	0.351
227.3	0.256	0.274	0.283	0.202	0.291	0.280	0.254	0.267	0.271	0.291	0.317
238.3	0.224	0.222	0.225	0.227	0.231	0.233	0.217	0.215	0.225	0.233	0.331
250.0	0.224	0.209	0.212	0.223	0.244	0.246	0.199	0.216	0.219	0.246	0.285
269.0	0.179	0.192	0.220	0.190	0.209	0.102	0.217	0.191	0.192	0.220	0.297
283.9	0.153	0.171	0.194	0.180	0.124	0.141	0.143	0.133	0.148	0.194	0.251
299.1	0.183	0.215	0.194	0.239	0.224	0.236	0.190	0.155	0.204	0.239	0.253
322.0	0.092	0.083	0.070	0.111	0.097	0.096	0.120	0.130	0.096	0.130	0.197
339.0	0.084	0.084	0.098	0.078	0.067	0.093	0.082	0.060	0.083	0.098	0.190
358.0	0.053	0.044	0.047	0	0.059	0.053	0.057	0.007	0.050	0.059	0.181
367.0	0.050	0.080	0.055	0.119	0.004	0.063	0.051	0.085	0.059	0.119	0.175
377.5	0.089	0.048	0.044	0.096	0	0.084	0.089	0.047	0.066	0.096	0.237

Table E-VI. 360T025B Aft Cylinder Insulation Performance (cont)

STATION (IN)	MATERIAL DECOMPOSITION RATE (MDR) MILS / SECOND								LOCATION AVE.	EXPOSURE TIME
	0.0	46.8	90.0	136.8	180.0	226.8	270.0	316.8		
	DEGREE									
85.0	9.0	8.6	8.8	7.1	9.8	9.9	6.2	9.6	8.6	44.9
90.0	9.2	8.3	9.2	10.0	6.8	9.4	5.9	8.9	8.5	44.3
98.0	11.7	10.4	9.9	10.2	8.6	11.3	7.0	10.0	9.9	43.3
105.8	10.8	9.7	10.0	9.4	11.0	11.0	8.3	11.2	10.2	42.5
116.0	10.4	9.6	9.2	9.5	10.4	10.6	9.9	9.7	9.9	41.7
124.5	11.8	10.5	9.2	10.7	10.7	10.5	6.0	10.5	10.0	40.7
133.0	10.7	10.8	9.8	9.9	11.0	11.2	6.1	11.0	10.1	39.5
145.5	10.5	9.5	9.8	10.2	10.4	11.0	9.4	10.8	10.2	37.5
158.5	9.7	9.3	9.0	10.3	11.0	11.4	9.6	9.0	9.9	35.9
166.0	10.5	8.6	9.0	9.9	10.6	10.1	10.5	10.4	9.9	35.5
177.7	9.7	10.3	10.4	12.0	11.2	11.8	11.7	10.9	11.0	34.1
192.5	9.9	8.5	8.7	9.6	10.3	10.9	6.6	9.1	9.2	31.0
202.5	8.5	7.7	7.9	7.8	9.8	7.6	5.6	9.0	8.0	29.6
214.0	9.7	9.6	9.5	9.3	11.0	9.5	6.4	9.2	9.3	27.8
227.3	9.9	10.6	11.0	7.8	11.3	10.9	9.8	10.3	10.2	25.8
238.3	9.3	9.2	9.3	9.4	9.5	9.6	9.0	8.9	9.3	24.2
250.0	9.9	9.2	9.4	9.9	10.8	10.9	8.8	9.6	9.8	22.6
269.0	9.1	9.7	11.2	9.6	10.6	5.2	11.0	9.7	9.5	19.7
283.9	9.1	10.1	11.5	10.7	7.3	8.3	8.5	7.9	9.2	16.9
299.1	10.5	12.3	11.1	13.7	12.8	13.5	10.9	8.9	11.7	17.5
322.0	7.2	6.5	5.5	8.7	7.6	7.6	9.4	10.2	7.9	12.7
339.0	6.9	6.9	8.1	6.4	5.5	7.7	6.8	5.0	6.7	12.1
358.0	4.7	3.9	4.2	0	5.2	4.7	5.0	0.6	3.5	11.3
367.0	4.6	7.3	5.0	10.9	0.4	5.8	4.7	7.8	5.8	10.9
377.5	4.4	2.4	2.2	4.7	0	4.1	4.4	2.3	3.1	20.3

MOTOR ACTION TIME = 122.3 SECONDS

Table E-VI. 360T025B Aft Cylinder Insulation Performance (cont)

PART NO. 1U76668-02
SERIAL NO. 0000019

PREFIRE MEASUREMENTS
INCHES

STATION (IN)	DEGREE LOCATIONS										
	0.0	46.8	90.0	136.8	180.0	226.8	270.0	316.8	MIN.	MEDIAN	MDT
85.0	1.561	1.564	1.560	1.556	1.573	1.611	1.590	1.588	1.556	1.569	1.300
90.0	1.452	1.436	1.469	1.448	1.418	1.438	1.478	1.408	1.408	1.443	1.265
98.0	1.469	1.459	1.459	1.413	1.435	1.440	1.469	1.441	1.413	1.450	1.135
105.8	1.125	1.137	1.145	1.122	1.158	1.122	1.143	1.139	1.122	1.138	1.080
116.0	1.095	1.092	1.100	1.102	1.109	1.088	1.092	1.121	1.088	1.098	1.050
124.5	1.101	1.087	1.095	1.095	1.099	1.082	1.080	1.094	1.080	1.095	1.030
133.0	1.190	1.198	1.207	1.171	1.177	1.174	1.192	1.207	1.171	1.191	0.980
145.5	0.934	0.925	0.929	0.929	0.926	0.930	0.915	0.924	0.915	0.928	0.930
158.5	0.904	0.897	0.900	0.910	0.903	0.899	0.882	0.893	0.882	0.900	0.880
166.0	1.042	1.032	1.008	1.037	1.031	1.020	1.028	1.030	1.008	1.031	0.850
177.7	1.544	1.526	1.520	1.537	1.534	1.536	1.540	1.511	1.511	1.535	1.000
192.5	0.916	0.921	0.909	0.881	0.887	0.893	0.929	0.901	0.881	0.905	0.780
202.5	0.742	0.738	0.739	0.744	0.736	0.739	0.755	0.735	0.735	0.739	0.730
214.0	0.721	0.710	0.715	0.709	0.713	0.714	0.730	0.709	0.709	0.714	0.700
227.3	0.769	0.789	0.774	0.767	0.753	0.761	0.767	0.738	0.738	0.767	0.650
238.3	0.637	0.636	0.636	0.637	0.638	0.638	0.633	0.635	0.633	0.637	0.630
250.0	0.559	0.563	0.563	0.562	0.563	0.564	0.555	0.556	0.555	0.563	0.550
269.0	0.585	0.582	0.577	0.578	0.582	0.582	0.572	0.571	0.571	0.580	0.500
283.9	0.489	0.507	0.490	0.495	0.495	0.500	0.495	0.522	0.489	0.495	0.450
299.1	1.093	1.097	1.084	1.091	1.098	1.093	1.080	1.095	1.080	1.093	0.676
322.0	0.410	0.413	0.402	0.412	0.408	0.410	0.396	0.410	0.396	0.410	0.380
339.0	0.402	0.407	0.410	0.398	0.404	0.404	0.402	0.408	0.398	0.404	0.380
358.0	0.418	0.411	0.423	0.397	0.403	0.412	0.427	0.420	0.397	0.415	0.380
367.0	0.467	0.470	0.465	0.481	0.433	0.482	0.438	0.446	0.433	0.466	0.380
377.5	0.657	0.657	0.630	0.744	0.618	0.616	0.644	0.618	0.616	0.637	0.530

Table E-VI. 360T025B Aft Cylinder Insulation Performance (cont)

PART NO. 1U76957-03 SERIAL NO. 0000010	POSTFIRE MEASUREMENTS INCHES									
	STATION (IN)	DEGREE LOCATIONS								MIN.
	0.0	46.8	90.0	136.8	180.0	226.8	270.0	316.8		
85.0	1.156	1.178	1.166	1.239	1.131	1.166	1.310	1.159	1.131	1.166
90.0	1.045	1.069	1.061	1.005	1.116	1.021	1.215	1.012	1.005	1.053
98.0	0.964	1.010	1.032	0.970	1.062	0.951	1.166	1.008	0.951	1.009
105.8	0.665	0.724	0.719	0.721	0.690	0.653	0.789	0.665	0.653	0.705
116.0	0.663	0.691	0.716	0.706	0.674	0.644	0.679	0.717	0.644	0.685
124.5	0.622	0.661	0.719	0.660	0.662	0.656	0.835	0.666	0.622	0.662
133.0	0.769	0.772	0.818	0.780	0.743	0.730	0.951	0.771	0.730	0.772
145.5	0.540	0.569	0.561	0.548	0.536	0.518	0.562	0.519	0.518	0.544
158.5	0.555	0.563	0.577	0.541	0.509	0.489	0.539	0.571	0.489	0.548
166.0	0.671	0.726	0.687	0.685	0.653	0.663	0.657	0.662	0.653	0.667
177.7	1.213	1.176	1.166	1.128	1.153	1.135	1.140	1.138	1.128	1.146
192.5	0.609	0.656	0.639	0.583	0.569	0.554	0.724	0.618	0.554	0.613
202.5	0.491	0.510	0.505	0.512	0.447	0.513	0.588	0.468	0.447	0.507
214.0	0.451	0.444	0.452	0.451	0.407	0.450	0.553	0.452	0.407	0.451
227.3	0.513	0.515	0.491	0.565	0.462	0.481	0.513	0.471	0.462	0.502
238.3	0.413	0.414	0.411	0.410	0.407	0.405	0.416	0.420	0.405	0.412
250.0	0.335	0.354	0.351	0.339	0.319	0.318	0.356	0.340	0.318	0.340
269.0	0.406	0.390	0.357	0.388	0.373	0.480	0.355	0.380	0.355	0.384
283.9	0.336	0.336	0.296	0.315	0.371	0.359	0.352	0.389	0.296	0.344
299.1	0.910	0.882	0.890	0.852	0.874	0.857	0.890	0.940	0.852	0.886
322.0	0.318	0.330	0.332	0.301	0.311	0.314	0.276	0.280	0.276	0.313
339.0	0.318	0.323	0.312	0.320	0.337	0.311	0.320	0.348	0.311	0.320
358.0	0.365	0.367	0.376	0.446	0.344	0.359	0.370	0.413	0.344	0.369
367.0	0.417	0.390	0.410	0.362	0.429	0.419	0.387	0.361	0.361	0.400
377.5	0.568	0.609	0.586	0.648	0.646	0.532	0.555	0.571	0.532	0.579

Table E-VII. 360T025B Aft Center Segment Insulation Performance

COMPLIANCE SAFETY FACTOR (CSF)

STATION (IN)	DEGREE LOCATIONS								MIN.	PLANE	REQUIRED S.F.
	0.0	46.0	90.0	136.0	180.0	226.0	270.0	316.0			
3.5	4.56	3.78	3.81	3.16	3.32	5.39	4.01	3.33	3.16	136.0	2.0
11.0	3.40	4.17	3.56	3.04	2.87	3.75	5.22	4.82	2.87	180.0	1.5
30.7	2.45	2.53	3.89	2.87	3.15	2.62	3.28	2.73	2.45	0.0	1.5
36.2	3.17	2.58	3.90	3.51	3.80	3.02	4.08	2.67	2.58	46.0	1.5
44.6	4.56	5.90	5.90	5.71	5.90	7.35	4.19	8.18	4.19	270.0	1.5
71.5	6.07	3.62	2.50	2.79	4.59	3.09	7.08	4.15	2.50	90.0	1.5
126.0	3.57	6.00	3.26	3.49	21.43	4.84	18.75	4.55	3.26	90.0	1.5
145.0	5.17	4.41	3.85	4.17	6.00	4.69	15.00	4.69	3.85	90.0	1.5
161.4	2.19	1.21<	3.81	2.15	1.48<	2.46	2.74	2.23	1.21	46.0	2.0
163.0	2.31	2.65	78.67	3.87	2.68	2.57	3.58	2.95	2.31	0.0	1.5
178.0	6.19	4.64	4.64	+	7.22	6.50	3.82	3.82	3.82	316.0	1.5
214.1	9.29	6.50	4.81	5.42	18.57	32.50	32.50	65.00	4.81	90.0	1.5
280.0	+	+	+	+	+	+	+	+	+	0.0	1.5
298.0	+	+	+	+	+	+	+	+	+	0.0	1.5
311.8	+	+	+	+	+	+	+	+	+	0.0	1.5

SEGMENT MINIMUM = 1.21 AT THE 161.4 INCH STATION

A " < " INDICATES THE PRECEDING SAFETY FACTOR HAS VIOLATED THE MINIMUM SAFETY FACTOR REQUIREMENT

A " + " MEANS NEGLIGIBLE MDD HAS OCCURRED

ACTUAL SAFETY FACTOR (ASF)

STATION (IN)	DEGREE LOCATIONS								MIN.	PLANE	REQUIRED S.F.
	0.0	46.0	90.0	136.0	180.0	226.0	270.0	316.0			
3.5	5.68	4.67	4.69	4.11	4.19	6.38	4.99	4.18	4.11	136.0	2.0
11.0	4.18	5.21	4.41	3.82	3.94	4.86	6.43	5.93	3.82	136.0	1.5
30.7	2.80	2.78	4.30	3.07	3.48	3.04	3.56	2.98	2.78	46.0	1.5
36.2	4.47	3.61	5.29	4.63	5.14	4.22	5.40	3.55	3.55	316.0	1.5
44.6	5.08	6.03	6.15	5.97	6.08	7.49	4.30	8.30	4.30	270.0	1.5
71.5	6.89	3.85	2.78	3.03	5.05	3.42	7.88	4.85	2.78	90.0	1.5
126.0	3.88	6.16	3.54	3.70	23.29	5.16	20.00	4.76	3.54	90.0	1.5
145.0	5.45	4.53	4.13	4.47	6.36	5.03	15.70	5.03	4.13	90.0	1.5
161.4	5.95	3.54	10.87	5.61	3.97	6.43	7.05	5.91	3.54	46.0	2.0
163.0	5.39	6.18	+	9.02	6.25	5.98	8.33	6.87	5.39	0.0	1.5
178.0	9.43	6.57	6.79	+	10.44	9.80	5.59	5.91	5.59	270.0	1.5
214.1	9.57	6.45	5.04	5.67	19.57	33.25	34.50	67.00	5.04	90.0	1.5
280.0	+	+	+	+	+	+	+	+	+	0.0	1.5
298.0	+	+	+	+	+	+	+	+	+	0.0	1.5
311.8	+	+	+	+	+	+	+	+	+	0.0	1.5

SEGMENT MINIMUM = 2.78 AT THE 30.7 INCH STATION

A " + " MEANS NEGLIGIBLE MDD HAS OCCURRED

Table E-VII. 360T025B Aft Center Segment Insulation Performance (cont)

MATERIAL DECOMPOSITION DEPTH (MDD) INCHES											
STATION (IN)	DEGREE LOCATIONS								MEDIAN	MAX.	DESIGN M+3S
	0.0	46.0	90.0	136.0	180.0	226.0	270.0	316.0			
3.5	0.465	0.561	0.557	0.671	0.639	0.393	0.529	0.636	0.559	0.671	1.067
11.0	0.559	0.456	0.533	0.626	0.663	0.506	0.364	0.394	0.519	0.663	0.829
30.7	0.316	0.306	0.199	0.270	0.246	0.295	0.236	0.284	0.277	0.316	0.484
36.2	0.189	0.233	0.154	0.171	0.158	0.199	0.147	0.225	0.180	0.233	0.318
44.6	0.079	0.061	0.061	0.063	0.061	0.049	0.086	0.044	0.061	0.086	0.090
71.5	0.028	0.047	0.068	0.061	0.037	0.055	0.024	0.041	0.044	0.068	0.086
126.0	0.042	0.025	0.046	0.043	0.007	0.031	0.008	0.033	0.032	0.046	0.074
145.0	0.029	0.034	0.039	0.036	0.025	0.032	0.010	0.032	0.032	0.039	0.063
161.4	0.108	<0.195	<0.062	0.110	<0.159	<0.096	<0.086	<0.106	0.107	0.195	0.082
163.0	0.102	<0.089	<0.003	0.061	0.088	<0.092	<0.066	0.080	0.084	0.102	0.082
178.0	0.021	0.028	0.028	0	0.018	0.020	0.034	0.034	0.024	0.034	0.065
214.1	0.014	0.020	0.027	0.024	0.007	0.004	0.004	0.002	0.011	0.027	0.029
280.0	0	0	0	0	0	0	0	0	0	0	0.005
298.0	0	0	0	0	0	0	0	0	0	0	0.005
311.8	0	0	0	0	0	0	0	0	0	0	0.003

A " < " INDICATES THE PRECEDING MDD HAS EXCEEDED THE M + 3 SIGMA DESIGN CRITERIA

MATERIAL DECOMPOSITION RATE (MDR) MILS / SECOND										
STATION (IN)	DEGREE LOCATIONS								AVE.	EXPOSURE TIME
	0.0	46.0	90.0	136.0	180.0	226.0	270.0	316.0		
3.5	4.2	5.0	5.0	6.0	5.7	3.5	4.8	5.7	5.0	111.2
11.0	5.8	4.7	5.5	6.5	6.9	5.2	3.8	4.1	5.3	96.7
30.7	6.7	6.5	4.2	5.7	5.2	6.2	5.0	6.0	5.7	47.3
36.2	5.8	7.2	4.8	5.3	4.9	6.1	4.5	6.9	5.7	32.4
44.6	6.6	5.1	5.1	5.3	5.1	4.1	7.2	3.7	5.3	11.9
71.5	2.8	4.7	6.7	6.0	3.7	5.4	2.4	4.1	4.5	10.1
126.0	4.8	2.9	5.3	4.9	0.8	3.6	0.9	3.8	3.4	8.7
145.0	4.0	4.7	5.3	4.9	3.4	4.4	1.4	4.4	4.1	7.3
161.4	10.9	19.7	6.3	11.1	16.1	9.7	8.7	10.7	11.6	9.9
163.0	10.3	9.0	0.3	6.2	8.9	9.3	6.7	8.1	7.3	9.9
178.0	3.5	4.7	4.7	0	3.0	3.3	5.7	5.7	3.8	6.0
214.1	2.3	3.3	4.5	4.0	1.2	0.7	0.7	0.3	2.1	6.0
280.0	0	0	0	0	0	0	0	0	0	3.4
298.0	0	0	0	0	0	0	0	0	0	2.8
311.8	0	0	0	0	0	0	0	0	0	2.0

MOTOR ACTION TIME = 122.3 SECONDS

Table E-VII. 360T025B Aft Center Segment Insulation Performance (cont)

PART NO. 1U76667-02		PREFIRE MEASUREMENTS .										
SERIAL NO. 0000049		INCHES										
STATION (IN)	DEGREE LOCATIONS									MIN.	MEDIAN	MDT
	0.0	46.0	90.0	136.0	180.0	226.0	270.0	316.0				
3.5	2.641	2.619	2.614	2.756	2.675	2.509	2.639	2.658	2.509	2.640	2.120	
11.0	2.339	2.374	2.353	2.389	2.613	2.457	2.342	2.338	2.338	2.364	1.900	
30.7	0.885	0.850	0.856	0.828	0.855	0.897	0.841	0.845	0.828	0.853	0.774	
36.2	0.844	0.842	0.814	0.792	0.812	0.839	0.794	0.799	0.792	0.813	0.600	
44.6	0.401	0.368	0.375	0.376	0.371	0.367	0.370	0.365	0.365	0.370	0.360	
71.5	0.193	0.181	0.189	0.185	0.187	0.188	0.189	0.199	0.181	0.189	0.170	
126.0	0.163	0.154	0.163	0.159	0.163	0.160	0.160	0.157	0.154	0.160	0.150	
145.0	0.158	0.154	0.161	0.161	0.159	0.161	0.157	0.161	0.154	0.160	0.150	
161.4	0.643	0.691	0.674	0.617	0.631	0.617	0.606	0.626	0.606	0.628	0.236	
163.0	0.550	0.550	0.550	0.550	0.550	0.550	0.550	0.550	0.550	0.550	0.236	
178.0	0.198	0.184	0.190	0.190	0.188	0.196	0.190	0.201	0.184	0.190	0.130	
214.1	0.134	0.129	0.136	0.136	0.137	0.133	0.138	0.134	0.129	0.135	0.130	
280.0	0.102	0.101	0.105	0.105	0.104	0.112	0.117	0.104	0.101	0.105	0.090	
298.0	0.101	0.105	0.111	0.110	0.108	0.111	0.112	0.109	0.101	0.109	0.090	
311.8	0.104	0.110	0.111	0.108	0.109	0.111	0.109	0.104	0.104	0.109	0.090	

PART NO. 1U76791-01		POSTFIRE MEASUREMENTS									
SERIAL NO. 0000020		INCHES									
STATION (IN)	DEGREE LOCATIONS									MIN.	MEDIAN
	0.0	46.0	90.0	136.0	180.0	226.0	270.0	316.0			
3.5	2.176	2.058	2.057	2.085	2.036	2.116	2.110	2.022	2.022	2.072	
11.0	1.780	1.918	1.820	1.763	1.950	1.951	1.978	1.944	1.763	1.931	
30.7	0.569	0.544	0.657	0.558	0.609	0.602	0.605	0.561	0.544	0.586	
36.2	0.655	0.609	0.660	0.621	0.654	0.640	0.647	0.574	0.574	0.644	
44.6	0.322	0.307	0.314	0.313	0.310	0.318	0.284	0.321	0.284	0.314	
71.5	0.165	0.134	0.121	0.124	0.150	0.133	0.165	0.158	0.121	0.142	
126.0	0.121	0.129	0.117	0.116	0.156	0.129	0.152	0.124	0.116	0.126	
145.0	0.129	0.120	0.122	0.125	0.134	0.129	0.147	0.129	0.120	0.129	
161.4	0.535	0.496	0.612	0.507	0.472	0.521	0.520	0.520	0.472	0.520	
163.0	0.448	0.461	0.547	0.489	0.462	0.458	0.484	0.470	0.448	0.466	
178.0	0.177	0.156	0.162	0.191	0.170	0.176	0.156	0.167	0.156	0.169	
214.1	0.120	0.109	0.109	0.112	0.130	0.129	0.134	0.132	0.109	0.124	
280.0	L	L	L	L	L	L	L	L	L	0.105	
298.0	L	L	L	L	L	L	L	L	L	0.109	
311.8	L	L	L	L	L	L	L	L	L	0.109	

AN " L " INDICATES THAT LINER MATERIAL WAS REMAINING AT THAT LOCATION.
THE MEDIAN AND MINIMUM VALUES WERE CALCULATED USING THE PREFIRE THICKNESSES
AT THE LOCATIONS WHERE LINER MATERIAL WAS REMAINING

Table E-VIII. 360T025B Forward Center Segment Insulation Performance

COMPLIANCE SAFETY FACTOR (CSF)

STATION (IN)	DEGREE LOCATIONS								MIN.	PLANE	REQUIRED S.F.
	0.0	46.0	90.0	136.0	180.0	226.0	270.0	316.0			
3.5	14.42	10.93	+	11.71	12.62	14.62	+	17.52	10.93	46.0	2.0
11.0	22.62	+	+	51.35	+	+	65.52	+	22.62	0.0	1.5
30.7	6.25	4.08	+	4.08	5.33	5.41	+	4.00	4.00	316.0	1.5
36.2	10.53	8.22	12.77	8.70	11.11	19.35	7.06	7.32	7.06	270.0	1.5
44.6	32.73	11.25	9.00	10.29	10.59	+	13.33	9.73	9.00	90.0	1.5
71.5	+	3.78	5.86	5.15	6.54	9.44	13.08	5.48	3.78	46.0	1.5
126.0	+	11.54	6.82	18.75	6.82	13.64	+	13.64	6.82	90.0	1.5
145.0	+	+	18.75	8.82	8.82	37.50	6.82	21.43	6.82	270.0	1.5
161.4	6.56	7.61	14.75	5.49	6.21	7.15	5.02	4.21	4.21	316.0	2.0
163.0	3.87	+	4.00	3.93	4.72	5.90	4.14	4.07	3.87	0.0	1.5
178.0	+	+	14.44	5.65	5.42	43.33	+	6.50	5.42	180.0	1.5
214.1	+	+	+	+	+	+	+	+	+	0.0	1.5
280.0	+	+	+	+	+	+	+	+	+	0.0	1.5
298.0	+	+	+	+	+	+	+	+	+	0.0	1.5
311.8	+	+	+	+	+	+	+	+	+	0.0	1.5

SEGMENT MINIMUM = 3.78 AT THE 71.5 INCH STATION
A " + " MEANS NEGLIGIBLE MDD HAS OCCURRED

ACTUAL SAFETY FACTOR (ASF)

STATION (IN)	DEGREE LOCATIONS								MIN.	PLANE	REQUIRED S.F.
	0.0	46.0	90.0	136.0	180.0	226.0	270.0	316.0			
3.5	17.01	13.38	+	14.70	15.35	18.46	+	21.46	13.38	46.0	2.0
11.0	29.18	+	+	62.76	+	+	82.97	+	29.18	0.0	1.5
30.7	13.31	8.68	+	8.56	11.29	11.30	+	8.37	8.37	316.0	1.5
36.2	14.40	11.25	17.62	11.77	15.20	26.16	9.84	9.80	9.80	316.0	1.5
44.6	34.73	11.91	9.70	11.00	11.26	+	14.15	10.27	9.70	90.0	1.5
71.5	+	4.29	6.52	5.79	7.35	10.50	14.85	6.06	4.29	46.0	1.5
126.0	+	13.15	7.36	21.00	7.41	14.82	+	15.00	7.36	90.0	1.5
145.0	+	+	19.87	9.82	9.82	40.75	7.50	23.29	7.50	270.0	1.5
161.4	16.67	18.81	33.81	13.33	14.63	16.73	11.77	10.32	10.32	316.0	2.0
163.0	9.02	+	9.32	9.17	11.00	13.75	9.65	9.48	9.02	0.0	1.5
178.0	+	+	21.89	8.57	8.08	63.00	+	9.50	8.08	180.0	1.5
214.1	+	+	+	+	+	+	+	+	+	0.0	1.5
280.0	+	+	+	+	+	+	+	+	+	0.0	1.5
298.0	+	+	+	+	+	+	+	+	+	0.0	1.5
311.8	+	+	+	+	+	+	+	+	+	0.0	1.5

SEGMENT MINIMUM = 4.29 AT THE 71.5 INCH STATION
A " + " MEANS NEGLIGIBLE MDD HAS OCCURRED

Table E-VIII. 360T025B Forward Center Segment Insulation Performance (cont)

MATERIAL DECOMPOSITION DEPTH (MDD) INCHES											
STATION (IN)	DEGREE LOCATIONS								MEDIAN	MAX.	DESIGN M+3S
	0.0	46.0	90.0	136.0	180.0	226.0	270.0	316.0			
3.5	0.147	0.194	0	0.181	0.168	0.145	0	0.121	0.146	0.194	1.067
11.0	0.084	0.005	0	0.037	0	0	0.029	0	0	0.084	0.829
30.7	0.064	0.098	0	0.098	0.075	0.074	0	0.100	0.074	0.100	0.484
36.2	0.057	0.073	0.047	0.069	0.054	0.031	0.085	0.082	0.063	0.085	0.318
44.6	0.011	0.032	0.040	0.035	0.034	0	0.027	0.037	0.033	0.040	0.090
71.5	0	0.045	0.029	0.033	0.026	0.018	0.013	0.031	0.027	0.045	0.086
126.0	0	0.013	0.022	0.008	0.022	0.011	0	0.011	0.011	0.022	0.074
145.0	0	0	0.008	0.017	0.017	0.004	0.022	0.007	0.008	0.022	0.063
161.4	0.036	0.031	0.016	0.043	0.038	0.033	0.047	0.056	0.037	0.056	0.082
163.0	0.061	0	0.059	0.060	0.050	0.040	0.057	0.058	0.058	0.061	0.082
178.0	0	0	0.009	0.023	0.024	0.003	0.001	0.020	0.006	0.024	0.065
214.1	0	0	0	0	0	0	0	0	0	0	0.029
280.0	0	0	0	0	0	0	0	0	0	0	0.005
298.0	0	0	0	0	0	0	0	0	0	0	0.005
311.8	0	0	0	0	0	0	0	0	0	0	0.003

MATERIAL DECOMPOSITION RATE (MDR) MILS / SECOND										
STATION (IN)	DEGREE LOCATIONS								AVE.	EXPOSURE TIME
	0.0	46.0	90.0	136.0	180.0	226.0	270.0	316.0		
3.5	1.3	1.7	0	1.6	1.5	1.3	0	1.1	1.1	111.2
11.0	0.9	0.1	0	0.4	0	0	0.3	0	0.2	96.9
30.7	1.3	2.1	0	2.1	1.6	1.6	0	2.1	1.3	47.6
36.2	1.7	2.2	1.4	2.1	1.6	0.9	2.6	2.5	1.9	33.0
44.6	0.9	2.5	3.1	2.8	2.7	0	2.1	2.9	2.1	12.7
71.5	0	4.1	2.7	3.0	2.4	1.7	1.2	2.8	2.2	10.9
126.0	0	1.4	2.3	0.8	2.3	1.2	0	1.2	1.1	9.5
145.0	0	0	1.0	2.2	2.2	0.5	2.8	0.9	1.2	7.9
161.4	3.4	2.9	1.5	4.0	3.6	3.1	4.4	5.2	3.5	10.7
163.0	5.7	0	5.5	5.6	4.7	3.7	5.3	5.4	4.5	10.7
178.0	0	0	1.3	3.2	3.4	0.4	0.1	2.8	1.4	7.1
214.1	0	0	0	0	0	0	0	0	0	7.1
280.0	0	0	0	0	0	0	0	0	0	4.2
298.0	0	0	0	0	0	0	0	0	0	4.0
311.8	0	0	0	0	0	0	0	0	0	3.4

MOTOR ACTION TIME = 122.3 SECONDS

Table E-VIII. 360T025B Forward Center Segment Insulation Performance (cont)

PART NO. 1U76667-02 SERIAL NO. 0000050		PREFIRE MEASUREMENTS INCHES										
STATION (IN)	DEGREE LOCATIONS									MIN.	MEDIAN	MDT
	0.0	46.0	90.0	136.0	180.0	226.0	270.0	316.0				
3.5	2.500	2.595	2.417	2.661	2.579	2.676	2.372	2.597	2.372	2.587	2.120	
11.0	2.451	2.422	2.287	2.322	2.363	2.208	2.406	2.344	2.208	2.354	1.900	
30.7	0.852	0.851	0.420	0.839	0.847	0.836	0.403	0.837	0.403	0.838	0.400	
36.2	0.821	0.821	0.828	0.812	0.821	0.811	0.836	0.804	0.804	0.821	0.600	
44.6	0.382	0.381	0.388	0.385	0.383	0.389	0.382	0.380	0.380	0.382	0.360	
71.5	0.196	0.193	0.189	0.191	0.191	0.189	0.193	0.188	0.188	0.191	0.170	
126.0	0.162	0.171	0.162	0.168	0.163	0.163	0.161	0.165	0.161	0.163	0.150	
145.0	0.166	0.172	0.159	0.167	0.167	0.163	0.165	0.163	0.159	0.166	0.150	
161.4	0.600	0.583	0.541	0.573	0.556	0.552	0.553	0.578	0.541	0.565	0.236	
163.0	0.550	0.550	0.550	0.550	0.550	0.550	0.550	0.550	0.550	0.550	0.236	
178.0	0.191	0.192	0.197	0.197	0.194	0.189	0.192	0.190	0.189	0.192	0.130	
214.1	0.139	0.137	0.139	0.138	0.138	0.136	0.137	0.139	0.136	0.138	0.130	
280.0	0.101	0.108	0.112	0.108	0.104	0.106	0.116	0.099	0.099	0.107	0.090	
298.0	0.110	0.100	0.108	0.111	0.110	0.100	0.100	0.108	0.100	0.108	0.090	
311.8	0.101	0.112	0.111	0.112	0.103	0.101	0.114	0.099	0.099	0.107	0.090	

PART NO. 1U76791-01 SERIAL NO. 0000021		POSTFIRE MEASUREMENTS INCHES										
STATION (IN)	DEGREE LOCATIONS									MIN.	MEDIAN	
	0.0	46.0	90.0	136.0	180.0	226.0	270.0	316.0				
3.5	2.353	2.401	2.427	2.480	2.411	2.531	2.505	2.476	2.353	2.452		
11.0	2.367	2.417	2.368	2.285	2.464	2.323	2.377	2.489	2.285	2.373		
30.7	0.788	0.753	0.775	0.741	0.772	0.762	0.747	0.737	0.737	0.758		
36.2	0.764	0.748	0.781	0.743	0.767	0.780	0.751	0.722	0.722	0.757		
44.6	0.371	0.349	0.348	0.350	0.349	0.399	0.355	0.343	0.343	0.350		
71.5	0.210	0.148	0.160	0.158	0.165	0.171	0.180	0.157	0.148	0.163		
126.0	0.167	0.158	0.140	0.160	0.141	0.152	0.162	0.154	0.140	0.156		
145.0	0.183	0.177	0.151	0.150	0.150	0.159	0.143	0.156	0.143	0.154		
161.4	0.564	0.552	0.525	0.530	0.518	0.519	0.506	0.522	0.506	0.524		
163.0	0.489	L	0.491	0.490	0.500	0.510	0.493	0.492	0.489	0.493		
178.0	L	L	0.188	0.174	0.170	0.186	0.191	0.170	0.170	0.187		
214.1	L	L	L	L	L	L	L	L	L	0.138		
280.0	L	L	L	L	L	L	L	L	L	0.107		
298.0	L	L	L	L	L	L	L	L	L	0.108		
311.8	L	L	L	L	L	L	L	L	L	0.107		

AN " L " INDICATES THAT LINER MATERIAL WAS REMAINING AT THAT LOCATION.
THE MEDIAN AND MINIMUM VALUES WERE CALCULATED USING THE PREFIRE THICKNESSES
AT THE LOCATIONS WHERE LINER MATERIAL WAS REMAINING

Table E-IX. 360T025B Forward Segment Star Tip Insulation Performance

COMPLIANCE SAFETY FACTOR (CSF)				ACTUAL SAFETY FACTOR (ASF)											
STATION (IN)	90.0	154.0	222.0	286.0	352.0	MIN.	PLANE	STATION (IN)	90.0	154.0	222.0	286.0	352.0	MIN.	PLANE
	DEGREE LOCATIONS				DEGREE LOCATIONS					DEGREE LOCATIONS					
	MIN.				MIN.					MIN.					
3.5	+	+	+	+	+	+	90.0	3.5	+	+	+	+	+	+	90.0
13.0	34.21	+	7.14	16.67	6.70	6.70	352.0	13.0	51.74	+	10.38	24.33	10.52	10.38	222.0
27.0	+	+	+	+	+	+	90.0	27.0	+	+	+	+	+	+	90.0
44.0	+	+	+	+	+	+	90.0	44.0	+	+	+	+	+	+	90.0
60.0	+	+	+	+	+	+	90.0	60.0	+	+	+	+	+	+	90.0
94.7	+	+	+	+	+	+	90.0	94.7	+	+	+	+	+	+	90.0
142.0	+	+	+	+	+	+	90.0	142.0	+	+	+	+	+	+	90.0
152.0	5.47	15.85	6.22	6.60	5.11	5.11	352.0	152.0	6.69	20.35	7.55	7.85	6.34	6.34	352.0
162.0	4.02	6.92	5.02	4.27	4.27	4.02	90.0	162.0	5.59	9.58	6.88	5.95	5.80	5.59	90.0
175.5	3.78	3.53	3.41	3.26	4.14	3.26	286.0	175.5	4.55	4.33	4.10	3.82	4.89	3.82	286.0
187.0	3.00	2.23	2.71	2.54	2.81	2.23	154.0	187.0	3.04	2.41	2.86	2.66	2.86	2.41	154.0
199.0	4.81	3.27	3.40	3.47	3.04	3.04	352.0	199.0	5.21	3.53	3.78	3.75	3.37	3.37	352.0
213.0	3.05	3.18	2.83	3.15	2.93	2.83	222.0	213.0	3.35	3.46	3.14	3.43	3.32	3.14	222.0
224.0	3.56	3.54	3.60	2.77	2.88	2.77	286.0	224.0	4.18	4.15	4.36	3.30	3.40	3.30	286.0
230.0	3.42	3.68	4.23	3.32	3.64	3.32	286.0	230.0	3.75	3.99	4.65	3.64	3.95	3.64	286.0
236.0	2.68	2.83	3.19	2.41	2.52	2.41	286.0	236.0	3.05	3.22	3.70	2.75	3.03	2.75	286.0
240.0	2.56	2.30	2.46	3.21	2.57	2.30	154.0	240.0	2.93	2.70	2.94	3.70	3.00	2.70	154.0
254.0	2.62	3.01	3.05	2.84	2.94	2.62	90.0	254.0	2.74	3.13	3.22	2.99	3.10	2.74	90.0
263.0	2.80	2.93	2.83	2.44	2.69	2.44	286.0	263.0	2.94	3.10	3.00	2.61	2.81	2.61	286.0
282.0	2.45	3.76	2.65	2.19	2.40	2.19	286.0	282.0	2.80	4.23	3.10	2.61	2.77	2.61	286.0
293.0	2.43	2.83	2.68	2.94	2.65	2.43	90.0	293.0	2.87	3.24	3.10	3.39	3.01	2.87	90.0
305.0	2.36	2.71	2.98	2.36	2.65	2.36	352.0	305.0	2.84	3.43	3.80	2.90	3.41	2.84	352.0
312.0	2.70	3.30	2.43	2.80	2.33	2.33	286.0	312.0	3.30	4.30	3.22	3.66	3.10	3.10	286.0
321.0	5.70	5.16	4.21	3.67	4.37	3.67	286.0	321.0	6.12	5.36	4.52	3.87	4.61	3.87	286.0
339.0	2.84	2.64	3.91	2.60	2.76	2.60	286.0	339.0	3.06	2.86	4.23	2.85	3.07	2.85	286.0
350.0	2.32	3.17	2.84	3.13	3.68	2.32	90.0	350.0	2.70	3.52	3.30	3.47	4.14	2.70	90.0
362.0	2.29	2.91	2.35	2.18	2.02	2.02	352.0	362.0	2.61	3.33	2.70	2.71	2.61	2.61	352.0
371.0	1.91	2.42	2.56	2.46	2.10	1.91	90.0	371.0	2.45	2.77	3.05	2.97	2.58	2.45	90.0
383.0	3.32	3.08	3.06	2.85	3.01	2.85	286.0	383.0	3.90	3.63	3.67	3.29	3.46	3.29	286.0
397.0	3.27	3.93	2.68	2.92	3.45	2.68	222.0	397.0	3.94	4.64	3.28	3.58	4.15	3.28	222.0
403.0	4.38	4.32	4.52	3.47	4.28	3.47	286.0	403.0	4.91	4.81	4.96	3.95	5.01	3.95	286.0

SEGMENT MINIMUM = 1.91 AT THE 371.0 INCH STATION
 SEGMENT MINIMUM = 2.41 AT THE 187.0 INCH STATION
 A " + " MEANS NEGLIGIBLE HDD HAS OCCURRED

Table E-IX. 360T025B Forward Segment Star Tip Insulation Performance (cont)

MATERIAL DECOMPOSITION DEPTH (MDD) INCHES			MATERIAL DECOMPOSITION RATE (MDR) MILS / SECOND			STATION (IN)	STATION (IN)	DESIGN M+3S	DEGREE LOCATIONS			EXPOSURE TIME	
90.0	154.0	222.0	286.0	352.0	90.0				154.0	222.0	286.0		352.0
3.5	0	0	0	0	0.020	0.103	3.5	0	0	0	0.6	0.1	34.1
13.0	0.019	0	0.091	0.039	0.097	0.101	13.0	1.0	0	4.7	2.0	2.5	19.3
27.0	0	0	0	0	0	0.044	27.0	0	0	0	0	0	4.8
44.0	0	0	0	0	0	0.015	44.0	0	0	0	0	0	3.0
60.0	0	0	0	0	0	0.012	60.0	0	0	0	0	0	1.4
94.7	0	0	0	0	0	0.004	94.7	0	0	0	0	0	0.8
142.0	0	0	0	0	0	0.019	142.0	0	0	0	0	0	1.0
152.0	0.058	0.020	0.051	0.048	0.062	0.123	152.0	1.8	0.6	1.6	1.5	1.5	32.4
162.0	0.136	0.079	0.109	0.128	0.136	0.227	162.0	2.4	1.4	1.9	2.2	2.0	57.6
175.5	0.160	0.171	0.177	0.185	0.185	0.324	175.5	1.8	1.9	2.0	2.1	1.6	1.9
187.0	0.213	0.287	0.236	0.252	0.228	0.398	187.0	2.1	2.8	2.3	2.5	2.3	86.5
199.0	0.142	0.209	0.201	0.197	0.225	0.427	199.0	1.4	2.1	2.0	1.9	2.2	2.4
213.0	0.222	0.213	0.239	0.215	0.231	0.423	213.0	2.2	2.1	2.4	2.1	2.3	101.3
224.0	0.190	0.191	0.188	0.244	0.235	0.422	224.0	1.9	1.9	1.9	2.4	2.3	2.2
236.0	0.216	0.204	0.181	0.240	0.229	0.375	236.0	2.0	1.8	1.6	2.0	1.8	101.3
240.0	0.224	0.250	0.233	0.179	0.223	0.327	240.0	2.1	2.0	1.8	2.4	2.3	101.3
254.0	0.217	0.189	0.186	0.200	0.193	0.318	254.0	2.2	2.5	2.3	1.8	2.2	101.3
263.0	0.203	0.194	0.201	0.233	0.211	0.334	263.0	2.0	1.9	1.9	2.0	2.1	101.3
282.0	0.232	0.151	0.214	0.259	0.237	0.349	282.0	2.3	1.5	2.1	2.6	2.3	101.3
293.0	0.225	0.193	0.204	0.186	0.206	0.330	293.0	2.2	1.9	2.0	1.8	2.0	101.3
305.0	0.222	0.194	0.176	0.222	0.198	0.309	305.0	2.2	1.9	1.7	2.2	2.0	101.3
312.0	0.200	0.164	0.223	0.193	0.232	0.308	312.0	2.0	1.6	2.2	1.9	2.3	101.3
321.0	0.161	0.178	0.218	0.250	0.210	0.434	321.0	1.6	1.7	2.1	2.4	2.0	103.4
339.0	0.194	0.209	0.141	0.212	0.200	0.319	339.0	1.9	2.1	1.4	2.1	2.0	99.9
350.0	0.225	0.165	0.184	0.167	0.142	0.300	350.0	2.3	1.7	1.8	1.7	1.4	1.8
362.0	0.227	0.179	0.221	0.239	0.257	0.285	362.0	2.3	1.8	2.2	2.4	2.6	98.7
371.0	0.272	0.215	0.203	0.211	0.248	0.304	371.0	2.9	2.3	2.2	2.2	2.6	94.3
383.0	0.154	0.166	0.167	0.179	0.170	0.295	383.0	1.6	1.7	1.7	1.9	1.8	95.5
397.0	0.154	0.128	0.188	0.172	0.146	0.287	397.0	1.5	1.3	1.9	1.7	1.5	1.6
403.0	0.217	0.220	0.210	0.274	0.222	0.287	403.0	1.8	1.8	1.7	2.2	1.8	122.3

MOTOR ACTION TIME = 122.3 SECONDS

Table E-IX. 360T025B Forward Segment Star Tip Insulation Performance (cont)

PREFIRE MEASUREMENTS				POSTFIRE MEASUREMENTS			
INCHES				INCHES			
PART NO. 1U76666-02 SERIAL NO. 0000026				PART NO. 1U76790-05 SERIAL NO. 0000009			
STATION (IN)	DEGREE LOCATIONS			STATION (IN)	DEGREE LOCATIONS		
	90.0	154.0	222.0 286.0 352.0		90.0	154.0	222.0 286.0 352.0
	MIN.	MEDIAN	MDF		MIN.	MEDIAN	
3.5	2.417	2.532	2.473	2.531	2.462	2.417	2.473
13.0	0.983	0.928	0.945	0.949	1.020	0.928	0.949
27.0	0.594	0.572	0.593	0.588	0.577	0.572	0.588
44.0	0.300	0.289	0.310	0.293	0.284	0.284	0.293
60.0	0.135	0.133	0.145	0.140	0.136	0.133	0.136
94.7	0.101	0.102	0.107	0.109	0.098	0.098	0.099
142.0	0.165	0.164	0.165	0.161	0.160	0.160	0.164
152.0	0.388	0.407	0.385	0.377	0.393	0.377	0.388
162.0	0.760	0.757	0.750	0.761	0.742	0.742	0.757
175.5	0.728	0.740	0.725	0.707	0.714	0.707	0.725
187.0	0.647	0.693	0.674	0.671	0.652	0.647	0.671
199.0	0.740	0.737	0.759	0.738	0.758	0.737	0.740
213.0	0.743	0.737	0.750	0.738	0.767	0.737	0.743
224.0	0.794	0.792	0.820	0.806	0.800	0.792	0.800
230.0	0.743	0.734	0.744	0.743	0.735	0.734	0.743
236.0	0.659	0.656	0.670	0.661	0.693	0.656	0.661
240.0	0.656	0.675	0.684	0.663	0.668	0.656	0.668
254.0	0.594	0.591	0.599	0.597	0.598	0.591	0.597
263.0	0.597	0.602	0.603	0.607	0.592	0.592	0.602
282.0	0.650	0.639	0.664	0.676	0.657	0.639	0.657
293.0	0.645	0.626	0.632	0.631	0.620	0.620	0.631
305.0	0.630	0.665	0.669	0.643	0.676	0.630	0.665
312.0	0.660	0.706	0.719	0.707	0.719	0.660	0.707
321.0	0.985	0.954	0.985	0.968	0.968	0.954	0.968
339.0	0.594	0.597	0.597	0.604	0.613	0.594	0.597
350.0	0.607	0.580	0.608	0.580	0.588	0.580	0.588
362.0	0.592	0.596	0.596	0.648	0.671	0.592	0.596
371.0	0.666	0.595	0.620	0.627	0.640	0.595	0.627
383.0	0.600	0.602	0.613	0.589	0.588	0.588	0.600
397.0	0.606	0.594	0.617	0.615	0.606	0.594	0.606
403.0	1.066	1.059	1.042	1.083	1.112	1.042	1.066

AN " L " INDICATES THAT LINER MATERIAL WAS REMAINING AT THAT LOCATION.
THE MEDIAN AND MINIMUM VALUES WERE CALCULATED USING THE PREFIRE THICKNESSES
AT THE LOCATIONS WHERE LINER MATERIAL WAS REMAINING

Table E-X. 360T025B Forward Segment Non-Star Tip Insulation Performance

COMPLIANCE SAFETY FACTOR (CSF)				ACTUAL SAFETY FACTOR (ASF)						
STATION (IN)	DEGREE LOCATIONS		MIN.	PLANE	REQUIRED S.F.	STATION (IN)	DEGREE LOCATIONS		MIN.	PLANE
	74.0	140.0					206.0	270.0		
3.5	+	+	42.40	336.0	2.0	3.5	+	+	49.88	336.0
13.0	+	0.78	3.74	270.0	1.5	13.0	+	12.59	6.36	270.0
27.0	+	+	+	74.0	1.5	27.0	+	+	+	74.0
44.0	+	+	+	74.0	1.5	44.0	+	+	+	74.0
60.0	+	+	+	74.0	1.5	60.0	+	+	+	74.0
94.7	+	+	+	74.0	1.5	94.7	+	+	+	74.0
142.0	+	+	+	74.0	1.5	142.0	+	+	+	74.0
152.0	+	17.61	17.61	206.0	1.5	152.0	+	21.67	21.67	206.0
162.0	18.23	8.04	6.67	336.0	2.0	162.0	24.63	10.93	9.21	336.0
175.5	3.75	5.98	6.79	74.0	1.5	175.5	4.52	7.31	5.60	74.0
187.0	3.88	5.08	4.74	74.0	1.5	187.0	4.01	5.20	4.87	74.0
199.0	4.91	6.21	4.52	336.0	1.5	199.0	5.27	6.72	4.91	336.0
213.0	5.69	5.29	5.21	336.0	1.5	213.0	6.15	5.78	5.75	336.0
224.0	5.99	5.79	4.98	206.0	1.5	224.0	6.91	6.81	5.92	336.0
230.0	4.94	5.17	4.77	336.0	1.5	230.0	5.42	5.65	5.18	336.0
236.0	4.66	5.16	4.07	270.0	1.5	236.0	5.47	6.11	4.75	270.0
240.0	4.28	4.48	3.59	336.0	1.5	240.0	5.13	5.32	4.38	336.0
254.0	4.73	5.12	4.66	206.0	1.5	254.0	4.93	5.44	4.98	206.0
263.0	5.86	6.11	3.86	336.0	1.5	263.0	6.06	6.42	4.16	336.0
282.0	4.34	5.03	4.34	74.0	1.5	282.0	4.97	6.03	5.45	74.0
293.0	4.67	5.15	4.33	206.0	1.5	293.0	5.47	6.04	5.33	206.0
305.0	5.41	4.82	4.20	336.0	1.5	305.0	6.62	6.11	5.21	336.0
312.0	3.47	4.75	3.47	74.0	1.5	312.0	4.42	6.32	5.47	74.0
321.0	8.35	9.09	5.74	270.0	2.0	321.0	9.15	9.55	6.14	270.0
339.0	4.08	4.24	3.85	336.0	1.5	339.0	4.27	4.64	4.16	336.0
350.0	2.80	3.40	2.75	270.0	1.5	350.0	3.18	3.84	3.34	74.0
362.0	2.51	3.38	2.99	206.0	1.5	362.0	3.00	3.95	3.39	74.0
371.0	3.04	3.11	2.60	336.0	1.5	371.0	3.77	3.55	3.03	336.0
383.0	2.48	2.95	2.39	270.0	1.5	383.0	2.93	3.45	2.87	270.0
397.0	3.47	3.07	2.61	336.0	1.5	397.0	4.21	3.66	3.20	336.0
403.0	4.26	4.55	4.13	270.0	1.5	403.0	4.81	5.08	4.59	270.0

SEGMENT MINIMUM = 2.39 AT THE 303.0 INCH STATION
 SEGMENT MINIMUM = 2.87 AT THE 303.0 INCH STATION
 A * + MEANS NEGLIGIBLE MDD HAS OCCURRED

Table E-X. 360T025B Forward Segment Non-Star Tip Insulation Performance (cont)

MATERIAL DECOMPOSITION DEPTH (MDD) INCHES				MATERIAL DECOMPOSITION RATE (MDR) MILS / SECOND				STATION (IN)	DEGREE LOCATIONS	DESIGN M+3S	MAX.	MEDIAN	STATION (IN)	DEGREE LOCATIONS	MATERIAL DECOMPOSITION RATE (MDR) MILS / SECOND	EXPOSURE TIME		
74.0	140.0	206.0	270.0	336.0	0	0.042	0.050										0.050	0.174
3.5	0	0	0	0	0	0	0	0.050	0.174	0.050	0.103	3.5	0	0	0	0	1.5	0.3
13.0	0	0.005	0.074	0.174	0.042	0.042	0	0	0	0.082	0.123	13.0	0	0.3	3.8	9.0	2.2	3.1
27.0	0	0	0	0	0	0	0	0	0	0.068	0.123	27.0	0	0	0	0	0	0
44.0	0	0	0	0	0	0	0	0	0	0.115	0.123	44.0	0	0	0	0	0	0
60.0	0	0	0	0	0	0	0	0	0	0.135	0.123	60.0	0	0	0	0	0	0
94.7	0	0	0	0	0	0	0	0	0	0.135	0.123	94.7	0	0	0	0	0	0
142.0	0	0	0	0	0	0	0	0	0	0.128	0.123	142.0	0	0	0	0	0	0
152.0	0	0	0.018	0	0.016	0.016	0	0.016	0.142	0.142	0.123	152.0	0	0	0.9	0	0.8	0.3
162.0	0.030	0.068	0.067	0.078	0.082	0.082	0.068	0.082	0.142	0.142	0.123	162.0	0.7	1.5	1.5	1.8	1.9	1.5
175.5	0.161	0.101	0.056	0.126	0.115	0.115	0.115	0.161	0.142	0.142	0.123	175.5	2.4	1.5	1.4	1.9	1.7	1.8
187.0	0.165	0.126	0.128	0.152	0.135	0.135	0.135	0.165	0.142	0.142	0.123	187.0	2.5	1.9	1.9	2.3	2.0	2.1
199.0	0.139	0.110	0.145	0.122	0.151	0.139	0.139	0.151	0.142	0.142	0.123	199.0	2.1	1.7	2.2	1.8	2.3	2.0
213.0	0.119	0.128	0.130	0.098	0.130	0.128	0.128	0.130	0.142	0.142	0.123	213.0	1.8	1.9	2.0	1.5	2.0	1.8
224.0	0.113	0.117	0.136	0.098	0.133	0.117	0.117	0.136	0.142	0.142	0.123	224.0	1.7	1.8	2.1	0.9	2.0	1.7
230.0	0.137	0.131	0.132	0.105	0.142	0.132	0.132	0.142	0.142	0.142	0.123	230.0	2.1	2.0	2.0	1.6	2.1	2.0
236.0	0.124	0.112	0.122	0.142	0.129	0.124	0.124	0.142	0.142	0.142	0.123	236.0	1.9	1.7	1.8	2.1	2.0	1.9
240.0	0.134	0.128	0.124	0.117	0.160	0.128	0.128	0.160	0.142	0.142	0.123	240.0	2.0	1.9	1.9	1.8	2.4	2.0
254.0	0.120	0.111	0.137	0.110	0.122	0.120	0.120	0.137	0.142	0.142	0.123	254.0	1.8	1.7	2.1	1.7	1.8	1.8
263.0	0.097	0.093	0.123	0.117	0.147	0.117	0.117	0.147	0.142	0.142	0.123	263.0	1.5	1.4	1.9	1.8	2.2	1.7
282.0	0.131	0.113	0.094	0.121	0.115	0.115	0.115	0.131	0.142	0.142	0.123	282.0	2.0	1.7	1.4	1.8	1.7	1.7
293.0	0.117	0.106	0.126	0.121	0.119	0.119	0.119	0.126	0.142	0.142	0.123	293.0	1.8	1.6	1.9	1.8	1.8	1.8
305.0	0.097	0.109	0.115	0.114	0.125	0.114	0.114	0.125	0.142	0.142	0.123	305.0	1.5	1.6	1.7	1.7	1.9	1.7
312.0	0.156	0.114	0.115	0.134	0.123	0.123	0.123	0.156	0.142	0.142	0.123	312.0	2.4	1.7	1.7	2.0	1.9	1.9
321.0	0.110	0.101	0.145	0.160	0.143	0.143	0.143	0.160	0.142	0.142	0.123	321.0	1.6	1.4	2.1	2.3	2.0	1.9
339.0	0.135	0.130	0.121	0.089	0.143	0.130	0.130	0.143	0.142	0.142	0.123	339.0	1.9	1.8	1.7	1.2	2.0	1.7
350.0	0.187	0.154	0.089	0.190	0.133	0.154	0.154	0.190	0.142	0.142	0.123	350.0	2.5	2.0	1.2	2.2	1.7	2.0
362.0	0.207	0.154	0.208	0.181	0.174	0.181	0.181	0.208	0.142	0.142	0.123	362.0	2.5	1.9	2.6	2.2	2.1	2.3
371.0	0.171	0.167	0.167	0.162	0.200	0.167	0.167	0.200	0.142	0.142	0.123	371.0	2.1	2.0	2.0	2.0	2.5	2.1
383.0	0.206	0.173	0.192	0.214	0.144	0.192	0.192	0.214	0.142	0.142	0.123	383.0	2.3	1.9	2.2	2.4	1.6	2.1
397.0	0.145	0.164	0.160	0.184	0.193	0.164	0.164	0.193	0.142	0.142	0.123	397.0	1.5	1.7	1.6	1.9	2.0	1.7
403.0	0.223	0.209	0.219	0.230	0.220	0.220	0.220	0.230	0.142	0.142	0.123	403.0	1.8	1.7	1.8	1.9	1.8	1.8

MOTOR ACTION TIME = 122.3 SECONDS

A * < " INDICATES THE PRECEDING MDD HAS EXCEEDED THE M + 3 SIGMA DESIGN CRITERIA

Table E-X. 360T025B Forward Segment Non-Star Tip Insulation Performance (cont)

PREFIRE MEASUREMENTS				POSTFIRE MEASUREMENTS							
INCHES				INCHES							
DEGREE LOCATIONS				DEGREE LOCATIONS							
STATION (IN)	74.0	140.0	206.0	270.0	336.0	STATION (IN)	74.0	140.0	206.0	270.0	336.0
	MIN.	MEDIAN	MDT				MIN.	MEDIAN	MDT		
3.5	2.471	2.491	2.499	2.372	2.494	3.5	2.490	2.549	2.523	2.383	2.444
13.0	0.905	0.978	0.932	1.106	0.960	13.0	0.950	0.973	0.850	0.932	0.918
27.0	0.593	0.576	0.577	0.556	0.575	27.0	L	L	L	L	L
44.0	0.285	0.287	0.286	0.311	0.292	44.0	L	L	L	L	L
60.0	0.134	0.135	0.133	0.136	0.136	60.0	L	L	L	L	L
94.7	0.105	0.106	0.105	0.109	0.097	94.7	L	L	L	L	L
142.0	0.160	0.167	0.165	0.164	0.154	142.0	L	L	L	L	L
152.0	0.404	0.367	0.390	0.388	0.375	152.0	0.431	L	0.372	L	0.359
162.0	0.739	0.743	0.730	0.768	0.755	162.0	0.709	0.675	0.663	0.690	0.673
175.5	0.728	0.738	0.694	0.705	0.730	175.5	0.567	0.637	0.598	0.579	0.615
187.0	0.661	0.655	0.653	0.650	0.658	187.0	0.496	0.529	0.525	0.506	0.523
199.0	0.733	0.739	0.743	0.752	0.742	199.0	0.594	0.629	0.598	0.630	0.591
213.0	0.732	0.740	0.767	0.773	0.748	213.0	0.613	0.612	0.637	0.675	0.618
224.0	0.781	0.797	0.821	0.802	0.787	224.0	0.668	0.680	0.685	0.744	0.654
230.0	0.743	0.740	0.746	0.734	0.736	230.0	0.606	0.609	0.614	0.629	0.594
236.0	0.678	0.684	0.672	0.675	0.680	236.0	0.554	0.572	0.550	0.533	0.551
240.0	0.688	0.681	0.659	0.659	0.700	240.0	0.554	0.553	0.535	0.542	0.540
254.0	0.592	0.604	0.589	0.600	0.607	254.0	0.472	0.493	0.452	0.490	0.485
263.0	0.588	0.597	0.595	0.603	0.611	263.0	0.491	0.504	0.472	0.486	0.464
282.0	0.651	0.681	0.640	0.659	0.653	282.0	0.520	0.568	0.546	0.538	0.538
293.0	0.640	0.640	0.614	0.640	0.634	293.0	0.523	0.534	0.488	0.519	0.515
305.0	0.642	0.666	0.636	0.647	0.651	305.0	0.545	0.557	0.521	0.533	0.526
312.0	0.690	0.721	0.711	0.689	0.673	312.0	0.534	0.607	0.596	0.555	0.550
321.0	1.006	0.965	1.056	0.983	0.964	321.0	0.896	0.864	0.911	0.823	0.821
339.0	0.577	0.603	0.567	0.572	0.595	339.0	0.442	0.473	0.446	0.483	0.452
350.0	0.594	0.592	0.596	0.634	0.596	350.0	0.407	0.438	0.507	0.444	0.463
362.0	0.622	0.608	0.648	0.586	0.589	362.0	0.415	0.454	0.440	0.405	0.415
371.0	0.645	0.593	0.619	0.596	0.606	371.0	0.474	0.426	0.452	0.434	0.406
383.0	0.603	0.596	0.603	0.614	0.617	383.0	0.397	0.423	0.411	0.400	0.473
397.0	0.610	0.601	0.609	0.623	0.618	397.0	0.465	0.437	0.449	0.439	0.425
403.0	1.073	1.061	1.051	1.056	1.097	403.0	0.850	0.852	0.832	0.826	0.877

AN "L" INDICATES THAT LINER MATERIAL WAS REMAINING AT THAT LOCATION. THE MEDIAN AND MINIMUM VALUES WERE CALCULATED USING THE PREFIRE THICKNESSES AT THE LOCATIONS WHERE LINER MATERIAL WAS REMAINING

Table E-XI. 360T025A Igniter Chamber and Adapter Insulation Performance

COMPLIANCE SAFETY FACTORS (CSF)

STATION (NO.)	DEGREE LOCATION								MINIMUM	PLANE
	0.0	60.0	90.0	150.0	180.0	240.0	270.0	330.0		
1.0	3.86	3.89	4.06	5.31	4.96	4.68	4.54	6.51	3.86	0.0
2.0	3.49	3.67	4.17	3.53	3.01	3.50	3.84	3.49	3.01	180.0
3.0	3.28	3.21	3.29	2.82	3.37	3.12	3.28	2.75	2.75	330.0
4.0	3.22	3.76	3.05	2.98	3.10	2.96	3.67	3.09	2.96	240.0
5.0	1.38	1.17	1.18	1.16	1.09	1.03	1.16	1.21	1.03	240.0
6.0	+	+	+	+	+	+	+	+	99.90	0.0
7.0	11.23	33.11	24.19	+	+	4.28	4.01	14.30	4.01	270.0
8.0	+	+	+	30.00	18.21	+	+	99.00	18.21	180.0
9.0	15.04	32.58	43.44	6.11	9.09	6.41	10.86	8.32	6.11	150.0
10.0	6.17	22.75	20.22	8.27	9.33	9.33	5.69	5.69	5.69	270.0
11.0	2.66	2.63	2.37	2.82	2.39	2.51	2.51	2.58	2.37	90.0

SP= + INDICATES THAT NEGLIGIBLE MDD OCCURRED

ACTUAL SAFETY FACTORS (ASF)

STATION (NO.)	DEGREE LOCATION								MINIMUM	PLANE
	0.0	60.0	90.0	150.0	180.0	240.0	270.0	330.0		
1.0	4.55	4.47	4.43	5.27	5.18	5.08	4.96	6.96	4.43	90.0
2.0	3.71	3.99	4.53	3.83	3.27	3.84	4.21	3.79	3.27	180.0
3.0	3.49	3.42	3.61	3.04	3.65	3.33	3.53	2.93	2.93	330.0
4.0	3.53	4.37	3.44	3.30	3.37	3.31	4.14	3.45	3.30	150.0
5.0	1.55	1.35	1.34	1.38	1.23	1.19	1.32	1.33	1.19	240.0
6.0	+	+	+	+	+	+	+	+	99.90	0.0
7.0	12.45	35.00	25.35	+	+	4.47	4.28	15.77	4.28	270.0
8.0	+	+	+	30.76	19.11	+	+	99.00	19.11	180.0
9.0	16.38	36.25	46.89	6.75	9.88	6.93	11.78	9.17	6.75	150.0
10.0	6.73	24.25	21.33	8.98	9.74	10.03	6.19	6.28	6.19	270.0
11.0	3.18	3.14	2.83	3.37	2.86	3.00	3.00	3.09	2.83	90.0

SP= + INDICATES THAT NEGLIGIBLE MDD OCCURRED

Table E-XI. 360T025A Igniter Chamber and Adapter Insulation Performance (cont)

MATERIAL DECOMPOSITION DEPTH (MDD) (INCHES)										
STATION (NO.)	DEGREE LOCATION								MEDIAN	MAXIMUM
	0.0	60.0	90.0	150.0	180.0	240.0	270.0	330.0		
1.0	0.238	0.236	0.226	0.173	0.185	0.196	0.202	0.141	0.199	0.238
2.0	0.263	0.250	0.220	0.260	0.305	0.262	0.239	0.263	0.261	0.305
3.0	0.280	0.286	0.279	0.326	0.272	0.294	0.280	0.334	0.283	0.334
4.0	0.285	0.244	0.301	0.308	0.296	0.310	0.250	0.297	0.297	0.310
5.0	0.250	0.295	0.293	0.297	0.316	0.336	0.299	0.285	0.296	0.336
6.0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7.0	0.056	0.019	0.026	0.000	0.000	0.147	0.157	0.044	0.035	0.157
8.0	0.000	0.000	0.000	0.017	0.028	0.000	0.000	0.005	0.000	0.028
9.0	0.026	0.012	0.009	0.064	0.043	0.061	0.036	0.047	0.039	0.064
10.0	0.059	0.016	0.018	0.044	0.039	0.039	0.064	0.064	0.042	0.064
11.0	0.170	0.172	0.191	0.160	0.189	0.180	0.180	0.175	0.178	0.191

MATERIAL DECOMPOSITION RATE (MDR) (MILS/SEC)										
STATION (NO.)	DEGREE LOCATION								AVERAGE	
	0.0	60.0	90.0	150.0	180.0	240.0	270.0	330.0		
1.0	1.9	1.9	1.9	1.4	1.5	1.6	1.7	1.2	1.6	
2.0	2.2	2.0	1.8	2.1	2.5	2.1	2.0	2.2	2.1	
3.0	2.3	2.3	2.3	2.7	2.2	2.4	2.3	2.7	2.4	
4.0	2.3	2.0	2.5	2.5	2.4	2.5	2.0	2.4	2.3	
5.0	2.0	2.4	2.4	2.4	2.6	2.8	2.4	2.3	2.4	
6.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
7.0	0.5	0.2	0.2	0.0	0.0	1.2	1.3	0.4	0.5	
8.0	0.0	0.0	0.0	0.1	0.2	0.0	0.0	0.0	0.1	
9.0	0.2	0.1	0.1	0.5	0.4	0.5	0.3	0.4	0.3	
10.0	0.5	0.1	0.1	0.4	0.3	0.3	0.5	0.5	0.4	
11.0	1.4	1.4	1.6	1.3	1.5	1.5	1.5	1.4	1.5	

MOTOR ACTION (EXPOSURE) TIME = 122.10 SEC

A MDR=0 INDICATES THAT MDR < .1 MIL/SEC

Table E-XI. 360T025A Igniter Chamber and Adapter Insulation Performance (cont)

CHAMBER PART NO. 1U75163-01(903)
 CHAMBER SERIAL NO. 0000066
 ADAPTER PART NO. 1U77392-01(902) PREFIRE MEASUREMENTS
 ADAPTER SERIAL NO. 0000006 INCHES

STATION (NO.)	DEGREE LOCATION								MEDIAN	MINIMUM
	0.0	60.0	90.0	150.0	180.0	240.0	270.0	330.0		
1.0	1.083	1.054	1.002	0.912	0.959	0.996	1.001	0.982	0.999	0.912
2.0	0.976	0.997	0.997	0.997	0.997	1.005	1.007	0.997	0.997	0.976
3.0	0.977	0.978	1.006	0.992	0.994	0.978	0.988	0.978	0.983	0.977
4.0	1.007	1.067	1.035	1.015	0.997	1.026	1.035	1.026	1.026	0.997
5.0	0.388	0.399	0.394	0.409	0.390	0.399	0.395	0.380	0.395	0.380
6.0	0.530	0.512	0.493	0.477	0.473	0.497	0.502	0.524	0.500	0.473
7.0	0.697	0.665	0.659	0.641	0.628	0.657	0.672	0.694	0.662	0.628
8.0	0.564	0.551	0.545	0.523	0.535	0.537	0.546	0.561	0.546	0.523
9.0	0.426	0.435	0.422	0.432	0.425	0.423	0.424	0.431	0.426	0.422
10.0	0.397	0.388	0.384	0.395	0.380	0.391	0.396	0.402	0.393	0.380
11.0	0.540	0.540	0.540	0.540	0.540	0.540	0.540	0.540	0.540	0.540

CHAMBER PART NO. 1U75163-07(902)
 CHAMBER SERIAL NO. 0000003
 ADAPTER PART NO. 1U77547-01(903) POSTFIRE MEASUREMENTS
 ADAPTER SERIAL NO. 0000003 INCHES

STATION (NO.)	DEGREE LOCATION								MEDIAN	MINIMUM
	0.0	60.0	90.0	150.0	180.0	240.0	270.0	330.0		
1.0	0.845	0.818	0.776	0.739	0.774	0.800	0.799	0.841	0.800	0.739
2.0	0.713	0.747	0.777	0.737	0.692	0.743	0.768	0.734	0.740	0.692
3.0	0.697	0.692	0.727	0.666	0.722	0.684	0.708	0.644	0.695	0.644
4.0	0.722	0.823	0.734	0.707	0.701	0.716	0.785	0.729	0.725	0.701
5.0	0.138	0.104	0.101	0.112	0.074	0.063	0.096	0.095	0.099	0.063
6.0	0.546	0.561	0.522	0.526	0.500	0.630	0.641	0.582	0.553	0.500
7.0	0.641	0.646	0.633	0.644	0.643	0.510	0.515	0.650	0.642	0.510
8.0	0.571	0.575	0.576	0.506	0.507	0.540	0.557	0.556	0.557	0.506
9.0	0.400	0.423	0.413	0.368	0.382	0.362	0.388	0.384	0.386	0.362
10.0	0.338	0.372	0.366	0.351	0.341	0.352	0.332	0.338	0.346	0.332
11.0	0.370	0.368	0.349	0.380	0.351	0.360	0.360	0.365	0.363	0.349

Table E-XII. 360T025B Igniter Chamber and Adapter Insulation Performance

COMPLIANCE SAFETY FACTORS (CSF)

STATION (NO.)	DEGREE LOCATION								MINIMUM	PLANE
	0.0	60.0	90.0	150.0	180.0	240.0	270.0	330.0		
1.0	3.79	5.28	4.17	4.50	3.54	4.17	3.96	4.31	3.54	180.0
2.0	3.78	4.71	3.61	4.57	3.99	4.57	3.18	2.65	2.65	330.0
3.0	2.91	4.31	4.19	3.48	3.52	3.27	3.31	3.01	2.91	0.0
4.0	2.65	2.95	3.04	3.11	3.64	3.50	2.93	2.75	2.65	0.0
5.0	1.21	1.28	1.44	1.25	1.33	1.19	1.14	1.08	1.08	330.0
6.0	+	99.00	+	+	+	+	+	+	99.00	60.0
7.0	+	+	17.47	23.30	+	78.62	20.97	+	17.47	90.0
8.0	+	85.00	+	13.78	+	99.00	+	+	13.78	150.0
9.0	17.00	11.50	13.96	8.69	+	+	39.10	13.03	8.69	150.0
10.0	11.03	7.00	15.17	5.87	6.39	16.55	7.14	45.50	5.87	150.0
11.0	2.92	2.84	3.05	3.01	2.99	2.79	2.84	2.92	2.79	240.0

SF= + INDICATES THAT NEGLIGIBLE MDD OCCURRED

ACTUAL SAFETY FACTORS (ASF)

STATION (NO.)	DEGREE LOCATION								MINIMUM	PLANE
	0.0	60.0	90.0	150.0	180.0	240.0	270.0	330.0		
1.0	4.41	6.24	4.95	5.29	4.22	4.92	4.57	5.14	4.22	180.0
2.0	4.12	5.13	4.11	4.90	4.32	4.96	3.54	3.02	3.02	330.0
3.0	3.15	4.56	4.57	3.70	3.78	3.48	3.55	3.20	3.15	0.0
4.0	2.97	3.34	3.48	3.58	4.14	4.00	3.26	3.10	2.97	0.0
5.0	1.46	1.44	1.67	1.50	1.62	1.36	1.36	1.21	1.21	330.0
6.0	+	99.00	+	+	+	+	+	+	99.00	60.0
7.0	+	+	17.86	24.30	+	80.25	22.00	+	17.86	90.0
8.0	+	91.33	+	15.54	+	99.00	+	+	15.54	150.0
9.0	18.17	12.32	15.11	9.93	+	+	42.40	14.50	9.93	150.0
10.0	11.73	7.67	15.92	6.48	7.00	17.50	7.71	48.75	6.48	150.0
11.0	3.48	3.40	3.65	3.60	3.58	3.33	3.40	3.48	3.33	240.0

SF= + INDICATES THAT NEGLIGIBLE MDD OCCURRED

Table E-XII. 360T025B Igniter Chamber and Adapter Insulation Performance (cont)

STATION (NO.)	MATERIAL DECOMPOSITION DEPTH (MDD) (INCHES)								MEDIAN	MAXIMUM
	0.0	60.0	90.0	DEGREE LOCATION						
				150.0	180.0	240.0	270.0	330.0		
1.0	0.242	0.174	0.220	0.204	0.259	0.220	0.232	0.213	0.220	0.259
2.0	0.243	0.195	0.254	0.201	0.230	0.201	0.289	0.347	0.236	0.347
3.0	0.315	0.213	0.219	0.264	0.261	0.281	0.277	0.305	0.271	0.315
4.0	0.346	0.311	0.302	0.295	0.252	0.262	0.313	0.334	0.306	0.346
5.0	0.285	0.271	0.240	0.277	0.260	0.290	0.303	0.321	0.281	0.321
6.0	0.000	0.004	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.004
7.0	0.000	0.000	0.036	0.027	0.000	0.008	0.030	0.000	0.004	0.036
8.0	0.000	0.006	0.000	0.037	0.000	0.003	0.000	0.000	0.000	0.037
9.0	0.023	0.034	0.028	0.045	0.000	0.000	0.010	0.030	0.025	0.045
10.0	0.033	0.052	0.024	0.062	0.057	0.022	0.051	0.008	0.042	0.062
11.0	0.155	0.159	0.148	0.150	0.151	0.162	0.159	0.155	0.155	0.162

STATION (NO.)	MATERIAL DECOMPOSITION RATE (MDR) (MILS/SEC)								AVERAGE
	0.0	60.0	90.0	DEGREE LOCATION					
				150.0	180.0	240.0	270.0	330.0	
1.0	2.0	1.4	1.8	1.7	2.1	1.8	1.9	1.7	1.8
2.0	2.0	1.6	2.1	1.6	1.9	1.6	2.4	2.8	2.0
3.0	2.6	1.7	1.8	2.2	2.1	2.3	2.3	2.5	2.2
4.0	2.8	2.5	2.5	2.4	2.1	2.1	2.6	2.7	2.5
5.0	2.3	2.2	2.0	2.3	2.1	2.4	2.5	2.6	2.3
6.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
7.0	0.0	0.0	0.3	0.2	0.0	0.1	0.2	0.0	0.1
8.0	0.0	0.0	0.0	0.3	0.0	0.0	0.0	0.0	0.0
9.0	0.2	0.3	0.2	0.4	0.0	0.0	0.1	0.2	0.2
10.0	0.3	0.4	0.2	0.5	0.5	0.2	0.4	0.1	0.3
11.0	1.3	1.3	1.2	1.2	1.2	1.3	1.3	1.3	1.3

MOTOR ACTION (EXPOSURE) TIME = 122.30 SEC

A MDR=0 INDICATES THAT MDR < .1 MIL/SEC

Table E-XII. 360T025B Igniter Chamber and Adapter Insulation Performance (cont)

CHAMBER PART NO. 1U75163-01(903)
CHAMBER SERIAL NO. 0000068
ADAPTER PART NO. 1U77392-01(902)
ADAPTER SERIAL NO. 0000008

PREFIRE MEASUREMENTS
INCHES

STATION (NO.)	DEGREE LOCATION								MEDIAN	MINIMUM
	0.0	60.0	90.0	150.0	180.0	240.0	270.0	330.0		
1.0	1.068	1.085	1.090	1.079	1.093	1.082	1.060	1.094	1.084	1.060
2.0	1.000	1.001	1.045	0.984	0.993	0.996	1.023	1.048	1.001	0.984
3.0	0.992	0.972	1.000	0.977	0.986	0.978	0.984	0.975	0.981	0.972
4.0	1.027	1.038	1.050	1.055	1.043	1.049	1.020	1.037	1.041	1.020
5.0	0.415	0.391	0.401	0.415	0.420	0.395	0.413	0.390	0.407	0.390
6.0	0.493	0.504	0.492	0.500	0.496	0.500	0.501	0.493	0.498	0.492
7.0	0.648	0.648	0.643	0.656	0.658	0.642	0.660	0.641	0.648	0.641
8.0	0.550	0.548	0.540	0.575	0.556	0.576	0.551	0.543	0.551	0.540
9.0	0.418	0.419	0.423	0.447	0.423	0.432	0.424	0.435	0.424	0.418
10.0	0.387	0.399	0.382	0.402	0.399	0.385	0.393	0.390	0.391	0.382
11.0	0.540	0.540	0.540	0.540	0.540	0.540	0.540	0.540	0.540	0.540

CHAMBER PART NO. 1U75163-07(902)
CHAMBER SERIAL NO. 0000004
ADAPTER PART NO. 1U77457-01(903)
ADAPTER SERIAL NO. 0000004

POSTFIRE MEASUREMENTS
INCHES

STATION (NO.)	DEGREE LOCATION								MEDIAN	MINIMUM
	0.0	60.0	90.0	150.0	180.0	240.0	270.0	330.0		
1.0	0.826	0.911	0.870	0.875	0.834	0.862	0.828	0.881	0.866	0.826
2.0	0.757	0.806	0.791	0.783	0.763	0.795	0.734	0.701	0.773	0.701
3.0	0.677	0.759	0.781	0.713	0.725	0.697	0.707	0.670	0.710	0.670
4.0	0.681	0.727	0.748	0.760	0.791	0.787	0.707	0.703	0.738	0.681
5.0	0.130	0.120	0.161	0.138	0.160	0.105	0.110	0.069	0.125	0.069
6.0	0.530	0.500	0.515	0.528	0.524	0.521	0.501	0.503	0.518	0.500
7.0	0.720	0.653	0.607	0.629	0.690	0.634	0.630	0.672	0.644	0.607
8.0	0.550	0.542	0.546	0.538	0.577	0.573	0.584	0.587	0.562	0.538
9.0	0.395	0.385	0.395	0.402	0.431	0.437	0.414	0.405	0.404	0.385
10.0	0.354	0.347	0.358	0.340	0.342	0.363	0.342	0.382	0.351	0.340
11.0	0.385	0.381	0.392	0.390	0.389	0.378	0.381	0.385	0.385	0.378

