



Integrated System Health Management: Foundational Concepts, Approach, and Implementation

Fernando Figueroa
NASA Stennis Space Center, MS

September 18, 2009





Acknowledgements

The author wishes to acknowledge the NASA Innovative Partnerships Program (IPP) for supporting the development of the technologies that enable Integrated System Health Management (ISHM) capability. Special thanks to Dr. Ramona Travis, Manager of the IPP at NASA Stennis, and to John Bailey, who as Chief of the Science and Technology Division, has been instrumental in making possible development of the ISHM area.



Outline

- Motivation
- Concepts and Approaches
 - ISHM: Background/Definition
 - ISHM Model of a system
 - Detection of anomaly indicators.
 - Determination and confirmation of anomalies.
 - Diagnostic of causes and determination of effects.
 - Consistency checking cycle.
 - Management of health information
 - User Interfaces
- Implementation
- Conclusions




Support rocket engine test mission with highly reliable, accurate measurements; reduced costs; etc.

A-1




B-1/B-2

A-2



A-3



Others:

- High-pressure Gas
- Industrial Water

E-2



E-3



E-1





Requirements Driving ISHM

Through comprehensive and continuous vigilance


- Improve quality
 - By more accurately understanding the state of a system.
- Minimize costs
 - Of configuration
 - Of repair and calibration
 - Of operations
- Avoid downtime
 - By predicting impending failures
 - By timely intervention
 - By faster diagnosis and recovery
- Increase safety (protect people and assets)



ISHM Objectives

- Use available data, information, and knowledge to
 - Identify system state
 - Detect anomalies
 - Determine anomaly causes
 - Predict system impacts
 - Predict future anomalies
 - Recommend timely mitigation steps
 - Evolve to incorporate new knowledge

ISHM implementation is a problem of “management” of data, information, and knowledge (DIAK) focused on achieving the objectives of ISHM




Concepts and Approach



ISHM is Being Done Now ... But

International Space Station

Layer 1
Vehicle/
Test Stand



Rocket Engine Test Stand



Signal
threshold
violation
detection

Layer 2
Astronaut/
Test
Conductor



Added
DlaK from
on-board
users.

Layer 3
Control
Room



Added
DlaK from
broad
group of
experts.

Layer 4
Back
Control
Room



Added
DlaK
resources
from larger
community



MOVE CAPABILITY TOWARD LEVELS 2 AND 1



Data, Information, and Knowledge Management Architecture for ISHM (Information Architecture)

**Intelligent
Subsystem
Processes**

**Intelligent
Element
Processes**


**Intelligent
Sensor
Processes**


**Intelligent
System Processes**

**Intelligent
Control
Processes**


Actuator

**Intelligent
Components**






Classic architecture describing how systems are built





Correspondence between elements in the ISHM Information Architecture and processes taking place in a system





SSC Integrated System Health Management (ISHM) Capabilities



ISHM Models (Embedded Data, Information, and Knowledge):
MTTP Implementation

Anomaly Detection:
Leaks, etc.

Intelligent Sensors: IEEE Standard+Health



Health Anomaly Database:
Health Electronic Data Sheets
Repository of anomalies




MTTP

Embedding of Predictive Models

Root Cause Analysis

Integrated Awareness:
3-D Health Visualization of MTTP



John C. Stennis Space Center ISHM Partnerships for Rocket Propulsion testing


Rocket Engine Test Stand



Open Systems
Architectures



Prognostics &
Anomaly
Detection



Root Cause
Analysis




Test Article

Integrated
Awareness

IEEE 1451
Smart & Intelligent
Sensors


MOBITRUM
Brings you mobility®






Detection and Confirmation of Anomalies

Consistency Checking Cycle






MTTP Embedded DiaK






Root-Cause Tree






ISHM Enabling Technologies: Root Cause Analysis





Virtual Intelligent Sensors

- Provides benefits of ISHM capabilities to existing data acquisition systems by adding Virtual Intelligent Sensor capability.






ISHM Implementations




Generic Architecture to implement ISHM capability for systems with conventional equipment, with option to incorporate advanced smart/intelligent sensors and actuators.






Top level view of the ISHM model of the Launch Complex 20 Facility at NASA Kennedy Space Center






Sensor anomaly indicators detected by an intelligent sensor during a pump test using the LC-20 facility at NASA Kennedy Space Center






Screenshot of the ISHM model of the LC-20 facility at KSC showing detection of a valve leak created by opening the valve manually






Expanded causal-directed graph generated by the detection of a leak in the subsystem where a valve was opened manually (injected leak)




Causal directed graph dynamically generated from events detected during the simulated leak at GNCP104






Pilot ISHM Implementation Chemical Steam Generator (CSG)





Pilot ISHM Implementation Chemical Steam Generator (CSG)






Conclusions

- A sound basis to guide the community in the conception and implementation of ISHM capability in operational systems was provided.
- The concept of “ISHM Model of a System” and a related architecture defined as a unique Data, Information, and Knowledge (DlaK) architecture were described. The ISHM architecture is independent of the typical system architecture, which is based on grouping physical elements that are assembled to make up a subsystem, and subsystems combine to form systems, etc.
- It was emphasized that ISHM capability needs to be implemented first at a low functional capability level (FCL), or limited ability to detect anomalies, diagnose, determine consequences, etc. As algorithms and tools to augment or improve the FCL are identified, they should be incorporated into the system. This means that the architecture, DlaK management, and software, must be modular and standards-based, in order to enable systematic augmentation of FCL (no ad-hoc modifications).
- A set of technologies (and tools) needed to implement ISHM were described. One essential tool is a software environment to create the ISHM Model. The software environment encapsulates DlaK, and an infrastructure to focus DlaK on determining health (detect anomalies, determine causes, determine effects, and provide integrated awareness of the system to the operator). The environment includes gateways to communicate in accordance to standards, specially the IEEE 1451.1 Standard for Smart Sensors and Actuators




Backup Slides




MTTP End-to-End System

Methane Thruster Testbed Project







A1 and J2-X ISHM MODEL






Runtime Predictive Modeling





Checking for Pressure Leaks






Electronic Datasheets

- Electronic Data Sheets (EDS)
 - Transducer Electronic Data Sheets (TEDS)
 - Calibration
 - Health Electronic Data Sheet (HEDS)
 - Codified fault conditions and system phases
 - Key detection algorithms w/ parameters
 - Component EDS (CEDS)
 - Manufacturing details
 - Engineering data
 - Traceability
 - Other EDS



Intelligent Sensors

- Smart sensor
 - NCAP (Go Active, Announce)
 - Publish data
 - Set/Get TEDS
- Intelligent sensor
 - Set/Get HEDS
 - Publish health
- Detect classes of anomalies using:
 - Using statistical measures
 - Mean
 - Standard deviation
 - RMS
 - Polynomial fits
 - Derivatives (1st, 2nd)
 - Filtering—e.g., Butterworth HP
 - FFT—e.g., 64-point
 - Algorithms for
 - Flat
 - Impulsive (“spike”) noise
 - White noise
 - Other (ANN, etc.)



Intelligent Sensors have embedded ISHM functionality and support **Smart Sensor** standards