



Acoustic Directivity of the DGEN Aero-propulsion Research Turbofan at Multiple Farfield Array Locations

Dan Sutliff / LTV / GRC
AIAA Aviation Forum
26-June-2018

National Aeronautics and Space Administration
Aeronautics Research Mission Directorate
Advanced Air Vehicles Program
Advanced Air Transportation Technology Project
Aircraft Noise Reduction Technical Challenge



OUTLINE

- I) DART Overview
- II) Baseline Data
 - a) Spectral Content
 - b) Repeatability
- III) Symmetry
 - a) Circular Array
 - b) Linear Array
- IV) Conclusion



I) DART Overview

DGEN380 Turbofan Engine

2 spool, geared fan (3.32 ratio), unmixed, separate flow exhaust

Centrifugal compressor, LP turbine (43,000 rpm), HP turbine (52,000 rpm)

14 inch diameter fan, 14 fan blades (13,000 rpm)

Thrust 560 lbf, 7.6 BPR, 1.2 FPR, 5.3 OPR, 28.7 lb/s


Inlet mass flow, V_{tip} = 785 fps subsonic tip speed

GEARED-DOWN FAN

Wide cord blades
casted fan



14 blades



Epicyclical Gearbox with
rafters

Ratio: 3.32



Low component count/easy disassembly
Drawings Available



Background


April 2017 DART entry at “ANCF” location provided installation checkouts and baseline acoustic/performance data.

A 2nd entry occurred to accomplish several goals:

- 1) Operate DART in center location (relocated cabling/fuel, etc)
- 2) Evaluate an existing noise reduction technology.
Limited time frame & need experience (walk before run)
 - a. MDOF liner (NIT/GFIT/ANCF/9x15 – *flight test?*)
 - b. Inlet (limits potential of attenuation – validate predictions)
- 3) **Evaluate symmetry of acoustic directivity and add linear array in preparation for potential 9x15/14x22 WT entries.**
- 4) **Compare fixed arrays (10ft arc, 88" linear) to overhead array (impact of PBS farfield).**
- 5) Develop work flow for incorporating DART standard acoustic data into DADS.
- 6) Obtain limited performance op line information.
- 7) Establish research/operational procedures and polices.

Testing occurred in Apr, Aug 2017

DART in AAPL



Farfield Acoustic Directivity Evaluation - Background

Desire to install DART in 9x15 / 14x22 Wind Tunnel

- Pylon would be on traverse side (acoustic measurement)
- Sideline vs Circular Array (azimuthal angle)

GOAL: Show acquiring data on pylon side is acoustically acceptable

Define & Determine Farfield (ideally PBS outdoor arena to “complete”)

- Acoustic farfield (based on wavelength – complex projection)
- Geometric farfield based on engine length (simple projection)

Overhead/Close-In Array comparisons and projection methodology

- OA little more into the geometric farfield but azimuthal angle variations!
- CA provides more diagnostic/research information (inlet/exhaust separation)
 - less attenuation (R,T,H, etc) & space/availability
- Geometric farfield arrays – point source EPNL calculation (not research)

GOAL: utilize CA advantages but develop methodology for projecting to farfield or determining when acquiring data in geometric farfield is required

Configurations Tested August-2017

PART II (arrays)

DATE	DGEN Config	Location	ARRAY	OTHER	THRUST
28-Apr-17	Baseline Inlet	ANCF	10ft arc - LHS	---	ON
4-Aug-17	Baseline Inlet	Near Center	10ft arc - LHS	Overhead Array	ON
7-Aug-17	Baseline Inlet	Near Center	10ft arc - LHS	Overhead Array	Locked Out
8-Aug-17	Baseline Inlet	Near Center	10ft arc - RHS	Overhead Array	Locked Out
10-Aug-17	Baseline Inlet	Near Center	Linear Array- RHS	Overhead Array	Locked Out
11-Aug-17	Baseline Inlet	Near Center	Linear Array- LHS	Overhead Array	Locked Out

STND FADEC Sweep:
30 sec

*safety restrictions limit max
achievable speed with temp
Lesson learned!


Point	RPMc(%)
1	idle
2	50.0%
3	60.0%
4	70.0%
5	80.0%
6	90.0%
7	92.5%
8	95.6%*
9	50.0%
10	95.6%*
11	idle

DATA Acquisition:
200 kHz @ 15 sec
BW Filter 50Hz – 50kHz






- II) Baseline Data
 - a) Spectral Content
 - b) Repeatability

Forward Mic Array Spectral Summation @ 92.5% RPMc-Fan




Aft Mic Array Spectral Summation @ 92.5% RPMc-Fan









10-ft Arc Array Dimensions



Tone/BB
separation
(Sree)



Baselines Comparison

92.5% RPMc

OASPL : 100 Hz to 40kHz

L1 – ANCF location

L2 – Near Center




STD – standard inlet length

EXT – Extended inlet length

ON – Pylon free

OFF – Pylon locked

- STD-L1 (ON)
- STD-L1 (ON)
- STD-L2 (ON)
- STD-L2 (OFF)
- EXT-L2 (OFF)



Baselines Comparison

92.5% RPMc

OASPL : 1 kHz to 10 kHz

L1 – ANCF location

L2 – Near Center




STD – standard inlet length

EXT – Extended inlet length

ON – Pylon free


OFF – Pylon locked

- STD-L1 (ON)
- STD-L1 (ON)
- STD-L2 (ON)
- STD-L2 (OFF)
- EXT-L2 (OFF)



Baselines Summary Comparison

92.5% RPMc



L1 – ANCF location

L2 – Near Center

STD – standard inlet length

EXT – Extended inlet length


ON – Pylon free

OFF – Pylon locked



OASPL : 1 kHz to 10 kHz

NO CORRECTIONS APPLIED!



Fundamental and Harmonic Tones Directivity Isolation





F1




C1



F2




L1





(F1,F2,F3,F4,C1,C2,L1,H1)



Interaction Tones Directivity Isolation





C1-F1



C1-F2



C1+F1



C1+F2


(C1+/- F1, C1+/- F2, C2+/- F1)




- III) Symmetry
 - a) Circular Array
 - b) Linear Array



10-ft Arc Array Dimensions




Tone/BB
separation
(Sree)




Total

Tonal




Symmetry Comparison

Left Hand Side (LHS)



Right Hand Side (RHS)






Symmetry Comparison

LHS




RHS



NO CORRECTIONS APPLIED!

(88" traverse in 9x15 WT)

Linear Array



Mic	Inches
1	0
2	8.97
3	17.94
4	26.91
5	35.88
6	44.85
7	53.82
8	62.79
9	71.76
10	80.73
11	89.7
12	98.67
13	107.64
14	116.61
15	125.58
16	134.55
17	143.52
18	152.49
19	161.46
20	170.43
21	179.4
22	188.37
23	197.34
24	206.31
25	215.28
26	224.25
27	233.22
28	242.19
29	251.16
30	260.13




Symmetry Comparison

92.5% RPMc

OASPL :
100 Hz to 40kHz

LHS

RHS



NO CORRECTIONS APPLIED! (Including R)



IV) Conclusion



Acoustic Directivity of the DGEN Aero-propulsion Research Turbofan at Multiple Farfield Array Locations


Acoustic Data Acquired from DART

- Repeatability is typical
- Symmetry is acceptable

Companion Paper Comparisons to Overhead Array @
Location #2 – projection to a common distance.

Part of an Proposed Effort to Compare & Define Geometric/
Acoustic Farfield

- Wind Tunnel?
- Outdoor Facility?



QUESTIONS?

Thanks to:

Price Induction, SA & TFOME Staff @ AAPL