



Hot Water, Cold Reality: Feasibility Assessment of Iodine Removal in Heated Spacecraft Potable Water Systems

ICES-2026-192

Mary Lou Nadeau, *Aerodyne Industries (JETS II), Johnson Space Center*

Rogelio Garcia Fernandez, *Amentum Technology Inc. (JETS II), Johnson Space Center*


Jaione Romero Mangado, *Amentum Technology Inc. (JETS II), Johnson Space Center*

Michael Callahan, *NASA Johnson Space Center*

55th International Conference on Environmental Systems, July 14th, 2026

Trade names and trademarks are used in this report for identification only. Their usage does not constitute an official endorsement, either expressed or implied, by the National Aeronautics and Space Administration.






Agenda




- 1. Introduction**
- 2. Background**
- 3. Strategy**
- 4. Challenges of Iodine Removal from Hot Water**
- 5. Path to a Solution**
- 6. Preliminary Trade Study**
- 7. Conclusions and Plan Forward**

- **ISS Potable Water Dispenser (PWD) and Exploration PWD (xPWD) use biocidal iodine for protection against microbial growth in the potable lines**
 - Iodine is not safe for crew consumption at its biocidal levels, so it must be removed before dispensed.
 - Current (x)PWD design removes iodine before the heater, leaving wetted segments without biocide




- **This segment without biocide is a concern for microbial growth to NESC, especially coming in and out of dormancy**
 - Exploration missions → dormant periods
 - ISS (x)PWD have not been proven for success during dormancy

- **In 2021, the NASA Engineering and Safety Center (NESC) published a report aimed at identifying and prioritizing biocide solutions for future missions to ensure robust microbial control coming in and out of dormancy**
 - NESC proposed 33 options, including iodine, silver, chlorine, and bromine-based biocide solutions.
- **The top-ranked architecture was iodine as a biocide, with a design change to the PWD to achieve iodine removal at or closer to needle**
 - NESC also indicated that the current removal media may perform less effectively in hot water than at ambient temperatures



- **The aim of this study is to investigate the feasibility of removing iodine from heated spacecraft potable water systems**

State of the Art: Activated Carbon and Ion Exchange (ACTEX)



Activated Carbon

- Adsorbs the molecular iodine (I_2)


Ion Exchange Resin

- Removes the ionic species

Together, reduce $I_2 + I^-$ from 6 mg/L to <0.2 mg/L

Spacecraft Potable Water Requirements

Parameter	Requirement	Reference
Dispense volumes	25 to >500 mL in 25 mL increments	ISS PWD
	25 to 250 mL in 25 mL increments	NASA-STD-3001
Hot dispense temperature	155°F to 175°F	NASA-STD-3001
	150 to 200 °F	ISS PWD
Nominal dispense temperature	64°F to 81°F	NASA-STD-3001
Hot water volume	600 mL per meal per crewmember available as Hot Water	NASA-STD-3001
Remove Iodine	Iodine <0.2 mg/L before crew consumption	Human Integration Design Handbook (HIDH), ISS PWD
Microbial Control	≤50 CFU/mL bacteria, no detectable coliforms	ISS PWD



Investigate: Can the State of the Art (SOA) ACTEX be used downstream of the heater as-is?


Anticipating challenges, simultaneously identify:

- Potential alternative media
- Potential system-level configuration changes support either:
 - A) Existing ACTEX
 - B) More efficient or thermally robust media





Challenges of Removing Iodine from Hot Water

- Temperature Effect on Removal Media
- Bubbles
- Delivery Temperature



Temperature Effect on State-of-the-Art Materials

Temperature Effect on Speciation of 5 mg/L Iodine in Water




	Activated Carbon	Ion Exchange Resin
<i>Thermal degradation of material properties</i>	Not anticipated	Not recommended for use for temperature > 60 °C (140 °F) Bulk material degradation
<i>Capacity change at hot temperature</i>	Likely	Potential due to hydrolysis of functional groups
<i>Iodine speciation</i>	Decreased [I₂] at hot temperature	Increased [I⁻] at hot temperature

- Dissolved gas in the potable water bus could evolve bubbles at the heater as O_2 solubility decreases



Downstream component impacts:

- **ACTEX**
 - Concern for reduced contact time of I_2 stream with removal media
 - Potential for clogging depending on how tightly packed the ACTEX is
- **New potential I_2 removal media**
 - Material-dependent. Same concerns as ACTEX
- **UV Filter (xPWD baseline)**
 - No adverse effects expected
- **Microbial filter (ISS PWD, potential alternate for xPWD)**
 - Pore blockage, potential for complete loss of flow

O_2 Solubility in Water, Partial Pressure of O_2 = 0.2 atm



- Heat losses** due to mixing with unheated water in wetted downstream components







Path to a Solution

What can we test/model to determine feasibility?

- Iodine Equilibrium Capacity Testing
- Thermally Robust Media
- Bubbles
- Delivery Temperature



Iodine equilibrium capacity testing:





- **Variables:**

16


- ### Higher pressure drop


- 18





Preliminary Trade Study








Key	Favorable Condition	More Info. Needed to Determine Favorability	Unfavorable Condition
-----	---------------------	---	-----------------------



Key	Favorable Condition	More Info. Needed to Determine Favorability	Unfavorable Condition
-----	---------------------	---	-----------------------



Key	Favorable Condition	More Info. Needed to Determine Favorability	Unfavorable Condition
-----	---------------------	---	-----------------------



Config.	Built-In Mass	Bubbles to ACTEX
X	Adds GLS + piping	Includes bubble mitigation

- *Iodine losses could occur through the GLS due to its high volatility*
- *Iodine compatibility with GLS materials?*

- | Config. | Description | Non-iodinated
Volume During
Ops | Ambient
Dispense
Temp | Hot
Dispense
Temp | Power
Demand | Built-In
Mass | Consumable
Mass | Bubbles
to ACTEX |
|---------|---|---------------------------------------|-----------------------------|-------------------------|-----------------|------------------|--------------------|---------------------|
| 0 | NESC Proposed
Config | | | | | | | |
| 1 | Separate Lines | | | | | | | |
| 2 | Separate Lines +
Heating Wrap | | | | | | | |
| 3B | Recirculation +
Re-iodination | | | | | | | |
| 4 | Separate Lines +
Recirculation + Re-
iodination | | | | | | | |

Key	Favorable Condition	More Info. Needed to Determine Favorability	Unfavorable Condition
-----	---------------------	---	-----------------------

- | Config. | Description | Non-iodinated
Volume During
Ops | Ambient
Dispense
Temp | Hot
Dispense
Temp | Power
Demand | Built-In
Mass | Consumable
Mass | Bubbles
to ACTEX |
|---------|---|---------------------------------------|-----------------------------|-------------------------|-----------------|------------------|--------------------|---------------------|
| 0 | NESC Proposed
Config | | | | | | | |
| 1 | Separate Lines | | | | | | | |
| 2 | Separate Lines +
Heating Wrap | | | | | | | |
| 3B | Recirculation +
Re-iodination | | | | | | | |
| 4 | Separate Lines +
Recirculation + Re-
iodination | | | | | | | |
- Re-circulation requires pumps and either adds volume without biocide or requires adding iodine only to remove it again
 - Future work will include testing the performance of the baseline configuration and potentially configurations 1 and 2

-

Conclusions and Proposed Plan Forward

- **Summary**

- We are actively characterizing performance of state of the art + newly identified materials in heated water
- Moving ACTEX to needle → likely need to modify PWD configuration even with highly efficient material

- **Plan forward:**


- Sharpen the pencil on bed size constraint for thermal effects downstream of the heater: how small does it really need to be?
 - Assess wetted volume (packed bed void fraction vs. pressure drop), transient thermal effects, and (x)PWD insulation
- Trade different architectural solutions
 - Is additional heating required? Would separate hot vs. ambient beds be required?
 - Determine placement of UV filter
- Testing to inform decision on degassing requirement




Questions?

Mary Lou Nadeau

Mary.L.Nadeau@nasa.gov




Backup




Preliminary Trade Study – *No Hot I₂ Removal*

Solutions that do not require iodine removal from hot water were identified:


- Point-of-use tankless heater



- Remove ACTEX and replace with jumper before dormancy



Preliminary Trade Study – No Hot I₂ Removal



Alt. Config. 5: Detachable Point of Use Tankless Heater


- This concept would need significant development / does not have current analog on station
 - Could be turned on or off depending on dispense temperature preference
 - Could be a consumable that is replaced between missions
 - Could potentially be cleaned more easily by crew during the missions themselves
 - Increased risk of contamination due to increased crew handling.

Config.	Non-iodinated Volume During Ops	Ambient Dispense Temp	Hot Dispense Temp	Power Demand	Built-In Mass	Consumable Mass	Bubbles to ACTEX
5	Minimizes non-iodinated vol. inside PWD, but increased handling may be problematic	Should meet req.	Should meet req.	Especially high peak power*	Reduces built-in mass	Does heater need to be replaced after dormancy?	Heater is downstream of ACTEX

*Preliminary research indicates that the peak power draw for induction tankless heaters < conduction tankless heaters

Key	Favorable Condition	More Info. Needed to Determine Favorability	Unfavorable Condition
------------	---------------------	---	-----------------------

Preliminary Trade Study – No Hot I_2 Removal



Alt. Config. 6: xPWD Config. + Jumper

- Does not address NESC's concern of leaving downstream lines without biocide during non-dormancy
 - Possible that biofilm forms downstream of the iodine filter during crewed ops.
- Shocking the system with a high concentration of biocide before going dormant may mitigate biofilm

Config.	Non-iodinated Volume During Ops	Ambient Dispense Temp	Hot Dispense Temp	Power Demand	Built-In Mass	Consumable Mass	Bubbles to ACTEX
6	Does not minimize	Should meet req.	Should meet req.	None	No extra	May require extra biocide shock between dormancy periods	Does not need any bubble mitigation

Key	Favorable Condition	More Info. Needed to Determine Favorability	Unfavorable Condition

Preliminary Trade Study – *No Hot I₂ Removal*

Config.	Description	Requires Hot I ₂ Removal	Non-iodinated Volume During Ops	Ambient Dispense Temp	Hot Dispense Temp	Power Demand	Built-In Mass	Consumable Mass	Bubbles to ACTEX
5	Point of Use Tankless Heater	N							
6	Keep xPWD design, remove ACTEX before dormancy	N							
N/A	NESC Option 2: Replaceable End Leg	N							

Key

Favorable Condition

More Info. Needed to Determine Favorability

Unfavorable Condition