

# MODIS Radiometric Calibration and Uncertainty Assessment

Xiaoxiong (Jack) Xiong<sup>1</sup>, Vincent Chiang<sup>2</sup>, Junqiang Sun<sup>2</sup>, and Aisheng Wu<sup>2</sup>

<sup>1</sup>*Sciences and Exploration Directorate, NASA/GSFC, Greenbelt, MD 20771, USA*

<sup>2</sup>*Sigma Space Co., 4801 Forbes Boulevard, Lanham, MD 20706, USA*

## ABSTRACT

Since launch, Terra and Aqua MODIS have collected more than 11 and 9 years of datasets for comprehensive studies of the Earth's land, ocean, and atmospheric properties. MODIS observations are made in 36 spectral bands: 20 reflective solar bands (RSB) and 16 thermal emissive bands (TEB). Compared to its heritage sensors, MODIS was developed with very stringent calibration and uncertainty requirements. As a result, MODIS was designed and built with a set of state of the art on-board calibrators (OBC), which allow key sensor performance parameters and on-orbit calibration coefficients to be monitored and updated if necessary. In terms of its calibration traceability, MODIS RSB calibration is reflectance based using an on-board solar diffuser (SD) and the TEB calibration is radiance based using an on-board blackbody (BB). In addition to on-orbit calibration coefficients derived from its OBC, calibration parameters determined from sensor pre-launch calibration and characterization are used in both the RSB and TEB calibration and retrieval algorithms. This paper provides a brief description of MODIS calibration methodologies and discusses details of its on-orbit calibration uncertainties. It assesses uncertainty contributions from individual components and differences between Terra and Aqua MODIS due to their design characteristics and on-orbit performance. Also discussed in this paper is the use of MODIS L1B uncertainty index (UI) product.

**Keywords:** Terra, Aqua, MODIS, calibration, uncertainty